

FirstEnergy – MetEd – 2026
Submission of Supplemental Projects for
Inclusion in the Local Plan

Met-Ed Transmission Zone M-3 Process Round Top Substation

Need Number: ME-2023-020

Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan

Previously Presented: Solution Meeting – 8/14/2025
Needs Meeting – 11/16/2023

Project Driver:

Operational Flexibility and Efficiency


Specific Assumption Reference:

System Performance Projects

- Add/Expand Bus Configuration
- Load at risk in planning and operational scenarios
- Reduce the amount of exposed potential local load loss during contingency conditions
- Eliminate simultaneous outages to multiple networked elements

Problem Statement:

Round Top Substation can be outaged from a fault on the 115 kV bus, a fault on the No. 1 or No. 2 115-13.2 kV transformers, or a stuck breaker on the Allen, Newberry, or Dillsburg 115 kV line exits. Round Top Substation serves 2,540 customers and approximately 18.8 MW.



Need Number: ME-2023-020

Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan


Selected Solution:

- Construct an eight-breaker breaker-and-a-half switchyard for the 115 kV bus at Roundtop Substation.
 - Install new 115 kV circuit breakers, associated disconnect switches and relaying at Roundtop Substation.
 - Replace one 115 kV capacitor bank and associated circuit breaker at Roundtop Substation.
 - Revise relay settings at Gardners, Cly, and Allen substations.

Estimated Project Cost: \$22.1M

Projected In-Service: 6/2/2028

Supplemental Project ID: s3733.1



Legend	
500 kV	—
345 kV	—
230 kV	—
138 kV	—
115 kV	—
69 kV	—
46 kV	—
34.5 kV	—
23 kV	—
New	—

Need Number: ME-2023-025

Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan

Previously Presented: Solution Meeting – 08/05/2025
Need Meeting – 12/05/2023

Project Driver:

Operational Flexibility and Efficiency

Specific Assumption Reference:


System Performance Projects

- Add/Expand Bus Configuration
- Load at risk in planning and operational scenarios
- Reduce the amount of exposed potential local load loss during contingency conditions
- Eliminate simultaneous outages to multiple networked elements

Problem Statement:

South Reading Substation contains two 230 – 69 kV transformers. Upon the N-1-1 loss of both transformers, there is low voltage seen on the surrounding 69 kV network.

Met-Ed Transmission Zone M-3 Process South Reading Substation



Need Number: ME-2023-025

Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan

Selected Solution:

At South Reading Substation:

- Install a new No. 9 230-69 kV 224 MVA transformer
- Install a new 69 kV grounding transformer
- Install two new 230 kV circuit breakers and associated switches
- Install one new 69 kV circuit breaker and associated switches
- Install new relaying


Transformer Ratings:

- Before Proposed Solution: N/A
- After Proposed Solution: 328 / 400 / 371 / 474 MVA (SN/SSTE/WN/WSTE)

Estimated Project Cost: \$20.4M

Projected In-Service: 11/15/2027

Supplemental Project ID: s3742.1



Legend	
500 kV	—
345 kV	—
230 kV	—
138 kV	—
115 kV	—
69 kV	—
46 kV	—
34.5 kV	—
23 kV	—
New	—

Need Number: ME-2024-008

Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan

Previously Presented: Solution Meeting - 8/14/2025
Need Meeting - 5/16/2024

Project Driver:

Equipment Material Condition, Performance and Risk

Specific Assumption Reference:

System Performance Global Factors

- System reliability/performance
- Substation/Line equipment limits
- Line Condition Rebuild/Replacement
- Age/condition of wood pole transmission line structures

Problem Statement:

The Carlisle Pike – Gardners 115 kV 976 Line was constructed approximately 69 years ago. The original poles were replaced in 1970. The conductor is original to the 1955 construction. The Met-Ed portion of this line is approximately 13.03 miles long with 96 wood H-frame transmission line structures.


The Met-Ed portion of this line is exhibiting deterioration. Inspection findings include:

- Six structures are Phase-Raised.
- 26 structures failed sound test.
- 39 structures are 54 years old.

There have been three unscheduled sustained outages in the last five years, two attributed to line equipment.

The line is limited by terminal equipment.

- Existing Transmission Line Ratings:
 - 86 / 110 / 122 / 137 MVA (SN/SE/WN/WE)



Need Number: ME-2024-008

Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan

Selected Solution:

Carlisle Pike-Gardners 115 kV 976 Line Rebuild

- Rebuild 13.0 miles of transmission line with new conductor
- At Gardners Substation, replace circuit breaker, disconnect switches, and wave trap

Transmission Line Ratings:

Carlisle Pike – Gardners 115 kV 976 Line

- Before Proposed Solution: 86 / 110 / 122 / 137 MVA (SN/SE/WN/WE)
- After Proposed Solution: 232 / 282 / 263 / 334 MVA (SN/SE/WN/WE)

Estimated Project Cost: \$32.35M

Projected In-Service: 12/21/2029

Supplemental Project ID: s3743.1



Carlisle Pike

Gardners

Legend	
500 kV	Red
345 kV	Blue
230 kV	Black
138 kV	Yellow
115 kV	Green
69 kV	Teal
46 kV	Light Green
34.5 kV	Red
23 kV	Red
New	Purple

Revision History

01/05/2026 – V1

s3733

s3742

s3743