

**FirstEnergy – Penelec – 2026**  
**Submission of Supplemental Projects for**  
**Inclusion in the Local Plan**

**Need Number:** PN-2024-017

**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Previously Presented:** Solution Meeting - 8/14/2025  
Need Meeting - 5/16/2024

**Project Driver:**

*Equipment Material Condition, Performance and Risk*

**Specific Assumption Reference:**

System Performance Global Factors

- System reliability/performance
- Substation/Line equipment limits

Line Condition Rebuild/Replacement

- Age/condition of wood pole transmission line structures

**Problem Statement:**

The Carlisle Pike – Gardners 115 kV 976 Line was constructed approximately 69 years ago. The original poles were replaced in 1970. The conductor is original to the 1955 construction. The Penelec portion of this line is approximately 7.55 miles long with 71 wood H-frame transmission line structures.


The Penelec portion of this line is exhibiting deterioration. Inspection findings include:

- 16 structures are Phase-Raised.
- 18 structures failed sound test.
- 54 structures are 54 years old.

There have been three unscheduled sustained outages in the last five years, two attributed to line equipment.

The line is limited by terminal equipment.

- Existing Transmission Line Ratings:
  - 86 / 110 / 122 / 137 MVA (SN/SE/WN/WE)



**Need Number:** PN-2024-017

**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

## Selected Solution:

Carlisle Pike-Gardners 115 kV 976 Line Rebuild

- Rebuild 7.55 miles of transmission with new conductor

## Transmission Line Ratings:

Carlisle Pike – Gardners 115 kV 976 Line

- Before Proposed Solution: 86 / 110 / 122 / 137 MVA (SN/SE/WN/WE)
- After Proposed Solution: 232 / 282 / 263 / 334 MVA (SN/SE/WN/WE)

**Estimated Project Cost:** \$20.5M

**Projected In-Service:** 12/21/2029

Supplemental Project ID: s3743.2



Legend	
500 kV	
345 kV	
230 kV	
138 kV	
115 kV	
69 kV	
46 kV	
34.5 kV	
23 kV	
New	

## Penelec Transmission Zone M-3 Process Warrior Ridge - Huntingdon - Owens Corning 46 kV Lines

**Need Number:** PN-2025-003

**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Previously Presented:** Solution Meeting 8/14/2025  
Need Meeting 06/12/2025

**Project Driver:** Equipment Condition/Performance/Risk

**Specific Assumption References:**

Line Condition Rebuild/Replacement

Age/condition of wood pole transmission line structures


**Problem Statement:**

The Owens Corning (Huntingdon) 46 kV OC Line was constructed approximately 70 years ago and is approaching end of life. The radial line is 0.39 miles in length and serves 3 substations.

Per recent inspection, safety concerns were identified in seven spans as this circuit passes above and adjacent to several buildings.

**Existing Transmission Line Ratings:**

- 24 / 24 / 26 / 26 MVA (SN/SE/WN/WE)



# Penelec Transmission Zone M-3 Process

## Warrior Ridge - Huntingdon - Owens Corning 46 kV Lines

**Need Number:** PN-2025-003

**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Selected Solution:**

- Remove the existing back up feed and tap switches to Owens Corning
- Install four new 46 kV switches
- Rebuild the line from the new tap to Owens Corning No. 1 (~0.09 miles)
- Rebuild the Huntingdon – Owens Corning No. 3 46 kV line (~0.3 miles)
- Build a new line from Owens Corning No. 3 to the Huntingdon-Warrior Ridge 46 kV Line (~0.2 miles) and operate as normally open

**Transmission Line Ratings:**

**Huntingdon – Owen Tap 46 kV Line:**

- After Proposed Solution: 50 / 50 / 50 / 50 MVA (SN/SE/WN/WE)

**Owen Tap – WRH Tap 46 kV Line:**

- After Proposed Solution: 93 / 113 / 105 / 134 MVA (SN/SE/WN/WE)

**Huntingdon – Owen Corning No. 1 46 kV Line:**

- After Proposed Solution: 93 / 113 / 105 / 134 MVA (SN/SE/WN/WE)

**Owen Corning No. 1 – Owen Corning No. 2 and No. 3 46 kV Line:**

- After Proposed Solution: 93 / 113 / 105 / 134 MVA (SN/SE/WN/WE)

**Owen Corning No. 2 and No. 3 – Warrior Ridge 46 kV Line:**


- After Proposed Solution: 93 / 113 / 105 / 134 MVA (SN/SE/WN/WE)

**Estimated Project Cost:** \$5.1M

**Projected In-Service:** 3/26/2026

**Supplemental Project ID:** s3744.1

Warrior Ridge



Legend	
500 kV	Red line
345 kV	Blue line
230 kV	Black line
138 kV	Orange line
115 kV	Green line
69 kV	Dark Green line
46 kV	Light Green line
34.5 kV	Red line
23 kV	Orange line
New	Purple line

## Penelec Transmission Zone M-3 Process Edinboro South Substation

**Need Number:** PN-2023-006

**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Previously Presented:** Solution Meeting – 09/18/2025  
Need Meeting – 07/20/2023

**Project Driver:**

*Operational Flexibility and Efficiency*

**Specific Assumption Reference:**

Add/Expand Bus Configuration

- Eliminate simultaneous outages to multiple network elements

System Performance Projects

- Substation/line equipment limits

System Performance Projects Global Factors

- Load and/or customers at risk on single transmission line

System Conversion Methodology

- Customer feedback

**Problem Statement:**

- Edinboro South Substation serves approximately 43 MW of load to 4,044 customers. A fault on the Erie South - Edinboro South 115 kV Line results in interruption of service to the No. 1 115-34.5 kV transformer with limited network transfer capability during peak conditions.
- The Erie South - Edinboro South 115 kV Line is approximately 16.9 miles long. Over the past five years, the Erie South - Edinboro South 115 kV Line has experienced two sustained outages.
- Edinboro South – Morgan Street – Springboro 115 kV Line has experienced a total of ten outages and there are five sustained outages over the past five years.



**Need Number:** PN-2023-006

**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Selected Solution:**


- Convert the Edinboro South Substation into a four-breaker ring bus.
- Adjust relay settings at Erie South and Morgan Street substations.

**Estimated Project Cost:** \$13.57M

**Projected In-Service:** 6/18/2027

**Supplemental Project ID:** s3745.1

Erie South



Edinboro South

Venango Jct

Morgan Street

Legend	
500 kV	—
345 kV	—
230 kV	—
138 kV	—
115 kV	—
69 kV	—
46 kV	—
34.5 kV	—
23 kV	—
New	—

**Need Number:** PN-2023-008  
**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan  
**Previously Presented:** Solution Meeting – 09/18/2025  
 Need Meeting – 08/17/2023

**Project Driver:**  
*Operational Flexibility and Efficiency*

**Specific Assumption Reference:**

Add/Expand Bus Configuration

- Eliminate simultaneous outages to multiple network elements

System Performance Projects


- Substation/line equipment limits

System Performance Projects Global Factors

- Load and/or customers at risk

**Problem Statement:**

- Morgan Street Substation serves 7,100 customers and 67 MW of load in the Meadville, Pennsylvania area.
- The current substation configuration of Morgan Street Substation is a straight bus with a bus tie breaker. In the event of a tie breaker failure, the entire Morgan Street Substation 115 kV bus is interrupted.
- In addition to a tie breaker failure at Morgan Street Substation, the consequential N-1-1 loss of the Geneva – Morgan Street 115 kV Line and the Edinboro South – Morgan Street – Springboro 115 kV Line eliminates the 115 kV source to the 34.5 kV system fed from Morgan Street Substation.



**Need Number:** PN-2023-008

**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Selected Solution:**

- Convert the Morgan Street Substation into a nine-breaker, breaker-and-a-half substation.
- Adjust relay settings at Geneva and Edinboro South substations.

**Transmission Line Ratings:**

Morgan Street - Venango Jct 115 kV Line:

- Before Proposed Solution: 147 / 191 / 201 / 201 MVA (SN/SE/WN/WE)
- After Proposed Solution: 232 / 282 / 263 / 334 MVA (SN/SE/WN/WE)

**Estimated Project Cost:** \$26.91M

**Projected In-Service:** 12/3/2027

**Supplemental Project ID:** s3746.1


Edinboro South



Venango Jct



Morgan Street



Geneva

Legend	
500 kV	—
345 kV	—
230 kV	—
138 kV	—
115 kV	—
69 kV	—
46 kV	—
34.5 kV	—
23 kV	—
New	—

## Penelec Transmission Zone M-3 Process Spangler Substation

**Need Number:** PN-2024-003

**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Previously Presented:** Solution Meeting – 09/18/2025  
Need Meeting – 03/14/2024

**Project Driver:**

*Operational Flexibility and Efficiency*

*Equipment Material Condition, Performance, and Risk*

**Specific Assumption Reference:**

System Performance Projects Global Factors


- System reliability and performance
- Substation and line equipment limits

**System Performance**

- Criticality, impact on reliability, customer outages
- Reliability of non-bulk electric system (Non-BES) Facilities
- Load at risk and customers impacted

**Problem Statement:**

- Spangler Substation is currently configured as a 46 kV straight bus where bus faults and/or breaker failures result in the interruption of the entire substation.
- Spangler Substation serves approximately 27 MW of load and 2,600 customers.
- The existing Spangler No. 2 115-46 kV Transformer is 48 years old. The transformer has required corrective maintenance for moisture due to leaks, consists of obsolete parts not supported by the OEM, and is limited by terminal equipment.
- Existing Ratings
  - 34 / 44 / 49 / 55 (SN/SE/WN/WE)



**Need Number:** PN-2024-003

**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Selected Solution:**

At Spangler:

- Convert the 46 kV yard into a five-breaker ring bus.
- Replace No. 2 115/46 kV transformer and install high side circuit breaker.

At Garman:

- Replace line relaying and substation conductor

At Carrolltown and Nanty Glo substations:

- Adjust remote end relaying

**Transmission Line Ratings:**

Spangler – St. Benedict 46 kV Line:

- Before Proposed Solution: 33 / 38 / 40 / 44 MVA (SN/SE/WN/WE)
- After Proposed Solution: 36 / 43 / 40 / 51 MVA (SN/SE/WN/WE)

Spangler No. 2 115/46 kV Transformer:

- Before Proposed Solution: 34 / 44 / 49 / 55 MVA (SN/SLTE/WN/WLTE)
- After Proposed Solution: 58 / 70 / 71 / 81 MVA (SN/SE/WN/WE)

Spangler – Garman 115 kV Line:


- Before Proposed Solution: 120 / 120 / 120 / 120 MVA (SN/SE/WN/WE)
- After Proposed Solution: 232 / 282 / 263 / 334 MVA (SN/SE/WN/WE)

**Estimated Project Cost:** \$14.2M

**Projected In-Service:** 7/12/2027

**Supplemental Project ID:** s3747.1

Legend	
500 kV	—
345 kV	—
230 kV	—
138 kV	—
115 kV	—
69 kV	—
46 kV	—
34.5 kV	—
23 kV	—
New	—



# Revision History

01/05/2026 – V1

s3743

s3744

s3745

s3746

s3747