



# SRRTEP - Western Committee ComEd Supplemental Projects

March 14, 2025

# Needs

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** ComEd-2025-004

**Process Stage:** Need Meeting 3/14/2025

**Project Driver:**


Customer Service

**Specific Assumption Reference:**

- New transmission customer interconnections or modification to an existing customer

**Problem Statement:**

An existing customer is looking for expansion of their transmission service in the Chicago area. Initial load increase is expected to be 40 MW in June 2026, 52 MW in 2029, with an ultimate load increase of 52 MW.



# Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** ComEd-2025-003

**Process Stage:** Solution Meeting 3/14/2025

**Previously Presented:** Need Meeting 2/14/2025

**Project Driver:**

Operational Flexibility and Efficiency


Equipment Material Condition, Performance and Risk

**Specific Assumption Reference:**

- Enhancing system functionality, flexibility, visibility, or operability
- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions

**Problem Statement:**

- Devon 138 kV is currently served by seven 138 kV lines, supplying four 138-12 kV distribution transformers. There are 138 kV line breakers on lines L8803 (Devon-Skokie), L11415 (Northwest-Rosehill-Devon), L8809 (Devon-Skokie), L11414 (Northwest-Rosehill-Devon), and L11411 (Northwest-Devon). 138 kV L11416 (Northwest-Devon) has a line circuit switcher. 138 kV L11416 (Devon-Skokie) has a line motor operated disconnect. 138 kV L8810 (Devon-Skokie) has a line disconnect.
- 138 kV oil circuit breakers for L11414 and L11415 were installed in 1953 and the L8810-L11411 oil circuit breaker was installed in 1962 at Devon substation. They are in deteriorating condition, lack replacement parts, and have elevated maintenance costs.



**Need Number:** ComEd-2025-003

**Process Stage:** Solution Meeting 3/14/2025

**Proposed Solution:**

- Replace three 138KV Oil Circuit Breakers for 138KV lines L11415 (Northwest-Rosehill-Devon), L11414 (Northwest-Rosehill-Devon), L11411 (Northwest-Devon).
  - Existing rating 1200A, 40kA; 1600A, 40 kA
  - Proposed rating 3000A, 63kA
- Install 138 kV 3000A SF6 line circuit breakers on 138 kV lines L11416 (Northwest-Devon) , L11416 (Devon-Skokie), and L8810 (Devon-Skokie).
- Install 138 kV, 3000A SF6 circuit breakers on high side of 138-12kV transformers 73 and 74.

**Estimated cost:** \$ 18.9 M


**Alternatives Considered:**

No feasible alternatives available

**Projected In-Service:** 12/31/2026

**Project Status:** Engineering

**Model:** 2029 RTEP



# Appendix

# High Level M-3 Meeting Schedule

## Assumptions

Activity	Timing
Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
Stakeholder comments	10 days after Assumptions Meeting

## Needs

Activity	Timing
TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
Stakeholder comments	10 days after Needs Meeting

## Solutions

Activity	Timing
TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
Stakeholder comments	10 days after Solutions Meeting

## Submission of Supplemental Projects & Local Plan

Activity	Timing
Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
Post selected solution(s)	Following completion of DNH analysis
Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions



# Revision History

3/4/2025 – V1 – Original version posted to pjm.com