

# Subregional RTEP Committee – Western FirstEnergy Supplemental Projects

September 19, 2025

# Needs

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** ATSI-2025-023

**Process Stage:** Need Meeting – 9/19/2025

**Supplemental Project Driver(s):**

*Equipment Material Condition, Performance and Risk  
Infrastructure Resilience*

**Specific Assumption Reference(s):**

System Performance Global Factors

- System Reliability and Performance
- Load at risk in planning and operational scenarios
- Age/condition of transmission line conductors and hardware
- Increase line loading limits


**Problem Statement:**

- The Harper – West Akron 138 kV Line is approximately 10 miles in length with mixed conductor types. The line serves approximately 71 MW and 2,800 customers. The line contains vintage 1920's conductor and hardware.
- Since 2022 there have been two sustained 138 kV line outages.
- Based on a 2024 Series 2029 RTEP Summer Case with the Perry generator offline followed by a loss of two 345 kV lines, the line approaches 100% of its summer emergency rating.

Existing Line Ratings: 143/146/161/161 MVA (SN/SE/WN/WE)

**Model:** 2024 Series 2029 Summer RTEP 50/50

## ATSI Transmission Zone M-3 Process Harper – West Akron 138 kV Line



**Need Number:** ATSI-2025-025  
**Process Stage:** Need Meeting – 09/19/2025

**Supplemental Project Driver(s):**  
*Customer Services*

### Specific Assumption Reference(s):

- New customer connection request will be evaluated based on FirstEnergy's "Requirements for Transmission Connected Facilities" document and FirstEnergy's "Transmission Planning Criteria" document

### Problem Statement

- New Customer Connection – A customer requested a new 138 kV delivery point near the Carlisle – Johnson 138 kV Line. The anticipated load of the new customer connection is 12 MVA. The request is 1.3 miles from the Carlisle – Johnson 138 kV Line.

**Model:** 2023 Series 2028 Summer RTEP 50/50



# Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** ATSI-2023-011  
**Process Stage:** Solutions Meeting – 09/19/2025  
**Previously Presented:** Need Meeting – 6/16/2023

## Supplemental Project Driver(s):

*Operational Flexibility and Efficiency*

*Equipment Material Condition, Performance and Risk*

*Infrastructure Resilience*

## Specific Assumption Reference(s):


Global Considerations

- System reliability and performance
- Load at risk in planning and operational scenarios

Add/Expand Bus Configuration

- Loss of substation bus adversely impacts transmission system performance
- Eliminate simultaneous outages to multiple networked elements under N-1 analysis
- Accommodate future transmission facilities
- Capability to perform system maintenance

*Continued on next slide...*






**Need Number:** ATSI-2023-011  
**Process Stage:** Solutions Meeting – 09/19/2025  
**Previously Presented:** Need Meeting – 6/16/2023

## Problem Statement:

- An N-1-1 outage will result in approximately 29,100 customers at risk and cause a consequential load loss of approximately 119 MW.
- An N-1-1 outage will result in approximately 9,360 customers at risk and cause a consequential load loss of approximately 38 MW and cause a backfeed condition from the Akron 23 kV system.
- Since 2014, the following lines have a combined total of seven momentary outages and six sustained outages:
  - Star - Urban 138 kV Line experienced three outages: 1 momentary. 2 sustained
  - Star - Wadsworth 138 kV Line experienced two outages: 1 momentary. 1 sustained
  - Pine - West Akron 138 kV Line experienced one outage: 0 momentary. 1 sustained
  - Star – Tusc 138 kV Line experienced no outages
  - Firestone - South Akron 138 kV Line experienced one outage: 0 momentary, 1 sustained
  - Firestone - Urban 138 kV Line experienced six outages: 5 momentary, 1 sustained





## ATSI Transmission Zone M-3 Process Tusc Substation

**Need Number:** ATSI-2023-011  
**Process Stage:** Solutions Meeting – 09/19/2025

### Proposed Solution:

- Expand the existing 138 kV bus at Tusc Substation from a four-breaker ring bus into a six-breaker ring bus.
- Loop the Pine-Wadsworth 138 kV Line in/out of the Tusc Substation ring bus
- The project will split the Pine-Wadsworth 138 kV Line to create the following two lines:
  - Tusc - Wadsworth 138 kV Line (~8 miles)
  - Pine - Tusc 138 kV Line (~7 miles)
- Adjust relays at the terminal ends.


### Alternatives Considered:

- Maintain existing condition with risk of consequential load loss under contingency scenarios.

**Estimated Project Cost:** \$16.72M

**Projected IS Date:** 12/31/2027

**Status:** Conceptual



Legend	
500 kV	
345 kV	
138 kV	
69 kV	
34.5 kV	
23 kV	
New	



**Need Number:** ATSI-2025-021  
**Process Stage:** Need Meeting – 07/18/2025  
 Need Represent Meeting – 9/19/2025

**Project Driver(s):**

*Operational Flexibility and Efficiency*  
*Equipment Performance and Risk*  
*Infrastructure Resilience*

**Specific Assumption Reference(s):**


System Performance Global Factors

- Load at risk in planning and operational scenarios
- Substation/line equipment limits
- Add/Expand Bus Configuration
- Loss of substation bus adversely impacts transmission system performance
- Eliminate simultaneous outages to multiple networked elements under N-1 analysis
- Capability to perform system maintenance

**Problem Statement:**

- Firestone Substation's 138 kV bus is a partial ring bus configuration with three breakers and two normally open switches.
  - With the current configuration, breaker maintenance on the transformer tie circuit breaker will interrupt the network path on the South Akron – Urban 138 kV Line. This interruption of the South Akron-Urban 138 kV Line results in a single ten-mile-long radial feed to Urban Substation.
- A failure of the bus tie circuit breaker will result in an outage of the entire 138 kV bus and substation, including two distribution transformers. This contingency impacts an industrial customer and results in a total load loss of 7 MVA
- This contingency also interrupts the South Akron-Urban 138 kV Line resulting in a single ten-mile long radial feed to Urban Substation.

## ATSI Transmission Zone M-3 Process Firestone Substation





## ATSI Transmission Zone M-3 Process Firestone Substation

**Need Number:** ATSI-2025-021  
**Process Stage:** Solutions Meeting – 09/19/2025

**Proposed Solution:**

- Convert the Firestone three-breaker ring bus into a four-breaker ring bus by installing an additional circuit breaker to the existing substation layout.


**Alternatives Considered:**

- Other options for reconfiguring the substation top reduce operational constraints was considered. However, this option was deemed infeasible due to the real estate constraints.

**Estimated Project Cost:** \$0.3M

**Projected IS Date:** 2/16/2026

**Status:** Conceptual



Legend	
500 kV	
345 kV	
138 kV	
69 kV	
34.5 kV	
23 kV	
New	

# Appendix

# High Level M-3 Meeting Schedule

## Assumptions

Activity	Timing
Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
Stakeholder comments	10 days after Assumptions Meeting

## Needs

Activity	Timing
TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
Stakeholder comments	10 days after Needs Meeting

## Solutions

Activity	Timing
TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
Stakeholder comments	10 days after Solutions Meeting

## Submission of Supplemental Projects & Local Plan

Activity	Timing
Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
Post selected solution(s)	Following completion of DNH analysis
Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

# Revision History

9/08/2025– V1 – Original version posted to pjm.com