

Subregional RTEP Committee – Western FirstEnergy Supplemental Projects APS Transmission Zone

January 16, 2026

Needs

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

Need Number: APS-2026-001
Process Stage: Need Meeting 01/16/2026
Project Driver:
 Operational Flexibility and Efficiency

Specific Assumption Reference:


System Performance Projects

- Add/Expand Bus Configuration
- Load at risk in planning and operational scenarios
- Reduce the amount of exposed potential local load loss during contingency conditions
- Eliminate simultaneous outages to multiple networked elements

Problem Statement:

Smithton Substation is currently configured as a 138 kV straight bus with a feed from the Charleroi - Mitchell - Yukon 138 kV Line (Shepler Hill Jct) and the Allenport - Iron Bridge - Yukon 138 kV Line (Layton Jct). Smithton Substation also serves two distribution transformers, totaling approximately 4,300 customers and 10 MW of load.

There is a normally open 138 kV bus tie that cannot be closed when the Shepler Hill Jct 138 kV Line is energized, as it does not have the ability to clear certain fault scenarios. Therefore, each distribution transformer at Smithton Substation is served radially and requires Operational switching to restore customers upon loss of 138 kV source.



Need Number: APS-2026-002

Process Stage: Need Meeting 01/16/2026

Project Driver:

Equipment Condition/Performance/Risk

Specific Assumption Reference:

System Performance Projects Global Factors

- System reliability and performance
- Substation/line equipment limits

Upgrade Relay Schemes

- Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
- Communication technology upgrades

Problem Statement:

FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation. Proper operation of the protection scheme requires all the separate components perform adequately during a fault. In many cases the protection equipment cannot be repaired due to a lack of replacement parts and available expertise in the outdated technology.


Transmission line ratings are limited by terminal equipment.

Goff Run - Grantsville 138 kV Line:

- Existing Line Rating: 195 / 209 / 217 / 229 MVA (SN/SE/WN/SE)
- Existing Conductor Rating: 221 / 268 / 250 / 317 MVA (SN/SE/WN/SE)

Grantsville - Glenville 138 kV Line:

- Existing Line Rating: 195 / 209 / 217 / 229 MVA (SN/SE/WN/SE)
- Existing Conductor Rating: 221 / 268 / 250 / 317 MVA (SN/SE/WN/SE)



Need Number: APS-2026-003
Process Stage: Need Meeting 01/16/2026
Project Driver:
Customer Service


Specific Assumption Reference:

New or existing customer connection requests will be evaluated per FirstEnergy's "Requirements for Transmission Connected Facilities" document and "Transmission Planning Criteria" document.

Problem Statement:

Existing Customer Connection - A customer located near the existing Joffre Substation requested an increase of load at the existing 138 kV delivery point. The anticipated load increase is 79 MVA for a total load of 99 MVA.

The requested in-service date is 05/27/2027.



Need Number: APS-2026-004
Process Stage: Need Meeting 01/16/2026
Project Driver:
Customer Service


Specific Assumption Reference:

New customer connection requests will be evaluated per FirstEnergy's "Requirements for Transmission Connected Facilities" document and "Transmission Planning Criteria" document.

Problem Statement:

New Customer Connection - A customer located near the existing Bredinville - McCalmont 138 kV Line requested a new 138 kV delivery point. The anticipated load of the new customer connection is 80 MW.

Anticipated in-service date is 3/15/2028.



Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

Need Number: APS-2025-016
Process Stage: Solution Meeting - 01/16/2026
Previously Presented: Need Meeting - 05/16/2025
Project Driver:

Equipment Condition/Performance/Risk

Specific Assumption Reference:

System Performance Global Factors


- System reliability/performance
- Substation/Line equipment limits
- Line Condition Rebuild/Replacement

Problem Statement:

- Line Switch 1007 on the Loughs Lane - Pickens 138 kV Line at Durbin Tap is obsolete and underrated.
- The Transmission Line ratings are limited by the switch.

Beverly Tap - Durbin Tap 138 kV Branch

- Existing Line Ratings: 164 / 206 / 216 / 248 MVA (SN/SE/WN/WE)
- Existing Conductor Ratings: 169 / 213 / 217 / 280 MVA (SN/SE/WN/WE)



Need Number: APS-2025-016
Process Stage: Solution Meeting - 01/16/2026

Proposed Solution:

Loughs Lane - Pickens 138 kV Line switch 1007

- Replace the Line Switch 1007 on the Loughs Lane - Pickens 138 kV Line at the Durbin Tap.


Beverly Tap - Durbin Tap 138 kV Line

- Before Proposed Solution: 164 / 206 / 216 / 248 MVA (SN/SE/WN/WE)
- After Proposed Solution: 169 / 213 / 217 / 280 MVA (SN/SE/WN/WE)

Alternatives Considered:

Maintain equipment in existing condition with elevated risk of switch failure.

Estimated Project Cost: \$1.05M
Projected In-Service: 12/31/2026
Project Status: Conceptual
Model: 2024 RTEP model for 2029 Summer & Winter (50/50)



Need Number: APS-2025-074
Process Stage: Solution Meeting - 01/16/2026
Previously Presented: Need Meeting - 08/16/2024
Project Driver:
Equipment Condition/Performance/Risk

Specific Assumption Reference:


System Performance Global Factors

- System reliability/performance
- Substation/Line equipment limits Line Condition Rebuild/Replacement
- Age/condition of wood transmission line structures

Problem Statement:

- The Weston – Glenville 138 kV Line was constructed approximately 44 years ago. It is approximately 31 miles long with 30 miles of wood pole structures and one mile of steel transmission line structures.
- The line has experienced six unplanned sustained outages over the last five years. Four outages related to failure of polymer insulators on the line.
- Per recent inspections, 124 of 130 wood pole structures utilize the polymer insulators related to recent failures.

Continued on next slide...




Need Number: APS-2025-074
Process Stage: Solution Meeting - 01/16/2026

Problem Statement:

Transmission Line / Substation Locations

- Glenville – Sand Fork Tap 138 kV Line
 - Existing Line Rating: 195 / 209 / 217 / 229 MVA (SN/SE/WN/WE)
 - Existing Conductor Rating: 221 / 268 / 250 / 317 MVA (SN/SE/WN/WE)
- Sand Fork Tap – Weston 138 kV Line
 - Existing Line Rating: 221 / 268 / 250 / 317 MVA (SN/SE/WN/WE)
 - Existing Conductor Rating: 221 / 268 / 250 / 317 MVA (SN/SE/WN/WE)



Need Number: APS-2025-074

Process Stage: Solution Meeting - 01/16/2026

Proposed Solution:

- Rebuild approximately 30.2 miles of Glenville - Weston 138 kV Line using steel structures and install new conductor.
- Replace one double circuit steel lattice structure #94-A with steel monopole structure.

At Glenville Substation:

- Replace line trap, substation conductor, and revise relay settings.

At Weston Substation:

- Replace substation conductor and revise relay settings.

Glenville - Sand Fork Tap 138 kV Line Ratings:

- Before Proposed Solution: 195 / 209 / 217 / 229 MVA (SN/SE/WN/WE)
- After Proposed Solution: 278 / 339 / 315 / 401 MVA (SN/SE/WN/WE)

Sand Fork Tap - Weston 138 kV Line Ratings:

- Before Proposed Solution: 221 / 268 / 250 / 317 MVA (SN/SE/WN/WE)
- After Proposed Solution: 278 / 339 / 315 / 401 MVA (SN/SE/WN/WE)

Alternatives Considered:


Maintain the line in existing condition with elevated risk of failure due polymer insulators.

Estimated Project Cost: \$89.52M

Projected In-Service: 12/15/2030

Project Status: Conceptual

Model: 2024 RTEP model for 2029 Summer & Winter (50/50)



Legend	
500 kV	
345 kV	
230 kV	
138 kV	
115 kV	
69 kV	
46 kV	
34.5 kV	
23 kV	
New	

Appendix

High level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

Revision History

01/06/2026– V1 – Original version posted to pjm.com