



# SRRTEP - Western Committee ComEd Supplemental Projects

March 19, 2026

# Needs

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** ComEd-2026-003

**Process Stage:** Need Meeting 3/19/2026

**Project Driver:**


Equipment Material Condition, Performance, and Risk

**Specific Assumption Reference:**

- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions
- Programmatic review and/or replacement of breakers, relays, wood poles, cables, etc.

**Problem Statement:**

Sabrooke 138kV oil circuit breakers L17113 and BT1-3 were installed in 1969 and 1976 respectively. They are in deteriorating condition, have a lack of replacement parts and have elevated maintenance costs.



**Need Number:** ComEd-2026-004

**Process Stage:** Need Meeting 3/19/2026

**Project Driver:**


Equipment Material Condition, Performance, and Risk

**Specific Assumption Reference:**

- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions
- Programmatic review and/or replacement of breakers, relays, wood poles, cables, etc.

**Problem Statement:**

Rockwell 138kV oil circuit breaker BT3-4 was installed in 1973. It is in deteriorating condition, has a lack of replacement parts and has elevated maintenance costs.



# Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** ComEd-2026-002

**Process Stage:** Solution meeting 3/19/2026

**Previously Presented:** Need Meeting 2/13/2026

**Project Driver:**


Operational Flexibility and Efficiency, Infrastructure Resilience

**Specific Assumption Reference:**

- Enhancing system functionality, flexibility, visibility, or operability

**Problem Statement:**

- Belvidere is currently a Straight Bus Substation with six 138KV Lines, two bus-tie breakers, two 138KV/34KV and two 138KV/12KV distribution transformers. A failure of any circuit breaker results in an outage of half of the station.
- Lack of 138KV Red-Blue bus-tie results in operational concerns during line outage scenarios due to lack of sources.



**Need Number:** ComEd-2026-002

**Process Stage:** Solution Meeting 3/19/2026

**Proposed Solution:**

- Replace 138kV open air straight bus with GIS in a breaker and half configuration (23 Circuit Breakers) at Belvidere

**Estimated Transmission cost:** \$131.8M

**Alternatives Considered:**


Replace existing 138kV open air straight bus with 138kV air insulated substation in a breaker and a half configuration (23 Circuit Breakers)

- This alternative was not pursued due to real estate constraints.

**Projected In-Service:** 12/31/2028

**Project Status:** Conceptual

**Model:** 2029 RTEP



# Appendix

# High Level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

# Revision History

3/9/2026 – V1 – Original version posted to pjm.com