

Submission of Supplemental Projects for Inclusion in the Local Plan

Need Numbers: APS-2024-057, APS-2024-058

Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan – 3/7/2025

Previously Presented: Solution Meeting 08/06/2024
Need Meeting 06/04/2024

Project Driver:

Equipment Material Condition, Performance and Risk

Specific Assumption Reference:

System Performance Projects Global Factors

- System reliability and performance
- Substation/line equipment limits

System Condition Projects

- Substation Condition Rebuild/Replacement


Upgrade Relay Schemes

- Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
- Communication technology upgrades

Problem Statement:

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault.
- In many cases the protection equipment cannot be repaired due to a lack of replacement parts and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.

Continued on next slide...



| Need # | Transmission Line / Substation Locations | Existing Line Rating MVA (SN / SE / WN /WE) | Existing Conductor Rating MVA (SN / SE / WN / WE) |
|--------------|--|---|--|
| APS-2024-057 | Doubs – Frostown Junction 230 kV Line | 617 / 698 / 699 / 762 | 617 / 754 / 699 / 894 |
| | Frostown Junction – Ringgold 230 kV Line | 324 / 349 / 361 / 381 | 617 / 754 / 699 / 894 |
| APS-2024-058 | Lime Kiln – Montgomery 230 kV Line | 548 / 688 / 699 / 804 | 617 / 754 / 699 / 894 |

Selected Solution:

| Need # | Transmission Line / Substation Locations | New MVA Line Rating (SN / SE / WN / WE) | Scope of Work | Supplemental ID | Estimated Cost (\$ M) | Target ISD |
|--------------|--|---|--|-----------------|-----------------------|------------|
| APS-2024-057 | Doubs – Frostown Junction 230 kV Line | 617 / 754 / 699 / 894 | • At Doubs, replace line trap, substation conductor and relaying | s3540.1 | \$6.30 | 12/31/2026 |
| | Frostown Junction – Ringgold 230 kV Line | 617 / 754 / 699 / 894 | • At Ringgold, replace line trap, disconnect switches, substation conductor and relaying | | | |
| APS-2024-058 | Lime Kiln – Montgomery 230 kV Line | 617 / 754 / 699 / 894 | <ul style="list-style-type: none"> • At Lime Kiln, replace CVT on bus, substation conductor and relaying • At Montgomery, replace CVT on bus, disconnect switches, substation conductor and relaying | s3541.1 | \$9.20 | 10/31/2026 |

Need Number: APS-2020-003
Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan – 3/7/2025
Previously Presented: Solution Meeting – 08/16/2024
 Need Meeting – 04/16/2020

Project Driver:
*Equipment Material Condition, Performance and Risk
 Operational Flexibility and Efficiency*

Specific Assumption Reference:

System Performance Projects Global Factors

- System reliability and performance
- Substation/line equipment limits


System Condition Projects

- Substation Condition Rebuild/Replacement

Upgrade Relay Schemes

- Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
- Communication technology upgrades

Continued on next slide...



Problem Statement:

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault.
- In many cases the protection equipment cannot be repaired due to a lack of replacement parts and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.

| Need # | Transmission Line / Substation Locations | Existing Line Rating MVA (SN/SE/WN/WE) | Existing Conductor Rating MVA (SN/SE/WN/WE) |
|-----------------------------|--|---|--|
| APS-2020-003 PN-2020-004 | Burma – Piney 115 kV Line | 221 / 262 / 263 / 286 | 232 / 282 / 263 / 334 |



APS Transmission Zone M-3 Process Misoperation Relay Project

Selected Solution:

| Need # | Transmission Line / Substation Locations | New MVA Line Rating (SN/SE/WN/WE) | Scope of Work | Supplemental ID | Estimated Cost (\$ M) | Target ISD |
|-----------------------------|--|-----------------------------------|---|-----------------|-----------------------|------------|
| APS-2020-003 PN-2020-004 | Burma – Piney 115 kV Line | 232 / 282 / 263 / 334 | <ul style="list-style-type: none">At Burma, replace line trap, substation conductor and relays. | s3542.1 | \$1.9 | 10/31/2025 |

APS Transmission Zone M-3 Process Monocacy No. 4 230/138 kV Transformer

Need Number: APS-2024-061
Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan – 4/7/2025
Previously Presented: Solution Meeting – 11/06/2024
 Need Meeting – 06/04/2024

Project Driver:

Equipment Material Condition, Performance and Risk

Specific Assumption Reference:

System Performance Projects Global Factors


- System reliability and performance

Add/Replace Transformers

Past System Reliability/Performance

Problem Statement:

- The Monocacy No. 4 230/138 kV Transformer is approximately 51 years old and is approaching end of life.
- The transformer has experienced an increase in the level of acetylene.
- The transformer relaying is obsolete.
- Existing transformer ratings:
 - 260 / 338 MVA (SN / SSTE)
 - 313 / 368 MVA (WN / WSTE)



APS Transmission Zone M-3 Process Monocacy No. 4 230/138 kV Transformer

Need Number: APS-2024-061
Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan 3/28/2025 – 4/7/2025

Selected Solution:

- At Monocacy Substation:
 - Replace No. 4 230/138 kV 224 MVA Transformer with a new 266 MVA unit
 - Replace transformer conductor, circuit breakers, disconnect switches and relaying

Anticipated Transformer Circuit Ratings:

- Monocacy No. 4 230/138 kV Transformer:
 - Before Proposed Solution: 260 / 338 / 313 / 368 MVA (SN/SSTE/WN/WSTE)
 - After Proposed Solution: 266 / 346 / 320 / 377 MVA (SN/SSTE/WN/WSTE)

Estimated Project Cost: \$9.00 M










Projected In-Service: 12/31/2027

Supplemental Number: s3573.1

Monocacy 138 kV



Monocacy 230 kV

| Legend | |
|---------|---|
| 500 kV |  |
| 345 kV |  |
| 230 kV |  |
| 138 kV |  |
| 115 kV |  |
| 69 kV |  |
| 46 kV |  |
| 34.5 kV |  |
| 23 kV |  |
| New | |

APS Transmission Zone M-3 Process Pruntytown No. 3 500/138 kV Transformer

Need Number: APS-2024-071
Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan - 4/7/2025
Previously Presented: Solution Meeting 01/07/2025
 Need Meeting 08/06/2024

Project Driver:

Equipment Material Condition, Performance and Risk

Specific Assumption Reference:

System Performance Projects Global Factors

- System reliability and performance


Add/Replace Transformers

Past System Reliability/Performance

Problem Statement:

- The Pruntytown No. 3 500/138 kV Transformer is approximately 48 years old and is approaching end of life.
- The transformer has experienced an increase in moisture content.
- The transformer parts and relaying are obsolete.
- The transformer and relaying equipment cannot be repaired due to a lack of replacement parts and available expertise in the outdated technology.
- Existing transformer ratings:
 - 430 / 552 MVA (SN / SSTE)
 - 505 / 585 MVA (WN / WSTE)

Continued on next slide...



Copyright(c) 2014 Esri

APS Transmission Zone M-3 Process Pruntytown No. 3 500/138 kV Transformer

Need Number: APS-2024-071
Process Stage: Submission of Supplemental Projects for Inclusion
in the Local Plan – 4/7/2025

Selected Solution:

- At Pruntytown Substation:
 - Replace the existing 500/138 kV Transformer No. 3
 - Replace transformer conductor, circuit breakers, disconnect switches and relaying

Anticipated Transformer Circuit Ratings:

- 500/138 kV Transformer No. 3 :
 - Before Proposed Solution: 430 / 552 / 505 / 585 MVA (SN / SSTE / WN / WSTE)
 - After Proposed Solution (anticipated): 448 / 582 / 527 / 618 MVA (SN / SSTE / WN / WSTE)

Estimated Project Cost: \$15.77 M










Projected In-Service: 6/30/2029

Supplemental Number: s3574.1

Pruntytown 138 kV



Pruntytown 500 kV

| Legend | |
|---------|---|
| 500 kV |  |
| 345 kV |  |
| 230 kV |  |
| 138 kV |  |
| 115 kV |  |
| 69 kV |  |
| 46 kV |  |
| 34.5 kV |  |
| 23 kV |  |
| New | |

Need Number: APS-2023-022

Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan – 4/7/2025

Previously Presented: Solution Meeting – 11/15/2024
Need Meeting – 07/21/2023

Project Driver:
Operational Flexibility and Efficiency


Specific Assumption Reference:

- System reliability and performance
- Load at risk in planning and operational scenarios
- Add/Expand Bus Configuration
- Upgrade Relay Schemes

Problem Statement:

- The Stony Springs Junction (Harrison City - Hempfield – Luxor) 138 kV Line is a three terminal line that provides direct service to over 25,000 customers and provides a transmission network path.
- The multi-terminal line creates difficulties for protective relaying.
- The tap stations on the line lack switches and SCADA.
- Terminals stations are equipped with antiquated relaying schemes and equipment that limits the use of the full capacity of the transmission line conductor.
- There is ~25 MW of load served directly from the line. Additionally, the line has 25 miles of exposure.

Continued on next slide...




| Need # | Transmission Line / Substation Locations | Existing Line Rating MVA (SN / SE / WN / WE) | Existing Conductor Rating MVA (SN / SE / WN / WE) |
|--------------|--|---|--|
| APS-2023-022 | Harrison City – Penn 138 kV Line | 242 / 297 / 310 / 351 | 308 / 376 / 349 / 445 |
| | Penn – North Oakford Tap 138 kV Line | 296 / 302 / 332 / 332 | 296 / 302 / 332 / 332 |
| | North Oakford Tap – South Oakford Tap 138 kV Line | 296 / 302 / 332 / 332 | 296 / 302 / 332 / 332 |
| | North Oakford Tap – Delmont 138 kV Line | 221 / 268 / 250 / 317 | 221 / 268 / 250 / 317 |
| | South Oakford Tap – Stony Springs Junction 138 kV Line | 296 / 302 / 332 / 322 | 296 / 302 / 332 / 322 |
| | Stony Springs Junction – North Greensburg 138 kV Line | 308 / 376 / 349 / 445 | 308 / 376 / 349 / 445 |
| | North Greensburg – Hempfield 138 kV Line | 294 / 350 / 349 / 401 | 308 / 376 / 349 / 445 |
| | Stony Springs Junction – Luxor 138 kV Line | 296 / 302 / 332 / 332 | 296 / 302 / 332 / 332 |

Selected Solution:

| Need # | Transmission Line / Substation Locations | New MVA Line Rating (SN / SE / WN / WE) | Scope of Work | Estimated Cost (\$M) | Target ISD |
|--------------|--|---|--|----------------------|------------|
| APS-2023-022 | Harrison City – Penn 138 kV Line | 308 / 376 / 349 / 445 | <ul style="list-style-type: none"> At Harrison City Substation: Replace bus and line side breaker risers. At Penn Substation: Install one line breaker and one bus tie breaker. | \$13.6 | 6/22/2027 |
| | Penn – North Oakford Tap 138 kV Line | 296 / 302 / 332 / 332 | <ul style="list-style-type: none"> At North Oakford Tap: Install new disconnect switches equipped with auto-sectionalizing. | | |
| | North Oakford Tap – South Oakford Tap 138 kV Line | 296 / 302 / 322 / 332 | <ul style="list-style-type: none"> At South Oakford Tap: Install three switches with SCADA. | | |
| | North Oakford – Delmont 138 kV Line | 221 / 268 / 250 / 317 | <ul style="list-style-type: none"> At North Oakford Substation: Install full SCADA control on the existing switch. At Delmont Substation: Install full SCADA control on the existing switch. | | |
| | South Oakford Tap – Stony Springs Junction 138 kV Line | 296 / 302 / 332 / 322 | <ul style="list-style-type: none"> At Stony Springs Junction: Install a three-breaker ring bus and associated relaying. | | |
| | Stony Springs Junction – North Greensburg 138 kV Line | 308 / 376 / 349 / 445 | <ul style="list-style-type: none"> At North Greensburg Substation: Replace circuit breaker. | | |
| | North Greensburg – Hempfield 138 kV Line | 308 / 376 / 349 / 445 | <ul style="list-style-type: none"> At Hempfield: Replace line circuit breaker, disconnect switches and associated relaying. | | |
| | Stony Springs Junction – Luxor 138 kV Line | 296 / 302 / 332 / 367 | <ul style="list-style-type: none"> At Luxor Substation: Replace circuit breaker, substation conductor, breaker risers on both sides of breaker and relaying. | | |

Selected Solution:



Estimated Project Cost: \$13.6M

Projected In-Service: 6/22/2027

Supplemental Number: s3575.1

| Legend | |
|---------|--|
| 500 kV | |
| 345 kV | |
| 230 kV | |
| 138 kV | |
| 115 kV | |
| 69 kV | |
| 46 kV | |
| 34.5 kV | |
| 23 kV | |
| New | |

Need Number: APS-2023-029 (s3150.1, s3150.2)

Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan - 4/7/2025

Previously Presented: Re-Present Solutions Meeting – 01/07/2025
Solution Meeting – 02/06/2024
Need Meeting – 7/11/2023

Project Driver(s):

Customer Service


Specific Assumption Reference(s):

New customer connection request will be evaluated per FirstEnergy's "Requirements for Transmission Connected Facilities" document and "Transmission Planning Criteria" document.

Problem Statement:

New Customer Connection- A customer has requested 230 kV transmission service for approximately 300 MW of load near the Doubs-Sage #206 230 kV Line.

Requested In-Service Date: May 15, 2025





APS Transmission Zone M-3 Process New Customer

Need Number: APS-2023-029 (s3150.1, s3150.2)

Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan – 4/7/2025


Selected Solution:

- Build a six breaker, three bay (expandable to four bays), breaker-and-a-half substation (Quantum 400)
- Loop the Doubs – Lime Kiln #231 230 kV Line in and out of the new substation
- Modify line relay settings at Doubs and Lime Kiln substations
- Provide two feeds to the customer facility

Estimated Project Cost: \$23.2M

Projected In-Service: 12/31/2025

Supplemental Number: s3150.1, s3150.2



| Legend | |
|---------|--|
| 500 kV | |
| 230 kV | |
| 138 kV | |
| 69 kV | |
| 34.5 kV | |
| 23 kV | |
| New | |



APS Transmission Zone M-3 Process
New Customer

Need Number: APS-2023-029


Process Stage: Submission of Supplemental Projects for Inclusion in the Local Plan – 4/7/2025

- Selected Solution:**
230 kV Transmission Substation (Quantum 400)
- Expand Quantum 400 station to a ten breaker, breaker-and-a-half substation
 - Loop the Doubs – Sage #206 230 kV Line in and out of the new substation
 - Modify line relay settings at Doubs and Sage substations

Estimated Project Cost: \$8M

Projected In-Service: 12/31/2027

Supplemental Number: s3150.1, s3150.2



| Legend | |
|---------|--|
| 500 kV | |
| 230 kV | |
| 138 kV | |
| 69 kV | |
| 34.5 kV | |
| 23 kV | |
| New | |



Revision History

3/7/2025 – V1 – Original Slides posted.

4/7/2025 – V2- s3573.1 ,s3574.1, s3575.1 ,s3150.1 (represent) & s3150.2 (represent)