


Reliability Analysis Update

Stan Sliwa, Senior Lead Engineer
PJM Transmission Planning

Transmission Expansion Advisory
Committee
April 1, 2025

2025 RTEP Window 1 Update

2025 RTEP Window 1 – Timeline



Scope Change & Cost Updates Baseline Reliability Projects

Dominion Transmission Zone: Baseline

New Mars – Lockridge – Golden 230kV Lines

New Mars – Golden 500kV Line

Scope change for B3800.210 – B3800.212 (230kV Line Mars – Lockridge – Golden & 500kV Line Mars – Golden)

Part of the recommended solution for 2022 Window 3 (2022-W3-692) is to construct a new 230kV line from Mars – Lockridge – Golden and a new 500kV line from Mars – Golden.

Original Solution:


- Build a new 230kV line approximately 5.2 miles from Mars - Lockridge on 500/230kV double circuit structures to achieve a summer rating of 1573 MVA. Install 230kV equipment at Mars and Lockridge substations. **(B3800.210) \$57.95M**
- Build a new 230kV line approximately 2.9 miles from Lockridge - Golden on 500/230kV double circuit structures to achieve a summer rating of 1573 MVA. Install 230kV equipment at Golden and Lockridge substations. **(B3800.211) \$56.93M**
- Build a new 500kV line approximately 8.3 miles from Mars substation to Golden substation on 500/230kV double circuit structures to achieve a summer normal rating of 4357 MVA. Install 500kV equipment at Golden and Mars substations. **(B3800.212) \$228.04M**

Transmission Estimated Cost: \$342.92M

Required in-service date: 6/1/2027

Projected in-service date: 6/1/2027

Previously Presented: 12/5/2023




B3800.210 – B3800.212 part of solution 2022-W3-692

Dominion Transmission Zone: Baseline

New Mars – Lockridge – Golden 230kV Lines

New Mars – Golden 500kV Line



Transmission Arrangement for area surrounding Mars before addition of Golden-Mars 5-2 project (after completion of Wishing Star – Mars project)

Dominion Transmission Zone: Baseline

New Mars – Lockridge – Golden 230kV Lines


New Mars – Golden 500kV Line

Revised Solution:

- Remove 230kV line #2095 Mars - Shellhorn and 230kV line #2292 Mars – Sojourner in the existing transmission corridor between Sojourner and Mars substations so that they can be re-routed to the south side of Mars substation, adding approximately 2 miles of new conductor. This is to allow for termination of the 5-2 Golden – Mars circuits into Mars substation.
- Cut 230kV line #2095 Mars – Shellhorn into Sojourner substation, creating 230kV line #2427 (Mars - Sojourner) and 230kV line #2095 (Sojourner - Shellhorn).
- Upgrade 4 230kV breakers at Sojourner substation from 63kA to 80kA

Reason for Scope Change & Cost Update:

- The new Golden – Mars 230kV & 500kV lines will intersect with the existing transmission corridor containing the 230kV lines Mars-Shellhorn Line #2095, Mars-Sojourner Line #2292, Celestial-Mars Line #2161, and Cabin Run-Mars Line #2287 just east of the Old Ox/Carters School Road Intersection. Spatial and FAA constraints along these existing lines would prevent installation of the Golden – Mars lines along any of the alternative routes.
- Cost increase due to additional 2 miles of transmission line and real estate required to reroute line #2095 Mars – Shellhorn & line #2292 Mars – Sojourner.



Transmission Arrangement for area surrounding Mars with proposed changes

Additional Cost Estimate: \$97M (B3800.210 \$49M + B3800.212 \$48M)

Total Proposed Cost Estimate: \$439.92M



Process Stage: Cost Update

Criteria: Short Circuit

Assumption Reference: 2024 RTEP assumptions

Model Used for Analysis: 2029 RTEP Short Circuit base case + PJM selected solution

Proposal Window Exclusion: None

Problem Statement:

In the 2029 RTEP Short Circuit base case that includes the 2024W1 selected solution, 1-500kV breaker at Doubs substation was identified as being over duty.

Recommended Solution:

Replace 50kA breaker DL-59 #2CAP with a 63kA breaker. **(b4000.110)**

Estimated Cost: ~~\$11.5 M~~ **\$10.06 M**

Reason for Cost Change:


Original estimated cost incorrectly reflected the future “in-service year” installed cost rather than the current year cost.

Required IS Date: 6/1/2029

Projected IS Date: 6/1/2029

Previously Presented: 1/10/2025
www.pjm.com | Public

APS Transmission Zone: Baseline Doubs 500kV Breaker Replacement



Cancellations

DOM Transmission Zone: Baseline Loudoun – Morrisville 500kV

Process Stage: Cancellation

Criteria: End of Life

Assumption Reference: FERC 715

B3211: Rebuild the 1.3 mile section of Line #569 Loudoun to Morrisville with single-circuit 500 kV structures at the current 500 kV standard. This will increase the rating of Line #569 to 3424 MVA.

The upgrade was identified through reliability studies that indicated that retiring Line #569 would result in thermal overloads in accordance with P6 NERC criteria violations.


Cancellation Reason: Baseline project b3800.312 from 2022 Window 3 will rebuild entire portion of line #569 Loudoun – Morrisville, therefore eliminating the need project.

Previously Presented: 8/8/2019 TEAC

Estimated Project Cost: \$4.5 M

Required In-Service Date: As Soon As Possible

Projected In-Service Date: 12/31/2024



COLOR	VOLTAGE	TRANSMISSION LINE NUMBER
Green	500 KV.	500 thru 599
Blue	230 KV.	200 thru 299 & 2000 thru 2099
Red	115 KV.	1 thru 199
Orange	138 KV.	AS NOTED
Cyan	69 KV.	AS NOTED

DOM Transmission Zone: Baseline Ox 500kV Breaker Replacements

Process Stage: Cancellation

Criteria: Short Circuit

Assumption Reference: 2024 RTEP assumptions

Model Used for Analysis: 2029 RTEP Short Circuit base case + PJM selected solution

Proposal Window Exclusion: None

B4000.130: Replace 40kA breakers 56142, H1T539, H2T539 with 63kA breakers.

Estimated Cost: \$3.045 M

Reason for Cancellation:


Baseline projects b3800.236 (H1T539, H2T539) & b3800.335 (56142) from 2022 Window 3 replace the same 3 breakers therefore eliminating the need for this project.

Required IS Date: 6/1/2029

Projected IS Date: 6/1/2029

www.pjm.com | Public

Previously Presented: 1/10/2025



Facilitator:

Eric Hsia,

Eric.Hsia@pjm.com

Secretary:

Joshua Stephenson,

Joshua.Stephenson@pjm.com

SME/Presenter:

Stan Sliwa,

Stanley.Sliwa@pjm.com

Reliability Analysis Update

A green speech bubble containing a white question mark, positioned above a blue speech bubble with three horizontal lines, indicating a question or contact point.

?

Member Hotline

(610) 666-8980

(866) 400-8980

custsvc@pjm.com

Version No.	Date	Description
1	Mar. 27 th , 2025	<ul style="list-style-type: none">Initial slides posted

**PROTECT THE
POWER GRID
THINK BEFORE
YOU CLICK!**



Be alert to
malicious
phishing emails.

Report suspicious email activity to PJM.
(610) 666-2244 / it_ops_ctr_shift@pjm.com



Resources Available to PJM Stakeholders (Transmission Planning)

- [PJM Learning Center](#) – Overviews on PJM's priorities and responsibilities, including Planning responsibilities
- [Process to build a new facility](#) – Overview of the steps and parties involved in the process to build a new facility from the need to completion.
- PJM Manual 14B – Details on how PJM conducts analysis ([web](#) or [pdf](#))
- PJM Manual 14F – Overview of the competitive process ([web](#) or [pdf](#))

- Generation interconnection queue – List of all projects for proposed generation. PJM does not solicit these requests, but PJM will ensure each project can operate reliably.
 - [Serial process](#) – Historic view of all projects submitted prior to 2022
 - [Cluster process](#) – Progress of all projects processed with the reformed interconnection process
- PJM Manual 14H – Overview of the generation interconnection process ([web](#) or [pdf](#))

- [General PJM training](#) – A variety of training resources on various aspects of PJM, including overviews such as [PJM Introduction](#) and [PJM 101: The Basics](#).
- [2022 RTEP Window 3 FAQ](#) – A lot of great background that applies to the current body of work.
- PJM's Client Management team – Single point of contact for any questions about PJM.
 - Phone: (610) 666-8980 or (866) 400-8980
 - E-mail: custsvc@pjm.com