

PJM/MISO Interregional Transfer Capability Study

- The MISO-PJM ITCS was designed to identify a confluence of transmission issues (reliability, economic, and transfer capability) along the seam, incorporating future generation and load assumptions
- The RTOs presented study results and MISO solicited stakeholder solution ideas in the first half of 2025
- The next step to realizing solution recommendations is developing a benefits evaluation framework, inclusive of multiple benefits, and RTO-RTO cost allocation methodology
- The RTOs are also in the process of developing long-term planning frameworks, including consideration of 7 transmission benefits outlined in FERC Order 1920
- MISO and PJM will continue to advance coordinated planning by developing an interregional transmission benefits evaluation methodology in the first half of 2026

MISO–PJM Interregional Transfer Capability Study (ITCS)

Timeline and milestones

3

2024		2025	2026	
Align Assumptions	Identify Issues	Solution Window & Evaluations	Benefit Framework & Cost Allocation	Recommendations & Tariff Updates
<ul style="list-style-type: none"> Harmonize long-term planning study models - futures (MISO LRTP Future 2A, PJM WPS 2032) Transparent modeling builds trust with state commissions and stakeholders. 	<ul style="list-style-type: none"> Joint economic, reliability, and transfer analyses reveal hundreds of seam constraints Issues mapped indicate constrained corridors or areas of stress for targeted solutions 	<ul style="list-style-type: none"> (MISO window) Stakeholders submitted conceptual projects through IPSAC Solution ideas included upgrades/enhancements and new corridors Solutions that resolve a confluence economic, transfer, and reliability issues proceed to benefits evaluations 	<ul style="list-style-type: none"> States engaged to validate assumptions and priorities Interregional cost allocation aligned with regional proportional to benefits, transparent, and Order 1920 compliant Framework documented as repeatable and durable 	<ul style="list-style-type: none"> Solutions re-evaluated and advanced through the benefit-cost framework PSCs and stakeholders review recommendation Tariff updates codify benefit cost thresholds and enable project advancement

- Blended Models reflect the future scenario assumptions with evolving transmission, load, and generation expansion of both regions
- Navigate RTO differences in solution solicitation models: procurement model vs. sponsorship mode
- Define benefits evaluation framework inclusive of multiple benefits and associated RTO-RTO cost allocation

Order 1920A/B Benefits	Description of Benefit ¹
Avoided/deferred piecemeal transmission investment	Comprehensively planned transmission can reduce the need for incremental reliability upgrades and replacement of aging infrastructure
Reduced LOLP or PRM	Transmission capability reduces system outage risk (LOLP) and need for building generation capacity to manage outages (PRM)
Production Cost savings	Transmission capability enhances market efficiency by reducing congestion and using lower cost generation
Reduced transmission energy loss	Transmission capability reduces energy loss from overly congested grid
Reduced congestion due to transmission outages	An efficiently planned grid faces fewer transmission outages and less congestion from lines being down, and reduces production cost
Mitigation of extreme weather events and unexpected event impact	A proactively planned grid reduces risk of unserved load during extreme weather events and unexpected conditions, and reduces production cost
Reduced capacity cost from reduced peak energy losses	Transmission capability reduces energy losses during peak period and reduces new generation capacity investment




Appendix

Summarized Study Results as presented June 25th, 2025

Overview of Solution Ideas from MISO Stakeholder Conceptual Window

Summary reflects conceptual solution submissions and alternatives MISO recommends for further evaluation



ITCS and PJM RTEP/M3 Overlaps (preliminary)

Area	State	RTO	Facility Name	kV	Total Transfers Impacted Red: >10 Yellow: 4-10 Black: 1-3	Transfer Rank	Facility Loading From Reliability Study Red: >150% Yellow: 100% - 150% Black: <100%	Annual Congestion(\$) Red: > \$1M Yellow: \$100k - \$1M Black: < \$100k	Potential Path Forward Under Existing Processes?
FE/ITCT	Pennsylvania (PA) / Michigan (MI)	Tie Line	Lemoyn - Laplaignance 345 kV	345	■	1	■	■	Yes
CE	Illinois (IL) / Illinois (IL)	PJM	Garden PI - ESSH71 138 kV	138	■	1	■	■	Yes
AEP/DEO&K	Indiana (IN) / Ohio (OH)	PJM	Tanners Creek - Miami Fort 345 kV	345	■	1	■	■	Yes
AEP/IPL	Indiana (IN) / Indiana (IN)	Tie Line	Fall Creek - Madison County 345 kV	345	■	1	■	■	No
AEP/NIPS	Indiana (IN) / Indiana (IN)	Tie Line	Meadow - Reynolds 345 kV	345	■	1	■	■	Yes
AEP	Indiana (IN) / Indiana (IN)	PJM	Desoto - Fall Creek 345 kV	345	■	1	■	■	Yes
CE/AMIL	Illinois (IL) / Illinois (IL)	Tie Line	Austin - Kincaid 345 kV	345	■	1	■	■	No
AEP/NIPS	Indiana (IN) / Indiana (IN)	Tie Line	Olive - Babcock 345 kV	345	■	1	■	■	Yes
CE	Illinois (IL) / Illinois (IL)	PJM	Goodings - Lockport 345 kV	345	■	1	■	■	No
CE/ALTE	Illinois (IL) / Wisconsin (WI)	Tie Line	Albany (South Desk) - Garden PI 138 kV	138	■	2	■	■	No
AEP/DEI	Indiana (IN) / Indiana (IN)	Tie Line	Eugene - Cayuga Sub 345 kV	345	■	2	■	■	Yes
AEP	Michigan (MI) / Michigan (MI)	PJM	Benton Harbor - Segreto 345 kV	345	■	2	■	■	Yes
AEP/DEI	Indiana (IN) / Indiana (IN)	Tie Line	Dresser - Sullivan 345 kV	345	■	2	■	■	No
AEP/AMIL	Ohio (OH) / Illinois (IL)	Tie Line	Snyder - Sullivan 345 kV	345	■	3	■	■	Yes
AEP	Michigan (MI) / Michigan (MI)	PJM	Cook - Segreto 345 kV	345	■	3	■	■	No
CE/AMIL	Illinois (IL) / Illinois (IL)	Tie Line	Powerton - Towerline 138 kV	138	■	3	■	■	Yes
CE	Illinois (IL) / Illinois (IL)	PJM	Lee - Byron 345 kV	345	■	3	■	■	No
AEP/DEI	Indiana (IN) / Indiana (IN)	Tie Line	Sullivan - Fairbanks 345 kV	345	■	3	■	■	No
AEP	Ohio (OH) / Ohio (OH)	PJM	Hyatt - Malis 345 kV	345	■	3	■	■	Yes
CE/ALTW	Illinois (IL) / Iowa (IA)	Tie Line	Quad Cities - Rock Creek (South Desk) 345 kV	345	■	3	■	■	Yes

* Results given ITCS model assumptions reported on slide 5, including PJM 2024 Load Forecast and Workshop Policy Study resource fleet

Reliability

Identified thermal overloads resulting from contingency events or the loss system elements

Transfer

Identified transmission facilities which limited the transfer of power between two specified areas as the transfer level is increased

Economic

Simulated full-year marked-based unit commitment and dispatch to identify transmission facilities or areas with significant congestion cost

Extreme Cold Weather Scenarios (Reliability)

Analyze the capability of proposed solutions to mitigate system constraints under increased system stress


MISO-PJM Study-Developed Transfers analyzed:



Additional Transfers:

General Transfers Between MISO & PJM	
MISO Classic <-> PJM	
NERC ITCS Transfers Between MISO & PJM	
E12:	MISO West <-> PJM West
E16:	MISO Central <-> PJM West
E22:	MISO East <-> PJM West

Summary count of issues by analysis area and footprint ¹⁰



PJM	Reflects total issues by RTO under Reliability, Transfer, and Economic categories
MISO	
PJM	Reflects unique issues by RTO under only Reliability, Transfer, and Economic categories
MISO	
PJM	Reflects unique issues by RTO under overlapping Reliability, Transfer, and Economic categories
MISO	

Notes:
Individual RTO footprint results from the joint study reflect analysis on the blended model
Issue counts represent RTO lines and tie-lines; tie lines are counted with 0.5 weight to avoid double counting at regional level.

- Top transfer limits:
 - MISO and PJM results
 - Facilities identified in each RTO as well as tie-lines
 - Voltages
 - Overlaps
 - Details in appendix (Slides 34-36)



Overlapping Reliability, Transfer, and Economic Issues (Center of the Venn Diagram on Slide 7)

Overlapping Issues Identified in All Analyses, PJM (Top 10 Transfers, Reliability, Economic) 13

Area	State	RTO	Facility Name	kV	Total Transfers Impacted Red: >10 Yellow: 4-10 Black: 1-3	Facility Loading From Reliability Study Red: >150% Yellow: 100% - 150% Black: <100%	Annual Congestion(\$) Red: > \$1M Yellow: \$100k - \$1M Black: < \$100k
AEP	Ohio (OH)	PJM	Marysville 765 kV Reactor (to Sorenson)	765	■	■	■
AEP	Ohio (OH)	PJM	Marysville 765 kV Reactor (To Maliszewski)	765	■	■	■
AEP	Ohio (OH) / Ohio (OH)	PJM	East Lima - Fostoria Central 345 kV	345	■	■	■
AEP	Michigan (MI) / Indiana (IN)	PJM	Benton Harbor - Segreto 345 kV	345	■	■	■
AEP/AMIL	Indiana (IN) / Illinois (IL)	Tie Line	Eugene - Bunsonville 345 kV Bus 1	345	■	■	■
AEP/AMIL	Ohio (OH) / Illinois (IL)	Tie Line	Snyder - Sullivan 345 kV	345	■	■	■
AEP/DEI	Indiana (IN) / Indiana (IN)	Tie Line	Eugene - Cayuga Sub 345 kV	345	■	■	■
AEP/DEO&K	Indiana (IN) / Ohio (OH)	PJM	Tanners Creek - Miami Fort 345 kV	345	■	■	■
AEP/NIPS	Ohio (OH) / Indiana (IN)	Tie Line	Meadow - Reynolds 345 kV	345	■	■	■
CE/ALTW	Illinois (IL) / Iowa (IA)	Tie Line	Albany (South Desk) - Garden PI 138 kV	138	■	■	■
CE/AMIL	Illinois (IL) / Illinois (IL)	Tie Line	Austin - Kincaid 345 kV	345	■	■	■
CE/AMIL	Illinois (IL) / Illinois (IL)	Tie Line	Powerton - Towerline 138 kV	138	■	■	■
CE	Illinois (IL) / Illinois (IL)	PJM	Lee - Byron 345 kV	345	■	■	■
CE	Illinois (IL) / Illinois (IL)	PJM	Enbridge - DeKalb tap (R) - Waterman 138 kV	138	■	■	■
CE	Illinois (IL) / Illinois (IL)	PJM	Garden PI - JESSH71 138 kV	138	■	■	■
CE	Illinois (IL) / Illinois (IL)	PJM	Haumesser - Dekalb 138 kV	138	■	■	■
NIPS/CE	Illinois (IL) / Indiana (IN)	Tie Line	Crete - St. John 345 kV tie line	345	■	■	■

Overlapping Issues Identified In All Analyses, MISO

Area	State	RTO	Facility Name	kV	Total Transfers Impacted Red: >10 Yellow: 4-10 Black: 1-3	Facility Loading From Reliability Study Red: >150% Yellow: 100% - 150% Black: <100%	Congestion Measure (\$) Red: > \$200k Yellow: \$50k - \$200k Black: < \$50K
DEI	Indiana (IN) / Indiana (IN)	MISO	Cayuga Sub - Cayuga 345 kV	345	■	■	■
CE/AMIL	Illinois (IL) / Illinois (IL)	Tie Line	Austin - Kincaid 345 kV	345	■	■	■
ALTW/MEC	Iowa (IA) / Iowa (IA)	Tie Line	Morgan Valley - Tiffin 345 kV	345	■	■	■
DEI/IPL	Indiana (IN) / Indiana (IN)	MISO	Whitestown - Guion 345 kV	345	■	■	■
ALTE	Wisconsin (WI) / Wisconsin (WI)	MISO	Albany - Bass Creek 138 kV	138	■	■	■
ALTE	Wisconsin (WI) / Wisconsin (WI)	MISO	Bristol - Elkhorn 138 kV	138	■	■	■
AEP/DEI	Indiana (IN) / Indiana (IN)	Tie Line	Eugene - Cayuga Sub 345 kV	345	■	■	■
ALTE	Wisconsin (WI) / Wisconsin (WI)	MISO	North Monroe - Albany 138 kV	138	■	■	■
AEP/AMIL	Ohio (OH) / Illinois (IL)	Tie Line	Snyder - Sullivan 345 kV	345	■	■	■
DEI	Indiana (IN) / Indiana (IN)	MISO	Cayuga - Nucor Steel 345 kV	345	■	■	■
AMIL	Illinois (IL) / Illinois (IL)	MISO	Casey - Snyder 345 kV	345	■	■	■