

PJM Task List Impacts

PJM Manual 13, Revision 98

Maureen Curley
Manager, State & Member Training

Dispatcher Training Subcommittee
July 14, 2026

- **Manual 13, Revision 98 (Effective 6/24/26)**
 - Changes will impact the PJM Generation and Transmission Owner Task Lists
 - New Capacity Advisory added to Section 2
 - New Attachment O – Emergency Use of Back-up Generators

5 **Terminal Task** Given a capacity emergency, respond to Emergency Procedures and take appropriate action in accordance with the appropriate PJM manuals

1.

5.1 **Enabling Objective** Respond to a PJM issued [Advisory](#)/Alert and take the appropriate action

5.2 **Enabling Objective** Respond to a PJM issued Warning and take the appropriate action

5.3 **Enabling Objective** Respond to a PJM issued Action and take the appropriate action

- **Add Capacity Advisory to Enabling Objective 5.1**
 - PJM will provide training on the new emergency procedure

7 **Terminal Task*** Given a capacity emergency, respond to the Emergency Procedures in accordance with the appropriate PJM manuals

1.

7.1 **Enabling Objective** Respond to a PJM issued Advisory/Alert and take the appropriate action

7.2 **Enabling Objective** Respond to a PJM issued Warning and take the appropriate action

7.3 **Enabling Objective** Respond to a PJM issued Action and take the appropriate action

- **Add Capacity Advisory to Enabling Objective 7.1**
 - PJM will provide training on the new emergency procedure
 - Given the limited impact to Transmission Owner Operators, task reverification is not required

7 **Terminal Task*** Given a capacity emergency, respond to the Emergency Procedures in accordance with the appropriate PJM manuals

7.1 **Enabling Objective** Respond to a PJM issued Advisory/Alert and take the appropriate action

7.2 **Enabling Objective** Respond to a PJM issued Warning and take the appropriate action

7.3 **Enabling Objective** Respond to a PJM issued Action and take the appropriate action

2.

7.4 **Company Specific Task*** Given a Department of Energy 202(c) Order is in effect and notification from PJM, explain how your company implements the Emergency Use of Back-up Generator procedures in accordance with company guidelines

- **Add Company Specific Task 7.4 to address Attachment O – Emergency Use of Back-up Generators**
 - New Task; ***Task Verification due December 24, 2026***
 - Member Company to provide training on company-specific procedure
 - PJM Manual 40 allows for Opt-Out if Task does not apply

Facilitator:
Marc Farinas,
marc.farinas@pjm.com

Presenter:
Maureen Curley,
maureen.curley@pjm.com

**PJM Task List Updates
(M13 Revision 98)**



Member Hotline

(610) 666 – 8980


(866) 400 – 8980

custsvc@pjm.com

**PROTECT THE
POWER GRID**
**THINK BEFORE
YOU CLICK!**



**BE ALERT TO
MALICIOUS PHISHING
EMAILS**



Report suspicious email activity to PJM.
Call (610) 666-2244 or email it_ops_ctr_shift@pjm.com