

## Manual 14-D: Generation Operational Requirements (Generation Operational Testing)

Ray Lee Lead Engineer, Generation, PJM SOS January 6, 2025



M14D Conforming Changes

- Conforming changes to align with Generation Operational Test language in OATT Attachment DD due to CIFP-RA filing ER24-99
- Purpose of testing is to better ensure resources are capable of operating when needed for reliability
- New Section 7.6 Generation Operational Testing
- Generation Operation Tests can begin starting June 1, 2025



- All Generation Capacity Resources committed in RPM or a FRR Plan are subject to testing except variable resources
- PJM can initiate up to two operational tests per season for relevant Delivery Year
  - Summer (May-October)
  - Winter (November-April)



## 7.6.1 Resource Selection for Testing

- Considerations for resource selection
  - $\circ$  Time since last operation
  - Operational issues (frequent outages or derates)
  - Failures to start or operate within resource schedule parameters
- PJM will select a schedule for testing based on the available schedule(s) in Markets Gateway
- No requirement for PJM to test all resources in a season or Delivery Year



7.6.2 Test Notification

- PJM will inform a resource that a Generation Operational Test is being initiated in real-time via phone call without advance notice
- PJM will communicate the schedule the resource will be tested on
- Resources undergoing initial Generation Operational Tests will be eligible for make whole (in accordance with OATT, Attachment K-Appendix, section 3.2.3(e)), reserves, and to set LMP



## 7.6.3 Test Evaluation Criteria

- Time to Start (Notification Time + Applicable Start-Up Time) and Minimum Run Time parameters for the selected schedule will be used for evaluation purposes
- Resource must meet all criteria below for a successful test
  - Time from resource commitment to unit breaker close <=
    [(Notification Time + Start Up Time) + greater of (10 min or
    0.1\*(Notification Time + Start Up Time)]</li>
  - 2. Resource must operate for at least the Minimum Run Time
- No penalty for failure of an initial test



- Resources that fail an initial Generation Operational Test may be re-tested within the same season
- Re-tests are considered to be part of the same initial operational test and do NOT count as a second test for the relevant season
- Re-tests will NOT be eligible for make whole, but will be eligible for reserves and to set LMP





- A Resource that fails a re-test and does NOT start and synchronize to the grid during the same day of the re-test shall be assessed a daily Generation Capacity Resource Operational Test Failure Charge
- Charge shall be assessed on the date of the failed re-test and end on the date the resource successfully starts and synchronizes to the grid. Resource is **NOT** required to meet the test evaluation criteria to stop the charge.
- Generation Capacity Resource Operational Test Failure Charge details in PJM Manual M-18 Sections 8 and 9



🔵 First Read 🛛 😑 Vote 🥚 Start of 25/26 DY



Contact

Chair: Kevin Hatch, <u>Kevin.Hatch@pjm.com</u>

Secretary: Matt Wharton <u>Matthew.Wharton@pjm.com</u>

SME/Presenter: Ray Lee, <u>Ray.Lee@pjm.com</u> Member Hotline (610) 666 – 8980 (866) 400 – 8980 custsvc@pjm.com











