

FirstEnergy West (FE-W)

1. **Finley – Mill Creek – Bellepoint – Tangy 138 kV** – Restore Finley-Mill Creek-Bellepoint or Tangy-Bellepoint following a fault on the Tangy-Bellepoint or Finley-Mill Creek-Bellepoint respectively.
 - Effective 3/24/25
2. **Vulcan – Univ. of Toledo – Bellevue – Toledo Hospital 138 kV** – Restore Vulcan-Univ. of Toledo-Bellevue or Bellevue-Toledo Hospital following a fault on the Bellevue-Toledo Hospital or Vulcan-Univ. of Toledo-Bellevue respectively.
 - Effective 3/24/25

FirstEnergy East (FE-E)

1. **Cly – Newberry – Round Top 115 kV** – Restore Cly-Newberry or Newberry-Round Top following a fault on the Newberry-Round Top or Cly-Newberry respectively.
 - Effective 3/24/25
2. **Cly – Collins – Middletown Jct. 115 kV** – Restore Cly-Collins or Collins-Middletown Jct. following a fault on the Collins-Middletown Jct. or Cly-Collins respectively.
 - Effective 3/24/25
3. **Marshall-Grover-Scotch Hollow 230 kV Sectionalized**– Restore Marshall-Grover or Scotch Hollow-Grover and Grover Transformer following a fault on Scotch Hollow-Grover or Marshall-Grover respectively. Restore Marshall-Grover and Scotch Hollow-Grover following a fault on Grover Transformer.
 - Retired

Dominion Virginia Electric Power (DOM)

2. **North Anna TX#1 Sectionalized** – Restores 500 kV Bus #1 Breakers WT576 and XT573 following a fault on the transformer.
 - Retired

Pennsylvania Power & Light Company (PPL)

1. **Juniata #4 230/69 kV Transformer Sectionalized** – Restores the 230 kV bus 2 at Juniata following a fault on the transformer #4.
 - Retired