

ROCKLAND CAPITAL

24 WATERWAY AVENUE, SUITE 400

THE WOODLANDS, TX 77380

PHONE: 281.863.9000

October 8, 2025

VIA EMAIL: Generatordeactivation@pjm.com

Re: Deactivation Notice for Sidney Unit 5

Dear PJM Generation Manager:

Rockland Capital, LP ("Rockland") hereby respectfully provides notice to PJM Interconnection, L.L.C. ("PJM") pursuant to Section 113.1 of the PJM Open Access Transmission Tariff ("Tariff") that it intends to immediately deactivate and retire Sidney Unit 5 ("Sidney 5", Sidney Station comprised of 5 individual 2.5 MW GM MU-20E CTs) located in Sidney, Ohio, as of October 8, 2025 due to catastrophic failure. Sidney 5 is a diesel combustion turbine. Sidney 5 is not designated as Black Start Unit. Total available capacity at the Sidney Station will be reduced from 12.5 MW to 10 MW.

On June 24, Sidney 5 experienced a fire and upon further investigation and determination, this event is a catastrophic failure for Sidney 5 and unable to return to service. Rockland acknowledges the current dates and rules associated with requesting a Deactivation Date, however, Section 113.1 of the Tariff acknowledges catastrophic failure events in that *"The desired Deactivation Date may be earlier than the above-referenced dates if the Generation Owner ... and (iii) the generating unit experiences a catastrophic failure as reasonably determined by the Transmission Provider which renders compliance with this provision infeasible."* Therefore, Rockland requests a Deactivate Date of October 8, 2025.

Please confirm receipt of this notice and let me know if you have any questions.

Regards,



Jim Maiz
Vice President