

Line #85 Rebuild (Lanexa to West Point)

General Information

Proposing entity name	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project?	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Company proposal ID	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
PJM Proposal ID	836
Project title	Line #85 Rebuild (Lanexa to West Point)
Project description	Rebuild approximately 10.94-mile double circuit segment of Line #85 between Lanexa (structure 85/1A) and structure 85/75C to current 115kV standards, and with a minimum summer rating of 393 MVA. Line #85 shares a double circuit with 230kV Line #2016. The terminal ends should be upgraded as needed to not limit the conductor rating.
Email	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Project in-service date	11/2028
Tie-line impact	No
Interregional project	No
Is the proposer offering a binding cap on capital costs?	No
Additional benefits	The redacted information is proprietary to the Company; therefore, it is privileged and confidential

Project Components

1. Line 85 Rebuild (Lanexa to West Point)
2. Line 2016 Rebuild (Lanexa to Harmony Village)
3. Lanexa Substation Terminal Equipment Upgrade
4. Goalders Creek Substation Relay Reset

Transmission Line Upgrade Component

Component title	Line 85 Rebuild (Lanexa to West Point)	
Project description	The redacted information is proprietary to the Company; therefore, it is privileged and confidential	
Impacted transmission line	Line 85	
Point A	Lanexa	
Point B	Owl Trap	
Point C		
Terrain description	The project is in the Coastal Plains region, specifically New Kent County and a portion of King William County. The area is mostly rural. There are several crossings of The Diascund Reservoir, a major crossing over the Pamunkey River and numerous wetland areas. There are elevation changes along the route with the highest being approximately 152 feet and the lowest being approximately 6 feet.	
Existing Line Physical Characteristics		
Operating voltage	115	
Conductor size and type	1351.5 ACSR (45/7) 90°C MOT & 1109 ACAR (24/13) 90°C MOT	
Hardware plan description	New hardware will be used for line rebuild	
Tower line characteristics	The existing line consists mainly of weathering steel double circuit H-frame structures built in 1979 and weathering steel double circuit towers built in 1969 and 1979.	
Proposed Line Characteristics		
	Designed	Operating
Voltage (kV)	115.000000	115.000000
	Normal ratings	Emergency ratings
Summer (MVA)	393.000000	393.000000
Winter (MVA)	412.000000	412.000000

Conductor size and type	1-768.2 ACSS/TW/HS (20/7) 250°C MOT
Shield wire size and type	(2) DNO-10410 shield wire
Rebuild line length	10.94 Miles
Rebuild portion description	Refer to "993539-Proposal 4_T-Line Scope & One Lines" for complete description.
Right of way	The existing right of way (ROW) width varies based on the map viewer inputs as well as plan and profiles. It ranges from 120 to 180 feet between Lanexa Substation and structure 85/2 (2016/2). From structures 85/2 (2016/2) to 85/6 (2016/6), the ROW remains at 180 feet and between structures 85/6 (2016/6) to West Point Substation, the ROW is 100 feet. For approximately 8.24 miles from structure 85/6 (2016/6) to 85/67 (2016/67) and for approximately 0.18 miles from structure 85/74 (2016/74) to 85/75A an additional 20 feet of right of way is required. This results in approximately 20.41 acres of additional ROW being required. a. An alternative option to acquiring ROW would be to rebuild the line with vertical structures rather than double circuit H-frames or to receive a project specific exemption for not meeting typical ROW requirements.
Construction responsibility	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Benefits/Comments	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Component Cost Details - In Current Year \$	
Engineering & design	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Permitting / routing / siting	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
ROW / land acquisition	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Materials & equipment	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Construction & commissioning	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Construction management	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Overheads & miscellaneous costs	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Contingency	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Total component cost	\$58,154,106.00
Component cost (in-service year)	\$62,283,048.00

Transmission Line Upgrade Component

Component title	Line 2016 Rebuild (Lanexa to Harmony Village)	
Project description	The redacted information is proprietary to the Company; therefore, it is privileged and confidential	
Impacted transmission line	Line 2016	
Point A	Lanexa	
Point B	Harmony Village	
Point C		
Terrain description	The project is in the Coastal Plains region, specifically New Kent County and a portion of King William County. The area is mostly rural. There are several crossings of The Diascund Reservoir, a major crossing over the Pamunkey River and numerous wetland areas. There are elevation changes along the route with the highest being approximately 152 feet and the lowest being approximately 6 feet.	
Existing Line Physical Characteristics		
Operating voltage	230	
Conductor size and type	1033.5 ACSS (45/7) 90°C MOT	
Hardware plan description	New hardware will be used for line rebuild	
Tower line characteristics	The existing line consists mainly of weathering steel double circuit H-frame structures built in 1979 and weathering steel double circuit towers built in 1969 and 1979.	
Proposed Line Characteristics		
	Designed	Operating
Voltage (kV)	230.000000	230.000000
	Normal ratings	Emergency ratings
Summer (MVA)	1573.000000	1573.000000
Winter (MVA)	1648.000000	1648.000000

Conductor size and type	2-768.2 ACSS/TW/HS (20/7) 250°C MOT
Shield wire size and type	(2) DNO-10410 shield wire
Rebuild line length	11.08 Miles
Rebuild portion description	Refer to "993539-Proposal 4_T-Line Scope & One Lines" for complete description.
Right of way	The existing right of way (ROW) width varies based on the map viewer inputs as well as plan and profiles. It ranges from 120 to 180 feet between Lanexa Substation and structure 85/2 (2016/2). From structures 85/2 (2016/2) to 85/6 (2016/6), the ROW remains at 180 feet and between structures 85/6 (2016/6) to West Point Substation, the ROW is 100 feet. For approximately 8.24 miles from structure 85/6 (2016/6) to 85/67 (2016/67) and for approximately 0.18 miles from structure 85/74 (2016/74) to 85/75A an additional 20 feet of right of way is required. This results in approximately 20.41 acres of additional ROW being required. a. An alternative option to acquiring ROW would be to rebuild the line with vertical structures rather than double circuit H-frames or to receive a project specific exemption for not meeting typical ROW requirements.
Construction responsibility	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Benefits/Comments	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Component Cost Details - In Current Year \$	
Engineering & design	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Permitting / routing / siting	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
ROW / land acquisition	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Materials & equipment	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Construction & commissioning	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Construction management	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Overheads & miscellaneous costs	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Contingency	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Total component cost	\$.00
Component cost (in-service year)	\$.00

Substation Upgrade Component

Component title	Lanexa Substation Terminal Equipment Upgrade
Project description	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Substation name	Lanexa
Substation zone	345
Substation upgrade scope	Purchase & Install Substation Material: 1. One (1), 115KV Wave Trap 2. One (1) 115KV Coupling Capacitor Voltage Transformer. 3. Conductors, connectors, insulators, control cables, foundations, steel structures, and grounding connections as per engineering standards. Retire Substation Material: 1. One (1), 115kV, Single phase Coupling Capacitor Voltage Transformer due to aging. 2. One (1), 115kV, 1600A, Wave Trap. Purchase & Install Relay Material: 1. Relay reset only.

Transformer Information

None	
New equipment description	1. One (1), 115KV Wave Trap 2. One (1) 115KV Coupling Capacitor Voltage Transformer.
Substation assumptions	1. The scope of work depicted on the drawings assumes that there is no overlap with other designs and construction activities, except if mentioned in this Project Summary. 2. Relay Settings and P&C design will be revised as part of the SPE Scope of Work.
Real-estate description	Substation is not being expanded.
Construction responsibility	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Benefits/Comments	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Component Cost Details - In Current Year \$	
Engineering & design	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Permitting / routing / siting	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
ROW / land acquisition	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Materials & equipment	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Construction & commissioning	The redacted information is proprietary to the Company; therefore, it is privileged and confidential

Construction management	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Overheads & miscellaneous costs	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Contingency	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Total component cost	\$252,776.40
Component cost (in-service year)	\$270,723.10
Substation Upgrade Component	
Component title	Goalders Creek Substation Relay Reset
Project description	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Substation name	Goalders Creek
Substation zone	345
Substation upgrade scope	1. Relay Reset Only.
Transformer Information	
None	
New equipment description	None.
Substation assumptions	1. The scope of work depicted on the drawings assumes that there is no overlap with other designs and construction activities, except if mentioned in this Project Summary. 2. Relay Settings and P&C design will be revised as part of the SPE Scope of Work.
Real-estate description	Substation is not being expanded.
Construction responsibility	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Benefits/Comments	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Component Cost Details - In Current Year \$	
Engineering & design	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Permitting / routing / siting	The redacted information is proprietary to the Company; therefore, it is privileged and confidential

ROW / land acquisition	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Materials & equipment	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Construction & commissioning	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Construction management	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Overheads & miscellaneous costs	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Contingency	The redacted information is proprietary to the Company; therefore, it is privileged and confidential
Total component cost	\$20,108.20
Component cost (in-service year)	\$21,535.67

Congestion Drivers

None

Existing Flowgates

FG #	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type	Status
2025W1-ME2	314188	3WEST PT	314387	3LANEXA	1	115	345	Market Efficiency	Included

New Flowgates

The redacted information is proprietary to the Company; therefore, it is privileged and confidential

Financial Information

Capital spend start date	10/2025
Construction start date	11/2027
Project Duration (In Months)	37

Additional Comments

The project is in the Coastal Plains region, specifically New Kent County and a portion of King William County. There are several crossings of The Diascund Reservoir, a major crossing over the Pamunkey River and numerous wetland areas. These are the main reasons for the relatively high cost estimate.