

Line 567 Terminal Upgrade Chickahominy & Surry

General Information

| | |
|---|---|
| Proposing entity name | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project? | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Company proposal ID | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| PJM Proposal ID | 126 |
| Project title | Line 567 Terminal Upgrade Chickahominy & Surry |
| Project description | Upgrade wave trap, lead, breaker and switch equipment supporting Line #567 at the Chickahominy and Surry Substations to 5000A, and update CTs to support 6000A. No transmission line rebuild. The existing transmission line conductor will become the most limiting element for Line #567. |
| Email | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Project in-service date | 06/2032 |
| Tie-line impact | No |
| Interregional project | No |
| Is the proposer offering a binding cap on capital costs? | Yes |
| Additional benefits | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |

Project Components

1. Chickahominy Substation Line Terminal Upgrade (993592 Alt_1)
2. Surry Substation Line Terminal Upgrade (993592 Alt_1)

Substation Upgrade Component

| | |
|-----------------|--|
| Component title | Chickahominy Substation Line Terminal Upgrade (993592 Alt_1) |
|-----------------|--|

| | |
|--|--|
| Project description | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Substation name | Chickahominy |
| Substation zone | 500 |
| Substation upgrade scope | Purchase & Install Substation Material: 1. Conductor, connectors, conduit, control cable, foundations, steel structures and grounding material as necessary per engineering standards. Remove Substation Material: 1. Conductor, connectors, conduit, control cable, foundations, steel structures and grounding material as necessary per engineering standards. |
| Transformer Information | |
| None | |
| New equipment description | NA |
| Substation assumptions | 1. The scope of work depicted on the drawings assumes that there is no overlap with other designs and construction activities, except if mentioned in this Project Summary. 2. 4-hole pad connections must be replaced with 6-hole pad connections to maintain 5000A ratings. 3. Relay Settings and P&C design will be revised as part of the SPE Scope of Work. 4. Detail Engineering to coordinate with circuit breaker vendor to achieve 6000A rated breaker CTs. |
| Real-estate description | Substation is not being expanded. |
| Construction responsibility | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Benefits/Comments | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Component Cost Details - In Current Year \$ | |
| Engineering & design | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Permitting / routing / siting | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| ROW / land acquisition | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Materials & equipment | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Construction & commissioning | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Construction management | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Overheads & miscellaneous costs | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |

| | |
|-------------------------------------|---|
| Contingency | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Total component cost | \$28,620.00 |
| Component cost (in-service year) | \$30,652.00 |
| Substation Upgrade Component | |
| Component title | Surry Substation Line Terminal Upgrade (993592 Alt_1) |
| Project description | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Substation name | Surry |
| Substation zone | 500 |
| Substation upgrade scope | <p>Purchase & Install Substation Material: 1. Three (3), 500kV, 5000A, Double End Break Switches 2. Three (3), 396kV, 318kV MCOV Station Class Surge Arresters 3. Three (3), 500kV, Coupling Capacitor Voltage Transformers 4. One (1), 500kV, 5000A, 90-200kHz, Wave Trap 5. Approximately 580 FT of 6 in. Sch. 80 tube bus 6. Conductor, connectors, conduit, control cable, foundations, steel structures and grounding material as necessary per engineering standards</p> <p>Remove Substation Material: 1. Five (5), 500kV, 3000A, Double End Break Switches 2. Three (3), 500kV, Coupling Capacitor Voltage Transformers 3. One (1), 500kV, 3000A, 90-200kHz, Wave Trap 4. Approximately 30 FT of 6 in. Sch. 40 tube bus 5. Approximately 550 FT of 5 in. Sch. 40 tube bus 6. Conductor, connectors, conduit, control cable, foundations, steel structures and grounding material as necessary per engineering standards</p> <p>Purchase & Install Relay Material: 1. One (1), 4506 – 3Ø CCVT Potential Makeup Box</p> |
| Transformer Information | |
| None | |
| New equipment description | 1. Three (3), 500kV, 5000A, Double End Break Switches 2. Three (3), 396kV, 318kV MCOV Station Class Surge Arresters 3. Three (3), 500kV, Coupling Capacitor Voltage Transformers 4. One (1), 500kV, 5000A, 90-200kHz, Wave Trap 5. One (1), 4506 – 3Ø CCVT Potential Makeup Box |
| Substation assumptions | 1. The scope of work depicted on the drawings assumes that there is no overlap with other designs and construction activities, except if mentioned in this Project Summary. 2. 4-hole pad connections must be replaced with 6-hole pad connections to maintain 5000A ratings. 3. Relay Settings and P&C design will be revised as part of the SPE Scope of Work. 4. Detail Engineering to coordinate with circuit breaker vendor to achieve 6000A rated breaker CTs. |
| Real-estate description | Substation is not being expanded. |

| | |
|---|---|
| Construction responsibility | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Benefits/Comments | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Component Cost Details - In Current Year \$ | |
| Engineering & design | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Permitting / routing / siting | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| ROW / land acquisition | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Materials & equipment | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Construction & commissioning | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Construction management | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Overheads & miscellaneous costs | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Contingency | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Total component cost | \$2,462,303.00 |
| Component cost (in-service year) | \$2,637,127.00 |

Congestion Drivers

None

Existing Flowgates

None

New Flowgates

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Financial Information

| | |
|------------------------------|---------|
| Capital spend start date | 01/2026 |
| Construction start date | 06/2032 |
| Project Duration (In Months) | 77 |

Cost Containment Commitment

| | |
|----------------------------|---|
| Cost cap (in current year) | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |
| Cost cap (in-service year) | The redacted information is proprietary to the Company; therefore, it is privileged and confidential. |

Components covered by cost containment

1. Chickahominy Substation Line Terminal Upgrade (993592 Alt_1) - Dominion
2. Surry Substation Line Terminal Upgrade (993592 Alt_1) - Dominion

Cost elements covered by cost containment

| | |
|---------------------------------|-----|
| Engineering & design | Yes |
| Permitting / routing / siting | No |
| ROW / land acquisition | No |
| Materials & equipment | No |
| Construction & commissioning | No |
| Construction management | No |
| Overheads & miscellaneous costs | No |
| Taxes | No |
| AFUDC | No |
| Escalation | No |

Additional Information

Is the proposer offering a binding cap on ROE?

Yes

Would this ROE cap apply to the determination of AFUDC?

Yes

Would the proposer seek to increase the proposed ROE if FERC finds that a higher ROE would not be unreasonable?

No

Is the proposer offering a Debt to Equity Ratio cap?

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Additional Comments

None