Line 563 Rebuild - Carson to Midlothian

General Information

Proposing entity name

Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project?

Company proposal ID

PJM Proposal ID

Project title

Project description

Email

Project in-service date

Tie-line impact

Interregional project

Is the proposer offering a binding cap on capital costs?

Additional benefits

Project Components

- 1. Line 563 Rebuild Carson to Midlothian (99-3597)
- 2. Carson Terminal Equipment Uprate (993597)
- 3. Midlothian Terminal Equipment Uprate (993597)

Transmission Line Upgrade Component

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

238

Line 563 Rebuild - Carson to Midlothian

Rebuild approximately 37.4 miles of existing transmission line from the Carson substation to the Midlothian substation. Upgrade/install equipment at Carson and Midlothian substations to support the new conductor termination.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

06/2032

No

No

Yes

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Component title Line 563 Rebuild - Carson to Midlothian (99-3597) Project description The redacted information is proprietary to the Company; therefore, it is privileged and confidential. Impacted transmission line Line 563 Point A Carson Point B Midlothian Point C Terrain description The project area is in the central Virginia Piedmont region with elevations ranging from approximately 125-300'. The terrain is predominately vegetated existing right-of-way in rural areas and some suburban developments. The line will include 39 VDOT road crossings, including 85, 288, and Powhite Parkway, as well as several creek and stream crossings. The line routes through Chesterfield and Dinwiddie Counties. **Existing Line Physical Characteristics** Operating voltage 500 Conductor size and type 2-2500 ACAR (84/7) [37.26 miles] & -1351 ACSR (45/7) [0.15 miles] New hardware will be used for line rebuild. Hardware plan description The existing line consists mainly of 500 kV SC Steel Suspension Towers built in 1981. The Tower line characteristics proposed structures to be installed are mainly 500/230kV Double Circuit V-String Suspension Towers. **Proposed Line Characteristics** Designed Operating Voltage (kV) 500.000000 500.000000 Normal ratings **Emergency ratings** Summer (MVA) 4357.000000 4357.000000 Winter (MVA) 5155.000000 5155.000000

Conductor size and type

Shield wire size and type

Rebuild line length

Rebuild portion description

Right of way

Construction responsibility

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design

Permitting / routing / siting

ROW / land acquisition

Materials & equipment

Construction & commissioning

Construction management

Overheads & miscellaneous costs

Contingency

Total component cost

3-1351 ACSS/TW/HS285 112° C MOT

(2) DNO-10410 shield wire

37.4 Miles

EXISTING FACILITIES TO BE REMOVED: 1. One Hundred and Eighty-five (185) 500 kV SC Steel Suspension Towers 2. Five (5) 500 kV SC Steel DDE Towers 3. Two (2) 500 kV SC Steel DDE Monopoles 4. Nineteen (19) 500 kV SC Steel Running Angle Towers 5. 0.15 miles of 3-1351 ACSR (45/7) Conductor 6. 37.26 miles of 2-2500 ACAR (84/7) Conductor 7. 37.41 miles of 2 – 7#7 Alumoweld Shield Wire MODIFICATIONS TO EXISTING FACILITIES: 1. Install three (3) conductor dead-end assemblies and two (2) OPGW dead-end assemblies on existing backbone structures 563/1C and 563/209A. PERMANENT FACILITIES TO BE INSTALLED: 1. One Hundred and Eighty-five (185) 500-230kV DC V-String Suspension Towers 2. Twenty-six (26) 500-230kV engineered steel DC DDE 3-pole 6. 37.41 miles of 3-1351 ACSS/TW/HS285 Conductor 7. 37.41 miles of 2 - DNO-10100 OPGW

Existing Right-of-Way shall be used.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

\$228,477,940.01

Component cost (in-service year)

Substation Upgrade Component

Component title

Project description

Substation name

Substation zone

Substation upgrade scope

Transformer Information

None

New equipment description

Substation assumptions

\$244.699.874.00

Carson Terminal Equipment Uprate (993597)

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Carson

345

Purchase & Install Substation Material: 1. Two (2), 500kV, 5000A, 63 kA SF6 Circuit Breaker. 2. Four (4), 500kV, 5000A, Double end break switch. 3. Three (3), 396kV MO, 318 kV MCOV Station Class Surge Arrester. 4. Approximately 550ft of 6IN Sch 80 AL bus. 5. Conductors, connectors, control cable, conduits, steel, foundation, and grounding material as required per engineering standards. Remove Substation Material: 1. Two (2), 500kV, 4000A, 50 kA SF6 Circuit Breaker. 2. Two (2), 500kV, 4000A, Double end break switch. 3. Two (2), 500kV, 3000A, Double end break switch. 4. One (1), 500kV, 4000A, Wave Trap. 5. Approximately 550ft of 5IN Sch 40 AL bus. 6. Conductors, connectors, control cable, conduits, steel, foundation, and grounding material as required per engineering standards. Purchase & Install Relay Material: 1. One (1), 4510 - SEL-2411 Equipment Annunciator 2. One (1), 4526 D – C.B. w/ BCM Fiber Optic Makeup Box 3. One (1), 1340 - Dual SEL-411L DCB/Fiber, CD/Fiber Line Panel (500kV w/ 2 Fiber Cables) 4. One (1), 4535 or 4536 - 500kV Circuit Breaker Condition Monitor 5. One (1), Panel Retirement. Reuse Relay Material: 1. Two (2), 1510 – Dual SEL-351 Transmission Breaker w/ Reclosing Panel 2. Two (2). 1515 - SEL-351 500kV Transmission Breaker w/ Reclosing Panel 3. One (1), 4535 or 4536 -500kV Circuit Breaker Condition Monitor 4. One (1), 4526 D - C.B. w/ BCM Fiber Optic Makeup Box 5. One (1), 4510 - SEL-2411 Equipment Annunciator

- 1. Two (2), 500kV, 5000A, 63 kA SF6 Circuit Breaker. 2. Four (4), 500kV, 5000A, Double end break switch. 3. Three (3), 396kV MO, 318 kV MCOV Station Class Surge Arrester. 4. One (1), 4510 SEL-2411 Equipment Annunciator 5. One (1), 4526_D C.B. w/ BCM Fiber Optic Makeup Box 6. One (1), 1340 Dual SEL-411L DCB/Fiber, CD/Fiber Line Panel (500kV w/ 2 Fiber Cables) 7. One (1), 4535 or 4536 500kV Circuit Breaker Condition Monitor
- 1. The scope of work depicted on the drawings assumes that there is no overlap with other designs and construction activities, except if mentioned in this Project Summary. 2. 4-hole pad connections must be replaced with 6-hole pad connections to maintain 5000A ratings. 3. Relay Settings and P&C design will be revised as part of the SPE Scope of Work.

Real-estate description

Construction responsibility

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design

Permitting / routing / siting

ROW / land acquisition

Materials & equipment

Construction & commissioning

Construction management

Overheads & miscellaneous costs

Contingency

Total component cost

Component cost (in-service year)

Substation Upgrade Component

Component title

Project description

Substation name

Substation zone

The substation will not be expanded for this project.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

\$6,152,116.00

\$6,588,916.00

Midlothian Terminal Equipment Uprate (993597)

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Midlothian

345

2025-W1-238 5

Substation upgrade scope

Transformer Information

None

New equipment description

Substation assumptions

Real-estate description

Construction responsibility

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design

Permitting / routing / siting

ROW / land acquisition

Materials & equipment

Construction & commissioning

Purchase & Install Substation Material: 1. One (1), 500kV, 5000A, 63 kA SF6 Circuit Breaker. 2. Three (3), 396kV MO, 318 kV MCOV Station Class Surge Arrester. 3. Approximately 100ft of 6IN Sch 80 AL bus. 4. Conductors, connectors, control cable, conduits, steel, foundation, and grounding material as required per engineering standards. Remove Substation Material: 1. One (1), 500kV, 4000A, 50 kA SF6 Circuit Breaker. 2. One (1), 500kV, 4000A, Wave Trap 3. Approximately 100ft of 5IN Sch 40 AL bus. 4. Conductors, connectors, control cable, conduits, steel, foundation, and grounding material as required per engineering standards. Purchase & Install Relay Material: 1. One (1), 1340 – Dual SEL-411L DCB/Fiber, CD/Fiber Line Panel (500kV w/ 2 Fiber Cables) Reuse Relay Material: 1. One (1), 1510 – Dual SEL-351 Transmission Breaker w/ Reclosing Panel 2. One (1), 1515 – SEL-351 500kV Transmission Breaker w/ Reclosing Panel 3. One (1), 4535 or 4536 – 500kV Circuit Breaker Condition Monitor 4. One (1), 4526_D – C.B. w/ BCM Fiber Optic Makeup Box 5. One (1), 4510 - SEL-2411 Equipment Annunciator

- 1. One (1), 500kV, 5000A, 63 kA SF6 Circuit Breaker. 2. Three (3), 396kV MO, 318 kV MCOV Station Class Surge Arrester. 3. One (1), 1340 Dual SEL-411L DCB/Fiber, CD/Fiber Line Panel (500kV w/ 2 Fiber Cables)
- 1. The scope of work depicted on the drawings assumes that there is no overlap with other designs and construction activities, except if mentioned in this Project Summary. 2. 4-hole pad connections must be replaced with 6-hole pad connections to maintain 5000A ratings. 3. Relay Settings and P&C design will be revised as part of the SPE Scope of Work.

The substation will not be expanded for this project.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Construction management

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Overheads & miscellaneous costs

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Total component cost

Contingency

\$2,429,026.00

Component cost (in-service year)

\$2,601,487.00

Congestion Drivers

None

Existing Flowgates

None

New Flowgates

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Financial Information

Capital spend start date 01/2026

Construction start date 06/2029

Project Duration (In Months) 77

Cost Containment Commitment

Cost cap (in current year)

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Cost cap (in-service year)

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Components covered by cost containment

2025-W1-238 7

Line 563 Rebuild - Carson to Midlothian (99-3597) - Dominion
 Carson Terminal Equipment Uprate (993597) - Dominion
 Midlothian Terminal Equipment Uprate (993597) - Dominion
 Cost elements covered by cost containment

Cost elements covered by cost containment

Engineering & design Yes Permitting / routing / siting No ROW / land acquisition No Materials & equipment No Construction & commissioning No Construction management No Overheads & miscellaneous costs No Taxes No **AFUDC** No **Escalation** No Additional Information The redacted information is proprietary to the Company; therefore, it is privileged and confidential. Is the proposer offering a binding cap on ROE? Yes Would this ROE cap apply to the determination of AFUDC? Yes

No

Would the proposer seek to increase the proposed ROE if FERC

finds that a higher ROE would not be unreasonable?

Is the proposer offering a Debt to Equity Ratio cap?

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Additional Comments

None