

# New 500kV Line - North Anna to Vontay

## General Information

Proposing entity name	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project?	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Company proposal ID	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
PJM Proposal ID	48
Project title	New 500kV Line - North Anna to Vontay
Project description	Construct one (1) new overhead 500kV transmission line (~20 miles in length) from the existing North Anna substation to the proposed Vontay substation. Construct one (1) new 500kV line terminal position at the existing North Anna substation. Construct one (1) new 500kV line terminal position at the proposed Vontay substation.
Email	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Project in-service date	06/2032
Tie-line impact	No
Interregional project	No
Is the proposer offering a binding cap on capital costs?	Yes
Additional benefits	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

## Project Components

1. New 500 kV Line - North Anna to Vontay
2. North Anna Substation Line Terminal
3. Vontay Substation Line Terminal

## Greenfield Transmission Line Component

Component title	New 500 kV Line - North Anna to Vontay	
Project description	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.	
Point A	North Anna	
Point B	Vontay	
Point C		
	Normal ratings	Emergency ratings
Summer (MVA)	5109.000000	5268.000000
Winter (MVA)	5691.000000	5867.000000
Conductor size and type	3-1351.5 ACSS/TW/HS285 145°C MOT	
Nominal voltage	AC	
Nominal voltage	500	
Line construction type	Overhead	
General route description	The proposed line mileage is based on a straight line distance from substation to substation. The linear distance is then increased by 5% in rural counties and 10% in populated counties. Structure quantities are then based on an assumed span length of 85% of the maximum span length allowable for typical Dominion standard right of ways. A detailed circuit route will be required prior to an SCC filing.	
Terrain description	This project is approximately 20 miles long through the Piedmont Region of central Virginia. The area is mostly rural and some suburban areas. There are numerous wetland crossings as well as 2 crossings of Lake Anna. There are elevation changes along the route, the highest being approximately 393 feet and the lowest being approximately 289 feet.	
Right-of-way width by segment	No new ROW required.	
Electrical transmission infrastructure crossings	To be determined in detailed design.	
Civil infrastructure/major waterway facility crossing plan	Refer to the attached Real Estate and Permitting Summary	

Environmental impacts	Refer to the attached Real Estate and Permitting Summary
Tower characteristics	Permanent Facilities to be Installed 1. Approximately (100) 500kV DC Steel Suspension Monopole 2. Approximately (14) 500kV DC Steel DDE Monopole 3. (1) 500kV SC A-Frame Backbone 4. Approximately 20 miles of 3-1351 ACSS/TW/HS285 Conductor 5. Approximately 20 miles of 2 DNO-10100 OPGW Existing Facilities to be Transferred or Modified 1. Install three (3) new 500 kV conductor dead-end assemblies and two (2) new OPGW dead-end assemblies on existing structure 553/808.
Construction responsibility	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Benefits/Comments	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Component Cost Details - In Current Year \$	
Engineering & design	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Permitting / routing / siting	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
ROW / land acquisition	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Materials & equipment	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Construction & commissioning	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Construction management	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Overheads & miscellaneous costs	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Contingency	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Total component cost	\$107,671,291.01
Component cost (in-service year)	\$115,315,953.00
<b>Substation Upgrade Component</b>	
Component title	North Anna Substation Line Terminal
Project description	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Substation name	North Anna

Substation zone	345
Substation upgrade scope	<p>Purchase &amp; Install Substation Material: 1. Two (2), 500kV, 63kAIC, 6000A, SF6 Circuit Breakers. 2. Four (4), 500kV, 6000A Double End Break Switches. 3. Three (3), 396kV, 318kV MCOV Station Class Surge Arresters. 4. Five (5), 500kV, Coupling Capacitor Voltage Transformers. 5. One (1), 500kV Backbone Structure (By Transmission) 6. Approximately 600 FT of 8 in. Sch. 40 AL tube bus. 7. Conductor, connectors, conduit, control cable, foundations, steel structures, and grounding material as necessary per engineering standards. Reuse Substation Material: 1. One (1), 500kV, Coupling Capacitor Voltage Transformer. Remove Substation Material: 1. One (1), 500kV, 50kAIC, 5000A, SF6 Circuit Breaker. 2. Two (2), 500kV, 5000A Double End Break Switches. 3. Approximately 600 FT 6IN. SCH 80 AL tube bus. 4. Conductor, connectors, conduit, control cable, foundations, steel structures, and grounding material as necessary per engineering standards. Reuse Relay Materials: 1. One (1), 4510 - SEL-2411 Equipment Annunciator 2. One (1), 1510 – Dual SEL-351 Transmission Breaker w/ Reclosing Panel 3. One (1), 1515 – Dual 500kV SEL-351 Transmission Breaker w/ Reclosing Panel 4. One (1), 4535 or 4536 – 500kV Circuit Breaker Condition Monitor 5. One (1), 4526_D – C.B. w/ BCM Fiber Optic Makeup Box Purchase &amp; Install Relay Material: 1. One (1), 4510 - SEL-2411 Equipment Annunciator 2. One (1), 1510 – Dual SEL-351 Transmission Breaker w/ Reclosing Panel 3. One (1), 1515 – Dual 500kV SEL-351 Transmission Breaker w/ Reclosing Panel 4. One (1), 4535 or 4536 – 500kV Circuit Breaker Condition Monitor 5. One (1), 1340 – Dual SEL-411L DCB/Fiber, CD/Fiber Line Panel (500kV w/ 2 Fiber Cables) 6. Two (2), 4506 – 3Ø CCVT Potential Makeup Box 7. One (1), 4526_D – C.B. w/ BCM Fiber Optic Makeup Box</p>
Transformer Information	
None	
New equipment description	<p>1. Two (2), 500kV, 63kAIC, 6000A, SF6 Circuit Breakers. 2. Four (4), 500kV, 6000A Double End Break Switches. 3. Three (3), 396kV, 318kV MCOV Station Class Surge Arresters. 4. Five (5), 500kV, Coupling Capacitor Voltage Transformers. 5. One (1), 4510 - SEL-2411 Equipment Annunciator 6. One (1), 1510 – Dual SEL-351 Transmission Breaker w/ Reclosing Panel 7. One (1), 1515 – Dual 500kV SEL-351 Transmission Breaker w/ Reclosing Panel 8. One (1), 4535 or 4536 – 500kV Circuit Breaker Condition Monitor 9. One (1), 1340 – Dual SEL-411L DCB/Fiber, CD/Fiber Line Panel (500kV w/ 2 Fiber Cables) 10. Two (2), 4506 – 3Ø CCVT Potential Makeup Box 11. One (1), 4526_D – C.B. w/ BCM Fiber Optic Makeup Box</p>
Substation assumptions	<p>1. The scope of work assumes that there is no overlap with other designs and construction activities, except if mentioned in this Project Summary. 2. 6-hole pad connections must be replaced with 8-hole pad connections to maintain 5000A ratings. 3. Relay Settings and P&amp;C design will be revised as part of the SPE Scope of Work. 4. Terminal ends must be upgraded to 6000A to ensure they are not the conductors limiting factor 5. It was determined that the GA would not need any additional equipment relocation thus it has been omitted from the submittal.</p>
Real-estate description	Substation is not being expanded.

Construction responsibility	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Benefits/Comments	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Component Cost Details - In Current Year \$	
Engineering & design	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Permitting / routing / siting	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
ROW / land acquisition	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Materials & equipment	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Construction & commissioning	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Construction management	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Overheads & miscellaneous costs	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Contingency	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Total component cost	\$6,710,869.10
Component cost (in-service year)	\$7,187,341.00
<b>Substation Upgrade Component</b>	
Component title	Vontay Substation Line Terminal
Project description	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Substation name	Vontay
Substation zone	345

Substation upgrade scope	<p>Purchase &amp; Install Substation Material: 1. Two (2), 500kV, 63kAIC, 6000A, SF6 Circuit Breakers. 2. Four (4), 500kV, 6000A Double End Break Switches. 3. Three (3), 396kV, 318kV MCOV Station Class Surge Arresters. 4. Five (5), 500kV, Coupling Capacitor Voltage Transformers. 5. One (1), 500kV Backbone Structure (By Transmission) 6. Approximately 600 FT of 8 in. Sch. 40 AL tube bus. 7. Conductor, connectors, conduit, control cable, foundations, steel structures, and grounding material as necessary per engineering standards. Reuse Substation Material: 1. One (1), 500kV, Coupling Capacitor Voltage Transformer. Remove Substation Material: 1. One (1), 500kV, 50kAIC, 5000A, SF6 Circuit Breaker. 2. Two (2), 500kV, 5000A Double End Break Switches. 3. Approximately 600 FT 6IN. SCH 80 AL tube bus. 4. Conductor, connectors, conduit, control cable, foundations, steel structures, and grounding material as necessary per engineering standards. Reuse Relay Materials: 1. One (1), 4510 - SEL-2411 Equipment Annunciator 2. One (1), 1510 – Dual SEL-351 Transmission Breaker w/ Reclosing Panel 3. One (1), 1515 – Dual 500kV SEL-351 Transmission Breaker w/ Reclosing Panel 4. One (1), 4535 or 4536 – 500kV Circuit Breaker Condition Monitor 5. One (1), 4526_D – C.B. w/ BCM Fiber Optic Makeup Box Purchase &amp; Install Relay Material: 1. One (1), 4510 - SEL-2411 Equipment Annunciator 2. One (1), 1510 – Dual SEL-351 Transmission Breaker w/ Reclosing Panel 3. One (1), 1515 – Dual 500kV SEL-351 Transmission Breaker w/ Reclosing Panel 4. One (1), 4535 or 4536 – 500kV Circuit Breaker Condition Monitor 5. One (1), 1340 – Dual SEL-411L DCB/Fiber, CD/Fiber Line Panel (500kV w/ 2 Fiber Cables) 6. Two (2), 4506 – 3Ø CCVT Potential Makeup Box 7. One (1), 4526_D – C.B. w/ BCM Fiber Optic Makeup Box</p>
Transformer Information	
None	
New equipment description	<p>1. Two (2), 500kV, 63kAIC, 6000A, SF6 Circuit Breakers. 2. Four (4), 500kV, 6000A Double End Break Switches. 3. Three (3), 396kV, 318kV MCOV Station Class Surge Arresters. 4. Five (5), 500kV, Coupling Capacitor Voltage Transformers. 5. One (1), 4510 - SEL-2411 Equipment Annunciator 6. One (1), 1510 – Dual SEL-351 Transmission Breaker w/ Reclosing Panel 7. One (1), 1515 – Dual 500kV SEL-351 Transmission Breaker w/ Reclosing Panel 8. One (1), 4535 or 4536 – 500kV Circuit Breaker Condition Monitor 9. One (1), 1340 – Dual SEL-411L DCB/Fiber, CD/Fiber Line Panel (500kV w/ 2 Fiber Cables) 10. Two (2), 4506 – 3Ø CCVT Potential Makeup Box 11. One (1), 4526_D – C.B. w/ BCM Fiber Optic Makeup Box</p>
Substation assumptions	<p>1. The scope of work assumes that there is no overlap with other designs and construction activities, except if mentioned in this Project Summary. 2. 6-hole pad connections must be replaced with 8-hole pad connections to maintain 5000A ratings. 3. Relay Settings and P&amp;C design will be revised as part of the SPE Scope of Work. 4. Terminal ends must be upgraded to 6000A to ensure they are not the conductors limiting factor 5. It was determined that the GA would not need any additional equipment relocation thus it has been omitted from the submittal.</p>
Real-estate description	Substation is not being expanded.
Construction responsibility	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Benefits/Comments	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Component Cost Details - In Current Year \$	
Engineering & design	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Permitting / routing / siting	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
ROW / land acquisition	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Materials & equipment	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Construction & commissioning	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Construction management	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Overheads & miscellaneous costs	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Contingency	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
Total component cost	\$6,710,869.10
Component cost (in-service year)	\$7,187,341.00

## Congestion Drivers

None

## Existing Flowgates

None

## New Flowgates

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

## Financial Information

Capital spend start date	01/2026
--------------------------	---------

Construction start date	06/2029
-------------------------	---------

Project Duration (In Months)	77
------------------------------	----

## Cost Containment Commitment

Cost cap (in current year)	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
----------------------------	---

Cost cap (in-service year)	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
----------------------------	---

### Components covered by cost containment

1. New 500 kV Line - North Anna to Vontay - Dominion

2. North Anna Substation Line Terminal - Dominion

### Cost elements covered by cost containment

Engineering & design	Yes
----------------------	-----

Permitting / routing / siting	No
-------------------------------	----

ROW / land acquisition	No
------------------------	----

Materials & equipment	No
-----------------------	----

Construction & commissioning	No
------------------------------	----

Construction management	No
-------------------------	----

Overheads & miscellaneous costs	No
---------------------------------	----

Taxes	No
-------	----

AFUDC	No
-------	----

Escalation	No
------------	----

Additional Information	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.
------------------------	---

Is the proposer offering a binding cap on ROE?	Yes
--	-----



Would this ROE cap apply to the determination of AFUDC?

Yes

Would the proposer seek to increase the proposed ROE if FERC finds that a higher ROE would not be unreasonable?

No

Is the proposer offering a Debt to Equity Ratio cap?

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

## Additional Comments

None