McCanns Rd 138 kV Switching Station

General Information

Proposing entity name

Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project?

Confidential Information

Confidential Information

Confidential Information

Company proposal ID

PJM Proposal ID 631

Project title McCanns Rd 138 kV Switching Station

Project description Construct the McCanns Rd 138 kV Switching Station and interconnect the existing Redbud – West

Winchester 138 kV Line and Bartonville - Stephenson 138 kV Line.

Email Confidential Information

Project in-service date 06/2030

Tie-line impact No

Interregional project No

Is the proposer offering a binding cap on capital costs?

Additional benefits Confidential Information

Project Components

1. McCanns Rd 138 kV Switching Station

2. Redbud - McCanns Rd 138 kV Line

Greenfield Substation Component

Component title McCanns Rd 138 kV Switching Station

2025-W1-631

Project description

Substation name

Substation description

Nominal voltage

Nominal voltage

Transformer Information

None

Major equipment description

Confidential Information

McCanns Rd

Construct McCanns Rd 138 kV Switching Station with four 138 kV circuit breakers in a ring bus configuration, expandable to a six breaker ring bus for future growth. Loop in the Redbud – West Winchester 138 kV Line and the Bartonville – Stephenson 138 kV Line, which share structures and are primarily constructed on double circuit steel monopoles in a vertical configuration. All new angle and dead-end structures will be engineered steel poles on drilled shaft foundations and all in-line tangent structures will be direct-embed light duty steel/wood pole equivalent poles. The new conductor will match the existing conductor which is 954 KCMIL45/7 ACSR.

AC

138

At McCanns Rd Switching Station: Install (1 Lot) of conduit, grounding, and foundations for substation expansion. Install (805) feet of fencing, (2) gates. Install driveway. Install (125) feet of cable trench. - Install (4) 138 kV H-Frame dead-end structures. - Install (1) Prefabricated control enclosure (36'x15'). - Install (4) 138kV Circuit breakers, 63 kA, 3000 A. - Install (8) 138kV GOAB disconnect switches, 2000 A. - Install (4) 138kV MOAB disconnect switches, 2000 A. - Install (12) 138 kV Surge arresters. - Install (12) 138kV CVT's. - Install (2) 138 kV Line Traps, Tuners and Coax, 2000 A. - Install (2) 138 kV SSVT's. - Install (1 Lot) of rigid bus, connectors and support structures. - Install substation lighting. - Install (4) Standard breaker panels, consisting of (1) SEL-451 relays with dedicated LOR. - Install (2) Standard line panels, consisting of (2) SEL-411L, over fiber (Redbud and Stephenson 138kV Line Terminals). - Install (2) Standard line panels, consisting of (1) SEL-421, (1) SEL-411L (Bartonville and West Winchester 138 kV Line terminals). -Install (2) carrier panels, consisting of (1) PCM5350, & (1) UPLC-II relays (Bartonville & West Winchester 138kV Line Terminals). - Install (1 Lot) of Control Cables. At Bartonville, West Winchester, Stephenson and Redbud Substations: - Install (3) FE Standard Line Relay Panel consisting of (1) SEL 421, (1) SEL-411L, (1) UPLC-II and (1) PCM 5350 (over PLC). - Install (3) FE Standard Breaker Panel consisting of (1) SEL-451, (1) UPLC -II and (1) PCM 5350(over PLC). -Install (3 Lot) of Control Cables. - Install (1) wave trap and line tuner at Bartonville Substation. -Replace limiting conductor at West Winchester Substation. Bartonville - Stephenson 138 kV Line and Redbud - West Winchester 138 kV Line Cut-ins: - Install (0.1) miles of 3-phase 954 KCMIL 45/7 ACSR conductor shielded by (1) 7#9 Alumoweld wire. - Install (1) SC steel monopole dead-end structure, like TR-138325, drilled shaft foundation. - Install (2) DC steel monopole dead-end structures, like TR-138375, drilled shaft foundations.

	Normal ratings	Emergency ratings		
Summer (MVA)	308.000000	376.000000		
Winter (MVA)	349.000000	445.000000		
Environmental assessment	An environmental review will be required to identify any additional construction constraints or additional permitting requirements. Road Bonds, Environmental Filming Documentation of Existing roads, Environmental Development of Permit Binder, Environmental Cultural Resource Consultation, Environmental Construction Walk down, Wetland delineations and WDR are required. ETR consultation letters are included. Stormwater permits and local approvals are anticipated.			
Outreach plan	other key stakeholders on the need for, and ber approach to public outreach is to be always can and means for directly impacted parties to enga	ate, and local agencies; local governments; and nefits of, this Project. The Proposing Entity's did and transparent, and to offer a variety of tools ge with our staff. The Proposing Entity will provide als, key stakeholders, and impacted parties as the volve collecting information about landowner		
Land acquisition plan	easement will be required along the new lines e on the new substation property. Real estate cos including permitting, document review, project p assistance with transfer of assets if required E acquisition (assuming voluntary, no condemnati required Easement digitization and other GIS rights and associated fees such as recording co	elanning meetings, subcontractor oversight and External support for general project support, ion); assuming no field construction support will be support provided Cost of purchasing new land lests or permits (estimated - actual cost will depend d negotiations) Access roads Recording fees:		
Construction responsibility	Confidential Information			
Benefits/Comments	Confidential Information			
Component Cost Details - In Current Year \$				
Engineering & design	Confidential Information			
Permitting / routing / siting	Confidential Information			

ROW / land acquisition Confidential Information

Materials & equipment Confidential Information

Construction & commissioning Confidential Information

Construction management Confidential Information

Overheads & miscellaneous costs Confidential Information

Contingency Confidential Information

Total component cost \$18,832,333.88

Component cost (in-service year) \$21,082,005.00

Transmission Line Upgrade Component

Component title Redbud - McCanns Rd 138 kV Line

Project description Confidential Information

Impacted transmission line Redbud - McCanns Rd 138 kV Line

Point A Redbud

Point B McCanns Rd

Point C

Terrain description Terrain is Flat. Access roads will be required along entire line route. Access Roads Assumptions: -

If required, Forestry will have clearing accomplished prior to access road construction start.

Existing Line Physical Characteristics

Operating voltage 138

Conductor size and type 556.5 KCMIL 26/7 ACSR

2025-W1-631

Hardware plan description
Tower line characteristics
Proposed Line Characteristics
Voltage (kV)
Summer (MVA)
Winter (MVA)
Conductor size and type
Shield wire size and type
Rebuild line length
Rebuild portion description
Right of way
Construction responsibility
Benefits/Comments

The existing conductor is 556.5 KCMIL 26/7 ACSR shielded by (2) 1/2" 7-Strand EHS steel wires. The new Redbud - McCanns Rd 138 kV Line will utilize 3-phase 795 KCMIL 45/7 ACSS conductor shielded by (1) SFSJ-J-6641 OPGW and (1) 7#9 Alumoweld wire for 0.5 miles. This project replaces limiting substation conductors, (1) 138 kV circuit breaker, and (2) 138 kV disconnect switches at Redbud 138 kV Substation to match the ratings of the new conductor.

The existing line is constructed on single circuit wood multi-pole structures in a horizontal configuration. Due to an increase in conductor size from 556.5 ACSR to 795 ACSS 45/7, it is assumed that a full rebuild of the existing line will be required. The potential of reusing the existing structures was not evaluated. The new structures will be steel H-Frame structures.

Designed	Operating
138.000000	138.000000
Normal ratings	Emergency ratings
435.000000	500.000000
435.000000	526.000000
795 KCMIL 45/7 ACSS	

SFSJ-J-6641 OPGW and 7#9 Alumoweld wire

0.5 miles

Rebuild new Redbud McCanns Rd 138 kV Line with 795 KCMIL 45/7 ACSS for 0.5 miles from Redbud 138 kV Substation to Str. 175 of the existing Redbud - West Winchester 138 kV Line at approximate coordinates (39.217478, -78.128621).

It is assumed all construction work areas (including wire-pulling sites) are located within the ROW. A rights and restrictions review by Real Estate will be required. Georeferenced ROW extents will be required to be provided to engineering.

Confidential Information

Confidential Information

Component Cost Details - In Current Year \$

Engineering & design Confidential Information

Permitting / routing / siting Confidential Information

ROW / land acquisition Confidential Information

Materials & equipment Confidential Information

Construction & commissioning Confidential Information

Construction management Confidential Information

Overheads & miscellaneous costs Confidential Information

Contingency Confidential Information

Total component cost \$5,038,249.99

Component cost (in-service year) \$5,524,125.00

Congestion Drivers

None

Existing Flowgates

FG#	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	СКТ	Voltage	TO Zone	Analysis type	Status
2025W1-N11-WT24	235502	01REDBUD	235519	01W WINC	1	138	201	N-1-1 Thermal	Excluded
2025W1-N11-WT23	235457	01DTG	235474	01GREENW	1	138	201	N-1-1 Thermal	Excluded
2025W1-N11-ST8	235457	01DTG	235474	01GREENW	1	138	201	N-1-1 Thermal	Excluded
2025W1-N11-ST7	235502	01REDBUD	235519	01W WINC	1	138	201	N-1-1 Thermal	Excluded
2025W1-N11-WLD1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N-1-1 Load Drop	Included
2025W1-N11-WLD2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N-1-1 Load Drop	Included

New Flowgates

2025-W1-631

Confidential Information

Financial Information

Capital spend start date 12/2025

Construction start date 07/2029

Project Duration (In Months) 54

Additional Comments

None