Roseland - Livingston & Roseland - Laurel 230kV Reconductoring

General Information

Proposing entity name Confidential

Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project?

Confidential

Company proposal ID Confidential

PJM Proposal ID 656

Project title Roseland - Livingston & Roseland - Laurel 230kV Reconductoring

Project description Thermal overloads have been identified on the 230kV overhead circuits from Roseland to Livingston

and from Roseland to Laurel. This proposal will upgrade both lines by replacing their conductors

with ones that have a higher MVA capacity to address these thermal violations.

Email Confidential

Project in-service date 03/2028

Tie-line impact No

Interregional project No

Is the proposer offering a binding cap on capital costs?

Additional benefits Confidential

Project Components

1. Roseland - Livingston 230kV

2. Roseland - Laurel Avenue 230kV

Transmission Line Upgrade Component

Component title Roseland - Livingston 230kV

2025-W1-656

Project description Confidential Impacted transmission line Roseland - Livingston 230kV Point A Roseland Point B Livingston Point C Terrain description Rolling terrain in suburban New Jersey **Existing Line Physical Characteristics** Operating voltage 230 Conductor size and type 1590 kcmil ACSR "Falcon" conductor Hardware plan description New hardware will be used for the reconductoring. Existing OPGW hardware will remain as-is. The existing structures on this circuit were installed in 2013. There is no need for structural repair or Tower line characteristics reinforcement to re-conductor the line. **Proposed Line Characteristics** Designed Operating Voltage (kV) 230.000000 230.000000 Normal ratings **Emergency ratings** Summer (MVA) 934.000000 1080.000000 Winter (MVA) 999.000000 1143.000000 1590 kcmil ACSS "Falcon" Conductor size and type Shield wire size and type N/A - existing shield wire to remain Rebuild line length 1 mile Rebuild portion description No portion of the line will be rebuilt. The existing structures will remain as-is

2025-W1-656

Right of way

No new ROW is needed for reconductoring the circuit.

Construction responsibility Confidential

Benefits/Comments Confidential

Component Cost Details - In Current Year \$

Engineering & design Confidential

Permitting / routing / siting Confidential

ROW / land acquisition Confidential

Materials & equipment Confidential

Construction & commissioning Confidential

Construction management Confidential

Overheads & miscellaneous costs Confidential

Contingency Confidential

Total component cost \$4,873,397.00

Component cost (in-service year) \$5,209,309.11

Transmission Line Upgrade Component

Component title Roseland - Laurel Avenue 230kV

Project description Confidential

Impacted transmission line Roseland - Laurel 230kV

Point A Roseland

Point B Laurel

Point C

Terrain description Rolling terrain in suburban New Jersey

Existing Line Physical Characteristics

Operating voltage 230

Conductor size and type 1590 kcmil ACSR "Falcon" conductor

Hardware plan description New hardware will be used for the reconductoring. Existing OPGW hardware will remain as-is.

Tower line characteristics The existing structures on this circuit were installed in 2013. There is no need for structural repair or

reinforcement to re-conductor the line.

Proposed Line Characteristics

Designed Operating

Voltage (kV) 230.000000 230.000000

Normal ratings Emergency ratings

Summer (MVA) 934.000000 1080.000000

Winter (MVA) 999.000000 1143.000000

Conductor size and type 1590 kcmil ACSS "Falcon"

Shield wire size and type N/A

Rebuild line length 2.36 miles

Rebuild portion description

No portion of the line will be rebuilt. The existing structures will remain as-is

Right of way No new ROW is needed for reconductoring the circuit.

Construction responsibility Confidential

Benefits/Comments Confidential

Component Cost Details - In Current Year \$

Engineering & design Confidential

Permitting / routing / siting Confidential

ROW / land acquisition Confidential

Materials & equipment Confidential

Construction & commissioning Confidential

Construction management Confidential

Overheads & miscellaneous costs Confidential

Contingency Confidential

Total component cost \$5,058,254.00

Component cost (in-service year) \$5,406,910.96

Congestion Drivers

None

Existing Flowgates

FG#	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	СКТ	Voltage	TO Zone	Analysis type	Status
2025W1-N11-ST158	216950	ROSELAND	217997	LIVINGSTON	1	230	231	N-1-1 Thermal	Included
2025W1-N11-ST159	216950	ROSELAND	217997	LIVINGSTON	1	230	231	N-1-1 Thermal	Included
2025W1-IPD-S188	216950	ROSELAND	217997	LIVINGSTON	1	230	231	Individual Plant Deliverability	Included
2025W1-N11-ST160	216950	ROSELAND	216973	LAUREL_J	1	230	231	N-1-1 Thermal	Included
2025W1-N11-ST161	216950	ROSELAND	216973	LAUREL_J	1	230	231	N-1-1 Thermal	Included
2025W1-N11-ST156	216950	ROSELAND	217997	LIVINGSTON	1	230	231	N-1-1 Thermal	Included
2025W1-IPD-S185	216950	ROSELAND	217997	LIVINGSTON	1	230	231	Individual Plant Deliverability	Included
2025W1-N11-ST157	216950	ROSELAND	217997	LIVINGSTON	1	230	231	N-1-1 Thermal	Included

New Flowgates

Confidential

Financial Information

Capital spend start date 03/2026

Construction start date 01/2028

Project Duration (In Months) 24

Additional Comments

None