

# 220-85 Linwood-Edgemoor 230 kV Tie-Line Facility Upgrade

## General Information

Proposing entity name	PE
Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project?	Yes
Company proposal ID	
PJM Proposal ID	758
Project title	220-85 Linwood-Edgemoor 230 kV Tie-Line Facility Upgrade
Project description	Rebuild 220-85 230 kV Tie-line from Linwood to Edgemoor substation and upgrade terminal equipment at Edgemoor substation to meet future capacity requirements.
Email	Proprietary Information
Project in-service date	05/2032
Tie-line impact	Yes
Interregional project	No
Is the proposer offering a binding cap on capital costs?	No
Additional benefits	This project helps alleviate overloads identified in 2032 Scenario 4 generation deliverability studies with the addition of the PPL load idvs to the cases. The increased 220-85 Tie-line capacity should help with projected load growth on the transmission system.

## Project Components

1. Rebuild 220-85 Linwood-Edgemoor 230 kV Tie-line (PECO Portion)
2. Rebuild 220-85 Linwood-Edgemoor 230 kV Tie-line (DPL Portion)
3. Edgemoor Substation Upgrades (DPL)

## Transmission Line Upgrade Component

Component title	Rebuild 220-85 Linwood-Edgemoor 230 kV Tie-line (PECO Portion)	
Project description	Rebuild the 220-85 Linwood-Edgemoor 230 kV Tie-line (PECO Portion) utilizing Dual 959.6 ACSS/TW "Suwannee" conductor.	
Impacted transmission line	220-85	
Point A	Linwood Substation	
Point B	Edgemoor Substation	
Point C		
Terrain description	Generally flat along Amtrak ROW.	
Existing Line Physical Characteristics		
Operating voltage	230	
Conductor size and type	Single 1590 ACSR "Falcon"	
Hardware plan description	The existing hardware will be replaced. OPGW fiber will be installed the entire length.	
Tower line characteristics	Existing transmission structures are inadequate to support proposed Dual 959.6 ACSS/TW "Suwannee" conductor.	
Proposed Line Characteristics		
	Designed	Operating
Voltage (kV)	230.000000	230.000000
	Normal ratings	Emergency ratings
Summer (MVA)	1523.000000	1767.000000
Winter (MVA)	1597.000000	1843.000000
Conductor size and type	Dual 959.6 ACSS/TW "Suwannee"	

Shield wire size and type	OPGW fiber (0.638" 96-count)
Rebuild line length	.55 miles
Rebuild portion description	The entire length is proposed to be rebuilt.
Right of way	Existing ROW should be adequate.
Construction responsibility	PECO
Benefits/Comments	Upgrade transmission line to meet future capacity needs.
Component Cost Details - In Current Year \$	
Engineering & design	detailed cost
Permitting / routing / siting	detailed cost
ROW / land acquisition	detailed cost
Materials & equipment	detailed cost
Construction & commissioning	detailed cost
Construction management	detailed cost
Overheads & miscellaneous costs	detailed cost
Contingency	detailed cost
Total component cost	\$4,162,533.00
Component cost (in-service year)	\$4,730,542.58
<b>Transmission Line Upgrade Component</b>	
Component title	Rebuild 220-85 Linwood-Edgemoor 230 kV Tie-line (DPL Portion)
Project description	Rebuild the 220-85 Linwood-Edgemoor 230 Tie-Line (DPL Portion) utilizing Dual 1590 ACSR "Lapwing" conductor.
Impacted transmission line	220-85

Point A	Linwood Substation	
Point B	Edgemoor Substation	
Point C		
Terrain description	Generally flat along Amtrak ROW.	
Existing Line Physical Characteristics		
Operating voltage	230	
Conductor size and type	Single 1590 ACSR "Lapwing"	
Hardware plan description	The existing hardware will be replaced. OPGW fiber (0.638" 96-count) will be installed the entire length.	
Tower line characteristics	Existing transmission structures are inadequate to support proposed Dual 1590 ACSR "Lapwing" conductor.	
Proposed Line Characteristics		
	Designed	Operating
Voltage (kV)	230.000000	230.000000
	Normal ratings	Emergency ratings
Summer (MVA)	1308.000000	1618.000000
Winter (MVA)	1506.000000	1822.000000
Conductor size and type	Dual 1590 ACSR "Lapwing"	
Shield wire size and type	OPGW fiber (0.638" 96-count)	
Rebuild line length	7.5 miles	
Rebuild portion description	The entire length is proposed to be rebuilt.	
Right of way	Existing ROW should be adequate.	

Construction responsibility	DPL
Benefits/Comments	Upgrade transmission line to meet future capacity needs.
Component Cost Details - In Current Year \$	
Engineering & design	detailed cost
Permitting / routing / siting	detailed cost
ROW / land acquisition	detailed cost
Materials & equipment	detailed cost
Construction & commissioning	detailed cost
Construction management	detailed cost
Overheads & miscellaneous costs	detailed cost
Contingency	detailed cost
Total component cost	\$71,679,998.00
Component cost (in-service year)	\$83,261,960.65
<b>Substation Upgrade Component</b>	
Component title	Edgemoor Substation Upgrades (DPL)
Project description	Upgrade 220-85 Terminal Equipment at Edgemoor Substation.
Substation name	Edgemoor Substation
Substation zone	DPL
Substation upgrade scope	Upgrade existing 220-85 facility to meet a 3000A rating. Replace existing (3) combination PT/CT metering instrumentation units with (3) 230kV; Combination; Meter Accuracy; 1-Ph (similar to model KOTEF245.ER). Replace existing (1) 2-1033.5 AAC stranded bus with (1) 2-1590 ACSR. Replace existing (1) 3.5" rigid bus with 5" AL EHV.
<b>Transformer Information</b>	

None

New equipment description

Upgrade existing 220-85 facility to meet a 3000A rating. Replace existing (3) combination PT/CT metering instrumentation units with (3) 230kV; Combination; Meter Accuracy; 1-Ph (similar to model KOTEF245.ER). Replace existing (1) 2-1033.5 AAC stranded bus with (1) 2-1590 ACSR. Replace existing (1) 3.5" rigid bus with 5" AL EHV.

Substation assumptions

It is assumed that no civil/structural work is required.

Real-estate description

Construction responsibility

DPL

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design

detailed cost

Permitting / routing / siting

detailed cost

ROW / land acquisition

detailed cost

Materials & equipment

detailed cost

Construction & commissioning

detailed cost

Construction management

detailed cost

Overheads & miscellaneous costs

detailed cost

Contingency

detailed cost

Total component cost

\$1,007,775.00

Component cost (in-service year)

\$1,102,889.74

**Congestion Drivers**

None

Existing Flowgates

None

New Flowgates

FG #	From Bus No.	From Bus Name	To Bus No.	To Bus Name	CKT	Voltage	TO Zone	Analysis type
FG-758-1	231001	EDGEMR 5	214236	LINWOOD85	1	230	DPL	2032 Generation Deliverability
FG-758-2	231001	EDGEMR 5	214236	LINWOOD85	1	230	PECO	2032 Generation Deliverability

Financial Information

Capital spend start date	01/2026
Construction start date	04/2028
Project Duration (In Months)	76

Additional Comments

None