

Frackville - Siegfried 500 kV line

General Information

| | |
|---|--|
| Proposing entity name | Proprietary Information |
| Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project? | Proprietary Information |
| Company proposal ID | Proprietary Information |
| PJM Proposal ID | 794 |
| Project title | Frackville - Siegfried 500 kV line |
| Project description | Adjacent to the existing Frackville - Siegfried 230 kV line, construct a 40-mile Frackville - Siegfried 500 kV line using 1113 ACSS 54/19 conductor. Build a Frackville 500 kV yard adjacent to the existing Frackville 230/69 kV Substation. Construct a three bay 500 kV breaker and a half design with six 500 kV 4,000 amp circuit breakers, and twelve 500 kV 4,000 amp MODs (with space for a total of five bays in the final design). |
| Email | Proprietary Information |
| Project in-service date | 05/2030 |
| Tie-line impact | No |
| Interregional project | No |
| Is the proposer offering a binding cap on capital costs? | Yes |
| Additional benefits | Proprietary Information |

Project Components

1. Frackville - Siegfried 500 kV line
2. Frackville 500 kV yard upgrade

Transmission Line Upgrade Component

| | | |
|--|--|-------------------|
| Component title | Frackville - Siegfried 500 kV line | |
| Project description | Proprietary Information | |
| Impacted transmission line | Frackville - Siegfried 230 kV line | |
| Point A | Frackville | |
| Point B | Siegfried | |
| Point C | | |
| Terrain description | Terrain is comprised of mountains punctuated by valleys dominated by farming. | |
| Existing Line Physical Characteristics | | |
| Operating voltage | 230 | |
| Conductor size and type | 795 ACSR 30/19 conductor, 1590 ACSS 54/19 conductor | |
| Hardware plan description | The existing Siegfried - Frackville 230 kV line will not be touched for this project. This project will be constructed adjacent to the existing 230 kV line. | |
| Tower line characteristics | The existing Siegfried - Frackville 230 kV line will not be touched for this project. This project will be constructed adjacent to the existing 230 kV line. | |
| Proposed Line Characteristics | | |
| | Designed | Operating |
| Voltage (kV) | 500.000000 | 500.000000 |
| | Normal ratings | Emergency ratings |
| Summer (MVA) | 3610.000000 | 4150.000000 |
| Winter (MVA) | 4276.000000 | 4755.000000 |
| Conductor size and type | Triple bundle 1113 54/19 ACSS conductor | |

| | |
|---|--|
| Shield wire size and type | OPGW |
| Rebuild line length | No line rebuild is involved in this project component. 500 kV line will be constructed adjacent to existing 230 kV line |
| Rebuild portion description | No line rebuild is involved in this project component. The 500 kV line will be constructed adjacent to the existing 230 kV line. |
| Right of way | Developer will provide comprehensive Siting and Right of Way (ROW) support starting with project development through construction and site restoration/project close out, to construct a new 500 kV transmission line between Developer's existing Frackville and Siegfried Substations. Siting will prepare and file a Full Siting Application (FSA) with the Pennsylvania Public Utility Commission (PUC) to obtain necessary approvals. A FSA is required for constructing the new 500 kV Line. Developer proposes to utilize an existing 500 kV future use ROW corridor and acquire additional ROW where necessary to accommodate the 500 kV transmission line project. Potential siting and ROW risks include potential interveners in the Siting approval process (impact to schedule) and ROW acquisition. The Siting and ROW Teams will engage proactively with landowners in the local community and serve as project liaisons to address landowner questions and maintain positive relationships throughout the project lifecycle. These efforts will include communicating the project and construction details, as well as calculating and issuing compensation for any crop damages resulting from the project. |
| Construction responsibility | Proprietary Information |
| Benefits/Comments | Proprietary Information |
| Component Cost Details - In Current Year \$ | |
| Engineering & design | Proprietary Information |
| Permitting / routing / siting | Proprietary Information |
| ROW / land acquisition | Proprietary Information |
| Materials & equipment | Proprietary Information |
| Construction & commissioning | Proprietary Information |
| Construction management | Proprietary Information |
| Overheads & miscellaneous costs | Proprietary Information |
| Contingency | Proprietary Information |

| | |
|----------------------|------------------|
| Total component cost | \$207,334,350.58 |
|----------------------|------------------|

| | |
|----------------------------------|------------------|
| Component cost (in-service year) | \$232,865,655.49 |
|----------------------------------|------------------|

Substation Upgrade Component

| | |
|-----------------|--------------------------------|
| Component title | Frackville 500 kV yard upgrade |
|-----------------|--------------------------------|

| | |
|---------------------|-------------------------|
| Project description | Proprietary Information |
|---------------------|-------------------------|

| | |
|-----------------|---------------------------------|
| Substation name | Frackville 230/69 kV Substation |
|-----------------|---------------------------------|

| | |
|-----------------|--------|
| Substation zone | PPL EU |
|-----------------|--------|

| | |
|--------------------------|---|
| Substation upgrade scope | Build a Frackville 500 kV yard adjacent to the existing Frackville 230/69 kV Substation. Construct a three bay 500 kV breaker and a half design with six 500 kV 4,000 amp circuit breakers, and twelve 500 kV 4,000 amp MODs (with space for a total of five bays in the final design). |
|--------------------------|---|

Transformer Information

None

| | |
|---------------------------|---|
| New equipment description | Three 500 kV breaker and a half bays Six 500 kV 4,000 amp circuit breakers Twelve 500 kV 4,000 amp MODs |
|---------------------------|---|

| | |
|------------------------|---|
| Substation assumptions | Developer has reviewed existing property ownership and determined space is sufficient for the 500 kV yard addition. |
|------------------------|---|

| | |
|-------------------------|---|
| Real-estate description | No new real estate is required to accommodate this project. |
|-------------------------|---|

| | |
|-----------------------------|-------------------------|
| Construction responsibility | Proprietary Information |
|-----------------------------|-------------------------|

| | |
|-------------------|-------------------------|
| Benefits/Comments | Proprietary Information |
|-------------------|-------------------------|

Component Cost Details - In Current Year \$

| | |
|----------------------|-------------------------|
| Engineering & design | Proprietary Information |
|----------------------|-------------------------|

| | |
|-------------------------------|-------------------------|
| Permitting / routing / siting | Proprietary Information |
|-------------------------------|-------------------------|

| | |
|------------------------|-------------------------|
| ROW / land acquisition | Proprietary Information |
|------------------------|-------------------------|

| | |
|-----------------------|-------------------------|
| Materials & equipment | Proprietary Information |
|-----------------------|-------------------------|

| | |
|----------------------------------|-------------------------|
| Construction & commissioning | Proprietary Information |
| Construction management | Proprietary Information |
| Overheads & miscellaneous costs | Proprietary Information |
| Contingency | Proprietary Information |
| Total component cost | \$46,162,373.03 |
| Component cost (in-service year) | \$51,880,109.30 |

Congestion Drivers

None

Existing Flowgates

| FG # | Fr Bus No. | From Bus Name | To Bus No. | To Bus Name | CKT | Voltage | TO Zone | Analysis type | Status |
|------------------|------------|---------------|------------|-------------|-----|---------|---------|--------------------------------|----------|
| 2025W1-GD-S478 | 207973 | FRAC | 208072 | SIEG | 1 | 230 | 229 | Generation Deliverability | Included |
| 2025W1-32GD-S128 | 207973 | FRAC | 208072 | SIEG | 1 | 230 | 229 | 2032 Generation Deliverability | Included |

New Flowgates

Proprietary Information

Financial Information

| | |
|------------------------------|---------|
| Capital spend start date | 02/2026 |
| Construction start date | 03/2028 |
| Project Duration (In Months) | 51 |

Cost Containment Commitment

| | |
|----------------------------|-------------------------|
| Cost cap (in current year) | Proprietary Information |
|----------------------------|-------------------------|

| | |
|--|-------------------------|
| Cost cap (in-service year) | Proprietary Information |
| Components covered by cost containment | |
| 1. Frackville - Siegfried 500 kV line - PPL | |
| 2. Frackville 500 kV yard upgrade - PPL | |
| Cost elements covered by cost containment | |
| Engineering & design | Yes |
| Permitting / routing / siting | Yes |
| ROW / land acquisition | Yes |
| Materials & equipment | Yes |
| Construction & commissioning | Yes |
| Construction management | Yes |
| Overheads & miscellaneous costs | Yes |
| Taxes | No |
| AFUDC | No |
| Escalation | Yes |
| Additional Information | Proprietary Information |
| Is the proposer offering a binding cap on ROE? | No |
| Is the proposer offering a Debt to Equity Ratio cap? | Proprietary Information |
| Additional Comments | |
| None | |