Line 576 Partial Rebuild - Vontay to Midlothian

General Information

Proposing entity name

Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project?

Company proposal ID

PJM Proposal ID

Project title

Project description

Email

Project in-service date

Tie-line impact

Interregional project

Is the proposer offering a binding cap on capital costs?

Additional benefits

Project Components

1. Line 576 Rebuild - Vontay to Midlothian

2. Midlothian Equipment Upgrade

Transmission Line Upgrade Component

Component title

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

9

Line 576 Partial Rebuild - Vontay to Midlothian

Rebuild 500 kV line 576 from Vontay Substation to Midlothian Substation using 6,000A, 500 kV conductor. Line 576 will cut-in to the new Vontay substation in a different proposal. Upgrade/install 6000A equipment at substations to support the new conductor termination.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

06/2032

No

No

Yes

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Line 576 Rebuild - Vontay to Midlothian

2025-W1-9

Project description The redacted information is proprietary to the Company; therefore, it is privileged and confidential. Impacted transmission line Line 576 Point A Vontay Point B Midlothian Point C Terrain description The project area is in the central Virginia Piedmont region with elevations ranging from approximately 130 to 260 feet. The terrain is predominately vegetated existing right-of-way with several areas of dense residential development consisting of minimal slopes. The line will include rebuilt crossings of Interstate 64, Jefferson Highway (Route 33), Midlothian Turnpike (Route 60), CSX railroads, Lake Anna, the James River, and the Little River. The line starts in Louisa County and runs through Hanover County, Goochland County, and Powhatan County, and terminates in Chesterfield County. **Existing Line Physical Characteristics** Operating voltage 500 2-2500 ACAR (84/7) 90°C MOT Conductor size and type New hardware will be used for line rebuild. Hardware plan description Existing Structures will be removed and new structures will be used for this rebuild. Tower line characteristics **Proposed Line Characteristics** Designed Operating Voltage (kV) 500.000000 500.000000 Normal ratings **Emergency ratings** Summer (MVA) 5109.000000 5268.000000 Winter (MVA) 5691.000000 5691.000000 3-1351 ACSS/TW/HS285 145° C MOT Conductor size and type

2025-W1-9

Shield wire size and type

Rebuild line length

Rebuild portion description

Right of way

Construction responsibility

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design

Permitting / routing / siting

ROW / land acquisition

Materials & equipment

Construction & commissioning

Construction management

Overheads & miscellaneous costs

Contingency

Total component cost

(2) DNO-10110 OPGW wire

20 Miles

EXISTING FACILITIES TO BE REMOVED: 1. Remove two (2) existing single circuit 5DE tower structures. 2. Remove existing single circuit 5HA tower structures. 3. Remove existing single circuit 5HT tower structures. 4. Remove existing single circuit 5LA tower structures. 5. Remove existing single circuit 5LT tower structures. 6. Remove existing single circuit 5MA tower structures. 7. Remove existing single circuit 5MT tower structures. 8. Remove one (1) existing single circuit 2-pole H-frame structures. 9. Remove approximately 20 miles of 2-2500 ACAR (84/7) conductor. 10. Remove approximately 20 miles of two (2) fiber optic GW 45/45 MM2 614. PERMANENT FACILITIES TO BE INSTALLED: 1. Install 500kV 5-2 KT Tower on foundations. 2. Install 500kV 5-2 MA Tower on foundations. 3. Install 500/230kV 3 Pole Steel DC DDE Heavy Angle on foundations. 4. Install 500/230kV 3 Pole Steel DC DDE Small/Medium Angle on foundations. 5. Install approximately 20 miles of two (2) DNO-10100 OPGW wire. 6. Install approximately 20 miles of three 3-phase 3-1351 ACSS conductor.

Existing Right-of-Way shall be used.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

\$102,700,058.00

2025-W1-9

Component cost (in-service year) **Substation Upgrade Component** Component title Project description Substation name Substation zone Substation upgrade scope Transformer Information None New equipment description Substation assumptions Real-estate description Construction responsibility Benefits/Comments Component Cost Details - In Current Year \$ Engineering & design Permitting / routing / siting ROW / land acquisition Materials & equipment Construction & commissioning

\$109,991,762.00

Midlothian Equipment Upgrade

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Midlothian

345

Replace four (4) 500kV, 3000 A Double End Break switches with 6000A switches. Replace/install associated equipment including CCVTs, wave traps and relay equipment.

Replace four (4) 500kV, 6000 A Double End Break switches

1. The scope of work assumes that there is no overlap with other designs and construction activities, except if mentioned in this Project Summary. 2. Pad connections must be replaced to maintain 6000A ratings. 3. Relay Settings and P&C design will be revised as part of the SPE Scope of Work.

No additional real estate needed

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

2025-W1-9 4

Construction management

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Overheads & miscellaneous costs

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Contingency

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Total component cost

\$2,158,171.20

Component cost (in-service year)

\$2,311,401.00

Congestion Drivers

None

Existing Flowgates

None

New Flowgates

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Financial Information

Capital spend start date 01/2026

Construction start date 06/2029

Project Duration (In Months) 77

Cost Containment Commitment

Cost cap (in current year)

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Cost cap (in-service year)

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Components covered by cost containment

2025-W1-9 5

2. Midlothian Equipment Upgrade - Dominion Cost elements covered by cost containment Engineering & design Yes Permitting / routing / siting No ROW / land acquisition No Materials & equipment No Construction & commissioning No Construction management No Overheads & miscellaneous costs No Taxes No **AFUDC** No Escalation No The redacted information is proprietary to the Company; therefore, it is privileged and confidential. Additional Information Is the proposer offering a binding cap on ROE? Yes Would this ROE cap apply to the determination of AFUDC? Yes Would the proposer seek to increase the proposed ROE if FERC No finds that a higher ROE would not be unreasonable?

Additional Comments

Is the proposer offering a Debt to Equity Ratio cap?

1. Line 576 Rebuild - Vontay to Midlothian - Dominion

None

2025-W1-9

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.