



## PJM Interconnection

### Winter 2019/20 Weather Normalized RTO Coincident Peaks (MW)

Zone	Peak	5CP Average	Adjustment Factor
<b>AE</b>	<b>1,490</b>	1,336	1.115
AECO	1,389.4		
Vineland	100.6		
<b>AEP</b>	<b>21,290</b>	19,832	1.074
<b>APS</b>	<b>8,610</b>	8,007	1.075
<b>ATSI</b>	<b>10,100</b>	9,331	1.082
<b>BGE</b>	<b>5,710</b>	5,114	1.117
<b>COMED</b>	<b>13,990</b>	12,553	1.114
<b>DAYTON</b>	<b>2,830</b>	2,615	1.082
<b>DEOK</b>	<b>4,420</b>	3,955	1.118
<b>DLCo</b>	<b>2,010</b>	1,813	1.109
<b>DOM</b>	<b>19,410</b>	16,767	1.158
<b>DPL</b>	<b>3,600</b>	3,109	1.158
DPLCO	3,543.1		
EASTON	56.9		
<b>EKPC</b>	<b>2,470</b>	2,160	1.143
<b>JCPL</b>	<b>3,550</b>	3,144	1.129
<b>METED</b>	<b>2,620</b>	2,434	1.076
<b>OVEC</b>	<b>50</b>	48	1.033
<b>PECO</b>	<b>6,600</b>	5,829	1.132
<b>PENLC</b>	<b>2,750</b>	2,619	1.050
<b>PEPCO</b>	<b>5,540</b>	4,741	1.168
PEP	4,728.9		
SMECO	811.1		
<b>PLGrp (PL, UGI)</b>	<b>7,350</b>	6,724	1.093
<b>PS</b>	<b>6,470</b>	5,801	1.115
<b>RECO</b>	<b>210</b>	183	1.148
<b>PJM RTO</b>	<b>131,070</b>	129,600	1.011

### Winter 2019/20 RTO Coincident Peaks (5CP)

Note: All times are listed in Hour Ending EPT

PJM RTO			
Day	Date	Hour	MW
Thursday	12/19/2019	8:00	120,271
Wednesday	1/22/2020	20:00	119,250
Tuesday	1/21/2020	8:00	118,763
Friday	12/20/2019	8:00	116,517
Wednesday	12/18/2019	19:00	115,779

**PJM INTERCONNECTION**  
**Winter 2019/20 - Coincident Peaks, By Zone (MW)**

Date	12/19/2019	1/22/2020	1/21/2020	12/20/2019	12/18/2019	Average
Hour End (EPT)	8:00	20:00	8:00	8:00	19:00	
AE	1,342.3	1,283.8	1,312.4	1,325.0	1,418.8	1,336.4
AEP	20,313.4	20,537.8	20,070.3	19,216.4	19,021.1	19,831.8
APS	8,093.1	8,189.5	7,990.1	7,939.0	7,824.7	8,007.3
ATSI	9,422.2	9,330.0	9,102.0	9,176.1	9,623.5	9,330.8
BGE	5,220.3	5,153.3	5,181.8	5,209.7	4,805.0	5,114.0
COMED	12,554.8	12,095.8	12,470.5	11,814.0	13,831.7	12,553.4
DAYTON	2,719.0	2,640.4	2,646.5	2,472.0	2,597.0	2,615.0
DEOK	4,144.5	4,016.0	3,863.0	3,799.0	3,952.7	3,955.0
DLC <sub>o</sub>	1,826.2	1,781.5	1,758.1	1,777.9	1,921.0	1,812.9
DOM	16,971.8	17,377.8	17,543.6	17,252.5	14,689.2	16,767.0
DPL	3,180.3	3,120.4	3,186.7	3,205.0	2,850.8	3,108.7
EKPC	2,308.6	2,342.6	2,056.8	2,057.3	2,036.3	2,160.3
JCPL	3,189.8	3,029.1	3,028.8	3,123.0	3,348.4	3,143.8
METED	2,515.1	2,427.3	2,453.8	2,403.7	2,370.1	2,434.0
OVEC	56.0	39.0	43.0	52.0	52.0	48.4
PECO	5,954.8	5,807.9	5,904.8	5,732.6	5,744.0	5,828.8
PENLC	2,646.5	2,656.8	2,577.1	2,563.1	2,651.9	2,619.1
PEPCO	4,854.1	4,873.3	4,849.4	4,785.5	4,344.3	4,741.3
PPL-EU	6,717.8	6,568.4	6,659.1	6,524.8	6,274.3	6,548.9
PS	5,882.4	5,628.4	5,708.8	5,741.3	6,045.3	5,801.2
RECO	182.1	176.5	178.7	177.9	199.8	183.0
UGI	176.2	174.2	177.8	169.6	177.1	175.0
<b>PJM RTO</b>	<b>120,271.1</b>	<b>119,249.8</b>	<b>118,763.2</b>	<b>116,517.4</b>	<b>115,778.9</b>	<b>118,116.1</b>
PLGrp	6,894.0	6,742.7	6,836.9	6,694.4	6,451.4	6,723.9
EASTON	50.5	50.0	50.6	52.6	42.3	
SMECO	706.7	726.5	710.2	736.7	594.9	
VINELAND	90.0	88.4	88.8	89.1	94.6	

8-Apr-20