

BAL-003 Performance Update &

M-12 Primary Frequency Response Review

Becky Davis
July 9, 2020
Operating Committee



BAL-003-1.1 Frequency Response & Frequency Bias Setting Requirement 1

 Requirement 1: Each Balancing Authority shall achieve an annual Frequency Response Measure (FRM) that is equal to or more negative than its Frequency Response Obligation (FRO)...

Interconnection Frequency Response Obligation X Balancing Authority Pro-rata Share


$$FRO_{BA} = IFRO \times \frac{Annual Gen_{BA} + Annual Load_{BA}}{Annual Gen_{Int} + Annual Load_{Int}}$$

PJM FRO for 2020 operating year = $(-1015 \text{ MW/}0.1 \text{ Hz}) \times (25.72\%) = -261.1 \text{ MW/}0.1 \text{Hz}$ 2020 Operating Year : December 2019 – November 2020

Field trial data prior to Operating Year 2017



Historic PJM BAL-003-1 Performance





- PJM is actively participating in NERC activities around Primary Frequency Response
- The Standard Drafting Team is working on Phase II of BAL-003 proposed changes (reference document: <u>BAL-003 Standards Authorization</u> <u>Request</u>). Current working items:
 - Whitepaper for industry review on path forward on PFR
 - Potential changes to BAL-003 requirements
- NERC 2019 Generator Operator Survey
 - NERC and NERC Resources Subcommittee conducted a voluntary survey for Generator Operators to submit Primary Frequency Response data for their resources
 - Results pending



- PFRSTF work had started in July 2017
- FERC Order 842 (2/18) requires PFR capability for new resources
- Unable to get stakeholder consensus on solution package
- PFRSTF has been on hiatus since January 2019
 - In January, 2020, MRC endorsed PFRSTF to continue hiatus for 6 months
- PJM continues to monitor unit PFR performance using criteria described in PFRSTF and documented in PJM Manual 12
- PFRSTF sunset at MRC June 18, 2020 meeting



M-12 Primary Frequency Response analysis

- Event Selection
 - Frequency goes outside +/- 40mHz deadband
 - Frequency stays outside +/- 40mHz deadband for 60 continuous seconds
 - Minimum/maximum frequency reaches +/- 53mHz

Recent events included in today's review:

Date / Time 9/23/19 12:06:07 2/7/20 22:42:13 2/10/20 13:31:13 2/10/20 15:14:14 4/1/20 16:24:47 4/4/20 2:16:51 5/29/20 14:03:49

Selected as BAL-003 Events through Feb. 2020




PJM Primary Frequency Response Review


 Evaluated 583 units (50MW and greater) for 10 events in 2019 and 6 events in first half of 2020

Fuel Type	# of Units Evaluated
Coal	197
Hydro	16
Municipal Waste	4
Natural Gas	246
Oil	40
Solar	9
Wind	71
Total	583




M-12 Primary Frequency Response by Event







2/10/2020 13:31:19 PM Review



02/07/2020 12:06:07 Review



2/10/2020 15:14:10 PM Review



PFR Legend

- Further Evaluation Needed
- No PFR
- Offline
- PFR
- Regulation




M-12 Primary Frequency Response by Event

4/01/2020 16:24:47 PM Review

04/04/2020 02:16:51 Review


5/29/2020 14:03:49 PM Review





PJM Primary Frequency Response Review

PFR by Fuel Type - Units > 50MWs






Appendix



BAL-003 Event Selection:


https://www.nerc.com/comm/OC/BAL0031_Supporting_Documents_2017_DL/IFR_Master_Event_List_REDACTED.xlsx

Events listed on NERC Resource Subcommittee Site





 Interactive tool for members to use to assist with understanding unit performance: https://www.pjm.com/-/media/committees-groups/task-forces/pfrstf/20181127/20181127-fr-performance-events.ashx



 Please reach out to <u>FrequencyResponse@pjm.com</u> with questions or to set up a call with PJM to discuss PFR.