

<b>Effective Date</b>	October 1, 2022
<b>Impacted Manual #(s)/Manual Title(s):</b>	
M-14-D: Generator Operational Requirements, Revision 61	
<b>Conforming Order(s):</b>	
None	
<b>Associated Issue Tracking Title:</b>	N/A
<b>Committee Approval Path - What committee(s) have already seen these changes?</b>	
Planned committee reviews/endorsements:  SOS: August 3, 2022, September 1, 2022 RSCS: August 19, 2022 OC: August 11, 2022, September 8, 2022 (Endorsement) MRC: August 24, 2022, September 21, 2022 (Endorsement)	
<b>MRC 1<sup>st</sup> read date:</b>	August 24, 2022
<b>MRC voting date:</b>	September 21, 2022
<b>Impacted Manual sections:</b>	
See detailed list below	
<b>Reason for change:</b>	
<p><b>Section 7.3.5: Fuel, Emissions and Operational Data Reporting</b></p> <ul style="list-style-type: none"> <li>• Seasonal Fuel and Emissions Reporting <ul style="list-style-type: none"> <li>○ Added Generating Facility minimum design temperature annual verification</li> </ul> </li> <li>• Real Time Reporting <ul style="list-style-type: none"> <li>○ Added reference to new Emergency Procedure: “Cold Weather Advisory”</li> <li>○ Added requirement for Generation Owners to enter/review/update Generating Facility cold weather operating limit temperature in Markets Gateway</li> </ul> </li> </ul> <p><b>Attachment N: Cold Weather Preparation Guideline and Checklist</b></p> <ul style="list-style-type: none"> <li>• Added recommendation to take into account the effects of precipitation and wind during cold weather preparation.</li> </ul>	