

Subregional RTEP Committee – Mid-Atlantic PPL Supplemental Projects

June 15, 2021

Needs

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

Need Number: PPL-2021-0004

Meeting Date: 6/15/2021

Process Stage: Need


Supplemental Project Driver: Equipment Material Condition, Performance and Risk

Problem Statement:

PPL EU plans to retire the Bloomsburg 69/12kV Substation since the substation is prone to flooding. The Columbia-Scott 69kV CAP Bank is located at the Bloomsburg 69/12kV substation.

Specific Assumption References:

[PPL 2021 Annual Assumptions](#)



Questions?



Appendix

High level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

Revision History

6/4/2020 – V1 – Original version posted to pjm.com