

# Reliability Analysis Update

Transmission Expansion Advisory Committee
November 14, 2019

PJM TEAC – 11/14/2019 PJM©2019



## **Proposal Window Exclusion Definitions**

- The following definitions explain the basis for excluding flowgates and/or projects from the competitive planning process and designating projects to the incumbent Transmission Owner.
- Flowgates/projects excluded from competition will include the underlined language on the corresponding slide.
  - <u>Immediate Need Exclusion</u>: Due to the immediate need of the violation (3 years or less), the timing required for an RTEP proposal window is infeasible. As a result, the local Transmission Owner will be the Designated Entity. Operating Agreement, Schedule 6 § 1.5.8(m)
  - Below 200kV Exclusion: Due to the lower voltage level of the identified violation(s), the driver(s) for this project are excluded from the competitive proposal window process. As a result, the local Transmission Owner will be the Designated Entity Operating Agreement, Schedule 6 § 1.5.8(n)
  - Substation Equipment Exclusion: Due to identification of the limiting element(s) as substation equipment, the driver(s) for this project are excluded from the competitive proposal window process. As a result, the local Transmission Owner will be the Designated Entity Operating Agreement, Schedule 6 § 1.5.8(p)



# 2019 RTEP Analysis Update

PJM TEAC – 11/14/2019 9JM©2019



### Retool study assumptions:

- The reinstatements of Davis Besse 1 (896MW), Perry 1 (1247MW), and Sammis 5-7 (1491MW)
- Remove B3005, B3013, B3014, B3010, B3011.6, B3012.3, B3012.4, B3017, B3061, B3062, B3063, B3065, B3065, B3066, B3067, B3068, B3069, B3070, B3071,B3072, B3073, B3074,B3075, B3076, B3077, B3078, B3079, B3080, B3081, B3082, B3083

### Scope of the study:

- Summer
  - Generator Deliverability, Baseline Analysis, Load Deliverability, N-1-1
- Winter
  - Generator Deliverability, Baseline Analysis, Load Deliverability, N-1-1
- Light Load
  - Generator Deliverability, Baseline Analysis



### Removed Flowgates:

- Kammer Gorge Washington 138KV line (GD-S10, GD-S539, GD-W444)
- Haviland 138kV tie (GD-W272)
- Wilton 765/345kV transformer #94 (GD-W252, GD-W253)
- Wilton 765/345kV transformer #93 (GD-W257, GD-W258)
- Brighton Alcoa 138 kV (GD-S544, N2-ST3, N2-ST4)
- Richland Ridgeville 138 kV (GD-S9)
- Bartonville 138 kV (Z1-113 Area) (N2-WVD2, N2-WVD3, N2-WVD4, N2-WVD5, N2-WVD6, N2-WVD7, N2-WVD8, N2-WVD9, N2-WVD10)



#### New issues found in retool:

 Flowgates caused by suspended queue generation – no solution will be pursued at this time

Fr Bus	Fr Name	To Bus	To Name	CKT	kVs	Areas	Cont Name	ContType	Rating	Final DC %LD	Final AC %LD	Suspended queue
24606	705NATRIUM34	243049	05NATRIUM12	Z1	138	205	AEP_P2-2_#8897_05NATRIU 138_2		240			AA2-119, AC1-055, AC1-097
24606	705NATRIUM34	243049	05NATRIUM12	Z1	138	205	SAEP_P4_#8897_05NATRIU 138_H	Breaker	240	97.07	100.28	AA2-119, AC1-055, AC1-097

- Potential Violation:
  - Hayes 345/138 kV Transformer overloaded in retooled 2024 Winter Generator Deliverability Testing for tower contingency removing two 345 kV lines in the Hayes area – review of analysis underway



## First Review

**Baseline Reliability Projects** 



Process Stage: First Review

Criteria: Summer N-1-1 Thermal

**Assumption Reference**: 2024 RTEP assumption

Model Used for Analysis: 2024 RTEP summer case

Proposal Window Exclusion: 200 kV

**Problem Statement:** Leroy Center – Pawnee Tap 138 kV line is overloaded for N-1-1 the loss of the Juniper – Northfield 138 kV and Nash – Painesville

138 kVlines. (N2-ST5, N2-ST6)

#### **Existing Facility Rating:**

Leroy Center – Pawnee 138 kV:115/115 (SN/SE)

#### **Proposed Solution:**


Reconductor the 8.4 mile section of the Leroy Center - Mayfield Q1 line between Leroy Center - Pawnee Tap to achieve a rating of at least 160

MVA / 192 MVA (SN/SE). Estimated Cost: \$14.1M

Alternatives: N/A

Required In-Service: 6/1/2024

ATSI Transmission Zone: Baseline Lerov Center – Pawnee Tap 138 kV





- Complete Deactivation re-tool
- Begin presenting window violation solutions
- Continue stability studies
- Continue other studies (e.g. 15 year analysis, outage analysis, etc.)



# **Questions?**



## **Upcoming TEAC Meetings**

2019

• TEAC meetings are the following Thursdays in 2019

• 1/10, 2/7, 3/7, 4/11, 5/16, 6/13, 7/11, 8/8, 9/12, 10/17, 11/14, 12/12.

PJM TEAC – 11/14/2019 11



- V1 11/07/2019 Original slides posted
- V2 11/12/2019 Slide 8 Cost added