



Cold Weather Generation Resource Preparation Update

OC Meeting
1/6/2015

- As of 1/2/2014 approximately 156 units with a total ICAP of 9350 MW performed the cold weather generation operational exercise:

Week of:	Units Exercised		Success Rate
	Units	MWs	
Dec 5th	21	659	57%
Dec 8th	48	2893	89%
Dec 15th	50	2937	88%
Dec 22nd	4	242	75%
Dec 29th	33	2618	70%
Jan 5th (projected)	18	980	
Total	174	10329	

- Scheduling of units continuing into first week of January due to many cancellations in December related to weather

- By unit count, 91% indicated that they completed their own checklist or the checklist in Manual M14D
- By total ICAP, 98% indicated that they completed their own checklist or the checklist in Manual M14D
- For CT / Diesel / Steam / Combined Cycle units:
 - By unit count, 98% indicated that they completed their own checklist or the checklist in Manual M14D
 - By total ICAP, 99% indicated that they completed their own checklist or the checklist in Manual M14D

- Questions?
- Contact
 - coldweathergenprep@pjm.com
 - David Schweizer, 610-666-4503, david.schweizer@pjm.com
 - Ray Lee, 610-666-4608, ray.lee@pjm.com