

# CIP-002-5.1a and CIP-014-2 IROL Determination

Preston Walker  
Reliability Compliance  
RSCS  
July 19, 2019

## FAC-014-2

**R5.** The RC, PA, and TP shall provide its SOLs and IROLs to those entities that have a reliability-related need for those limits

**R5.1.1.** Identification and status of the associated Facility (or group of Facilities) that is (are) critical to the derivation of the IROL.

**R5.1.3.** The associated Contingency(ies).

## **CIP-002-5.1a, Attachment 1 – Criteria 2.6**

*Generation at a single plant location or Transmission Facilities at a single station or substation location that are identified by its Reliability Coordinator, Planning Coordinator, or Transmission Planner as critical to the derivation of Interconnection Reliability Operating Limits (IROLs) and their associated contingencies*

## **CIP-014-2, Section 4.1.1.3**

*Transmission Facilities at a single station or substation location that are identified by its Reliability Coordinator, Planning Coordinator, or Transmission Planner as critical to the derivation of Interconnection Reliability Operating Limits (IROLs) and their associated contingencies.*