



Effective Date	7/26/2018
Impacted Manual #(s)/Manual Title(s): Manual 01, Control Center and Data Exchange Requirements	
Conforming Order(s): N/A	
Associated Issue Tracking Title: N/A	
Committee Approval Path - What committee(s) have already seen these changes?	
<p>First Read</p> <ul style="list-style-type: none"> • 5/9 – DMS (informational) • 6/1 – SOS • 6/5 – OC • 6/15 – RSCS/TTMS (informational) <p>Second Read/Endorsement</p> <ul style="list-style-type: none"> • 7/5 – SOS • 7/10 – OC 	
MRC 1 st read date:	6/21/2018
MRC voting date:	7/26/2018
Impacted Manual sections:	
Section 1.6: Markets Gateway Section 2.3.1: Transmission Monitoring Capability Section 2.7: PJM Member Back Up Capability Section 3.2: EMS Data Exchange Section 3.3: Synchrophasor System Data Exchange	Section 4.1: Dispatch Voice & Fax Communications Section 4.5: PJM Communication Protocol Attachment A: Data Specification and Collection Attachment B: Schedule of Data Submittals
Reason for change:	
<ul style="list-style-type: none"> • Sections 1.6, 3.2 and 3.3, Attachment A – Revised for clarity and completeness. • Sections 2.3.1, 2.7, 4.1, 4.5.3, Attachment B – Updated to align with NERC Standards and TO/TOP Matrix. • Section 3.2 – New requirement on ICCP data definition files. • Attachment A – Added PAI Trigger via SCADA/ICCP to the list of data provided by PJM to Generating Entities. 	
Summary of the changes:	
<ul style="list-style-type: none"> • Section 1.6: Revised language to explain what Markets Gateway tool is used for instead of a detailed overview of PJM Markets which is covered in Manual 11. • Section 2.3.1: Changes related to TOP-001 R13 and TO/TOP Matrix regarding Real-time Assessment capability requirements • Section 2.7: NERC Standard references to TOP-001 R1, R12, R14 and TOP-003 R1, R3, R5 updated. • Section 3.2: <ul style="list-style-type: none"> ○ Added missing information about DNP3 communication protocol and Jetstream system, and revised for clarity. ○ Added new requirement regarding ICCP data definition files. • Section 3.3: Revised language for clarity and alignment with PJM Manual M14D. • Section 4.1: Per COM-001, added Distribution Providers to the list of entities PJM has voice communications with. • Section 4.5.3: New language to define what qualifies as Emergency in accordance with COM-002. • Attachment A: <ul style="list-style-type: none"> ○ Table A: Removed the references to the data submission timeline requirements for Generation scheduling. ○ Table B: Added PAI Trigger via SCADA/ICCP as an optional service for generating entities. • Attachment B: Reworded EOP-008-1 R5 to ensure TOs are submitting the right evidence. 	