

Effective Date	February 25, 2019
Impacted Manual #(s)/Manual Title(s):	
M-14D: Generator Operational Requirements, Revision 48	
Conforming Order(s):	
None	
Associated Issue Tracking Title:	N/A
Committee Approval Path - What committee(s) have already seen these changes?	
Planned committee reviews/endorsements: SOS: January 4, 2019, February 1, 2019 OC: January 8, 2019, February 5, 2019 (Endorsement) MRC: January 24, 2019, February 21, 2019 (Endorsement)	
MRC 1st read date:	January 24, 2019
MRC voting date:	February 21, 2019
Impacted Manual sections:	
Section 7.1.1 – Generator Real Power Control	
Reason for change:	
Added requirements associated with FERC Order 824 – Primary Frequency Response for new ISAs effective 10/1/18.	
Summary of the changes:	
<ul style="list-style-type: none"> • Requirement added for generating resources subject to new ISA to have Primary Frequency Response capability • Applies to generating resources that entered PJM queue on or after 10/1/2018 • References performance evaluation – Details included in Manual 12 	