

<b>Effective Date</b>	February 25, 2019
<b>Impacted Manual #(s)/Manual Title(s):</b>	
M-14D: Generator Operational Requirements, Revision 48	
<b>Conforming Order(s):</b>	
None	
<b>Associated Issue Tracking Title:</b>	N/A
<b>Committee Approval Path - What committee(s) have already seen these changes?</b>	
Planned committee reviews/endorsements:  SOS: January 4, 2019, February 1, 2019 OC: January 8, 2019, February 5, 2019 (Endorsement) MRC: January 24, 2019, February 21, 2019 (Endorsement)	
<b>MRC 1<sup>st</sup> read date:</b>	January 24, 2019
<b>MRC voting date:</b>	February 21, 2019
<b>Impacted Manual sections:</b>	
Section 7.1.1 – Generator Real Power Control	
<b>Reason for change:</b>	
Added requirements associated with FERC Order 824 – Primary Frequency Response for new ISAs effective 10/1/18.	
<b>Summary of the changes:</b>	
<ul style="list-style-type: none"> <li>• Section 7.1.1 <ul style="list-style-type: none"> <li>○ Requirement added for generating resources subject to new ISA to have Primary Frequency Response capability</li> <li>○ Applies to generating resources that entered PJM queue on or after 10/1/2018</li> <li>○ References performance evaluation – Details included in Manual 12</li> </ul> </li> <li>• Section 7.1.2 <ul style="list-style-type: none"> <li>○ Corrected typos</li> </ul> </li> <li>• Section 7.3.1 <ul style="list-style-type: none"> <li>○ Deleted reference to three working day notification to TO and PJM</li> </ul> </li> </ul>	