

Generating Facility Cold Weather Operating Limits

Vince Stefanowicz
Sr. Lead Engineer, Generation
System Operations Subcommittee
October 10, 2019

FERC/NERC joint report on MISO cold weather operations January, 2018 recommendations

- Generator Operators determine lowest ambient temperature to which plants can reliably operate
- Generator Operators to provide these limits to their Balancing Authority (BA) and Reliability Coordinator (RC)
- Balancing Authority (BA) and Reliability Coordinator (RC) to incorporate these limits in their operating plans

Report Link: https://www.nerc.com/pa/rrm/ea/Documents/South_Central_Cold_Weather_Event_FERC-NERC-Report_20190718.pdf

Generating Facility Minimum Operating Temperature Survey

- Based on joint NERC/FERC report on MISO cold weather event in January 2018
- Focused on low ambient operating temperature limits
- Include all units modeled in eDART

Generating Facility Minimum Operating Temperature Survey

- Survey to be initiated in eDART
 - Independent of Seasonal Fuel & Emissions Survey
 - Open from 12/1/19 – 4/1/20