

Effective Date	5/28/2020
Impacted Manual #(s)/Manual Title(s): Manual 01, Control Center and Data Exchange Requirements	
Conforming Order(s): N/A	
Associated Issue Tracking Title: N/A	
Committee Approval Path - What committee(s) have already seen these changes?	
First Read <ul style="list-style-type: none"> 4/13 – SOS 4/16 – OC 4/17 – RSCS (informational) Second Read/Endorsement <ul style="list-style-type: none"> 5/18 – SOS 5/14 – OC 5/15 – RSCS/TTMS (informational) 	
MRC 1st read date:	4/30/2020
MRC voting date:	5/28/2020
Impacted Manual sections:	
Attachment A: Data Specification and Collection Attachment B: Schedule of Data Submittals	
Reason for change:	
<ul style="list-style-type: none"> Cover to Cover Periodic Review 	
Summary of the changes:	
<ul style="list-style-type: none"> Cover to Cover Periodic Review. Attachment A: Added external entities PJM shares network model information with. Attachment A: To comply with TOP-003, added a new column in the data specification tables that reflects the periodicity of providing the mentioned data where applicable. Attachment A: Removed Row B.5 Black Start Test Data from Table B since this is not an EMS service. Attachment A: Removed Row B.16 AVR/PSS Excitation control since this is not an output from PJM. Attachment A: Changed Row B.3.5 Frequency input from 'Required' to 'Optional' for PJM Member Generating Entities. Attachment A: Changed Row B.3.6 Status of BES Circuit Breakers from 'Required' to 'Mandatory if not Attainable by Existing Telemetry' for PJM Member Generating Entities. Attachment B: Removed references to EOP-005-3 R3 and R4, as these are already covered by Manual 36 Attachment G. 	