



Current Requirements for Reporting of Governor Outages

Vince Stefanowicz

PFRSTF

September 26, 2018

- 7.1.1 Generator Real-Power Control
 - “All generators, including pseudo tied or dynamically scheduled generating resources, should operate on unrestricted governor (or equivalent electronic speed control device) control to assist in maintaining interconnection frequency...”
 - “Governor outages during periods of operations must be kept to a minimum. If a governor or equivalent electronic speed control device for any unit, regardless of resource type, is out of service or **unable to react to a change in system frequency**, it **must be immediately reported** to PJM via eDART as a governor outage.”

- As of 9/4/18, only 4 Active Governor tickets in eDART
 - This implies that all other units are indicating they are capable of providing PFR, i.e. responding to changes in grid frequency
- From 1/1/16 to 9/4/18, a total of 41 Governor tickets were submitted
 - Of the 41, 37 are now marked as completed