



Event Performance

Events	Frequency Delta	Count of units (with expected response)	Sum of Gen (MW) response	Count of units including Max Capacity & Regulation units	Sum of Gen (MW) response including Max Capacity & Regulation units	MW/0.1 Hz	Requirement	BAL-003 Performance
12/5/2017 17:19	-0.039	114	92.4373	380	38.8885	-100.2	-258	-136
12/6/2017 18:27	-0.047	138	33.9128	456	37.8589	-80.6	-258	-99
12/11/2017 8:58	-0.053	169	91.8245	481	171.0122	-322.7	-258	-563
1/3/2018 2:59	-0.056	124	93.8815	451	215.0025	-383.9	-258	-329
1/27/2018 16:17	-0.044	148	129.4156	404	215.5001	-489.8	-258	-418
2/3/2018 8:35	-0.051	136	34.5468	500	118.4821	-232.3	-258	-542
2/16/2018 10:14	-0.049	144	60.9423	429	94.6316	-193.1	-258	-239
2/20/2018 19:17	-0.034	143	24.6155	388	53.8662	-158.4	-258	-298
3/8/2018 0:16	-0.058	132	37.6415	379	40.1563	-69.2	-258	-236
3/14/2018 8:38	-0.047	159	32.7475	567	111.4437	-237.1	-258	-280
3/18/2018 12:59	-0.043	127	65.7993	432	90.5855	-210.7	-258	-356
4/7/2018 8:36	-0.056	138	57.1822	406	91.8662	-164.0	-258	-223
4/12/2018 13:26	-0.031	142	33.7516	440	58.189	-187.7	-258	-658