



PJM Interconnection, L.L.C.  
2750 Monroe Blvd.  
Audubon, PA 19403

Pauline Foley  
Associate General Counsel  
T: (610) 666-8248 | F: (610) 666-8211  
[pauline.foley@pjm.com](mailto:pauline.foley@pjm.com)

January 8, 2021

Honorable Kimberly D. Bose, Secretary  
Federal Energy Regulatory Commission  
888 First Street, N.E., Room 1A  
Washington, D.C. 20426

*Re: PJM Interconnection, L.L.C., Docket No. ER21-\_\_\_\_-000  
[30-Day Comment Period Requested]*

Dear Secretary Bose:

In accordance with PJM Open Access Transmission Tariff, Schedule 12 (“Tariff” or “Schedule 12”)<sup>1</sup> and Amended and Restated Operating Agreement of PJM Interconnection, L.L.C., Schedule 6, section 1.6 (“Operating Agreement” or “Schedule 6”), and pursuant to section 205 of the Federal Power Act,<sup>2</sup> PJM Interconnection, L.L.C. (“PJM”) hereby submits amendments to the Tariff, Schedule 12-Appendix A to incorporate cost responsibility assignments for 14 baseline upgrades in the recent update to the Regional Transmission Expansion Plan (“RTEP”) approved by the PJM Board of Managers (“PJM Board”) on December 9, 2020. PJM requests that the revised Tariff sections become effective on April 8, 2021, 90 days after the date of this filing.

---

<sup>1</sup> All capitalized terms that are not otherwise defined herein have the meaning as defined in the Tariff, Operating Agreement, and Reliability Assurance Agreement among Load Serving Entities in the PJM Region.

<sup>2</sup> 16 U.S.C. § 824d.

## I. DESCRIPTION OF FILING

### A. *Description of the Board Approved Updated RTEP Upgrades*

On December 9, 2020, the PJM Board approved changes to the RTEP, which included approximately \$69.7 million<sup>3</sup> in new baseline transmission enhancements and expansions. With these approvals, the PJM Board has authorized a total of more than \$38 billion in investments since 2000.

### B. *Schedule 12 Requirements to Designate Cost Responsibility Assignments*

This filing represents PJM's fifty-fifth filing of cost responsibility assignments for new RTEP baseline upgrades since the Federal Energy Regulatory Commission ("Commission") directed such filings under Tariff, Schedule 12. Pursuant to Schedule 12, PJM is required to designate in Tariff, Schedule 12-Appendix A, cost responsibility assignments for all transmission enhancements and expansions included in the RTEP after February 1, 2013. Similarly, Schedule 12 requires that within 30 days of the PJM Board's approval of each RTEP, or addition to the RTEP, PJM shall designate in Schedule 12-Appendix A, and in a report filed with the Commission, the "Responsible Customers" that will be subject to charges related to transmission enhancements and expansions included in the RTEP.<sup>4</sup>

---

<sup>3</sup> The 14 baseline upgrades approved by the PJM Board on December 9, 2020 with estimated costs totaling \$69.7 million include: (i) 12 new baseline upgrades were new transmission system enhancements and expansions with an estimated cost of \$44.08 million; (ii) one baseline upgrade b3110.3 was a scope change to existing baseline project b3110 with an estimated cost of \$0.93 million; and (iii) baseline upgrade b3142 is an Interregional Market Efficiency Project under the MISO-PJM Joint Operating Agreement located in Northern Indiana Public Service Company (NIPSCO) with an estimated cost of \$24.69 million.

<sup>4</sup> Tariff, Schedule 12, section (b)(viii); *see also* Operating Agreement, Schedule 6, section 1.6.

Schedule 12 further provides that customers designated to be responsible for assignments of costs that PJM files with the Commission shall have 30 days from the date of such filing to submit comments regarding the proposed cost responsibility assignments.<sup>5</sup>

***C. Description of Proposed Amendments to Schedule 12-Appendix A***

On March 22, 2013, the Commission accepted revisions to Schedule 12 modifying the cost allocation methodologies for transmission projects included in the RTEP, effective February 1, 2013.<sup>6</sup> These revisions were filed by the PJM Transmission Owners in compliance with Order No. 1000 and revised the methodologies for allocating cost responsibility for all RTEP transmission enhancements and expansions, including reliability and economic projects, replacement projects, and high voltage direct current transmission projects.

These revisions only apply to the cost allocations for projects included in the RTEP on a prospective basis and do not disturb the cost allocations for projects previously included in the RTEP. Therefore, the cost responsibility assignments for RTEP projects approved after February 1, 2013 are segregated in a separate appendix from the previously-approved cost responsibility assignments for RTEP upgrades. Thus, cost responsibility assignments for all new RTEP projects are located in Schedule 12-Appendix A.<sup>7</sup>

As required by Schedule 12, PJM hereby submits amendments to Schedule 12-Appendix A to include the new cost responsibility assignments for RTEP upgrades approved by the PJM Board on December 9, 2020.<sup>8</sup> The revised Tariff sections containing new language,

---

<sup>5</sup> See Tariff, Schedule 12, section (b)(viii).

<sup>6</sup> *PJM Interconnection, L.L.C.*, 142 FERC ¶ 61,214 at PP 411, 448 (2013) (“March 22 Order”).

<sup>7</sup> See Tariff, Schedule 12, section (a)(v).

<sup>8</sup> See *id.*, section (b)(viii).

including new cost responsibility assignments, are reflected in redline and clean format in Attachments B and C, respectively, to this filing.<sup>9</sup>

*1. Assignment of Cost Responsibility for Regional Facilities*

PJM amends Schedule 12-Appendix A to include the cost responsibility for one (1) new transmission enhancement or expansion that will operate at or above 500 kV (“Regional Facility”) included in the most recent update to the RTEP approved by the PJM Board on December 9, 2020.<sup>10</sup>

The cost responsibility assignment for the one Regional Facility is based on the hybrid cost allocation methodology approved by the Commission in the March 22 Order. Pursuant to this hybrid methodology, 50 percent of the costs of the Regional Facilities are allocated on a region-wide postage stamp basis while the other 50 percent is allocated to specifically-identified beneficiaries.<sup>11</sup>

The region-wide, postage stamp allocations for each Transmission Owner zone are based on its annual load-ratio share using the applicable zonal loads at the time of each Transmission Owner’s annual peak load from the 12-month period ending October 31 of the year preceding the year for which the annual cost responsibility allocation is determined.<sup>12</sup> Similarly, the cost responsibility assignments for the new Regional Facility to the owners of merchant transmission

---

<sup>9</sup> The revised Tariff sections do not include any proposed rates or charges for recovery of any system upgrade costs. In accordance with Tariff, Schedule 12, recovery of the costs of such facilities that the RTEP requires Transmission Owners to construct, own and/or finance is governed by the Transmission Owners’ established rates.

<sup>10</sup> The Regional Facility included in the RTEP upgrades is b3247.

<sup>11</sup> Schedule 12 provides different methodologies to identify and allocate costs to specific beneficiaries depending on whether the project is designed to address one or more reliability or operational adequacy and performance issues (“Reliability Projects”) or to relieve one or more economic constraints (i.e., “economic” projects). PJM Tariff, Schedule 12(b)(i)(A)(2).

<sup>12</sup> See PJM Tariff, Schedule 12, section (b)(i)(A).

facilities with Firm Transmission Withdrawal Rights are based on the merchant transmission facilities' annual peak load (not to exceed actual Firm Transmission Withdrawal Rights set forth in their respective Interconnection Service Agreements) from the 12-month period ending October 31 of the year preceding the year for which the annual cost responsibility allocation is determined.<sup>13</sup> The annual peak loads used to determine the new annual cost responsibility assignments for the Regional Facilities included in this filing are the 2020 peak loads.<sup>14</sup>

The Regional Facility is a reliability project addressing a transmission owner's Form No. 715 criteria. The second 50 percent of the costs of the facility are allocated using the "solution-based" distribution factor, or DFAX, methodology set forth in Tariff, Schedule 12, section (b)(iii). This DFAX methodology evaluates the projected relative use on the new facility by the load of each transmission zone or merchant transmission facility and allocates costs based on such usage. More specifically, to determine cost responsibility under the DFAX methodology, PJM, based on a computer model of the electric network and using power flow modeling software, calculates distribution factors, represented as decimal values or percentages, which express the portions of a transfer of energy from a defined source to a defined sink that will flow across a particular transmission facility or group of transmission facilities. These distribution factors represent a measure of the relative use of the specific transmission facility by the load of each transmission zone or merchant transmission facility, as determined by a power flow analysis.<sup>15</sup>

---

<sup>13</sup> Currently, Neptune Regional Transmission is the owner of merchant transmission facilities in PJM with Firm Transmission Withdrawal Rights.

<sup>14</sup> See *PJM Interconnection, L.L.C.*, 2021 Annual RTEP Cost Allocation Update, Docket No. ER21-726-000 (Dec. 23, 2020) (requesting an effective date of January 1, 2021).

<sup>15</sup> See PJM Tariff, Schedule 12, section (b)(iii).

2. *Assignments of Cost Responsibility for Lower Voltage Facilities Needed for Reliability*

- a. Cost Responsibility Assignments that Address Transmission Enhancements Costing More than \$5 Million and Require DFAX Analysis

Consistent with the Tariff, Schedule 12, PJM submits amendments to the Tariff, Schedule 12-Appendix A to include the cost responsibility assignments for transmission enhancements or expansions that are not Regional Facilities (“Lower Voltage Facilities”).<sup>16</sup> Five (5) enhancements or expansions<sup>17</sup> included in this filing, approved by the PJM Board on December 9, 2020, are Lower Voltage Facilities required to address reliability needs for which PJM applied the solution-based DFAX analysis described in Tariff, Schedule 12, section (b)(iii).

- b. Cost Responsibility Assignments that Address Transmission Enhancements Costing Less than \$5 Million

Tariff, Schedule 12, section (b)(vi) provides that, notwithstanding Schedule 12, sections (b)(i), (b)(ii), (b)(iv) and (b)(v), cost responsibility for an enhancement or expansion for which the good faith estimate of the cost of such enhancement or expansion included for the first time in the RTEP does not equal or exceed \$5 million shall be assigned to the zone where the enhancement or expansion is to be located. Consistent with Schedule 12, section (b)(vi), PJM proposes revisions to Schedule 12-Appendix A to include cost responsibility assignments for four (4) enhancements or expansions needed for reliability.<sup>18</sup> Therefore, consistent with Schedule 12, section (b)(vi), cost responsibility for such enhancements or expansions shall be

---

<sup>16</sup> See Tariff, Schedule 12, section (b)(ii)(A) (“If the Lower Voltage Facility is a Reliability Project, [PJM] shall use the DFAX analysis described in section (b)(iii) of this Schedule 12 . . .”).

<sup>17</sup> The Lower Voltage Facilities include: b3223.1, b3223.2, b3223.3, b3270 and b3270.1.

<sup>18</sup> The following enhancements and expansions allocated pursuant to Schedule 12, section (b)(vi) include: b3220, b3221, b3271 and b3272.

allocated 100 percent to the zone of the Transmission Owner where the enhancements or expansions are to be located.

c. Cost Responsibility Assignments that Address Spare Parts, Replacement Equipment and Circuit Breakers

The Tariff, Schedule 12, section (b)(iv)(C) provides that cost responsibility for circuit breakers and associated equipment independently included in the RTEP and not a part of the design specifications of a transmission element of a Required Transmission Enhancement shall be assigned to the zone of the owner of the spare part, if the owner of the spare part is a Transmission Owner listed in Tariff, Attachment J.

PJM proposes revisions to Schedule 12-Appendix A to include cost responsibility assignment for three (3) enhancements needed to address spare parts, replacement equipment and circuit breakers.<sup>19</sup> Therefore, consistent with Tariff, Schedule 12, section (b)(iv)(C), cost responsibility for such enhancement shall be allocated 100 percent to the zone of the Transmission Owner of the spare parts.

3. *PJM's Assignment of Cost Responsibility for a Lower Voltage Facility Interregional Market Efficiency Project is Allocated Under PJM's Tariff, Schedule 12 as an Economic Project*

This filing includes one lower voltage Interregional Market Efficiency Project as defined under the Joint Operating Agreement between Midcontinent Independent System Operator, Inc. ("MISO") and PJM ("MISO-PJM JOA") and approved by the PJM Board and the MISO Board of Directors.<sup>20</sup>

---

<sup>19</sup> The following enhancements and expansions allocated pursuant to Schedule 12, section (b)(iv) include: b3110.3, b3261 and b3269.

<sup>20</sup> See MISO-PJM JOA, section 9.4.4.1.3

The cost allocation method proposed for an Interregional Market Efficiency Project that satisfies all of the qualifications in the MISO-PJM JOA, section 9.4.4.1.3, allocates costs to the respective RTOs in proportion to the net present value of the total benefits calculated for each RTO pursuant to each RTO's respective tariff. The costs allocated to each RTO region are then further allocated within each region pursuant to the cost allocation methodology contained in each region's respective Tariff.

Under the PJM Tariff, Schedule 12, section (b)(v)(C), cost responsibility is assigned for Economic Projects that are new enhancements or expansions to relieve one or more economic constraint to zones that show a decrease in the net present value of the Changes in Load Energy Payments determined for the 15-year period starting with the applicable RTEP Year (which is the current year plus five).<sup>21</sup> Cost responsibility is assigned based on each zone's pro rata share of the sum of the net present values of the Changes in Load Energy Payments only of the zones in which the net present value of the Changes in Load Energy Payments shows a decrease.<sup>22</sup>

Consistent with Schedule 12 section (b)(v), which details the cost allocation methodology for Economic Projects to the zones and merchant transmission facilities in the PJM region that are shown to have experienced a decrease in the net present value of the Changes in Load Energy Payments, PJM proposes revisions to Schedule 12-Appendix A to include the cost responsibility assignments for one (1) Interregional Market Efficiency Project.<sup>23</sup>

---

<sup>21</sup> See Amended and Restated Operating Agreement of PJM Interconnection, L.L.C., Schedule 6, section 1.5.7(d).

<sup>22</sup> Tariff, Schedule 12, section (b)(v)(C).

<sup>23</sup> The Economic Project b3142.



#### ***D. Cost Responsibility Assignment Summary***

For informational purposes, PJM also includes as Attachment A to this filing a Cost Responsibility Assignment Summary for the enhancements or expansions approved by the PJM Board on December 9, 2020. In addition to specifying the cost responsibility assignments for the enhancements or expansions, the summary sheets provide the criteria violation and test, a description of the upgrade, in-service date, estimated upgrade costs, and the entity designated with construction responsibility for each enhancement or expansion.

#### **II. COMMENT PERIOD**

The Tariff, Schedule 12 section (b)(viii) provides that customers designated to be responsible for assignments of cost responsibility shall have 30 days from the date of such filing to seek review regarding the proposed cost responsibility assignments. Consistent with this provision, PJM requests that the comment date for this filing be set 30 days from the date of this filing, February 8, 2021.<sup>24</sup> To accommodate such a comment date, PJM requests an effective date of April 8, 2021 (90 days from the date of this filing) for all revised Tariff sections submitted in this docket.<sup>25</sup>

#### **III. DOCUMENTS ENCLOSED**

PJM encloses the following:

1. This transmittal letter;

---

<sup>24</sup> Since February 7, 2021 falls on a Sunday, comments would be due on Monday, February 8, 2021. See 18 C.F.R. § 385.2007 (a)(2) (2020).

<sup>25</sup> See, e.g., *PJM Interconnection, L.L.C.*, Errata Notice of Extending Comment Period, Docket Nos. ER06-456-018, *et al.* (Dec. 2, 2008) (granting extension of time for filing protests or comments to accommodate Schedule 12 of the PJM Tariff); *PJM Interconnection, L.L.C.*, Errata Notice Extending Comment Date, Docket No. ER08-229-000 (Nov. 30, 2007) (same); *PJM Interconnection, L.L.C.*, Notice Extending Comment Date, Docket No. ER07-1186-000 (July 31, 2007) (same).

2. Attachment A – Cost Responsibility Assignment Summary sheets;
3. Attachment B – Revised Tariff, Schedule 12-Appendix A (in redlined form); and
4. Attachment C – Revised Tariff, Schedule 12-Appendix A (in clean form).

#### **IV. CORRESPONDENCE AND COMMUNICATIONS**

Correspondence and communications with respect to this filing should be sent to the following persons:

Craig Glazer  
Vice President – Federal Government Policy  
PJM Interconnection, L.L.C.  
1200 G Street, N.W., Suite 600  
Washington, D.C. 20005  
Ph: (202) 423-4743  
Fax: (202) 393-7741  
[craig.glazer@pjm.com](mailto:craig.glazer@pjm.com)

Pauline Foley  
Associate General Counsel  
PJM Interconnection, L.L.C.  
2750 Monroe Blvd.  
Audubon, PA 19403  
Ph: (610) 666-8248  
Fax: (610)666-8211  
[pauline.foley@pjm.com](mailto:pauline.foley@pjm.com)

#### **V. SERVICE**

PJM has served a copy of this filing on all PJM Members on all state utility regulatory commissions in the PJM Region by posting this filing electronically. In accordance with the Commission's regulations,<sup>26</sup> PJM will post a copy of this filing to the FERC filings section of its internet site, located at the following link: <http://www.pjm.com/documents/ferc-manuals/fercfilings.aspx> with a specific link to the newly-filed document, and will send an e-mail on the same date as this filing to all PJM Members and all state utility regulatory commissions in the PJM Region<sup>27</sup> alerting them that this filing has been made by PJM and is available by following such link. If the document is not immediately available by using the referenced link, the document

---

<sup>26</sup> See 18 C.F.R. §§ 35.2(e) and 385.2010(f)(3) (2020).

<sup>27</sup> PJM already maintains, updates and regularly uses e-mail lists for all PJM Members and affected state commissions.

will be available through the referenced link within 24 hours of the filing. Also, a copy of this filing will be available on the FERC's eLibrary website located at the following link: <http://www.ferc.gov/docs-filing/elibrary.asp> in accordance with the Commission's regulations and Order No. 714.

Respectfully submitted,



By: \_\_\_\_\_

Craig Glazer  
Vice President – Federal Government Policy  
PJM Interconnection, L.L.C.  
1200 G Street, N.W., Suite 600  
Washington, D.C. 20005  
Ph: (202) 423-4743  
Fax: (202) 393-7741  
[craig.glazer@pjm.com](mailto:craig.glazer@pjm.com)

Pauline Foley  
Associate General Counsel  
PJM Interconnection, L.L.C.  
2750 Monroe Blvd.  
Audubon, PA 19403  
Ph: (610) 666-8248  
Fax: (610)666-8211  
[pauline.foley@pjm.com](mailto:pauline.foley@pjm.com)

# **Attachment A**

Cost Responsibility Assignment Summary Sheets

### **Baseline Upgrade b3110.3**

- Overview of Reliability Problem
  - Criteria Violation: FERC Form 715 Criteria Violation - Overstress of the Clifton 230 kV "201182" and "XT2011" breakers
  - Contingency: Fault at Clifton 230 kV
  - Criteria test: Short Circuit
- Overview of Reliability Solution
  - Description of Upgrade: Replace the Clifton 230 kV breakers "201182" and "XT2011" with 63 kA breakers
  - Required Upgrade In-Service Date: December 31, 2021
  - Estimated Upgrade Cost: \$ 0.93 M
  - Construction Responsibility: Dominion
- Cost Allocation
  - The cost for this baseline upgrade is allocated 100% to Dominion

## **Baseline Upgrade b3142**

- Overview of Reliability Problem
  - Criteria Violation: Congestion Relief - Economic
  - Contingency: NA
  - Criteria test: Market Efficiency
  
- Overview of Reliability Solution
  - Description of Upgrade: Rebuild the Michigan City – Trail Creek – Bosserman 138 kV line (10.7 miles)
  - Required Upgrade In-Service Date: January 01, 2023
  - Estimated Upgrade Cost: \$ 24.69 M
  - Construction Responsibility: NIPSCO
  
- Cost Allocation
  - The cost for this Interregional Economic Project is allocated between PJM and MISO in proportion to share of benefits calculated by each region's benefit calculation method. The resulting allocation is 10.90% to MISO and 89.10% to PJM. Within PJM, cost responsibility is assigned 100.00% to ComEd based on consideration of each zone's and Merchant Transmission Facility's market efficiency benefits from the project

## **Baseline Upgrade b3220**

- Overview of Reliability Problem
  - Criteria Violation: Richland, Whitewood, Shack Mills, Grassy Creek, Buchanan, Keen Mountain 138 kV buses became radial line connection. These radial connected 138 kV buses and 69 kV buses through Richland 138 kV bus have voltage magnitude and drop violations.
  - Contingency: Loss of Broadford - Claypool Hill and Claypool Hill – Richland 138 kV; loss of Hales Branch - Garden Creek and Hales Branch – Shack Mills 138 kV along with loss of Hales Branch 69 kV bus
  - Criteria test: FERC 715 AEP criteria (N-1-1 Voltage)
- Overview of Reliability Solution
  - Description of Upgrade: Install 14.4 MVAR capacitor bank at Whitewood 138 kV
  - Required Upgrade In-Service Date: June 01, 2023
  - Estimated Upgrade Cost: \$ 1.20 M
  - Construction Responsibility: AEP
- Cost Allocation
  - The cost for this baseline upgrade is allocated 100% to AEP

### **Baseline Upgrade b3221**

- Overview of Reliability Problem
  - Criteria Violation: Overload of Steel City 500/230 kV Transformer #1
  - Contingency: loss of the Hosensack – Steel City 500 kV circuit
  - Criteria test: Generator Deliverability
  
- Overview of Reliability Solution
  - Description of Upgrade: Replace terminal equipment (bus conductor) on the 230 kV side of the Steel City 500/230 kV Transformer #1
  - Required Upgrade In-Service Date: June 01, 2025
  - Estimated Upgrade Cost: \$ 0.09 M
  - Construction Responsibility: PPL
  
- Cost Allocation
  - The cost for this baseline upgrade is allocated 100% to PPL



### **Baseline Upgrade b3223.1**

- Overview of Reliability Problem
  - Criteria Violation: N-1-1 voltage magnitude and voltage drop violations, N-1-1 thermal violations and more than 300 MW Load Loss in the Northern Neck area
  - Contingency: Loss of 230 kV Line #224 and 230 kV Line #2145
  - Criteria test: N-1-1 Thermal and Voltage and 300 MW Load Loss
- Overview of Reliability Solution
  - Description of Upgrade: Install a second 230 kV circuit with a minimum summer emergency rating of 1047 MVA between Lanexa and Northern Neck substations. The second circuit will utilize the vacant arms on the double-circuit structures that are being installed on Line #224 (Lanexa – Northern Neck) as part of the End-of-Life rebuild project (b3089)
  - Required Upgrade In-Service Date: June 01, 2023
  - Estimated Upgrade Cost: \$ 14.00 M
  - Construction Responsibility: Dominion
- Cost Allocation
  - Baseline upgrades b3223.1, b3223.2 and b3223.3 constitutes a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

## **Baseline Upgrade b3223.2**

- Overview of Reliability Problem
  - Criteria Violation: N-1-1 voltage magnitude and voltage drop violations, N-1-1 thermal violations and more than 300 MW Load Loss in the Northern Neck area
  - Contingency: Loss of 230 kV Line #224 and 230 kV Line #2145
  - Criteria test: N-1-1 Thermal and Voltage, 300 MW Load Loss
- Overview of Reliability Solution
  - Description of Upgrade: Expand the Northern Neck terminal from a 230 kV, 4-breaker ring bus to a 6-breaker ring bus
  - Required Upgrade In-Service Date: June 01, 2023
  - Estimated Upgrade Cost: \$ 5.00 M
  - Construction Responsibility: Dominion
- Cost Allocation
  - Baseline upgrades b3223.1, b3223.2 and b3223.3 constitutes a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

### **Baseline Upgrade b3223.3**

- Overview of Reliability Problem
  - Criteria Violation: N-1-1 voltage magnitude and voltage drop violations, N-1-1 thermal violations and more than 300 MW Load Loss in the Northern Neck area
  - Contingency: Loss of 230 kV Line #224 and 230 kV Line #2145
  - Criteria test: N-1-1 Thermal and Voltage, 300 MW Load Loss
- Overview of Reliability Solution
  - Description of Upgrade: Expand the Lanexa terminal from a 6-breaker ring bus to a breaker-and-a-half arrangement
  - Required Upgrade In-Service Date: June 01, 2023
  - Estimated Upgrade Cost: \$ 4.00 M
  - Construction Responsibility: Dominion
- Cost Allocation
  - Baseline upgrades b3223.1, b3223.2 and b3223.3 constitutes a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

### **Baseline Upgrade b3247**

- Overview of Reliability Problem
  - Criteria Violation: FERC Form 715 Criteria Violation - Loss of 500 kV Line #514 from Doubs to Goose Creek
  - Contingency: Loss of 500 kV Line #514 from Doubs to Goose Creek
  - Criteria test: End of Life Criteria
- Overview of Reliability Solution
  - Description of Upgrade: Replace 13 towers with galvanized steel towers on Doubs - Goose Creek 500 kV. Reconductor 3 mile section with three (3) 1351.5 ACSR 45/7. Upgrade line terminal equipment at Goose Creek substation to support the 500 kV line rebuild
  - Required Upgrade In-Service Date: June 01, 2025
  - Estimated Upgrade Cost: \$ 7.60 M
  - Construction Responsibility: Dominion
- Cost Allocation
  - 50% of the cost for this baseline upgrade is allocated based on load ratio and 50% of the cost for this baseline upgrade is allocated to Dominion based on DFAX:

<b>Transmission Zone</b>	<b>Planned Load (MW)</b>	<b>DFAX</b>	<b>%Flow</b>	<b>DFAX Allocation</b>
APS	9,185	-1.64%	0.00%	0.00%
DPL	4,144	-1.04%	0.00%	0.00%
Dominion	21,397	4.14%	100.00%	100.00%
ME	3,156	-1.14%	0.00%	0.00%

<b>Transmission Zone</b>	<b>2020 Peak Load (MW)</b>	<b>2021 Load Ratio Allocation (%)</b>
AEC	2634.5	1.71%
AEP	21614.9	14.04%
APS	8637.6	5.61%
ATSI	12465.2	8.10%
BGE	6700.3	4.36%
ComEd	20220.0	13.14%
Dayton	3308.8	2.15%
DEOK	4975.0	3.23%
DL	2667.5	1.73%
Dominion	20060.6	13.03%
DPL	4085.6	2.65%
EKPC	2719.7	1.77%
JCPL	5903.2	3.84%
ME	2976.3	1.93%
NEPTUNE*	674.6	0.45%
OVEC	108.0	0.07%
PECO	8147.9	5.29%
PENELEC	2911.3	1.89%
PEPCO	5886.6	3.82%
PPL	7260.0	4.72%
PSEG	9557.3	6.21%
RE	397.5	0.26%

### **Baseline Upgrade b3261**

- Overview of Reliability Problem
  - Criteria Violation: Overstress of the Tanners creek 345 kV “R1” breaker
  - Contingency: NA
  - Criteria test: Short Circuit
  
- Overview of Reliability Solution
  - Description of Upgrade: Upgrade circuit breaker “R1” at Tanners Creek 345 kV. Install Transient Recovery Voltage capacitor to increase the rating from 50 kA to 63 kA
  - Required Upgrade In-Service Date: December 31, 2020
  - Estimated Upgrade Cost: \$ 0.05 M
  - Construction Responsibility: AEP
  
- Cost Allocation
  - The cost for this baseline upgrade is allocated 100% to AEP

## **Baseline Upgrade b3269**

- Overview of Reliability Problem
  - Criteria Violation: FERC Form 715 Criteria Violation - Overload of the GEN TIRE – Newcomerstown 34.5 kV line, the GREENR – MILL ST SS 34.5 kV line, the New Philadelphia – New PHILA 34.5 kV and the GREERZ – GREER 69 kV line
  - Contingency: Loss of the West New Philadelphia – Newcomerstown 138 kV line with West New Philadelphia 139/69 kV transformer and the South Canton – Bolivar – North Intertie 138 kV line.
  - Criteria test: AEP FERC 715 Criteria
- Overview of Reliability Solution
  - Description of Upgrade: At West New Philadelphia station, add a high side 138 kV breaker on the 138/69 kV Transformer #2 along with a 138 kV breaker on the line towards Newcomerstown
  - Required Upgrade In-Service Date: June 01, 2025
  - Estimated Upgrade Cost: \$ 2.02 M
  - Construction Responsibility: AEP
- Cost Allocation
  - The cost for this baseline upgrade is allocated 100% to AEP

## **Baseline Upgrade b3270**

- Overview of Reliability Problem
  - Criteria Violation: FERC Form 715 Criteria Violation - Overload of the AM General #2 – AM General #1, AM General #2 – Twin Branch2, Beiger – Virgil S, BEIGER – Kline, CAP AV – AM General #1, Dodge SS –12th St, 12th St – Virgil, Dragoon – Railroad, Grape Rd – South Bend 34.5kV lines and Kline and South Bend 138/69/34.5 kV transformers
  - Contingency: Multiple N-1-1 contingency pairs
  - Criteria test: AEP FERC 715 Criteria
- Overview of Reliability Solution
  - Description of Upgrade: Install 1.7 miles of 795 ACSR 138 kV conductor along the other side of Dragoon Tap 138 kV line, which is currently double circuit tower with one position open. Additionally, install a second 138/34.5 kV transformer at Dragoon, install a high side circuit switcher on the current transformer at Dragoon Station, and install two (2) 138 kV line breakers on the Dragoon - Jackson 138 kV and Dragoon - Twin Branch 138 kV lines
  - Required Upgrade In-Service Date: June 01, 2025
  - Estimated Upgrade Cost: \$ 4.89 M
  - Construction Responsibility: AEP
- Cost Allocation
  - Baseline upgrades b3270 and b3270.1 constitutes a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to AEP

### **Baseline Upgrade b3270.1**

- Overview of Reliability Problem
  - Criteria Violation: FERC Form 715 Criteria Violation - Overstress of Dragoon 34.5 kV "B", "C" and "D" breakers
  - Contingency: Fault at Dragoon 34.5 kV
  - Criteria test: Short Circuit
- Overview of Reliability Solution
  - Description of Upgrade: Replace Dragoon 34.5 kV breakers "B", "C", and "D" with 40 kA breakers
  - Required Upgrade In-Service Date: June 01, 2025
  - Estimated Upgrade Cost: \$ 2.00 M
  - Construction Responsibility: AEP
- Cost Allocation
  - Baseline upgrades b3270 and b3270.1 constitutes a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to AEP



### **Baseline Upgrade b3271**

- Overview of Reliability Problem
  - Criteria Violation: FERC Form 715 Criteria Violation - Overload of the Fremont Center – Holran – Maple GR – Riverview 69 kV line
  - Contingency: AEP\_P4\_#7728\_05FREMCT 138\_C (loss of Fremont Center – Tiffin 138 kV line, West Fremont – Fremont – Fremont Center 138kV line, Fremont 138/69/12 kV transformer, Fremont Center 138/69 kV transformer and Fremont Center 138 kV switching shunt).
  - Criteria test: AEP FERC 715 Criteria
- Overview of Reliability Solution
  - Description of Upgrade: Install a 138 kV circuit breaker at Fremont station on the line towards Fremont Center and install a 9.6 MVAR 69 kV capacitor bank at Bloom Road station
  - Required Upgrade In-Service Date: June 01, 2025
  - Estimated Upgrade Cost: \$ 1.76 M
  - Construction Responsibility: AEP
- Cost Allocation
  - The cost for this baseline upgrade is allocated 100% to AEP

## **Baseline Upgrade b3272**

- Overview of Reliability Problem
  - Criteria Violation: FERC Form 715 Criteria Violation - Overload of the Days Inn – Rockhill, Days Inn – South Side, Exc&L PM – South Side, Exc&L PM – Sterling1 34.5 kV lines
  - Contingency: AEP\_P1- 3\_#12222\_05ROCKHILL2 138\_1-2 (the loss of East Lima – Rockhill – Eastow 138 kV line and Rockhill 138/34.5 kV Transformers #1 and #2) and AEP\_P1-2\_#5226\_2061 (The loss of East Lima – Ford Lima2 13 kV line)
  - Criteria test: AEP FERC 715 Criteria
- Overview of Reliability Solution
  - Description of Upgrade: Install two 138 kV circuit switchers on the high side of 138/34.5 kV Transformers #1 and #2 at Rockhill station
  - Required Upgrade In-Service Date: June 01, 2025
  - Estimated Upgrade Cost: \$ 1.47 M
  - Construction Responsibility: AEP
- Cost Allocation
  - The cost for this baseline upgrade is allocated 100% to AEP

# **Attachment B**

Schedule 12 – Appendix A of the  
PJM Open Access Transmission Tariff

(Marked / Redline Format)

**SCHEDULE 12 – APPENDIX A**

**(9) PPL Electric Utilities Corporation**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1813.12	Replace the Blooming Grove 230 kV breaker 'Peckville'	PPL (100%)
b2223	Rebuild and reconductor 2.6 miles of the Sunbury - Dauphin 69 kV circuit	PPL (100%)
b2224	Add a 2nd 150 MVA 230/69 kV transformer at Springfield	PPL (100%)
b2237	150 MVAR shunt reactor at Alburdis 500 kV	<b>Load-Ratio Share Allocation:</b> AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		<b>DFAX Allocation:</b> PPL (100%)
b2238	100 MVAR shunt reactor at Elimspport 230 kV	PPL (100%)

\* Neptune Regional Transmission System, LLC

**PPL Electric Utilities Corporation (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2269	Rebuild approximately 23.7 miles of the Susquehanna - Jenkins 230kV circuit. This replaces a temporary SPS that is already planned to mitigate the violation until this solution is implemented	PPL (100%)
b2282	Rebuild the Siegfried-Frackville 230 kV line	PPL (100%)
b2406.1	Rebuild Stanton-Providence 69 kV 2&3 9.5 miles with 795 SCSR	PPL (100%)
b2406.2	Reconductor 7 miles of the Lackawanna - Providence 69 kV #1 and #2 with 795 ACSR	PPL (100%)
b2406.3	Rebuild SUB2 Tap 1 (Lackawanna - Scranton 1) 69 kV 1.5 miles 556 ACSR	PPL (100%)
b2406.4	Rebuild SUB2 Tap 2 (Lackawanna - Scranton 1) 69 kV 1.6 miles 556 ACSR	PPL (100%)
b2406.5	Create Providence - Scranton 69 kV #1 and #2, 3.5 miles with 795 ACSR	PPL (100%)
b2406.6	Rebuild Providence 69 kV switchyard	PPL (100%)
b2406.7	Install 2 - 10.8 MVAR capacitors at EYNO 69 kV	PPL (100%)
b2406.8	Rebuild Stanton 230 kV yard	PPL (100%)

**PPL Electric Utilities Corporation (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2446	Replace wave trap and protective relays at Montour	PPL (100%)
b2447	Replace wave trap and protective relays at Montour	PPL (100%)
b2448	Install a 2nd Sunbury 900MVA 500-230kV transformer and associated equipment	PPL (100%)
b2552.2	Reconductor the North Meshoppen - Oxbow – Lackawanna 230 kV circuit and upgrade terminal equipment (PPL portion)	PENELEC (98.84%) / PPL (1.16%)
b2574	Replace the Sunbury 230 kV ‘MONTOUR NORT’ breaker with a 63kA breaker	PPL (100%)
b2690	Reconductor two spans of the Graceton – Safe Harbor 230 kV transmission line. Includes termination point upgrades	PPL (100%)
b2691	Reconductor three spans limiting Brunner Island – Yorkana 230 kV line, add 2 breakers to Brunner Island switchyard, upgrade associated terminal equipment	PPL (100%)

**PPL Electric Utilities Corporation (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2716	Add a 200 MVAR shunt reactor at Lackawanna 500 kV substation	<p><b>Load-Ratio Share Allocation:</b>                      AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>                      PPL (100%)</p>
b2754.1	Install 7 miles of optical ground wire (OPGW) between Gilbert and Springfield 230 kV substations	PPL (100%)
b2754.4	Use ~ 40 route miles of existing fibers on PPL 230 kV system to establish direct fiber circuits	PPL (100%)
b2754.5	Upgrade relaying at Martins Creek 230 kV	PPL (100%)
b2756	Install 2% reactors at Martins Creek 230 kV	PPL (100%)
b2813	Expand existing Lycoming 69 kV yard to double bus double breaker arrangement	PPL (100%)

\* Neptune Regional Transmission System, LLC

**PPL Electric Utilities Corporation (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2824	Reconfigure/Expand the Lackawanna 500 kV substation by adding a third bay with three breakers	<p><b>Load-Ratio Share Allocation:</b>                      AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>                      PPL (100%)</p>
b2838	Build a new 230/69 kV substation by tapping the Montour – Susquehanna 230 kV double circuits and Berwick – Hunlock & Berwick – Colombia 69 kV circuits	PPL (100%)
b2979	Replace Martins Creek 230 kV circuit breakers with 80 kA rating	PPL (100%)
<u>b3221</u>	<u>Replace terminal equipment (bus conductor) on the 230 kV side of the Steel City 500/230 kV Transformer #1</u>	<u>PPL (100%)</u>

\* Neptune Regional Transmission System, LLC



**SCHEDULE 12 – APPENDIX A**

- (17) **AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1570.4	Add a 345 kV breaker at Marysville station and a 0.1 mile 345 kV line extension from Marysville to the new 345/69 kV Dayton transformer	AEP (100%)
b1660.1	Cloverdale: install 6-765 kV breakers, incremental work for 2 additional breakers, reconfigure and relocate miscellaneous facilities, establish 500 kV station and 500 kV tie with 765 kV station	<b>Load-Ratio Share Allocation:</b> AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPSCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		<b>DFAX Allocation:</b> Dayton (8.37%) / DEOK (21.94%) / Dominion (56.40%) / EKPC (13.29%)

\*Neptune Regional Transmission System, LLC

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1797.1	Reconductor the AEP portion of the Cloverdale - Lexington 500 kV line with 2-1780 ACSS	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  AEP (0.79%) / APS (53.70%) / Dayton (0.15%) / DEOK (0.40%) / Dominion (1.13%) / EKPC (0.23%) / PEPCO (43.60%)</p>
b2055	Upgrade relay at Brues station	AEP (100%)
b2122.3	Upgrade terminal equipment at Howard on the Howard - Brookside 138 kV line to achieve ratings of 252/291 (SN/SE)	AEP (100%)
b2122.4	Perform a sag study on the Howard - Brookside 138 kV line	AEP (100%)
b2229	Install a 300 MVAR reactor at Dequine 345 kV	AEP (100%)

\*Neptune Regional Transmission System, LLC

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2230	Replace existing 150 MVAR reactor at Amos 765 kV substation on Amos - N. Proctorville - Hanging Rock with 300 MVAR reactor	<p><b>Load-Ratio Share Allocation:</b>                      AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>                      AEP (100%)</p>
b2231	Install 765 kV reactor breaker at Dumont 765 kV substation on the Dumont - Wilton Center line	AEP (100%)
b2232	Install 765 kV reactor breaker at Marysville 765 kV substation on the Marysville - Maliszewski line	AEP (100%)
b2233	Change transformer tap settings for the Baker 765/345 kV transformer	AEP (100%)
b2252	Loop the North Muskingum - Crooksville 138 kV line into AEP's Philo 138 kV station which lies approximately 0.4 miles from the line	AEP (100%)

\*Neptune Regional Transmission System, LLC

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2253	Install an 86.4 MVAR capacitor bank at Gorsuch 138 kV station in Ohio		AEP (100%)
b2254	Rebuild approximately 4.9 miles of Corner - Degussa 138 kV line in Ohio		AEP (100%)
b2255	Rebuild approximately 2.8 miles of Maliszewski - Polaris 138 kV line in Ohio		AEP (100%)
b2256	Upgrade approximately 36 miles of 138 kV through path facilities between Harrison 138 kV station and Ross 138 kV station in Ohio		AEP (100%)
b2257	Rebuild the Pokagon - Corey 69 kV line as a double circuit 138 kV line with one side at 69 kV and the other side as an express circuit between Pokagon and Corey stations		AEP (100%)
b2258	Rebuild 1.41 miles of #2 CU 46 kV line between Tams Mountain - Slab Fork to 138 kV standards. The line will be strung with 1033 ACSR		AEP (100%)
b2259	Install a new 138/69 kV transformer at George Washington 138/69 kV substation to provide support to the 69 kV system in the area		AEP (100%)
b2286	Rebuild 4.7 miles of Muskingum River - Wolf Creek 138 kV line and remove the 138/138 kV transformer at Wolf Creek Station		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2287	Loop in the Meadow Lake - Olive 345 kV circuit into Reynolds 765/345 kV station	AEP (100%)
b2344.1	Establish a new 138/12 kV station, transfer and consolidate load from its Nicholasville and Marcellus 34.5 kV stations at this new station	AEP (100%)
b2344.2	Tap the Hydramatic – Valley 138 kV circuit (~structure 415), build a new 138 kV line (~3.75 miles) to this new station	AEP (100%)
b2344.3	From this station, construct a new 138 kV line (~1.95 miles) to REA’s Marcellus station	AEP (100%)
b2344.4	From REA’s Marcellus station construct new 138 kV line (~2.35 miles) to a tap point on Valley – Hydramatic 138 kV ckt (~structure 434)	AEP (100%)
b2344.5	Retire sections of the 138 kV line in between structure 415 and 434 (~ 2.65 miles)	AEP (100%)
b2344.6	Retire AEP’s Marcellus 34.5/12 kV and Nicholasville 34.5/12 kV stations and also the Marcellus – Valley 34.5 kV line	AEP (100%)
b2345.1	Construct a new 69 kV line from Hartford to Keeler (~8 miles)	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2345.2	Rebuild the 34.5 kV lines between Keeler - Sister Lakes and Glenwood tap switch to 69 kV (~12 miles)		AEP (100%)
b2345.3	Implement in - out at Keeler and Sister Lakes 34.5 kV stations		AEP (100%)
b2345.4	Retire Glenwood tap switch and construct a new Rothadew station. These new lines will continue to operate at 34.5 kV		AEP (100%)
b2346	Perform a sag study for Howard - North Bellville - Millwood 138 kV line including terminal equipment upgrades		AEP (100%)
b2347	Replace the North Delphos 600A switch. Rebuild approximately 18.7 miles of 138 kV line North Delphos - S073. Reconductor the line and replace the existing tower structures		AEP (100%)
b2348	Construct a new 138 kV line from Richlands Station to intersect with the Hales Branch - Grassy Creek 138 kV circuit		AEP (100%)
b2374	Change the existing CT ratios of the existing equipment along Bearskin - Smith Mountain 138kV circuit		AEP (100%)
b2375	Change the existing CT ratios of the existing equipment along East Danville-Banister 138kV circuit		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2376	Replace the Turner 138 kV breaker 'D'	AEP (100%)
b2377	Replace the North Newark 138 kV breaker 'P'	AEP (100%)
b2378	Replace the Sporn 345 kV breaker 'DD'	AEP (100%)
b2379	Replace the Sporn 345 kV breaker 'DD2'	AEP (100%)
b2380	Replace the Muskingum 345 kV breaker 'SE'	AEP (100%)
b2381	Replace the East Lima 138 kV breaker 'E1'	AEP (100%)
b2382	Replace the Delco 138 kV breaker 'R'	AEP (100%)
b2383	Replace the Sporn 345 kV breaker 'AA2'	AEP (100%)
b2384	Replace the Sporn 345 kV breaker 'CC'	AEP (100%)
b2385	Replace the Sporn 345 kV breaker 'CC2'	AEP (100%)
b2386	Replace the Astor 138 kV breaker '102'	AEP (100%)
b2387	Replace the Muskingum 345 kV breaker 'SH'	AEP (100%)
b2388	Replace the Muskingum 345 kV breaker 'SI'	AEP (100%)
b2389	Replace the Hyatt 138 kV breaker '105N'	AEP (100%)
b2390	Replace the Muskingum 345 kV breaker 'SG'	AEP (100%)
b2391	Replace the Hyatt 138 kV breaker '101C'	AEP (100%)
b2392	Replace the Hyatt 138 kV breaker '104N'	AEP (100%)
b2393	Replace the Hyatt 138 kV breaker '104S'	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2394	Replace the Sporn 345 kV breaker 'CC1'	AEP (100%)
b2409	Install two 56.4 MVAR capacitor banks at the Melmore 138 kV station in Ohio	AEP (100%)
b2410	Convert Hogan Mullin 34.5 kV line to 138 kV, establish 138 kV line between Jones Creek and Strawton, rebuild existing Mullin Elwood 34.5 kV and terminate line into Strawton station, retire Mullin station	AEP (100%)
b2411	Rebuild the 3/0 ACSR portion of the Hadley - Kroemer Tap 69 kV line utilizing 795 ACSR conductor	AEP (100%)
b2423	Install a 300 MVAR shunt reactor at AEP's Wyoming 765 kV station	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  AEP (100%)</p>



**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2444	Willow - Eureka 138 kV line: Reconductor 0.26 mile of 4/0 CU with 336 ACSS		AEP (100%)
b2445	Complete a sag study of Tidd - Mahans Lake 138 kV line		AEP (100%)
b2449	Rebuild the 7-mile 345 kV line between Meadow Lake and Reynolds 345 kV stations		AEP (100%)
b2462	Add two 138 kV circuit breakers at Fremont station to fix tower contingency '408_2'		AEP (100%)
b2501	Construct a new 138/69 kV Yager station by tapping 2-138 kV FE circuits (Nottingham-Cloverdale, Nottingham-Harmon)		AEP (100%)
b2501.2	Build a new 138 kV line from new Yager station to Azalea station		AEP (100%)
b2501.3	Close the 138 kV loop back into Yager 138 kV by converting part of local 69 kV facilities to 138 kV		AEP (100%)
b2501.4	Build 2 new 69 kV exits to reinforce 69 kV facilities and upgrade conductor between Irish Run 69 kV Switch and Bowerstown 69 kV Switch		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2502.1	Construct new 138 kV switching station Nottingham tapping 6-138 kV FE circuits (Holloway-Brookside, Holloway-Harmon #1 and #2, Holloway-Reeds, Holloway-New Stacy, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd station		AEP (100%)
b2502.2	Convert Freebyrd 69 kV to 138 kV		AEP (100%)
b2502.3	Rebuild/convert Freebyrd-South Cadiz 69 kV circuit to 138 kV		AEP (100%)
b2502.4	Upgrade South Cadiz to 138 kV breaker and a half		AEP (100%)
b2530	Replace the Sporn 138 kV breaker 'G1' with 80kA breaker		AEP (100%)
b2531	Replace the Sporn 138 kV breaker 'D' with 80kA breaker		AEP (100%)
b2532	Replace the Sporn 138 kV breaker 'O1' with 80kA breaker		AEP (100%)
b2533	Replace the Sporn 138 kV breaker 'P2' with 80kA breaker		AEP (100%)
b2534	Replace the Sporn 138 kV breaker 'U' with 80kA breaker		AEP (100%)
b2535	Replace the Sporn 138 kV breaker 'O' with 80 kA breaker		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2536	Replace the Sporn 138 kV breaker 'O2' with 80 kA breaker		AEP (100%)
b2537	Replace the Robinson Park 138 kV breakers A1, A2, B1, B2, C1, C2, D1, D2, E1, E2, and F1 with 63 kA breakers		AEP (100%)
b2555	Reconductor 0.5 miles Tiltonsville – Windsor 138 kV and string the vacant side of the 4.5 mile section using 556 ACSR in a six wire configuration		AEP (100%)
b2556	Install two 138 kV prop structures to increase the maximum operating temperature of the Clinch River- Clinch Field 138 kV line		AEP (100%)
b2581	Temporary operating procedure for delay of upgrade b1464. Open the Corner 138 kV circuit breaker 86 for an overload of the Corner – Washington MP 138 kV line. The tower contingency loss of Belmont – Trissler 138 kV and Belmont – Edgelawn 138 kV should be added to Operational contingency		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2591	Construct a new 69 kV line approximately 2.5 miles from Colfax to Drewry's. Construct a new Drewry's station and install a new circuit breaker at Colfax station.		AEP (100%)
b2592	Rebuild existing East Coshocton – North Coshocton double circuit line which contains Newcomerstown – N. Coshocton 34.5 kV Circuit and Coshocton – North Coshocton 69 kV circuit		AEP (100%)
b2593	Rebuild existing West Bellaire – Glencoe 69 kV line with 138 kV & 69 kV circuits and install 138/69 kV transformer at Glencoe Switch		AEP (100%)
b2594	Rebuild 1.0 mile of Brantley – Bridge Street 69 kV Line with 1033 ACSR overhead conductor		AEP (100%)
b2595.1	Rebuild 7.82 mile Elkhorn City – Haysi S.S 69 kV line utilizing 1033 ACSR built to 138 kV standards		AEP (100%)
b2595.2	Rebuild 5.18 mile Moss – Haysi SS 69 kV line utilizing 1033 ACSR built to 138 kV standards		AEP (100%)
b2596	Move load from the 34.5 kV bus to the 138 kV bus by installing a new 138/12 kV XF at New Carlisle station in Indiana		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2597	Rebuild approximately 1 mi. section of Dragoon-Virgil Street 34.5 kV line between Dragoon and Dodge Tap switch and replace Dodge switch MOAB to increase thermal capability of Dragoon-Dodge Tap branch		AEP (100%)
b2598	Rebuild approximately 1 mile section of the Kline-Virgil Street 34.5 kV line between Kline and Virgil Street tap. Replace MOAB switches at Beiger, risers at Kline, switches and bus at Virgil Street.		AEP (100%)
b2599	Rebuild approximately 0.1 miles of 69 kV line between Albion and Albion tap		AEP (100%)
b2600	Rebuild Fremont – Pound line as 138 kV		AEP (100%)
b2601	Fremont Station Improvements		AEP (100%)
b2601.1	Replace MOAB towards Beaver Creek with 138 kV breaker		AEP (100%)
b2601.2	Replace MOAB towards Clinch River with 138 kV breaker		AEP (100%)
b2601.3	Replace 138 kV Breaker A with new bus-tie breaker		AEP (100%)
b2601.4	Re-use Breaker A as high side protection on transformer #1		AEP (100%)
b2601.5	Install two (2) circuit switchers on high side of transformers # 2 and 3 at Fremont Station		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2602.1	Install 138 kV breaker E2 at North Proctorville		AEP (100%)
b2602.2	Construct 2.5 Miles of 138 kV 1033 ACSR from East Huntington to Darrah 138 kV substations		AEP (100%)
b2602.3	Install breaker on new line exit at Darrah towards East Huntington		AEP (100%)
b2602.4	Install 138 kV breaker on new line at East Huntington towards Darrah		AEP (100%)
b2602.5	Install 138 kV breaker at East Huntington towards North Proctorville		AEP (100%)
b2603	Boone Area Improvements		AEP (100%)
b2603.1	Purchase approximately a 200X300 station site near Slaughter Creek 46 kV station (Wilbur Station)		AEP (100%)
b2603.2	Install 3 138 kV circuit breakers, Cabin Creek to Hernshaw 138 kV circuit		AEP (100%)
b2603.3	Construct 1 mi. of double circuit 138 kV line on Wilbur – Boone 46 kV line with 1590 ACSS 54/19 conductor @ 482 Degree design temp. and 1-159 12/7 ACSR and one 86 Sq.MM. 0.646” OPGW Static wires		AEP (100%)
b2604	Bellefonte Transformer Addition		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2605	Rebuild and reconductor Kammer – George Washington 69 kV circuit and George Washington – Moundville ckt #1, designed for 138kV. Upgrade limiting equipment at remote ends and at tap stations		AEP (100%)
b2606	Convert Bane – Hammondsville from 23 kV to 69 kV operation		AEP (100%)
b2607	Pine Gap Relay Limit Increase		AEP (100%)
b2608	Richlands Relay Upgrade		AEP (100%)
b2609	Thorofare – Goff Run – Powell Mountain 138 kV Build		AEP (100%)
b2610	Rebuild Pax Branch – Scaraboro as 138 kV		AEP (100%)
b2611	Skin Fork Area Improvements		AEP (100%)
b2611.1	New 138/46 kV station near Skin Fork and other components		AEP (100%)
b2611.2	Construct 3.2 miles of 1033 ACSR double circuit from new Station to cut into Sundial-Baileysville 138 kV line		AEP (100%)
b2634.1	Replace metering BCT on Tanners Creek CB T2 with a slip over CT with higher thermal rating in order to remove 1193 MVA limit on facility (Miami Fort-Tanners Creek 345 kV line)		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2643	Replace the Darrah 138 kV breaker 'L' with 40kA rated breaker		AEP (100%)
b2645	Ohio Central 138 kV Loop		AEP (100%)
b2667	Replace the Muskingum 138 kV bus # 1 and 2		AEP (100%)
b2668	Reconductor Dequine to Meadow Lake 345 kV circuit #1 utilizing dual 954 ACSR 54/7 cardinal conductor		AEP (100%)
b2669	Install a second 345/138 kV transformer at Desoto		AEP (100%)
b2670	Replace switch at Elk Garden 138 kV substation (on the Elk Garden – Lebanon 138 kV circuit)		AEP (100%)
b2671	Replace/upgrade/add terminal equipment at Bradley, Mullensville, Pinnacle Creek, Itmann, and Tams Mountain 138 kV substations. Sag study on Mullens – Wyoming and Mullens – Tams Mt. 138 kV circuits		AEP (100%)



**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2687.1	Install a +/- 450 MVAR SVC at Jacksons Ferry 765 kV substation	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPSCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  AEP (100%)</p>

\*Neptune Regional Transmission System, LLC

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2687.2	Install a 300 MVAR shunt line reactor on the Broadford end of the Broadford – Jacksons Ferry 765 kV line	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  AEP (100%)</p>
b2697.1	Mitigate violations identified by sag study to operate Fieldale-Thornton-Franklin 138 kV overhead line conductor at its max. operating temperature. 6 potential line crossings to be addressed.	AEP (100%)
b2697.2	Replace terminal equipment at AEP’s Danville and East Danville substations to improve thermal capacity of Danville – East Danville 138 kV circuit	AEP (100%)

\*Neptune Regional Transmission System, LLC

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2698	Replace relays at AEP's Cloverdale and Jackson's Ferry substations to improve the thermal capacity of Cloverdale – Jackson's Ferry 765 kV line		AEP (100%)
b2701.1	Construct Herlan station as breaker and a half configuration with 9-138 kV CB's on 4 strings and with 2-28.8 MVAR capacitor banks		AEP (100%)
b2701.2	Construct new 138 kV line from Herlan station to Blue Racer station. Estimated approx. 3.2 miles of 1234 ACSS/TW Yukon and OPGW		AEP (100%)
2701.3	Install 1-138 kV CB at Blue Racer to terminate new Herlan circuit		AEP (100%)
b2714	Rebuild/upgrade line between Glencoe and Willow Grove Switch 69 kV		AEP (100%)
b2715	Build approximately 11.5 miles of 34.5 kV line with 556.5 ACSR 26/7 Dove conductor on wood poles from Flushing station to Smyrna station		AEP (100%)
b2727	Replace the South Canton 138 kV breakers 'K', 'J', 'J1', and 'J2' with 80kA breakers		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2731	Convert the Sunnyside – East Sparta – Malvern 23 kV sub-transmission network to 69 kV. The lines are already built to 69 kV standards		AEP (100%)
b2733	Replace South Canton 138 kV breakers ‘L’ and ‘L2’ with 80 kA rated breakers		AEP (100%)
b2750.1	Retire Betsy Layne 138/69/43 kV station and replace it with the greenfield Stanville station about a half mile north of the existing Betsy Layne station		AEP (100%)
b2750.2	Relocate the Betsy Layne capacitor bank to the Stanville 69 kV bus and increase the size to 14.4 MVAR		AEP (100%)
b2753.1	Replace existing George Washington station 138 kV yard with GIS 138 kV breaker and a half yard in existing station footprint. Install 138 kV revenue metering for new IPP connection		AEP (100%)
b2753.2	Replace Dilles Bottom 69/4 kV Distribution station as breaker and a half 138 kV yard design including AEP Distribution facilities but initial configuration will constitute a 3 breaker ring bus		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2753.3	Connect two 138 kV 6-wired circuits from “Point A” (currently de-energized and owned by FirstEnergy) in circuit positions previously designated Burger #1 & Burger #2 138 kV. Install interconnection settlement metering on both circuits exiting Holloway		AEP (100%)
b2753.6	Build double circuit 138 kV line from Dilles Bottom to “Point A”. Tie each new AEP circuit in with a 6-wired line at Point A. This will create a Dilles Bottom – Holloway 138 kV circuit and a George Washington – Holloway 138 kV circuit		AEP (100%)
b2753.7	Retire line sections (Dilles Bottom – Bellaire and Moundsville – Dilles Bottom 69 kV lines) south of FirstEnergy 138 kV line corridor, near “Point A”. Tie George Washington – Moundsville 69 kV circuit to George Washington – West Bellaire 69 kV circuit		AEP (100%)
b2753.8	Rebuild existing 69 kV line as double circuit from George Washington – Dilles Bottom 138 kV. One circuit will cut into Dilles Bottom 138 kV initially and the other will go past with future plans to cut in		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2760	Perform a Sag Study of the Saltville – Tazewell 138 kV line to increase the thermal rating of the line		AEP (100%)
b2761.1	Replace the Hazard 161/138 kV transformer		AEP (100%)
b2761.2	Perform a Sag Study of the Hazard – Wooten 161 kV line to increase the thermal rating of the line		AEP (100%)
b2761.3	Rebuild the Hazard – Wooton 161 kV line utilizing 795 26/7 ACSR conductor (300 MVA rating)		AEP (100%)
b2762	Perform a Sag Study of Nagel – West Kingsport 138 kV line to increase the thermal rating of the line		AEP (100%)
b2776	Reconductor the entire Dequine – Meadow Lake 345 kV circuit #2		AEP (100%)
b2777	Reconductor the entire Dequine – Eugene 345 kV circuit #1		<i>EKPC</i> (100%)
b2779.1	Construct a new 138 kV station, Campbell Road, tapping into the Grabill – South Hicksville 138 kV line		AEP (100%)
b2779.2	Reconstruct sections of the Butler-N.Hicksville and Auburn-Butler 69 kV circuits as 138 kV double circuit and extend 138 kV from Campbell Road station		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2779.3	Construct a new 345/138 kV SDI Wilmington Station which will be sourced from Collingwood 345 kV and serve the SDI load at 345 kV and 138 kV, respectively		AEP (100%)
b2779.4	Loop 138 kV circuits in-out of the new SDI Wilmington 138 kV station resulting in a direct circuit to Auburn 138 kV and an indirect circuit to Auburn and Rob Park via Dunton Lake, and a circuit to Campbell Road; Reconductor 138 kV line section between Dunton Lake – SDI Wilmington		AEP (100%)
b2779.5	Expand Auburn 138 kV bus		AEP (100%)
b2787	Reconductor 0.53 miles (14 spans) of the Kaiser Jct. - Air Force Jct. Sw section of the Kaiser - Heath 69 kV circuit/line with 336 ACSR to match the rest of the circuit (73 MVA rating, 78% loading)		AEP (100%)
b2788	Install a new 3-way 69 kV line switch to provide service to AEP's Barnesville distribution station. Remove a portion of the #1 copper T-Line from the 69 kV through-path		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2789	Rebuild the Brues - Glendale Heights 69 kV line section (5 miles) with 795 ACSR (128 MVA rating, 43% loading)	AEP (100%)
b2790	Install a 3 MVAR, 34.5 kV cap bank at Caldwell substation	AEP (100%)
b2791	Rebuild Tiffin – Howard, new transformer at Chatfield	AEP (100%)
b2791.1	Rebuild portions of the East Tiffin - Howard 69 kV line from East Tiffin to West Rockaway Switch (0.8 miles) using 795 ACSR Drake conductor (129 MVA rating, 50% loading)	AEP (100%)
b2791.2	Rebuild Tiffin - Howard 69 kV line from St. Stephen’s Switch to Hinesville (14.7 miles) using 795 ACSR Drake conductor (90 MVA rating, non-conductor limited, 38% loading)	AEP (100%)
b2791.3	New 138/69 kV transformer with 138/69 kV protection at Chatfield	AEP (100%)
b2791.4	New 138/69 kV protection at existing Chatfield transformer	AEP (100%)
b2792	Replace the Elliott transformer with a 130 MVA unit, reconductor 0.42 miles of the Elliott – Ohio University 69 kV line with 556 ACSR to match the rest of the line conductor (102 MVA rating, 73% loading) and rebuild 4 miles of the Clark Street – Strouds R	AEP (100%)



**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2793	Energize the spare Fremont Center 138/69 kV 130 MVA transformer #3. Reduces overloaded facilities to 46% loading	AEP (100%)
b2794	Construct new 138/69/34 kV station and 1-34 kV circuit (designed for 69 kV) from new station to Decliff station, approximately 4 miles, with 556 ACSR conductor (51 MVA rating)	AEP (100%)
b2795	Install a 34.5 kV 4.8 MVAR capacitor bank at Killbuck 34.5 kV station	AEP (100%)
b2796	Rebuild the Malvern - Oneida Switch 69 kV line section with 795 ACSR (1.8 miles, 125 MVA rating, 55% loading)	AEP (100%)
b2797	Rebuild the Ohio Central - Conesville 69 kV line section (11.8 miles) with 795 ACSR conductor (128 MVA rating, 57% loading). Replace the 50 MVA Ohio Central 138/69 kV XFMR with a 90 MVA unit	AEP (100%)
b2798	Install a 14.4 MVAR capacitor bank at West Hicksville station. Replace ground switch/MOAB at West Hicksville with a circuit switcher	AEP (100%)
b2799	Rebuild Valley - Almena, Almena - Hartford, Riverside - South Haven 69 kV lines. New line exit at Valley Station. New transformers at Almena and Hartford	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2799.1	Rebuild 12 miles of Valley – Almena 69 kV line as a double circuit 138/69 kV line using 795 ACSR conductor (360 MVA rating) to introduce a new 138 kV source into the 69 kV load pocket around Almena station	AEP (100%)
b2799.2	Rebuild 3.2 miles of Almena to Hartford 69 kV line using 795 ACSR conductor (90 MVA rating)	AEP (100%)
b2799.3	Rebuild 3.8 miles of Riverside – South Haven 69 kV line using 795 ACSR conductor (90 MVA rating)	AEP (100%)
b2799.4	At Valley station, add new 138 kV line exit with a 3000 A 40 kA breaker for the new 138 kV line to Almena and replace CB D with a 3000 A 40 kA breaker	AEP (100%)
b2799.5	At Almena station, install a 90 MVA 138/69 kV transformer with low side 3000 A 40 kA breaker and establish a new 138 kV line exit towards Valley	AEP (100%)
b2799.6	At Hartford station, install a second 90 MVA 138/69 kV transformer with a circuit switcher and 3000 A 40 kA low side breaker	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2817	Replace Delaware 138 kV breaker 'P' with a 40 kA breaker	AEP (100%)
b2818	Replace West Huntington 138 kV breaker 'F' with a 40 kA breaker	AEP (100%)
b2819	Replace Madison 138 kV breaker 'V' with a 63 kA breaker	AEP (100%)
b2820	Replace Sterling 138 kV breaker 'G' with a 40 kA breaker	AEP (100%)
b2821	Replace Morse 138 kV breakers '103', '104', '105', and '106' with 63 kA breakers	AEP (100%)
b2822	Replace Clinton 138 kV breakers '105' and '107' with 63 kA breakers	AEP (100%)
b2826.1	Install 300 MVAR reactor at Ohio Central 345 kV substation	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2826.2	Install 300 MVAR reactor at West Bellaire 345 kV substation		AEP (100%)
b2831.1	Upgrade the Tanner Creek – Miami Fort 345 kV circuit (AEP portion)		<b>DFAX Allocation:</b> Dayton (61.71%) / DEOK (37.68%) / OVEC (0.61%)
b2832	Six wire the Kyger Creek – Sporn 345 kV circuits #1 and #2 and convert them to one circuit		AEP (100%)
b2833	Reconductor the Maddox Creek – East Lima 345 kV circuit with 2-954 ACSS Cardinal conductor		<b>DFAX Allocation:</b> AEP (80.83%) / Dayton (18.73%) / OVEC (0.44%)
b2834	Reconductor and string open position and sixwire 6.2 miles of the Chemical – Capitol Hill 138 kV circuit		AEP (100%)
b2872	Replace the South Canton 138 kV breaker ‘K2’ with a 80 kA breaker		AEP (100%)
b2873	Replace the South Canton 138 kV breaker “M” with a 80 kA breaker		AEP (100%)
b2874	Replace the South Canton 138 kV breaker “M2” with a 80 kA breaker		AEP (100%)
b2878	Upgrade the Clifty Creek 345 kV risers		AEP (100%)
b2880	Rebuild approximately 4.77 miles of the Cannonsburg – South Neal 69 kV line section utilizing 795 ACSR conductor (90 MVA rating)		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2881	Rebuild ~1.7 miles of the Dunn Hollow – London 46 kV line section utilizing 795 26/7 ACSR conductor (58 MVA rating, non-conductor limited)	AEP (100%)
b2882	Rebuild Reusens - Peakland Switch 69 kV line. Replace Peakland Switch	AEP (100%)
b2882.1	Rebuild the Reusens - Peakland Switch 69 kV line (approximately 0.8 miles) utilizing 795 ACSR conductor (86 MVA rating, non-conductor limited)	AEP (100%)
b2882.2	Replace existing Peakland S.S with new 3 way switch phase over phase structure	AEP (100%)
b2883	Rebuild the Craneco – Pardee – Three Forks – Skin Fork 46 kV line section (approximately 7.2 miles) utilizing 795 26/7 ACSR conductor (108 MVA rating)	AEP (100%)
b2884	Install a second transformer at Nagel station, comprised of 3 single phase 250 MVA 500/138 kV transformers. Presently, TVA operates their end of the Boone Dam – Holston 138 kV interconnection as normally open preemptively for the loss of the existing Nagel	AEP (100%)
b2885	New delivery point for City of Jackson	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2885.1	Install a new Ironman Switch to serve a new delivery point requested by the City of Jackson for a load increase request	AEP (100%)
b2885.2	Install a new 138/69 kV station (Rhodes) to serve as a third source to the area to help relieve overloads caused by the customer load increase	AEP (100%)
b2885.3	Replace Coalton Switch with a new three breaker ring bus (Heppner)	AEP (100%)
b2886	Install 90 MVA 138/69 kV transformer, new transformer high and low side 3000 A 40 kA CBs, and a 138 kV 40 kA bus tie breaker at West End Fostoria	AEP (100%)
b2887	Add 2-138 kV CB's and relocate 2-138 kV circuit exits to different bays at Morse Road. Eliminate 3 terminal line by terminating Genoa - Morse circuit at Morse Road	AEP (100%)
b2888	Retire Poston substation. Install new Lemaster substation	AEP (100%)
b2888.1	Remove and retire the Poston 138 kV station	AEP (100%)
b2888.2	Install a new greenfield station, Lemaster 138 kV Station, in the clear	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2888.3	Relocate the Trimble 69 kV AEP Ohio radial delivery point to 138 kV, to be served off of the Poston – Strouds Run – Crooksville 138 kV circuit via a new three-way switch. Retire the Poston - Trimble 69 kV line	AEP (100%)
b2889	Expand Cliffview station	AEP (100%)
b2889.1	Cliffview Station: Establish 138 kV bus. Install two 138/69 kV XFRs (130 MVA), six 138 kV CBs (40 kA 3000 A) and four 69 kV CBs (40 kA 3000 A)	AEP (100%)
b2889.2	Byllesby – Wythe 69 kV: Retire all 13.77 miles (1/0 CU) of this circuit (~4 miles currently in national forest)	AEP (100%)
b2889.3	Galax – Wythe 69 kV: Retire 13.53 miles (1/0 CU section) of line from Lee Highway down to Byllesby. This section is currently double circuited with Byllesby – Wythe 69 kV. Terminate the southern 3/0 ACSR section into the newly opened position at Byllesby	AEP (100%)
b2889.4	Cliffview Line: Tap the existing Pipers Gap – Jubal Early 138 kV line section. Construct double circuit in/out (~2 miles) to newly established 138 kV bus, utilizing 795 26/7 ACSR conductor	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2890.1	Rebuild 23.55 miles of the East Cambridge – Smyrna 34.5 kV circuit with 795 ACSR conductor (128 MVA rating) and convert to 69 kV	AEP (100%)
b2890.2	East Cambridge: Install a 2000 A 69 kV 40 kA circuit breaker for the East Cambridge – Smyrna 69 kV circuit	AEP (100%)
b2890.3	Old Washington: Install 69 kV 2000 A two way phase over phase switch	AEP (100%)
b2890.4	Install 69 kV 2000 A two way phase over phase switch	AEP (100%)
b2891	Rebuild the Midland Switch to East Findlay 34.5 kV line (3.31 miles) with 795 ACSR (63 MVA rating) to match other conductor in the area	AEP (100%)
b2892	Install new 138/12 kV transformer with high side circuit switcher at Leon and a new 138 kV line exit towards Ripley. Establish 138 kV at the Ripley station with a new 138/69 kV 130 MVA transformer and move the distribution load to 138 kV service	AEP (100%)
b2936.1	Rebuild approximately 6.7 miles of 69 kV line between Mottville and Pigeon River using 795 ACSR conductor (129 MVA rating). New construction will be designed to 138 kV standards but operated at 69 kV	AEP (100%)



**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements      Annual Revenue Requirement      Responsible Customer(s)

b2936.2	Pigeon River Station: Replace existing MOAB Sw. 'W' with a new 69 kV 3000 A 40 kA breaker, and upgrade existing relays towards HMD station. Replace CB H with a 3000 A 40 kA breaker		AEP (100%)
b2937	Replace the existing 636 ACSR 138 kV bus at Fletchers Ridge with a larger 954 ACSR conductor		AEP (100%)
b2938	Perform a sag mitigations on the Broadford – Wolf Hills 138 kV circuit to allow the line to operate to a higher maximum temperature		AEP (100%)
b2958.1	Cut George Washington – Tidd 138 kV circuit into Sand Hill and reconfigure Brues & Warton Hill line entrances		AEP (100%)
b2958.2	Add 2 138 kV 3000 A 40 kA breakers, disconnect switches, and update relaying at Sand Hill station		AEP (100%)
b2968	Upgrade existing 345 kV terminal equipment at Tanner Creek station		AEP (100%)
b2969	Replace terminal equipment on Maddox Creek - East Lima 345 kV circuit		AEP (100%)
b2976	Upgrade terminal equipment at Tanners Creek 345 kV station. Upgrade 345 kV bus and risers at Tanners Creek for the Dearborn circuit		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2988	Replace the Twin Branch 345 kV breaker “JM” with 63 kA breaker and associated substation works including switches, bus leads, control cable and new DICM	AEP (100%)
b2993	Rebuild the Torrey – South Gambrinus Switch – Gambrinus Road 69 kV line section (1.3 miles) with 1033 ACSR ‘Curlew’ conductor and steel poles	AEP (100%)
b3000	Replace South Canton 138 kV breaker ‘N’ with an 80kA breaker	AEP (100%)
b3001	Replace South Canton 138 kV breaker ‘N1’ with an 80kA breaker	AEP (100%)
b3002	Replace South Canton 138 kV breaker ‘N2’ with an 80kA breaker	AEP (100%)
b3036	Rebuild 15.6 miles of Haviland - North Delphos 138 kV line	AEP (100%)
b3037	Upgrades at the Natrium substation	AEP (100%)
b3038	Reconductor the Capitol Hill – Coco 138 kV line section	AEP (100%)
b3039	Line swaps at Muskingum 138 kV station	AEP (100%)
b3040.1	Rebuild Ravenswood – Racine tap 69 kV line section (~15 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3040.2	Rebuild existing Ripley – Ravenswood 69 kV circuit (~9 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)
b3040.3	Install new 3-way phase over phase switch at Sarah Lane station to replace the retired switch at Cottageville	AEP (100%)
b3040.4	Install new 138/12 kV 20 MVA transformer at Polymer station to transfer load from Mill Run station to help address overload on the 69 kV network	AEP (100%)
b3040.5	Retire Mill Run station	AEP (100%)
b3040.6	Install 28.8 MVAR cap bank at South Buffalo station	AEP (100%)
b3051.2	Adjust CT tap ratio at Ronceverte 138 kV	AEP (100%)
b3085	Reconductor Kammer – George Washington 138 kV line (approx. 0.08 mile). Replace the wave trap at Kammer 138 kV	AEP (100%)
b3086.1	Rebuild New Liberty – Findlay 34 kV line Str’s 1–37 (1.5 miles), utilizing 795 26/7 ACSR conductor	AEP (100%)
b3086.2	Rebuild New Liberty – North Baltimore 34 kV line Str’s 1-11 (0.5 mile), utilizing 795 26/7 ACSR conductor	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3086.3	Rebuild West Melrose – Whirlpool 34 kV line Str’s 55–80 (1 mile), utilizing 795 26/7 ACSR conductor	AEP (100%)
b3086.4	North Findlay station: Install a 138 kV 3000A 63kA line breaker and low side 34.5 kV 2000A 40kA breaker, high side 138 kV circuit switcher on T1	AEP (100%)
b3086.5	Ebersole station: Install second 90 MVA 138/69/34 kV transformer. Install two low side (69 kV) 2000A 40kA breakers for T1 and T2	AEP (100%)
b3087.1	Construct a new greenfield station to the west (approx. 1.5 miles) of the existing Fords Branch Station in the new Kentucky Enterprise Industrial Park. This station will consist of six 3000A 40kA 138 kV breakers laid out in a ring arrangement, two 30 MVA 138/34.5 kV transformers, and two 30 MVA 138/12 kV transformers. The existing Fords Branch Station will be retired	AEP (100%)
b3087.2	Construct approximately 5 miles of new double circuit 138 kV line in order to loop the new Kewanee station into the existing Beaver Creek – Cedar Creek 138 kV circuit	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3087.3	Remote end work will be required at Cedar Creek Station	AEP (100%)
b3087.4	Install 28.8 MVar switching shunt at the new Fords Branch substation	AEP (100%)
b3095	Rebuild Lakin – Racine Tap 69 kV line section (9.2 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)
b3099	Install a 138 kV 3000A 40 kA circuit switcher on the high side of the existing 138/34.5 kV transformer No.5 at Holston station	AEP (100%)
b3100	Replace the 138 kV MOAB switcher “YY” with a new 138 kV circuit switcher on the high side of Chemical transformer No.6	AEP (100%)
b3101	Rebuild the 1/0 Cu. conductor sections (approx. 1.5 miles) of the Fort Robinson – Moccasin Gap 69 kV line section (approx. 5 miles) utilizing 556 ACSR conductor and upgrade existing relay trip limit (WN/WE: 63 MVA, line limited by remaining conductor sections)	AEP (100%)
b3102	Replace existing 50 MVA 138/69 kV transformers #1 and #2 (both 1957 vintage) at Fremont station with new 130 MVA 138/69 kV transformers	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement		Responsible Customer(s)
b3103.1	Install a 138/69 kV transformer at Royerton station. Install a 69 kV bus with one 69 kV breaker toward Bosman station. Rebuild the 138 kV portion into a ring bus configuration built for future breaker and a half with four 138 kV breakers		AEP (100%)
b3103.2	Rebuild the Bosman/Strawboard station in the clear across the road to move it out of the flood plain and bring it up to 69 kV standards		AEP (100%)
b3103.3	Retire 138 kV breaker L at Delaware station and re-purpose 138 kV breaker M for the Jay line		AEP (100%)
b3103.4	Retire all 34.5 kV equipment at Hartford City station. Re-purpose breaker M for the Bosman line 69 kV exit		AEP (100%)
b3103.5	Rebuild the 138 kV portion of Jay station as a 6 breaker, breaker and a half station re-using the existing breakers "A", "B", and "G." Rebuild the 69 kV portion of this station as a 6 breaker ring bus re-using the 2 existing 69 kV breakers. Install a new 138/69 kV transformer		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3103.6	Rebuild the 69 kV Hartford City – Armstrong Cork line but instead of terminating it into Armstrong Cork, terminate it into Jay station	AEP (100%)
b3103.7	Build a new 69 kV line from Armstrong Cork – Jay station	AEP (100%)
b3103.8	Rebuild the 34.5 kV Delaware – Bosman line as the 69 kV Royerton – Strawboard line. Retire the line section from Royerton to Delaware stations	AEP (100%)
b3104	Perform a sag study on the Polaris – Westerville 138 kV line (approx. 3.6 miles) to increase the summer emergency rating to 310 MVA	AEP (100%)
b3105	Rebuild the Delaware – Hyatt 138 kV line (approx. 4.3 miles) along with replacing conductors at both Hyatt and Delaware substations	AEP (100%)
b3106	Perform a sag study (6.8 miles of line) to increase the SE rating to 310 MVA. Note that results from the sag study could cover a wide range of outcomes, from no work required to a complete rebuild	AEP (100%)
b3109	Rebuild 5.2 miles Bethel – Sawmill 138 kV line including ADSS	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3112	Construct a single circuit 138 kV line (approx. 3.5 miles) from Amlin to Dublin using 1033 ACSR Curlew (296 MVA SN), convert Dublin station into a ring configuration, and re-terminating the Britton UG cable to Dublin station	AEP (100%)
b3116	Replace existing Mullens 138/46 kV 30 MVA transformer No.4 and associated protective equipment with a new 138/46 kV 90 MVA transformer and associated protective equipment	AEP (100%)
b3118.1	Expand existing Chadwick station and install a second 138/69 kV transformer at a new 138 kV bus tied into the Bellefonte – Grangston 138 kV circuit. The 69 kV bus will be reconfigured into a ring bus arrangement to tie the new transformer into the existing 69 kV via installation of four 3000A 63 kA 69 kV circuit breakers	AEP (100%)
b3118.2	Perform 138 kV remote end work at Grangston station	AEP (100%)
b3118.3	Perform 138 kV remote end work at Bellefonte station	AEP (100%)
b3118.4	Relocate the Chadwick – Leach 69 kV circuit within Chadwick station	AEP (100%)



**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3118.5	Terminate the Bellefonte – Grangston 138 kV circuit to the Chadwick 138 kV bus	AEP (100%)
b3118.6	Chadwick – Tri-State #2 138 kV circuit will be reconfigured within the station to terminate into the newly established 138 kV bus #2 at Chadwick due to construability aspects	AEP (100%)
b3118.7	Reconductor Chadwick – Leach and Chadwick – England Hill 69 kV lines with 795 ACSS conductor. Perform a LiDAR survey and a sag study to confirm that the reconductored circuits would maintain acceptable clearances	AEP (100%)
b3118.8	Replace the 20 kA 69 kV circuit breaker ‘F’ at South Neal station with a new 3000A 40 kA 69 kV circuit breaker. Replace line risers towards Leach station	AEP (100%)
b3118.9	Rebuild 336 ACSR portion of Leach – Miller S.S 69 kV line section (approx. 0.3 mile) with 795 ACSS conductor	AEP (100%)
b3118.10	Replace 69 kV line risers (towards Chadwick) at Leach station	AEP (100%)
b3119.1	Rebuild the Jay – Pennville 138 kV line as double circuit 138/69 kV. Build a new 9.8 mile single circuit 69 kV line from near Pennville station to North Portland station	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3119.2	Install three (3) 69 kV breakers to create the “U” string and add a low side breaker on the Jay transformer 2	AEP (100%)
b3119.3	Install two (2) 69 kV breakers at North Portland station to complete the ring and allow for the new line	AEP (100%)
b3129	At Conesville 138 kV station: Remove line leads to generating units, transfer plant AC service to existing station service feeds in Conesville 345/138 kV yard, and separate and reconfigure protection schemes	AEP (100%)
b3131	At East Lima and Haviland 138 kV stations, replace line relays and wavetrap on the East Lima – Haviland 138 kV facility	AEP (100%)
b3132	Rebuild 3.11 miles of the LaPorte Junction – New Buffalo 69 kV line with 795 ACSR	AEP (100%)
b3139	Rebuild the Garden Creek – Whetstone 69 kV line (approx. 4 miles)	AEP (100%)
b3140	Rebuild the Whetstone – Knox Creek 69 kV line (approx. 3.1 miles)	AEP (100%)
b3141	Rebuild the Knox Creek – Coal Creek 69 kV line (approx. 2.9 miles)	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3148.1	Rebuild the 46 kV Bradley – Scarbro line to 96 kV standards using 795 ACSR to achieve a minimum rate of 120 MVA. Rebuild the new line adjacent to the existing one leaving the old line in service until the work is completed	AEP (100%)
b3148.2	Bradley remote end station work, replace 46 kV bus, install new 12 MVAR capacitor bank	AEP (100%)
b3148.3	Replace the existing switch at Sun substation with a 2-way SCADA-controlled motor-operated air-breaker switch	AEP (100%)
b3148.4	Remote end work and associated equipment at Scarbro station	AEP (100%)
b3148.5	Retire Mt. Hope station and transfer load to existing Sun station	AEP (100%)
b3149	Rebuild the 2.3 mile Decatur – South Decatur 69 kV line using 556 ACSR	AEP (100%)
b3150	Rebuild Ferguson 69/12 kV station in the clear as the 138/12 kV Bear station and connect it to an approx. 1 mile double circuit 138 kV extension from the Aviation – Ellison Road 138 kV line to remove the load from the 69 kV line	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3151.1	Rebuild the 30 mile Gateway – Wallen 34.5 kV circuit as the 27 mile Gateway – Wallen 69 kV line	AEP (100%)
b3151.2	Retire approx. 3 miles of the Columbia – Whitley 34.5 kV line	AEP (100%)
b3151.3	At Gateway station, remove all 34.5 kV equipment and install one (1) 69 kV circuit breaker for the new Whitley line entrance	AEP (100%)
b3151.4	Rebuild Whitley as a 69 kV station with two (2) lines and one (1) bus tie circuit breaker	AEP (100%)
b3151.5	Replace the Union 34.5 kV switch with a 69 kV switch structure	AEP (100%)
b3151.6	Replace the Eel River 34.5 kV switch with a 69 kV switch structure	AEP (100%)
b3151.7	Install a 69 kV Bobay switch at Woodland station	AEP (100%)
b3151.8	Replace the Carroll and Churubusco 34.5 kV stations with the 69 kV Snapper station. Snapper station will have two (2) line circuit breakers, one (1) bus tie circuit breaker and a 14.4 MVAR cap bank	AEP (100%)
b3151.9	Remove 34.5 kV circuit breaker “AD” at Wallen station	AEP (100%)
b3151.10	Rebuild the 2.5 miles of the Columbia – Gateway 69 kV line	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3151.11	Rebuild Columbia station in the clear as a 138/69 kV station with two (2) 138/69 kV transformers and 4-breaker ring buses on the high and low side. Station will reuse 69 kV breakers “J” & “K” and 138 kV breaker “D”	AEP (100%)
b3151.12	Rebuild the 13 miles of the Columbia – Richland 69 kV line	AEP (100%)
b3151.13	Rebuild the 0.5 mile Whitley – Columbia City No.1 line as 69 kV	AEP (100%)
b3151.14	Rebuild the 0.5 mile Whitley – Columbia City No.2 line as 69 kV	AEP (100%)
b3151.15	Rebuild the 0.6 mile double circuit section of the Rob Park – South Hicksville / Rob Park – Diebold Road as 69 kV	AEP (100%)
b3160.1	Construct an approx. 2.4 miles double circuit 138 kV extension using 1033 ACSR (Aluminum Conductor Steel Reinforced) to connect Lake Head to the 138 kV network	AEP (100%)
b3160.2	Retire the approx.2.5 miles 34.5 kV Niles – Simplicity Tap line	AEP (100%)
b3160.3	Retire the approx.4.6 miles Lakehead 69 kV Tap	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement		Responsible Customer(s)
b3160.4	Build new 138/69 kV drop down station to feed Lakehead with a 138 kV breaker, 138 kV switcher, 138/69 kV transformer and a 138 kV Motor-Operated Air Break		AEP (100%)
b3160.5	Rebuild the approx. 1.2 miles Buchanan South 69 kV Radial Tap using 795 ACSR (Aluminum Conductor Steel Reinforced)		AEP (100%)
b3160.6	Rebuild the approx.8.4 miles 69 kV Pletcher – Buchanan Hydro line as the approx. 9 miles Pletcher – Buchanan South 69 kV line using 795 ACSR (Aluminum Conductor Steel Reinforced)		AEP (100%)
b3160.7	Install a PoP (Point-of-Presence) switch at Buchanan South station with 2 line MOABs (Motor-Operated Air Break)		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3208	Retire approximately 38 miles of the 44 mile Clifford – Scottsville 46 kV circuit. Build new 138 kV “in and out” to two new distribution stations to serve the load formerly served by Phoenix, Shipman, Schuyler (AEP), and Rockfish stations. Construct new 138 kV lines from Joshua Falls – Riverville (approx. 10 miles) and Riverville – Gladstone (approx. 5 miles). Install required station upgrades at Joshua Falls, Riverville and Gladstone stations to accommodate the new 138 kV circuits. Rebuild Reusen – Monroe 69 kV (approx. 4 miles)	AEP (100%)
b3209	Rebuild the 10.5 mile Berne – South Decatur 69 kV line using 556 ACSR	AEP (100%)
b3210	Replace approx. 0.7 mile Beatty – Galloway 69 kV line with 4000 kcmil XLPE cable	AEP (100%)
<u>b3220</u>	<u>Install 14.4 MVAR capacitor bank at Whitewood 138 kV</u>	<u>AEP (100%)</u>
<u>b3261</u>	<u>Upgrade circuit breaker “R1” at Tanners Creek 345 kV. Install Transient Recovery Voltage capacitor to increase the rating from 50 kA to 63 kA</u>	<u>AEP (100%)</u>

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
<u>b3269</u>	<u>At West New Philadelphia station, add a high side 138 kV breaker on the 138/69 kV Transformer #2 along with a 138 kV breaker on the line towards Newcomerstown</u>	<u>AEP (100%)</u>
<u>b3270</u>	<u>Install 1.7 miles of 795 ACSR 138 kV conductor along the other side of Dragoon Tap 138 kV line, which is currently double circuit tower with one position open. Additionally, install a second 138/34.5 kV transformer at Dragoon, install a high side circuit switcher on the current transformer at the Dragoon Station, and install two (2) 138 kV line breakers on the Dragoon – Jackson 138 kV and Dragoon – Twin Branch 138 kV lines</u>	<u>AEP (100%)</u>
<u>b3270.1</u>	<u>Replace Dragoon 34.5 kV breakers “B”, “C”, and “D” with 40 kA breakers</u>	<u>AEP (100%)</u>
<u>b3271</u>	<u>Install a 138 kV circuit breaker at Fremont station on the line towards Fremont Center and install a 9.6 MVAR 69 kV capacitor bank at Bloom Road station</u>	<u>AEP (100%)</u>
<u>b3272</u>	<u>Install two 138 kV circuit switchers on the high side of 138/34.5 kV Transformers #1 and #2 at Rockhill station</u>	<u>AEP (100%)</u>



**SCHEDULE 12 – APPENDIX A**

**(19) Northern Indiana Public Service Company**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2971	Reconfigure Munster 345 kV as ring bus	MISO (12.00%) / AEC (0.97%) / AEP (16.65%) / APS (4.94%) / ATSI (7.77%) / BGE (5.20%) / Dayton (1.85%) / DEOK (2.29%) / Dominion (15.20%) / DPL (1.75%) / DL (1.43%) / EKPC (0.60%) / JCPL (2.16%) / ME (1.72%) / PECO (4.32%) / PENELEC (4.98%) / PEPCO (5.80%) / PPL (4.74%) / PSEG (5.08%) / RE (0.15%) / NEPTUNE* (0.33%) / ECP** (0.05%) / HTP*** (0.02%)
b2973	Reconductor Michigan City - Bosserman 138 kV	MISO (10.00%) / AEC (0.93%) / AEP (26.02%) / APS (4.19%) / ATSI (5.95%) / BGE (4.38%) / Dayton (1.58%) / DEOK (2.30%) / Dominion (14.70%) / DPL (1.53%) / DL (1.26%) / EKPC (0.98%) / JCPL (1.92%) / ME (1.39%) / PECO (4.19%) / PENELEC (4.34%) / PEPCO (5.05%) / PPL (4.03%) / PSEG (4.48%) / RE (0.12%) / NEPTUNE* (0.56%) / ECP** (0.08%) / HTP*** (0.02%)
b2974	Replace terminal equipment at Reynolds on the Reynolds - Magnetation 138 kV	MISO (59.00%) / AEC (0.01%) / AEP (40.28%) / APS (0.13%) / ATSI (0.05%) / BGE (0.08%) / Dayton (0.03%) / DPL (0.01%) / ME (0.04%) / PENELEC (0.06%) / PPL (0.20%) / PSEG (0.03%) / NEPTUNE* (0.04%) / HTP*** (0.04%)

**Northern Indiana Public Service Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2975	Reconductor Roxana - Praxair 138 kV	MISO (76.00%) / AEC (0.28%) / AEP (4.51%) / APS (1.31%) / ATSI (1.91%) / BGE (1.40%) / Dayton (0.49%) / DEOK (0.69%) / Dominion (4.35%) / DPL (0.46%) / DL (0.38%) / EKPC (0.27%) / JCPL (0.57%) / ME (0.43%) / PECO (1.25%) / PENELEC (1.34%) / PEPCO (1.53%) / PPL (1.23%) / PSEG (1.41%) / RE (0.04%) / NEPTUNE* (0.14%) / HTP*** (0.01%)
<u>b3142</u>	<u>Rebuild the Michigan City – Trail Creek – Bosserman 138 kV line (10.7 miles)</u>	<u>MISO (10.90%) / ComEd (89.10%)</u>

**SCHEDULE 12 – APPENDIX A**

**(20) Virginia Electric and Power Company**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1698.7	Replace Loudoun 230 kV breaker '203052' with 63kA rating	Dominion (100%)
b1696.1	Replace the Idylwood 230 kV '25112' breaker with 50kA breaker	Dominion (100%)
b1696.2	Replace the Idylwood 230 kV '209712' breaker with 50kA breaker	Dominion (100%)
b1793.1	Remove the Carolina 22 SPS to include relay logic changes, minor control wiring, relay resets and SCADA programming upon completion of project	Dominion (100%)
b2281	Additional Temporary SPS at Bath County	Dominion (100%)
b2350	Reconductor 211 feet of 545.5 ACAR conductor on 59 Line Elmont - Greenwood DP 115 kV to achieve a summer emergency rating of 906 amps or greater	Dominion (100%)
b2358	Install a 230 kV 54 MVAR capacitor bank on the 2016 line at Harmony Village Substation	Dominion (100%)
b2359	Wreck and rebuild approximately 1.3 miles of existing 230 kV line between Cochran Mill - X4-039 Switching Station	Dominion (100%)
b2360	Build a new 39 mile 230 kV transmission line from Doods - Lexington on existing right-of-way	Dominion (100%)
b2361	Construct 230 kV OH line along existing Line #2035 corridor, approx. 2.4 miles from Idylwood - Dulles Toll Road (DTR) and 2.1 miles on new right-of-way along DTR to new Scott's Run Substation	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2368	Replace the Brambleton 230 kV breaker '209502' with 63kA breaker	Dominion (100%)
b2369	Replace the Brambleton 230 kV breaker '213702' with 63kA breaker	Dominion (100%)
b2370	Replace the Brambleton 230 kV breaker 'H302' with 63kA breaker	Dominion (100%)
b2373	Build a 2nd Loudoun - Brambleton 500 kV line within the existing ROW. The Loudoun - Brambleton 230 kV line will be relocated as an underbuild on the new 500 kV line	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  APS (25.51%) / Dominion (74.49%)</p>
b2397	Replace the Beaumeade 230 kV breaker '2079T2116' with 63kA	Dominion (100%)
b2398	Replace the Beaumeade 230 kV breaker '2079T2130' with 63kA	Dominion (100%)
b2399	Replace the Beaumeade 230 kV breaker '208192' with 63kA	Dominion (100%)
b2400	Replace the Beaumeade 230 kV breaker '209592' with 63kA	Dominion (100%)
b2401	Replace the Beaumeade 230 kV breaker '211692' with 63kA	Dominion (100%)
b2402	Replace the Beaumeade 230 kV breaker '227T2130' with 63kA	Dominion (100%)

The Annual Revenue Requirement for all Virginia Electric and Power Company projects in this Section 20 shall be as specified in Attachment 7 to Appendix A of Attachment H-16A and under the procedures detailed in Attachment H-16B.

\*Neptune Regional Transmission System, LLC

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2403	Replace the Beaumeade 230 kV breaker '274T2130' with 63kA	Dominion (100%)
b2404	Replace the Beaumeade 230 kV breaker '227T2095' with 63kA	Dominion (100%)
b2405	Replace the Pleasant view 230 kV breaker '203T274' with 63kA	Dominion (100%)
b2443	Construct new underground 230 kV line from Glebe to Station C, rebuild Glebe Substation, construct 230 kV high side bus at Station C with option to install 800 MVA PAR	Dominion (97.11%) / ME (0.18%) / PEPCO (2.71%)
b2443.1	Replace the Idylwood 230 kV breaker '203512' with 50kA	Dominion (100%)
b2443.2	Replace the Ox 230 kV breaker '206342' with 63kA breaker	Dominion (100%)
b2443.3	Glebe – Station C PAR	<b>DFAX Allocation:</b> Dominion (22.57%) / PEPCO (77.43%)
b2443.6	Install a second 500/230 kV transformer at Possum Point substation and replace bus work and associated equipment as needed	Dominion (100%)
b2443.7	Replace 19 63kA 230 kV breakers with 19 80kA 230 kV breakers	Dominion (100%)
b2457	Replace 24 115 kV wood h-frames with 230 kV Dominion pole H-frame structures on the Clubhouse – Purdy 115 kV line	Dominion (100%)
b2458.1	Replace 12 wood H-frame structures with steel H-frame structures and install shunts on all conductor splices on Carolina – Woodland 115 kV	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2458.2	Upgrade all line switches and substation components at Carolina 115 kV to meet or exceed new conductor rating of 174 MVA	Dominion (100%)
b2458.3	Replace 14 wood H-frame structures on Carolina – Woodland 115 kV	Dominion (100%)
b2458.4	Replace 2.5 miles of static wire on Carolina – Woodland 115 kV	Dominion (100%)
b2458.5	Replace 4.5 miles of conductor between Carolina 115 kV and Jackson DP 115 kV with min. 300 MVA summer STE rating; Replace 8 wood H-frame structures located between Carolina and Jackson DP with steel H-frames	Dominion (100%)
b2460.1	Replace Hanover 230 kV substation line switches with 3000A switches	Dominion (100%)
b2460.2	Replace wave traps at Four River 230 kV and Elmont 230 kV substations with 3000A wave traps	Dominion (100%)
b2461	Wreck and rebuild existing Remington CT – Warrenton 230 kV (approx. 12 miles) as a double-circuit 230 kV line	Dominion (100%)
b2461.1	Construct a new 230 kV line approximately 6 miles from NOVEC’s Wheeler Substation a new 230 kV switching station in Vint Hill area	Dominion (100%)
b2461.2	Convert NOVEC’s Gainesville – Wheeler line (approximately 6 miles) to 230 kV	Dominion (100%)
b2461.3	Complete a Vint Hill – Wheeler – Loudoun 230 kV networked line	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2471	Replace Midlothian 500 kV breaker 563T576 and motor operated switches with 3 breaker 500 kV ring bus. Terminate Lines # 563 Carson – Midlothian, #576 Midlothian –North Anna, Transformer #2 in new ring	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  Dominion (100%)</p>
b2504	Rebuild 115 kV Line #32 from Halifax-South Boston (6 miles) for min. of 240 MVA and transfer Welco tap to Line #32. Moving Welco to Line #32 requires disabling auto-sectionalizing scheme	Dominion (100%)
b2505	Install structures in river to remove the 115 kV #65 line (Whitestone-Harmony Village 115 kV) from bridge and improve reliability of the line	Dominion (100%)
b2542	Replace the Loudoun 500 kV ‘H2T502’ breaker with a 50kA breaker	Dominion (100%)
b2543	Replace the Loudoun 500 kV ‘H2T584’ breaker with a 50kA breaker	Dominion (100%)
b2565	Reconductor wave trap at Carver Substation with a 2000A wave trap	Dominion (100%)
b2566	Reconductor 1.14 miles of existing line between ACCA and Hermitage and upgrade associated terminal equipment	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2582	Rebuild the Elmont – Cunningham 500 kV line	<p><b>Load-Ratio Share Allocation:</b>                      AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>                      Dominion (100%)</p>
b2583	Install 500 kV breaker at Ox Substation to remove Ox Tx#1 from H1T561 breaker failure outage.	Dominion (100%)
b2584	Relocate the Bremono load (transformer #5) to #2028 (Bremono-Charlottesville 230 kV) line and Cartersville distribution station to #2027 (Bremono-Midlothian 230 kV) line	Dominion (100%)
b2585	Reconductor 7.63 miles of existing line between Cranes and Stafford, upgrade associated line switches at Stafford	PEPCO (100%)
b2620	Wreck and rebuild the Chesapeake – Deep Creek – Bowers Hill – Hodges Ferry 115 kV line; minimum rating 239 MVA normal/emergency, 275 MVA load dump rating	Dominion (100%)



**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2622	Rebuild Line #47 between Kings Dominion 115 kV and Fredericksburg 115 kV to current standards with summer emergency rating of 353 MVA at 115 kV	Dominion (100%)
b2623	Rebuild Line #4 between Bremono and Structure 8474 (4.5 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV	Dominion (100%)
b2624	Rebuild 115 kV Lines #18 and #145 between Possum Point Generating Station and NOVEC's Smoketown DP (approx. 8.35 miles) to current 230 kV standards with a normal continuous summer rating of 524 MVA at 115 kV	Dominion (100%)
b2625	Rebuild 115 kV Line #48 between Thole Street and Structure 48/71 to current standard. The remaining line to Sewells Point is 2007 vintage. Rebuild 115 kV Line #107 line, Sewells Point to Oakwood, between structure 107/17 and 107/56 to current standard.	Dominion (100%)
b2626	Rebuild 115 kV Line #34 between Skiffes Creek and Yorktown and the double circuit portion of 115 kV Line #61 to current standards with a summer emergency rating of 353 MVA at 115 kV	Dominion (100%)
b2627	Rebuild 115 kV Line #1 between Crewe 115 kV and Fort Pickett DP 115 kV (12.2 miles) to current standards with summer emergency rating of 261 MVA at 115 kV	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2628	Rebuild 115 kV Line #82 Everetts – Voice of America (20.8 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV	Dominion (100%)
b2629	Rebuild the 115 kV Lines #27 and #67 lines from Greenwich 115 kV to Burton 115 kV Structure 27/280 to current standard with a summer emergency rating of 262 MVA at 115 kV	Dominion (100%)
b2630	Install circuit switchers on Gravel Neck Power Station GSU units #4 and #5. Install two 230 kV CCVT's on Lines #2407 and #2408 for loss of source sensing	Dominion (100%)
b2636	Install three 230 kV bus breakers and 230 kV, 100 MVAR Variable Shunt Reactor at Dahlgren to provide line protection during maintenance, remove the operational hazard and provide voltage reduction during light load conditions	Dominion (100%)
b2647	Rebuild Boydton Plank Rd – Kerr Dam 115 kV Line #38 (8.3 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)
b2648	Rebuild Carolina – Kerr Dam 115 kV Line #90 (38.7 miles) to current standards with summer emergency rating of 353 MVA 115 kV.	Dominion (100%)
b2649	Rebuild Clubhouse – Carolina 115 kV Line #130 (17.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2649.1	Rebuild of 1.7 mile tap to Metcalf and Belfield DP (MEC) due to poor condition. The existing summer rating of the tap is 48 MVA and existing conductor is 4/0 ACSR on wood H-frames. The proposed new rating is 176 MVA using 636 ACSR conductor	Dominion (100%)
b2649.2	Rebuild of 4.1 mile tap to Brinks DP (MEC) due to wood poles built in 1962. The existing summer rating of the tap is 48 MVA and existing conductor is 4/0 ACSR and 393.6 ACSR on wood H-frames. The proposed new rating is 176 MVA using 636 ACSR conductor	Dominion (100%)
b2650	Rebuild Twittys Creek – Pamplin 115 kV Line #154 (17.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2651	Rebuild Buggs Island – Plywood 115 kV Line #127 (25.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV. The line should be rebuilt for 230 kV and operated at 115 kV.	Dominion (100%)
b2652	Rebuild Greatbridge – Hickory 115 kV Line #16 and Greatbridge – Chesapeake E.C. to current standard with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)
b2653.1	Build 20 mile 115 kV line from Pantego to Trowbridge with summer emergency rating of 353 MVA.	Dominion (100%)
b2653.2	Install 115 kV four-breaker ring bus at Pantego	Dominion (100%)
b2653.3	Install 115 kV breaker at Trowbridge	Dominion (100%)
b2654.1	Build 15 mile 115 kV line from Scotland Neck to S Justice Branch with summer emergency rating of 353 MVA. New line will be routed to allow HEMC to convert Dawson’s Crossroads RP from 34.5 kV to 115 kV.	Dominion (100%)
b2654.2	Install 115 kV three-breaker ring bus at S Justice Branch	Dominion (100%)
b2654.3	Install 115 kV breaker at Scotland Neck	Dominion (100%)
b2654.3	Install a 2nd 224 MVA 230/115 kV transformer at Hathaway	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2665	Rebuild the Cunningham – Dooms 500 kV line	<p><b>Load-Ratio Share Allocation:</b>                      AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>                      Dominion (100%)</p>
b2686	Pratts Area Improvement	Dominion (100%)
b2686.1	Build a 230 kV line from Remington Substation to Gordonsville Substation utilizing existing ROW	Dominion (100%)
b2686.2	Install a 3rd 230/115 kV transformer at Gordonsville Substation	Dominion (100%)
b2686.3	Upgrade Line 2088 between Gordonsville Substation and Louisa CT Station	Dominion (100%)
b2686.4	Replace the Remington CT 230 kV breaker “2114T2155” with a 63 kA breaker	Dominion (100%)
b2686.11	Upgrading sections of the Gordonsville – Somerset 115 kV circuit	Dominion (100%)
b2686.12	Upgrading sections of the Somerset – Doubleday 115 kV circuit	Dominion (100%)
b2686.13	Upgrading sections of the Orange – Somerset 115 kV circuit	Dominion (100%)
b2686.14	Upgrading sections of the Mitchell – Mt. Run 115 kV circuit	Dominion (100%)

\*Neptune Regional Transmission System, LLC

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2717.1	De-energize Davis – Rosslyn #179 and #180 69 kV lines	Dominion (100%)
b2717.2	Remove splicing and stop joints in manholes	Dominion (100%)
b2717.3	Evacuate and dispose of insulating fluid from various reservoirs and cables	Dominion (100%)
b2717.4	Remove all cable along the approx. 2.5 mile route, swab and cap-off conduits for future use, leave existing communication fiber in place	Dominion (100%)
b2719.1	Expand Perth substation and add a 115 kV four breaker ring	Dominion (100%)
b2719.2	Extend the Hickory Grove DP tap 0.28 miles to Perth and terminate it at Perth	Dominion (100%)
b2719.3	Split Line #31 at Perth and terminate it into the new ring bus with 2 breakers separating each of the line terminals to prevent a breaker failure from taking out both 115 kV lines	Dominion (100%)
b2720	Replace the Loudoun 500 kV ‘H1T569’ breakers with 50kA breaker	Dominion (100%)
b2729	Optimal Capacitors Configuration: New 175 MVAR capacitor at Brambleton, new 175 MVAR capacitor at Ashburn, new 300 MVAR capacitor at Shelhorn, new 150 MVAR capacitor at Liberty	AEC (1.96%) / BGE (14.37%) / Dominion (35.11%) / DPL (3.76%) / ECP (0.29%) / HTP (0.34%) / JCPL (3.31%) / ME (2.51%) / Neptune (0.63%) / PECO (6.26%) / PEPCO (20.23%) / PPL (3.94%) / PSEG (7.29%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2744	Rebuild the Carson – Rogers Rd 500 kV circuit	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  Dominion (100%)</p>
b2745	Rebuild 21.32 miles of existing line between Chesterfield – Lakeside 230 kV	Dominion (100%)
b2746.1	Rebuild Line #137 Ridge Rd – Kerr Dam 115 kV, 8.0 miles, for 346 MVA summer emergency rating	Dominion (100%)
b2746.2	Rebuild Line #1009 Ridge Rd – Chase City 115 kV, 9.5 miles, for 346 MVA summer emergency rating	Dominion (100%)
b2746.3	Install a second 4.8 MVAR capacitor bank on the 13.8 kV bus of each transformer at Ridge Rd	Dominion (100%)
b2747	Install a Motor Operated Switch and SCADA control between Dominion’s Gordonsville 115 kV bus and FirstEnergy’s 115 kV line	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2757	Install a +/-125 MVAR Statcom at Colington 230 kV	Dominion (100%)
b2758	Rebuild Line #549 Dooms – Valley 500kV	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  Dominion (100%)</p>
b2759	Rebuild Line #550 Mt. Storm – Valley 500kV	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  APS (87.50%) / ATSI (0.37%) / DL (0.19%) / Dominion (1.04%) / EKPC (10.90%)</p>



**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2800	The 7 mile section from Dozier to Thompsons Corner of line #120 will be rebuilt to current standards using 768.2 ACSS conductor with a summer emergency rating of 346 MVA at 115 kV. Line is proposed to be rebuilt on single circuit steel monopole structure	Dominion (100%)
b2801	Lines #76 and #79 will be rebuilt to current standard using 768.2 ACSS conductor with a summer emergency rating of 346 MVA at 115 kV. Proposed structure for rebuild is double circuit steel monopole structure	Dominion (100%)
b2802	Rebuild Line #171 from Chase City – Boydton Plank Road tap by removing end-of-life facilities and installing 9.4 miles of new conductor. The conductor used will be at current standards with a summer emergency rating of 393 MVA at 115kV	Dominion (100%)
b2815	Build a new Pinewood 115kV switching station at the tap serving North Doswell DP with a 115kV four breaker ring bus	Dominion (100%)
b2842	Update the nameplate for Mount Storm 500 kV "57272" to be 50kA breaker	Dominion (100%)
b2843	Replace the Mount Storm 500 kV "G2TY" with 50kA breaker	Dominion (100%)
b2844	Replace the Mount Storm 500 kV "G2TZ" with 50kA breaker	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2845	Update the nameplate for Mount Storm 500 kV "G3TSX1" to be 50kA breaker	Dominion (100%)
b2846	Update the nameplate for Mount Storm 500 kV "SX172" to be 50kA breaker	Dominion (100%)
b2847	Update the nameplate for Mount Storm 500 kV "Y72" to be 50kA breaker	Dominion (100%)
b2848	Replace the Mount Storm 500 kV "Z72" with 50kA breaker	Dominion (100%)
b2871	Rebuild 230 kV line #247 from Swamp to Suffolk (31 miles) to current standards with a summer emergency rating of 1047 MVA at 230 kV	Dominion (100%)
b2876	Rebuild line #101 from Mackeys – Creswell 115 kV, 14 miles, with double circuit structures. Install one circuit with provisions for a second circuit. The conductor used will be at current standards with a summer emergency rating of 262 MVA at 115 kV	Dominion (100%)
b2877	Rebuild line #112 from Fudge Hollow – Lowmoor 138 kV (5.16 miles) to current standards with a summer emergency rating of 314 MVA at 138 kV	Dominion (100%)
b2899	Rebuild 230 kV line #231 to current standard with a summer emergency rating of 1046 MVA. Proposed conductor is 2-636 ACSR	Dominion (100%)
b2900	Build a new 230/115 kV switching station connecting to 230 kV network line #2014 (Earleys – Everetts). Provide a 115 kV source from the new station to serve Windsor DP	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2922	Rebuild 8 of 11 miles of 230 kV lines #211 and #228 to current standard with a summer emergency rating of 1046 MVA for rebuilt section. Proposed conductor is 2-636 ACSR	Dominion (100%)
b2928	Rebuild four structures of 500 kV line #567 from Chickahominy to Surry using galvanized steel and replace the river crossing conductor with 3-1534 ACSR. This will increase the line #567 line rating from 1954 MVA to 2600 MVA	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  Dominion (100%)</p>
b2929	Rebuild 230 kV line #2144 from Winfall to Swamp (4.3 miles) to current standards with a standard conductor (bundled 636 ACSR) having a summer emergency rating of 1047 MVA at 230 kV	Dominion (100%)
b2960	Replace fixed series capacitors on 500 kV Line #547 at Lexington and on 500 kV Line #548 at Valley	See sub-IDs for cost allocations

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2960.1	Replace fixed series capacitors on 500 kV Line #547 at Lexington	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  DEOK (5.63%) / Dominion (91.06%) / EKPC (3.31%)</p>

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2960.2	Replace fixed series capacitors on 500 kV Line #548 at Valley	<p><b>Load-Ratio Share Allocation:</b>                      AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>                      DEOK (17.57%) / Dominion (74.24%) / EKPC (8.19%)</p>
b2961	Rebuild approximately 3 miles of Line #205 & Line #2003 from Chesterfield to Locks & Poe respectively	Dominion (100%)
b2962	Split Line #227 (Brambleton – Beaumeade 230 kV) and terminate into existing Belmont substation	Dominion (100%)
b2962.1	Replace the Beaumeade 230 kV breaker “274T2081” with 63kA breaker	Dominion (100%)
b2962.2	Replace the NIVO 230 kV breaker “2116T2130” with 63kA breaker	Dominion (100%)
b2963	Reconductor the Woodbridge to Occoquan 230 kV line segment of Line #2001 with 1047 MVA conductor and replace line terminal equipment at Possum Point, Woodbridge, and Occoquan	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2978	Install 2-125 MVAR STATCOMs at Rawlings and 1-125 MVAR STATCOM at Clover 500 kV substations	<p><b>Load-Ratio Share Allocation:</b>                      AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>                      Dominion (100%)</p>
b2980	Rebuild 115 kV Line #43 between Staunton and Harrisonburg (22.8 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV	Dominion (100%)
b2981	Rebuild 115 kV Line #29 segment between Fredericksburg and Aquia Harbor to current 230 kV standards (operating at 115 kV) utilizing steel H-frame structures with 2-636 ACSR to provide a normal continuous summer rating of 524 MVA at 115 kV (1047 MVA at 230 kV)	Dominion (100%)

\*Neptune Regional Transmission System, LLC

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2989	Install a second 230/115 kV Transformer (224 MVA) approximately 1 mile north of Bremono and tie 230 kV Line #2028 (Bremono – Charlottesville) and 115 kV Line #91 (Bremono - Sherwood) together. A three breaker 230 kV ring bus will split Line #2028 into two lines and Line #91 will also be split into two lines with a new three breaker 115 kV ring bus. Install a temporary 230/115 kV transformer at Bremono substation for the interim until the new substation is complete	Dominion (100%)
b2990	Chesterfield to Basin 230 kV line – Replace 0.14 miles of 1109 ACAR with a conductor which will increase the line rating to approximately 706 MVA	Dominion (100%)
b2991	Chaparral to Locks 230 kV line – Replace breaker lead	Dominion (100%)
b2994	Acquire land and build a new switching station (Skippers) at the tap serving Brink DP with a 115 kV four breaker ring to split Line #130 and terminate the end points	Dominion (100%)
b3018	Rebuild Line #49 between New Road and Middleburg substations with single circuit steel structures to current 115 kV standards with a minimum summer emergency rating of 261 MVA	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3019	Rebuild 500 kV Line #552 Bristers to Chancellor – 21.6 miles long	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%)  / APS (5.61%) / ATSI (8.10%)  / BGE (4.36%) / ComEd  (13.14%) / Dayton (2.15%) /  DEOK (3.23%) / DL (1.73%) /  DPL (2.65%) / Dominion  (13.03%) / EKPC (1.77%) /  JCPL (3.84%) / ME (1.93%) /  NEPTUNE* (0.45%) / OVEC  (0.07%) / PECO (5.29%) /  PENELEC (1.89%) / PEPCO  (3.82%) / PPL (4.72%) / PSEG  (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  Dominion (89.20%) / PEPCO  (10.80%)</p>
b3019.1	Update the nameplate for Morrisville 500 kV breaker “H1T594” to be 50kA	Dominion (100%)
b3019.2	Update the nameplate for Morrisville 500 kV breaker “H1T545” to be 50kA	Dominion (100%)



**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3020	Rebuild 500 kV Line #574 Ladysmith to Elmont – 26.2 miles long	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  APS (16.36%) / DEOK (11.61%) / Dominion (51.27%) / EKPC (5.30%) / PEPCO (15.46%)</p>
b3021	Rebuild 500 kV Line #581 Ladysmith to Chancellor – 15.2 miles long	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  Dominion (100%)</p>
b3026	Reconductor Line #274 (Pleasant View – Ashburn – Beaumeade 230 kV) with a minimum rating of 1200 MVA. Also upgrade terminal equipment	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3027.1	Add a 2nd 500/230 kV 840 MVA transformer at Dominion's Ladysmith substation	Dominion (100%)
b3027.2	Reconductor 230 kV Line #2089 between Ladysmith and Ladysmith CT substations to increase the line rating from 1047 MVA to 1225 MVA	Dominion (100%)
b3027.3	Replace the Ladysmith 500 kV breaker "H1T581" with 50kA breaker	Dominion (100%)
b3027.4	Update the nameplate for Ladysmith 500 kV breaker "H1T575" to be 50kA breaker	Dominion (100%)
b3027.5	Update the nameplate for Ladysmith 500 kV breaker "568T574" (will be renumbered as "H2T568") to be 50kA breaker	Dominion (100%)
b3055	Install spare 230/69 kV transformer at Davis substation	Dominion (100%)
b3056	Partial rebuild 230 kV Line #2113 Waller to Lightfoot	Dominion (100%)
b3057	Rebuild 230 kV Lines #2154 and #19 Waller to Skiffes Creek	Dominion (100%)
b3058	Partial rebuild of 230 kV Lines #265, #200 and #2051	Dominion (100%)
b3059	Rebuild 230 kV Line #2173 Loudoun to Elklick	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3060	Rebuild 4.6 mile Elklick – Bull Run 230 kV Line #295 and the portion (3.85 miles) of the Clifton – Walney 230 kV Line #265 which shares structures with Line #295	Dominion (100%)
b3088	Rebuild 4.75 mile section of Line #26 between Lexington and Rockbridge with a minimum summer emergency rating of 261 MVA	Dominion (100%)
b3089	Rebuild 230 kV Line #224 between Lanexa and Northern Neck utilizing double circuit structures to current 230 kV standards. Only one circuit is to be installed on the structures with this project with a minimum summer emergency rating of 1047 MVA	Dominion (100%)
b3090	Convert the overhead portion (approx. 1500 feet) of 230 kV Lines #248 & #2023 to underground and convert Glebe substation to gas insulated substation	Dominion (100%)
b3096	Rebuild 230 kV line No.2063 (Clifton – Ox) and part of 230 kV line No.2164 (Clifton – Keene Mill) with double circuit steel structures using double circuit conductor at current 230 kV northern Virginia standards with a minimum rating of 1200 MVA	Dominion (100%)
b3097	Rebuild 4 miles of 115 kV Line #86 between Chesterfield and Centralia to current standards with a minimum summer emergency rating of 393 MVA	Dominion (100%)
b3098	Rebuild 9.8 miles of 115 kV Line #141 between Balcony Falls and Skimmer and 3.8 miles of 115 kV Line #28 between Balcony Falls and Cushaw to current standards with a minimum rating of 261 MVA	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3098.1	Rebuild Balcony Falls 115 kV substation	Dominion (100%)
b3110.1	Rebuild Line #2008 between Loudoun to Dulles Junction using single circuit conductor at current 230 kV northern Virginia standards with minimum summer ratings of 1200 MVA. Cut and loop Line #265 (Clifton – Sully) into Bull Run substation. Add three (3) 230 kV breakers at Bull Run to accommodate the new line and upgrade the substation	Dominion (100%)
b3110.2	Replace the Bull Run 230 kV breakers “200T244” and “200T295” with 50 kA breakers	Dominion (100%)
<u>b3110.3</u>	<u>Replace the Clifton 230 kV breakers “201182” and “XT2011” with 63 kA breakers</u>	<u>Dominion (100%)</u>
b3113	Rebuild approximately 1 mile of 115 kV Lines #72 and #53 to current standards with a minimum summer emergency rating of 393 MVA. The resulting summer emergency rating of Line #72 segment from Brown Boveri to Bellwood is 180 MVA. There is no change to Line #53 ratings	Dominion (100%)
b3114	Rebuild the 18.6 mile section of 115 kV Line #81 which includes 1.7 miles of double circuit Line #81 and 230 kV Line #2056. This segment of Line #81 will be rebuilt to current standards with a minimum rating of 261 MVA. Line #2056 rating will not change	Dominion (100%)
b3121	Rebuild Clubhouse – Lakeview 230 kV Line #254 with single-circuit wood pole equivalent structures at the current 230 kV standard with a minimum rating of 1047 MVA	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3122	Rebuild Hathaway – Rocky Mount (Duke Energy Progress) 230 kV Line #2181 and Line #2058 with double circuit steel structures using double circuit conductor at current 230 kV standards with a minimum rating of 1047 MVA	Dominion (100%)
b3161.1	Split Chesterfield-Plaza 115 kV Line No. 72 by rebuilding the Brown Boveri tap line as double circuit loop in-and-out of the Brown Boveri Breaker station	Dominion (100%)
b3161.2	Install a 115 kV breaker at the Brown Boveri Breaker station. Site expansion is required to accommodate the new layout	Dominion (100%)
b3162	Acquire land and build a new 230 kV switching station (Stevensburg) with a 224 MVA, 230/115 kV transformer. Gordonsville-Remington 230 kV Line No. 2199 will be cut and connected to the new station. Remington-Mt. Run 115 kV Line No.70 and Mt. Run-Oak Green 115 kV Line No. 2 will also be cut and connected to the new station	Dominion (100%)
b3211	Rebuild the 1.3 mile section of 500 kV Line No. 569 (Loudoun – Morrisville) with single-circuit 500 kV structures at the current 500 kV standard. This will increase the rating of the line to 3424 MVA	Dominion (100%)
b3213	Install 2nd Chickahominy 500/230 kV transformer	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3223.1	<p><u>Install a second 230 kV circuit with a minimum summer emergency rating of 1047 MVA between Lanexa and Northern Next substations. The second circuit will utilize the vacant arms on the double-circuit structures that are being installed on Line #224 (Lanexa – Northern Next) as part of the End-of-Life rebuild project (b3089)</u></p>	<p><u>Dominion (100%)</u></p>
b3223.2	<p><u>Expand the Northern Neck terminal from a 230 kV, 4-breaker ring bus to a 6-breaker ring bus</u></p>	<p><u>Dominion (100%)</u></p>
b3223.3	<p><u>Expand the Lanexa terminal from a 6-breaker ring bus to a breaker-and-a-half arrangement</u></p>	<p><u>Dominion (100%)</u></p>
b3247	<p><u>Replace 13 towers with galvanized steel towers on Doubs – Goose Creek 500 kV. Reconductor 3 mile section with three (3) 1351.5 ACSR 45/7. Upgrade line terminal equipment at Goose Creek substation to support the 500 kV line rebuild</u></p>	<p><b><u>Load-Ratio Share Allocation:</u></b>  <u>AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</u></p> <p><b><u>DFAX Allocation:</u></b>  <u>Dominion (100%)</u></p>

# **Attachment C**

Schedule 12 – Appendix A of the  
PJM Open Access Transmission Tariff

(Clean Format)

**SCHEDULE 12 – APPENDIX A**

**(9) PPL Electric Utilities Corporation**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1813.12	Replace the Blooming Grove 230 kV breaker 'Peckville'	PPL (100%)
b2223	Rebuild and reconductor 2.6 miles of the Sunbury - Dauphin 69 kV circuit	PPL (100%)
b2224	Add a 2nd 150 MVA 230/69 kV transformer at Springfield	PPL (100%)
b2237	150 MVAR shunt reactor at Alburdis 500 kV	<b>Load-Ratio Share Allocation:</b> AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		<b>DFAX Allocation:</b> PPL (100%)
b2238	100 MVAR shunt reactor at Elimspport 230 kV	PPL (100%)

\* Neptune Regional Transmission System, LLC



**PPL Electric Utilities Corporation (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2269	Rebuild approximately 23.7 miles of the Susquehanna - Jenkins 230kV circuit. This replaces a temporary SPS that is already planned to mitigate the violation until this solution is implemented	PPL (100%)
b2282	Rebuild the Siegfried-Frackville 230 kV line	PPL (100%)
b2406.1	Rebuild Stanton-Providence 69 kV 2&3 9.5 miles with 795 SCSR	PPL (100%)
b2406.2	Reconductor 7 miles of the Lackawanna - Providence 69 kV #1 and #2 with 795 ACSR	PPL (100%)
b2406.3	Rebuild SUB2 Tap 1 (Lackawanna - Scranton 1) 69 kV 1.5 miles 556 ACSR	PPL (100%)
b2406.4	Rebuild SUB2 Tap 2 (Lackawanna - Scranton 1) 69 kV 1.6 miles 556 ACSR	PPL (100%)
b2406.5	Create Providence - Scranton 69 kV #1 and #2, 3.5 miles with 795 ACSR	PPL (100%)
b2406.6	Rebuild Providence 69 kV switchyard	PPL (100%)
b2406.7	Install 2 - 10.8 MVAR capacitors at EYNO 69 kV	PPL (100%)
b2406.8	Rebuild Stanton 230 kV yard	PPL (100%)

**PPL Electric Utilities Corporation (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2446	Replace wave trap and protective relays at Montour	PPL (100%)
b2447	Replace wave trap and protective relays at Montour	PPL (100%)
b2448	Install a 2nd Sunbury 900MVA 500-230kV transformer and associated equipment	PPL (100%)
b2552.2	Reconductor the North Meshoppen - Oxbow – Lackawanna 230 kV circuit and upgrade terminal equipment (PPL portion)	PENELEC (98.84%) / PPL (1.16%)
b2574	Replace the Sunbury 230 kV ‘MONTOUR NORT’ breaker with a 63kA breaker	PPL (100%)
b2690	Reconductor two spans of the Graceton – Safe Harbor 230 kV transmission line. Includes termination point upgrades	PPL (100%)
b2691	Reconductor three spans limiting Brunner Island – Yorkana 230 kV line, add 2 breakers to Brunner Island switchyard, upgrade associated terminal equipment	PPL (100%)

**PPL Electric Utilities Corporation (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2716	Add a 200 MVAR shunt reactor at Lackawanna 500 kV substation	<p><b>Load-Ratio Share Allocation:</b>                      AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>                      PPL (100%)</p>
b2754.1	Install 7 miles of optical ground wire (OPGW) between Gilbert and Springfield 230 kV substations	PPL (100%)
b2754.4	Use ~ 40 route miles of existing fibers on PPL 230 kV system to establish direct fiber circuits	PPL (100%)
b2754.5	Upgrade relaying at Martins Creek 230 kV	PPL (100%)
b2756	Install 2% reactors at Martins Creek 230 kV	PPL (100%)
b2813	Expand existing Lycoming 69 kV yard to double bus double breaker arrangement	PPL (100%)

\* Neptune Regional Transmission System, LLC

**PPL Electric Utilities Corporation (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2824	Reconfigure/Expand the Lackawanna 500 kV substation by adding a third bay with three breakers	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  PPL (100%)</p>
b2838	Build a new 230/69 kV substation by tapping the Montour – Susquehanna 230 kV double circuits and Berwick – Hunlock & Berwick – Colombia 69 kV circuits	PPL (100%)
b2979	Replace Martins Creek 230 kV circuit breakers with 80 kA rating	PPL (100%)
b3221	Replace terminal equipment (bus conductor) on the 230 kV side of the Steel City 500/230 kV Transformer #1	PPL (100%)

\* Neptune Regional Transmission System, LLC

**SCHEDULE 12 – APPENDIX A**

- (17) **AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1570.4	Add a 345 kV breaker at Marysville station and a 0.1 mile 345 kV line extension from Marysville to the new 345/69 kV Dayton transformer	AEP (100%)
b1660.1	Cloverdale: install 6-765 kV breakers, incremental work for 2 additional breakers, reconfigure and relocate miscellaneous facilities, establish 500 kV station and 500 kV tie with 765 kV station	<b>Load-Ratio Share Allocation:</b> AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPSCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		<b>DFAX Allocation:</b> Dayton (8.37%) / DEOK (21.94%) / Dominion (56.40%) / EKPC (13.29%)

\*Neptune Regional Transmission System, LLC

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1797.1	Reconductor the AEP portion of the Cloverdale - Lexington 500 kV line with 2-1780 ACSS	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  AEP (0.79%) / APS (53.70%) / Dayton (0.15%) / DEOK (0.40%) / Dominion (1.13%) / EKPC (0.23%) / PEPCO (43.60%)</p>
b2055	Upgrade relay at Brues station	AEP (100%)
b2122.3	Upgrade terminal equipment at Howard on the Howard - Brookside 138 kV line to achieve ratings of 252/291 (SN/SE)	AEP (100%)
b2122.4	Perform a sag study on the Howard - Brookside 138 kV line	AEP (100%)
b2229	Install a 300 MVAR reactor at Dequine 345 kV	AEP (100%)

\*Neptune Regional Transmission System, LLC

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2230	Replace existing 150 MVAR reactor at Amos 765 kV substation on Amos - N. Proctorville - Hanging Rock with 300 MVAR reactor	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  AEP (100%)</p>
b2231	Install 765 kV reactor breaker at Dumont 765 kV substation on the Dumont - Wilton Center line	AEP (100%)
b2232	Install 765 kV reactor breaker at Marysville 765 kV substation on the Marysville - Maliszewski line	AEP (100%)
b2233	Change transformer tap settings for the Baker 765/345 kV transformer	AEP (100%)
b2252	Loop the North Muskingum - Crooksville 138 kV line into AEP's Philo 138 kV station which lies approximately 0.4 miles from the line	AEP (100%)

\*Neptune Regional Transmission System, LLC

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2253	Install an 86.4 MVAR capacitor bank at Gorsuch 138 kV station in Ohio		AEP (100%)
b2254	Rebuild approximately 4.9 miles of Corner - Degussa 138 kV line in Ohio		AEP (100%)
b2255	Rebuild approximately 2.8 miles of Maliszewski - Polaris 138 kV line in Ohio		AEP (100%)
b2256	Upgrade approximately 36 miles of 138 kV through path facilities between Harrison 138 kV station and Ross 138 kV station in Ohio		AEP (100%)
b2257	Rebuild the Pokagon - Corey 69 kV line as a double circuit 138 kV line with one side at 69 kV and the other side as an express circuit between Pokagon and Corey stations		AEP (100%)
b2258	Rebuild 1.41 miles of #2 CU 46 kV line between Tams Mountain - Slab Fork to 138 kV standards. The line will be strung with 1033 ACSR		AEP (100%)
b2259	Install a new 138/69 kV transformer at George Washington 138/69 kV substation to provide support to the 69 kV system in the area		AEP (100%)
b2286	Rebuild 4.7 miles of Muskingum River - Wolf Creek 138 kV line and remove the 138/138 kV transformer at Wolf Creek Station		AEP (100%)



**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2287	Loop in the Meadow Lake - Olive 345 kV circuit into Reynolds 765/345 kV station		AEP (100%)
b2344.1	Establish a new 138/12 kV station, transfer and consolidate load from its Nicholasville and Marcellus 34.5 kV stations at this new station		AEP (100%)
b2344.2	Tap the Hydramatic – Valley 138 kV circuit (~ structure 415), build a new 138 kV line (~3.75 miles) to this new station		AEP (100%)
b2344.3	From this station, construct a new 138 kV line (~1.95 miles) to REA’s Marcellus station		AEP (100%)
b2344.4	From REA’s Marcellus station construct new 138 kV line (~2.35 miles) to a tap point on Valley – Hydramatic 138 kV ckt (~structure 434)		AEP (100%)
b2344.5	Retire sections of the 138 kV line in between structure 415 and 434 (~ 2.65 miles)		AEP (100%)
b2344.6	Retire AEP’s Marcellus 34.5/12 kV and Nicholasville 34.5/12 kV stations and also the Marcellus – Valley 34.5 kV line		AEP (100%)
b2345.1	Construct a new 69 kV line from Hartford to Keeler (~8 miles)		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2345.2	Rebuild the 34.5 kV lines between Keeler - Sister Lakes and Glenwood tap switch to 69 kV (~12 miles)		AEP (100%)
b2345.3	Implement in - out at Keeler and Sister Lakes 34.5 kV stations		AEP (100%)
b2345.4	Retire Glenwood tap switch and construct a new Rothadew station. These new lines will continue to operate at 34.5 kV		AEP (100%)
b2346	Perform a sag study for Howard - North Bellville - Millwood 138 kV line including terminal equipment upgrades		AEP (100%)
b2347	Replace the North Delphos 600A switch. Rebuild approximately 18.7 miles of 138 kV line North Delphos - S073. Reconductor the line and replace the existing tower structures		AEP (100%)
b2348	Construct a new 138 kV line from Richlands Station to intersect with the Hales Branch - Grassy Creek 138 kV circuit		AEP (100%)
b2374	Change the existing CT ratios of the existing equipment along Bearskin - Smith Mountain 138kV circuit		AEP (100%)
b2375	Change the existing CT ratios of the existing equipment along East Danville-Banister 138kV circuit		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2376	Replace the Turner 138 kV breaker 'D'	AEP (100%)
b2377	Replace the North Newark 138 kV breaker 'P'	AEP (100%)
b2378	Replace the Sporn 345 kV breaker 'DD'	AEP (100%)
b2379	Replace the Sporn 345 kV breaker 'DD2'	AEP (100%)
b2380	Replace the Muskingum 345 kV breaker 'SE'	AEP (100%)
b2381	Replace the East Lima 138 kV breaker 'E1'	AEP (100%)
b2382	Replace the Delco 138 kV breaker 'R'	AEP (100%)
b2383	Replace the Sporn 345 kV breaker 'AA2'	AEP (100%)
b2384	Replace the Sporn 345 kV breaker 'CC'	AEP (100%)
b2385	Replace the Sporn 345 kV breaker 'CC2'	AEP (100%)
b2386	Replace the Astor 138 kV breaker '102'	AEP (100%)
b2387	Replace the Muskingum 345 kV breaker 'SH'	AEP (100%)
b2388	Replace the Muskingum 345 kV breaker 'SI'	AEP (100%)
b2389	Replace the Hyatt 138 kV breaker '105N'	AEP (100%)
b2390	Replace the Muskingum 345 kV breaker 'SG'	AEP (100%)
b2391	Replace the Hyatt 138 kV breaker '101C'	AEP (100%)
b2392	Replace the Hyatt 138 kV breaker '104N'	AEP (100%)
b2393	Replace the Hyatt 138 kV breaker '104S'	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2394	Replace the Sporn 345 kV breaker 'CC1'	AEP (100%)
b2409	Install two 56.4 MVAR capacitor banks at the Melmore 138 kV station in Ohio	AEP (100%)
b2410	Convert Hogan Mullin 34.5 kV line to 138 kV, establish 138 kV line between Jones Creek and Strawton, rebuild existing Mullin Elwood 34.5 kV and terminate line into Strawton station, retire Mullin station	AEP (100%)
b2411	Rebuild the 3/0 ACSR portion of the Hadley - Kroemer Tap 69 kV line utilizing 795 ACSR conductor	AEP (100%)
b2423	Install a 300 MVAR shunt reactor at AEP's Wyoming 765 kV station	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  AEP (100%)</p>

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2444	Willow - Eureka 138 kV line: Reconductor 0.26 mile of 4/0 CU with 336 ACSS		AEP (100%)
b2445	Complete a sag study of Tidd - Mahans Lake 138 kV line		AEP (100%)
b2449	Rebuild the 7-mile 345 kV line between Meadow Lake and Reynolds 345 kV stations		AEP (100%)
b2462	Add two 138 kV circuit breakers at Fremont station to fix tower contingency '408_2'		AEP (100%)
b2501	Construct a new 138/69 kV Yager station by tapping 2-138 kV FE circuits (Nottingham-Cloverdale, Nottingham-Harmon)		AEP (100%)
b2501.2	Build a new 138 kV line from new Yager station to Azalea station		AEP (100%)
b2501.3	Close the 138 kV loop back into Yager 138 kV by converting part of local 69 kV facilities to 138 kV		AEP (100%)
b2501.4	Build 2 new 69 kV exits to reinforce 69 kV facilities and upgrade conductor between Irish Run 69 kV Switch and Bowerstown 69 kV Switch		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2502.1	Construct new 138 kV switching station Nottingham tapping 6-138 kV FE circuits (Holloway-Brookside, Holloway-Harmon #1 and #2, Holloway-Reeds, Holloway-New Stacy, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd station		AEP (100%)
b2502.2	Convert Freebyrd 69 kV to 138 kV		AEP (100%)
b2502.3	Rebuild/convert Freebyrd-South Cadiz 69 kV circuit to 138 kV		AEP (100%)
b2502.4	Upgrade South Cadiz to 138 kV breaker and a half		AEP (100%)
b2530	Replace the Sporn 138 kV breaker 'G1' with 80kA breaker		AEP (100%)
b2531	Replace the Sporn 138 kV breaker 'D' with 80kA breaker		AEP (100%)
b2532	Replace the Sporn 138 kV breaker 'O1' with 80kA breaker		AEP (100%)
b2533	Replace the Sporn 138 kV breaker 'P2' with 80kA breaker		AEP (100%)
b2534	Replace the Sporn 138 kV breaker 'U' with 80kA breaker		AEP (100%)
b2535	Replace the Sporn 138 kV breaker 'O' with 80 kA breaker		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2536	Replace the Sporn 138 kV breaker 'O2' with 80 kA breaker	AEP (100%)
b2537	Replace the Robinson Park 138 kV breakers A1, A2, B1, B2, C1, C2, D1, D2, E1, E2, and F1 with 63 kA breakers	AEP (100%)
b2555	Reconductor 0.5 miles Tiltonsville – Windsor 138 kV and string the vacant side of the 4.5 mile section using 556 ACSR in a six wire configuration	AEP (100%)
b2556	Install two 138 kV prop structures to increase the maximum operating temperature of the Clinch River- Clinch Field 138 kV line	AEP (100%)
b2581	Temporary operating procedure for delay of upgrade b1464. Open the Corner 138 kV circuit breaker 86 for an overload of the Corner – Washington MP 138 kV line. The tower contingency loss of Belmont – Trissler 138 kV and Belmont – Edgelawn 138 kV should be added to Operational contingency	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2591	Construct a new 69 kV line approximately 2.5 miles from Colfax to Drewry's. Construct a new Drewry's station and install a new circuit breaker at Colfax station.		AEP (100%)
b2592	Rebuild existing East Coshocton – North Coshocton double circuit line which contains Newcomerstown – N. Coshocton 34.5 kV Circuit and Coshocton – North Coshocton 69 kV circuit		AEP (100%)
b2593	Rebuild existing West Bellaire – Glencoe 69 kV line with 138 kV & 69 kV circuits and install 138/69 kV transformer at Glencoe Switch		AEP (100%)
b2594	Rebuild 1.0 mile of Brantley – Bridge Street 69 kV Line with 1033 ACSR overhead conductor		AEP (100%)
b2595.1	Rebuild 7.82 mile Elkhorn City – Haysi S.S 69 kV line utilizing 1033 ACSR built to 138 kV standards		AEP (100%)
b2595.2	Rebuild 5.18 mile Moss – Haysi SS 69 kV line utilizing 1033 ACSR built to 138 kV standards		AEP (100%)
b2596	Move load from the 34.5 kV bus to the 138 kV bus by installing a new 138/12 kV XF at New Carlisle station in Indiana		AEP (100%)



**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2597	Rebuild approximately 1 mi. section of Dragoon-Virgil Street 34.5 kV line between Dragoon and Dodge Tap switch and replace Dodge switch MOAB to increase thermal capability of Dragoon-Dodge Tap branch		AEP (100%)
b2598	Rebuild approximately 1 mile section of the Kline-Virgil Street 34.5 kV line between Kline and Virgil Street tap. Replace MOAB switches at Beiger, risers at Kline, switches and bus at Virgil Street.		AEP (100%)
b2599	Rebuild approximately 0.1 miles of 69 kV line between Albion and Albion tap		AEP (100%)
b2600	Rebuild Fremont – Pound line as 138 kV		AEP (100%)
b2601	Fremont Station Improvements		AEP (100%)
b2601.1	Replace MOAB towards Beaver Creek with 138 kV breaker		AEP (100%)
b2601.2	Replace MOAB towards Clinch River with 138 kV breaker		AEP (100%)
b2601.3	Replace 138 kV Breaker A with new bus-tie breaker		AEP (100%)
b2601.4	Re-use Breaker A as high side protection on transformer #1		AEP (100%)
b2601.5	Install two (2) circuit switchers on high side of transformers # 2 and 3 at Fremont Station		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2602.1	Install 138 kV breaker E2 at North Proctorville		AEP (100%)
b2602.2	Construct 2.5 Miles of 138 kV 1033 ACSR from East Huntington to Darrah 138 kV substations		AEP (100%)
b2602.3	Install breaker on new line exit at Darrah towards East Huntington		AEP (100%)
b2602.4	Install 138 kV breaker on new line at East Huntington towards Darrah		AEP (100%)
b2602.5	Install 138 kV breaker at East Huntington towards North Proctorville		AEP (100%)
b2603	Boone Area Improvements		AEP (100%)
b2603.1	Purchase approximately a 200X300 station site near Slaughter Creek 46 kV station (Wilbur Station)		AEP (100%)
b2603.2	Install 3 138 kV circuit breakers, Cabin Creek to Hernshaw 138 kV circuit		AEP (100%)
b2603.3	Construct 1 mi. of double circuit 138 kV line on Wilbur – Boone 46 kV line with 1590 ACSS 54/19 conductor @ 482 Degree design temp. and 1-159 12/7 ACSR and one 86 Sq.MM. 0.646” OPGW Static wires		AEP (100%)
b2604	Bellefonte Transformer Addition		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2605	Rebuild and reconductor Kammer – George Washington 69 kV circuit and George Washington – Moundville ckt #1, designed for 138kV. Upgrade limiting equipment at remote ends and at tap stations		AEP (100%)
b2606	Convert Bane – Hammondsville from 23 kV to 69 kV operation		AEP (100%)
b2607	Pine Gap Relay Limit Increase		AEP (100%)
b2608	Richlands Relay Upgrade		AEP (100%)
b2609	Thorofare – Goff Run – Powell Mountain 138 kV Build		AEP (100%)
b2610	Rebuild Pax Branch – Scaraboro as 138 kV		AEP (100%)
b2611	Skin Fork Area Improvements		AEP (100%)
b2611.1	New 138/46 kV station near Skin Fork and other components		AEP (100%)
b2611.2	Construct 3.2 miles of 1033 ACSR double circuit from new Station to cut into Sundial-Baileysville 138 kV line		AEP (100%)
b2634.1	Replace metering BCT on Tanners Creek CB T2 with a slip over CT with higher thermal rating in order to remove 1193 MVA limit on facility (Miami Fort-Tanners Creek 345 kV line)		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2643	Replace the Darrah 138 kV breaker 'L' with 40kA rated breaker	AEP (100%)
b2645	Ohio Central 138 kV Loop	AEP (100%)
b2667	Replace the Muskingum 138 kV bus # 1 and 2	AEP (100%)
b2668	Reconductor Dequine to Meadow Lake 345 kV circuit #1 utilizing dual 954 ACSR 54/7 cardinal conductor	AEP (100%)
b2669	Install a second 345/138 kV transformer at Desoto	AEP (100%)
b2670	Replace switch at Elk Garden 138 kV substation (on the Elk Garden – Lebanon 138 kV circuit)	AEP (100%)
b2671	Replace/upgrade/add terminal equipment at Bradley, Mullensville, Pinnacle Creek, Itmann, and Tams Mountain 138 kV substations. Sag study on Mullens – Wyoming and Mullens – Tams Mt. 138 kV circuits	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2687.1	Install a +/- 450 MVAR SVC at Jacksons Ferry 765 kV substation	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  AEP (100%)</p>

\*Neptune Regional Transmission System, LLC

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2687.2	Install a 300 MVAR shunt line reactor on the Broadford end of the Broadford – Jacksons Ferry 765 kV line	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  AEP (100%)</p>
b2697.1	Mitigate violations identified by sag study to operate Fieldale-Thornton-Franklin 138 kV overhead line conductor at its max. operating temperature. 6 potential line crossings to be addressed.	AEP (100%)
b2697.2	Replace terminal equipment at AEP’s Danville and East Danville substations to improve thermal capacity of Danville – East Danville 138 kV circuit	AEP (100%)

\*Neptune Regional Transmission System, LLC

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2698	Replace relays at AEP's Cloverdale and Jackson's Ferry substations to improve the thermal capacity of Cloverdale – Jackson's Ferry 765 kV line		AEP (100%)
b2701.1	Construct Herlan station as breaker and a half configuration with 9-138 kV CB's on 4 strings and with 2-28.8 MVAR capacitor banks		AEP (100%)
b2701.2	Construct new 138 kV line from Herlan station to Blue Racer station. Estimated approx. 3.2 miles of 1234 ACSS/TW Yukon and OPGW		AEP (100%)
2701.3	Install 1-138 kV CB at Blue Racer to terminate new Herlan circuit		AEP (100%)
b2714	Rebuild/upgrade line between Glencoe and Willow Grove Switch 69 kV		AEP (100%)
b2715	Build approximately 11.5 miles of 34.5 kV line with 556.5 ACSR 26/7 Dove conductor on wood poles from Flushing station to Smyrna station		AEP (100%)
b2727	Replace the South Canton 138 kV breakers 'K', 'J', 'J1', and 'J2' with 80kA breakers		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2731	Convert the Sunnyside – East Sparta – Malvern 23 kV sub-transmission network to 69 kV. The lines are already built to 69 kV standards		AEP (100%)
b2733	Replace South Canton 138 kV breakers ‘L’ and ‘L2’ with 80 kA rated breakers		AEP (100%)
b2750.1	Retire Betsy Layne 138/69/43 kV station and replace it with the greenfield Stanville station about a half mile north of the existing Betsy Layne station		AEP (100%)
b2750.2	Relocate the Betsy Layne capacitor bank to the Stanville 69 kV bus and increase the size to 14.4 MVAR		AEP (100%)
b2753.1	Replace existing George Washington station 138 kV yard with GIS 138 kV breaker and a half yard in existing station footprint. Install 138 kV revenue metering for new IPP connection		AEP (100%)
b2753.2	Replace Dilles Bottom 69/4 kV Distribution station as breaker and a half 138 kV yard design including AEP Distribution facilities but initial configuration will constitute a 3 breaker ring bus		AEP (100%)



**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2753.3	Connect two 138 kV 6-wired circuits from “Point A” (currently de-energized and owned by FirstEnergy) in circuit positions previously designated Burger #1 & Burger #2 138 kV. Install interconnection settlement metering on both circuits exiting Holloway		AEP (100%)
b2753.6	Build double circuit 138 kV line from Dilles Bottom to “Point A”. Tie each new AEP circuit in with a 6-wired line at Point A. This will create a Dilles Bottom – Holloway 138 kV circuit and a George Washington – Holloway 138 kV circuit		AEP (100%)
b2753.7	Retire line sections (Dilles Bottom – Bellaire and Moundsville – Dilles Bottom 69 kV lines) south of FirstEnergy 138 kV line corridor, near “Point A”. Tie George Washington – Moundsville 69 kV circuit to George Washington – West Bellaire 69 kV circuit		AEP (100%)
b2753.8	Rebuild existing 69 kV line as double circuit from George Washington – Dilles Bottom 138 kV. One circuit will cut into Dilles Bottom 138 kV initially and the other will go past with future plans to cut in		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2760	Perform a Sag Study of the Saltville – Tazewell 138 kV line to increase the thermal rating of the line		AEP (100%)
b2761.1	Replace the Hazard 161/138 kV transformer		AEP (100%)
b2761.2	Perform a Sag Study of the Hazard – Wooten 161 kV line to increase the thermal rating of the line		AEP (100%)
b2761.3	Rebuild the Hazard – Wooten 161 kV line utilizing 795 26/7 ACSR conductor (300 MVA rating)		AEP (100%)
b2762	Perform a Sag Study of Nagel – West Kingsport 138 kV line to increase the thermal rating of the line		AEP (100%)
b2776	Reconductor the entire Dequine – Meadow Lake 345 kV circuit #2		AEP (100%)
b2777	Reconductor the entire Dequine – Eugene 345 kV circuit #1		<i>EKPC</i> (100%)
b2779.1	Construct a new 138 kV station, Campbell Road, tapping into the Grabill – South Hicksville 138 kV line		AEP (100%)
b2779.2	Reconstruct sections of the Butler-N.Hicksville and Auburn-Butler 69 kV circuits as 138 kV double circuit and extend 138 kV from Campbell Road station		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2779.3	Construct a new 345/138 kV SDI Wilmington Station which will be sourced from Collingwood 345 kV and serve the SDI load at 345 kV and 138 kV, respectively		AEP (100%)
b2779.4	Loop 138 kV circuits in-out of the new SDI Wilmington 138 kV station resulting in a direct circuit to Auburn 138 kV and an indirect circuit to Auburn and Rob Park via Dunton Lake, and a circuit to Campbell Road; Reconductor 138 kV line section between Dunton Lake – SDI Wilmington		AEP (100%)
b2779.5	Expand Auburn 138 kV bus		AEP (100%)
b2787	Reconductor 0.53 miles (14 spans) of the Kaiser Jct. - Air Force Jct. Sw section of the Kaiser - Heath 69 kV circuit/line with 336 ACSR to match the rest of the circuit (73 MVA rating, 78% loading)		AEP (100%)
b2788	Install a new 3-way 69 kV line switch to provide service to AEP's Barnesville distribution station. Remove a portion of the #1 copper T-Line from the 69 kV through-path		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2789	Rebuild the Brues - Glendale Heights 69 kV line section (5 miles) with 795 ACSR (128 MVA rating, 43% loading)	AEP (100%)
b2790	Install a 3 MVAR, 34.5 kV cap bank at Caldwell substation	AEP (100%)
b2791	Rebuild Tiffin – Howard, new transformer at Chatfield	AEP (100%)
b2791.1	Rebuild portions of the East Tiffin - Howard 69 kV line from East Tiffin to West Rockaway Switch (0.8 miles) using 795 ACSR Drake conductor (129 MVA rating, 50% loading)	AEP (100%)
b2791.2	Rebuild Tiffin - Howard 69 kV line from St. Stephen’s Switch to Hinesville (14.7 miles) using 795 ACSR Drake conductor (90 MVA rating, non-conductor limited, 38% loading)	AEP (100%)
b2791.3	New 138/69 kV transformer with 138/69 kV protection at Chatfield	AEP (100%)
b2791.4	New 138/69 kV protection at existing Chatfield transformer	AEP (100%)
b2792	Replace the Elliott transformer with a 130 MVA unit, reconductor 0.42 miles of the Elliott – Ohio University 69 kV line with 556 ACSR to match the rest of the line conductor (102 MVA rating, 73% loading) and rebuild 4 miles of the Clark Street – Strouds R	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2793	Energize the spare Fremont Center 138/69 kV 130 MVA transformer #3. Reduces overloaded facilities to 46% loading	AEP (100%)
b2794	Construct new 138/69/34 kV station and 1-34 kV circuit (designed for 69 kV) from new station to Decliff station, approximately 4 miles, with 556 ACSR conductor (51 MVA rating)	AEP (100%)
b2795	Install a 34.5 kV 4.8 MVAR capacitor bank at Killbuck 34.5 kV station	AEP (100%)
b2796	Rebuild the Malvern - Oneida Switch 69 kV line section with 795 ACSR (1.8 miles, 125 MVA rating, 55% loading)	AEP (100%)
b2797	Rebuild the Ohio Central - Conesville 69 kV line section (11.8 miles) with 795 ACSR conductor (128 MVA rating, 57% loading). Replace the 50 MVA Ohio Central 138/69 kV XFMR with a 90 MVA unit	AEP (100%)
b2798	Install a 14.4 MVAR capacitor bank at West Hicksville station. Replace ground switch/MOAB at West Hicksville with a circuit switcher	AEP (100%)
b2799	Rebuild Valley - Almena, Almena - Hartford, Riverside - South Haven 69 kV lines. New line exit at Valley Station. New transformers at Almena and Hartford	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2799.1	Rebuild 12 miles of Valley – Almena 69 kV line as a double circuit 138/69 kV line using 795 ACSR conductor (360 MVA rating) to introduce a new 138 kV source into the 69 kV load pocket around Almena station	AEP (100%)
b2799.2	Rebuild 3.2 miles of Almena to Hartford 69 kV line using 795 ACSR conductor (90 MVA rating)	AEP (100%)
b2799.3	Rebuild 3.8 miles of Riverside – South Haven 69 kV line using 795 ACSR conductor (90 MVA rating)	AEP (100%)
b2799.4	At Valley station, add new 138 kV line exit with a 3000 A 40 kA breaker for the new 138 kV line to Almena and replace CB D with a 3000 A 40 kA breaker	AEP (100%)
b2799.5	At Almena station, install a 90 MVA 138/69 kV transformer with low side 3000 A 40 kA breaker and establish a new 138 kV line exit towards Valley	AEP (100%)
b2799.6	At Hartford station, install a second 90 MVA 138/69 kV transformer with a circuit switcher and 3000 A 40 kA low side breaker	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2817	Replace Delaware 138 kV breaker 'P' with a 40 kA breaker	AEP (100%)
b2818	Replace West Huntington 138 kV breaker 'F' with a 40 kA breaker	AEP (100%)
b2819	Replace Madison 138 kV breaker 'V' with a 63 kA breaker	AEP (100%)
b2820	Replace Sterling 138 kV breaker 'G' with a 40 kA breaker	AEP (100%)
b2821	Replace Morse 138 kV breakers '103', '104', '105', and '106' with 63 kA breakers	AEP (100%)
b2822	Replace Clinton 138 kV breakers '105' and '107' with 63 kA breakers	AEP (100%)
b2826.1	Install 300 MVAR reactor at Ohio Central 345 kV substation	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements    Annual Revenue Requirement    Responsible Customer(s)

b2826.2	Install 300 MVAR reactor at West Bellaire 345 kV substation		AEP (100%)
b2831.1	Upgrade the Tanner Creek – Miami Fort 345 kV circuit (AEP portion)		<b>DFAX Allocation:</b> Dayton (61.71%) / DEOK (37.68%) / OVEC (0.61%)
b2832	Six wire the Kyger Creek – Sporn 345 kV circuits #1 and #2 and convert them to one circuit		AEP (100%)
b2833	Reconductor the Maddox Creek – East Lima 345 kV circuit with 2-954 ACSS Cardinal conductor		<b>DFAX Allocation:</b> AEP (80.83%) / Dayton (18.73%) / OVEC (0.44%)
b2834	Reconductor and string open position and sixwire 6.2 miles of the Chemical – Capitol Hill 138 kV circuit		AEP (100%)
b2872	Replace the South Canton 138 kV breaker ‘K2’ with a 80 kA breaker		AEP (100%)
b2873	Replace the South Canton 138 kV breaker “M” with a 80 kA breaker		AEP (100%)
b2874	Replace the South Canton 138 kV breaker “M2” with a 80 kA breaker		AEP (100%)
b2878	Upgrade the Clifty Creek 345 kV risers		AEP (100%)
b2880	Rebuild approximately 4.77 miles of the Cannonsburg – South Neal 69 kV line section utilizing 795 ACSR conductor (90 MVA rating)		AEP (100%)



**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2881	Rebuild ~1.7 miles of the Dunn Hollow – London 46 kV line section utilizing 795 26/7 ACSR conductor (58 MVA rating, non-conductor limited)	AEP (100%)
b2882	Rebuild Reusens - Peakland Switch 69 kV line. Replace Peakland Switch	AEP (100%)
b2882.1	Rebuild the Reusens - Peakland Switch 69 kV line (approximately 0.8 miles) utilizing 795 ACSR conductor (86 MVA rating, non-conductor limited)	AEP (100%)
b2882.2	Replace existing Peakland S.S with new 3 way switch phase over phase structure	AEP (100%)
b2883	Rebuild the Craneco – Pardee – Three Forks – Skin Fork 46 kV line section (approximately 7.2 miles) utilizing 795 26/7 ACSR conductor (108 MVA rating)	AEP (100%)
b2884	Install a second transformer at Nagel station, comprised of 3 single phase 250 MVA 500/138 kV transformers. Presently, TVA operates their end of the Boone Dam – Holston 138 kV interconnection as normally open preemptively for the loss of the existing Nagel	AEP (100%)
b2885	New delivery point for City of Jackson	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2885.1	Install a new Ironman Switch to serve a new delivery point requested by the City of Jackson for a load increase request	AEP (100%)
b2885.2	Install a new 138/69 kV station (Rhodes) to serve as a third source to the area to help relieve overloads caused by the customer load increase	AEP (100%)
b2885.3	Replace Coalton Switch with a new three breaker ring bus (Heppner)	AEP (100%)
b2886	Install 90 MVA 138/69 kV transformer, new transformer high and low side 3000 A 40 kA CBs, and a 138 kV 40 kA bus tie breaker at West End Fostoria	AEP (100%)
b2887	Add 2-138 kV CB's and relocate 2-138 kV circuit exits to different bays at Morse Road. Eliminate 3 terminal line by terminating Genoa - Morse circuit at Morse Road	AEP (100%)
b2888	Retire Poston substation. Install new Lemaster substation	AEP (100%)
b2888.1	Remove and retire the Poston 138 kV station	AEP (100%)
b2888.2	Install a new greenfield station, Lemaster 138 kV Station, in the clear	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2888.3	Relocate the Trimble 69 kV AEP Ohio radial delivery point to 138 kV, to be served off of the Poston – Strouds Run – Crooksville 138 kV circuit via a new three-way switch. Retire the Poston - Trimble 69 kV line	AEP (100%)
b2889	Expand Cliffview station	AEP (100%)
b2889.1	Cliffview Station: Establish 138 kV bus. Install two 138/69 kV XFRs (130 MVA), six 138 kV CBs (40 kA 3000 A) and four 69 kV CBs (40 kA 3000 A)	AEP (100%)
b2889.2	Byllesby – Wythe 69 kV: Retire all 13.77 miles (1/0 CU) of this circuit (~4 miles currently in national forest)	AEP (100%)
b2889.3	Galax – Wythe 69 kV: Retire 13.53 miles (1/0 CU section) of line from Lee Highway down to Byllesby. This section is currently double circuited with Byllesby – Wythe 69 kV. Terminate the southern 3/0 ACSR section into the newly opened position at Byllesby	AEP (100%)
b2889.4	Cliffview Line: Tap the existing Pipers Gap – Jubal Early 138 kV line section. Construct double circuit in/out (~2 miles) to newly established 138 kV bus, utilizing 795 26/7 ACSR conductor	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2890.1	Rebuild 23.55 miles of the East Cambridge – Smyrna 34.5 kV circuit with 795 ACSR conductor (128 MVA rating) and convert to 69 kV	AEP (100%)
b2890.2	East Cambridge: Install a 2000 A 69 kV 40 kA circuit breaker for the East Cambridge – Smyrna 69 kV circuit	AEP (100%)
b2890.3	Old Washington: Install 69 kV 2000 A two way phase over phase switch	AEP (100%)
b2890.4	Install 69 kV 2000 A two way phase over phase switch	AEP (100%)
b2891	Rebuild the Midland Switch to East Findlay 34.5 kV line (3.31 miles) with 795 ACSR (63 MVA rating) to match other conductor in the area	AEP (100%)
b2892	Install new 138/12 kV transformer with high side circuit switcher at Leon and a new 138 kV line exit towards Ripley. Establish 138 kV at the Ripley station with a new 138/69 kV 130 MVA transformer and move the distribution load to 138 kV service	AEP (100%)
b2936.1	Rebuild approximately 6.7 miles of 69 kV line between Mottville and Pigeon River using 795 ACSR conductor (129 MVA rating). New construction will be designed to 138 kV standards but operated at 69 kV	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2936.2	Pigeon River Station: Replace existing MOAB Sw. 'W' with a new 69 kV 3000 A 40 kA breaker, and upgrade existing relays towards HMD station. Replace CB H with a 3000 A 40 kA breaker	AEP (100%)
b2937	Replace the existing 636 ACSR 138 kV bus at Fletchers Ridge with a larger 954 ACSR conductor	AEP (100%)
b2938	Perform a sag mitigations on the Broadford – Wolf Hills 138 kV circuit to allow the line to operate to a higher maximum temperature	AEP (100%)
b2958.1	Cut George Washington – Tidd 138 kV circuit into Sand Hill and reconfigure Brues & Warton Hill line entrances	AEP (100%)
b2958.2	Add 2 138 kV 3000 A 40 kA breakers, disconnect switches, and update relaying at Sand Hill station	AEP (100%)
b2968	Upgrade existing 345 kV terminal equipment at Tanner Creek station	AEP (100%)
b2969	Replace terminal equipment on Maddox Creek - East Lima 345 kV circuit	AEP (100%)
b2976	Upgrade terminal equipment at Tanners Creek 345 kV station. Upgrade 345 kV bus and risers at Tanners Creek for the Dearborn circuit	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2988	Replace the Twin Branch 345 kV breaker “JM” with 63 kA breaker and associated substation works including switches, bus leads, control cable and new DICM	AEP (100%)
b2993	Rebuild the Torrey – South Gambrinus Switch – Gambrinus Road 69 kV line section (1.3 miles) with 1033 ACSR ‘Curlew’ conductor and steel poles	AEP (100%)
b3000	Replace South Canton 138 kV breaker ‘N’ with an 80kA breaker	AEP (100%)
b3001	Replace South Canton 138 kV breaker ‘N1’ with an 80kA breaker	AEP (100%)
b3002	Replace South Canton 138 kV breaker ‘N2’ with an 80kA breaker	AEP (100%)
b3036	Rebuild 15.6 miles of Haviland - North Delphos 138 kV line	AEP (100%)
b3037	Upgrades at the Natrium substation	AEP (100%)
b3038	Reconductor the Capitol Hill – Coco 138 kV line section	AEP (100%)
b3039	Line swaps at Muskingum 138 kV station	AEP (100%)
b3040.1	Rebuild Ravenswood – Racine tap 69 kV line section (~15 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3040.2	Rebuild existing Ripley – Ravenswood 69 kV circuit (~9 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)
b3040.3	Install new 3-way phase over phase switch at Sarah Lane station to replace the retired switch at Cottageville	AEP (100%)
b3040.4	Install new 138/12 kV 20 MVA transformer at Polymer station to transfer load from Mill Run station to help address overload on the 69 kV network	AEP (100%)
b3040.5	Retire Mill Run station	AEP (100%)
b3040.6	Install 28.8 MVAR cap bank at South Buffalo station	AEP (100%)
b3051.2	Adjust CT tap ratio at Ronceverte 138 kV	AEP (100%)
b3085	Reconductor Kammer – George Washington 138 kV line (approx. 0.08 mile). Replace the wave trap at Kammer 138 kV	AEP (100%)
b3086.1	Rebuild New Liberty – Findlay 34 kV line Str’s 1–37 (1.5 miles), utilizing 795 26/7 ACSR conductor	AEP (100%)
b3086.2	Rebuild New Liberty – North Baltimore 34 kV line Str’s 1-11 (0.5 mile), utilizing 795 26/7 ACSR conductor	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3086.3	Rebuild West Melrose – Whirlpool 34 kV line Str’s 55–80 (1 mile), utilizing 795 26/7 ACSR conductor	AEP (100%)
b3086.4	North Findlay station: Install a 138 kV 3000A 63kA line breaker and low side 34.5 kV 2000A 40kA breaker, high side 138 kV circuit switcher on T1	AEP (100%)
b3086.5	Ebersole station: Install second 90 MVA 138/69/34 kV transformer. Install two low side (69 kV) 2000A 40kA breakers for T1 and T2	AEP (100%)
b3087.1	Construct a new greenfield station to the west (approx. 1.5 miles) of the existing Fords Branch Station in the new Kentucky Enterprise Industrial Park. This station will consist of six 3000A 40kA 138 kV breakers laid out in a ring arrangement, two 30 MVA 138/34.5 kV transformers, and two 30 MVA 138/12 kV transformers. The existing Fords Branch Station will be retired	AEP (100%)
b3087.2	Construct approximately 5 miles of new double circuit 138 kV line in order to loop the new Kewanee station into the existing Beaver Creek – Cedar Creek 138 kV circuit	AEP (100%)



**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3087.3	Remote end work will be required at Cedar Creek Station	AEP (100%)
b3087.4	Install 28.8 MVar switching shunt at the new Fords Branch substation	AEP (100%)
b3095	Rebuild Lakin – Racine Tap 69 kV line section (9.2 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)
b3099	Install a 138 kV 3000A 40 kA circuit switcher on the high side of the existing 138/34.5 kV transformer No.5 at Holston station	AEP (100%)
b3100	Replace the 138 kV MOAB switcher “YY” with a new 138 kV circuit switcher on the high side of Chemical transformer No.6	AEP (100%)
b3101	Rebuild the 1/0 Cu. conductor sections (approx. 1.5 miles) of the Fort Robinson – Moccasin Gap 69 kV line section (approx. 5 miles) utilizing 556 ACSR conductor and upgrade existing relay trip limit (WN/WE: 63 MVA, line limited by remaining conductor sections)	AEP (100%)
b3102	Replace existing 50 MVA 138/69 kV transformers #1 and #2 (both 1957 vintage) at Fremont station with new 130 MVA 138/69 kV transformers	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement		Responsible Customer(s)
b3103.1	Install a 138/69 kV transformer at Royerton station. Install a 69 kV bus with one 69 kV breaker toward Bosman station. Rebuild the 138 kV portion into a ring bus configuration built for future breaker and a half with four 138 kV breakers		AEP (100%)
b3103.2	Rebuild the Bosman/Strawboard station in the clear across the road to move it out of the flood plain and bring it up to 69 kV standards		AEP (100%)
b3103.3	Retire 138 kV breaker L at Delaware station and re-purpose 138 kV breaker M for the Jay line		AEP (100%)
b3103.4	Retire all 34.5 kV equipment at Hartford City station. Re-purpose breaker M for the Bosman line 69 kV exit		AEP (100%)
b3103.5	Rebuild the 138 kV portion of Jay station as a 6 breaker, breaker and a half station re-using the existing breakers "A", "B", and "G." Rebuild the 69 kV portion of this station as a 6 breaker ring bus re-using the 2 existing 69 kV breakers. Install a new 138/69 kV transformer		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement		Responsible Customer(s)
b3103.6	Rebuild the 69 kV Hartford City – Armstrong Cork line but instead of terminating it into Armstrong Cork, terminate it into Jay station		AEP (100%)
b3103.7	Build a new 69 kV line from Armstrong Cork – Jay station		AEP (100%)
b3103.8	Rebuild the 34.5 kV Delaware – Bosman line as the 69 kV Royerton – Strawboard line. Retire the line section from Royerton to Delaware stations		AEP (100%)
b3104	Perform a sag study on the Polaris – Westerville 138 kV line (approx. 3.6 miles) to increase the summer emergency rating to 310 MVA		AEP (100%)
b3105	Rebuild the Delaware – Hyatt 138 kV line (approx. 4.3 miles) along with replacing conductors at both Hyatt and Delaware substations		AEP (100%)
b3106	Perform a sag study (6.8 miles of line) to increase the SE rating to 310 MVA. Note that results from the sag study could cover a wide range of outcomes, from no work required to a complete rebuild		AEP (100%)
b3109	Rebuild 5.2 miles Bethel – Sawmill 138 kV line including ADSS		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3112	Construct a single circuit 138 kV line (approx. 3.5 miles) from Amlin to Dublin using 1033 ACSR Curlew (296 MVA SN), convert Dublin station into a ring configuration, and re-terminating the Britton UG cable to Dublin station	AEP (100%)
b3116	Replace existing Mullens 138/46 kV 30 MVA transformer No.4 and associated protective equipment with a new 138/46 kV 90 MVA transformer and associated protective equipment	AEP (100%)
b3118.1	Expand existing Chadwick station and install a second 138/69 kV transformer at a new 138 kV bus tied into the Bellefonte – Grangston 138 kV circuit. The 69 kV bus will be reconfigured into a ring bus arrangement to tie the new transformer into the existing 69 kV via installation of four 3000A 63 kA 69 kV circuit breakers	AEP (100%)
b3118.2	Perform 138 kV remote end work at Grangston station	AEP (100%)
b3118.3	Perform 138 kV remote end work at Bellefonte station	AEP (100%)
b3118.4	Relocate the Chadwick – Leach 69 kV circuit within Chadwick station	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3118.5	Terminate the Bellefonte – Grangston 138 kV circuit to the Chadwick 138 kV bus	AEP (100%)
b3118.6	Chadwick – Tri-State #2 138 kV circuit will be reconfigured within the station to terminate into the newly established 138 kV bus #2 at Chadwick due to construability aspects	AEP (100%)
b3118.7	Reconductor Chadwick – Leach and Chadwick – England Hill 69 kV lines with 795 ACSS conductor. Perform a LiDAR survey and a sag study to confirm that the reconductored circuits would maintain acceptable clearances	AEP (100%)
b3118.8	Replace the 20 kA 69 kV circuit breaker ‘F’ at South Neal station with a new 3000A 40 kA 69 kV circuit breaker. Replace line risers towards Leach station	AEP (100%)
b3118.9	Rebuild 336 ACSR portion of Leach – Miller S.S 69 kV line section (approx. 0.3 mile) with 795 ACSS conductor	AEP (100%)
b3118.10	Replace 69 kV line risers (towards Chadwick) at Leach station	AEP (100%)
b3119.1	Rebuild the Jay – Pennville 138 kV line as double circuit 138/69 kV. Build a new 9.8 mile single circuit 69 kV line from near Pennville station to North Portland station	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3119.2	Install three (3) 69 kV breakers to create the “U” string and add a low side breaker on the Jay transformer 2	AEP (100%)
b3119.3	Install two (2) 69 kV breakers at North Portland station to complete the ring and allow for the new line	AEP (100%)
b3129	At Conesville 138 kV station: Remove line leads to generating units, transfer plant AC service to existing station service feeds in Conesville 345/138 kV yard, and separate and reconfigure protection schemes	AEP (100%)
b3131	At East Lima and Haviland 138 kV stations, replace line relays and wavetraps on the East Lima – Haviland 138 kV facility	AEP (100%)
b3132	Rebuild 3.11 miles of the LaPorte Junction – New Buffalo 69 kV line with 795 ACSR	AEP (100%)
b3139	Rebuild the Garden Creek – Whetstone 69 kV line (approx. 4 miles)	AEP (100%)
b3140	Rebuild the Whetstone – Knox Creek 69 kV line (approx. 3.1 miles)	AEP (100%)
b3141	Rebuild the Knox Creek – Coal Creek 69 kV line (approx. 2.9 miles)	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3148.1	Rebuild the 46 kV Bradley – Scarbro line to 96 kV standards using 795 ACSR to achieve a minimum rate of 120 MVA. Rebuild the new line adjacent to the existing one leaving the old line in service until the work is completed	AEP (100%)
b3148.2	Bradley remote end station work, replace 46 kV bus, install new 12 MVAR capacitor bank	AEP (100%)
b3148.3	Replace the existing switch at Sun substation with a 2-way SCADA-controlled motor-operated air-breaker switch	AEP (100%)
b3148.4	Remote end work and associated equipment at Scarbro station	AEP (100%)
b3148.5	Retire Mt. Hope station and transfer load to existing Sun station	AEP (100%)
b3149	Rebuild the 2.3 mile Decatur – South Decatur 69 kV line using 556 ACSR	AEP (100%)
b3150	Rebuild Ferguson 69/12 kV station in the clear as the 138/12 kV Bear station and connect it to an approx. 1 mile double circuit 138 kV extension from the Aviation – Ellison Road 138 kV line to remove the load from the 69 kV line	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3151.1	Rebuild the 30 mile Gateway – Wallen 34.5 kV circuit as the 27 mile Gateway – Wallen 69 kV line	AEP (100%)
b3151.2	Retire approx. 3 miles of the Columbia – Whitley 34.5 kV line	AEP (100%)
b3151.3	At Gateway station, remove all 34.5 kV equipment and install one (1) 69 kV circuit breaker for the new Whitley line entrance	AEP (100%)
b3151.4	Rebuild Whitley as a 69 kV station with two (2) lines and one (1) bus tie circuit breaker	AEP (100%)
b3151.5	Replace the Union 34.5 kV switch with a 69 kV switch structure	AEP (100%)
b3151.6	Replace the Eel River 34.5 kV switch with a 69 kV switch structure	AEP (100%)
b3151.7	Install a 69 kV Bobay switch at Woodland station	AEP (100%)
b3151.8	Replace the Carroll and Churubusco 34.5 kV stations with the 69 kV Snapper station. Snapper station will have two (2) line circuit breakers, one (1) bus tie circuit breaker and a 14.4 MVAR cap bank	AEP (100%)
b3151.9	Remove 34.5 kV circuit breaker “AD” at Wallen station	AEP (100%)
b3151.10	Rebuild the 2.5 miles of the Columbia – Gateway 69 kV line	AEP (100%)



**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3151.11	Rebuild Columbia station in the clear as a 138/69 kV station with two (2) 138/69 kV transformers and 4-breaker ring buses on the high and low side. Station will reuse 69 kV breakers “J” & “K” and 138 kV breaker “D”	AEP (100%)
b3151.12	Rebuild the 13 miles of the Columbia – Richland 69 kV line	AEP (100%)
b3151.13	Rebuild the 0.5 mile Whitley – Columbia City No.1 line as 69 kV	AEP (100%)
b3151.14	Rebuild the 0.5 mile Whitley – Columbia City No.2 line as 69 kV	AEP (100%)
b3151.15	Rebuild the 0.6 mile double circuit section of the Rob Park – South Hicksville / Rob Park – Diebold Road as 69 kV	AEP (100%)
b3160.1	Construct an approx. 2.4 miles double circuit 138 kV extension using 1033 ACSR (Aluminum Conductor Steel Reinforced) to connect Lake Head to the 138 kV network	AEP (100%)
b3160.2	Retire the approx.2.5 miles 34.5 kV Niles – Simplicity Tap line	AEP (100%)
b3160.3	Retire the approx.4.6 miles Lakehead 69 kV Tap	AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement		Responsible Customer(s)
b3160.4	Build new 138/69 kV drop down station to feed Lakehead with a 138 kV breaker, 138 kV switcher, 138/69 kV transformer and a 138 kV Motor-Operated Air Break		AEP (100%)
b3160.5	Rebuild the approx. 1.2 miles Buchanan South 69 kV Radial Tap using 795 ACSR (Aluminum Conductor Steel Reinforced)		AEP (100%)
b3160.6	Rebuild the approx.8.4 miles 69 kV Pletcher – Buchanan Hydro line as the approx. 9 miles Pletcher – Buchanan South 69 kV line using 795 ACSR (Aluminum Conductor Steel Reinforced)		AEP (100%)
b3160.7	Install a PoP (Point-of-Presence) switch at Buchanan South station with 2 line MOABs (Motor-Operated Air Break)		AEP (100%)

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
<p>b3208</p>	<p>Retire approximately 38 miles of the 44 mile Clifford – Scottsville 46 kV circuit. Build new 138 kV “in and out” to two new distribution stations to serve the load formerly served by Phoenix, Shipman, Schuyler (AEP), and Rockfish stations. Construct new 138 kV lines from Joshua Falls – Riverville (approx. 10 miles) and Riverville – Gladstone (approx. 5 miles). Install required station upgrades at Joshua Falls, Riverville and Gladstone stations to accommodate the new 138 kV circuits. Rebuild Reusen – Monroe 69 kV (approx. 4 miles)</p>	<p>AEP (100%)</p>
<p>b3209</p>	<p>Rebuild the 10.5 mile Berne – South Decatur 69 kV line using 556 ACSR</p>	<p>AEP (100%)</p>
<p>b3210</p>	<p>Replace approx. 0.7 mile Beatty – Galloway 69 kV line with 4000 kcmil XLPE cable</p>	<p>AEP (100%)</p>
<p>b3220</p>	<p>Install 14.4 MVAR capacitor bank at Whitewood 138 kV</p>	<p>AEP (100%)</p>
<p>b3261</p>	<p>Upgrade circuit breaker “R1” at Tanners Creek 345 kV. Install Transient Recovery Voltage capacitor to increase the rating from 50 kA to 63 kA</p>	<p>AEP (100%)</p>

**AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3269	At West New Philadelphia station, add a high side 138 kV breaker on the 138/69 kV Transformer #2 along with a 138 kV breaker on the line towards Newcomerstown	AEP (100%)
b3270	Install 1.7 miles of 795 ACSR 138 kV conductor along the other side of Dragoon Tap 138 kV line, which is currently double circuit tower with one position open. Additionally, install a second 138/34.5 kV transformer at Dragoon, install a high side circuit switcher on the current transformer at the Dragoon Station, and install two (2) 138 kV line breakers on the Dragoon – Jackson 138 kV and Dragoon – Twin Branch 138 kV lines	AEP (100%)
b3270.1	Replace Dragoon 34.5 kV breakers “B”, “C”, and “D” with 40 kA breakers	AEP (100%)
b3271	Install a 138 kV circuit breaker at Fremont station on the line towards Fremont Center and install a 9.6 MVAR 69 kV capacitor bank at Bloom Road station	AEP (100%)
b3272	Install two 138 kV circuit switchers on the high side of 138/34.5 kV Transformers #1 and #2 at Rockhill station	AEP (100%)

**SCHEDULE 12 – APPENDIX A**

**(19) Northern Indiana Public Service Company**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2971	Reconfigure Munster 345 kV as ring bus	MISO (12.00%) / AEC (0.97%) / AEP (16.65%) / APS (4.94%) / ATSI (7.77%) / BGE (5.20%) / Dayton (1.85%) / DEOK (2.29%) / Dominion (15.20%) / DPL (1.75%) / DL (1.43%) / EKPC (0.60%) / JCPL (2.16%) / ME (1.72%) / PECO (4.32%) / PENELEC (4.98%) / PEPCO (5.80%) / PPL (4.74%) / PSEG (5.08%) / RE (0.15%) / NEPTUNE* (0.33%) / ECP** (0.05%) / HTP*** (0.02%)
b2973	Reconductor Michigan City - Bosserman 138 kV	MISO (10.00%) / AEC (0.93%) / AEP (26.02%) / APS (4.19%) / ATSI (5.95%) / BGE (4.38%) / Dayton (1.58%) / DEOK (2.30%) / Dominion (14.70%) / DPL (1.53%) / DL (1.26%) / EKPC (0.98%) / JCPL (1.92%) / ME (1.39%) / PECO (4.19%) / PENELEC (4.34%) / PEPCO (5.05%) / PPL (4.03%) / PSEG (4.48%) / RE (0.12%) / NEPTUNE* (0.56%) / ECP** (0.08%) / HTP*** (0.02%)
b2974	Replace terminal equipment at Reynolds on the Reynolds - Magnetation 138 kV	MISO (59.00%) / AEC (0.01%) / AEP (40.28%) / APS (0.13%) / ATSI (0.05%) / BGE (0.08%) / Dayton (0.03%) / DPL (0.01%) / ME (0.04%) / PENELEC (0.06%) / PPL (0.20%) / PSEG (0.03%) / NEPTUNE* (0.04%) / HTP*** (0.04%)

**Northern Indiana Public Service Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2975	Reconductor Roxana - Praxair 138 kV	MISO (76.00%) / AEC (0.28%) / AEP (4.51%) / APS (1.31%) / ATSI (1.91%) / BGE (1.40%) / Dayton (0.49%) / DEOK (0.69%) / Dominion (4.35%) / DPL (0.46%) / DL (0.38%) / EKPC (0.27%) / JCPL (0.57%) / ME (0.43%) / PECO (1.25%) / PENELEC (1.34%) / PEPCO (1.53%) / PPL (1.23%) / PSEG (1.41%) / RE (0.04%) / NEPTUNE* (0.14%) / HTP*** (0.01%)
b3142	Rebuild the Michigan City – Trail Creek – Bosserman 138 kV line (10.7 miles)	MISO (10.90%) / ComEd (89.10%)

**SCHEDULE 12 – APPENDIX A**

**(20) Virginia Electric and Power Company**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1698.7	Replace Loudoun 230 kV breaker '203052' with 63kA rating	Dominion (100%)
b1696.1	Replace the Idylwood 230 kV '25112' breaker with 50kA breaker	Dominion (100%)
b1696.2	Replace the Idylwood 230 kV '209712' breaker with 50kA breaker	Dominion (100%)
b1793.1	Remove the Carolina 22 SPS to include relay logic changes, minor control wiring, relay resets and SCADA programming upon completion of project	Dominion (100%)
b2281	Additional Temporary SPS at Bath County	Dominion (100%)
b2350	Reconductor 211 feet of 545.5 ACAR conductor on 59 Line Elmont - Greenwood DP 115 kV to achieve a summer emergency rating of 906 amps or greater	Dominion (100%)
b2358	Install a 230 kV 54 MVAR capacitor bank on the 2016 line at Harmony Village Substation	Dominion (100%)
b2359	Wreck and rebuild approximately 1.3 miles of existing 230 kV line between Cochran Mill - X4-039 Switching Station	Dominion (100%)
b2360	Build a new 39 mile 230 kV transmission line from Doods - Lexington on existing right-of-way	Dominion (100%)
b2361	Construct 230 kV OH line along existing Line #2035 corridor, approx. 2.4 miles from Idylwood - Dulles Toll Road (DTR) and 2.1 miles on new right-of-way along DTR to new Scott's Run Substation	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2368	Replace the Brambleton 230 kV breaker '209502' with 63kA breaker	Dominion (100%)
b2369	Replace the Brambleton 230 kV breaker '213702' with 63kA breaker	Dominion (100%)
b2370	Replace the Brambleton 230 kV breaker 'H302' with 63kA breaker	Dominion (100%)
b2373	Build a 2nd Loudoun - Brambleton 500 kV line within the existing ROW. The Loudoun - Brambleton 230 kV line will be relocated as an underbuild on the new 500 kV line	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  APS (25.51%) / Dominion (74.49%)</p>
b2397	Replace the Beaumeade 230 kV breaker '2079T2116' with 63kA	Dominion (100%)
b2398	Replace the Beaumeade 230 kV breaker '2079T2130' with 63kA	Dominion (100%)
b2399	Replace the Beaumeade 230 kV breaker '208192' with 63kA	Dominion (100%)
b2400	Replace the Beaumeade 230 kV breaker '209592' with 63kA	Dominion (100%)
b2401	Replace the Beaumeade 230 kV breaker '211692' with 63kA	Dominion (100%)
b2402	Replace the Beaumeade 230 kV breaker '227T2130' with 63kA	Dominion (100%)

The Annual Revenue Requirement for all Virginia Electric and Power Company projects in this Section 20 shall be as specified in Attachment 7 to Appendix A of Attachment H-16A and under the procedures detailed in Attachment H-16B.

\*Neptune Regional Transmission System, LLC



**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2403	Replace the Beaumeade 230 kV breaker '274T2130' with 63kA	Dominion (100%)
b2404	Replace the Beaumeade 230 kV breaker '227T2095' with 63kA	Dominion (100%)
b2405	Replace the Pleasant view 230 kV breaker '203T274' with 63kA	Dominion (100%)
b2443	Construct new underground 230 kV line from Glebe to Station C, rebuild Glebe Substation, construct 230 kV high side bus at Station C with option to install 800 MVA PAR	Dominion (97.11%) / ME (0.18%) / PEPCO (2.71%)
b2443.1	Replace the Idylwood 230 kV breaker '203512' with 50kA	Dominion (100%)
b2443.2	Replace the Ox 230 kV breaker '206342' with 63kA breaker	Dominion (100%)
b2443.3	Glebe – Station C PAR	<b>DFAX Allocation:</b> Dominion (22.57%) / PEPCO (77.43%)
b2443.6	Install a second 500/230 kV transformer at Possum Point substation and replace bus work and associated equipment as needed	Dominion (100%)
b2443.7	Replace 19 63kA 230 kV breakers with 19 80kA 230 kV breakers	Dominion (100%)
b2457	Replace 24 115 kV wood h-frames with 230 kV Dominion pole H-frame structures on the Clubhouse – Purdy 115 kV line	Dominion (100%)
b2458.1	Replace 12 wood H-frame structures with steel H-frame structures and install shunts on all conductor splices on Carolina – Woodland 115 kV	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2458.2	Upgrade all line switches and substation components at Carolina 115 kV to meet or exceed new conductor rating of 174 MVA	Dominion (100%)
b2458.3	Replace 14 wood H-frame structures on Carolina – Woodland 115 kV	Dominion (100%)
b2458.4	Replace 2.5 miles of static wire on Carolina – Woodland 115 kV	Dominion (100%)
b2458.5	Replace 4.5 miles of conductor between Carolina 115 kV and Jackson DP 115 kV with min. 300 MVA summer STE rating; Replace 8 wood H-frame structures located between Carolina and Jackson DP with steel H-frames	Dominion (100%)
b2460.1	Replace Hanover 230 kV substation line switches with 3000A switches	Dominion (100%)
b2460.2	Replace wave traps at Four River 230 kV and Elmont 230 kV substations with 3000A wave traps	Dominion (100%)
b2461	Wreck and rebuild existing Remington CT – Warrenton 230 kV (approx. 12 miles) as a double-circuit 230 kV line	Dominion (100%)
b2461.1	Construct a new 230 kV line approximately 6 miles from NOVEC’s Wheeler Substation a new 230 kV switching station in Vint Hill area	Dominion (100%)
b2461.2	Convert NOVEC’s Gainesville – Wheeler line (approximately 6 miles) to 230 kV	Dominion (100%)
b2461.3	Complete a Vint Hill – Wheeler – Loudoun 230 kV networked line	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2471	Replace Midlothian 500 kV breaker 563T576 and motor operated switches with 3 breaker 500 kV ring bus. Terminate Lines # 563 Carson – Midlothian, #576 Midlothian –North Anna, Transformer #2 in new ring	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  Dominion (100%)</p>
b2504	Rebuild 115 kV Line #32 from Halifax-South Boston (6 miles) for min. of 240 MVA and transfer Welco tap to Line #32. Moving Welco to Line #32 requires disabling auto-sectionalizing scheme	Dominion (100%)
b2505	Install structures in river to remove the 115 kV #65 line (Whitestone-Harmony Village 115 kV) from bridge and improve reliability of the line	Dominion (100%)
b2542	Replace the Loudoun 500 kV ‘H2T502’ breaker with a 50kA breaker	Dominion (100%)
b2543	Replace the Loudoun 500 kV ‘H2T584’ breaker with a 50kA breaker	Dominion (100%)
b2565	Reconductor wave trap at Carver Substation with a 2000A wave trap	Dominion (100%)
b2566	Reconductor 1.14 miles of existing line between ACCA and Hermitage and upgrade associated terminal equipment	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2582	Rebuild the Elmont – Cunningham 500 kV line	<p><b>Load-Ratio Share Allocation:</b>                      AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>                      Dominion (100%)</p>
b2583	Install 500 kV breaker at Ox Substation to remove Ox Tx#1 from H1T561 breaker failure outage.	Dominion (100%)
b2584	Relocate the Bremono load (transformer #5) to #2028 (Bremono-Charlottesville 230 kV) line and Cartersville distribution station to #2027 (Bremono-Midlothian 230 kV) line	Dominion (100%)
b2585	Reconductor 7.63 miles of existing line between Cranes and Stafford, upgrade associated line switches at Stafford	PEPCO (100%)
b2620	Wreck and rebuild the Chesapeake – Deep Creek – Bowers Hill – Hodges Ferry 115 kV line; minimum rating 239 MVA normal/emergency, 275 MVA load dump rating	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2622	Rebuild Line #47 between Kings Dominion 115 kV and Fredericksburg 115 kV to current standards with summer emergency rating of 353 MVA at 115 kV	Dominion (100%)
b2623	Rebuild Line #4 between Bremo and Structure 8474 (4.5 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV	Dominion (100%)
b2624	Rebuild 115 kV Lines #18 and #145 between Possum Point Generating Station and NOVEC's Smoketown DP (approx. 8.35 miles) to current 230 kV standards with a normal continuous summer rating of 524 MVA at 115 kV	Dominion (100%)
b2625	Rebuild 115 kV Line #48 between Thole Street and Structure 48/71 to current standard. The remaining line to Sewells Point is 2007 vintage. Rebuild 115 kV Line #107 line, Sewells Point to Oakwood, between structure 107/17 and 107/56 to current standard.	Dominion (100%)
b2626	Rebuild 115 kV Line #34 between Skiffes Creek and Yorktown and the double circuit portion of 115 kV Line #61 to current standards with a summer emergency rating of 353 MVA at 115 kV	Dominion (100%)
b2627	Rebuild 115 kV Line #1 between Crewe 115 kV and Fort Pickett DP 115 kV (12.2 miles) to current standards with summer emergency rating of 261 MVA at 115 kV	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2628	Rebuild 115 kV Line #82 Everetts – Voice of America (20.8 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV	Dominion (100%)
b2629	Rebuild the 115 kV Lines #27 and #67 lines from Greenwich 115 kV to Burton 115 kV Structure 27/280 to current standard with a summer emergency rating of 262 MVA at 115 kV	Dominion (100%)
b2630	Install circuit switchers on Gravel Neck Power Station GSU units #4 and #5. Install two 230 kV CCVT's on Lines #2407 and #2408 for loss of source sensing	Dominion (100%)
b2636	Install three 230 kV bus breakers and 230 kV, 100 MVAR Variable Shunt Reactor at Dahlgren to provide line protection during maintenance, remove the operational hazard and provide voltage reduction during light load conditions	Dominion (100%)
b2647	Rebuild Boydton Plank Rd – Kerr Dam 115 kV Line #38 (8.3 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)
b2648	Rebuild Carolina – Kerr Dam 115 kV Line #90 (38.7 miles) to current standards with summer emergency rating of 353 MVA 115 kV.	Dominion (100%)
b2649	Rebuild Clubhouse – Carolina 115 kV Line #130 (17.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2649.1	Rebuild of 1.7 mile tap to Metcalf and Belfield DP (MEC) due to poor condition. The existing summer rating of the tap is 48 MVA and existing conductor is 4/0 ACSR on wood H-frames. The proposed new rating is 176 MVA using 636 ACSR conductor	Dominion (100%)
b2649.2	Rebuild of 4.1 mile tap to Brinks DP (MEC) due to wood poles built in 1962. The existing summer rating of the tap is 48 MVA and existing conductor is 4/0 ACSR and 393.6 ACSR on wood H-frames. The proposed new rating is 176 MVA using 636 ACSR conductor	Dominion (100%)
b2650	Rebuild Twittys Creek – Pamplin 115 kV Line #154 (17.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement		Responsible Customer(s)
b2651	Rebuild Buggs Island – Plywood 115 kV Line #127 (25.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV. The line should be rebuilt for 230 kV and operated at 115 kV.		Dominion (100%)
b2652	Rebuild Greatbridge – Hickory 115 kV Line #16 and Greatbridge – Chesapeake E.C. to current standard with summer emergency rating of 353 MVA at 115 kV.		Dominion (100%)
b2653.1	Build 20 mile 115 kV line from Pantego to Trowbridge with summer emergency rating of 353 MVA.		Dominion (100%)
b2653.2	Install 115 kV four-breaker ring bus at Pantego		Dominion (100%)
b2653.3	Install 115 kV breaker at Trowbridge		Dominion (100%)
b2654.1	Build 15 mile 115 kV line from Scotland Neck to S Justice Branch with summer emergency rating of 353 MVA. New line will be routed to allow HEMC to convert Dawson’s Crossroads RP from 34.5 kV to 115 kV.		Dominion (100%)
b2654.2	Install 115 kV three-breaker ring bus at S Justice Branch		Dominion (100%)
b2654.3	Install 115 kV breaker at Scotland Neck		Dominion (100%)
b2654.3	Install a 2nd 224 MVA 230/115 kV transformer at Hathaway		Dominion (100%)



**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2665	Rebuild the Cunningham – Dooms 500 kV line	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  Dominion (100%)</p>
b2686	Pratts Area Improvement	Dominion (100%)
b2686.1	Build a 230 kV line from Remington Substation to Gordonsville Substation utilizing existing ROW	Dominion (100%)
b2686.2	Install a 3rd 230/115 kV transformer at Gordonsville Substation	Dominion (100%)
b2686.3	Upgrade Line 2088 between Gordonsville Substation and Louisa CT Station	Dominion (100%)
b2686.4	Replace the Remington CT 230 kV breaker “2114T2155” with a 63 kA breaker	Dominion (100%)
b2686.11	Upgrading sections of the Gordonsville – Somerset 115 kV circuit	Dominion (100%)
b2686.12	Upgrading sections of the Somerset – Doubleday 115 kV circuit	Dominion (100%)
b2686.13	Upgrading sections of the Orange – Somerset 115 kV circuit	Dominion (100%)
b2686.14	Upgrading sections of the Mitchell – Mt. Run 115 kV circuit	Dominion (100%)

\*Neptune Regional Transmission System, LLC

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2717.1	De-energize Davis – Rosslyn #179 and #180 69 kV lines	Dominion (100%)
b2717.2	Remove splicing and stop joints in manholes	Dominion (100%)
b2717.3	Evacuate and dispose of insulating fluid from various reservoirs and cables	Dominion (100%)
b2717.4	Remove all cable along the approx. 2.5 mile route, swab and cap-off conduits for future use, leave existing communication fiber in place	Dominion (100%)
b2719.1	Expand Perth substation and add a 115 kV four breaker ring	Dominion (100%)
b2719.2	Extend the Hickory Grove DP tap 0.28 miles to Perth and terminate it at Perth	Dominion (100%)
b2719.3	Split Line #31 at Perth and terminate it into the new ring bus with 2 breakers separating each of the line terminals to prevent a breaker failure from taking out both 115 kV lines	Dominion (100%)
b2720	Replace the Loudoun 500 kV ‘H1T569’ breakers with 50kA breaker	Dominion (100%)
b2729	Optimal Capacitors Configuration: New 175 MVAR capacitor at Brambleton, new 175 MVAR capacitor at Ashburn, new 300 MVAR capacitor at Shelhorn, new 150 MVAR capacitor at Liberty	AEC (1.96%) / BGE (14.37%) / Dominion (35.11%) / DPL (3.76%) / ECP (0.29%) / HTP (0.34%) / JCPL (3.31%) / ME (2.51%) / Neptune (0.63%) / PECO (6.26%) / PEPCO (20.23%) / PPL (3.94%) / PSEG (7.29%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2744	Rebuild the Carson – Rogers Rd 500 kV circuit	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  Dominion (100%)</p>
b2745	Rebuild 21.32 miles of existing line between Chesterfield – Lakeside 230 kV	Dominion (100%)
b2746.1	Rebuild Line #137 Ridge Rd – Kerr Dam 115 kV, 8.0 miles, for 346 MVA summer emergency rating	Dominion (100%)
b2746.2	Rebuild Line #1009 Ridge Rd – Chase City 115 kV, 9.5 miles, for 346 MVA summer emergency rating	Dominion (100%)
b2746.3	Install a second 4.8 MVAR capacitor bank on the 13.8 kV bus of each transformer at Ridge Rd	Dominion (100%)
b2747	Install a Motor Operated Switch and SCADA control between Dominion’s Gordonsville 115 kV bus and FirstEnergy’s 115 kV line	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2757	Install a +/-125 MVar Statcom at Colington 230 kV	Dominion (100%)
b2758	Rebuild Line #549 Dooms – Valley 500kV	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  Dominion (100%)</p>
b2759	Rebuild Line #550 Mt. Storm – Valley 500kV	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  APS (87.50%) / ATSI (0.37%) / DL (0.19%) / Dominion (1.04%) / EKPC (10.90%)</p>

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2800	The 7 mile section from Dozier to Thompsons Corner of line #120 will be rebuilt to current standards using 768.2 ACSS conductor with a summer emergency rating of 346 MVA at 115 kV. Line is proposed to be rebuilt on single circuit steel monopole structure	Dominion (100%)
b2801	Lines #76 and #79 will be rebuilt to current standard using 768.2 ACSS conductor with a summer emergency rating of 346 MVA at 115 kV. Proposed structure for rebuild is double circuit steel monopole structure	Dominion (100%)
b2802	Rebuild Line #171 from Chase City – Boydton Plank Road tap by removing end-of-life facilities and installing 9.4 miles of new conductor. The conductor used will be at current standards with a summer emergency rating of 393 MVA at 115kV	Dominion (100%)
b2815	Build a new Pinewood 115kV switching station at the tap serving North Doswell DP with a 115kV four breaker ring bus	Dominion (100%)
b2842	Update the nameplate for Mount Storm 500 kV "57272" to be 50kA breaker	Dominion (100%)
b2843	Replace the Mount Storm 500 kV "G2TY" with 50kA breaker	Dominion (100%)
b2844	Replace the Mount Storm 500 kV "G2TZ" with 50kA breaker	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2845	Update the nameplate for Mount Storm 500 kV "G3TSX1" to be 50kA breaker	Dominion (100%)
b2846	Update the nameplate for Mount Storm 500 kV "SX172" to be 50kA breaker	Dominion (100%)
b2847	Update the nameplate for Mount Storm 500 kV "Y72" to be 50kA breaker	Dominion (100%)
b2848	Replace the Mount Storm 500 kV "Z72" with 50kA breaker	Dominion (100%)
b2871	Rebuild 230 kV line #247 from Swamp to Suffolk (31 miles) to current standards with a summer emergency rating of 1047 MVA at 230 kV	Dominion (100%)
b2876	Rebuild line #101 from Mackeys – Creswell 115 kV, 14 miles, with double circuit structures. Install one circuit with provisions for a second circuit. The conductor used will be at current standards with a summer emergency rating of 262 MVA at 115 kV	Dominion (100%)
b2877	Rebuild line #112 from Fudge Hollow – Lowmoor 138 kV (5.16 miles) to current standards with a summer emergency rating of 314 MVA at 138 kV	Dominion (100%)
b2899	Rebuild 230 kV line #231 to current standard with a summer emergency rating of 1046 MVA. Proposed conductor is 2-636 ACSR	Dominion (100%)
b2900	Build a new 230/115 kV switching station connecting to 230 kV network line #2014 (Earleys – Everetts). Provide a 115 kV source from the new station to serve Windsor DP	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2922	Rebuild 8 of 11 miles of 230 kV lines #211 and #228 to current standard with a summer emergency rating of 1046 MVA for rebuilt section. Proposed conductor is 2-636 ACSR	Dominion (100%)
b2928	Rebuild four structures of 500 kV line #567 from Chickahominy to Surry using galvanized steel and replace the river crossing conductor with 3-1534 ACSR. This will increase the line #567 line rating from 1954 MVA to 2600 MVA	<p><b>Load-Ratio Share Allocation:</b>            AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>            Dominion (100%)</p>
b2929	Rebuild 230 kV line #2144 from Winfall to Swamp (4.3 miles) to current standards with a standard conductor (bundled 636 ACSR) having a summer emergency rating of 1047 MVA at 230 kV	Dominion (100%)
b2960	Replace fixed series capacitors on 500 kV Line #547 at Lexington and on 500 kV Line #548 at Valley	See sub-IDs for cost allocations

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2960.1	Replace fixed series capacitors on 500 kV Line #547 at Lexington	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  DEOK (5.63%) / Dominion (91.06%) / EKPC (3.31%)</p>



**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2960.2	Replace fixed series capacitors on 500 kV Line #548 at Valley	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  DEOK (17.57%) / Dominion (74.24%) / EKPC (8.19%)</p>
b2961	Rebuild approximately 3 miles of Line #205 & Line #2003 from Chesterfield to Locks & Poe respectively	Dominion (100%)
b2962	Split Line #227 (Brambleton – Beaumeade 230 kV) and terminate into existing Belmont substation	Dominion (100%)
b2962.1	Replace the Beaumeade 230 kV breaker “274T2081” with 63kA breaker	Dominion (100%)
b2962.2	Replace the NIVO 230 kV breaker “2116T2130” with 63kA breaker	Dominion (100%)
b2963	Reconductor the Woodbridge to Occoquan 230 kV line segment of Line #2001 with 1047 MVA conductor and replace line terminal equipment at Possum Point, Woodbridge, and Occoquan	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2978	Install 2-125 MVAR STATCOMs at Rawlings and 1-125 MVAR STATCOM at Clover 500 kV substations	<p><b>Load-Ratio Share Allocation:</b>                      AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>                      Dominion (100%)</p>
b2980	Rebuild 115 kV Line #43 between Staunton and Harrisonburg (22.8 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV	Dominion (100%)
b2981	Rebuild 115 kV Line #29 segment between Fredericksburg and Aquia Harbor to current 230 kV standards (operating at 115 kV) utilizing steel H-frame structures with 2-636 ACSR to provide a normal continuous summer rating of 524 MVA at 115 kV (1047 MVA at 230 kV)	Dominion (100%)

\*Neptune Regional Transmission System, LLC

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement		Responsible Customer(s)
b2989	Install a second 230/115 kV Transformer (224 MVA) approximately 1 mile north of Bremono and tie 230 kV Line #2028 (Bremono – Charlottesville) and 115 kV Line #91 (Bremono - Sherwood) together. A three breaker 230 kV ring bus will split Line #2028 into two lines and Line #91 will also be split into two lines with a new three breaker 115 kV ring bus. Install a temporary 230/115 kV transformer at Bremono substation for the interim until the new substation is complete		Dominion (100%)
b2990	Chesterfield to Basin 230 kV line – Replace 0.14 miles of 1109 ACAR with a conductor which will increase the line rating to approximately 706 MVA		Dominion (100%)
b2991	Chaparral to Locks 230 kV line – Replace breaker lead		Dominion (100%)
b2994	Acquire land and build a new switching station (Skippers) at the tap serving Brink DP with a 115 kV four breaker ring to split Line #130 and terminate the end points		Dominion (100%)
b3018	Rebuild Line #49 between New Road and Middleburg substations with single circuit steel structures to current 115 kV standards with a minimum summer emergency rating of 261 MVA		Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3019	Rebuild 500 kV Line #552 Bristers to Chancellor – 21.6 miles long	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%)  / APS (5.61%) / ATSI (8.10%)  / BGE (4.36%) / ComEd  (13.14%) / Dayton (2.15%) /  DEOK (3.23%) / DL (1.73%) /  DPL (2.65%) / Dominion  (13.03%) / EKPC (1.77%) /  JCPL (3.84%) / ME (1.93%) /  NEPTUNE* (0.45%) / OVEC  (0.07%) / PECO (5.29%) /  PENELEC (1.89%) / PEPCO  (3.82%) / PPL (4.72%) / PSEG  (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  Dominion (89.20%) / PEPCO  (10.80%)</p>
b3019.1	Update the nameplate for Morrisville 500 kV breaker “H1T594” to be 50kA	Dominion (100%)
b3019.2	Update the nameplate for Morrisville 500 kV breaker “H1T545” to be 50kA	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3020	Rebuild 500 kV Line #574 Ladysmith to Elmont – 26.2 miles long	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  APS (16.36%) / DEOK (11.61%) / Dominion (51.27%) / EKPC (5.30%) / PEPCO (15.46%)</p>
b3021	Rebuild 500 kV Line #581 Ladysmith to Chancellor – 15.2 miles long	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>  Dominion (100%)</p>
b3026	Reconductor Line #274 (Pleasant View – Ashburn – Beaumeade 230 kV) with a minimum rating of 1200 MVA. Also upgrade terminal equipment	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3027.1	Add a 2nd 500/230 kV 840 MVA transformer at Dominion's Ladysmith substation	Dominion (100%)
b3027.2	Reconductor 230 kV Line #2089 between Ladysmith and Ladysmith CT substations to increase the line rating from 1047 MVA to 1225 MVA	Dominion (100%)
b3027.3	Replace the Ladysmith 500 kV breaker "H1T581" with 50kA breaker	Dominion (100%)
b3027.4	Update the nameplate for Ladysmith 500 kV breaker "H1T575" to be 50kA breaker	Dominion (100%)
b3027.5	Update the nameplate for Ladysmith 500 kV breaker "568T574" (will be renumbered as "H2T568") to be 50kA breaker	Dominion (100%)
b3055	Install spare 230/69 kV transformer at Davis substation	Dominion (100%)
b3056	Partial rebuild 230 kV Line #2113 Waller to Lightfoot	Dominion (100%)
b3057	Rebuild 230 kV Lines #2154 and #19 Waller to Skiffes Creek	Dominion (100%)
b3058	Partial rebuild of 230 kV Lines #265, #200 and #2051	Dominion (100%)
b3059	Rebuild 230 kV Line #2173 Loudoun to Elklick	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3060	Rebuild 4.6 mile Elklick – Bull Run 230 kV Line #295 and the portion (3.85 miles) of the Clifton – Walney 230 kV Line #265 which shares structures with Line #295	Dominion (100%)
b3088	Rebuild 4.75 mile section of Line #26 between Lexington and Rockbridge with a minimum summer emergency rating of 261 MVA	Dominion (100%)
b3089	Rebuild 230 kV Line #224 between Lanexa and Northern Neck utilizing double circuit structures to current 230 kV standards. Only one circuit is to be installed on the structures with this project with a minimum summer emergency rating of 1047 MVA	Dominion (100%)
b3090	Convert the overhead portion (approx. 1500 feet) of 230 kV Lines #248 & #2023 to underground and convert Glebe substation to gas insulated substation	Dominion (100%)
b3096	Rebuild 230 kV line No.2063 (Clifton – Ox) and part of 230 kV line No.2164 (Clifton – Keene Mill) with double circuit steel structures using double circuit conductor at current 230 kV northern Virginia standards with a minimum rating of 1200 MVA	Dominion (100%)
b3097	Rebuild 4 miles of 115 kV Line #86 between Chesterfield and Centralia to current standards with a minimum summer emergency rating of 393 MVA	Dominion (100%)
b3098	Rebuild 9.8 miles of 115 kV Line #141 between Balcony Falls and Skimmer and 3.8 miles of 115 kV Line #28 between Balcony Falls and Cushaw to current standards with a minimum rating of 261 MVA	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3098.1	Rebuild Balcony Falls 115 kV substation	Dominion (100%)
b3110.1	Rebuild Line #2008 between Loudoun to Dulles Junction using single circuit conductor at current 230 kV northern Virginia standards with minimum summer ratings of 1200 MVA. Cut and loop Line #265 (Clifton – Sully) into Bull Run substation. Add three (3) 230 kV breakers at Bull Run to accommodate the new line and upgrade the substation	Dominion (100%)
b3110.2	Replace the Bull Run 230 kV breakers “200T244” and “200T295” with 50 kA breakers	Dominion (100%)
b3110.3	Replace the Clifton 230 kV breakers “201182” and “XT2011” with 63 kA breakers	Dominion (100%)
b3113	Rebuild approximately 1 mile of 115 kV Lines #72 and #53 to current standards with a minimum summer emergency rating of 393 MVA. The resulting summer emergency rating of Line #72 segment from Brown Boveri to Bellwood is 180 MVA. There is no change to Line #53 ratings	Dominion (100%)
b3114	Rebuild the 18.6 mile section of 115 kV Line #81 which includes 1.7 miles of double circuit Line #81 and 230 kV Line #2056. This segment of Line #81 will be rebuilt to current standards with a minimum rating of 261 MVA. Line #2056 rating will not change	Dominion (100%)
b3121	Rebuild Clubhouse – Lakeview 230 kV Line #254 with single-circuit wood pole equivalent structures at the current 230 kV standard with a minimum rating of 1047 MVA	Dominion (100%)



**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3122	Rebuild Hathaway – Rocky Mount (Duke Energy Progress) 230 kV Line #2181 and Line #2058 with double circuit steel structures using double circuit conductor at current 230 kV standards with a minimum rating of 1047 MVA	Dominion (100%)
b3161.1	Split Chesterfield-Plaza 115 kV Line No. 72 by rebuilding the Brown Boveri tap line as double circuit loop in-and-out of the Brown Boveri Breaker station	Dominion (100%)
b3161.2	Install a 115 kV breaker at the Brown Boveri Breaker station. Site expansion is required to accommodate the new layout	Dominion (100%)
b3162	Acquire land and build a new 230 kV switching station (Stevensburg) with a 224 MVA, 230/115 kV transformer. Gordonsville-Remington 230 kV Line No. 2199 will be cut and connected to the new station. Remington-Mt. Run 115 kV Line No.70 and Mt. Run-Oak Green 115 kV Line No. 2 will also be cut and connected to the new station	Dominion (100%)
b3211	Rebuild the 1.3 mile section of 500 kV Line No. 569 (Loudoun – Morrisville) with single-circuit 500 kV structures at the current 500 kV standard. This will increase the rating of the line to 3424 MVA	Dominion (100%)
b3213	Install 2nd Chickahominy 500/230 kV transformer	Dominion (100%)

**Virginia Electric and Power Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3223.1	Install a second 230 kV circuit with a minimum summer emergency rating of 1047 MVA between Lanexa and Northern Next substations. The second circuit will utilize the vacant arms on the double-circuit structures that are being installed on Line #224 (Lanexa – Northern Next) as part of the End-of-Life rebuild project (b3089)	Dominion (100%)
b3223.2	Expand the Northern Neck terminal from a 230 kV, 4-breaker ring bus to a 6-breaker ring bus	Dominion (100%)
b3223.3	Expand the Lanexa terminal from a 6-breaker ring bus to a breaker-and-a-half arrangement	Dominion (100%)
b3247	Replace 13 towers with galvanized steel towers on Doubs – Goose Creek 500 kV. Reconductor 3 mile section with three (3) 1351.5 ACSR 45/7. Upgrade line terminal equipment at Goose Creek substation to support the 500 kV line rebuild	<p><b>Load-Ratio Share Allocation:</b>                      AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p><b>DFAX Allocation:</b>                      Dominion (100%)</p>