



PJM Interconnection
2750 Monroe Boulevard
Audubon, PA 19403-2497

Steven R. Pincus
Associate General Counsel
610.666.4370 | fax 610.666.8211
steven.pincus@pjm.com

February 25, 2021

Honorable Kimberly D. Bose
Secretary
Federal Energy Regulatory Commission
888 First Street, N.E., Room 1A
Washington, D.C. 20426

Re: *PJM Interconnection, L.L.C., Docket No. ER21-1207-000 (OATT)*
PJM Interconnection, L.L.C., Docket No. ER21-1208-000 (CTOA)
Revisions to PJM Open Access Transmission Tariff and
Consolidated Transmission Owners Agreement
for American Electric Power Service Corporation on behalf of its PJM Member
affiliates

Dear Secretary Bose:

Pursuant to the Federal Power Act, Section 205¹ and the Commission's Regulations,² PJM Interconnection, L.L.C. ("PJM") submits for filing proposed revisions to the PJM Open Access Transmission Tariff ("Tariff") and the Consolidated Transmissions Owners Agreement ("CTOA"), Rate Schedule No. 42,³ on behalf of American Electric Power Service Corporation ("AEP") for its affiliate companies to reflect corrections that were inadvertently omitted from the Tariff and the CTOA.⁴ Specifically, PJM, files to amend the Tariff and CTOA to correct

¹ 16 U.S.C. § 824d.

² 18 C.F.R. Part 35.

³ Capitalized terms not otherwise defined herein have the meaning specified in, as applicable, the Tariff and the CTOA.

⁴ AEP acts for its AEP Affiliates who are PJM Members and signatories of the CTOA and the Reliability Assurance Agreement among Load-Serving Entities in the PJM Region.

references to AEP and its Affiliate companies.⁵

PJM requests an effective date of April 27, 2021, for the attached revised CTOA and Tariff sections.

I. BACKGROUND

On October 14, 2015, PJM submitted revisions to the PJM Tariff and CTOA on behalf of AEP to accurately reflect AEP's affiliate companies in Docket Nos. ER16-73-000 (the "ER16-73 AEP Tariff Filing") and ER16-74-000 (the "ER16-74 AEP CTOA Filing"). The Commission issued letter orders accepting the ER16-73 AEP Tariff Filing and ER16-14 AEP CTOA Filing on November 19, 2015 and November 30, 2015, respectively.

The ER16-74 AEP CTOA Filing proposed revisions to (i) PJM Tariff, Schedule 12-Appendix – 17 and Schedule 12-Appendix A – 17 and (ii) the CTOA- Attachment A and the AEP signature page, to update the references to AEP to accurately reflect its affiliate companies, as follows: "American Electric Power Service Corporation on behalf of its ~~operating~~-affiliate companies: AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, ~~Columbus-Southern-Power-Company~~, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company." These changes were not implemented by PJM due to an administrative oversight.

However, there were errors in the ER16-73 AEP Tariff Filing and ER16-14 AEP CTOA Filing. More specifically, the ER16-73 AEP Tariff Filing and the ER16-74 AEP CTOA Filing

⁵ Due to eTariff restrictions the proposed revisions to the PJM Tariff and CTOA will be filed under separate cover using the same transmittal letter with specified attachments corresponding to each filing.

did not (i) include corresponding changes to PJM Tariff Attachment L; and (ii) use the full legal name for AEP and its Affiliates in the Tariff and the CTOA.

II. DESCRIPTION OF PROPOSED TARIFF AND CTOA REVISIONS

In order to correct these inaccuracies, PJM proposes to revise (i) Tariff, Attachment L; (ii) Tariff, Schedule 12-Appendix – 17; (iii) Tariff, Schedule 12-Appendix A – 17; (iv) CTOA, Attachment A; and (v) the CTOA, AEP signature page as follows:

A. Tariff, Attachment L Revision

~~AEP East Operating Companies~~ American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; ~~Appalachian Power Company;~~ ~~Columbus Southern Power Company;~~ Indiana Michigan Power Company; ~~Kentucky Power Company;~~ Kingsport Power Company; Ohio Power Company and Wheeling Power Company

B. Tariff, Schedule 12-Appendix – 17 Revisions

~~American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company~~
~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~

C. Tariff, Schedule 12- Appendix A – 17 Revisions

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~

D. CTOA, Attachment A Revisions

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company_; Indiana Michigan Power Company_; Kentucky Power Company_; Kingsport Power Company_; Ohio Power Company and Wheeling Power Company

E. CTOA - AEP Signature Block Revision

IN WITNESS WHEREOF, the Parties and PJM have caused this Agreement to be executed by their duly authorized representatives.

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company_; Indiana Michigan Power Company_; Kentucky Power Company_; Kingsport Power Company_; Ohio Power Company and Wheeling Power Company

By: _____
Name: Lisa M. Barton
Title: Executive Vice President - AEP Transmission
Date: October 13, 2015

III. EFFECTIVE DATE

PJM requests an effective date of April 27, 2021, for the attached PJM Tariff and CTOA sections, which at least 60 days after the filing date.

IV. DOCUMENTS ENCLOSED

Along with this transmittal letter, PJM submits the following attachments:

1. Attachment A – Marked Tariff – Redline revisions to Tariff, Schedule 12-Appendix – 17, Tariff, Schedule 12-Appendix A – 17 and Tariff, Attachment L; and
2. Attachment B – Clean Tariff – Clean format of Tariff, Schedule 12-Appendix – 17, Tariff, Schedule 12-Appendix A – 17 and Tariff, Attachment L.

V. CORRESPONDENCE AND COMMUNICATIONS

Steven R. Pincus
Associate General Counsel
PJM Interconnection, L.L.C.
2750 Monroe Boulevard
Audubon, PA 19403
(610) 666-4370
steven.pincus@pjm.com

Craig Glazer
Vice President, Federal Government Policy
PJM Interconnection, L.L.C.
1200 G Street, N.W, Suite 600
Washington, D.C. 20005
(202) 423-4743
craig.glazer@pjm.com

VI. SERVICE

PJM has served a copy of this filing on all PJM Members and on all state utility regulatory commissions in the PJM Region by posting this filing electronically. In accordance with the Commission's regulations,⁶ PJM will post a copy of this filing to the FERC filings section of its internet site, located at the following link: <http://www.pjm.com/documents/ferc-manuals/ferc-filings.aspx> with a specific link to the newly-filed document, and will send an e-mail on the same date as this filing to all PJM Members and all state utility regulatory

⁶ See 18C.F.R §§ 35.2(e) and 385.2010(f)(3).

commissions in the PJM Region⁷ alerting them this filing has been made by PJM and is available by following such link. If the document is not immediately available by using the referenced link, the document will be available through the referenced link within 24 hours of the filing. Also, a copy of this filing will be available on the FERC's eLibrary website located at the following link: <http://www.ferc.gov/docs-filing/elibrary.asp> in accordance with the Commission's regulations and Order No. 714.

Respectfully submitted,

/s/ Steven R. Pincus

Steven R. Pincus
Associate General Counsel
PJM Interconnection, L.L.C.
2750 Monroe Boulevard
Audubon, PA 19403
(610) 666-4370
steven.pincus@pjm.com

cc via email:

American Electric Power
Stacey L. Burbure
Senior Counsel
slburbure@aep.com

⁷ PJM already maintains, updates and regularly uses e-mail lists for all PJM Members and affected state commissions.

Attachment A

Revisions to the PJM Open Access Transmission Tariff

(Marked / Redline Format)

SCHEDULE 12 – APPENDIX

(17) American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b0318	Install a 765/138 kV transformer at Amos		AEP (99.00%) / PEPCO (1.00%)
b0324	Replace entrance conductors, wave traps, and risers at the Tidd 345 kV station on the Tidd – Canton Central 345 kV circuit		AEP (100%)
b0447	Replace Cook 345 kV breaker M2		AEP (100%)
b0448	Replace Cook 345 kV breaker N2		AEP (100%)
b0490	Construct an Amos – Bedington 765 kV circuit (AEP equipment)	As specified under the procedures detailed in Attachment H-19B	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
			DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) /

				PPL (6.39%) / PSEG (15.86%) / RE (0.59%)
*	Neptune	Regional	Transmission	System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.2	Replace Amos 138 kV breaker 'B'	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)</p>

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.3	Replace Amos 138 kV breaker 'B1'	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.4	Replace Amos 138 kV breaker 'C'	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.5	Replace Amos 138 kV breaker 'C1'	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)</p>

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.6	Replace Amos 138 kV breaker 'D'	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)</p>

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.7	Replace Amos 138 kV breaker 'D2'	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.8	Replace Amos 138 kV breaker 'E'	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.9	Replace Amos 138 kV breaker 'E2'	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)</p>

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0504	Add two advanced technology circuit breakers at Hanging Rock 765 kV to improve operational performance	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b0570	Reconductor East Side Lima – Sterling 138 kV	AEP (41.99%) / ComEd (58.01%)
b0571	Reconductor West Millersport – Millersport 138 kV	AEP (73.83%) / ComEd (19.26%) / Dayton (6.91%)
b0748	Establish a new 69 kV circuit between the Canal Road and East Wooster stations, establish a new 69 kV circuit between the West Millersburg and Moreland Switch stations (via Shreve), add reactive support via cap banks	AEP (100%)
b0838	Hazard Area 138 kV and 69 kV Improvement Projects	AEP (100%)
b0839	Replace existing 450 MVA transformer at Twin Branch 345 / 138 kV with a 675	AEP (99.73%) / Dayton (0.27%)

	MVA transformer		
*	Neptune	Regional	Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0840	String a second 138 kV circuit on the open tower position between Twin Branch and East Elkhart	AEP (100%)
b0840.1	Establish a new 138/69-34.5kV Station to interconnect the existing 34.5kV network	AEP (100%)
b0917	Replace Baileysville 138 kV breaker 'P'	AEP (100%)
b0918	Replace Riverview 138 kV breaker '634'	AEP (100%)
b0919	Replace Torrey 138 kV breaker 'W'	AEP (100%)
b1032.1	Construct a new 345/138kV station on the Marquis-Bixby 345kV line near the intersection with Ross - Highland 69kV	AEP (89.97%) / Dayton (10.03%)
b1032.2	Construct two 138kV outlets to Delano 138kV station and to Camp Sherman station	AEP (89.97%) / Dayton (10.03%)
b1032.3	Convert Ross - Circleville 69kV to 138kV	AEP (89.97%) / Dayton (10.03%)
b1032.4	Install 138/69kV transformer at new station and connect in the Ross - Highland 69kV line	AEP (89.97%) / Dayton (10.03%)
b1033	Add a third delivery point from AEP's East Danville Station to the City of Danville.	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1034.1	Establish new South Canton - West Canton 138kV line (replacing Torrey - West Canton) and Wagenhals - Wayview 138kV	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1034.2	Loop the existing South Canton - Wayview 138kV circuit in-and-out of West Canton	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1034.3	Install a 345/138kV 450 MVA transformer at Canton Central	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1034.4	Rebuild/reconductor the Sunnyside - Torrey 138kV line	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1034.5	Disconnect/eliminate the West Canton 138kV terminal at Torrey Station	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1034.6	Replace all 138kV circuit breakers at South Canton Station and operate the station in a breaker and a half configuration	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1034.7	Replace all obsolete 138kV circuit breakers at the Torrey and Wagenhals stations	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1034.8	Install additional 138kV circuit breakers at the West Canton, South Canton, Canton Central, and Wagenhals stations to accommodate the new circuits	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1035	Establish a third 345kV breaker string in the West Millersport Station. Construct a new West Millersport – Gahanna 138kV circuit. Miscellaneous improvements to 138kV transmission system.	AEP (100%)
b1036	Upgrade terminal equipment at Poston Station and update remote end relays	AEP (100%)
b1037	Sag check Bonsack–Cloverdale 138 kV, Cloverdale–Centerville 138kV, Centerville–Ivy Hill 138kV, Ivy Hill–Reusens 138kV, Bonsack–Reusens 138kV and Reusens–Monel–Gomingo–Joshua Falls 138 kV.	AEP (100%)
b1038	Check the Crooksville - Muskingum 138 kV sag and perform the required	AEP (100%)

	work to improve the emergency rating		
--	---	--	--

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1039	Perform a sag study for the Madison – Cross Street 138 kV line and perform the required work to improve the emergency rating	AEP (100%)
b1040	Rebuild an 0.065 mile section of the New Carlisle – Olive 138 kV line and change the 138 kV line switches at New Carlisle	AEP (100%)
b1041	Perform a sag study for the Moseley - Roanoke 138 kV to increase the emergency rating	AEP (100%)
b1042	Perform sag studies to raise the emergency rating of Amos – Poca 138kV	AEP (100%)
b1043	Perform sag studies to raise the emergency rating of Turner - Ruth 138kV	AEP (100%)
b1044	Perform sag studies to raise the emergency rating of Kenova – South Point 138kV	AEP (100%)
b1045	Perform sag studies of Tri State - Darrah 138 kV	AEP (100%)
b1046	Perform sag study of Scottsville – Bremo 138kV to raise the emergency rating	AEP (100%)
b1047	Perform sag study of Otter Switch - Altavista 138kV to raise the emergency	AEP (100%)

	rating		
--	--------	--	--

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1048	Reconductor the Bixby - Three C - Groves and Bixby - Groves 138 kV tower line	AEP (100%)
b1049	Upgrade the risers at the Riverside station to increase the rating of Benton Harbor – Riverside 138kV	AEP (100%)
b1050	Rebuilding and reconductor the Bixby – Pickerington Road - West Lancaster 138 kV line	AEP (100%)
b1051	Perform a sag study for the Kenzie Creek – Pokagon 138 kV line and perform the required work to improve the emergency rating	AEP (100%)
b1052	Unsix-wire the existing Hyatt - Sawmill 138 kV line to form two Hyatt - Sawmill 138 kV circuits	AEP (100%)
b1053	Perform a sag study and remediation of 32 miles between Claytor and Matt Funk.	AEP (100%)
b1091	Add 28.8 MVAR 138 kV capacitor bank at Huffman and 43.2 MVAR 138 kV Bank at Jubal Early and 52.8 MVAR 138 kV Bank at Progress Park Stations	AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1092	Add 28.8 MVAR 138 kV capacitor bank at Sullivan Gardens and 52.8 MVAR 138 kV Bank at Reedy Creek Stations	AEP (100%)
b1093	Add a 43.2 MVAR capacitor bank at the Morgan Fork 138 kV Station	AEP (100%)
b1094	Add a 64.8 MVAR capacitor bank at the West Huntington 138 kV Station	AEP (100%)
b1108	Replace Ohio Central 138 kV breaker 'C2'	AEP (100%)
b1109	Replace Ohio Central 138 kV breaker 'D1'	AEP (100%)
b1110	Replace Sporn A 138 kV breaker 'J'	AEP (100%)
b1111	Replace Sporn A 138 kV breaker 'J2'	AEP (100%)
b1112	Replace Sporn A 138 kV breaker 'L'	AEP (100%)
b1113	Replace Sporn A 138 kV breaker 'L1'	AEP (100%)
b1114	Replace Sporn A 138 kV breaker 'L2'	AEP (100%)
b1115	Replace Sporn A 138 kV breaker 'N'	AEP (100%)
b1116	Replace Sporn A 138 kV breaker 'N2'	AEP (100%)
b1227	Perform a sag study on Altavista – Leesville 138	AEP (100%)

	kV circuit		
--	------------	--	--

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1231	Replace the existing 138/69-12 kV transformer at West Moulton Station with a 138/69 kV transformer and a 69/12 kV transformer	AEP (96.69%) / Dayton (3.31%)
b1375	Replace Roanoke 138 kV breaker 'T'	AEP (100%)
b1376	Replace Roanoke 138 kV breaker 'E'	AEP (100%)
b1377	Replace Roanoke 138 kV breaker 'F'	AEP (100%)
b1378	Replace Roanoke 138 kV breaker 'G'	AEP (100%)
b1379	Replace Roanoke 138 kV breaker 'B'	AEP (100%)
b1380	Replace Roanoke 138 kV breaker 'A'	AEP (100%)
b1381	Replace Olive 345 kV breaker 'E'	AEP (100%)
b1382	Replace Olive 345 kV breaker 'R2'	AEP (100%)
b1416	Perform a sag study on the Desoto – Deer Creek 138 kV line to increase the emergency rating	AEP (100%)
b1417	Perform a sag study on the Delaware – Madison 138 kV line to increase the emergency rating	AEP (100%)
b1418	Perform a sag study on the Rockhill – East Lima 138 kV line to increase the emergency rating	AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1419	Perform a sag study on the Findlay Center – Fostoria Ctl 138 kV line to increase the emergency rating	AEP (100%)
b1420	A sag study will be required to increase the emergency rating for this line. Depending on the outcome of this study, more action may be required in order to increase the rating	AEP (100%)
b1421	Perform a sag study on the Sorenson – McKinley 138 kV line to increase the emergency rating	AEP (100%)
b1422	Perform a sag study on John Amos – St. Albans 138 kV line to allow for operation up to its conductor emergency rating	AEP (100%)
b1423	A sag study will be performed on the Chemical – Capitol Hill 138 kV line to determine if the emergency rating can be utilized	AEP (100%)
b1424	Perform a sag study for Benton Harbor – West Street – Hartford 138 kV line to improve the emergency rating	AEP (100%)
b1425	Perform a sag study for the East Monument – East Danville 138 kV line to allow for operation up to the conductor's maximum	AEP (100%)

	operating temperature		
--	-----------------------	--	--

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1426	Perform a sag study for the Reusens – Graves 138 kV line to allow for operation up to the conductor’s maximum operating temperature	AEP (100%)
b1427	Perform a sag study on Smith Mountain – Leesville – Altavista – Otter 138 kV and on Boones – Forest – New London – JohnsMT – Otter	AEP (100%)
b1428	Perform a sag study on Smith Mountain – Candler’s Mountain 138 kV and Joshua Falls – Cloverdale 765 kV to allow for operation up to	AEP (100%)
b1429	Perform a sag study on Fremont – Clinch River 138 kV to allow for operation up to its conductor emergency ratings	AEP (100%)
b1430	Install a new 138 kV circuit breaker at Benton Harbor station and move the load from Watervliet 34.5 kV station to West street 138 kV	AEP (100%)
b1432	Perform a sag study on the Kenova – Tri State 138 kV line to allow for operation up to their conductor emergency rating	AEP (100%)
b1433	Replace risers in the West Huntington Station to increase the line ratings	AEP (100%)

	which would eliminate the overloads for the contingencies listed		
--	--	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1434 Perform a sag study on the line from Desoto to Madison. Replace bus and risers at Daleville station and replace bus and risers at Madison		AEP (100%)
b1435 Replace the 2870 MCM ACSR riser at the Sporn station		AEP (100%)
b1436 Perform a sag study on the Sorenson – Illinois Road 138 kV line to increase the emergency MOT for this line. Replace bus and risers at Illinois Road		AEP (100%)
b1437 Perform sag study on Rock Cr. – Hummel Cr. 138 kV to increase the emergency MOT for the line, replace bus and risers at Huntington J., and replace relays for Hummel Cr. – Hunt – Soren. Line at Soren		AEP (100%)
b1438 Replacement of risers at McKinley and Industrial Park stations and performance of a sag study for the 4.53 miles of 795 ACSR section is expected to improve the Summer Emergency rating to 335 MVA		AEP (100%)
b1439 By replacing the risers at Lincoln both the Summer Normal and Summer		AEP (100%)

	Emergency ratings will improve to 268 MVA		
--	--	--	--

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1440	By replacing the breakers at Lincoln the Summer Emergency rating will improve to 251 MVA	AEP (100%)
b1441	Replacement of risers at South Side and performance of a sag study for the 1.91 miles of 795 ACSR section is expected to improve the Summer Emergency rating to 335 MVA	AEP (100%)
b1442	Replacement of 954 ACSR conductor with 1033 ACSR and performance of a sag study for the 4.54 miles of 2-636 ACSR section is expected	AEP (100%)
b1443	Station work at Thelma and Busseyville Stations will be performed to replace bus and risers	AEP (100%)
b1444	Perform electrical clearance studies on Clinch River – Clinchfield 139 kV line (a.k.a. sag studies) to determine if the emergency ratings can be utilized	AEP (100%)
b1445	Perform a sag study on the Addison (Buckeye CO-OP) – Thinever and North Crown City – Thivener 138 kV sag study and switch	AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1446	Perform a sag study on the Parkersburg (Allegheny Power) – Belpre (AEP) 138 kV	AEP (100%)
b1447	Dexter – Elliot tap 138 kV sag check	AEP (100%)
b1448	Dexter – Meigs 138 kV Electrical Clearance Study	AEP (100%)
b1449	Meigs tap – Rutland 138 kV sag check	AEP (100%)
b1450	Muskingum – North Muskingum 138 kV sag check	AEP (100%)
b1451	North Newark – Sharp Road 138 kV sag check	AEP (100%)
b1452	North Zanesville – Zanesville 138 kV sag check	AEP (100%)
b1453	North Zanesville – Powelson and Ohio Central – Powelson 138 kV sag check	AEP (100%)
b1454	Perform an electrical clearance study on the Ross – Delano – Scioto Trail 138 kV line to determine if the emergency rating can be utilized	AEP (100%)
b1455	Perform a sag check on the Sunny – Canton Central – Wagenhals 138 kV line to determine if all circuits can be operated at their summer emergency rating	AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1456 The Tidd – West Bellaire 345 kV circuit has been de-rated to its normal rating and would need an electrical clearance study to determine if the emergency rating can be utilized		AEP (100%)
b1457 The Tiltonsville – Windsor 138 kV circuit has been derated to its normal rating and would need an electrical clearance study to determine if the emergency rating could be utilized		AEP (100%)
b1458 Install three new 345 kV breakers at Bixby to separate the Marquis 345 kV line and transformer #2. Operate Circleville – Harrison 138 kV and Harrison – Zuber 138 kV up to conductor emergency ratings		AEP (100%)
b1459 Several circuits have been de-rated to their normal conductor ratings and could benefit from electrical clearance studies to determine if the emergency rating could be utilized		AEP (100%)
b1460 Replace 2156 & 2874 risers		AEP (100%)
b1461 Replace meter, metering CTs and associated equipment at the Paden City feeder		AEP (100%)

b1462	Replace relays at both South Cadiz 138 kV and Tidd 138 kV		AEP (100%)
-------	---	--	------------

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1463	Reconductor the Bexley – Groves 138 kV circuit	AEP (100%)
b1464	Corner 138 kV upgrades	AEP (100%)
b1465.1	Add a 3rd 2250 MVA 765/345 kV transformer at Sullivan station	AEC (0.71%) / AEP (75.06%) / APS (1.25%) / BGE (1.81%) / ComEd (5.91%) / Dayton (0.86%) / DL (1.23%) / DPL (0.95%) / Dominion (3.89%) / JCPL (1.58%) / NEPTUNE (0.15%) / HTP (0.07%) / PECO (2.08%) / PEPCO (1.66%) / ECP (0.07%)** / PSEG (2.62%) / RE (0.10%)
b1465.2	Replace the 100 MVAR 765 kV shunt reactor bank on Rockport – Jefferson 765 kV line with a 300 MVAR bank at Rockport Station	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEP (100%)

*Neptune Regional Transmission System, LLC

**East Coast Power, L.L.C.

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b1465.3	Transpose the Rockport – Sullivan 765 kV line and the Rockport – Jefferson 765 kV line		<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b1465.4	Make switching improvements at Sullivan and Jefferson 765 kV stations		<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b1466.1	Create an in and out loop at Adams Station by removing the hard tap that currently exists		AEP (100%)

b1466.2	Upgrade the Adams transformer to 90 MVA		AEP (100%)
---------	--	--	------------

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1466.3	At Seaman Station install a new 138 kV bus and two new 138 kV circuit breakers	AEP (100%)
b1466.4	Convert South Central Co-op's New Market 69 kV Station to 138 kV	AEP (100%)
b1466.5	The Seaman – Highland circuit is already built to 138 kV, but is currently operating at 69 kV, which would now increase to 138 kV	AEP (100%)
b1466.6	At Highland Station, install a new 138 kV bus, three new 138 kV circuit breakers and a new 138/69 kV 90 MVA transformer	AEP (100%)
b1466.7	Using one of the bays at Highland, build a 138 kV circuit from Hillsboro – Highland 138 kV, which is approximately 3 miles	AEP (100%)
b1467.1	Install a 14.4 MVar Capacitor Bank at New Buffalo station	AEP (100%)
b1467.2	Reconfigure the 138 kV bus at LaPorte Junction station to eliminate a contingency resulting in loss of two 138 kV sources serving the LaPorte area	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1468.1	Expand Selma Parker Station and install a 138/69/34.5 kV transformer	AEP (100%)
b1468.2	Rebuild and convert 34.5 kV line to Winchester to 69 kV, including Farmland Station	AEP (100%)
b1468.3	Retire the 34.5 kV line from Haymond to Selma Wire	AEP (100%)
b1469.1	Conversion of the Newcomerstown – Cambridge 34.5 kV system to 69 kV operation	AEP (100%)
b1469.2	Expansion of the Derwent 69 kV Station (including reconfiguration of the 69 kV system)	AEP (100%)
b1469.3	Rebuild 11.8 miles of 69 kV line, and convert additional 34.5 kV stations to 69 kV operation	AEP (100%)
b1470.1	Build a new 138 kV double circuit off the Kanawha – Bailyville #2 138 kV circuit to Skin Fork Station	AEP (100%)
b1470.2	Install a new 138/46 kV transformer at Skin Fork	AEP (100%)
b1470.3	Replace 5 Moab's on the Kanawha – Baileysville line with breakers at the Sundial 138 kV station	AEP (100%)
b1471	Perform a sag study on the East Lima – For Lima – Rockhill 138 kV line to increase the emergency	AEP (100%)

	rating		
--	--------	--	--

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1472	Perform a sag study on the East Lima – Haviland 138 kV line to increase the emergency rating	AEP (100%)
b1473	Perform a sag study on the East New Concord – Muskingum River section of the Muskingum River – West Cambridge 138 kV circuit	AEP (100%)
b1474	Perform a sag study on the Ohio Central – Prep Plant tap 138 kV circuit	AEP (100%)
b1475	Perform a sag study on the S73 – North Delphos 138 kV line to increase the emergency rating	AEP (100%)
b1476	Perform a sag study on the S73 – T131 138 kV line to increase the emergency rating	AEP (100%)
b1477	The Natrium – North Martin 138 kV circuit would need an electrical clearance study among other equipment upgrades	AEP (100%)
b1478	Upgrade Strouds Run – Strouds Tap 138 kV relay and riser	AEP (100%)
b1479	West Hebron station upgrades	AEP (100%)
b1480	Perform upgrades and a sag study on the Corner – Layman 138 kV section of the Corner – Muskingum River 138 kV circuit	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1481	Perform a sag study on the West Lima – Eastown Road – Rockhill 138 kV line and replace the 138 kV risers at Rockhill station to increase the emergency rating	AEP (100%)
b1482	Perform a sag study for the Albion – Robison Park 138 kV line to increase its emergency rating	AEP (100%)
b1483	Sag study 1 mile of the Clinch River – Saltville 138 kV line and replace the risers and bus at Clinch River, Lebanon and Elk Garden Stations	AEP (100%)
b1484	Perform a sag study on the Hacienda – Harper 138 kV line to increase the emergency rating	AEP (100%)
b1485	Perform a sag study on the Jackson Road – Concord 183 kV line to increase the emergency rating	AEP (100%)
b1486	The Matt Funk – Poages Mill – Starkey 138 kV line requires	AEP (100%)
b1487	Perform a sag study on the New Carlisle – Trail Creek 138 kV line to increase the emergency rating	AEP (100%)
b1488	Perform a sag study on the Olive – LaPorte Junction 138 kV line to increase the	AEP (100%)

	emergency rating		
--	------------------	--	--

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1489	A sag study must be performed for the 5.40 mile Tristate – Chadwick 138 kV line to determine if a higher emergency rating can be used	AEP (100%)
b1490.1	Establish a new 138/69 kV Butler Center station	AEP (100%)
b1490.2	Build a new 14 mile 138 kV line from Auburn station to Woods Road station VIA Butler Center station	AEP (100%)
b1490.3	Replace the existing 40 MVA 138/69 kV transformer at Auburn station with a 90 MVA 138/96 kV transformer	AEP (100%)
b1490.4	Improve the switching arrangement at Kendallville station	AEP (100%)
b1491	Replace bus and risers at Thelma and Busseyville stations and perform a sag study for the Big Sandy – Busseyville 138 kV line	AEP (100%)
b1492	Reconductor 0.65 miles of the Glen Lyn – Wythe 138 kV line with 3 – 1590 ACSR	AEP (100%)
b1493	Perform a sag study for the Bellfonte – Grantston 138 kV line to increase its emergency rating	AEP (100%)
b1494	Perform a sag study for the North Proctorville – Solida – Bellefonte 138 kV line to increase its emergency rating	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1495	Add an additional 765/345 kV transformer at Baker Station	AEC (0.41%) / AEP (87.22%) / BGE (1.03%) / ComEd (3.38%) / Dayton (1.23%) / DL (1.46%) / DPL (0.54%) / JCPL (0.90%) / NEPTUNE (0.09%) / HTP (0.04%) / PECO (1.18%) / PEPCO (0.94%) / ECP** (0.04%) / PSEG (1.48%) / RE (0.06%)
b1496	Replace 138 kV bus and risers at Johnson Mountain Station	AEP (100%)
b1497	Replace 138 kV bus and risers at Leesville Station	AEP (100%)
b1498	Replace 138 kV risers at Wurno Station	AEP (100%)
b1499	Perform a sag study on Sporn A – Gavin 138 kV to determine if the emergency rating can be improved	AEP (100%)
b1500	The North East Canton – Wagenhals 138 kV circuit would need an electrical clearance study to determine if the emergency rating can be utilized	AEP (100%)
b1501	The Moseley – Reusens 138 kV circuit requires a sag study to determine if the emergency rating can be utilized to address a thermal loading issue for a category C3	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b1502	Reconductor the Conesville East – Conesville Prep Plant Tap 138 kV section of the Conesville – Ohio Central to fix Reliability N-1-1 thermal overloads		AEP (100%)
b1659	Establish Sorenson 345/138 kV station as a 765/345 kV station		AEP (93.61%) / ATSI (2.99%) / ComEd (2.07%) / HTP (0.03%) / PENELEC (0.31%) / ECP** (0.03%) / PSEG (0.92%) / RE (0.04%)
b1659.1	Replace Sorenson 138 kV breaker 'L1'		AEP (100%)
b1659.2	Replace Sorenson 138 kV breaker 'L2' breaker		AEP (100%)
b1659.3	Replace Sorenson 138 kV breaker 'M1'		AEP (100%)
b1659.4	Replace Sorenson 138 kV breaker 'M2'		AEP (100%)
b1659.5	Replace Sorenson 138 kV breaker 'N1'		AEP (100%)
b1659.6	Replace Sorenson 138 kV breaker 'N2'		AEP (100%)
b1659.7	Replace Sorenson 138 kV breaker 'O1'		AEP (100%)
b1659.8	Replace Sorenson 138 kV breaker 'O2'		AEP (100%)
b1659.9	Replace Sorenson 138 kV breaker 'M'		AEP (100%)
b1659.10	Replace Sorenson 138 kV breaker 'N'		AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1659.11	Replace Sorenson 138 kV breaker 'O'	AEP (100%)
b1659.12	Replace McKinley 138 kV breaker 'L1'	AEP (100%)
b1659.13	Establish 765 kV yard at Sorenson and install four 765 kV breakers	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (75.95%) / Dayton (7.52%) / DEOK (12.77%) / EKPC (3.76%)</p>
b1659.14	Build approximately 14 miles of 765 kV line from existing Dumont - Marysville line	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation:</p>

			AEP (71.06%) / ATSI (15.95%) / Dayton (7.10%) / DL (4.84%) / EKPC (0.77%) / OVEC (0.28%)
--	--	--	--

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1660	Install a 765/500 kV transformer at Cloverdale	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: Dayton (8.37%) / DEOK (21.94%) / Dominion (56.40%) / EKPC (13.29%)
b1661	Install a 765 kV circuit breaker at Wyoming station	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1662	Rebuild 4 miles of 46 kV line to 138 kV from Pemberton to Cherry Creek	AEP (100%)
b1662.1	Circuit Breakers are installed at Cherry Creek (facing Pemberton) and at Pemberton (facing Tams Mtn. and Cherry Creek)	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1662.2	Install three 138 kV breakers at Grandview Station (facing Cherry Creek, Hinton, and Bradley Stations)	AEP (100%)
b1662.3	Remove Sullivan Switching Station (46 kV)	AEP (100%)
b1663	Install a new 765/138 kV transformer at Jackson Ferry substation	AEP (100%)
b1663.1	Establish a new 10 mile double circuit 138 kV line between Jackson Ferry and Wythe	AEP (100%)
b1663.2	Install 2 765 kV circuit breakers, breaker disconnect switches and associated bus work for the new 765 kV breakers, and new relays for the 765 kV breakers at Jackson's Ferry	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEP (100%)
b1664	Install switched capacitor banks at Kenwood 138 kV stations	AEP (100%)
b1665	Install a second 138/69 kV transformer at Thelma station	AEP (100%)

b1665.1	Construct a single circuit 69 kV line from West Paintsville to the new Paintsville station		AEP (100%)
---------	--	--	------------

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1665.2	Install new 7.2 MVAR, 46 kV bank at Kenwood Station	AEP (100%)
b1666	Build an 8 breaker 138 kV station tapping both circuits of the Fostoria - East Lima 138 kV line	AEP (90.65%) / Dayton (9.35%)
b1667	Establish Melmore as a switching station with both 138 kV circuits terminating at Melmore. Extend the double circuit 138 kV line from Melmore to Fremont Center	AEP (100%)
b1668	Revise the capacitor setting at Riverside 138 kV station	AEP (100%)
b1669	Capacitor setting changes at Ross 138 kV stations	AEP (100%)
b1670	Capacitor setting changes at Wooster 138 kV station	AEP (100%)
b1671	Install four 138 kV breakers in Danville area	AEP (100%)
b1676	Replace Natrium 138 kV breaker 'G (rehab)'	AEP (100%)
b1677	Replace Huntley 138 kV breaker '106'	AEP (100%)
b1678	Replace Kammer 138 kV breaker 'G'	AEP (100%)
b1679	Replace Kammer 138 kV breaker 'H'	AEP (100%)
b1680	Replace Kammer 138 kV breaker 'J'	AEP (100%)
b1681	Replace Kammer 138 kV breaker 'K'	AEP (100%)

b1682	Replace Kammer 138 kV breaker 'M'		AEP (100%)
-------	-----------------------------------	--	------------

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ **(cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1683	Replace Kammer 138 kV breaker 'N'	AEP (100%)
b1684	Replace Clinch River 138 kV breaker 'E1'	AEP (100%)
b1685	Replace Lincoln 138 kV breaker 'D'	AEP (100%)
b1687	Advance s0251.7 (Replace Corrid 138 kV breaker '104S')	AEP (100%)
b1688	Advance s0251.8 (Replace Corrid 138 kV breaker '104C')	AEP (100%)
b1712.1	Perform sag study on Altavista - Leesville 138 kV line	Dominion (75.30%) / PEPCO (24.70%)
b1712.2	Rebuild the Altavista - Leesville 138 kV line	Dominion (75.30%) / PEPCO (24.70%)
b1733	Perform a sag study of the Bluff Point - Jauby 138 kV line. Upgrade breaker, wavetrap, and risers at the terminal ends	AEP (100%)
b1734	Perform a sag study of Randolph - Hodgins 138 kV line. Upgrade terminal equipment	AEP (100%)
b1735	Perform a sag study of R03 - Magely 138 kV line. Upgrade terminal equipment	AEP (100%)

b1736	Perform a sag study of the Industrial Park - Summit 138 kV line		AEP (100%)
b1737	Sag study of Newcomerstown - Hillview 138 kV line. Upgrade - terminal equipment		AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1738	Perform a sag study of the Wolf Creek - Layman 138 kV line. -Upgrade terminal equipment including a 138 kV breaker and wavetrap	AEP (100%)
b1739	Perform a sag study of the Ohio Central - West Trinway 138 kV line	AEP (100%)
b1741	Replace Beatty 138 kV breaker '2C(IPP)'	AEP (100%)
b1742	Replace Beatty 138 kV breaker '1E'	AEP (100%)
b1743	Replace Beatty 138 kV breaker '2E'	AEP (100%)
b1744	Replace Beatty 138 kV breaker '3C'	AEP (100%)
b1745	Replace Beatty 138 kV breaker '2W'	AEP (100%)
b1746	Replace St. Claire 138 kV breaker '8'	AEP (100%)
b1747	Replace Cloverdale 138 kV breaker 'C'	AEP (100%)
b1748	Replace Cloverdale 138 kV breaker 'D1'	AEP (100%)
b1780	Install two 138kV breakers and two 138kV circuit switchers at South Princeton Station and one 138kV breaker and one 138kV circuit switcher at Switchback Station	AEP (100%)
b1781	Install three 138 kV breakers and a 138kV circuit switcher	AEP (100%)

	at Trail Fork Station in Pineville, WV		
--	---	--	--

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1782	Install a 46kV Moab at Montgomery Station facing Carbondale (on the London - Carbondale 46 kV circuit)	AEP (100%)
b1783	Add two 138 kV Circuit Breakers and two 138 kV circuit switchers on the Lonesome Pine - South Bluefield 138 kV line	AEP (100%)
b1784	Install a 52.8 MVAR capacitor bank at the Clifford 138 kV station	AEP (100%)
b1811.1	Perform a sag study of 4 miles of the Waterford - Muskingum line	AEP (100%)
b1811.2	Rebuild 0.1 miles of Waterford - Muskingum 345 kV with 1590 ACSR	AEP (100%)
b1812	Reconductor the AEP portion of the South Canton - Harmon 345 kV with 954 ACSR and upgrade terminal equipment at South Canton. Expected rating is 1800 MVA S/N and 1800 MVA S/E	AEP (100%)
b1817	Install (3) 345 kV circuit breakers at East Elkhart station in ring bus designed as a breaker and half scheme	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1818	Expand the Allen station by installing a second 345/138 kV transformer and adding four 138 kV exits by cutting in the Lincoln - Sterling and Milan - Timber Switch 138 kV double circuit tower line	AEP (88.30%) / ATSI (8.86%) / Dayton (2.84%)
b1819	Rebuild the Robinson Park - Sorenson 138 kV line corridor as a 345 kV double circuit line with one side operated at 345 kV and one side at 138 kV	AEP (87.18%) / ATSI (10.06%) / Dayton (2.76%)
b1859	Perform a sag study for Hancock - Cave Spring - Roanoke 138 kV circuit to reach new SE ratings of 272MVA (Cave Spring-Hancock), 205MVA (Cave Spring-Sunscape), 245MVA (ROANO2-Sunscape)	AEP (100%)
b1860	Perform a sag study on the Crooksville - Spencer Ridge section (14.3 miles) of the Crooksville-Poston-Strouds Run 138 kV circuit to see if any remedial action needed to reach the SE rating (175MVA)	AEP (100%)
b1861	Reconductor 0.83 miles of the Dale - West Canton 138 kV Tie-line and upgrade risers at West Canton 138 kV	AEP (100%)
b1862	Perform a sag study on the Grant - Greentown 138 kV circuit and replace the relay CT at Grant 138 kV station to see if any	AEP (100%)

	remedial action needed to reach the new ratings of 251/286MVA		
--	--	--	--

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1863	Perform a sag study of the Kammer - Wayman SW 138 kV line to see if any remedial action needed to reach the new SE rating of 284MVA	AEP (100%)
b1864.1	Add two additional 345/138 kV transformers at Kammer	AEP (87.22%) / APS (8.22%) / ATSI (3.52%) / DL (1.04%)
b1864.2	Add second West Bellaire - Brues 138 kV circuit	AEP (87.22%) / APS (8.22%) / ATSI (3.52%) / DL (1.04%)
b1864.3	Replace Kammer 138 kV breaker 'E'	AEP (100%)
b1865	Perform a sag study on the Kanawha - Carbondale 138 kV line to see if any remedial action needed to reach the new ratings of 251/335MVA	AEP (100%)
b1866	Perform a sag study on the Clinch River-Lock Hart-Dorton 138kV line, increase the Relay Compliance Trip Limit at Clinch River on the C.R.-Dorton 138kV line to 310 and upgrade the risers with 1590ACSR	AEP (100%)
b1867	Perform a sag study on the Newcomerstown - South Coshocton 138 kV line to see if any remedial action is needed to reach the new SE rating of 179MVA	AEP (100%)
b1868	Perform sag study on the East Lima - new Liberty 138 kV line to see if any remedial	AEP (100%)

	action is needed to reach the new SE rating of 219MVA		
--	--	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1869	Perform a sag study of the Ohio Central - South Coshocton 138 kV circuit to see if any remedial action needed to reach the new SE ratings of 250MVA	AEP (100%)
b1870	Replace the Ohio Central transformer #1 345/138/12 kV 450 MVA for a 345/138/34.5 kV 675 MVA transformer	AEP (68.16%) / ATSI (25.27%) / Dayton (3.88%) / PENELEC (1.59%) / DEOK (1.10%)
b1871	Perform a sag study on the Central - West Coshocton 138 kV line (improving the emergency rating of this line to 254 MVA)	AEP (100%)
b1872	Add a 57.6 MVar capacitor bank at East Elkhart 138 kv station in Indiana	AEP (100%)
b1873	Install two 138 kV circuit breakers at Cedar Creek Station and primary side circuit switcher on the 138/69/46 kV transformer	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1874	Install two 138 kV circuit breakers and one 138 kV circuit switcher at Magely 138 kV station in Indiana	AEP (100%)
b1875	Build 25 miles of new 138 kV line from Bradley Station through Tower 117 Station and terminating at McClung 138 kV station. Existing 69 kV distribution transformers will be replaced with 138 kV transformers	APS (100%)
b1876	Install a 14.4 MVar capacitor bank at Capital Avenue (AKA Currant Road) 34.5 kV bus	AEP (100%)
b1877	Relocate 138 kV Breaker G to the West Kingsport - Industry Drive 138 kV line and Remove 138 kV MOAB	AEP (100%)
b1878	Perform a sag study on the Lincoln - Robinson Park 138 kV line (Improve the emergency rating to 244 MVA)	AEP (100%)
b1879	Perform a sag study on the Hansonville - Meadowview 138 kV line (Improve the emergency rating to 245 MVA)	AEP (100%)
b1880	Rebuild the 15 miles of the Moseley - Roanoke 138 kV line. This project would	AEP (100%)

	consist of rebuilding both circuits on the double circuit line		
--	--	--	--

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1881	Replace existing 600 Amp switches, station risers and increase the CT ratios associated with breaker 'G' at Sterling 138 kV Station. It will increase the rating to 296 MVA S/N and 384 MVA S/E	AEP (100%)
b1882	Perform a sag study on the Bluff Point - Randolph 138 kV line to see if any remedial action needed to reach the new SE rating of 255 MVA	AEP (100%)
b1883	Switch the breaker position of transformer #1 and SW Lima at East Lima 345 kV bus	AEP (100%)
b1884	Perform a sag study on Strawton station - Fisher Body - Deer Creek 138 kV line to see if any remedial action needed to reach the new SE rating of 250 MVA	AEP (100%)
b1887	Establish a new 138/69 kV source at Carrollton and construct two new 69 kV lines from Carrollton to tie into the Dennison - Miller SW 69 kV line and to East Dover 69 kV station respectively	AEP (100%)
b1888	Install a 69 kV line breaker at Blue Pennant 69 kV Station facing Bim Station and 14.4 MVA capacitor bank	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1889	Install a 43.2 MVAR capacitor bank at Hinton 138 kV station (APCO WV)	AEP (100%)
b1901	Rebuild the Ohio Central - West Trinway (4.84 miles) section of the Academia - Ohio Central 138 kV circuit. Upgrade the Ohio Central riser, Ohio Central switch and the West Trinway riser	AEP (100%)
b1904.1	Construct new 138/69 Michiana Station near Bridgman by tapping the new Carlisle - Main Street 138 kV and the Bridgman - Buchanan Hydro 69 kV line	AEP (100%)
b1904.2	Establish a new 138/12 kV New Galien station by tapping the Olive - Hickory Creek 138 kV line	AEP (100%)
b1904.3	Retire the existing Galien station and move its distribution load to New Galien station. Retire the Buchanan Hydro - New Carlisle 34.5 kV line	AEP (100%)
b1904.4	Implement an in and out scheme at Cook 69 kV by eliminating the Cook 69 kV tap point and by installing two new 69 kV circuit breakers	AEP (100%)
b1904.5	Rebuild the Bridgman - Cook 69 kV and the Derby - Cook 69 kV lines	AEP (100%)
b1946	Perform a sag study on the Brues - West Bellaire 138 kV line	AEP (100%)

b1947	A sag study of the Dequine - Meadowlake 345 kV line #1 line may improve the emergency rating to 1400 MVA		AEP (100%)
-------	--	--	------------

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1948	Establish a new 765/345 interconnection at Sporn. Install a 765/345 kV transformer at Mountaineer and build ¾ mile of 345 kV to Sporn	ATSI (61.08%) / DL (21.87%) / Dominion (13.97%) / PENELEC (3.08%)
b1949	Perform a sag study on the Grant Tap – Deer Creek 138 kV line and replace bus and risers at Deer Creek station	AEP (100%)
b1950	Perform a sag study on the Kammer – Ormet 138 kV line of the conductor section	AEP (100%)
b1951	Perform a sag study of the Maddox- Convoy 345 kV line to improve the emergency rating to 1400 MVA	AEP (100%)
b1952	Perform a sag study of the Maddox – T130 345 kV line to improve the emergency rating to 1400 MVA	AEP (100%)
b1953	Perform a sag study of the Meadowlake - Olive 345 kV line to improve the emergency rating to 1400 MVA	AEP (100%)
b1954	Perform a sag study on the Milan - Harper 138 kV line and replace bus and switches at Milan Switch station	AEP (100%)
b1955	Perform a sag study of the R-049 - Tillman 138 kV line may improve the emergency rating to 245 MVA	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1956	Perform a sag study of the Tillman - Dawkins 138 kV line may improve the emergency rating to 245 MVA	AEP (100%)
b1957	Terminate Transformer #2 at SW Lima in a new bay position	AEP (69.41%) / ATSI (23.11%) / ECP** (0.17%) / HTP (0.19%) / PENELEC (2.42%) / PSEG (4.52%) / RE (0.18%)
b1958	Perform a sag study on the Brookside - Howard 138 kV line and replace bus and risers at AEP Howard station	AEP (100%)
b1960	Sag Study on 7.2 miles SE Canton-Canton Central 138kV ckt	AEP (100%)
b1961	Sag study on the Southeast Canton – Sunnyside 138kV line	AEP (100%)

*Neptune Regional Transmission System, LLC

**East Coast Power, L.L.C.

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1962	Add four 765 kV breakers at Kammer	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b1963	Build approximately 1 mile of circuit comprising of 2-954 ACSR to get the rating of Waterford-Muskinum 345 kV higher	AEP (100%)
b1970	Reconductor 13 miles of the Kammer – West Bellaire 345kV circuit	APS (33.51%) / ATSI (32.21%) / DL (18.64%) / Dominion (6.01%) / ECP** (0.10%) / HTP (0.11%) / JCPL (1.68%) / Neptune* (0.18%) / PENELEC (4.58%) / PSEG (2.87%) / RE (0.11%)
b1971	Perform a sag study to improve the emergency rating on the Bridgville – Chandlersville 138 kV line	AEP (100%)
b1972	Replace disconnect switch on the South Canton 765/345 kV transformer	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1973	Perform a sag study to improve the emergency rating on the Carrollton – Sunnyside 138 kV line	AEP (100%)
b1974	Perform a sag study to improve the emergency rating on the Bethel Church – West Dover 138 kV line	AEP (100%)
b1975	Replace a switch at South Millersburg switch station	AEP (100%)
b2017	Reconductor or rebuild Sporn - Waterford - Muskingum River 345 kV line	ATSI (37.04%) / AEP (34.35%) / DL (10.41%) / Dominion (6.19%) / APS (3.94%) / PENELEC (3.09%) / JCPL (1.39%) / Dayton (1.20%) / Neptune* (0.14%) / HTP (0.09%) / ECP** (0.08%) / PSEG (2.00%) / RE (0.08%)
b2018	Loop Conesville - Bixby 345 kV circuit into Ohio Central	ATSI (58.58%) / AEP (14.16%) / APS (12.88%) / DL (7.93%) / PENELEC (5.73%) / Dayton (0.72%)
b2019	Establish Burger 345/138 kV station	AEP (93.74%) / APS (4.40%) / DL (1.11%) / ATSI (0.74%) / PENELEC (0.01%)
b2020	Rebuild Amos - Kanawah River 138 kV corridor	AEP (88.39%) / APS (7.12%) / ATSI (2.89%) / DEOK (1.58%) / PEPCO (0.02%)
b2021	Add 345/138 transformer at Sporn, Kanawah River & Muskingum River stations	AEP (91.92%) / DEOK (3.60%) / APS (2.19%) / ATSI (1.14%) / DL (1.08%) / PEPCO (0.04%) / BGE (0.03%)
b2021.1	Replace Kanawah 138 kV breaker 'L'	AEP (100%)

b2021.2	Replace Muskingum 138 kV breaker 'HG'		AEP (100%)
---------	--	--	------------

*Neptune Regional Transmission System, LLC

**East Coast Power, L.L.C.

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2021.3	Replace Muskingum 138 kV breaker 'HJ'		AEP (100%)
b2021.4	Replace Muskingum 138 kV breaker 'HE'		AEP (100%)
b2021.5	Replace Muskingum 138 kV breaker 'HD'		AEP (100%)
b2021.6	Replace Muskingum 138 kV breaker 'HF'		AEP (100%)
b2021.7	Replace Muskingum 138 kV breaker 'HC'		AEP (100%)
b2021.8	Replace Sporn 138 kV breaker 'D1'		AEP (100%)
b2021.9	Replace Sporn 138 kV breaker 'D2'		AEP (100%)
b2021.10	Replace Sporn 138 kV breaker 'F1'		AEP (100%)
b2021.11	Replace Sporn 138 kV breaker 'F2'		AEP (100%)
b2021.12	Replace Sporn 138 kV breaker 'G'		AEP (100%)
b2021.13	Replace Sporn 138 kV breaker 'G2'		AEP (100%)
b2021.14	Replace Sporn 138 kV breaker 'N1'		AEP (100%)
b2021.15	Replace Kanawah 138 kV breaker 'M'		AEP (100%)
b2022	Terminate Tristate - Kyger Creek 345 kV line at Sporn		AEP (97.99%) / DEOK (2.01%)
b2027	Perform a sag study of the Tidd - Collier 345 kV line		AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2028	Perform a sag study on East Lima - North Woodcock 138 kV line to improve the rating	AEP (100%)
b2029	Perform a sag study on Bluebell - Canton Central 138 kV line to improve the rating	AEP (100%)
b2030	Install 345 kV circuit breakers at West Bellaire	AEP (100%)
b2031	Sag study on Tilton - W. Bellaire section 1 (795 ACSR), about 12 miles	AEP (100%)
b2032	Rebuild 138 kV Elliot tap - Poston line	ATSI (73.02%) / Dayton (19.39%) / DL (7.59%)
b2033	Perform a sag study of the Brues - W. Bellaire 138 kV line	AEP (100%)
b2046	Adjust tap settings for Muskingum River transformers	AEP (100%)
b2047	Replace relay at Greenlawn	AEP (100%)
b2048	Replace both 345/138 kV transformers with one bigger transformer	AEP (92.49%) / Dayton (7.51%)
b2049	Replace relay	AEP (100%)
b2050	Perform sag study	AEP (100%)
b2051	Install 3 138 kV breakers and a circuit switcher at Dorton station	AEP (100%)
b2052	Replace transformer	AEP (67.17%) / ATSI (27.37%) / Dayton (3.73%) / PENELEC

			(1.73%)
b2054	Perform a sag study of Sporn - Rutland 138 kV line		AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2069	Replace George Washington 138 kV breaker 'A' with 63kA rated breaker	AEP (100%)
b2070	Replace Harrison 138 kV breaker '6C' with 63kA rated breaker	AEP (100%)
b2071	Replace Lincoln 138 kV breaker 'L' with 63kA rated breaker	AEP (100%)
b2072	Replace Natrum 138 kV breaker 'T' with 63kA rated breaker	AEP (100%)
b2073	Replace Darrah 138 kV breaker 'B' with 63kA rated breaker	AEP (100%)
b2074	Replace Wyoming 138 kV breaker 'G' with 80kA rated breaker	AEP (100%)
b2075	Replace Wyoming 138 kV breaker 'G1' with 80kA rated breaker	AEP (100%)
b2076	Replace Wyoming 138 kV breaker 'G2' with 80kA rated breaker	AEP (100%)
b2077	Replace Wyoming 138 kV breaker 'H' with 80kA rated breaker	AEP (100%)
b2078	Replace Wyoming 138 kV breaker 'H1' with 80kA rated breaker	AEP (100%)
b2079	Replace Wyoming 138 kV breaker 'H2' with 80kA rated breaker	AEP (100%)

b2080	Replace Wyoming 138 kV breaker 'J' with 80kA rated breaker		AEP (100%)
-------	--	--	------------

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2081	Replace Wyoming 138 kV breaker 'J1' with 80kA rated breaker		AEP (100%)
b2082	Replace Wyoming 138 kV breaker 'J2' with 80kA rated breaker		AEP (100%)
b2083	Replace Natrum 138 kV breaker 'K' with 63kA rated breaker		AEP (100%)
b2084	Replace Tanner Creek 345 kV breaker 'P' with 63kA rated breaker		AEP (100%)
b2085	Replace Tanner Creek 345 kV breaker 'P2' with 63kA rated breaker		AEP (100%)
b2086	Replace Tanner Creek 345 kV breaker 'Q1' with 63kA rated breaker		AEP (100%)
b2087	Replace South Bend 138 kV breaker 'T' with 63kA rated breaker		AEP (100%)
b2088	Replace Tidd 138 kV breaker 'L' with 63kA rated breaker		AEP (100%)
b2089	Replace Tidd 138 kV breaker 'M2' with 63kA rated breaker		AEP (100%)
b2090	Replace McKinley 138 kV breaker 'A' with 40kA rated breaker		AEP (100%)
b2091	Replace West Lima 138 kV breaker 'M' with 63kA rated breaker		AEP (100%)
b2092	Replace George Washington 138 kV breaker 'B' with 63kA		AEP (100%)

	rated breaker		
--	---------------	--	--

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2093	Replace Turner 138 kV breaker 'W' with 63kA rated breaker	AEP (100%)
b2135	Build a new 138 kV line from Falling Branch to Merrimac and add a 138/69 kV transformer at Merrimac Station	AEP (100%)
b2160	Add a fourth circuit breaker to the station being built for the U4-038 project (Conelley), rebuild U4-038 - Grant Tap line as double circuit tower line	AEP (100%)
b2161	Rebuild approximately 20 miles of the Allen - S073 double circuit 138 kV line (with one circuit from Allen - Tillman - Timber Switch - S073 and the other circuit from Allen - T-131 - S073) utilizing 1033 ACSR	AEP (100%)
b2162	Perform a sag study to improve the emergency rating of the Belpre - Degussa 138 kV line	AEP (100%)
b2163	Replace breaker and wavetrap at Jay 138 kV station	AEP (100%)

*Neptune Regional Transmission System, LLC

SCHEDULE 12 – APPENDIX A

(17) American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1570.4	Add a 345 kV breaker at Marysville station and a 0.1 mile 345 kV line extension from Marysville to the new 345/69 kV Dayton transformer	AEP (100%)
b1660.1	Cloverdale: install 6-765 kV breakers, incremental work for 2 additional breakers, reconfigure and relocate miscellaneous facilities, establish 500 kV station and 500 kV tie with 765 kV station	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: Dayton (8.37%) / DEOK (21.94%) / Dominion (56.40%) / EKPC (13.29%)</p>

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1797.1	Reconductor the AEP portion of the Cloverdale - Lexington 500 kV line with 2-1780 ACSS	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (0.79%) / APS (53.70%) / Dayton (0.15%) / DEOK (0.40%) / Dominion (1.13%) / EKPC (0.23%) / PEPCO (43.60%)</p>
b2055	Upgrade relay at Brues station	AEP (100%)
b2122.3	Upgrade terminal equipment at Howard on the Howard - Brookside 138 kV line to achieve ratings of 252/291 (SN/SE)	AEP (100%)
b2122.4	Perform a sag study on the Howard - Brookside 138 kV line	AEP (100%)
b2229	Install a 300 MVAR reactor at Dequine 345 kV	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2230	Replace existing 150 MVAR reactor at Amos 765 kV substation on Amos - N. Proctorville - Hanging Rock with 300 MVAR reactor	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b2231	Install 765 kV reactor breaker at Dumont 765 kV substation on the Dumont - Wilton Center line	AEP (100%)
b2232	Install 765 kV reactor breaker at Marysville 765 kV substation on the Marysville - Maliszewski line	AEP (100%)
b2233	Change transformer tap settings for the Baker 765/345 kV transformer	AEP (100%)
b2252	Loop the North Muskingum - Crooksville 138 kV line into AEP's Philo 138 kV station which lies approximately 0.4 miles	AEP (100%)

	from the line		
--	---------------	--	--

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2253	Install an 86.4 MVAR capacitor bank at Gorsuch 138 kV station in Ohio	AEP (100%)
b2254	Rebuild approximately 4.9 miles of Corner - Degussa 138 kV line in Ohio	AEP (100%)
b2255	Rebuild approximately 2.8 miles of Maliszewski - Polaris 138 kV line in Ohio	AEP (100%)
b2256	Upgrade approximately 36 miles of 138 kV through path facilities between Harrison 138 kV station and Ross 138 kV station in Ohio	AEP (100%)
b2257	Rebuild the Pokagon - Corey 69 kV line as a double circuit 138 kV line with one side at 69 kV and the other side as an express circuit between Pokagon and Corey stations	AEP (100%)
b2258	Rebuild 1.41 miles of #2 CU 46 kV line between Tams Mountain - Slab Fork to 138 kV standards. The line will be strung with 1033 ACSR	AEP (100%)
b2259	Install a new 138/69 kV transformer at George Washington 138/69 kV substation to provide support to the 69 kV system in the area	AEP (100%)

b2286	Rebuild 4.7 miles of Muskingum River - Wolf Creek 138 kV line and remove the 138/138 kV transformer at Wolf Creek Station		AEP (100%)
-------	---	--	------------

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2287	Loop in the Meadow Lake - Olive 345 kV circuit into Reynolds 765/345 kV station	AEP (100%)
b2344.1	Establish a new 138/12 kV station, transfer and consolidate load from its Nicholasville and Marcellus 34.5 kV stations at this new station	AEP (100%)
b2344.2	Tap the Hydramatic – Valley 138 kV circuit (~ structure 415), build a new 138 kV line (~3.75 miles) to this new station	AEP (100%)
b2344.3	From this station, construct a new 138 kV line (~1.95 miles) to REA’s Marcellus station	AEP (100%)
b2344.4	From REA’s Marcellus station construct new 138 kV line (~2.35 miles) to a tap point on Valley – Hydramatic 138 kV ckt (~structure 434)	AEP (100%)
b2344.5	Retire sections of the 138 kV line in between structure 415 and 434 (~ 2.65 miles)	AEP (100%)
b2344.6	Retire AEP’s Marcellus 34.5/12 kV and Nicholasville 34.5/12 kV stations and also the Marcellus – Valley 34.5 kV line	AEP (100%)

b2345.1	Construct a new 69 kV line from Hartford to Keeler (~8 miles)		AEP (100%)
---------	---	--	------------

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company
~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2345.2	Rebuild the 34.5 kV lines between Keeler - Sister Lakes and Glenwood tap switch to 69 kV (~12 miles)	AEP (100%)
b2345.3	Implement in - out at Keeler and Sister Lakes 34.5 kV stations	AEP (100%)
b2345.4	Retire Glenwood tap switch and construct a new Rothadew station. These new lines will continue to operate at 34.5 kV	AEP (100%)
b2346	Perform a sag study for Howard - North Bellville - Millwood 138 kV line including terminal equipment upgrades	AEP (100%)
b2347	Replace the North Delphos 600A switch. Rebuild approximately 18.7 miles of 138 kV line North Delphos - S073. Reconductor the line and replace the existing tower structures	AEP (100%)
b2348	Construct a new 138 kV line from Richlands Station to intersect with the Hales Branch - Grassy Creek 138 kV circuit	AEP (100%)
b2374	Change the existing CT ratios of the existing equipment along Bearskin - Smith Mountain 138kV	AEP (100%)

	circuit		
b2375	Change the existing CT ratios of the existing equipment along East Danville-Banister 138kV circuit		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2376	Replace the Turner 138 kV breaker 'D'	AEP (100%)
b2377	Replace the North Newark 138 kV breaker 'P'	AEP (100%)
b2378	Replace the Sporn 345 kV breaker 'DD'	AEP (100%)
b2379	Replace the Sporn 345 kV breaker 'DD2'	AEP (100%)
b2380	Replace the Muskingum 345 kV breaker 'SE'	AEP (100%)
b2381	Replace the East Lima 138 kV breaker 'E1'	AEP (100%)
b2382	Replace the Delco 138 kV breaker 'R'	AEP (100%)
b2383	Replace the Sporn 345 kV breaker 'AA2'	AEP (100%)
b2384	Replace the Sporn 345 kV breaker 'CC'	AEP (100%)
b2385	Replace the Sporn 345 kV breaker 'CC2'	AEP (100%)
b2386	Replace the Astor 138 kV breaker '102'	AEP (100%)
b2387	Replace the Muskingum 345 kV breaker 'SH'	AEP (100%)
b2388	Replace the Muskingum 345 kV breaker 'SI'	AEP (100%)
b2389	Replace the Hyatt 138 kV breaker '105N'	AEP (100%)
b2390	Replace the Muskingum 345 kV breaker 'SG'	AEP (100%)
b2391	Replace the Hyatt 138 kV breaker '101C'	AEP (100%)

b2392	Replace the Hyatt 138 kV breaker '104N'		AEP (100%)
b2393	Replace the Hyatt 138 kV breaker '104S'		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2394	Replace the Sporn 345 kV breaker 'CC1'	AEP (100%)
b2409	Install two 56.4 MVAR capacitor banks at the Melmore 138 kV station in Ohio	AEP (100%)
b2410	Convert Hogan Mullin 34.5 kV line to 138 kV, establish 138 kV line between Jones Creek and Strawton, rebuild existing Mullin Elwood 34.5 kV and terminate line into Strawton station, retire Mullin station	AEP (100%)
b2411	Rebuild the 3/0 ACSR portion of the Hadley - Kroemer Tap 69 kV line utilizing 795 ACSR conductor	AEP (100%)
b2423	Install a 300 MVAR shunt reactor at AEP's Wyoming 765 kV station	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)

			DFAX Allocation: AEP (100%)
--	--	--	---------------------------------------

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company
~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2444	Willow - Eureka 138 kV line: Reconductor 0.26 mile of 4/0 CU with 336 ACSS	AEP (100%)
b2445	Complete a sag study of Tidd - Mahans Lake 138 kV line	AEP (100%)
b2449	Rebuild the 7-mile 345 kV line between Meadow Lake and Reynolds 345 kV stations	AEP (100%)
b2462	Add two 138 kV circuit breakers at Fremont station to fix tower contingency '408_2'	AEP (100%)
b2501	Construct a new 138/69 kV Yager station by tapping 2-138 kV FE circuits (Nottingham-Cloverdale, Nottingham-Harmon)	AEP (100%)
b2501.2	Build a new 138 kV line from new Yager station to Azalea station	AEP (100%)
b2501.3	Close the 138 kV loop back into Yager 138 kV by converting part of local 69 kV facilities to 138 kV	AEP (100%)
b2501.4	Build 2 new 69 kV exits to reinforce 69 kV facilities and upgrade conductor between Irish Run 69 kV Switch and Bowerstown 69 kV Switch	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2502.1	Construct new 138 kV switching station Nottingham tapping 6-138 kV FE circuits (Holloway-Brookside, Holloway-Harmon #1 and #2, Holloway-Reeds, Holloway-New Stacy, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd station	AEP (100%)
b2502.2	Convert Freebyrd 69 kV to 138 kV	AEP (100%)
b2502.3	Rebuild/convert Freebyrd-South Cadiz 69 kV circuit to 138 kV	AEP (100%)
b2502.4	Upgrade South Cadiz to 138 kV breaker and a half	AEP (100%)
b2530	Replace the Sporn 138 kV breaker 'G1' with 80kA breaker	AEP (100%)
b2531	Replace the Sporn 138 kV breaker 'D' with 80kA breaker	AEP (100%)
b2532	Replace the Sporn 138 kV breaker 'O1' with 80kA breaker	AEP (100%)
b2533	Replace the Sporn 138 kV breaker 'P2' with 80kA breaker	AEP (100%)
b2534	Replace the Sporn 138 kV breaker 'U' with 80kA breaker	AEP (100%)

b2535	Replace the Sporn 138 kV breaker 'O' with 80 kA breaker		AEP (100%)
-------	---	--	------------

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2536	Replace the Sporn 138 kV breaker 'O2' with 80 kA breaker	AEP (100%)
b2537	Replace the Robinson Park 138 kV breakers A1, A2, B1, B2, C1, C2, D1, D2, E1, E2, and F1 with 63 kA breakers	AEP (100%)
b2555	Reconductor 0.5 miles Tiltonsville – Windsor 138 kV and string the vacant side of the 4.5 mile section using 556 ACSR in a six wire configuration	AEP (100%)
b2556	Install two 138 kV prop structures to increase the maximum operating temperature of the Clinch River- Clinch Field 138 kV line	AEP (100%)
b2581	Temporary operating procedure for delay of upgrade b1464. Open the Corner 138 kV circuit breaker 86 for an overload of the Corner – Washington MP 138 kV line. The tower contingency loss of Belmont – Trissler 138 kV and Belmont – Edgelawn 138 kV should be added to Operational contingency	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2591	Construct a new 69 kV line approximately 2.5 miles from Colfax to Drewry's. Construct a new Drewry's station and install a new circuit breaker at Colfax station.	AEP (100%)
b2592	Rebuild existing East Coshocton – North Coshocton double circuit line which contains Newcomerstown – N. Coshocton 34.5 kV Circuit and Coshocton – North Coshocton 69 kV circuit	AEP (100%)
b2593	Rebuild existing West Bellaire – Glencoe 69 kV line with 138 kV & 69 kV circuits and install 138/69 kV transformer at Glencoe Switch	AEP (100%)
b2594	Rebuild 1.0 mile of Brantley – Bridge Street 69 kV Line with 1033 ACSR overhead conductor	AEP (100%)
b2595.1	Rebuild 7.82 mile Elkhorn City – Haysi S.S 69 kV line utilizing 1033 ACSR built to 138 kV standards	AEP (100%)
b2595.2	Rebuild 5.18 mile Moss – Haysi SS 69 kV line utilizing 1033 ACSR built to 138 kV standards	AEP (100%)

b2596	Move load from the 34.5 kV bus to the 138 kV bus by installing a new 138/12 kV XF at New Carlisle station in Indiana		AEP (100%)
-------	--	--	------------

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2597	Rebuild approximately 1 mi. section of Dragoon-Virgil Street 34.5 kV line between Dragoon and Dodge Tap switch and replace Dodge switch MOAB to increase thermal capability of Dragoon-Dodge Tap branch	AEP (100%)
b2598	Rebuild approximately 1 mile section of the Kline-Virgil Street 34.5 kV line between Kline and Virgil Street tap. Replace MOAB switches at Beiger, risers at Kline, switches and bus at Virgil Street.	AEP (100%)
b2599	Rebuild approximately 0.1 miles of 69 kV line between Albion and Albion tap	AEP (100%)
b2600	Rebuild Fremont – Pound line as 138 kV	AEP (100%)
b2601	Fremont Station Improvements	AEP (100%)
b2601.1	Replace MOAB towards Beaver Creek with 138 kV breaker	AEP (100%)
b2601.2	Replace MOAB towards Clinch River with 138 kV breaker	AEP (100%)
b2601.3	Replace 138 kV Breaker A with new bus-tie breaker	AEP (100%)

b2601.4	Re-use Breaker A as high side protection on transformer #1		AEP (100%)
b2601.5	Install two (2) circuit switchers on high side of transformers # 2 and 3 at Fremont Station		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company
~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2602.1	Install 138 kV breaker E2 at North Proctorville		AEP (100%)
b2602.2	Construct 2.5 Miles of 138 kV 1033 ACSR from East Huntington to Darrah 138 kV substations		AEP (100%)
b2602.3	Install breaker on new line exit at Darrah towards East Huntington		AEP (100%)
b2602.4	Install 138 kV breaker on new line at East Huntington towards Darrah		AEP (100%)
b2602.5	Install 138 kV breaker at East Huntington towards North Proctorville		AEP (100%)
b2603	Boone Area Improvements		AEP (100%)
b2603.1	Purchase approximately a 200X300 station site near Slaughter Creek 46 kV station (Wilbur Station)		AEP (100%)
b2603.2	Install 3 138 kV circuit breakers, Cabin Creek to Hernshaw 138 kV circuit		AEP (100%)
b2603.3	Construct 1 mi. of double circuit 138 kV line on Wilbur – Boone 46 kV line with 1590 ACSS 54/19 conductor @ 482 Degree design temp. and 1-159 12/7 ACSR and one 86 Sq.MM. 0.646” OPGW Static wires		AEP (100%)

b2604	Bellefonte Transformer Addition		AEP (100%)
-------	------------------------------------	--	------------

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2605	Rebuild and reconductor Kammer – George Washington 69 kV circuit and George Washington – Moundsville ckt #1, designed for 138kV. Upgrade limiting equipment at remote ends and at tap stations	AEP (100%)
b2606	Convert Bane – Hammondsville from 23 kV to 69 kV operation	AEP (100%)
b2607	Pine Gap Relay Limit Increase	AEP (100%)
b2608	Richlands Relay Upgrade	AEP (100%)
b2609	Thorofare – Goff Run – Powell Mountain 138 kV Build	AEP (100%)
b2610	Rebuild Pax Branch – Scaraboro as 138 kV	AEP (100%)
b2611	Skin Fork Area Improvements	AEP (100%)
b2611.1	New 138/46 kV station near Skin Fork and other components	AEP (100%)
b2611.2	Construct 3.2 miles of 1033 ACSR double circuit from new Station to cut into Sundial-Baileysville 138 kV line	AEP (100%)
b2634.1	Replace metering BCT on Tanners Creek CB T2 with	AEP (100%)

	a slip over CT with higher thermal rating in order to remove 1193 MVA limit on facility (Miami Fort-Tanners Creek 345 kV line)		
--	--	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2643	Replace the Darrah 138 kV breaker 'L' with 40kA rated breaker	AEP (100%)
b2645	Ohio Central 138 kV Loop	AEP (100%)
b2667	Replace the Muskingum 138 kV bus # 1 and 2	AEP (100%)
b2668	Reconductor Dequine to Meadow Lake 345 kV circuit #1 utilizing dual 954 ACSR 54/7 cardinal conductor	AEP (100%)
b2669	Install a second 345/138 kV transformer at Desoto	AEP (100%)
b2670	Replace switch at Elk Garden 138 kV substation (on the Elk Garden – Lebanon 138 kV circuit)	AEP (100%)
b2671	Replace/upgrade/add terminal equipment at Bradley, Mullensville, Pinnacle Creek, Itmann, and Tams Mountain 138 kV substations. Sag study on Mullens – Wyoming and Mullens – Tams Mt. 138 kV circuits	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2687.1	Install a +/- 450 MVAR SVC at Jacksons Ferry 765 kV substation	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2687.2	Install a 300 MVAR shunt line reactor on the Broadford end of the Broadford – Jacksons Ferry 765 kV line	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b2697.1	Mitigate violations identified by sag study to operate Fieldale-Thornton-Franklin 138 kV overhead line conductor at its max. operating temperature. 6 potential line crossings to be addressed.	AEP (100%)
b2697.2	Replace terminal equipment at AEP's Danville and East Danville substations to improve thermal capacity of Danville – East Danville 138 kV circuit	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2698	Replace relays at AEP's Cloverdale and Jackson's Ferry substations to improve the thermal capacity of Cloverdale – Jackson's Ferry 765 kV line		AEP (100%)
b2701.1	Construct Herlan station as breaker and a half configuration with 9-138 kV CB's on 4 strings and with 2-28.8 MVAR capacitor banks		AEP (100%)
b2701.2	Construct new 138 kV line from Herlan station to Blue Racer station. Estimated approx. 3.2 miles of 1234 ACSS/TW Yukon and OPGW		AEP (100%)
2701.3	Install 1-138 kV CB at Blue Racer to terminate new Herlan circuit		AEP (100%)
b2714	Rebuild/upgrade line between Glencoe and Willow Grove Switch 69 kV		AEP (100%)
b2715	Build approximately 11.5 miles of 34.5 kV line with 556.5 ACSR 26/7 Dove conductor on wood poles from Flushing station to Smyrna station		AEP (100%)
b2727	Replace the South Canton 138 kV breakers 'K', 'J', 'J1', and 'J2' with 80kA		AEP (100%)

	breakers		
--	----------	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company
~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2731	Convert the Sunnyside – East Sparta – Malvern 23 kV sub-transmission network to 69 kV. The lines are already built to 69 kV standards		AEP (100%)
b2733	Replace South Canton 138 kV breakers ‘L’ and ‘L2’ with 80 kA rated breakers		AEP (100%)
b2750.1	Retire Betsy Layne 138/69/43 kV station and replace it with the greenfield Stanville station about a half mile north of the existing Betsy Layne station		AEP (100%)
b2750.2	Relocate the Betsy Layne capacitor bank to the Stanville 69 kV bus and increase the size to 14.4 MVAR		AEP (100%)
b2753.1	Replace existing George Washington station 138 kV yard with GIS 138 kV breaker and a half yard in existing station footprint. Install 138 kV revenue metering for new IPP connection		AEP (100%)
b2753.2	Replace Dilles Bottom 69/4 kV Distribution station as breaker and a half 138 kV yard design including AEP Distribution facilities but		AEP (100%)

	initial configuration will constitute a 3 breaker ring bus		
--	--	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2753.3	Connect two 138 kV 6-wired circuits from “Point A” (currently de-energized and owned by FirstEnergy) in circuit positions previously designated Burger #1 & Burger #2 138 kV. Install interconnection settlement metering on both circuits exiting Holloway		AEP (100%)
b2753.6	Build double circuit 138 kV line from Dilles Bottom to “Point A”. Tie each new AEP circuit in with a 6-wired line at Point A. This will create a Dilles Bottom – Holloway 138 kV circuit and a George Washington – Holloway 138 kV circuit		AEP (100%)
b2753.7	Retire line sections (Dilles Bottom – Bellaire and Moundsville – Dilles Bottom 69 kV lines) south of FirstEnergy 138 kV line corridor, near “Point A”. Tie George Washington – Moundsville 69 kV circuit to George Washington – West Bellaire 69 kV circuit		AEP (100%)
b2753.8	Rebuild existing 69 kV line as double circuit from George Washington – Dilles		AEP (100%)

	Bottom 138 kV. One circuit will cut into Dilles Bottom 138 kV initially and the other will go past with future plans to cut in		
--	--	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2760	Perform a Sag Study of the Saltville – Tazewell 138 kV line to increase the thermal rating of the line		AEP (100%)
b2761.1	Replace the Hazard 161/138 kV transformer		AEP (100%)
b2761.2	Perform a Sag Study of the Hazard – Wooten 161 kV line to increase the thermal rating of the line		AEP (100%)
b2761.3	Rebuild the Hazard – Wooten 161 kV line utilizing 795 26/7 ACSR conductor (300 MVA rating)		AEP (100%)
b2762	Perform a Sag Study of Nagel – West Kingsport 138 kV line to increase the thermal rating of the line		AEP (100%)
b2776	Reconductor the entire Dequine – Meadow Lake 345 kV circuit #2		AEP (100%)
b2777	Reconductor the entire Dequine – Eugene 345 kV circuit #1		EKPC (100%)
b2779.1	Construct a new 138 kV station, Campbell Road, tapping into the Grabill – South Hicksville 138 kV line		AEP (100%)
b2779.2	Reconstruct sections of the Butler-N.Hicksville and Auburn-Butler 69 kV circuits as 138 kV double circuit and		AEP (100%)

	extend 138 kV from Campbell Road station		
--	---	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2779.3	Construct a new 345/138 kV SDI Wilmington Station which will be sourced from Collingwood 345 kV and serve the SDI load at 345 kV and 138 kV, respectively		AEP (100%)
b2779.4	Loop 138 kV circuits in-out of the new SDI Wilmington 138 kV station resulting in a direct circuit to Auburn 138 kV and an indirect circuit to Auburn and Rob Park via Dunton Lake, and a circuit to Campbell Road; Reconductor 138 kV line section between Dunton Lake – SDI Wilmington		AEP (100%)
b2779.5	Expand Auburn 138 kV bus		AEP (100%)
b2787	Reconductor 0.53 miles (14 spans) of the Kaiser Jct. - Air Force Jct. Sw section of the Kaiser - Heath 69 kV circuit/line with 336 ACSR to match the rest of the circuit (73 MVA rating, 78% loading)		AEP (100%)
b2788	Install a new 3-way 69 kV line switch to provide service to AEP's Barnesville distribution station. Remove a portion of the #1 copper T-		AEP (100%)

	Line from the 69 kV through-path		
--	----------------------------------	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company
AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2789	Rebuild the Brues - Glendale Heights 69 kV line section (5 miles) with 795 ACSR (128 MVA rating, 43% loading)		AEP (100%)
b2790	Install a 3 MVAR, 34.5 kV cap bank at Caldwell substation		AEP (100%)
b2791	Rebuild Tiffin – Howard, new transformer at Chatfield		AEP (100%)
b2791.1	Rebuild portions of the East Tiffin - Howard 69 kV line from East Tiffin to West Rockaway Switch (0.8 miles) using 795 ACSR Drake conductor (129 MVA rating, 50% loading)		AEP (100%)
b2791.2	Rebuild Tiffin - Howard 69 kV line from St. Stephen's Switch to Hinesville (14.7 miles) using 795 ACSR Drake conductor (90 MVA rating, non-conductor limited, 38% loading)		AEP (100%)
b2791.3	New 138/69 kV transformer with 138/69 kV protection at Chatfield		AEP (100%)
b2791.4	New 138/69 kV protection at existing Chatfield transformer		AEP (100%)

b2792	<p>Replace the Elliott transformer with a 130 MVA unit, reconductor 0.42 miles of the Elliott – Ohio University 69 kV line with 556 ACSR to match the rest of the line conductor (102 MVA rating, 73% loading) and rebuild 4 miles of the Clark Street – Strouds R</p>		AEP (100%)
-------	--	--	------------

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2793	Energize the spare Fremont Center 138/69 kV 130 MVA transformer #3. Reduces overloaded facilities to 46% loading	AEP (100%)
b2794	Construct new 138/69/34 kV station and 1-34 kV circuit (designed for 69 kV) from new station to Decliff station, approximately 4 miles, with 556 ACSR conductor (51 MVA rating)	AEP (100%)
b2795	Install a 34.5 kV 4.8 MVAR capacitor bank at Killbuck 34.5 kV station	AEP (100%)
b2796	Rebuild the Malvern - Oneida Switch 69 kV line section with 795 ACSR (1.8 miles, 125 MVA rating, 55% loading)	AEP (100%)
b2797	Rebuild the Ohio Central - Conesville 69 kV line section (11.8 miles) with 795 ACSR conductor (128 MVA rating, 57% loading). Replace the 50 MVA Ohio Central 138/69 kV XFMR with a 90 MVA unit	AEP (100%)
b2798	Install a 14.4 MVAR capacitor bank at West Hicksville station. Replace ground switch/MOAB at West Hicksville with a circuit switcher	AEP (100%)

b2799	Rebuild Valley - Almena, Almena - Hartford, Riverside - South Haven 69 kV lines. New line exit at Valley Station. New transformers at Almena and Hartford		AEP (100%)
-------	---	--	------------

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2799.1	Rebuild 12 miles of Valley – Almena 69 kV line as a double circuit 138/69 kV line using 795 ACSR conductor (360 MVA rating) to introduce a new 138 kV source into the 69 kV load pocket around Almena station	AEP (100%)
b2799.2	Rebuild 3.2 miles of Almena to Hartford 69 kV line using 795 ACSR conductor (90 MVA rating)	AEP (100%)
b2799.3	Rebuild 3.8 miles of Riverside – South Haven 69 kV line using 795 ACSR conductor (90 MVA rating)	AEP (100%)
b2799.4	At Valley station, add new 138 kV line exit with a 3000 A 40 kA breaker for the new 138 kV line to Almena and replace CB D with a 3000 A 40 kA breaker	AEP (100%)
b2799.5	At Almena station, install a 90 MVA 138/69 kV transformer with low side 3000 A 40 kA breaker and	AEP (100%)

	establish a new 138 kV line exit towards Valley		
b2799.6	At Hartford station, install a second 90 MVA 138/69 kV transformer with a circuit switcher and 3000 A 40 kA low side breaker		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company ~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)~~ **(cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2817	Replace Delaware 138 kV breaker 'P' with a 40 kA breaker	AEP (100%)
b2818	Replace West Huntington 138 kV breaker 'F' with a 40 kA breaker	AEP (100%)
b2819	Replace Madison 138 kV breaker 'V' with a 63 kA breaker	AEP (100%)
b2820	Replace Sterling 138 kV breaker 'G' with a 40 kA breaker	AEP (100%)
b2821	Replace Morse 138 kV breakers '103', '104', '105', and '106' with 63 kA breakers	AEP (100%)
b2822	Replace Clinton 138 kV breakers '105' and '107' with 63 kA breakers	AEP (100%)
b2826.1	Install 300 MVAR reactor at Ohio Central 345 kV substation	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2826.2	Install 300 MVAR reactor at West Bellaire 345 kV substation	AEP (100%)
b2831.1	Upgrade the Tanner Creek – Miami Fort 345 kV circuit (AEP portion)	DFAX Allocation: Dayton (61.71%) / DEOK (37.68%) / OVEC (0.61%)
b2832	Six wire the Kyger Creek – Sporn 345 kV circuits #1 and #2 and convert them to one circuit	AEP (100%)
b2833	Reconductor the Maddox Creek – East Lima 345 kV circuit with 2-954 ACSS Cardinal conductor	DFAX Allocation: AEP (80.83%) / Dayton (18.73%) / OVEC (0.44%)
b2834	Reconductor and string open position and sixwire 6.2 miles of the Chemical – Capitol Hill 138 kV circuit	AEP (100%)
b2872	Replace the South Canton 138 kV breaker ‘K2’ with a 80 kA breaker	AEP (100%)
b2873	Replace the South Canton 138 kV breaker “M” with a 80 kA breaker	AEP (100%)
b2874	Replace the South Canton 138 kV breaker “M2” with a 80 kA breaker	AEP (100%)
b2878	Upgrade the Clifty Creek 345 kV risers	AEP (100%)
b2880	Rebuild approximately 4.77 miles of the Cannonsburg – South Neal 69 kV line section utilizing 795 ACSR	AEP (100%)

	conductor (90 MVA rating)		
--	---------------------------	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2881	Rebuild ~1.7 miles of the Dunn Hollow – London 46 kV line section utilizing 795 26/7 ACSR conductor (58 MVA rating, non-conductor limited)	AEP (100%)
b2882	Rebuild Reusens - Peakland Switch 69 kV line. Replace Peakland Switch	AEP (100%)
b2882.1	Rebuild the Reusens - Peakland Switch 69 kV line (approximately 0.8 miles) utilizing 795 ACSR conductor (86 MVA rating, non-conductor limited)	AEP (100%)
b2882.2	Replace existing Peakland S.S with new 3 way switch phase over phase structure	AEP (100%)
b2883	Rebuild the Craneco – Pardee – Three Forks – Skin Fork 46 kV line section (approximately 7.2 miles) utilizing 795 26/7 ACSR conductor (108 MVA rating)	AEP (100%)
b2884	Install a second transformer at Nagel station, comprised of 3 single phase 250 MVA 500/138 kV transformers. Presently, TVA operates their end of the Boone Dam – Holston 138 kV interconnection as normally	AEP (100%)

	open preemptively for the loss of the existing Nagel		
b2885	New delivery point for City of Jackson		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2885.1	Install a new Ironman Switch to serve a new delivery point requested by the City of Jackson for a load increase request	AEP (100%)
b2885.2	Install a new 138/69 kV station (Rhodes) to serve as a third source to the area to help relieve overloads caused by the customer load increase	AEP (100%)
b2885.3	Replace Coalton Switch with a new three breaker ring bus (Heppner)	AEP (100%)
b2886	Install 90 MVA 138/69 kV transformer, new transformer high and low side 3000 A 40 kA CBs, and a 138 kV 40 kA bus tie breaker at West End Fostoria	AEP (100%)
b2887	Add 2-138 kV CB's and relocate 2-138 kV circuit exits to different bays at Morse Road. Eliminate 3 terminal line by terminating Genoa - Morse circuit at Morse Road	AEP (100%)
b2888	Retire Poston substation. Install new Lemaster substation	AEP (100%)
b2888.1	Remove and retire the Poston 138 kV station	AEP (100%)
b2888.2	Install a new greenfield station, Lemaster 138 kV	AEP (100%)

	Station, in the clear		
--	-----------------------	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2888.3	Relocate the Trimble 69 kV AEP Ohio radial delivery point to 138 kV, to be served off of the Poston – Strouds Run – Crooksville 138 kV circuit via a new three-way switch. Retire the Poston - Trimble 69 kV line	AEP (100%)
b2889	Expand Cliffview station	AEP (100%)
b2889.1	Cliffview Station: Establish 138 kV bus. Install two 138/69 kV XFRs (130 MVA), six 138 kV CBs (40 kA 3000 A) and four 69 kV CBs (40 kA 3000 A)	AEP (100%)
b2889.2	Byllesby – Wythe 69 kV: Retire all 13.77 miles (1/0 CU) of this circuit (~4 miles currently in national forest)	AEP (100%)
b2889.3	Galax – Wythe 69 kV: Retire 13.53 miles (1/0 CU section) of line from Lee Highway down to Byllesby. This section is currently double circuited with Byllesby – Wythe 69 kV. Terminate the southern 3/0 ACSR section into the newly opened position at Byllesby	AEP (100%)
b2889.4	Cliffview Line: Tap the existing Pipers Gap – Jubal	AEP (100%)

	<p>Early 138 kV line section. Construct double circuit in/out (~2 miles) to newly established 138 kV bus, utilizing 795 26/7 ACSR conductor</p>		
--	---	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)-(cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2890.1	Rebuild 23.55 miles of the East Cambridge – Smyrna 34.5 kV circuit with 795 ACSR conductor (128 MVA rating) and convert to 69 kV	AEP (100%)
b2890.2	East Cambridge: Install a 2000 A 69 kV 40 kA circuit breaker for the East Cambridge – Smyrna 69 kV circuit	AEP (100%)
b2890.3	Old Washington: Install 69 kV 2000 A two way phase over phase switch	AEP (100%)
b2890.4	Install 69 kV 2000 A two way phase over phase switch	AEP (100%)
b2891	Rebuild the Midland Switch to East Findlay 34.5 kV line (3.31 miles) with 795 ACSR (63 MVA rating) to match other conductor in the area	AEP (100%)
b2892	Install new 138/12 kV transformer with high side circuit switcher at Leon and a new 138 kV line exit towards Ripley. Establish 138 kV at the Ripley station with a new 138/69 kV 130 MVA transformer and move the distribution load to 138 kV service	AEP (100%)
b2936.1	Rebuild approximately 6.7 miles of 69 kV line between	AEP (100%)

	<p>Mottville and Pigeon River using 795 ACSR conductor (129 MVA rating). New construction will be designed to 138 kV standards but operated at 69 kV</p>		
--	--	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2936.2	Pigeon River Station: Replace existing MOAB Sw. 'W' with a new 69 kV 3000 A 40 kA breaker, and upgrade existing relays towards HMD station. Replace CB H with a 3000 A 40 kA breaker	AEP (100%)
b2937	Replace the existing 636 ACSR 138 kV bus at Fletchers Ridge with a larger 954 ACSR conductor	AEP (100%)
b2938	Perform a sag mitigations on the Broadford – Wolf Hills 138 kV circuit to allow the line to operate to a higher maximum temperature	AEP (100%)
b2958.1	Cut George Washington – Tidd 138 kV circuit into Sand Hill and reconfigure Brues & Warton Hill line entrances	AEP (100%)
b2958.2	Add 2 138 kV 3000 A 40 kA breakers, disconnect switches, and update relaying at Sand Hill station	AEP (100%)
b2968	Upgrade existing 345 kV terminal equipment at Tanner Creek station	AEP (100%)
b2969	Replace terminal equipment on Maddox Creek - East Lima 345 kV circuit	AEP (100%)
b2976	Upgrade terminal equipment at Tanners Creek 345 kV	AEP (100%)

	station. Upgrade 345 kV bus and risers at Tanners Creek for the Dearborn circuit		
--	--	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2988	Replace the Twin Branch 345 kV breaker “JM” with 63 kA breaker and associated substation works including switches, bus leads, control cable and new DICM	AEP (100%)
b2993	Rebuild the Torrey – South Gambrinus Switch – Gambrinus Road 69 kV line section (1.3 miles) with 1033 ACSR ‘Curlew’ conductor and steel poles	AEP (100%)
b3000	Replace South Canton 138 kV breaker ‘N’ with an 80kA breaker	AEP (100%)
b3001	Replace South Canton 138 kV breaker ‘N1’ with an 80kA breaker	AEP (100%)
b3002	Replace South Canton 138 kV breaker ‘N2’ with an 80kA breaker	AEP (100%)
b3036	Rebuild 15.6 miles of Haviland - North Delphos 138 kV line	AEP (100%)
b3037	Upgrades at the Natrium substation	AEP (100%)
b3038	Reconductor the Capitol Hill – Coco 138 kV line section	AEP (100%)
b3039	Line swaps at Muskingum 138 kV station	AEP (100%)
b3040.1	Rebuild Ravenswood – Racine tap 69 kV line section	AEP (100%)

	(~15 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor		
--	---	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3040.2	Rebuild existing Ripley – Ravenswood 69 kV circuit (~9 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)
b3040.3	Install new 3-way phase over phase switch at Sarah Lane station to replace the retired switch at Cottageville	AEP (100%)
b3040.4	Install new 138/12 kV 20 MVA transformer at Polymer station to transfer load from Mill Run station to help address overload on the 69 kV network	AEP (100%)
b3040.5	Retire Mill Run station	AEP (100%)
b3040.6	Install 28.8 MVAR cap bank at South Buffalo station	AEP (100%)
b3051.2	Adjust CT tap ratio at Ronceverte 138 kV	AEP (100%)
b3085	Reconductor Kammer – George Washington 138 kV line (approx. 0.08 mile). Replace the wave trap at Kammer 138 kV	AEP (100%)
b3086.1	Rebuild New Liberty – Findlay 34 kV line Str's 1–37 (1.5 miles), utilizing 795 26/7 ACSR conductor	AEP (100%)
b3086.2	Rebuild New Liberty – North Baltimore 34 kV line Str's 1-	AEP (100%)

	11 (0.5 mile), utilizing 795 26/7 ACSR conductor		
--	---	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3086.3	Rebuild West Melrose – Whirlpool 34 kV line Str's 55–80 (1 mile), utilizing 795 26/7 ACSR conductor	AEP (100%)
b3086.4	North Findlay station: Install a 138 kV 3000A 63kA line breaker and low side 34.5 kV 2000A 40kA breaker, high side 138 kV circuit switcher on T1	AEP (100%)
b3086.5	Ebersole station: Install second 90 MVA 138/69/34 kV transformer. Install two low side (69 kV) 2000A 40kA breakers for T1 and T2	AEP (100%)
b3087.1	Construct a new greenfield station to the west (approx. 1.5 miles) of the existing Fords Branch Station in the new Kentucky Enterprise Industrial Park. This station will consist of six 3000A 40kA 138 kV breakers laid out in a ring arrangement, two 30 MVA 138/34.5 kV transformers, and two 30 MVA 138/12 kV transformers. The existing Fords Branch Station will be retired	AEP (100%)
b3087.2	Construct approximately 5 miles of new double circuit	AEP (100%)

	138 kV line in order to loop the new Kewanee station into the existing Beaver Creek – Cedar Creek 138 kV circuit		
--	--	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3087.3	Remote end work will be required at Cedar Creek Station	AEP (100%)
b3087.4	Install 28.8 MVar switching shunt at the new Fords Branch substation	AEP (100%)
b3095	Rebuild Lakin – Racine Tap 69 kV line section (9.2 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)
b3099	Install a 138 kV 3000A 40 kA circuit switcher on the high side of the existing 138/34.5 kV transformer No.5 at Holston station	AEP (100%)
b3100	Replace the 138 kV MOAB switcher “YY” with a new 138 kV circuit switcher on the high side of Chemical transformer No.6	AEP (100%)
b3101	Rebuild the 1/0 Cu. conductor sections (approx. 1.5 miles) of the Fort Robinson – Moccasin Gap 69 kV line section (approx. 5 miles) utilizing 556 ACSR conductor and upgrade existing relay trip limit (WN/WE: 63 MVA, line limited by remaining conductor sections)	AEP (100%)
b3102	Replace existing 50 MVA 138/69 kV transformers #1	AEP (100%)

	and #2 (both 1957 vintage) at Fremont station with new 130 MVA 138/69 kV transformers		
--	---	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3103.1	Install a 138/69 kV transformer at Royerton station. Install a 69 kV bus with one 69 kV breaker toward Bosman station. Rebuild the 138 kV portion into a ring bus configuration built for future breaker and a half with four 138 kV breakers		AEP (100%)
b3103.2	Rebuild the Bosman/Strawboard station in the clear across the road to move it out of the flood plain and bring it up to 69 kV standards		AEP (100%)
b3103.3	Retire 138 kV breaker L at Delaware station and re-purpose 138 kV breaker M for the Jay line		AEP (100%)
b3103.4	Retire all 34.5 kV equipment at Hartford City station. Re-purpose breaker M for the Bosman line 69 kV exit		AEP (100%)
b3103.5	Rebuild the 138 kV portion of Jay station as a 6 breaker, breaker and a half station re-using the existing breakers "A", "B", and "G." Rebuild the 69 kV portion of this station as a 6 breaker ring bus re-using the 2 existing 69 kV		AEP (100%)

	breakers. Install a new 138/69 kV transformer		
--	--	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3103.6	Rebuild the 69 kV Hartford City – Armstrong Cork line but instead of terminating it into Armstrong Cork, terminate it into Jay station	AEP (100%)
b3103.7	Build a new 69 kV line from Armstrong Cork – Jay station	AEP (100%)
b3103.8	Rebuild the 34.5 kV Delaware – Bosman line as the 69 kV Royerton – Strawboard line. Retire the line section from Royerton to Delaware stations	AEP (100%)
b3104	Perform a sag study on the Polaris – Westerville 138 kV line (approx. 3.6 miles) to increase the summer emergency rating to 310 MVA	AEP (100%)
b3105	Rebuild the Delaware – Hyatt 138 kV line (approx. 4.3 miles) along with replacing conductors at both Hyatt and Delaware substations	AEP (100%)
b3106	Perform a sag study (6.8 miles of line) to increase the SE rating to 310 MVA. Note that results from the sag study could cover a wide range of outcomes, from no work required to a complete rebuild	AEP (100%)

b3109	Rebuild 5.2 miles Bethel – Sawmill 138 kV line including ADSS		AEP (100%)
-------	---	--	------------

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3112	Construct a single circuit 138 kV line (approx. 3.5 miles) from Amlin to Dublin using 1033 ACSR Curlew (296 MVA SN), convert Dublin station into a ring configuration, and re-terminating the Britton UG cable to Dublin station	AEP (100%)
b3116	Replace existing Mullens 138/46 kV 30 MVA transformer No.4 and associated protective equipment with a new 138/46 kV 90 MVA transformer and associated protective equipment	AEP (100%)
b3118.1	Expand existing Chadwick station and install a second 138/69 kV transformer at a new 138 kV bus tied into the Bellefonte – Grangston 138 kV circuit. The 69 kV bus will be reconfigured into a ring bus arrangement to tie the new transformer into the existing 69 kV via installation of four 3000A 63 kA 69 kV circuit breakers	AEP (100%)
b3118.2	Perform 138 kV remote end work at Grangston station	AEP (100%)

b3118.3	Perform 138 kV remote end work at Bellefonte station		AEP (100%)
b3118.4	Relocate the Chadwick – Leach 69 kV circuit within Chadwick station		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3118.5	Terminate the Bellefonte – Grangston 138 kV circuit to the Chadwick 138 kV bus	AEP (100%)
b3118.6	Chadwick – Tri-State #2 138 kV circuit will be reconfigured within the station to terminate into the newly established 138 kV bus #2 at Chadwick due to construability aspects	AEP (100%)
b3118.7	Reconductor Chadwick – Leach and Chadwick – England Hill 69 kV lines with 795 ACSS conductor. Perform a LiDAR survey and a sag study to confirm that the reconducted circuits would maintain acceptable clearances	AEP (100%)
b3118.8	Replace the 20 kA 69 kV circuit breaker ‘F’ at South Neal station with a new 3000A 40 kA 69 kV circuit breaker. Replace line risers towards Leach station	AEP (100%)
b3118.9	Rebuild 336 ACSR portion of Leach – Miller S.S 69 kV line section (approx. 0.3 mile) with 795 ACSS conductor	AEP (100%)
b3118.10	Replace 69 kV line risers (towards Chadwick) at Leach station	AEP (100%)

b3119.1	Rebuild the Jay – Pennville 138 kV line as double circuit 138/69 kV. Build a new 9.8 mile single circuit 69 kV line from near Pennville station to North Portland station		AEP (100%)
---------	---	--	------------

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3119.2	Install three (3) 69 kV breakers to create the “U” string and add a low side breaker on the Jay transformer 2		AEP (100%)
b3119.3	Install two (2) 69 kV breakers at North Portland station to complete the ring and allow for the new line		AEP (100%)
b3129	At Conesville 138 kV station: Remove line leads to generating units, transfer plant AC service to existing station service feeds in Conesville 345/138 kV yard, and separate and reconfigure protection schemes		AEP (100%)
b3131	At East Lima and Haviland 138 kV stations, replace line relays and wavetrap on the East Lima – Haviland 138 kV facility		AEP (100%)
b3132	Rebuild 3.11 miles of the LaPorte Junction – New Buffalo 69 kV line with 795 ACSR		AEP (100%)

b3139	Rebuild the Garden Creek – Whetstone 69 kV line (approx. 4 miles)		AEP (100%)
b3140	Rebuild the Whetstone – Knox Creek 69 kV line (approx. 3.1 miles)		AEP (100%)
b3141	Rebuild the Knox Creek – Coal Creek 69 kV line (approx. 2.9 miles)		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3148.1	Rebuild the 46 kV Bradley – Scarbro line to 96 kV standards using 795 ACSR to achieve a minimum rate of 120 MVA. Rebuild the new line adjacent to the existing one leaving the old line in service until the work is completed	AEP (100%)
b3148.2	Bradley remote end station work, replace 46 kV bus, install new 12 MVAR capacitor bank	AEP (100%)
b3148.3	Replace the existing switch at Sun substation with a 2-way SCADA-controlled motor-operated air-breaker switch	AEP (100%)
b3148.4	Remote end work and associated equipment at Scarbro station	AEP (100%)
b3148.5	Retire Mt. Hope station and transfer load to existing Sun station	AEP (100%)
b3149	Rebuild the 2.3 mile Decatur – South Decatur 69 kV line using 556 ACSR	AEP (100%)
b3150	Rebuild Ferguson 69/12 kV station in the clear as the 138/12 kV Bear station and connect it to an approx. 1 mile double circuit 138 kV extension from the Aviation –	AEP (100%)

	Ellison Road 138 kV line to remove the load from the 69 kV line		
--	---	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3151.1	Rebuild the 30 mile Gateway – Wallen 34.5 kV circuit as the 27 mile Gateway – Wallen 69 kV line	AEP (100%)
b3151.2	Retire approx. 3 miles of the Columbia – Whitley 34.5 kV line	AEP (100%)
b3151.3	At Gateway station, remove all 34.5 kV equipment and install one (1) 69 kV circuit breaker for the new Whitley line entrance	AEP (100%)
b3151.4	Rebuild Whitley as a 69 kV station with two (2) lines and one (1) bus tie circuit breaker	AEP (100%)
b3151.5	Replace the Union 34.5 kV switch with a 69 kV switch structure	AEP (100%)
b3151.6	Replace the Eel River 34.5 kV switch with a 69 kV switch structure	AEP (100%)
b3151.7	Install a 69 kV Bobay switch at Woodland station	AEP (100%)
b3151.8	Replace the Carroll and Churubusco 34.5 kV stations with the 69 kV Snapper station. Snapper station will have two (2) line circuit breakers, one (1) bus tie circuit breaker and a 14.4 MVAR cap bank	AEP (100%)

b3151.9	Remove 34.5 kV circuit breaker “AD” at Wallen station		AEP (100%)
b3151.10	Rebuild the 2.5 miles of the Columbia – Gateway 69 kV line		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)
~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3151.11	Rebuild Columbia station in the clear as a 138/69 kV station with two (2) 138/69 kV transformers and 4-breaker ring buses on the high and low side. Station will reuse 69 kV breakers “J” & “K” and 138 kV breaker “D”		AEP (100%)
b3151.12	Rebuild the 13 miles of the Columbia – Richland 69 kV line		AEP (100%)
b3151.13	Rebuild the 0.5 mile Whitley – Columbia City No.1 line as 69 kV		AEP (100%)
b3151.14	Rebuild the 0.5 mile Whitley – Columbia City No.2 line as 69 kV		AEP (100%)
b3151.15	Rebuild the 0.6 mile double circuit section of the Rob Park – South Hicksville / Rob Park – Diebold Road as 69 kV		AEP (100%)
b3160.1	Construct an approx. 2.4 miles double circuit 138 kV extension using 1033 ACSR (Aluminum Conductor Steel Reinforced) to connect Lake		AEP (100%)

	Head to the 138 kV network		
b3160.2	Retire the approx.2.5 miles 34.5 kV Niles – Simplicity Tap line		AEP (100%)
b3160.3	Retire the approx.4.6 miles Lakehead 69 kV Tap		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement		Responsible Customer(s)
b3160.4	Build new 138/69 kV drop down station to feed Lakehead with a 138 kV breaker, 138 kV switcher, 138/69 kV transformer and a 138 kV Motor-Operated Air Break		AEP (100%)
b3160.5	Rebuild the approx. 1.2 miles Buchanan South 69 kV Radial Tap using 795 ACSR (Aluminum Conductor Steel Reinforced)		AEP (100%)
b3160.6	Rebuild the approx. 8.4 miles 69 kV Pletcher – Buchanan Hydro line as the approx. 9 miles Pletcher – Buchanan South 69 kV line using 795 ACSR (Aluminum Conductor Steel Reinforced)		AEP (100%)
b3160.7	Install a PoP (Point-of-Presence) switch at Buchanan South station with 2 line MOABs (Motor-Operated Air Break)		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3208	Retire approximately 38 miles of the 44 mile Clifford – Scottsville 46 kV circuit. Build new 138 kV “in and out” to two new distribution stations to serve the load formerly served by Phoenix, Shipman, Schuyler (AEP), and Rockfish stations. Construct new 138 kV lines from Joshua Falls – Riverville (approx. 10 miles) and Riverville – Gladstone (approx. 5 miles). Install required station upgrades at Joshua Falls, Riverville and Gladstone stations to accommodate the new 138 kV circuits. Rebuild Reusen – Monroe 69 kV (approx. 4 miles)	AEP (100%)
b3209	Rebuild the 10.5 mile Berne – South Decatur 69 kV line using 556 ACSR	AEP (100%)
b3210	Replace approx. 0.7 mile Beatty – Galloway 69 kV line with 4000 kcmil XLPE cable	AEP (100%)
b3220	Install 14.4 MVAR capacitor bank at Whitewood 138 kV	AEP (100%)
b3261	Upgrade circuit breaker “R1” at Tanners Creek 345 kV. Install Transient Recovery	AEP (100%)

	Voltage capacitor to increase the rating from 50 kA to 63 kA		
--	--	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

~~AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)~~

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3269	At West New Philadelphia station, add a high side 138 kV breaker on the 138/69 kV Transformer #2 along with a 138 kV breaker on the line towards Newcomerstown	AEP (100%)
b3270	Install 1.7 miles of 795 ACSR 138 kV conductor along the other side of Dragoon Tap 138 kV line, which is currently double circuit tower with one position open. Additionally, install a second 138/34.5 kV transformer at Dragoon, install a high side circuit switcher on the current transformer at the Dragoon Station, and install two (2) 138 kV line breakers on the Dragoon – Jackson 138 kV and Dragoon – Twin Branch 138 kV lines	AEP (100%)
b3270.1	Replace Dragoon 34.5 kV breakers “B”, “C”, and “D” with 40 kA breakers	AEP (100%)
b3271	Install a 138 kV circuit breaker at Fremont station on the line towards Fremont Center and install a 9.6 MVAR 69 kV capacitor bank at Bloom Road station	AEP (100%)

b3272	Install two 138 kV circuit switchers on the high side of 138/34.5 kV Transformers #1 and #2 at Rockhill station		AEP (100%)
-------	---	--	------------

ATTACHMENT L
List of Transmission Owners

Allegheny Electric Cooperative, Inc.
American Transmission Systems, Incorporated
Atlantic City Electric Company
Baltimore Gas and Electric Company
Delmarva Power & Light Company
Duke Energy Ohio, Inc.
Duke Energy Kentucky, Inc.
East Kentucky Power Cooperative, Inc.
Essential Power Rock Springs, LLC
Hudson Transmission Partners, LLC
ITC Interconnection LLC
Jersey Central Power & Light Company
Mid-Atlantic Interstate Transmission, LLC
Neptune Regional Transmission System, LLC
Old Dominion Electric Cooperative
PECO Energy Company
Pennsylvania Power & Light Company
Potomac Electric Power Company
Public Service Electric and Gas Company
Rockland Electric Company
Trans-Allegheny Interstate Line Company
Transource West Virginia, LLC
UGI Utilities, Inc.
Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power
Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.
The Dayton Power and Light Company
~~AEP East Operating Companies~~ American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.;
~~(Appalachian Power Company; Columbus Southern Power Company;~~ Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company)
Duquesne Light Company
Virginia Electric and Power Company
Linden VFT, LLC
City of Cleveland, Department of Public Utilities, Division of Cleveland Public Power
City of Hamilton, OH
Southern Maryland Electric Cooperative, Inc.
Ohio Valley Electric Cooperative
AMP Transmission, LLC
Silver Run Electric, LLC

NextEra Energy Transmission MidAtlantic Indiana, Inc.
Wabash Valley Power Association, Inc.

Attachment B

Revisions to the PJM Open Access Transmission Tariff

(Clean Format)

SCHEDULE 12 – APPENDIX

- (17) **American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b0318	Install a 765/138 kV transformer at Amos		AEP (99.00%) / PEPCO (1.00%)
b0324	Replace entrance conductors, wave traps, and risers at the Tidd 345 kV station on the Tidd – Canton Central 345 kV circuit		AEP (100%)
b0447	Replace Cook 345 kV breaker M2		AEP (100%)
b0448	Replace Cook 345 kV breaker N2		AEP (100%)
b0490	Construct an Amos – Bedington 765 kV circuit (AEP equipment)	As specified under the procedures detailed in Attachment H-19B	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
			DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)
*	Neptune	Regional	Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.2	Replace Amos 138 kV breaker 'B'	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.3	Replace Amos 138 kV breaker 'B1'	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.4	Replace Amos 138 kV breaker 'C'	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.5	Replace Amos 138 kV breaker 'C1'	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.6	Replace Amos 138 kV breaker 'D'	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.7	Replace Amos 138 kV breaker 'D2'	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.8	Replace Amos 138 kV breaker 'E'	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0490.9	Replace Amos 138 kV breaker 'E2'	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b0504	Add two advanced technology circuit breakers at Hanging Rock 765 kV to improve operational performance		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: AEP (100%)
b0570	Reconductor East Side Lima – Sterling 138 kV		AEP (41.99%) / ComEd (58.01%)
b0571	Reconductor West Millersport – Millersport 138 kV		AEP (73.83%) / ComEd (19.26%) / Dayton (6.91%)
b0748	Establish a new 69 kV circuit between the Canal Road and East Wooster stations, establish a new 69 kV circuit between the West Millersburg and Moreland Switch stations (via Shreve), add reactive support via cap banks		AEP (100%)
b0838	Hazard Area 138 kV and 69 kV Improvement Projects		AEP (100%)
b0839	Replace existing 450 MVA transformer at Twin Branch 345 / 138 kV with a 675 MVA transformer		AEP (99.73%) / Dayton (0.27%)
* Neptune Regional		Transmission	System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0840	String a second 138 kV circuit on the open tower position between Twin Branch and East Elkhart	AEP (100%)
b0840.1	Establish a new 138/69-34.5kV Station to interconnect the existing 34.5kV network	AEP (100%)
b0917	Replace Baileysville 138 kV breaker 'P'	AEP (100%)
b0918	Replace Riverview 138 kV breaker '634'	AEP (100%)
b0919	Replace Torrey 138 kV breaker 'W'	AEP (100%)
b1032.1	Construct a new 345/138kV station on the Marquis-Bixby 345kV line near the intersection with Ross - Highland 69kV	AEP (89.97%) / Dayton (10.03%)
b1032.2	Construct two 138kV outlets to Delano 138kV station and to Camp Sherman station	AEP (89.97%) / Dayton (10.03%)
b1032.3	Convert Ross - Circleville 69kV to 138kV	AEP (89.97%) / Dayton (10.03%)
b1032.4	Install 138/69kV transformer at new station and connect in the Ross - Highland 69kV line	AEP (89.97%) / Dayton (10.03%)
b1033	Add a third delivery point from AEP's East Danville Station to the City of Danville.	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1034.1	Establish new South Canton - West Canton 138kV line (replacing Torrey - West Canton) and Wagenhals - Wayview 138kV	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1034.2	Loop the existing South Canton - Wayview 138kV circuit in-and-out of West Canton	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1034.3	Install a 345/138kV 450 MVA transformer at Canton Central	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1034.4	Rebuild/reconductor the Sunnyside - Torrey 138kV line	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1034.5	Disconnect/eliminate the West Canton 138kV terminal at Torrey Station	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1034.6	Replace all 138kV circuit breakers at South Canton Station and operate the station in a breaker and a half configuration	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1034.7	Replace all obsolete 138kV circuit breakers at the Torrey and Wagenhals stations	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1034.8	Install additional 138kV circuit breakers at the West Canton, South Canton, Canton Central, and Wagenhals stations to accommodate the new circuits	AEP (96.01%) / APS (0.62%) / ComEd (0.19%) / Dayton (0.44%) / DL (0.13%) / PENELEC (2.61%)
b1035	Establish a third 345kV breaker string in the West Millersport Station. Construct a new West Millersport – Gahanna 138kV circuit. Miscellaneous improvements to 138kV transmission system.	AEP (100%)
b1036	Upgrade terminal equipment at Poston Station and update remote end relays	AEP (100%)
b1037	Sag check Bonsack–Cloverdale 138 kV, Cloverdale–Centerville 138kV, Centerville–Ivy Hill 138kV, Ivy Hill–Reusens 138kV, Bonsack–Reusens 138kV and Reusens–Monel–Gomingo–Joshua Falls 138 kV.	AEP (100%)
b1038	Check the Crooksville - Muskingum 138 kV sag and perform the required work to improve the emergency rating	AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1039	Perform a sag study for the Madison – Cross Street 138 kV line and perform the required work to improve the emergency rating	AEP (100%)
b1040	Rebuild an 0.065 mile section of the New Carlisle – Olive 138 kV line and change the 138 kV line switches at New Carlisle	AEP (100%)
b1041	Perform a sag study for the Moseley - Roanoke 138 kV to increase the emergency rating	AEP (100%)
b1042	Perform sag studies to raise the emergency rating of Amos – Poca 138kV	AEP (100%)
b1043	Perform sag studies to raise the emergency rating of Turner - Ruth 138kV	AEP (100%)
b1044	Perform sag studies to raise the emergency rating of Kenova – South Point 138kV	AEP (100%)
b1045	Perform sag studies of Tri State - Darrah 138 kV	AEP (100%)
b1046	Perform sag study of Scottsville – Bremo 138kV to raise the emergency rating	AEP (100%)
b1047	Perform sag study of Otter Switch - Altavista 138kV to raise the emergency rating	AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1048	Reconductor the Bixby - Three C - Groves and Bixby - Groves 138 kV tower line	AEP (100%)
b1049	Upgrade the risers at the Riverside station to increase the rating of Benton Harbor – Riverside 138kV	AEP (100%)
b1050	Rebuilding and reconductor the Bixby – Pickerington Road - West Lancaster 138 kV line	AEP (100%)
b1051	Perform a sag study for the Kenzie Creek – Pokagon 138 kV line and perform the required work to improve the emergency rating	AEP (100%)
b1052	Unsix-wire the existing Hyatt - Sawmill 138 kV line to form two Hyatt - Sawmill 138 kV circuits	AEP (100%)
b1053	Perform a sag study and remediation of 32 miles between Claytor and Matt Funk.	AEP (100%)
b1091	Add 28.8 MVAR 138 kV capacitor bank at Huffman and 43.2 MVAR 138 kV Bank at Jubal Early and 52.8 MVAR 138 kV Bank at Progress Park Stations	AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1092	Add 28.8 MVAR 138 kV capacitor bank at Sullivan Gardens and 52.8 MVAR 138 kV Bank at Reedy Creek Stations	AEP (100%)
b1093	Add a 43.2 MVAR capacitor bank at the Morgan Fork 138 kV Station	AEP (100%)
b1094	Add a 64.8 MVAR capacitor bank at the West Huntington 138 kV Station	AEP (100%)
b1108	Replace Ohio Central 138 kV breaker 'C2'	AEP (100%)
b1109	Replace Ohio Central 138 kV breaker 'D1'	AEP (100%)
b1110	Replace Sporn A 138 kV breaker 'J'	AEP (100%)
b1111	Replace Sporn A 138 kV breaker 'J2'	AEP (100%)
b1112	Replace Sporn A 138 kV breaker 'L'	AEP (100%)
b1113	Replace Sporn A 138 kV breaker 'L1'	AEP (100%)
b1114	Replace Sporn A 138 kV breaker 'L2'	AEP (100%)
b1115	Replace Sporn A 138 kV breaker 'N'	AEP (100%)
b1116	Replace Sporn A 138 kV breaker 'N2'	AEP (100%)
b1227	Perform a sag study on Altavista – Leesville 138 kV circuit	AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1231 Replace the existing 138/69-12 kV transformer at West Moulton Station with a 138/69 kV transformer and a 69/12 kV transformer		AEP (96.69%) / Dayton (3.31%)
b1375 Replace Roanoke 138 kV breaker 'T'		AEP (100%)
b1376 Replace Roanoke 138 kV breaker 'E'		AEP (100%)
b1377 Replace Roanoke 138 kV breaker 'F'		AEP (100%)
b1378 Replace Roanoke 138 kV breaker 'G'		AEP (100%)
b1379 Replace Roanoke 138 kV breaker 'B'		AEP (100%)
b1380 Replace Roanoke 138 kV breaker 'A'		AEP (100%)
b1381 Replace Olive 345 kV breaker 'E'		AEP (100%)
b1382 Replace Olive 345 kV breaker 'R2'		AEP (100%)
b1416 Perform a sag study on the Desoto – Deer Creek 138 kV line to increase the emergency rating		AEP (100%)
b1417 Perform a sag study on the Delaware – Madison 138 kV line to increase the emergency rating		AEP (100%)
b1418 Perform a sag study on the Rockhill – East Lima 138 kV line to increase the emergency rating		AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1419 Perform a sag study on the Findlay Center – Fostoria Ctl 138 kV line to increase the emergency rating		AEP (100%)
b1420 A sag study will be required to increase the emergency rating for this line. Depending on the outcome of this study, more action may be required in order to increase the rating		AEP (100%)
b1421 Perform a sag study on the Sorenson – McKinley 138 kV line to increase the emergency rating		AEP (100%)
b1422 Perform a sag study on John Amos – St. Albans 138 kV line to allow for operation up to its conductor emergency rating		AEP (100%)
b1423 A sag study will be performed on the Chemical – Capitol Hill 138 kV line to determine if the emergency rating can be utilized		AEP (100%)
b1424 Perform a sag study for Benton Harbor – West Street – Hartford 138 kV line to improve the emergency rating		AEP (100%)
b1425 Perform a sag study for the East Monument – East Danville 138 kV line to allow for operation up to the conductor's maximum operating temperature		AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required	Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1426	Perform a sag study for the Reusens – Graves 138 kV line to allow for operation up to the conductor’s maximum operating temperature		AEP (100%)
b1427	Perform a sag study on Smith Mountain – Leesville – Altavista – Otter 138 kV and on Boones – Forest – New London – JohnsMT – Otter		AEP (100%)
b1428	Perform a sag study on Smith Mountain – Candler’s Mountain 138 kV and Joshua Falls – Cloverdale 765 kV to allow for operation up to		AEP (100%)
b1429	Perform a sag study on Fremont – Clinch River 138 kV to allow for operation up to its conductor emergency ratings		AEP (100%)
b1430	Install a new 138 kV circuit breaker at Benton Harbor station and move the load from Watervliet 34.5 kV station to West street 138 kV		AEP (100%)
b1432	Perform a sag study on the Kenova – Tri State 138 kV line to allow for operation up to their conductor emergency rating		AEP (100%)
b1433	Replace risers in the West Huntington Station to increase the line ratings which would eliminate the overloads for the contingencies listed		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1434 Perform a sag study on the line from Desoto to Madison. Replace bus and risers at Daleville station and replace bus and risers at Madison		AEP (100%)
b1435 Replace the 2870 MCM ACSR riser at the Sporn station		AEP (100%)
b1436 Perform a sag study on the Sorenson – Illinois Road 138 kV line to increase the emergency MOT for this line. Replace bus and risers at Illinois Road		AEP (100%)
b1437 Perform sag study on Rock Cr. – Hummel Cr. 138 kV to increase the emergency MOT for the line, replace bus and risers at Huntington J., and replace relays for Hummel Cr. – Hunt – Soren. Line at Soren		AEP (100%)
b1438 Replacement of risers at McKinley and Industrial Park stations and performance of a sag study for the 4.53 miles of 795 ACSR section is expected to improve the Summer Emergency rating to 335 MVA		AEP (100%)
b1439 By replacing the risers at Lincoln both the Summer Normal and Summer Emergency ratings will improve to 268 MVA		AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1440	By replacing the breakers at Lincoln the Summer Emergency rating will improve to 251 MVA	AEP (100%)
b1441	Replacement of risers at South Side and performance of a sag study for the 1.91 miles of 795 ACSR section is expected to improve the Summer Emergency rating to 335 MVA	AEP (100%)
b1442	Replacement of 954 ACSR conductor with 1033 ACSR and performance of a sag study for the 4.54 miles of 2-636 ACSR section is expected	AEP (100%)
b1443	Station work at Thelma and Busseyville Stations will be performed to replace bus and risers	AEP (100%)
b1444	Perform electrical clearance studies on Clinch River – Clinchfield 139 kV line (a.k.a. sag studies) to determine if the emergency ratings can be utilized	AEP (100%)
b1445	Perform a sag study on the Addison (Buckeye CO-OP) – Thinever and North Crown City – Thivener 138 kV sag study and switch	AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1446	Perform a sag study on the Parkersburg (Allegheny Power) – Belpre (AEP) 138 kV	AEP (100%)
b1447	Dexter – Elliot tap 138 kV sag check	AEP (100%)
b1448	Dexter – Meigs 138 kV Electrical Clearance Study	AEP (100%)
b1449	Meigs tap – Rutland 138 kV sag check	AEP (100%)
b1450	Muskingum – North Muskingum 138 kV sag check	AEP (100%)
b1451	North Newark – Sharp Road 138 kV sag check	AEP (100%)
b1452	North Zanesville – Zanesville 138 kV sag check	AEP (100%)
b1453	North Zanesville – Powelson and Ohio Central – Powelson 138 kV sag check	AEP (100%)
b1454	Perform an electrical clearance study on the Ross – Delano – Scioto Trail 138 kV line to determine if the emergency rating can be utilized	AEP (100%)
b1455	Perform a sag check on the Sunny – Canton Central – Wagenhals 138 kV line to determine if all circuits can be operated at their summer emergency rating	AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1456	The Tidd – West Bellaire 345 kV circuit has been de-rated to its normal rating and would need an electrical clearance study to determine if the emergency rating can be utilized	AEP (100%)
b1457	The Tiltonsville – Windsor 138 kV circuit has been derated to its normal rating and would need an electrical clearance study to determine if the emergency rating could be utilized	AEP (100%)
b1458	Install three new 345 kV breakers at Bixby to separate the Marquis 345 kV line and transformer #2. Operate Circleville – Harrison 138 kV and Harrison – Zuber 138 kV up to conductor emergency ratings	AEP (100%)
b1459	Several circuits have been de-rated to their normal conductor ratings and could benefit from electrical clearance studies to determine if the emergency rating could be utilized	AEP (100%)
b1460	Replace 2156 & 2874 risers	AEP (100%)
b1461	Replace meter, metering CTs and associated equipment at the Paden City feeder	AEP (100%)
b1462	Replace relays at both South Cadiz 138 kV and Tidd 138 kV	AEP (100%)

* Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b1463	Reconductor the Bexley – Groves 138 kV circuit		AEP (100%)
b1464	Corner 138 kV upgrades		AEP (100%)
b1465.1	Add a 3rd 2250 MVA 765/345 kV transformer at Sullivan station		AEC (0.71%) / AEP (75.06%) / APS (1.25%) / BGE (1.81%) / ComEd (5.91%) / Dayton (0.86%) / DL (1.23%) / DPL (0.95%) / Dominion (3.89%) / JCPL (1.58%) / NEPTUNE (0.15%) / HTP (0.07%) / PECO (2.08%) / PEPCO (1.66%) / ECP (0.07%)** / PSEG (2.62%) / RE (0.10%)
b1465.2	Replace the 100 MVAR 765 kV shunt reactor bank on Rockport – Jefferson 765 kV line with a 300 MVAR bank at Rockport Station		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
			DFAX Allocation: AEP (100%)

*Neptune Regional Transmission System, LLC

**East Coast Power, L.L.C.

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1465.3	Transpose the Rockport – Sullivan 765 kV line and the Rockport – Jefferson 765 kV line	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b1465.4	Make switching improvements at Sullivan and Jefferson 765 kV stations	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b1466.1	Create an in and out loop at Adams Station by removing the hard tap that currently exists	AEP (100%)
b1466.2	Upgrade the Adams transformer to 90 MVA	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1466.3	At Seaman Station install a new 138 kV bus and two new 138 kV circuit breakers	AEP (100%)
b1466.4	Convert South Central Co-op's New Market 69 kV Station to 138 kV	AEP (100%)
b1466.5	The Seaman – Highland circuit is already built to 138 kV, but is currently operating at 69 kV, which would now increase to 138 kV	AEP (100%)
b1466.6	At Highland Station, install a new 138 kV bus, three new 138 kV circuit breakers and a new 138/69 kV 90 MVA transformer	AEP (100%)
b1466.7	Using one of the bays at Highland, build a 138 kV circuit from Hillsboro – Highland 138 kV, which is approximately 3 miles	AEP (100%)
b1467.1	Install a 14.4 MVAR Capacitor Bank at New Buffalo station	AEP (100%)
b1467.2	Reconfigure the 138 kV bus at LaPorte Junction station to eliminate a contingency resulting in loss of two 138 kV sources serving the LaPorte area	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1468.1	Expand Selma Parker Station and install a 138/69/34.5 kV transformer	AEP (100%)
b1468.2	Rebuild and convert 34.5 kV line to Winchester to 69 kV, including Farmland Station	AEP (100%)
b1468.3	Retire the 34.5 kV line from Haymond to Selma Wire	AEP (100%)
b1469.1	Conversion of the Newcomerstown – Cambridge 34.5 kV system to 69 kV operation	AEP (100%)
b1469.2	Expansion of the Derwent 69 kV Station (including reconfiguration of the 69 kV system)	AEP (100%)
b1469.3	Rebuild 11.8 miles of 69 kV line, and convert additional 34.5 kV stations to 69 kV operation	AEP (100%)
b1470.1	Build a new 138 kV double circuit off the Kanawha – Bailysville #2 138 kV circuit to Skin Fork Station	AEP (100%)
b1470.2	Install a new 138/46 kV transformer at Skin Fork	AEP (100%)
b1470.3	Replace 5 Moab's on the Kanawha – Baileysville line with breakers at the Sundial 138 kV station	AEP (100%)
b1471	Perform a sag study on the East Lima – For Lima – Rockhill 138 kV line to increase the emergency rating	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1472	Perform a sag study on the East Lima – Haviland 138 kV line to increase the emergency rating	AEP (100%)
b1473	Perform a sag study on the East New Concord – Muskingum River section of the Muskingum River – West Cambridge 138 kV circuit	AEP (100%)
b1474	Perform a sag study on the Ohio Central – Prep Plant tap 138 kV circuit	AEP (100%)
b1475	Perform a sag study on the S73 – North Delphos 138 kV line to increase the emergency rating	AEP (100%)
b1476	Perform a sag study on the S73 – T131 138 kV line to increase the emergency rating	AEP (100%)
b1477	The Natrium – North Martin 138 kV circuit would need an electrical clearance study among other equipment upgrades	AEP (100%)
b1478	Upgrade Strouds Run – Strouds Tap 138 kV relay and riser	AEP (100%)
b1479	West Hebron station upgrades	AEP (100%)
b1480	Perform upgrades and a sag study on the Corner – Layman 138 kV section of the Corner – Muskingum River 138 kV circuit	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1481	Perform a sag study on the West Lima – Eastown Road – Rockhill 138 kV line and replace the 138 kV risers at Rockhill station to increase the emergency rating	AEP (100%)
b1482	Perform a sag study for the Albion – Robison Park 138 kV line to increase its emergency rating	AEP (100%)
b1483	Sag study 1 mile of the Clinch River – Saltville 138 kV line and replace the risers and bus at Clinch River, Lebanon and Elk Garden Stations	AEP (100%)
b1484	Perform a sag study on the Hacienda – Harper 138 kV line to increase the emergency rating	AEP (100%)
b1485	Perform a sag study on the Jackson Road – Concord 183 kV line to increase the emergency rating	AEP (100%)
b1486	The Matt Funk – Poages Mill – Starkey 138 kV line requires	AEP (100%)
b1487	Perform a sag study on the New Carlisle – Trail Creek 138 kV line to increase the emergency rating	AEP (100%)
b1488	Perform a sag study on the Olive – LaPorte Junction 138 kV line to increase the emergency rating	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1489	A sag study must be performed for the 5.40 mile Tristate – Chadwick 138 kV line to determine if a higher emergency rating can be used	AEP (100%)
b1490.1	Establish a new 138/69 kV Butler Center station	AEP (100%)
b1490.2	Build a new 14 mile 138 kV line from Auburn station to Woods Road station VIA Butler Center station	AEP (100%)
b1490.3	Replace the existing 40 MVA 138/69 kV transformer at Auburn station with a 90 MVA 138/96 kV transformer	AEP (100%)
b1490.4	Improve the switching arrangement at Kendallville station	AEP (100%)
b1491	Replace bus and risers at Thelma and Busseyville stations and perform a sag study for the Big Sandy – Busseyville 138 kV line	AEP (100%)
b1492	Reconductor 0.65 miles of the Glen Lyn – Wythe 138 kV line with 3 – 1590 ACSR	AEP (100%)
b1493	Perform a sag study for the Bellfonte – Grantston 138 kV line to increase its emergency rating	AEP (100%)
b1494	Perform a sag study for the North Proctorville – Solida – Bellefonte 138 kV line to increase its emergency rating	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1495	Add an additional 765/345 kV transformer at Baker Station	AEC (0.41%) / AEP (87.22%) / BGE (1.03%) / ComEd (3.38%) / Dayton (1.23%) / DL (1.46%) / DPL (0.54%) / JCPL (0.90%) / NEPTUNE (0.09%) / HTP (0.04%) / PECO (1.18%) / PEPCO (0.94%) / ECP** (0.04%) / PSEG (1.48%) / RE (0.06%)
b1496	Replace 138 kV bus and risers at Johnson Mountain Station	AEP (100%)
b1497	Replace 138 kV bus and risers at Leesville Station	AEP (100%)
b1498	Replace 138 kV risers at Wurno Station	AEP (100%)
b1499	Perform a sag study on Sporn A – Gavin 138 kV to determine if the emergency rating can be improved	AEP (100%)
b1500	The North East Canton – Wagenhals 138 kV circuit would need an electrical clearance study to determine if the emergency rating can be utilized	AEP (100%)
b1501	The Moseley – Reusens 138 kV circuit requires a sag study to determine if the emergency rating can be utilized to address a thermal loading issue for a category C3	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b1502	Reconductor the Conesville East – Conesville Prep Plant Tap 138 kV section of the Conesville – Ohio Central to fix Reliability N-1-1 thermal overloads		AEP (100%)
b1659	Establish Sorenson 345/138 kV station as a 765/345 kV station		AEP (93.61%) / ATSI (2.99%) / ComEd (2.07%) / HTP (0.03%) / PENELEC (0.31%) / ECP** (0.03%) / PSEG (0.92%) / RE (0.04%)
b1659.1	Replace Sorenson 138 kV breaker 'L1'		AEP (100%)
b1659.2	Replace Sorenson 138 kV breaker 'L2' breaker		AEP (100%)
b1659.3	Replace Sorenson 138 kV breaker 'M1'		AEP (100%)
b1659.4	Replace Sorenson 138 kV breaker 'M2'		AEP (100%)
b1659.5	Replace Sorenson 138 kV breaker 'N1'		AEP (100%)
b1659.6	Replace Sorenson 138 kV breaker 'N2'		AEP (100%)
b1659.7	Replace Sorenson 138 kV breaker 'O1'		AEP (100%)
b1659.8	Replace Sorenson 138 kV breaker 'O2'		AEP (100%)
b1659.9	Replace Sorenson 138 kV breaker 'M'		AEP (100%)
b1659.10	Replace Sorenson 138 kV breaker 'N'		AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b1659.11	Replace Sorenson 138 kV breaker 'O'		AEP (100%)
b1659.12	Replace McKinley 138 kV breaker 'L1'		AEP (100%)
b1659.13	Establish 765 kV yard at Sorenson and install four 765 kV breakers		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
			DFAX Allocation: AEP (75.95%) / Dayton (7.52%) / DEOK (12.77%) / EKPC (3.76%)
b1659.14	Build approximately 14 miles of 765 kV line from existing Dumont - Marysville line		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
			DFAX Allocation: AEP (71.06%) / ATSI (15.95%) / Dayton (7.10%) / DL (4.84%) / EKPC (0.77%) / OVEC (0.28%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1660	Install a 765/500 kV transformer at Cloverdale	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: Dayton (8.37%) / DEOK (21.94%) / Dominion (56.40%) / EKPC (13.29%)
b1661	Install a 765 kV circuit breaker at Wyoming station	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b1662	Rebuild 4 miles of 46 kV line to 138 kV from Pemberton to Cherry Creek		AEP (100%)
b1662.1	Circuit Breakers are installed at Cherry Creek (facing Pemberton) and at Pemberton (facing Tams Mtn. and Cherry Creek)		AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1662.2	Install three 138 kV breakers at Grandview Station (facing Cherry Creek, Hinton, and Bradley Stations)	AEP (100%)
b1662.3	Remove Sullivan Switching Station (46 kV)	AEP (100%)
b1663	Install a new 765/138 kV transformer at Jackson Ferry substation	AEP (100%)
b1663.1	Establish a new 10 mile double circuit 138 kV line between Jackson Ferry and Wythe	AEP (100%)
b1663.2	Install 2 765 kV circuit breakers, breaker disconnect switches and associated bus work for the new 765 kV breakers, and new relays for the 765 kV breakers at Jackson's Ferry	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEP (100%)
b1664	Install switched capacitor banks at Kenwood 138 kV stations	AEP (100%)
b1665	Install a second 138/69 kV transformer at Thelma station	AEP (100%)
b1665.1	Construct a single circuit 69 kV line from West Paintsville to the new Paintsville station	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b1665.2	Install new 7.2 MVAR, 46 kV bank at Kenwood Station		AEP (100%)
b1666	Build an 8 breaker 138 kV station tapping both circuits of the Fostoria - East Lima 138 kV line		AEP (90.65%) / Dayton (9.35%)
b1667	Establish Melmore as a switching station with both 138 kV circuits terminating at Melmore. Extend the double circuit 138 kV line from Melmore to Fremont Center		AEP (100%)
b1668	Revise the capacitor setting at Riverside 138 kV station		AEP (100%)
b1669	Capacitor setting changes at Ross 138 kV stations		AEP (100%)
b1670	Capacitor setting changes at Wooster 138 kV station		AEP (100%)
b1671	Install four 138 kV breakers in Danville area		AEP (100%)
b1676	Replace Natrium 138 kV breaker 'G (rehab)'		AEP (100%)
b1677	Replace Huntley 138 kV breaker '106'		AEP (100%)
b1678	Replace Kammer 138 kV breaker 'G'		AEP (100%)
b1679	Replace Kammer 138 kV breaker 'H'		AEP (100%)
b1680	Replace Kammer 138 kV breaker 'J'		AEP (100%)
b1681	Replace Kammer 138 kV breaker 'K'		AEP (100%)
b1682	Replace Kammer 138 kV breaker 'M'		AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b1683	Replace Kammer 138 kV breaker 'N'		AEP (100%)
b1684	Replace Clinch River 138 kV breaker 'E1'		AEP (100%)
b1685	Replace Lincoln 138 kV breaker 'D'		AEP (100%)
b1687	Advance s0251.7 (Replace Corrid 138 kV breaker '104S')		AEP (100%)
b1688	Advance s0251.8 (Replace Corrid 138 kV breaker '104C')		AEP (100%)
b1712.1	Perform sag study on Altavista - Leesville 138 kV line		Dominion (75.30%) / PEPCO (24.70%)
b1712.2	Rebuild the Altavista - Leesville 138 kV line		Dominion (75.30%) / PEPCO (24.70%)
b1733	Perform a sag study of the Bluff Point - Jauby 138 kV line. Upgrade breaker, wavetrap, and risers at the terminal ends		AEP (100%)
b1734	Perform a sag study of Randolph - Hodgins 138 kV line. Upgrade terminal equipment		AEP (100%)
b1735	Perform a sag study of R03 - Magely 138 kV line. Upgrade terminal equipment		AEP (100%)
b1736	Perform a sag study of the Industrial Park - Summit 138 kV line		AEP (100%)
b1737	Sag study of Newcomerstown - Hillview 138 kV line. Upgrade - terminal equipment		AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1738	Perform a sag study of the Wolf Creek - Layman 138 kV line. -Upgrade terminal equipment including a 138 kV breaker and wavetrap	AEP (100%)
b1739	Perform a sag study of the Ohio Central - West Trinway 138 kV line	AEP (100%)
b1741	Replace Beatty 138 kV breaker '2C(IPP)'	AEP (100%)
b1742	Replace Beatty 138 kV breaker '1E'	AEP (100%)
b1743	Replace Beatty 138 kV breaker '2E'	AEP (100%)
b1744	Replace Beatty 138 kV breaker '3C'	AEP (100%)
b1745	Replace Beatty 138 kV breaker '2W'	AEP (100%)
b1746	Replace St. Claire 138 kV breaker '8'	AEP (100%)
b1747	Replace Cloverdale 138 kV breaker 'C'	AEP (100%)
b1748	Replace Cloverdale 138 kV breaker 'D1'	AEP (100%)
b1780	Install two 138kV breakers and two 138kV circuit switchers at South Princeton Station and one 138kV breaker and one 138kV circuit switcher at Switchback Station	AEP (100%)
b1781	Install three 138 kV breakers and a 138kV circuit switcher at Trail Fork Station in Pineville, WV	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1782	Install a 46kV Moab at Montgomery Station facing Carbondale (on the London - Carbondale 46 kV circuit)	AEP (100%)
b1783	Add two 138 kV Circuit Breakers and two 138 kV circuit switchers on the Lonesome Pine - South Bluefield 138 kV line	AEP (100%)
b1784	Install a 52.8 MVAR capacitor bank at the Clifford 138 kV station	AEP (100%)
b1811.1	Perform a sag study of 4 miles of the Waterford - Muskingum line	AEP (100%)
b1811.2	Rebuild 0.1 miles of Waterford - Muskingum 345 kV with 1590 ACSR	AEP (100%)
b1812	Reconductor the AEP portion of the South Canton - Harmon 345 kV with 954 ACSR and upgrade terminal equipment at South Canton. Expected rating is 1800 MVA S/N and 1800 MVA S/E	AEP (100%)
b1817	Install (3) 345 kV circuit breakers at East Elkhart station in ring bus designed as a breaker and half scheme	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1818	Expand the Allen station by installing a second 345/138 kV transformer and adding four 138 kV exits by cutting in the Lincoln - Sterling and Milan - Timber Switch 138 kV double circuit tower line	AEP (88.30%) / ATSI (8.86%) / Dayton (2.84%)
b1819	Rebuild the Robinson Park - Sorenson 138 kV line corridor as a 345 kV double circuit line with one side operated at 345 kV and one side at 138 kV	AEP (87.18%) / ATSI (10.06%) / Dayton (2.76%)
b1859	Perform a sag study for Hancock - Cave Spring - Roanoke 138 kV circuit to reach new SE ratings of 272MVA (Cave Spring-Hancock), 205MVA (Cave Spring-Sunscape), 245MVA (ROANO2-Sunscape)	AEP (100%)
b1860	Perform a sag study on the Crooksville - Spencer Ridge section (14.3 miles) of the Crooksville-Poston-Strouds Run 138 kV circuit to see if any remedial action needed to reach the SE rating (175MVA)	AEP (100%)
b1861	Reconductor 0.83 miles of the Dale - West Canton 138 kV Tie-line and upgrade risers at West Canton 138 kV	AEP (100%)
b1862	Perform a sag study on the Grant - Greentown 138 kV circuit and replace the relay CT at Grant 138 kV station to see if any remedial action needed to reach the new ratings of 251/286MVA	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1863	Perform a sag study of the Kammer - Wayman SW 138 kV line to see if any remedial action needed to reach the new SE rating of 284MVA	AEP (100%)
b1864.1	Add two additional 345/138 kV transformers at Kammer	AEP (87.22%) / APS (8.22%) / ATSI (3.52%) / DL (1.04%)
b1864.2	Add second West Bellaire - Brues 138 kV circuit	AEP (87.22%) / APS (8.22%) / ATSI (3.52%) / DL (1.04%)
b1864.3	Replace Kammer 138 kV breaker 'E'	AEP (100%)
b1865	Perform a sag study on the Kanawha - Carbondale 138 kV line to see if any remedial action needed to reach the new ratings of 251/335MVA	AEP (100%)
b1866	Perform a sag study on the Clinch River-Lock Hart-Dorton 138kV line,increase the Relay Compliance Trip Limit at Clinch River on the C.R.-Dorton 138kV line to 310 and upgrade the risers with 1590ACSR	AEP (100%)
b1867	Perform a sag study on the Newcomerstown - South Coshocton 138 kV line to see if any remedial action is needed to reach the new SE rating of 179MVA	AEP (100%)
b1868	Perform sag study on the East Lima - new Liberty 138 kV line to see if any remedial action is needed to reach the new SE rating of 219MVA	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1869	Perform a sag study of the Ohio Central - South Coshocton 138 kV circuit to see if any remedial action needed to reach the new SE ratings of 250MVA	AEP (100%)
b1870	Replace the Ohio Central transformer #1 345/138/12 kV 450 MVA for a 345/138/34.5 kV 675 MVA transformer	AEP (68.16%) / ATSI (25.27%) / Dayton (3.88%) / PENELEC (1.59%) / DEOK (1.10%)
b1871	Perform a sag study on the Central - West Coshocton 138 kV line (improving the emergency rating of this line to 254 MVA)	AEP (100%)
b1872	Add a 57.6 MVA capacitor bank at East Elkhart 138 kv station in Indiana	AEP (100%)
b1873	Install two 138 kV circuit breakers at Cedar Creek Station and primary side circuit switcher on the 138/69/46 kV transformer	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1874	Install two 138 kV circuit breakers and one 138 kV circuit switcher at Magely 138 kV station in Indiana	AEP (100%)
b1875	Build 25 miles of new 138 kV line from Bradley Station through Tower 117 Station and terminating at McClung 138 kV station. Existing 69 kV distribution transformers will be replaced with 138 kV transformers	APS (100%)
b1876	Install a 14.4 MVar capacitor bank at Capital Avenue (AKA Currant Road) 34.5 kV bus	AEP (100%)
b1877	Relocate 138 kV Breaker G to the West Kingsport - Industry Drive 138 kV line and Remove 138 kV MOAB	AEP (100%)
b1878	Perform a sag study on the Lincoln - Robinson Park 138 kV line (Improve the emergency rating to 244 MVA)	AEP (100%)
b1879	Perform a sag study on the Hansonville - Meadowview 138 kV line (Improve the emergency rating to 245 MVA)	AEP (100%)
b1880	Rebuild the 15 miles of the Moseley - Roanoke 138 kV line. This project would consist of rebuilding both circuits on the double circuit line	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement		Responsible Customer(s)
b1881	Replace existing 600 Amp switches, station risers and increase the CT ratios associated with breaker 'G' at Sterling 138 kV Station. It will increase the rating to 296 MVA S/N and 384 MVA S/E		AEP (100%)
b1882	Perform a sag study on the Bluff Point - Randolph 138 kV line to see if any remedial action needed to reach the new SE rating of 255 MVA		AEP (100%)
b1883	Switch the breaker position of transformer #1 and SW Lima at East Lima 345 kV bus		AEP (100%)
b1884	Perform a sag study on Strawton station - Fisher Body - Deer Creek 138 kV line to see if any remedial action needed to reach the new SE rating of 250 MVA		AEP (100%)
b1887	Establish a new 138/69 kV source at Carrollton and construct two new 69 kV lines from Carrollton to tie into the Dennison - Miller SW 69 kV line and to East Dover 69 kV station respectively		AEP (100%)
b1888	Install a 69 kV line breaker at Blue Pennant 69 kV Station facing Bim Station and 14.4 MVar capacitor bank		AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1889	Install a 43.2 MVAR capacitor bank at Hinton 138 kV station (APCO WV)	AEP (100%)
b1901	Rebuild the Ohio Central - West Trinway (4.84 miles) section of the Academia - Ohio Central 138 kV circuit. Upgrade the Ohio Central riser, Ohio Central switch and the West Trinway riser	AEP (100%)
b1904.1	Construct new 138/69 Michiana Station near Bridgman by tapping the new Carlisle - Main Street 138 kV and the Bridgman - Buchanan Hydro 69 kV line	AEP (100%)
b1904.2	Establish a new 138/12 kV New Galien station by tapping the Olive - Hickory Creek 138 kV line	AEP (100%)
b1904.3	Retire the existing Galien station and move its distribution load to New Galien station. Retire the Buchanan Hydro - New Carlisle 34.5 kV line	AEP (100%)
b1904.4	Implement an in and out scheme at Cook 69 kV by eliminating the Cook 69 kV tap point and by installing two new 69 kV circuit breakers	AEP (100%)
b1904.5	Rebuild the Bridgman - Cook 69 kV and the Derby - Cook 69 kV lines	AEP (100%)
b1946	Perform a sag study on the Brues – West Bellaire 138 kV line	AEP (100%)
b1947	A sag study of the Dequine - Meadowlake 345 kV line #1 line may improve the emergency rating to 1400 MVA	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1948	Establish a new 765/345 interconnection at Sporn. Install a 765/345 kV transformer at Mountaineer and build ¾ mile of 345 kV to Sporn	ATSI (61.08%) / DL (21.87%) / Dominion (13.97%) / PENELEC (3.08%)
b1949	Perform a sag study on the Grant Tap – Deer Creek 138 kV line and replace bus and risers at Deer Creek station	AEP (100%)
b1950	Perform a sag study on the Kammer – Ormet 138 kV line of the conductor section	AEP (100%)
b1951	Perform a sag study of the Maddox- Convoy 345 kV line to improve the emergency rating to 1400 MVA	AEP (100%)
b1952	Perform a sag study of the Maddox – T130 345 kV line to improve the emergency rating to 1400 MVA	AEP (100%)
b1953	Perform a sag study of the Meadowlake - Olive 345 kV line to improve the emergency rating to 1400 MVA	AEP (100%)
b1954	Perform a sag study on the Milan - Harper 138 kV line and replace bus and switches at Milan Switch station	AEP (100%)
b1955	Perform a sag study of the R-049 - Tillman 138 kV line may improve the emergency rating to 245 MVA	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1956 Perform a sag study of the Tillman - Dawkins 138 kV line may improve the emergency rating to 245 MVA		AEP (100%)
b1957 Terminate Transformer #2 at SW Lima in a new bay position		AEP (69.41%) / ATSI (23.11%) / ECP** (0.17%) / HTP (0.19%) / PENELEC (2.42%) / PSEG (4.52%) / RE (0.18%)
b1958 Perform a sag study on the Brookside - Howard 138 kV line and replace bus and risers at AEP Howard station		AEP (100%)
b1960 Sag Study on 7.2 miles SE Canton-Canton Central 138kV ckt		AEP (100%)
b1961 Sag study on the Southeast Canton – Sunnyside 138kV line		AEP (100%)

*Neptune Regional Transmission System, LLC

**East Coast Power, L.L.C.

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1962	Add four 765 kV breakers at Kammer	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b1963	Build approximately 1 mile of circuit comprising of 2-954 ACSR to get the rating of Waterford-Muskinum 345 kV higher	AEP (100%)
b1970	Reconductor 13 miles of the Kammer – West Bellaire 345kV circuit	APS (33.51%) / ATSI (32.21%) / DL (18.64%) / Dominion (6.01%) / ECP** (0.10%) / HTP (0.11%) / JCPL (1.68%) / Neptune* (0.18%) / PENELEC (4.58%) / PSEG (2.87%) / RE (0.11%)
b1971	Perform a sag study to improve the emergency rating on the Bridgville – Chandlersville 138 kV line	AEP (100%)
b1972	Replace disconnect switch on the South Canton 765/345 kV transformer	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1973	Perform a sag study to improve the emergency rating on the Carrollton – Sunnyside 138 kV line	AEP (100%)
b1974	Perform a sag study to improve the emergency rating on the Bethel Church – West Dover 138 kV line	AEP (100%)
b1975	Replace a switch at South Millersburg switch station	AEP (100%)
b2017	Reconductor or rebuild Sporn - Waterford - Muskingum River 345 kV line	ATSI (37.04%) / AEP (34.35%) / DL (10.41%) / Dominion (6.19%) / APS (3.94%) / PENELEC (3.09%) / JCPL (1.39%) / Dayton (1.20%) / Neptune* (0.14%) / HTP (0.09%) / ECP** (0.08%) / PSEG (2.00%) / RE (0.08%)
b2018	Loop Conesville - Bixby 345 kV circuit into Ohio Central	ATSI (58.58%) / AEP (14.16%) / APS (12.88%) / DL (7.93%) / PENELEC (5.73%) / Dayton (0.72%)
b2019	Establish Burger 345/138 kV station	AEP (93.74%) / APS (4.40%) / DL (1.11%) / ATSI (0.74%) / PENELEC (0.01%)
b2020	Rebuild Amos - Kanawah River 138 kV corridor	AEP (88.39%) / APS (7.12%) / ATSI (2.89%) / DEOK (1.58%) / PEPCO (0.02%)
b2021	Add 345/138 transformer at Sporn, Kanawah River & Muskingum River stations	AEP (91.92%) / DEOK (3.60%) / APS (2.19%) / ATSI (1.14%) / DL (1.08%) / PEPCO (0.04%) / BGE (0.03%)
b2021.1	Replace Kanawah 138 kV breaker 'L'	AEP (100%)
b2021.2	Replace Muskingum 138 kV breaker 'HG'	AEP (100%)

*Neptune Regional Transmission System, LLC

**East Coast Power, L.L.C.

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2021.3	Replace Muskingum 138 kV breaker 'HJ'		AEP (100%)
b2021.4	Replace Muskingum 138 kV breaker 'HE'		AEP (100%)
b2021.5	Replace Muskingum 138 kV breaker 'HD'		AEP (100%)
b2021.6	Replace Muskingum 138 kV breaker 'HF'		AEP (100%)
b2021.7	Replace Muskingum 138 kV breaker 'HC'		AEP (100%)
b2021.8	Replace Sporn 138 kV breaker 'D1'		AEP (100%)
b2021.9	Replace Sporn 138 kV breaker 'D2'		AEP (100%)
b2021.10	Replace Sporn 138 kV breaker 'F1'		AEP (100%)
b2021.11	Replace Sporn 138 kV breaker 'F2'		AEP (100%)
b2021.12	Replace Sporn 138 kV breaker 'G'		AEP (100%)
b2021.13	Replace Sporn 138 kV breaker 'G2'		AEP (100%)
b2021.14	Replace Sporn 138 kV breaker 'N1'		AEP (100%)
b2021.15	Replace Kanawah 138 kV breaker 'M'		AEP (100%)
b2022	Terminate Tristate - Kyger Creek 345 kV line at Sporn		AEP (97.99%) / DEOK (2.01%)
b2027	Perform a sag study of the Tidd - Collier 345 kV line		AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2028	Perform a sag study on East Lima - North Woodcock 138 kV line to improve the rating	AEP (100%)
b2029	Perform a sag study on Bluebell - Canton Central 138 kV line to improve the rating	AEP (100%)
b2030	Install 345 kV circuit breakers at West Bellaire	AEP (100%)
b2031	Sag study on Tilton - W. Bellaire section 1 (795 ACSR), about 12 miles	AEP (100%)
b2032	Rebuild 138 kV Elliot tap - Poston line	ATSI (73.02%) / Dayton (19.39%) / DL (7.59%)
b2033	Perform a sag study of the Brues - W. Bellaire 138 kV line	AEP (100%)
b2046	Adjust tap settings for Muskingum River transformers	AEP (100%)
b2047	Replace relay at Greenlawn	AEP (100%)
b2048	Replace both 345/138 kV transformers with one bigger transformer	AEP (92.49%) / Dayton (7.51%)
b2049	Replace relay	AEP (100%)
b2050	Perform sag study	AEP (100%)
b2051	Install 3 138 kV breakers and a circuit switcher at Dorton station	AEP (100%)
b2052	Replace transformer	AEP (67.17%) / ATSI (27.37%) / Dayton (3.73%) / PENELEC (1.73%)
b2054	Perform a sag study of Sporn - Rutland 138 kV line	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2069	Replace George Washington 138 kV breaker 'A' with 63kA rated breaker	AEP (100%)
b2070	Replace Harrison 138 kV breaker '6C' with 63kA rated breaker	AEP (100%)
b2071	Replace Lincoln 138 kV breaker 'L' with 63kA rated breaker	AEP (100%)
b2072	Replace Natrum 138 kV breaker 'T' with 63kA rated breaker	AEP (100%)
b2073	Replace Darrah 138 kV breaker 'B' with 63kA rated breaker	AEP (100%)
b2074	Replace Wyoming 138 kV breaker 'G' with 80kA rated breaker	AEP (100%)
b2075	Replace Wyoming 138 kV breaker 'G1' with 80kA rated breaker	AEP (100%)
b2076	Replace Wyoming 138 kV breaker 'G2' with 80kA rated breaker	AEP (100%)
b2077	Replace Wyoming 138 kV breaker 'H' with 80kA rated breaker	AEP (100%)
b2078	Replace Wyoming 138 kV breaker 'H1' with 80kA rated breaker	AEP (100%)
b2079	Replace Wyoming 138 kV breaker 'H2' with 80kA rated breaker	AEP (100%)
b2080	Replace Wyoming 138 kV breaker 'J' with 80kA rated breaker	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2081	Replace Wyoming 138 kV breaker 'J1' with 80kA rated breaker	AEP (100%)
b2082	Replace Wyoming 138 kV breaker 'J2' with 80kA rated breaker	AEP (100%)
b2083	Replace Natrum 138 kV breaker 'K' with 63kA rated breaker	AEP (100%)
b2084	Replace Tanner Creek 345 kV breaker 'P' with 63kA rated breaker	AEP (100%)
b2085	Replace Tanner Creek 345 kV breaker 'P2' with 63kA rated breaker	AEP (100%)
b2086	Replace Tanner Creek 345 kV breaker 'Q1' with 63kA rated breaker	AEP (100%)
b2087	Replace South Bend 138 kV breaker 'T' with 63kA rated breaker	AEP (100%)
b2088	Replace Tidd 138 kV breaker 'L' with 63kA rated breaker	AEP (100%)
b2089	Replace Tidd 138 kV breaker 'M2' with 63kA rated breaker	AEP (100%)
b2090	Replace McKinley 138 kV breaker 'A' with 40kA rated breaker	AEP (100%)
b2091	Replace West Lima 138 kV breaker 'M' with 63kA rated breaker	AEP (100%)
b2092	Replace George Washington 138 kV breaker 'B' with 63kA rated breaker	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2093	Replace Turner 138 kV breaker 'W' with 63kA rated breaker	AEP (100%)
b2135	Build a new 138 kV line from Falling Branch to Merrimac and add a 138/69 kV transformer at Merrimac Station	AEP (100%)
b2160	Add a fourth circuit breaker to the station being built for the U4-038 project (Conelley), rebuild U4-038 - Grant Tap line as double circuit tower line	AEP (100%)
b2161	Rebuild approximately 20 miles of the Allen - S073 double circuit 138 kV line (with one circuit from Allen - Tillman - Timber Switch - S073 and the other circuit from Allen - T-131 - S073) utilizing 1033 ACSR	AEP (100%)
b2162	Perform a sag study to improve the emergency rating of the Belpre - Degussa 138 kV line	AEP (100%)
b2163	Replace breaker and wavetrap at Jay 138 kV station	AEP (100%)

*Neptune Regional Transmission System, LLC

SCHEDULE 12 – APPENDIX A

- (17) **American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1570.4	Add a 345 kV breaker at Marysville station and a 0.1 mile 345 kV line extension from Marysville to the new 345/69 kV Dayton transformer	AEP (100%)
b1660.1	Cloverdale: install 6-765 kV breakers, incremental work for 2 additional breakers, reconfigure and relocate miscellaneous facilities, establish 500 kV station and 500 kV tie with 765 kV station	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: Dayton (8.37%) / DEOK (21.94%) / Dominion (56.40%) / EKPC (13.29%)</p>

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b1797.1	Reconductor the AEP portion of the Cloverdale - Lexington 500 kV line with 2-1780 ACSS		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
			DFAX Allocation: AEP (0.79%) / APS (53.70%) / Dayton (0.15%) / DEOK (0.40%) / Dominion (1.13%) / EKPC (0.23%) / PEPCO (43.60%)
b2055	Upgrade relay at Brues station		AEP (100%)
b2122.3	Upgrade terminal equipment at Howard on the Howard - Brookside 138 kV line to achieve ratings of 252/291 (SN/SE)		AEP (100%)
b2122.4	Perform a sag study on the Howard - Brookside 138 kV line		AEP (100%)
b2229	Install a 300 MVAR reactor at Dequine 345 kV		AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2230	Replace existing 150 MVAR reactor at Amos 765 kV substation on Amos - N. Proctorville - Hanging Rock with 300 MVAR reactor	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b2231	Install 765 kV reactor breaker at Dumont 765 kV substation on the Dumont - Wilton Center line	AEP (100%)
b2232	Install 765 kV reactor breaker at Marysville 765 kV substation on the Marysville - Maliszewski line	AEP (100%)
b2233	Change transformer tap settings for the Baker 765/345 kV transformer	AEP (100%)
b2252	Loop the North Muskingum - Crooksville 138 kV line into AEP's Philo 138 kV station which lies approximately 0.4 miles from the line	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2253	Install an 86.4 MVAR capacitor bank at Gorsuch 138 kV station in Ohio		AEP (100%)
b2254	Rebuild approximately 4.9 miles of Corner - Degussa 138 kV line in Ohio		AEP (100%)
b2255	Rebuild approximately 2.8 miles of Maliszewski - Polaris 138 kV line in Ohio		AEP (100%)
b2256	Upgrade approximately 36 miles of 138 kV through path facilities between Harrison 138 kV station and Ross 138 kV station in Ohio		AEP (100%)
b2257	Rebuild the Pokagon - Corey 69 kV line as a double circuit 138 kV line with one side at 69 kV and the other side as an express circuit between Pokagon and Corey stations		AEP (100%)
b2258	Rebuild 1.41 miles of #2 CU 46 kV line between Tams Mountain - Slab Fork to 138 kV standards. The line will be strung with 1033 ACSR		AEP (100%)
b2259	Install a new 138/69 kV transformer at George Washington 138/69 kV substation to provide support to the 69 kV system in the area		AEP (100%)
b2286	Rebuild 4.7 miles of Muskingum River - Wolf Creek 138 kV line and remove the 138/138 kV transformer at Wolf Creek		AEP (100%)

	Station		
--	---------	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2287	Loop in the Meadow Lake - Olive 345 kV circuit into Reynolds 765/345 kV station		AEP (100%)
b2344.1	Establish a new 138/12 kV station, transfer and consolidate load from its Nicholasville and Marcellus 34.5 kV stations at this new station		AEP (100%)
b2344.2	Tap the Hydramatic – Valley 138 kV circuit (~ structure 415), build a new 138 kV line (~3.75 miles) to this new station		AEP (100%)
b2344.3	From this station, construct a new 138 kV line (~1.95 miles) to REA’s Marcellus station		AEP (100%)
b2344.4	From REA’s Marcellus station construct new 138 kV line (~2.35 miles) to a tap point on Valley – Hydramatic 138 kV ckt (~structure 434)		AEP (100%)
b2344.5	Retire sections of the 138 kV line in between structure 415 and 434 (~ 2.65 miles)		AEP (100%)
b2344.6	Retire AEP’s Marcellus 34.5/12 kV and Nicholasville 34.5/12 kV stations and also the Marcellus – Valley 34.5 kV line		AEP (100%)
b2345.1	Construct a new 69 kV line from Hartford to Keeler (~8 miles)		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2345.2	Rebuild the 34.5 kV lines between Keeler - Sister Lakes and Glenwood tap switch to 69 kV (~12 miles)		AEP (100%)
b2345.3	Implement in - out at Keeler and Sister Lakes 34.5 kV stations		AEP (100%)
b2345.4	Retire Glenwood tap switch and construct a new Rothadew station. These new lines will continue to operate at 34.5 kV		AEP (100%)
b2346	Perform a sag study for Howard - North Bellville - Millwood 138 kV line including terminal equipment upgrades		AEP (100%)
b2347	Replace the North Delphos 600A switch. Rebuild approximately 18.7 miles of 138 kV line North Delphos - S073. Reconductor the line and replace the existing tower structures		AEP (100%)
b2348	Construct a new 138 kV line from Richlands Station to intersect with the Hales Branch - Grassy Creek 138 kV circuit		AEP (100%)
b2374	Change the existing CT ratios of the existing equipment along Bearskin - Smith Mountain 138kV circuit		AEP (100%)
b2375	Change the existing CT ratios of the existing equipment along East Danville-Banister 138kV		AEP (100%)

	circuit		
--	---------	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2376	Replace the Turner 138 kV breaker 'D'		AEP (100%)
b2377	Replace the North Newark 138 kV breaker 'P'		AEP (100%)
b2378	Replace the Sporn 345 kV breaker 'DD'		AEP (100%)
b2379	Replace the Sporn 345 kV breaker 'DD2'		AEP (100%)
b2380	Replace the Muskingum 345 kV breaker 'SE'		AEP (100%)
b2381	Replace the East Lima 138 kV breaker 'E1'		AEP (100%)
b2382	Replace the Delco 138 kV breaker 'R'		AEP (100%)
b2383	Replace the Sporn 345 kV breaker 'AA2'		AEP (100%)
b2384	Replace the Sporn 345 kV breaker 'CC'		AEP (100%)
b2385	Replace the Sporn 345 kV breaker 'CC2'		AEP (100%)
b2386	Replace the Astor 138 kV breaker '102'		AEP (100%)
b2387	Replace the Muskingum 345 kV breaker 'SH'		AEP (100%)
b2388	Replace the Muskingum 345 kV breaker 'SI'		AEP (100%)
b2389	Replace the Hyatt 138 kV breaker '105N'		AEP (100%)
b2390	Replace the Muskingum 345 kV breaker 'SG'		AEP (100%)
b2391	Replace the Hyatt 138 kV breaker '101C'		AEP (100%)
b2392	Replace the Hyatt 138 kV breaker '104N'		AEP (100%)
b2393	Replace the Hyatt 138 kV breaker '104S'		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2394	Replace the Sporn 345 kV breaker 'CC1'		AEP (100%)
b2409	Install two 56.4 MVAR capacitor banks at the Melmore 138 kV station in Ohio		AEP (100%)
b2410	Convert Hogan Mullin 34.5 kV line to 138 kV, establish 138 kV line between Jones Creek and Strawton, rebuild existing Mullin Elwood 34.5 kV and terminate line into Strawton station, retire Mullin station		AEP (100%)
b2411	Rebuild the 3/0 ACSR portion of the Hadley - Kroemer Tap 69 kV line utilizing 795 ACSR conductor		AEP (100%)
b2423	Install a 300 MVAR shunt reactor at AEP's Wyoming 765 kV station		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
			DFAX Allocation: AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2444	Willow - Eureka 138 kV line: Reconductor 0.26 mile of 4/0 CU with 336 ACSS		AEP (100%)
b2445	Complete a sag study of Tidd - Mahans Lake 138 kV line		AEP (100%)
b2449	Rebuild the 7-mile 345 kV line between Meadow Lake and Reynolds 345 kV stations		AEP (100%)
b2462	Add two 138 kV circuit breakers at Fremont station to fix tower contingency '408 2'		AEP (100%)
b2501	Construct a new 138/69 kV Yager station by tapping 2-138 kV FE circuits (Nottingham-Cloverdale, Nottingham-Harmon)		AEP (100%)
b2501.2	Build a new 138 kV line from new Yager station to Azalea station		AEP (100%)
b2501.3	Close the 138 kV loop back into Yager 138 kV by converting part of local 69 kV facilities to 138 kV		AEP (100%)
b2501.4	Build 2 new 69 kV exits to reinforce 69 kV facilities and upgrade conductor between Irish Run 69 kV Switch and Bowerstown 69 kV Switch		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2502.1	Construct new 138 kV switching station Nottingham tapping 6-138 kV FE circuits (Holloway-Brookside, Holloway-Harmon #1 and #2, Holloway-Reeds, Holloway-New Stacy, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd station		AEP (100%)
b2502.2	Convert Freebyrd 69 kV to 138 kV		AEP (100%)
b2502.3	Rebuild/convert Freebyrd-South Cadiz 69 kV circuit to 138 kV		AEP (100%)
b2502.4	Upgrade South Cadiz to 138 kV breaker and a half		AEP (100%)
b2530	Replace the Sporn 138 kV breaker 'G1' with 80kA breaker		AEP (100%)
b2531	Replace the Sporn 138 kV breaker 'D' with 80kA breaker		AEP (100%)
b2532	Replace the Sporn 138 kV breaker 'O1' with 80kA breaker		AEP (100%)
b2533	Replace the Sporn 138 kV breaker 'P2' with 80kA breaker		AEP (100%)
b2534	Replace the Sporn 138 kV breaker 'U' with 80kA breaker		AEP (100%)
b2535	Replace the Sporn 138 kV breaker 'O' with 80 kA breaker		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2536	Replace the Sporn 138 kV breaker 'O2' with 80 kA breaker		AEP (100%)
b2537	Replace the Robinson Park 138 kV breakers A1, A2, B1, B2, C1, C2, D1, D2, E1, E2, and F1 with 63 kA breakers		AEP (100%)
b2555	Reconductor 0.5 miles Tiltonsville – Windsor 138 kV and string the vacant side of the 4.5 mile section using 556 ACSR in a six wire configuration		AEP (100%)
b2556	Install two 138 kV prop structures to increase the maximum operating temperature of the Clinch River- Clinch Field 138 kV line		AEP (100%)
b2581	Temporary operating procedure for delay of upgrade b1464. Open the Corner 138 kV circuit breaker 86 for an overload of the Corner – Washington MP 138 kV line. The tower contingency loss of Belmont – Trissler 138 kV and Belmont – Edgelawn 138 kV should be added to Operational contingency		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2591	Construct a new 69 kV line approximately 2.5 miles from Colfax to Drewry's. Construct a new Drewry's station and install a new circuit breaker at Colfax station.		AEP (100%)
b2592	Rebuild existing East Coshocton – North Coshocton double circuit line which contains Newcomerstown – N. Coshocton 34.5 kV Circuit and Coshocton – North Coshocton 69 kV circuit		AEP (100%)
b2593	Rebuild existing West Bellaire – Glencoe 69 kV line with 138 kV & 69 kV circuits and install 138/69 kV transformer at Glencoe Switch		AEP (100%)
b2594	Rebuild 1.0 mile of Brantley – Bridge Street 69 kV Line with 1033 ACSR overhead conductor		AEP (100%)
b2595.1	Rebuild 7.82 mile Elkhorn City – Haysi S.S 69 kV line utilizing 1033 ACSR built to 138 kV standards		AEP (100%)
b2595.2	Rebuild 5.18 mile Moss – Haysi SS 69 kV line utilizing 1033 ACSR built to 138 kV standards		AEP (100%)
b2596	Move load from the 34.5 kV bus to the 138 kV bus by installing a new 138/12 kV XF at New Carlisle station in Indiana		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2597	Rebuild approximately 1 mi. section of Dragoon-Virgil Street 34.5 kV line between Dragoon and Dodge Tap switch and replace Dodge switch MOAB to increase thermal capability of Dragoon-Dodge Tap branch		AEP (100%)
b2598	Rebuild approximately 1 mile section of the Kline-Virgil Street 34.5 kV line between Kline and Virgil Street tap. Replace MOAB switches at Beiger, risers at Kline, switches and bus at Virgil Street.		AEP (100%)
b2599	Rebuild approximately 0.1 miles of 69 kV line between Albion and Albion tap		AEP (100%)
b2600	Rebuild Fremont – Pound line as 138 kV		AEP (100%)
b2601	Fremont Station Improvements		AEP (100%)
b2601.1	Replace MOAB towards Beaver Creek with 138 kV breaker		AEP (100%)
b2601.2	Replace MOAB towards Clinch River with 138 kV breaker		AEP (100%)
b2601.3	Replace 138 kV Breaker A with new bus-tie breaker		AEP (100%)
b2601.4	Re-use Breaker A as high side protection on transformer #1		AEP (100%)
b2601.5	Install two (2) circuit switchers on high side of transformers # 2 and 3 at		AEP (100%)

	Fremont Station		
--	-----------------	--	--

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2602.1	Install 138 kV breaker E2 at North Proctorville		AEP (100%)
b2602.2	Construct 2.5 Miles of 138 kV 1033 ACSR from East Huntington to Darrah 138 kV substations		AEP (100%)
b2602.3	Install breaker on new line exit at Darrah towards East Huntington		AEP (100%)
b2602.4	Install 138 kV breaker on new line at East Huntington towards Darrah		AEP (100%)
b2602.5	Install 138 kV breaker at East Huntington towards North Proctorville		AEP (100%)
b2603	Boone Area Improvements		AEP (100%)
b2603.1	Purchase approximately a 200X300 station site near Slaughter Creek 46 kV station (Wilbur Station)		AEP (100%)
b2603.2	Install 3 138 kV circuit breakers, Cabin Creek to Hernshaw 138 kV circuit		AEP (100%)
b2603.3	Construct 1 mi. of double circuit 138 kV line on Wilbur – Boone 46 kV line with 1590 ACSS 54/19 conductor @ 482 Degree design temp. and 1-159 12/7 ACSR and one 86 Sq.MM. 0.646” OPGW Static wires		AEP (100%)
b2604	Bellefonte Transformer Addition		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2605	Rebuild and reconductor Kammer – George Washington 69 kV circuit and George Washington – Moundsville ckt #1, designed for 138kV. Upgrade limiting equipment at remote ends and at tap stations		AEP (100%)
b2606	Convert Bane – Hammondsville from 23 kV to 69 kV operation		AEP (100%)
b2607	Pine Gap Relay Limit Increase		AEP (100%)
b2608	Richlands Relay Upgrade		AEP (100%)
b2609	Thorofare – Goff Run – Powell Mountain 138 kV Build		AEP (100%)
b2610	Rebuild Pax Branch – Scaraboro as 138 kV		AEP (100%)
b2611	Skin Fork Area Improvements		AEP (100%)
b2611.1	New 138/46 kV station near Skin Fork and other components		AEP (100%)
b2611.2	Construct 3.2 miles of 1033 ACSR double circuit from new Station to cut into Sundial-Baileysville 138 kV line		AEP (100%)
b2634.1	Replace metering BCT on Tanners Creek CB T2 with a slip over CT with higher thermal rating in order to remove 1193 MVA limit on facility (Miami Fort-Tanners Creek 345 kV line)		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2643	Replace the Darrah 138 kV breaker 'L' with 40kA rated breaker		AEP (100%)
b2645	Ohio Central 138 kV Loop		AEP (100%)
b2667	Replace the Muskingum 138 kV bus # 1 and 2		AEP (100%)
b2668	Reconductor Dequine to Meadow Lake 345 kV circuit #1 utilizing dual 954 ACSR 54/7 cardinal conductor		AEP (100%)
b2669	Install a second 345/138 kV transformer at Desoto		AEP (100%)
b2670	Replace switch at Elk Garden 138 kV substation (on the Elk Garden – Lebanon 138 kV circuit)		AEP (100%)
b2671	Replace/upgrade/add terminal equipment at Bradley, Mullensville, Pinnacle Creek, Itmann, and Tams Mountain 138 kV substations. Sag study on Mullens – Wyoming and Mullens – Tams Mt. 138 kV circuits		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2687.1	Install a +/- 450 MVAR SVC at Jacksons Ferry 765 kV substation	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2687.2	Install a 300 MVAR shunt line reactor on the Broadford end of the Broadford – Jacksons Ferry 765 kV line	<p>Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b2697.1	Mitigate violations identified by sag study to operate Fieldale-Thornton-Franklin 138 kV overhead line conductor at its max. operating temperature. 6 potential line crossings to be addressed.	AEP (100%)
b2697.2	Replace terminal equipment at AEP's Danville and East Danville substations to improve thermal capacity of Danville – East Danville 138 kV circuit	AEP (100%)

*Neptune Regional Transmission System, LLC

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2698	Replace relays at AEP's Cloverdale and Jackson's Ferry substations to improve the thermal capacity of Cloverdale – Jackson's Ferry 765 kV line		AEP (100%)
b2701.1	Construct Herlan station as breaker and a half configuration with 9-138 kV CB's on 4 strings and with 2-28.8 MVAR capacitor banks		AEP (100%)
b2701.2	Construct new 138 kV line from Herlan station to Blue Racer station. Estimated approx. 3.2 miles of 1234 ACSS/TW Yukon and OPGW		AEP (100%)
2701.3	Install 1-138 kV CB at Blue Racer to terminate new Herlan circuit		AEP (100%)
b2714	Rebuild/upgrade line between Glencoe and Willow Grove Switch 69 kV		AEP (100%)
b2715	Build approximately 11.5 miles of 34.5 kV line with 556.5 ACSR 26/7 Dove conductor on wood poles from Flushing station to Smyrna station		AEP (100%)
b2727	Replace the South Canton 138 kV breakers 'K', 'J', 'J1', and 'J2' with 80kA breakers		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2731	Convert the Sunnyside – East Sparta – Malvern 23 kV sub-transmission network to 69 kV. The lines are already built to 69 kV standards		AEP (100%)
b2733	Replace South Canton 138 kV breakers ‘L’ and ‘L2’ with 80 kA rated breakers		AEP (100%)
b2750.1	Retire Betsy Layne 138/69/43 kV station and replace it with the greenfield Stanville station about a half mile north of the existing Betsy Layne station		AEP (100%)
b2750.2	Relocate the Betsy Layne capacitor bank to the Stanville 69 kV bus and increase the size to 14.4 MVAR		AEP (100%)
b2753.1	Replace existing George Washington station 138 kV yard with GIS 138 kV breaker and a half yard in existing station footprint. Install 138 kV revenue metering for new IPP connection		AEP (100%)
b2753.2	Replace Dilles Bottom 69/4 kV Distribution station as breaker and a half 138 kV yard design including AEP Distribution facilities but initial configuration will constitute a 3 breaker ring bus		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2753.3	Connect two 138 kV 6-wired circuits from “Point A” (currently de-energized and owned by FirstEnergy) in circuit positions previously designated Burger #1 & Burger #2 138 kV. Install interconnection settlement metering on both circuits exiting Holloway		AEP (100%)
b2753.6	Build double circuit 138 kV line from Dilles Bottom to “Point A”. Tie each new AEP circuit in with a 6-wired line at Point A. This will create a Dilles Bottom – Holloway 138 kV circuit and a George Washington – Holloway 138 kV circuit		AEP (100%)
b2753.7	Retire line sections (Dilles Bottom – Bellaire and Moundsville – Dilles Bottom 69 kV lines) south of FirstEnergy 138 kV line corridor, near “Point A”. Tie George Washington – Moundsville 69 kV circuit to George Washington – West Bellaire 69 kV circuit		AEP (100%)
b2753.8	Rebuild existing 69 kV line as double circuit from George Washington – Dilles Bottom 138 kV. One circuit will cut into Dilles Bottom 138 kV initially and the other will go past with future plans to cut in		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2760	Perform a Sag Study of the Saltville – Tazewell 138 kV line to increase the thermal rating of the line		AEP (100%)
b2761.1	Replace the Hazard 161/138 kV transformer		AEP (100%)
b2761.2	Perform a Sag Study of the Hazard – Wooten 161 kV line to increase the thermal rating of the line		AEP (100%)
b2761.3	Rebuild the Hazard – Wooten 161 kV line utilizing 795 26/7 ACSR conductor (300 MVA rating)		AEP (100%)
b2762	Perform a Sag Study of Nagel – West Kingsport 138 kV line to increase the thermal rating of the line		AEP (100%)
b2776	Reconductor the entire Dequine – Meadow Lake 345 kV circuit #2		AEP (100%)
b2777	Reconductor the entire Dequine – Eugene 345 kV circuit #1		<i>EKPC</i> (100%)
b2779.1	Construct a new 138 kV station, Campbell Road, tapping into the Grabill – South Hicksville 138 kV line		AEP (100%)
b2779.2	Reconstruct sections of the Butler-N.Hicksville and Auburn-Butler 69 kV circuits as 138 kV double circuit and extend 138 kV from Campbell Road station		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2779.3	Construct a new 345/138 kV SDI Wilmington Station which will be sourced from Collingwood 345 kV and serve the SDI load at 345 kV and 138 kV, respectively		AEP (100%)
b2779.4	Loop 138 kV circuits in-out of the new SDI Wilmington 138 kV station resulting in a direct circuit to Auburn 138 kV and an indirect circuit to Auburn and Rob Park via Dunton Lake, and a circuit to Campbell Road; Reconductor 138 kV line section between Dunton Lake – SDI Wilmington		AEP (100%)
b2779.5	Expand Auburn 138 kV bus		AEP (100%)
b2787	Reconductor 0.53 miles (14 spans) of the Kaiser Jct. - Air Force Jct. Sw section of the Kaiser - Heath 69 kV circuit/line with 336 ACSR to match the rest of the circuit (73 MVA rating, 78% loading)		AEP (100%)
b2788	Install a new 3-way 69 kV line switch to provide service to AEP's Barnesville distribution station. Remove a portion of the #1 copper T-Line from the 69 kV through-path		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2789	Rebuild the Brues - Glendale Heights 69 kV line section (5 miles) with 795 ACSR (128 MVA rating, 43% loading)	AEP (100%)
b2790	Install a 3 MVAR, 34.5 kV cap bank at Caldwell substation	AEP (100%)
b2791	Rebuild Tiffin – Howard, new transformer at Chatfield	AEP (100%)
b2791.1	Rebuild portions of the East Tiffin - Howard 69 kV line from East Tiffin to West Rockaway Switch (0.8 miles) using 795 ACSR Drake conductor (129 MVA rating, 50% loading)	AEP (100%)
b2791.2	Rebuild Tiffin - Howard 69 kV line from St. Stephen's Switch to Hinesville (14.7 miles) using 795 ACSR Drake conductor (90 MVA rating, non-conductor limited, 38% loading)	AEP (100%)
b2791.3	New 138/69 kV transformer with 138/69 kV protection at Chatfield	AEP (100%)
b2791.4	New 138/69 kV protection at existing Chatfield transformer	AEP (100%)
b2792	Replace the Elliott transformer with a 130 MVA unit, reconductor 0.42 miles of the Elliott – Ohio University 69 kV line with 556 ACSR to match the rest of the line conductor (102 MVA rating, 73% loading) and rebuild 4 miles of the Clark Street – Strouds R	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2793	Energize the spare Fremont Center 138/69 kV 130 MVA transformer #3. Reduces overloaded facilities to 46% loading		AEP (100%)
b2794	Construct new 138/69/34 kV station and 1-34 kV circuit (designed for 69 kV) from new station to Decliff station, approximately 4 miles, with 556 ACSR conductor (51 MVA rating)		AEP (100%)
b2795	Install a 34.5 kV 4.8 MVAR capacitor bank at Killbuck 34.5 kV station		AEP (100%)
b2796	Rebuild the Malvern - Oneida Switch 69 kV line section with 795 ACSR (1.8 miles, 125 MVA rating, 55% loading)		AEP (100%)
b2797	Rebuild the Ohio Central - Conesville 69 kV line section (11.8 miles) with 795 ACSR conductor (128 MVA rating, 57% loading). Replace the 50 MVA Ohio Central 138/69 kV XFMR with a 90 MVA unit		AEP (100%)
b2798	Install a 14.4 MVAR capacitor bank at West Hicksville station. Replace ground switch/MOAB at West Hicksville with a circuit switcher		AEP (100%)
b2799	Rebuild Valley - Almena, Almena - Hartford, Riverside - South Haven 69 kV lines. New line exit at Valley Station. New transformers at Almena and Hartford		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2799.1	Rebuild 12 miles of Valley – Almena 69 kV line as a double circuit 138/69 kV line using 795 ACSR conductor (360 MVA rating) to introduce a new 138 kV source into the 69 kV load pocket around Almena station	AEP (100%)
b2799.2	Rebuild 3.2 miles of Almena to Hartford 69 kV line using 795 ACSR conductor (90 MVA rating)	AEP (100%)
b2799.3	Rebuild 3.8 miles of Riverside – South Haven 69 kV line using 795 ACSR conductor (90 MVA rating)	AEP (100%)
b2799.4	At Valley station, add new 138 kV line exit with a 3000 A 40 kA breaker for the new 138 kV line to Almena and replace CB D with a 3000 A 40 kA breaker	AEP (100%)
b2799.5	At Almena station, install a 90 MVA 138/69 kV transformer with low side 3000 A 40 kA breaker and establish a new 138 kV line exit towards Valley	AEP (100%)
b2799.6	At Hartford station, install a second 90 MVA 138/69 kV transformer with a circuit switcher and 3000 A 40 kA low side breaker	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2817	Replace Delaware 138 kV breaker 'P' with a 40 kA breaker		AEP (100%)
b2818	Replace West Huntington 138 kV breaker 'F' with a 40 kA breaker		AEP (100%)
b2819	Replace Madison 138 kV breaker 'V' with a 63 kA breaker		AEP (100%)
b2820	Replace Sterling 138 kV breaker 'G' with a 40 kA breaker		AEP (100%)
b2821	Replace Morse 138 kV breakers '103', '104', '105', and '106' with 63 kA breakers		AEP (100%)
b2822	Replace Clinton 138 kV breakers '105' and '107' with 63 kA breakers		AEP (100%)
b2826.1	Install 300 MVAR reactor at Ohio Central 345 kV substation		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2826.2	Install 300 MVAR reactor at West Bellaire 345 kV substation		AEP (100%)
b2831.1	Upgrade the Tanner Creek – Miami Fort 345 kV circuit (AEP portion)		DFAX Allocation: Dayton (61.71%) / DEOK (37.68%) / OVEC (0.61%)
b2832	Six wire the Kyger Creek – Sporn 345 kV circuits #1 and #2 and convert them to one circuit		AEP (100%)
b2833	Reconductor the Maddox Creek – East Lima 345 kV circuit with 2-954 ACSS Cardinal conductor		DFAX Allocation: AEP (80.83%) / Dayton (18.73%) / OVEC (0.44%)
b2834	Reconductor and string open position and sixwire 6.2 miles of the Chemical – Capitol Hill 138 kV circuit		AEP (100%)
b2872	Replace the South Canton 138 kV breaker ‘K2’ with a 80 kA breaker		AEP (100%)
b2873	Replace the South Canton 138 kV breaker “M” with a 80 kA breaker		AEP (100%)
b2874	Replace the South Canton 138 kV breaker “M2” with a 80 kA breaker		AEP (100%)
b2878	Upgrade the Clifty Creek 345 kV risers		AEP (100%)
b2880	Rebuild approximately 4.77 miles of the Cannonsburg – South Neal 69 kV line section utilizing 795 ACSR conductor (90 MVA rating)		AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2881	Rebuild ~1.7 miles of the Dunn Hollow – London 46 kV line section utilizing 795 26/7 ACSR conductor (58 MVA rating, non-conductor limited)	AEP (100%)
b2882	Rebuild Reusens - Peakland Switch 69 kV line. Replace Peakland Switch	AEP (100%)
b2882.1	Rebuild the Reusens - Peakland Switch 69 kV line (approximately 0.8 miles) utilizing 795 ACSR conductor (86 MVA rating, non-conductor limited)	AEP (100%)
b2882.2	Replace existing Peakland S.S with new 3 way switch phase over phase structure	AEP (100%)
b2883	Rebuild the Craneco – Pardee – Three Forks – Skin Fork 46 kV line section (approximately 7.2 miles) utilizing 795 26/7 ACSR conductor (108 MVA rating)	AEP (100%)
b2884	Install a second transformer at Nagel station, comprised of 3 single phase 250 MVA 500/138 kV transformers. Presently, TVA operates their end of the Boone Dam – Holston 138 kV interconnection as normally open preemptively for the loss of the existing Nagel	AEP (100%)
b2885	New delivery point for City of Jackson	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2885.1	Install a new Ironman Switch to serve a new delivery point requested by the City of Jackson for a load increase request	AEP (100%)
b2885.2	Install a new 138/69 kV station (Rhodes) to serve as a third source to the area to help relieve overloads caused by the customer load increase	AEP (100%)
b2885.3	Replace Coalton Switch with a new three breaker ring bus (Heppner)	AEP (100%)
b2886	Install 90 MVA 138/69 kV transformer, new transformer high and low side 3000 A 40 kA CBs, and a 138 kV 40 kA bus tie breaker at West End Fostoria	AEP (100%)
b2887	Add 2-138 kV CB's and relocate 2-138 kV circuit exits to different bays at Morse Road. Eliminate 3 terminal line by terminating Genoa - Morse circuit at Morse Road	AEP (100%)
b2888	Retire Poston substation. Install new Lemaster substation	AEP (100%)
b2888.1	Remove and retire the Poston 138 kV station	AEP (100%)
b2888.2	Install a new greenfield station, Lemaster 138 kV Station, in the clear	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2888.3	Relocate the Trimble 69 kV AEP Ohio radial delivery point to 138 kV, to be served off of the Poston – Strouds Run – Crooksville 138 kV circuit via a new three-way switch. Retire the Poston - Trimble 69 kV line	AEP (100%)
b2889	Expand Cliffview station	AEP (100%)
b2889.1	Cliffview Station: Establish 138 kV bus. Install two 138/69 kV XFRs (130 MVA), six 138 kV CBs (40 kA 3000 A) and four 69 kV CBs (40 kA 3000 A)	AEP (100%)
b2889.2	Byllesby – Wythe 69 kV: Retire all 13.77 miles (1/0 CU) of this circuit (~4 miles currently in national forest)	AEP (100%)
b2889.3	Galax – Wythe 69 kV: Retire 13.53 miles (1/0 CU section) of line from Lee Highway down to Byllesby. This section is currently double circuited with Byllesby – Wythe 69 kV. Terminate the southern 3/0 ACSR section into the newly opened position at Byllesby	AEP (100%)
b2889.4	Cliffview Line: Tap the existing Pipers Gap – Jubal Early 138 kV line section. Construct double circuit in/out (~2 miles) to newly established 138 kV bus, utilizing 795 26/7 ACSR conductor	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2890.1	Rebuild 23.55 miles of the East Cambridge – Smyrna 34.5 kV circuit with 795 ACSR conductor (128 MVA rating) and convert to 69 kV	AEP (100%)
b2890.2	East Cambridge: Install a 2000 A 69 kV 40 kA circuit breaker for the East Cambridge – Smyrna 69 kV circuit	AEP (100%)
b2890.3	Old Washington: Install 69 kV 2000 A two way phase over phase switch	AEP (100%)
b2890.4	Install 69 kV 2000 A two way phase over phase switch	AEP (100%)
b2891	Rebuild the Midland Switch to East Findlay 34.5 kV line (3.31 miles) with 795 ACSR (63 MVA rating) to match other conductor in the area	AEP (100%)
b2892	Install new 138/12 kV transformer with high side circuit switcher at Leon and a new 138 kV line exit towards Ripley. Establish 138 kV at the Ripley station with a new 138/69 kV 130 MVA transformer and move the distribution load to 138 kV service	AEP (100%)
b2936.1	Rebuild approximately 6.7 miles of 69 kV line between Mottville and Pigeon River using 795 ACSR conductor (129 MVA rating). New construction will be designed to 138 kV standards but operated at 69 kV	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2936.2	Pigeon River Station: Replace existing MOAB Sw. 'W' with a new 69 kV 3000 A 40 kA breaker, and upgrade existing relays towards HMD station. Replace CB H with a 3000 A 40 kA breaker	AEP (100%)
b2937	Replace the existing 636 ACSR 138 kV bus at Fletchers Ridge with a larger 954 ACSR conductor	AEP (100%)
b2938	Perform a sag mitigations on the Broadford – Wolf Hills 138 kV circuit to allow the line to operate to a higher maximum temperature	AEP (100%)
b2958.1	Cut George Washington – Tidd 138 kV circuit into Sand Hill and reconfigure Brues & Warton Hill line entrances	AEP (100%)
b2958.2	Add 2 138 kV 3000 A 40 kA breakers, disconnect switches, and update relaying at Sand Hill station	AEP (100%)
b2968	Upgrade existing 345 kV terminal equipment at Tanner Creek station	AEP (100%)
b2969	Replace terminal equipment on Maddox Creek - East Lima 345 kV circuit	AEP (100%)
b2976	Upgrade terminal equipment at Tanners Creek 345 kV station. Upgrade 345 kV bus and risers at Tanners Creek for the Dearborn circuit	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2988	Replace the Twin Branch 345 kV breaker “JM” with 63 kA breaker and associated substation works including switches, bus leads, control cable and new DICM	AEP (100%)
b2993	Rebuild the Torrey – South Gambrinus Switch – Gambrinus Road 69 kV line section (1.3 miles) with 1033 ACSR ‘Curlew’ conductor and steel poles	AEP (100%)
b3000	Replace South Canton 138 kV breaker ‘N’ with an 80kA breaker	AEP (100%)
b3001	Replace South Canton 138 kV breaker ‘N1’ with an 80kA breaker	AEP (100%)
b3002	Replace South Canton 138 kV breaker ‘N2’ with an 80kA breaker	AEP (100%)
b3036	Rebuild 15.6 miles of Haviland - North Delphos 138 kV line	AEP (100%)
b3037	Upgrades at the Natrium substation	AEP (100%)
b3038	Reconductor the Capitol Hill – Coco 138 kV line section	AEP (100%)
b3039	Line swaps at Muskingum 138 kV station	AEP (100%)
b3040.1	Rebuild Ravenswood – Racine tap 69 kV line section (~15 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3040.2	Rebuild existing Ripley – Ravenswood 69 kV circuit (~9 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)
b3040.3	Install new 3-way phase over phase switch at Sarah Lane station to replace the retired switch at Cottageville	AEP (100%)
b3040.4	Install new 138/12 kV 20 MVA transformer at Polymer station to transfer load from Mill Run station to help address overload on the 69 kV network	AEP (100%)
b3040.5	Retire Mill Run station	AEP (100%)
b3040.6	Install 28.8 MVAR cap bank at South Buffalo station	AEP (100%)
b3051.2	Adjust CT tap ratio at Roncerverte 138 kV	AEP (100%)
b3085	Reconductor Kammer – George Washington 138 kV line (approx. 0.08 mile). Replace the wave trap at Kammer 138 kV	AEP (100%)
b3086.1	Rebuild New Liberty – Findlay 34 kV line Str's 1–37 (1.5 miles), utilizing 795 26/7 ACSR conductor	AEP (100%)
b3086.2	Rebuild New Liberty – North Baltimore 34 kV line Str's 1–11 (0.5 mile), utilizing 795 26/7 ACSR conductor	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3086.3	Rebuild West Melrose – Whirlpool 34 kV line Str's 55–80 (1 mile), utilizing 795 26/7 ACSR conductor	AEP (100%)
b3086.4	North Findlay station: Install a 138 kV 3000A 63kA line breaker and low side 34.5 kV 2000A 40kA breaker, high side 138 kV circuit switcher on T1	AEP (100%)
b3086.5	Ebersole station: Install second 90 MVA 138/69/34 kV transformer. Install two low side (69 kV) 2000A 40kA breakers for T1 and T2	AEP (100%)
b3087.1	Construct a new greenfield station to the west (approx. 1.5 miles) of the existing Fords Branch Station in the new Kentucky Enterprise Industrial Park. This station will consist of six 3000A 40kA 138 kV breakers laid out in a ring arrangement, two 30 MVA 138/34.5 kV transformers, and two 30 MVA 138/12 kV transformers. The existing Fords Branch Station will be retired	AEP (100%)
b3087.2	Construct approximately 5 miles of new double circuit 138 kV line in order to loop the new Kewanee station into the existing Beaver Creek – Cedar Creek 138 kV circuit	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3087.3	Remote end work will be required at Cedar Creek Station	AEP (100%)
b3087.4	Install 28.8 MVar switching shunt at the new Fords Branch substation	AEP (100%)
b3095	Rebuild Lakin – Racine Tap 69 kV line section (9.2 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)
b3099	Install a 138 kV 3000A 40 kA circuit switcher on the high side of the existing 138/34.5 kV transformer No.5 at Holston station	AEP (100%)
b3100	Replace the 138 kV MOAB switcher “YY” with a new 138 kV circuit switcher on the high side of Chemical transformer No.6	AEP (100%)
b3101	Rebuild the 1/0 Cu. conductor sections (approx. 1.5 miles) of the Fort Robinson – Moccasin Gap 69 kV line section (approx. 5 miles) utilizing 556 ACSR conductor and upgrade existing relay trip limit (WN/WE: 63 MVA, line limited by remaining conductor sections)	AEP (100%)
b3102	Replace existing 50 MVA 138/69 kV transformers #1 and #2 (both 1957 vintage) at Fremont station with new 130 MVA 138/69 kV transformers	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3103.1	Install a 138/69 kV transformer at Royerton station. Install a 69 kV bus with one 69 kV breaker toward Bosman station. Rebuild the 138 kV portion into a ring bus configuration built for future breaker and a half with four 138 kV breakers	AEP (100%)
b3103.2	Rebuild the Bosman/Strawboard station in the clear across the road to move it out of the flood plain and bring it up to 69 kV standards	AEP (100%)
b3103.3	Retire 138 kV breaker L at Delaware station and re-purpose 138 kV breaker M for the Jay line	AEP (100%)
b3103.4	Retire all 34.5 kV equipment at Hartford City station. Re-purpose breaker M for the Bosman line 69 kV exit	AEP (100%)
b3103.5	Rebuild the 138 kV portion of Jay station as a 6 breaker, breaker and a half station re-using the existing breakers "A", "B", and "G." Rebuild the 69 kV portion of this station as a 6 breaker ring bus re-using the 2 existing 69 kV breakers. Install a new 138/69 kV transformer	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3103.6	Rebuild the 69 kV Hartford City – Armstrong Cork line but instead of terminating it into Armstrong Cork, terminate it into Jay station	AEP (100%)
b3103.7	Build a new 69 kV line from Armstrong Cork – Jay station	AEP (100%)
b3103.8	Rebuild the 34.5 kV Delaware – Bosman line as the 69 kV Royerton – Strawboard line. Retire the line section from Royerton to Delaware stations	AEP (100%)
b3104	Perform a sag study on the Polaris – Westerville 138 kV line (approx. 3.6 miles) to increase the summer emergency rating to 310 MVA	AEP (100%)
b3105	Rebuild the Delaware – Hyatt 138 kV line (approx. 4.3 miles) along with replacing conductors at both Hyatt and Delaware substations	AEP (100%)
b3106	Perform a sag study (6.8 miles of line) to increase the SE rating to 310 MVA. Note that results from the sag study could cover a wide range of outcomes, from no work required to a complete rebuild	AEP (100%)
b3109	Rebuild 5.2 miles Bethel – Sawmill 138 kV line including ADSS	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3112	Construct a single circuit 138 kV line (approx. 3.5 miles) from Amlin to Dublin using 1033 ACSR Curlew (296 MVA SN), convert Dublin station into a ring configuration, and re-terminating the Britton UG cable to Dublin station	AEP (100%)
b3116	Replace existing Mullens 138/46 kV 30 MVA transformer No.4 and associated protective equipment with a new 138/46 kV 90 MVA transformer and associated protective equipment	AEP (100%)
b3118.1	Expand existing Chadwick station and install a second 138/69 kV transformer at a new 138 kV bus tied into the Bellefonte – Grangston 138 kV circuit. The 69 kV bus will be reconfigured into a ring bus arrangement to tie the new transformer into the existing 69 kV via installation of four 3000A 63 kA 69 kV circuit breakers	AEP (100%)
b3118.2	Perform 138 kV remote end work at Grangston station	AEP (100%)
b3118.3	Perform 138 kV remote end work at Bellefonte station	AEP (100%)
b3118.4	Relocate the Chadwick – Leach 69 kV circuit within Chadwick station	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3118.5	Terminate the Bellefonte – Grangston 138 kV circuit to the Chadwick 138 kV bus	AEP (100%)
b3118.6	Chadwick – Tri-State #2 138 kV circuit will be reconfigured within the station to terminate into the newly established 138 kV bus #2 at Chadwick due to constructability aspects	AEP (100%)
b3118.7	Reconductor Chadwick – Leach and Chadwick – England Hill 69 kV lines with 795 ACSS conductor. Perform a LiDAR survey and a sag study to confirm that the reconducted circuits would maintain acceptable clearances	AEP (100%)
b3118.8	Replace the 20 kA 69 kV circuit breaker ‘F’ at South Neal station with a new 3000A 40 kA 69 kV circuit breaker. Replace line risers towards Leach station	AEP (100%)
b3118.9	Rebuild 336 ACSR portion of Leach – Miller S.S 69 kV line section (approx. 0.3 mile) with 795 ACSS conductor	AEP (100%)
b3118.10	Replace 69 kV line risers (towards Chadwick) at Leach station	AEP (100%)
b3119.1	Rebuild the Jay – Pennville 138 kV line as double circuit 138/69 kV. Build a new 9.8 mile single circuit 69 kV line from near Pennville station to North Portland station	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3119.2	Install three (3) 69 kV breakers to create the “U” string and add a low side breaker on the Jay transformer 2	AEP (100%)
b3119.3	Install two (2) 69 kV breakers at North Portland station to complete the ring and allow for the new line	AEP (100%)
b3129	At Conesville 138 kV station: Remove line leads to generating units, transfer plant AC service to existing station service feeds in Conesville 345/138 kV yard, and separate and reconfigure protection schemes	AEP (100%)
b3131	At East Lima and Haviland 138 kV stations, replace line relays and wavetrap on the East Lima – Haviland 138 kV facility	AEP (100%)
b3132	Rebuild 3.11 miles of the LaPorte Junction – New Buffalo 69 kV line with 795 ACSR	AEP (100%)
b3139	Rebuild the Garden Creek – Whetstone 69 kV line (approx. 4 miles)	AEP (100%)
b3140	Rebuild the Whetstone – Knox Creek 69 kV line (approx. 3.1 miles)	AEP (100%)
b3141	Rebuild the Knox Creek – Coal Creek 69 kV line (approx. 2.9 miles)	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3148.1	Rebuild the 46 kV Bradley – Scarbro line to 96 kV standards using 795 ACSR to achieve a minimum rate of 120 MVA. Rebuild the new line adjacent to the existing one leaving the old line in service until the work is completed	AEP (100%)
b3148.2	Bradley remote end station work, replace 46 kV bus, install new 12 MVAR capacitor bank	AEP (100%)
b3148.3	Replace the existing switch at Sun substation with a 2-way SCADA-controlled motor-operated air-breaker switch	AEP (100%)
b3148.4	Remote end work and associated equipment at Scarbro station	AEP (100%)
b3148.5	Retire Mt. Hope station and transfer load to existing Sun station	AEP (100%)
b3149	Rebuild the 2.3 mile Decatur – South Decatur 69 kV line using 556 ACSR	AEP (100%)
b3150	Rebuild Ferguson 69/12 kV station in the clear as the 138/12 kV Bear station and connect it to an approx. 1 mile double circuit 138 kV extension from the Aviation – Ellison Road 138 kV line to remove the load from the 69 kV line	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3151.1	Rebuild the 30 mile Gateway – Wallen 34.5 kV circuit as the 27 mile Gateway – Wallen 69 kV line	AEP (100%)
b3151.2	Retire approx. 3 miles of the Columbia – Whitley 34.5 kV line	AEP (100%)
b3151.3	At Gateway station, remove all 34.5 kV equipment and install one (1) 69 kV circuit breaker for the new Whitley line entrance	AEP (100%)
b3151.4	Rebuild Whitley as a 69 kV station with two (2) lines and one (1) bus tie circuit breaker	AEP (100%)
b3151.5	Replace the Union 34.5 kV switch with a 69 kV switch structure	AEP (100%)
b3151.6	Replace the Eel River 34.5 kV switch with a 69 kV switch structure	AEP (100%)
b3151.7	Install a 69 kV Bobay switch at Woodland station	AEP (100%)
b3151.8	Replace the Carroll and Churubusco 34.5 kV stations with the 69 kV Snapper station. Snapper station will have two (2) line circuit breakers, one (1) bus tie circuit breaker and a 14.4 MVAR cap bank	AEP (100%)
b3151.9	Remove 34.5 kV circuit breaker “AD” at Wallen station	AEP (100%)
b3151.10	Rebuild the 2.5 miles of the Columbia – Gateway 69 kV line	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3151.11	Rebuild Columbia station in the clear as a 138/69 kV station with two (2) 138/69 kV transformers and 4-breaker ring buses on the high and low side. Station will reuse 69 kV breakers “J” & “K” and 138 kV breaker “D”	AEP (100%)
b3151.12	Rebuild the 13 miles of the Columbia – Richland 69 kV line	AEP (100%)
b3151.13	Rebuild the 0.5 mile Whitley – Columbia City No.1 line as 69 kV	AEP (100%)
b3151.14	Rebuild the 0.5 mile Whitley – Columbia City No.2 line as 69 kV	AEP (100%)
b3151.15	Rebuild the 0.6 mile double circuit section of the Rob Park – South Hicksville / Rob Park – Diebold Road as 69 kV	AEP (100%)
b3160.1	Construct an approx. 2.4 miles double circuit 138 kV extension using 1033 ACSR (Aluminum Conductor Steel Reinforced) to connect Lake Head to the 138 kV network	AEP (100%)
b3160.2	Retire the approx.2.5 miles 34.5 kV Niles – Simplicity Tap line	AEP (100%)
b3160.3	Retire the approx.4.6 miles Lakehead 69 kV Tap	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3160.4	Build new 138/69 kV drop down station to feed Lakehead with a 138 kV breaker, 138 kV switcher, 138/69 kV transformer and a 138 kV Motor-Operated Air Break	AEP (100%)
b3160.5	Rebuild the approx. 1.2 miles Buchanan South 69 kV Radial Tap using 795 ACSR (Aluminum Conductor Steel Reinforced)	AEP (100%)
b3160.6	Rebuild the approx. 8.4 miles 69 kV Pletcher – Buchanan Hydro line as the approx. 9 miles Pletcher – Buchanan South 69 kV line using 795 ACSR (Aluminum Conductor Steel Reinforced)	AEP (100%)
b3160.7	Install a PoP (Point-of-Presence) switch at Buchanan South station with 2 line MOABs (Motor-Operated Air Break)	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3208	Retire approximately 38 miles of the 44 mile Clifford – Scottsville 46 kV circuit. Build new 138 kV “in and out” to two new distribution stations to serve the load formerly served by Phoenix, Shipman, Schuyler (AEP), and Rockfish stations. Construct new 138 kV lines from Joshua Falls – Riverville (approx. 10 miles) and Riverville – Gladstone (approx. 5 miles). Install required station upgrades at Joshua Falls, Riverville and Gladstone stations to accommodate the new 138 kV circuits. Rebuild Reusen – Monroe 69 kV (approx. 4 miles)	AEP (100%)
b3209	Rebuild the 10.5 mile Berne – South Decatur 69 kV line using 556 ACSR	AEP (100%)
b3210	Replace approx. 0.7 mile Beatty – Galloway 69 kV line with 4000 kcmil XLPE cable	AEP (100%)
b3220	Install 14.4 MVAR capacitor bank at Whitewood 138 kV	AEP (100%)
b3261	Upgrade circuit breaker “R1” at Tanners Creek 345 kV. Install Transient Recovery Voltage capacitor to increase the rating from 50 kA to 63 kA	AEP (100%)

American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3269	At West New Philadelphia station, add a high side 138 kV breaker on the 138/69 kV Transformer #2 along with a 138 kV breaker on the line towards Newcomerstown	AEP (100%)
b3270	Install 1.7 miles of 795 ACSR 138 kV conductor along the other side of Dragoon Tap 138 kV line, which is currently double circuit tower with one position open. Additionally, install a second 138/34.5 kV transformer at Dragoon, install a high side circuit switcher on the current transformer at the Dragoon Station, and install two (2) 138 kV line breakers on the Dragoon – Jackson 138 kV and Dragoon – Twin Branch 138 kV lines	AEP (100%)
b3270.1	Replace Dragoon 34.5 kV breakers “B”, “C”, and “D” with 40 kA breakers	AEP (100%)
b3271	Install a 138 kV circuit breaker at Fremont station on the line towards Fremont Center and install a 9.6 MVAR 69 kV capacitor bank at Bloom Road station	AEP (100%)
b3272	Install two 138 kV circuit switchers on the high side of 138/34.5 kV Transformers #1 and #2 at Rockhill station	AEP (100%)

ATTACHMENT L
List of Transmission Owners

Allegheny Electric Cooperative, Inc.
American Transmission Systems, Incorporated
Atlantic City Electric Company
Baltimore Gas and Electric Company
Delmarva Power & Light Company
Duke Energy Ohio, Inc.
Duke Energy Kentucky, Inc.
East Kentucky Power Cooperative, Inc.
Essential Power Rock Springs, LLC
Hudson Transmission Partners, LLC
ITC Interconnection LLC
Jersey Central Power & Light Company
Mid-Atlantic Interstate Transmission, LLC
Neptune Regional Transmission System, LLC
Old Dominion Electric Cooperative
PECO Energy Company
Pennsylvania Power & Light Company
Potomac Electric Power Company
Public Service Electric and Gas Company
Rockland Electric Company
Trans-Allegheny Interstate Line Company
Transource West Virginia, LLC
UGI Utilities, Inc.
Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power
Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.
The Dayton Power and Light Company
American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company
Duquesne Light Company
Virginia Electric and Power Company
Linden VFT, LLC
City of Cleveland, Department of Public Utilities, Division of Cleveland Public Power
City of Hamilton, OH
Southern Maryland Electric Cooperative, Inc.
Ohio Valley Electric Cooperative
AMP Transmission, LLC
Silver Run Electric, LLC
NextEra Energy Transmission MidAtlantic Indiana, Inc.

Wabash Valley Power Association, Inc.