



PJM Interconnection, L.L.C.
2750 Monroe Blvd.
Audubon, PA 19403-2497

Chenchao Lu
Associate General Counsel
T: 610.666.2255 | F: 610.666.8211

August 28, 2023

Kimberly D. Bose, Secretary
Federal Energy Regulatory Commission
888 First Street, N.E.
Washington, D.C. 20426-0001

*Re: PJM Interconnection, L.L.C., Docket No. ER23-2714-000
Governing Document Enhancements and Clarifications Tariff and Operating
Agreement Revisions*

Dear Secretary Bose,

Pursuant to Section 205 of the Federal Power Act (“FPA”),¹ and Part 35 of the Federal Energy Regulatory Commission’s (“Commission”) Regulations,² PJM Interconnection, L.L.C. (“PJM”) hereby submits for filing clerical and ministerial revisions to correct, clarify, and/or make consistent certain provisions of the PJM Open Access Transmission Tariff (“Tariff”), the Amended and Restated Operating Agreement of PJM Interconnection, L.L.C. (“Operating Agreement”), and the Reliability Assurance Agreement Among Load Serving Entities in the PJM Region (“RAA”). PJM respectfully requests that the Commission accept the enclosed revisions with an effective date of October 28, 2023.

I. BACKGROUND

In the last several years, PJM has used its Governing Documents Enhancement and Clarifications Subcommittee (“GDECS”) stakeholder process as the primary vehicle to effectuate review of its Governing Documents to ensure that provisions are clear, consistent, and accurately

¹ 16 U.S.C. § 824d (2020).

² 18 C.F.R. Part 35 (2020).

reflect PJM's practices and procedures. To date, PJM has submitted several filings to correct and clarify definitions and provisions identified via GDECS that were ambiguous, incorrect, or required additional detail, which the Commission has accepted.³

In establishing GDECS, PJM and its stakeholders intended to utilize the GDECS process as a means to continually review and make non-controversial substantive and non-substantive revisions to the Governing Documents.⁴ Through these ongoing efforts, PJM has identified a number of additional revisions that will help clarify, correct, and/or reflect previously filed and accepted revisions to PJM's Governing Documents, thereby decreasing the likelihood of compliance violations through misinterpretation or ambiguity in the language of a given provision. Other proposed revisions will correct or remove language that does not accurately describe the current processes that PJM utilizes or is no longer applicable, in an effort to eliminate inconsistencies between provisions within the Governing Documents or otherwise bring the Governing Document up to date.

II. PROPOSED REVISIONS

The revisions proposed herein remove obsolete provisions and terms, eliminate ambiguity, modify incorrect references, correct formatting errors, reincorporate revisions that the Commission has previously accepted but which are not reflected in the posted versions of the governing

³ See, e.g., *PJM Interconnection L.L.C.*, Delegated Letter Order, Docket No. ER19-744-000 (Feb. 4, 2019); *PJM Interconnection L.L.C.*, Delegated Letter Order, Docket No. ER18-1528-000 (June 25, 2018); *PJM Interconnection, L.L.C.*, Delegated Letter Order, Docket No. ER17-1372-000 (May 17, 2017); *PJM Interconnection, L.L.C.*, Delegated Letter Order, Docket No. ER16-1737-000 (June 20, 2016); *PJM Interconnection, L.L.C.*, 155 FERC ¶ 61,303 (2016) (accepting all proposed revisions except one); *PJM Interconnection L.L.C.*, Delegated Letter Order, Docket No. ER19-2799-000 (October 9, 2020), and *PJM Interconnection L.L.C.*, Delegated Letter Order, Docket No. ER22-846-000 (June 22, 2022).

⁴ See PJM, GDECS Charter, <https://www.pjm.com/-/media/committees-groups/subcommittees/gdecs/20151023/20151023-charter.ashx?la=en> (indicating that meetings will be held as needed and that expected duration of the work of the subcommittee to be "indefinite.").

documents, and otherwise clarify provisions or remove obsolete provisions. For ease of review of the proposed revisions, PJM has provided a table appended hereto as Attachment C, which describes the proposed revisions, the Governing Document in which the revision is being made, the current language, and the rationale for making the referenced changes. Given that each of the proposed revisions are discrete, severable, and not interdependent, PJM requests the Commission evaluate the justness and reasonableness of these revisions separately.⁵

III. STAKEHOLDER PROCESS

PJM worked with its stakeholders through the GDECS between March 2023 and August 2023 to review changes that were needed to PJM's Governing Documents.⁶ PJM discussed the proposed revisions and associated rationale for each of the items listed on the enclosed table with stakeholders in the GDECS during this timeframe, and modified some of the proposed revisions based on stakeholder feedback. The proposed revisions were presented to, and discussed with, the PJM Markets and Reliability Committee ("MRC") between May and June 2023. The MRC endorsed the revisions by acclamation with no objection and one abstention at its July 24, 2023 meeting.⁷ The Members Committee ("MC") endorsed the revisions by acclamation with no objections and no abstentions at its July 26, 2023 meeting.

⁵ See *NRG Power Mktg., LLC v. FERC*, 862 F.3d 108, 114-15 (D.C. Cir. 2017) (finding that the Commission has "authority to propose modifications to a utility's [FPA section 205] proposal if the utility consents to the modifications") (emphasis in original); see also *Public Service Company of New Mexico*, 178 FERC ¶ 61,088, at P 31 n.48 (2022) (accepting the filer's proposed tariff revisions, but directing certain revisions to remove specific charges, as agreed to by the filer) (citing 862 F.3d 108); *Southwest Power Pool, Inc.*, 177 FERC ¶ 61,148, at P 27 n.42 (2021); *PJM Interconnection, L.L.C.*, 176 FERC ¶ 61,080, at P 43 n.54 (2021); *Southwest Power Pool, Inc.*, 177 FERC ¶ 61,230, at P 24 n.43 (2021).

⁶ See PJM, 2023 GDECS Timeline, <https://www.pjm.com/-/media/committees-groups/subcommittees/gdecs/2023/20230323/20230323-item-02---gdecs-timeline.ashx>.

⁷ PJM, Minutes from MRC Meeting on June 22, 2023, <https://www.pjm.com/-/media/committees-groups/committees/mrc/2023/20230726/20230726-consent-agenda-a---draft-mrc-minutes---6222023.ashx>.

IV. PROPOSED EFFECTIVE DATE

PJM respectively requests that the Commission accept the enclosed revisions to the PJM Tariff, Operating Agreement, and RAA, effective October 28, 2023.

V. DESCRIPTION OF SUBMITTAL

This filing consists of the following:

1. This transmittal letter;
2. Electronic versions of the revisions to the Tariff, Operating Agreement, and RAA in marked (showing the changes) form (as Attachment A);
3. Electronic versions of the revisions to the Tariff, Operating Agreement, and RAA in clean form (as Attachment B); and
4. A chart describing the proposed Tariff, Operating Agreement, and RAA revisions in detail (as Attachment C).

VI. CORRESPONDENCE

The following individuals are designated for inclusion on the official service list in this proceeding and for receipt of any communications regarding this filing:

Chenchao Lu
Associate General Counsel
PJM Interconnection, L.L.C.
2750 Monroe Boulevard
Audubon, Pennsylvania 19403
(610) 666-2255
chenchao.lu@pjm.com

Craig Glazer
Vice President - Federal Government Policy
PJM Interconnection, L.L.C.
1200 G Street, N.W, Suite 600
Washington, D.C. 20005
(202) 423-4743
craig.glazer@pjm.com

VII. SERVICE

PJM has served a copy of this filing on all PJM Members and on all state utility regulatory commissions in the PJM Region by posting this filing electronically. In accordance with the Commission's regulations,⁸ PJM will post a copy of this filing to the FERC filings section of its

⁸ See 18 C.F.R. §§ 35.2(e) and 385.2010(f)(3).

internet site, located at the following link: <https://www.pjm.com/library/filing-order> with a specific link to the newly-filed document, and will send an e-mail on the same date as this filing to all PJM Members and all state utility regulatory commissions in the PJM Region⁹ alerting them that this filing has been made by PJM and is available by following such link. If the document is not immediately available by using the referenced link, the document will be available through the referenced link within 24 hours of the filing. Also, a copy of this filing will be available on the FERC's eLibrary website located at the following link: <http://www.ferc.gov/docs-filing/elibrary.asp> in accordance with the Commission's regulations and Order No. 714.

VIII. CONCLUSION

For the reasons discussed herein, PJM respectfully requests that the Commission accept the enclosed revisions to the PJM Tariff and Operating Agreement effective October 28, 2023.

Respectfully submitted,

/s/ Chenchao Lu

Craig Glazer
Vice President–Federal Government Policy
PJM Interconnection, L.L.C.
1200 G Street, N.W., Suite 600
Washington, D.C. 20005
(202) 423-4743 (phone)
(202) 393-7741 (fax)
craig.glazer@pjm.com

Chenchao Lu
Associate General Counsel
PJM Interconnection, L.L.C.
2750 Monroe Blvd.
Audubon, PA 19403
(610) 666-2255 (phone)
(610) 666-8211 (fax)
chenchao.lu@pjm.com

⁹ PJM already maintains, updates and regularly uses e-mail lists for all PJM Members and affected state commissions.

Attachment A

Revisions to the
PJM Open Access Transmission Tariff,
PJM Operating Agreement
and PJM Reliability Assurance Agreement

(Marked / Redline Format)

Definitions – L – M – N

Legacy Policy:

“Legacy Policy” shall mean any legislative, executive, or regulatory action that specifically directs a payment outside of PJM Markets to a designated or prospective Generation Capacity Resource and the enactment of such action predates October 1, 2021, regardless of when any implementing governmental action to effectuate the action to direct payment outside of PJM Markets occurs.

Limited Demand Resource:

“Limited Demand Resource” shall have the meaning specified in the Reliability Assurance Agreement.

Limited Demand Resource Reliability Target:

“Limited Demand Resource Reliability Target” for the PJM Region or an LDA, shall mean the maximum amount of Limited Demand Resources determined by PJM to be consistent with the maintenance of reliability, stated in Unforced Capacity that shall be used to calculate the Minimum Extended Summer Demand Resource Requirement for Delivery Years through May 31, 2017 and the Limited Resource Constraint for the 2017/2018 and 2018/2019 Delivery Years for the PJM Region or such LDA. As more fully set forth in the PJM Manuals, PJM calculates the Limited Demand Resource Reliability Target by first: i) testing the effects of the ten-interruption requirement by comparing possible loads on peak days under a range of weather conditions (from the daily load forecast distributions for the Delivery Year in question) against possible generation capacity on such days under a range of conditions (using the cumulative capacity distributions employed in the Installed Reserve Margin study for the PJM Region and in the Capacity Emergency Transfer Objective study for the relevant LDAs for such Delivery Year) and, by varying the assumed amounts of DR that is committed and displaces committed generation, determines the DR penetration level at which there is a ninety percent probability that DR will not be called (based on the applicable operating reserve margin for the PJM Region and for the relevant LDAs) more than ten times over those peak days; ii) testing the six-hour duration requirement by calculating the MW difference between the highest hourly unrestricted peak load and seventh highest hourly unrestricted peak load on certain high peak load days (e.g., the annual peak, loads above the weather normalized peak, or days where load management was called) in recent years, then dividing those loads by the forecast peak for those years and averaging the result; and (iii) (for the 2016/2017 and 2017/2018 Delivery Years) testing the effects of the six-hour duration requirement by comparing possible hourly loads on peak days under a range of weather conditions (from the daily load forecast distributions for the Delivery Year in question) against possible generation capacity on such days under a range of conditions (using a Monte Carlo model of hourly capacity levels that is consistent with the capacity model employed in the Installed Reserve Margin study for the PJM Region and in the Capacity Emergency Transfer Objective study for the relevant LDAs for such Delivery Year) and, by varying the assumed amounts of DR that is committed and displaces committed generation, determines the DR penetration level at which there is a ninety percent probability that DR will

not be called (based on the applicable operating reserve margin for the PJM Region and for the relevant LDAs) for more than six hours over any one or more of the tested peak days. Second, PJM adopts the lowest result from these three tests as the Limited Demand Resource Reliability Target. The Limited Demand Resource Reliability Target shall be expressed as a percentage of the forecasted peak load of the PJM Region or such LDA and is converted to Unforced Capacity by multiplying [the reliability target percentage] times [the Forecast Pool Requirement] times [the DR Factor] times [the forecasted peak load of the PJM Region or such LDA, reduced by the amount of load served under the FRR Alternative].

Limited Resource Constraint:

“Limited Resource Constraint” shall mean, for the 2017/2018 Delivery Year and for FRR Capacity Plans the 2017/2018 and Delivery Years, for the PJM Region or each LDA for which the Office of the Interconnection is required under Tariff, Attachment DD, section 5.10(a) to establish a separate VRR Curve for a Delivery Year, a limit on the total amount of Unforced Capacity that can be committed as Limited Demand Resources for the 2017/2018 Delivery Year in the PJM Region or in such LDA, calculated as the Limited Demand Resource Reliability Target for the PJM Region or such LDA, respectively, minus the Short Term Resource Procurement Target for the PJM Region or such LDA, respectively.

Limited Resource Price Decrement:

“Limited Resource Price Decrement” shall mean, for the 2017/2018 Delivery Year, a difference between the clearing price for Limited Demand Resources and the clearing price for Extended Summer Demand Resources and Annual Resources, representing the cost to procure additional Extended Summer Demand Resources or Annual Resources out of merit order when the Limited Resource Constraint is binding.

List of Approved Contractors:

“List of Approved Contractors” shall mean a list developed by each Transmission Owner and published in a PJM Manual of (a) contractors that the Transmission Owner considers to be qualified to install or construct new facilities and/or upgrades or modifications to existing facilities on the Transmission Owner’s system, provided that such contractors may include, but need not be limited to, contractors that, in addition to providing construction services, also provide design and/or other construction-related services, and (b) manufacturers or vendors of major transmission-related equipment (e.g., high-voltage transformers, transmission line, circuit breakers) whose products the Transmission Owner considers acceptable for installation and use on its system.

Load Interest:

“Load Interest” shall mean, for the purposes of the minimum offer price rule, responsibility for serving load within the PJM Region, whether by the Capacity Market Seller, an affiliate of the Capacity Market Seller, or by an entity with which the Capacity Market Seller is in contractual privity with respect to the subject Generation Capacity Resource.

Load Management:

“Load Management” shall mean a Demand Resource (“DR”) as defined in the Reliability Assurance Agreement.

Load Management Event:

“Load Management Event” shall mean a) a single temporally contiguous dispatch of Demand Resources in a Compliance Aggregation Area during an Operating Day, or b) multiple dispatches of Demand Resources in a Compliance Aggregation Area during an Operating Day that are temporally contiguous.

Load Ratio Share:

“Load Ratio Share” shall mean the ratio of a Transmission Customer’s Network Load to the Transmission Provider’s total load.

Load Reduction Event:

“Load Reduction Event” shall mean a reduction in demand by a Member or Special Member for the purpose of participating in the PJM Interchange Energy Market.

Load Serving Charging Energy:

“Load Serving Charging Energy” shall mean energy that is purchased from the PJM Interchange Energy Market and stored in an Energy Storage Resource for later resale to end-use load.

Load Serving Entity (LSE):

“Load Serving Entity” or “LSE” shall have the meaning specified in the Reliability Assurance Agreement.

Load Shedding:

“Load Shedding” shall mean the systematic reduction of system demand by temporarily decreasing load in response to transmission system or area capacity shortages, system instability, or voltage control considerations under Tariff, Part II or Part III.

Local Upgrades:

“Local Upgrades” shall mean modifications or additions of facilities to abate any local thermal loading, voltage, short circuit, stability or similar engineering problem caused by the interconnection and delivery of generation to the Transmission System. Local Upgrades shall include:

(i) Direct Connection Local Upgrades which are Local Upgrades that only serve the Customer Interconnection Facility and have no impact or potential impact on the Transmission System until the final tie-in is complete; and

(ii) Non-Direct Connection Local Upgrades which are parallel flow Local Upgrades that are not Direct Connection Local Upgrades.

Location:

“Location” as used in the Economic Load Response rules shall mean an end-use customer site as defined by the relevant electric distribution company account number.

LOC Deviation:

“LOC Deviation,” shall mean, for units other than wind units, the LOC Deviation shall equal the desired megawatt amount for the resource determined according to the point on the Final Offer curve corresponding to the Real-time Settlement Interval real-time Locational Marginal Price at the resource’s bus and adjusted for any reduction in megawatts due to Regulation, Synchronized Reserve, or Secondary Reserve assignments and limited to the lesser of the unit’s Economic Maximum or the unit’s Generation Resource Maximum Output, minus the actual output of the unit. For wind units, the LOC Deviation shall mean the deviation of the generating unit’s output equal to the lesser of the PJM forecasted output for the unit or the desired megawatt amount for the resource determined according to the point on the Final Offer curve corresponding to the Real-time Settlement Interval integrated real-time Locational Marginal Price at the resource’s bus, and shall be limited to the lesser of the unit’s Economic Maximum or the unit’s Generation Resource Maximum Output, minus the actual output of the unit.

Locational Deliverability Area (LDA):

“Locational Deliverability Area” or “LDA” shall mean a geographic area within the PJM Region that has limited transmission capability to import capacity to satisfy such area’s reliability requirement, as determined by the Office of the Interconnection in connection with preparation of the Regional Transmission Expansion Plan, and as specified in Reliability Assurance Agreement, Schedule 10.1.

Locational Deliverability Area Reliability Requirement:

“Locational Deliverability Area Reliability Requirement” shall mean the projected internal capacity in the Locational Deliverability Area plus the Capacity Emergency Transfer Objective for the Delivery Year, as determined by the Office of the Interconnection in connection with preparation of the Regional Transmission Expansion Plan, less the minimum internal resources required for all FRR Entities in such Locational Deliverability Area. Notwithstanding the foregoing, effective with the 2024/2025 Delivery Year, during the auction process, the Office of Interconnection shall exclude from the Locational Deliverability Area Reliability Requirement any Planned Generation Capacity Resource in an LDA that does not participate in the relevant RPM Auction as projected internal capacity and in the Capacity Emergency Transfer Objective

model where the Locational Deliverability Area Reliability Requirement for the Base Residual Auction increases by more than one percent over the reliability requirement used from the prior Delivery Year's Base Residual Auction (for Incremental Auctions the Locational Deliverability Area Reliability Requirement would be compared with the reliability requirement used in the prior relevant RPM Auction associated with the same Delivery Year) for that LDA due to the cumulative addition of such Planned Generation Capacity Resources.

Locational Price Adder:

“Locational Price Adder” shall mean an addition to the marginal value of Unforced Capacity within an LDA as necessary to reflect the price of Capacity Resources required to relieve applicable binding locational constraints.

Locational Reliability Charge:

“Locational Reliability Charge” shall have the meaning specified in the Reliability Assurance Agreement.

Locational UCAP:

“Locational UCAP” shall mean unforced capacity that a Member with available uncommitted capacity sells in a bilateral transaction to a Member that previously committed capacity through an RPM Auction but now requires replacement capacity to fulfill its RPM Auction commitment. The Locational UCAP Seller retains responsibility for performance of the resource providing such replacement capacity.

Locational UCAP Seller:

“Locational UCAP Seller” shall mean a Member that sells Locational UCAP.

Long-lead Project:

“Long-lead Project” shall have the same meaning provided in the Operating Agreement.

Long-Term Firm Point-To-Point Transmission Service:

“Long-Term Firm Point-To-Point Transmission Service” shall mean firm Point-To-Point Transmission Service under Tariff, Part II with a term of one year or more.

Loss Price:

“Loss Price” shall mean the loss component of the Locational Marginal Price, which is the effect on transmission loss costs (whether positive or negative) associated with increasing the output of a generation resource or decreasing the consumption by a Demand Resource based on the effect of increased generation from or consumption by the resource on transmission losses, calculated

as specified in Operating Agreement, Schedule 1, section 2, and the parallel provisions of Tariff, Attachment K-Appendix, section 2.

M2M Flowgate:

“M2M Flowgate” shall have the meaning provided in the Joint Operating Agreement between the Midcontinent Independent Transmission System Operator, Inc. and PJM Interconnection, L.L.C.

Maintenance Adder:

“Maintenance Adder” shall mean an adder that may be included to account for variable operation and maintenance expenses in a Market Seller’s Fuel Cost Policy. The Maintenance Adder is calculated in accordance with the applicable provisions of PJM Manual 15, and may only include expenses incurred as a result of electric production.

Manual Load Dump Action:

“Manual Load Dump Action” shall mean an Operating Instruction, as defined by NERC, from PJM to shed firm load when the PJM Region cannot provide adequate capacity to meet the PJM Region’s load and tie schedules, or to alleviate critically overloaded transmission lines or other equipment.

Manual Load Dump Warning:

“Manual Load Dump Warning” shall mean a notification from PJM to warn Members of an increasingly critical condition of present operations that may require manually shedding load.

Marginal Value:

“Marginal Value” shall mean the incremental change in system dispatch costs, measured as a \$/MW value incurred by providing one additional MW of relief to the transmission constraint.

Market Monitor:

“Market Monitor” means the head of the Market Monitoring Unit.

Market Monitoring Unit or MMU:

“Market Monitoring Unit” or “MMU” means the independent Market Monitoring Unit defined in 18 CFR § 35.28(a)(7) and established under the PJM Market Monitoring Plan (Attachment M) to the PJM Tariff that is responsible for implementing the Market Monitoring Plan, including the Market Monitor. The Market Monitoring Unit may also be referred to as the IMM or Independent Market Monitor for PJM

Market Monitoring Unit Advisory Committee or MMU Advisory Committee:

“Market Monitoring Unit Advisory Committee” or “MMU Advisory Committee” shall mean the committee established under Tariff, Attachment M, section III.H.

Market Operations Center:

“Market Operations Center” shall mean the equipment, facilities and personnel used by or on behalf of a Market Participant to communicate and coordinate with the Office of the Interconnection in connection with transactions in the PJM Interchange Energy Market or the operation of the PJM Region.

Market Participant:

“Market Participant” shall mean a Market Buyer, a Market Seller, an Economic Load Response Participant, or all three, except when such term is used in Tariff, Attachment M, in which case Market Participant shall mean an entity that generates, transmits, distributes, purchases, or sells electricity, ancillary services, or any other product or service provided under the PJM Tariff or Operating Agreement within, into, out of, or through the PJM Region, but it shall not include an Authorized Government Agency that consumes energy for its own use but does not purchase or sell energy at wholesale.

Market Participant Energy Injection:

“Market Participant Energy Injection” shall mean transactions in the Day-ahead Energy Market and Real-time Energy Market, including but not limited to Day-ahead generation schedules, real-time generation output, Increment Offers, internal bilateral transactions and import transactions, as further described in the PJM Manuals.

Market Participant Energy Withdrawal:

“Market Participant Energy Withdrawal” shall mean transactions in the Day-ahead Energy Market and Real-time Energy Market, including but not limited to Demand Bids, Decrement Bids, real-time load (net of Behind The Meter Generation expected to be operating, but not to be less than zero), internal bilateral transactions and Export Transactions, as further described in the PJM Manuals.

Market Revenue Neutrality Offset:

“Market Revenue Neutrality Offset” shall mean the revenue in excess of the cost for a resource from the energy, Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve markets realized from an increase in real-time market megawatt assignment from a day-ahead market megawatt assignment in any of these markets due to the decrease in the real-time reserve market megawatt assignment from a day-ahead reserve market megawatt assignment in any of the reserve markets.

Market Seller Offer Cap:

“Market Seller Offer Cap” shall mean a maximum offer price applicable to certain Market Sellers under certain conditions, as determined in accordance with Tariff, Attachment DD. section 6 and Tariff, Attachment M-Appendix, section II.E.

Market Suspension:

“Market Suspension” shall mean the inability of the Office of the Interconnection to clear the Day-ahead Energy Market prior to 11:59 p.m. on the day before the affected Operating Day due to extraordinary circumstances, as further described in Operating Agreement, Schedule 1, section 1.10.8(d) and the parallel provisions of Tariff, Attachment K-Appendix, section 1.10.8(d), or the inability of the Office of the Interconnection to produce Zonal Dispatch Rates for a total of seven (7) or more Real-time Settlement Intervals within a clock hour, for the purposes of the Real-time Energy Market, as further described in Operating Agreement, Schedule 1, section 1.11.6 and the parallel provisions of Tariff, Attachment K-Appendix, section 1.11.6.

Market Violation:

“Market Violation” shall mean a tariff violation, violation of a Commission-approved order, rule or regulation, market manipulation, or inappropriate dispatch that creates substantial concerns regarding unnecessary market inefficiencies, as defined in 18 C.F.R. § 35.28(b)(8).

Material Modification:

“Material Modification” shall mean any modification to an Interconnection Request that has a material adverse effect on the cost or timing of Interconnection Studies related to, or any Network Upgrades or Local Upgrades needed to accommodate, any Interconnection Request with a later Queue Position.

Maximum Daily Starts:

“Maximum Daily Starts” shall mean the maximum number of times that a generating unit can be started in an Operating Day under normal operating conditions.

Maximum Emergency:

“Maximum Emergency” shall mean the designation of all or part of the output of a generating unit for which the designated output levels may require extraordinary procedures and therefore are available to the Office of the Interconnection only when the Office of the Interconnection declares a Maximum Generation Emergency and requests generation designated as Maximum Emergency to run. The Office of the Interconnection shall post on the PJM website the aggregate amount of megawatts that are classified as Maximum Emergency.

Maximum Facility Output:

“Maximum Facility Output” shall mean the maximum (not nominal) net electrical power output in megawatts, specified in the Interconnection Service Agreement, after supply of any parasitic or host facility loads, that a Generation Interconnection Customer’s Customer Facility is expected to produce, provided that the specified Maximum Facility Output shall not exceed the output of the proposed Customer Facility that Transmission Provider utilized in the System Impact Study.

Maximum Generation Emergency:

“Maximum Generation Emergency” shall mean an Emergency declared by the Office of the Interconnection to address either a generation or transmission emergency in which the Office of the Interconnection anticipates requesting one or more Generation Capacity Resources, or Non-Retail Behind The Meter Generation resources to operate at its maximum net or gross electrical power output, subject to the equipment stress limits for such Generation Capacity Resource or Non-Retail Behind The Meter resource in order to manage, alleviate, or end the Emergency.

Maximum Generation Emergency Alert:

“Maximum Generation Emergency Alert” shall mean an alert issued by the Office of the Interconnection to notify PJM Members, Transmission Owners, resource owners and operators, customers, and regulators that a Maximum Generation Emergency may be declared, for any Operating Day in either, as applicable, the Day-ahead Energy Market or the Real-time Energy Market, for all or any part of such Operating Day.

Maximum Run Time:

“Maximum Run Time” shall mean the maximum number of hours a generating unit can run over the course of an Operating Day, as measured by PJM’s State Estimator.

Maximum Weekly Starts:

“Maximum Weekly Starts” shall mean the maximum number of times that a generating unit can be started in one week, defined as the 168 hour period starting Monday 0001 hour, under normal operating conditions.

Member:

“Member” shall have the meaning provided in the Operating Agreement.

Merchant A.C. Transmission Facilities:

“Merchant A.C. Transmission Facility” shall mean Merchant Transmission Facilities that are alternating current (A.C.) transmission facilities, other than those that are Controllable A.C. Merchant Transmission Facilities.

Merchant D.C. Transmission Facilities:

“Merchant D.C. Transmission Facilities” shall mean direct current (D.C.) transmission facilities that are interconnected with the Transmission System pursuant to Tariff, Part IV and Part VI.

Merchant Network Upgrades:

“Merchant Network Upgrades” shall mean additions to, or modifications or replacements of, physical facilities of the Interconnected Transmission Owner that, on the date of the pertinent Transmission Interconnection Customer’s Upgrade Request, are part of the Transmission System or are included in the Regional Transmission Expansion Plan.

Merchant Transmission Facilities:

“Merchant Transmission Facilities” shall mean A.C. or D.C. transmission facilities that are interconnected with or added to the Transmission System pursuant to Tariff, Part IV and Part VI and that are so identified in Tariff, Attachment T, provided, however, that Merchant Transmission Facilities shall not include (i) any Customer Interconnection Facilities, (ii) any physical facilities of the Transmission System that were in existence on or before March 20, 2003 ; (iii) any expansions or enhancements of the Transmission System that are not identified as Merchant Transmission Facilities in the Regional Transmission Expansion Plan and Attachment T to the Tariff, or (iv) any transmission facilities that are included in the rate base of a public utility and on which a regulated return is earned.

Merchant Transmission Provider:

“Merchant Transmission Provider” shall mean an Interconnection Customer that (1) owns, controls, or controls the rights to use the transmission capability of, Merchant D.C. Transmission Facilities and/or Controllable A.C. Merchant Transmission Facilities that connect the Transmission System with another control area, (2) has elected to receive Transmission Injection Rights and Transmission Withdrawal Rights associated with such facility pursuant to Tariff, Part IV, section 36, and (3) makes (or will make) the transmission capability of such facilities available for use by third parties under terms and conditions approved by the Commission and stated in the Tariff, consistent with Tariff, section 38.

Metering Equipment:

“Metering Equipment” shall mean all metering equipment installed at the metering points designated in the appropriate appendix to an Interconnection Service Agreement.

Minimum Annual Resource Requirement:

“Minimum Annual Resource Requirement” shall mean, for Delivery Years through May 31, 2017, the minimum amount of capacity that PJM will seek to procure from Annual Resources for the PJM Region and for each Locational Deliverability Area for which the Office of the Interconnection is required under Tariff, Attachment DD, section 5.10(a) to establish a separate VRR Curve for such Delivery Year. For the PJM Region, the Minimum Annual Resource

Requirement shall be equal to the RTO Reliability Requirement minus [the Sub-Annual Resource Reliability Target for the RTO in Unforced Capacity]. For an LDA, the Minimum Annual Resource Requirement shall be equal to the LDA Reliability Requirement minus [the LDA CETL] minus [the Sub-Annual Resource Reliability Target for such LDA in Unforced Capacity]. The LDA CETL may be adjusted pro rata for the amount of load served under the FRR Alternative.

Minimum Down Time:

For all generating units that are not combined cycle units, “Minimum Down Time” shall mean the minimum number of hours under normal operating conditions between unit shutdown and unit startup, calculated as the shortest time difference between the unit’s generator breaker opening and after the unit’s generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero. For combined cycle units, “Minimum Down Time” shall mean the minimum number of hours between the last generator breaker opening and after first combustion turbine generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero.

Minimum Extended Summer Resource Requirement:

“Minimum Extended Summer Resource Requirement” shall mean, for Delivery Years through May 31, 2017, the minimum amount of capacity that PJM will seek to procure from Extended Summer Demand Resources and Annual Resources for the PJM Region and for each Locational Deliverability Area for which the Office of the Interconnection is required under Tariff, Attachment DD, section 5.10(a) to establish a separate VRR Curve for such Delivery Year. For the PJM Region, the Minimum Extended Summer Resource Requirement shall be equal to the RTO Reliability Requirement minus [the Limited Demand Resource Reliability Target for the PJM Region in Unforced Capacity]. For an LDA, the Minimum Extended Summer Resource Requirement shall be equal to the LDA Reliability Requirement minus [the LDA CETL] minus [the Limited Demand Resource Reliability Target for such LDA in Unforced Capacity]. The LDA CETL may be adjusted pro rata for the amount of load served under the FRR Alternative.

Minimum Generation Emergency:

“Minimum Generation Emergency” shall mean an Emergency declared by the Office of the Interconnection in which the Office of the Interconnection anticipates requesting one or more generating resources to operate at or below Normal Minimum Generation, in order to manage, alleviate, or end the Emergency.

Minimum Participation Requirements:

“Minimum Participation Requirements” shall mean a set of minimum training, risk management, communication and capital or collateral requirements required for Participants in the PJM Markets, as set forth herein and in the Form of Annual Certification set forth as Tariff, Attachment Q, Appendix 1. Participants transacting in FTRs in certain circumstances will be

required to demonstrate additional risk management procedures and controls as further set forth in the Annual Certification found in Tariff, Attachment Q, Appendix 1.

Minimum Run Time:

For all generating units that are not combined cycle units, “Minimum Run Time” shall mean the minimum number of hours a unit must run, in real-time operations, from the time after generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero, to the time of generator breaker opening, as measured by PJM's State Estimator. For combined cycle units, “Minimum Run Time” shall mean the time period after the first combustion turbine generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero, ~~and~~ to the time of the last generator breaker opening as measured by PJM’s State Estimator.

MISO:

“MISO” shall mean the Midcontinent Independent System Operator, Inc. or any successor thereto.

Mixed Technology Facility:

“Mixed Technology Facility” shall mean a facility composed of distinct generation and/or electric storage technology types behind the same Point of Interconnection. Co-Located Resources and Hybrid Resources form all or part of Mixed Technology Facilities.

MOPR Floor Offer Price:

“MOPR Floor Offer Price” shall mean a minimum offer price applicable to certain Market Seller’s Capacity Resources under certain conditions, as determined in accordance with Tariff, Attachment DD, sections 5.14(h), 5.14(h-1), and 5.14(h-2).

Multi-Driver Project:

“Multi-Driver Project” shall have the same meaning provided in the Operating Agreement.

Native Load Customers:

“Native Load Customers” shall mean the wholesale and retail power customers of a Transmission Owner on whose behalf the Transmission Owner, by statute, franchise, regulatory requirement, or contract, has undertaken an obligation to construct and operate the Transmission Owner’s system to meet the reliable electric needs of such customers.

NERC:

“NERC” shall mean the North American Electric Reliability Corporation or any successor thereto.

NERC Interchange Distribution Calculator:

“NERC Interchange Distribution Calculator” shall mean the NERC mechanism that is in effect and being used to calculate the distribution of energy, over specific transmission interfaces, from energy transactions.

Net Benefits Test:

“Net Benefits Test” shall mean a calculation to determine whether the benefits of a reduction in price resulting from the dispatch of Economic Load Response exceeds the cost to other loads resulting from the billing unit effects of the load reduction, as specified in Operating Agreement, Schedule 1, section 3.3A.4 and the parallel provisions of Tariff, Attachment K-Appendix, section 3.3A.4.

Net Cost of New Entry:

“Net Cost of New Entry” shall mean the Cost of New Entry minus the Net Energy and Ancillary Service Revenue Offset.

Net Obligation:

“Net Obligation” shall mean the amount owed to PJMSettlement and PJM for purchases from the PJM Markets, Transmission Service, (under Tariff, Parts II and III , and other services pursuant to the Agreements, after applying a deduction for amounts owed to a Participant by PJMSettlement as it pertains to monthly market activity and services. Should other markets be formed such that Participants may incur future Obligations in those markets, then the aggregate amount of those Obligations will also be added to the Net Obligation.

Net Sell Position:

“Net Sell Position” shall mean the amount of Net Obligation when Net Obligation is negative.

Network Customer:

“Network Customer” shall mean an entity receiving transmission service pursuant to the terms of the Transmission Provider’s Network Integration Transmission Service under Tariff, Part III.

Network External Designated Transmission Service:

“Network External Designated Transmission Service” shall have the meaning set forth in Reliability Assurance Agreement, Article I.

Network Integration Transmission Service:

“Network Integration Transmission Service” shall mean the transmission service provided under Tariff, Part III.

Network Load:

“Network Load” shall mean the load that a Network Customer designates for Network Integration Transmission Service under Tariff, Part III. The Network Customer’s Network Load shall include all load (including losses, Non-Dispatched Charging Energy, and Load Serving Charging Energy) served by the output of any Network Resources designated by the Network Customer. A Network Customer may elect to designate less than its total load as Network Load but may not designate only part of the load at a discrete Point of Delivery. Where an Eligible Customer has elected not to designate a particular load at discrete points of delivery as Network Load, the Eligible Customer is responsible for making separate arrangements under Tariff, Part II for any Point-To-Point Transmission Service that may be necessary for such non-designated load. Network Load shall not include Dispatched Charging Energy.

Network Operating Agreement:

“Network Operating Agreement” shall mean an executed agreement that contains the terms and conditions under which the Network Customer shall operate its facilities and the technical and operational matters associated with the implementation of Network Integration Transmission Service under Tariff, Part III.

Network Operating Committee:

“Network Operating Committee” shall mean a group made up of representatives from the Network Customer(s) and the Transmission Provider established to coordinate operating criteria and other technical considerations required for implementation of Network Integration Transmission Service under Tariff, Part III.

Network Resource:

“Network Resource” shall mean any designated generating resource owned, purchased, or leased by a Network Customer under the Network Integration Transmission Service Tariff. Network Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Network Customer’s Network Load on a non-interruptible basis, except for purposes of fulfilling obligations under a reserve sharing program.

Network Service User:

“Network Service User” shall mean an entity using Network Transmission Service.

Network Transmission Service:

“Network Transmission Service” shall mean transmission service provided pursuant to the rates, terms and conditions set forth in Tariff, Part III, or transmission service comparable to such service that is provided to a Load Serving Entity that is also a Transmission Owner.

Network Upgrades:

“Network Upgrades” shall mean modifications or additions to transmission-related facilities that are integrated with and support the Transmission Provider’s overall Transmission System for the general benefit of all users of such Transmission System. Network Upgrades shall include:

(i) **Direct Connection Network Upgrades** which are Network Upgrades that are not part of an Affected System; only serve the Customer Interconnection Facility; and have no impact or potential impact on the Transmission System until the final tie-in is complete. Both Transmission Provider and Interconnection Customer must agree as to what constitutes Direct Connection Network Upgrades and identify them in the Interconnection Construction Service Agreement, Schedule D. If the Transmission Provider and Interconnection Customer disagree about whether a particular Network Upgrade is a Direct Connection Network Upgrade, the Transmission Provider must provide the Interconnection Customer a written technical explanation outlining why the Transmission Provider does not consider the Network Upgrade to be a Direct Connection Network Upgrade within 15 days of its determination.

(ii) **Non-Direct Connection Network Upgrades** which are parallel flow Network Upgrades that are not Direct Connection Network Upgrades.

Neutral Party:

“Neutral Party” shall have the meaning provided in Tariff, Part I, section 9.3(v).

New Entry Capacity Resource with State Subsidy:

“New Entry Capacity Resource with State Subsidy” shall mean (1) starting with the 2022/2023 Delivery Year, the MWs (in installed capacity) comprising a Capacity Resource with State Subsidy that have not cleared in an RPM Auction pursuant to its Sell Offer at or above its resource-specific MOPR Floor Offer Price or the applicable default New Entry MOPR Floor Offer Price or (2) starting with the Base Residual Auction for the 2022/2023 Delivery Year, any of those MWs (in installed capacity) comprising a Capacity Resource with State Subsidy that was not included in an FRR Capacity Plan at the time of the Base Residual Auction or the subject of a Sell Offer in a Base Residual Auction occurring for a Delivery Year after it last cleared an RPM Auction and since then has yet to clear an RPM Auction pursuant to its Sell Offer at or above its resource-specific MOPR Floor Offer Price or the applicable default New Entry MOPR Floor Offer Price. Notwithstanding the foregoing, any Capacity Resource that previously cleared an RPM Auction before it became entitled to receive a State Subsidy shall not be deemed a New Entry Capacity Resource, unless, starting with the Base Residual Auction for the 2022/2023 Delivery Year, the Capacity Resource with State Subsidy was not the subject of a Sell Offer in a Base Residual Auction or included in an FRR Capacity Plan at the time of the Base Residual Auction for a Delivery Year after it last cleared an RPM Auction.

New PJM Zone(s):

“New PJM Zone(s)” shall mean the Zone included in the Tariff, along with applicable Schedules and Attachments, for Commonwealth Edison Company, The Dayton Power and Light Company and the AEP East Operating Companies (Appalachian Power Company, Columbus Southern Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company).

New Service Customers:

“New Service Customers” shall mean all customers that submit an Interconnection Request, a Completed Application, or an Upgrade Request that is pending in the New Services Queue.

New Service Request:

“New Service Request” shall mean an Interconnection Request, a Completed Application, or an Upgrade Request.

New Services Queue:

“New Services Queue” shall mean all Interconnection Requests, Completed Applications, and Upgrade Requests that are received within each six-month period ending on March 31 and September 30 of each year shall collectively comprise a New Services Queue.

New York ISO or NYISO:

“New York ISO” or “NYISO” shall mean the New York Independent System Operator, Inc. or any successor thereto.

Nodal Reference Price:

The “Nodal Reference Price” at each location shall mean the 97th percentile price differential between day-ahead and real-time prices experienced over the corresponding two-month reference period in the prior calendar year. Reference periods will be Jan-Feb, Mar-Apr, May-Jun, Jul-Aug, Sept-Oct, Nov-Dec. For any given current-year month, the reference period months will be the set of two months in the prior calendar year that include the month corresponding to the current month. For example, July and August 2003 would each use July-August 2002 as their reference period.

No-load Cost:

“No-load Cost” shall mean the hourly cost required to theoretically operate a synchronized unit at zero MW. It consists primarily of the cost of fuel, as determined by the unit’s no load heat (adjusted by the performance factor) times the fuel cost. It also includes operating costs, Maintenance Adders, and emissions allowances.

Nominal Rated Capability:

“Nominal Rated Capability” shall mean the nominal maximum rated capability in megawatts of a Transmission Interconnection Customer’s Customer Facility or the nominal increase in transmission capability in megawatts of the Transmission System resulting from the interconnection or addition of a Transmission Interconnection Customer’s Customer Facility, as determined in accordance with pertinent Applicable Standards and specified in the Interconnection Service Agreement.

Nominated Demand Resource Value:

“Nominated Demand Resource Value” shall mean the amount of load reduction that a Demand Resource commits to provide either through direct load control, firm service level or guaranteed load drop programs. For existing Demand Resources, the maximum Nominated Demand Resource Value is limited, in accordance with the PJM Manuals, to the value appropriate for the method by which the load reduction would be accomplished, at the time the Base Residual Auction or Incremental Auction is being conducted.

Nominated Energy Efficiency Value:

“Nominated Energy Efficiency Value” shall mean the amount of load reduction that an Energy Efficiency Resource commits to provide through installation of more efficient devices or equipment or implementation of more efficient processes or systems.

Non-Dispatched Charging Energy:

“Non-Dispatched Charging Energy” shall mean all Direct Charging Energy that an Energy Storage Resource Model Participant receives from the electric grid that is not otherwise Dispatched Charging Energy.

Non-Firm Point-To-Point Transmission Service:

“Non-Firm Point-To-Point Transmission Service” shall mean Point-To-Point Transmission Service under the Tariff that is reserved and scheduled on an as-available basis and is subject to Curtailment or Interruption as set forth in Tariff, Part II, section 14.7. Non-Firm Point-To-Point Transmission Service is available on a stand-alone basis for periods ranging from one hour to one month.

Non-Firm Sale:

“Non-Firm Sale” shall mean an energy sale for which receipt or delivery may be interrupted for any reason or no reason, without liability on the part of either the buyer or seller.

Non-Firm Transmission Withdrawal Rights:

“No-Firm Transmission Withdrawal Rights” shall mean the rights to schedule energy withdrawals from a specified point on the Transmission System. Non-Firm Transmission Withdrawal Rights may be awarded only to a Merchant D.C. Transmission Facility that connects the Transmission System to another control area. Withdrawals scheduled using Non-Firm Transmission Withdrawal Rights have rights similar to those under Non-Firm Point-to-Point Transmission Service.

Non-Performance Charge:

“Non-Performance Charge” shall mean the charge applicable to Capacity Performance Resources as defined in Tariff, Attachment DD, section 10A(e).

Nonincumbent Developer:

“Nonincumbent Developer” shall have the same meaning provided in the Operating Agreement.

Non-Regulatory Opportunity Cost:

“Non-Regulatory Opportunity Cost” shall mean the difference between (a) the forecasted cost to operate a specific generating unit when the unit only has a limited number of starts or available run hours resulting from (i) the physical equipment limitations of the unit, for up to one year, due to original equipment manufacturer recommendations or insurance carrier restrictions, (ii) a fuel supply limitation, for up to one year, resulting from an event of Catastrophic Force Majeure; and, (b) the forecasted future Locational Marginal Price at which the generating unit could run while not violating such limitations. Non-Regulatory Opportunity Cost therefore is the value associated with a specific generating unit’s lost opportunity to produce energy during a higher valued period of time occurring within the same period of time in which the unit is bound by the referenced restrictions, and is reflected in the rules set forth in PJM Manual 15. Non-Regulatory Opportunity Costs shall be limited to those resources which are specifically delineated in Operating Agreement, Schedule 2.

Non-Retail Behind The Meter Generation:

“Non-Retail Behind The Meter Generation” shall mean Behind the Meter Generation that is used by municipal electric systems, electric cooperatives, or electric distribution companies to serve load.

Non-Synchronized Reserve:

“Non-Synchronized Reserve” shall mean the reserve capability of non-emergency generation resources that can be converted fully into energy within ten minutes of a request from the Office of the Interconnection dispatcher, and is provided by equipment that is not electrically synchronized to the Transmission System.

Non-Synchronized Reserve Event:

“Non-Synchronized Reserve Event” shall mean a request from the Office of the Interconnection to generation resources able and assigned to provide Non-Synchronized Reserve in one or more specified Reserve Zones or Reserve Sub-zones, within ten minutes to increase the energy output by the amount of assigned Non-Synchronized Reserve capability.

Non-Variable Loads:

“Non-Variable Loads” shall have the meaning specified in Operating Agreement, Schedule 1, section 1.5A.6, and the parallel provisions of Tariff, Attachment K-Appendix, section 1.5A.6.

Non-Zone Network Load:

“Non-Zone Network Load shall mean Network Load that is located outside of the PJM Region.

Normal Maximum Generation:

“Normal Maximum Generation” shall mean the highest output level of a generating resource under normal operating conditions.

Normal Minimum Generation:

“Normal Minimum Generation” shall mean the lowest output level of a generating resource under normal operating conditions.

1.10 Scheduling.

1.10.1 General.

(a) The Office of the Interconnection shall administer scheduling processes to implement a Day-ahead Energy Market and a Real-time Energy Market. PJMSettlement shall be the Counterparty to the purchases and sales of energy that clear the Day-ahead Energy Market and the Real-time Energy Market; provided that PJMSettlement shall not be a contracting party to bilateral transactions between Market Participants or with respect to a Generating Market Buyer's self-schedule or self-supply of its generation resources up to that Generating Market Buyer's Equivalent Load.

(b) The Day-ahead Energy Market shall enable Market Participants to purchase and sell energy through the PJM Interchange Energy Market at Day-ahead Prices and enable Transmission Customers to reserve transmission service with Transmission Congestion Charges and Transmission Loss Charges based on locational differences in Day-ahead Prices. Up-to Congestion Transactions submitted in the Day-ahead Energy Market shall not require transmission service and Transmission Customers shall not reserve transmission service for such Up-to Congestion Transactions. Market Participants whose purchases and sales, and Transmission Customers whose transmission uses are scheduled in the Day-ahead Energy Market, shall be obligated to purchase or sell energy, or pay Transmission Congestion Charges and Transmission Loss Charges, at the applicable Day-ahead Prices for the amounts scheduled.

(c) (i) In the Real-time Energy Market, Market Participants that deviate from the amounts of energy purchases or sales scheduled in the Day-ahead Energy Market shall be obligated to purchase or sell energy for the amount of the deviations at the applicable Real-time Prices or price differences, unless otherwise specified by this Schedule.

(ii) In the Real-time Energy Market, Transmission Customers that deviate from the transmission uses, scheduled in the Day-ahead Energy Market shall be obligated to pay Transmission Congestion Charges and Transmission Loss Charges for the amount of the deviations at the applicable Real-time Prices or price differences, unless otherwise specified by this Schedule.

(iii) Market Participants that deviate in real-time from the amounts of Secondary Reserve, Non-Synchronized Reserve, or Synchronized Reserve sales, scheduled day-ahead shall be obligated to purchase Secondary Reserve, Non-Synchronized Reserve, or Synchronized Reserve for the amount of the deviations at the applicable Real-time Prices or price differences, unless otherwise specified by this Schedule.

(d) The following scheduling procedures and principles shall govern the commitment of resources to the Day-ahead Energy Market and the Real-time Energy Market over a period extending from one week to one hour prior to the real-time dispatch. Scheduling encompasses the day-ahead and hourly scheduling process, through which the Office of the Interconnection determines the Day-ahead Energy Market and determines, based on changing forecasts of

conditions and actions by Market Participants and system constraints, a plan to serve the hourly energy and reserve requirements of the Internal Market Buyers and the purchase requests of the External Market Buyers in the least costly manner, subject to maintaining the reliability of the PJM Region. Scheduling does not encompass Coordinated External Transactions, which are subject to the procedures of Tariff, Attachment K-Appendix, section 1.13. Scheduling shall be conducted as specified in section 1.10.1A below, subject to the following condition. If the Office of the Interconnection's forecast for the next seven days projects a likelihood of Emergency conditions, the Office of the Interconnection may commit, for all or part of such seven day period, to the use of generation resources with notification or start-up times greater than one day as necessary in order to alleviate or mitigate such Emergency, in accordance with the Market Sellers' offers for such units for such periods and the specifications in the PJM Manuals. Such resources committed by the Office of the Interconnection to alleviate or mitigate an Emergency will not receive Operating Reserve Credits nor otherwise be made whole for its hours of operation for the duration of any portion of such commitment that exceeds the maximum start-up and notification times for such resources during Hot Weather Alerts and Cold Weather Alerts, consistent with Tariff, Attachment K-Appendix, section 3.2.3 and Tariff, Attachment K-Appendix, section 6.6.

1.10.1A Day-ahead and Real-time Energy Market Scheduling.

The following actions shall occur not later than 11:00 a.m. on the day before the Operating Day for which transactions are being scheduled, or such other deadline as may be specified by the Office of the Interconnection in order to comply with the practical requirements and the economic and efficiency objectives of the scheduling process specified in this Schedule.

(a) Each Market Participant may submit to the Office of the Interconnection specifications of the amount and location of its customer loads and/or energy purchases to be included in the Day-ahead Energy Market for each hour of the next Operating Day, such specifications to comply with the requirements set forth in the PJM Manuals. Each Market Buyer shall inform the Office of the Interconnection of the prices, if any, at which it desires not to include its load in the Day-ahead Energy Market rather than pay the Day-ahead Price. PRD Providers that have committed Price Responsive Demand in accordance with the Reliability Assurance Agreement shall submit to the Office of the Interconnection, in accordance with procedures specified in the PJM Manuals, any desired updates to their previously submitted PRD Curves, provided that such updates are consistent with their Price Responsive Demand commitments, and provided further that PRD Providers that are not Load Serving Entities for the Price Responsive Demand at issue may only submit PRD Curves for the Real-time Energy Market. Price Responsive Demand that has been committed in accordance with the Reliability Assurance Agreement shall be presumed available for the next Operating Day in accordance with the most recently submitted PRD Curve unless the PRD Curve is updated to indicate otherwise. PRD Providers may also submit PRD Curves for any Price Responsive Demand that is not committed in accordance with the Reliability Assurance Agreement; provided that PRD Providers that are not Load Serving Entities for the Price Responsive Demand at issue may only submit PRD Curves for the Real-time Energy Market. All PRD Curves shall be on a PRD Substation basis, and shall specify the maximum time period required to implement load reductions.

(b) Each Generating Market Buyer shall submit to the Office of the Interconnection: (i) hourly schedules for resource increments, including hydropower units, self-scheduled by the Market Buyer to meet its Equivalent Load; and (ii) the Dispatch Rate at which each such self-scheduled resource will disconnect or reduce output, or confirmation of the Market Buyer's intent not to reduce output.

(c) All Market Participants shall submit to the Office of the Interconnection schedules for any energy exports, energy imports, and wheel through transactions involving use of generation or Transmission Facilities as specified below, and shall inform the Office of the Interconnection if the transaction is to be scheduled in the Day-ahead Energy Market. Any Market Participant that elects to schedule an export, import or wheel through transaction in the Day-ahead Energy Market may specify the price (such price not to exceed \$2,000/MWh), if any, at which the export, import or wheel through transaction will be wholly or partially curtailed. The foregoing price specification shall apply to the applicable interface pricing point. Any Market Participant that elects not to schedule its export, import or wheel through transaction in the Day-ahead Energy Market shall inform the Office of the Interconnection if the parties to the transaction are not willing to incur Transmission Congestion and Loss Charges in the Real-time Energy Market in order to complete any such scheduled transaction. Such transactions in the Real-time Energy Market, other than Coordinated Transaction Schedules and emergency energy sales and purchases, may specify a price up to \$2,000/MWh. Scheduling of such transactions shall be conducted in accordance with the specifications in the PJM Manuals and the following requirements:

i) Market Participants shall submit schedules for all energy purchases for delivery within the PJM Region, whether from resources inside or outside the PJM Region;

ii) Market Participants shall submit schedules for exports for delivery outside the PJM Region from resources within the PJM Region that are not Dynamic Transfers to such entities pursuant to Tariff, Attachment K-Appendix, section 1.12; and

iii) In addition to the foregoing schedules for exports, imports and wheel through transactions, Market Participants shall submit confirmations of each scheduled transaction from each other party to the transaction in addition to the party submitting the schedule, or the adjacent Control Area.

(c-1) A Market Participant may elect to submit in the Day-ahead Energy Market a form of Virtual Transaction that combines an offer to sell energy at a source, with a bid to buy the same megawatt quantity of energy at a sink where such transaction specifies the maximum difference between the Locational Marginal Prices at the source and sink. The Office of Interconnection will schedule these transactions only to the extent this difference in Locational Marginal Prices is within the maximum amount specified by the Market Participant. A Virtual Transaction of this type is referred to as an "Up-to Congestion Transaction." Such Up-to Congestion Transactions may be wholly or partially scheduled depending on the price difference between the source and sink locations in the Day-ahead Energy Market. The maximum

difference between the source and sink prices that a participant may specify shall be limited to +/- \$50/MWh. The foregoing price specification shall apply to the price difference between the specified source and sink in the day-ahead scheduling process only. An accepted Up-to Congestion Transaction results in scheduled injection at a specified source and scheduled withdrawal of the same megawatt quantity at a specified sink in the Day-ahead Energy Market.

(c-2) A Market Participant may elect to submit an Increment Offer and/or Decrement Bid form of Virtual Transaction in the Day-ahead Energy Market and shall specify the price for such transaction which shall be limited to \$2,000/megawatt-hour.

(c-3) Up-to Congestion Transactions may only be submitted at hubs, Residual Metered Load and interfaces not described in Tariff, Attachment K-Appendix, section 2.6A(b). Increment Offers and Decrement Bids may be only submitted at hubs, nodes at which physical generation or load is settled, Residual Metered Load and interfaces not described in Tariff, Attachment K-Appendix, section 2.6A(b).

(d) Market Sellers in the Day-ahead Energy Market shall submit offers for the supply of energy, demand reductions, or other services for the following Operating Day for each clock hour for which the Market Seller desires or is required to make its resource available to the Office of the Interconnection. Offers for the supply of energy may be cost-based, market-based, or both, and may vary hourly. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A(d), section 1.10.9B below, Operating Agreement, Schedule 2, and the PJM Manuals, as applicable. Market Sellers owning or controlling the output of a Generation Capacity Resource that is committed as a Capacity Resource under Tariff, Attachment DD or RAA, Schedule 8.1, and that has not been rendered unavailable by a Generator Planned Outage, a Generator Maintenance Outage, or a Generator Forced Outage shall submit offers for the available capacity of such Generation Capacity Resource, including any portion that is self-scheduled by the Generating Market Buyer. Such offers shall be based on the ICAP equivalent of the Market Seller's cleared UCAP capacity commitment, provided, however, where the underlying resource is a Capacity Storage Resource or an Intermittent Resource, the Market Seller shall satisfy the must offer requirement by either self-scheduling or offering the unit as a dispatchable resource, in accordance with the PJM Manuals, where the hourly day-ahead self-scheduled values for such Capacity Storage Resources and Intermittent Resources may vary hour to hour from the capacity commitment. Any offer not designated as a Maximum Emergency offer shall be considered available for scheduling and dispatch under both Emergency and non-Emergency conditions. Offers may only be designated as Maximum Emergency offers to the extent that the Generation Capacity Resource falls into at least one of the following categories:

i) Environmental limits. If the resource has a limit on its run hours imposed by a federal, state, or other governmental agency that will significantly limit its availability, on either a temporary or long-term basis. This includes a resource that is limited to operating only during declared PJM capacity emergencies by a governmental authority.

ii) Fuel limits. If physical events beyond the control of the resource owner result in the temporary interruption of fuel supply and there is limited on-site fuel storage. A fuel supplier's exercise of a contractual right to interrupt supply or delivery under an interruptible service agreement shall not qualify as an event beyond the control of the resource owner.

iii) Temporary emergency conditions at the unit. If temporary emergency physical conditions at the resource significantly limit its availability.

iv) Temporary megawatt additions. If a resource can provide additional megawatts on a temporary basis by oil topping, boiler over-pressure, or similar techniques, and such megawatts are not ordinarily otherwise available.

The submission of offers for resource increments that are not committed as a Capacity Resource under Tariff, Attachment DD or RAA, Schedule 8.1 shall be optional, but any such offers must contain the information specified in the Office of the Interconnection's Offer Data specification, Operating Agreement, Schedule 1, sections 1.10.1A(d) and 1.10.9B, Operating Agreement, Schedule 2, and the PJM Manuals, as applicable. Energy offered from generation resources that are not committed as a Capacity Resource under Tariff, Attachment DD or RAA, Schedule 8.1 shall not be supplied from resources that are included in or otherwise committed to supply the Operating Reserves of a Control Area outside the PJM Region.

The foregoing offers:

i) Shall specify the Generation Capacity Resource or Economic Load Response Participant resource and energy or demand reduction amount, respectively, for each clock hour in the offer period;

ii) Shall specify the amounts and prices for each clock hour during the entire Operating Day for each resource component offered by the Market Seller to the Office of the Interconnection;

iii) May specify for generation resources offer parameters for each clock hour during the entire Operating Day, as applicable and in accordance with section 1.10.9B below, including: (1) Minimum Run Time; (2) maximum run time; (3) Start-up Costs; (4) No-load Costs; (5) Incremental Energy Offer; (6) notification time; (7) availability; (8) ramp rate; (9) Economic Minimum; (10) Economic Maximum; (11) emergency minimum MW; (12) emergency maximum MW; (13) Synchronized Reserve maximum MW; (14) Secondary Reserve maximum MW; and (15) condense to generation time constraints, and may specify offer parameters for Economic Load Response Participant resources for each clock hour during the entire Operating Day, as applicable and in accordance with section 1.10.9B below, including: (1) minimum down time; (2) shutdown costs; (3) Incremental Energy Offer; (4) notification time; (5) Economic Minimum; and (6) Economic Maximum;

iv) Shall set forth any special conditions upon which the Market Seller proposes to supply a resource increment, including any curtailment rate specified in a bilateral contract for the output of the resource, or any cancellation fees;

v) May include a schedule of offers for prices and operating data contingent on acceptance by the deadline specified in this Schedule, with additional schedules applicable if accepted after the foregoing deadline;

vi) Shall constitute an offer to submit the resource increment to the Office of the Interconnection for scheduling and dispatch in accordance with the terms of the offer for the clock hour, which offer shall remain open through the Operating Day, for which the offer is submitted, unless the Market Seller a) submits a Real-time Offer for the applicable clock hour, or b) updates the availability of its offer for that hour, as further described in the PJM Manuals;

vii) Shall be final as to the price or prices at which the Market Seller proposes to supply energy or other services to the PJM Interchange Energy Market, such price or prices being guaranteed by the Market Seller for the period extending through the end of the following Operating Day, unless modified after the close of the Day-ahead Energy Market as permitted pursuant to sections 1.10.9A or 1.10.9B below;

viii) Shall not exceed an energy offer price of \$1,000/megawatt-hour for all generation resources, except (1) when a Market Seller's cost-based offer is above \$1,000/megawatt-hour and less than or equal to \$2,000/megawatt-hour, then its market-based offer must be less than or equal to the cost-based offer; and (2) when a Market Seller's cost-based offer is greater than \$2,000/megawatt-hour, then its market-based offer must be less than or equal to \$2,000/megawatt-hour;

ix) Shall not exceed a demand reduction offer price of \$1,000/megawatt-hour, except when an Economic Load Response Participant submits a cost-based offer that includes an incremental cost component that is above \$1,000/megawatt-hour, then its market-based offer must be less than or equal to the cost-based offer but in no event greater than \$2,000/megawatt-hour;

x) Shall not exceed an offer price as follows for Emergency Load Response and Pre-Emergency Load Response participants with:

a) a 30 minute lead time, pursuant to Tariff, Attachment DD-1, section A.2 and the parallel provision of RAA, Schedule 6, \$1,000/megawatt-hour, plus the applicable Reserve Penalty Factor for the Primary Reserve Requirement, minus \$1.00;

b) an approved 60 minute lead time, pursuant to Tariff, Attachment DD-1, section A.2 and the parallel provision of RAA, Schedule 6, \$1,000/megawatt hour, plus [the applicable Reserve Penalty Factor for the Primary Reserve Requirement divided by 2]; and

c) an approved 120 minute lead time, pursuant to Tariff, Attachment DD-1, section A.2 and the parallel provisions of RAA, Schedule 6, \$1,100/megawatt-hour; and

xi) Shall not exceed an energy offer price of \$0.00/MWh for pumped storage hydropower units scheduled by the Office of the Interconnection pursuant to the hydro optimization tool in the Day-ahead Energy Market.

(e) A Market Seller that wishes to make a resource available to sell Regulation service shall submit an offer for Regulation for each clock hour for which the Market Seller desires to make its resource available to the Office of the Interconnection to provide Regulation that shall specify the megawatts of Regulation being offered, which must equal or exceed 0.1 megawatts, the Regulation Zone for which such Regulation is offered, the price of the capability offer in dollars per MW, the price of the performance offer in Dollars per change in MW, and such other information specified by the Office of the Interconnection as may be necessary to evaluate the offer and the resource's opportunity costs. Such offers may vary hourly, and may be updated each hour, up to 65 minutes before the applicable clock hour during the Operating Day. The total of the performance offer multiplied by the historical average mileage used in the market clearing plus the capability offer shall not exceed \$100/megawatt-hour in the case of Regulation offered for all Regulation Zones. In addition to any market-based offer for Regulation, the Market Seller also shall submit a cost-based offer. A cost-based offer must be in the form specified in the PJM Manuals and consist of the following components as well as any other components specified in the PJM Manuals:

i. The costs (in \$/MW) of the fuel cost increase due to the steady-state heat rate increase resulting from operating the unit at lower megawatt output incurred from the provision of Regulation shall apply to the capability offer;

ii. The cost increase (in \$/ΔMW) in costs associated with movement of the regulation resource incurred from the provision of Regulation shall apply to the performance offer; and

iii. An adder of up to \$12.00 per megawatt of Regulation provided applied to the capability offer.

Qualified Regulation capability must satisfy the measurement and verification tests specified in the PJM Manuals.

(f) Each Market Seller owning or controlling the output of a Generation Capacity Resource committed to service of PJM loads under the Reliability Pricing Model or Fixed Resource Requirement Alternative shall submit a forecast of the availability of each such Generation Capacity Resource for the next seven days. A Market Seller (i) may submit a non-binding forecast of the price at which it expects to offer a generation resource increment to the Office of the Interconnection over the next seven days, and (ii) shall submit a binding offer for energy, along with Start-up Costs and No-load Costs, if any, for the next seven days or part

thereof, for any generation resource with minimum notification or start-up requirement greater than 24 hours. Such resources committed by the Office of the Interconnection will not receive Operating Reserve Credits nor otherwise be made whole for its hours of operation for the duration of any portion of such commitment that exceeds the maximum start-up and notification times for such resources during Hot Weather Alerts and Cold Weather Alerts, consistent with Tariff, Attachment K-Appendix, section 3.2.3 and Tariff, Attachment K-Appendix, section 6.6.

(g) Each component of an offer by a Market Seller of a Generation Capacity Resource that is constant for the entire Operating Day and does not vary hour to hour shall remain in effect for subsequent Operating Days until superseded or canceled.

(h) The Office of the Interconnection shall post the total hourly loads scheduled in the Day-ahead Energy Market, as well as, its estimate of the combined hourly load of the Market Buyers for the next four days, and peak load forecasts for an additional three days.

(i) Except for Economic Load Response Participants, all Market Participants may submit Virtual Transactions that apply to the Day-ahead Energy Market only. Such Virtual Transactions must comply with the requirements set forth in the PJM Manuals and must specify amount, location and price, if any, at which the Market Participant desires to purchase or sell energy in the Day-ahead Energy Market. The Office of the Interconnection may require that a market participant shall not submit in excess of a defined number of bid/offer segments in the Day-ahead Energy Market, as specified in the PJM Manuals, when the Office of the Interconnection determines that such limit is required to avoid or mitigate significant system performance problems related to bid/offer volume. Notice of the need to impose such limit shall be provided prior to 10:00 a.m. EPT on the day that the Day-ahead Energy Market will clear. For purposes of this provision, a bid/offer segment is each pairing of price and megawatt quantity submitted as part of an Increment Offer or Decrement Bid. For purposes of applying this provision to an Up-to Congestion Transaction, a bid/offer segment shall refer to the pairing of a source and sink designation, as well as price and megawatt quantity, that comprise each Up-to Congestion Transaction.

(j) (i) Offers to Supply Synchronized and Non-Synchronized Reserves By Generation Resources in the Day-ahead and Real-time Reserve Markets

(1) Market Sellers owning or controlling the output of a Generation Capacity Resource that was committed in an FRR Capacity Plan, self-supplied, offered and cleared in a Base Residual Auction or Incremental Auction, or designated as replacement capacity, as specified in Tariff, Attachment DD, is capable of providing Synchronized Reserve or Non-Synchronized Reserve as specified in section 1.7.19A(a), in section 1.7.19A.01(a) and in the PJM Manuals, and has not been rendered unavailable by a Generator Planned Outage, a Generator Maintenance Outage, or a Generator Forced Outage, shall submit offers or otherwise make their 10-minute reserve capability available to supply Synchronized Reserve or, as applicable, Non-Synchronized Reserve, including any portion that is self-scheduled by the Generating Market Buyer, in an amount equal to the available 10-minute reserve capability of such Generation Capacity

Resource. Market Sellers of Generation Capacity Resources subject to this must-offer requirement that do not make the reserve capability of such resources available when such resource is able to operate with a dispatchable range (e.g. through offering a fixed output) will be in violation of this provision.

(2) Market Sellers of all other generation resources that (A) are capable of providing Synchronized Reserve or Non-Synchronized Reserve, as specified in section 1.7.19A(a), in section 1.7.19A.01(a) and in the PJM Manuals, (B) are located within the metered boundaries of the PJM Region, and (C) have submitted offers for the supply of energy into the Day-ahead Energy Market and/or Real-time Energy Market shall be deemed to have made their reserve capability available to provide Synchronized Reserve or Non-Synchronized Reserve in the Day-ahead Energy Market and/or Real-time Energy Market for each clock hour for which the Market Seller submits an available offer to supply energy; provided, however that hydroelectric generation resources and Energy Storage Resources are not automatically deemed available to provide reserves based on the submission of an available energy offer but may submit offers to supply Synchronized Reserve and Non-Synchronized Reserve, as applicable.

(3) Offers for the supply of Synchronized Reserve by all generation resources must be cost-based. Consistent with the resource's offer to supply energy, such offers may vary hourly and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A, section 1.10.9B below, and the PJM Manuals, as applicable. For offers to supply Synchronized Reserve, the offer price shall not exceed the expected value of the penalty for failing to provide Synchronized Reserve, where such expected value shall be recalculated annually, in accordance with the PJM Manuals, and posted on PJM's website. The expected value of the penalty is calculated as the product of: (A) the average penalty, expressed in \$/MWh, multiplied by (B) the average rate of non-performance during Synchronized Reserve events multiplied by (C) the probability a Synchronized Reserve event that will qualify for non-performance assessments will occur.

The expected value of the penalty shall be determined by an annual review of the twelve-month period ending October 31 of the calendar year in which the review is performed. The Office of the Interconnection shall post the results of its annual review by no later than December 15, and the revised offer price cap shall be effective as of the following January 1; provided, however, that at the time of implementation of this rule the expected value of the penalty shall be \$0.02/MWh, and for the period from the second month after implementation through the second ~~January 1~~December 31 following such date of implementation, the expected value of the penalty shall be recalculated on a monthly basis using data

from the implementation date of this rule through the 15th day of the current month, and the revised value shall be effective the 1st day of the following month.

(4) All Non-Synchronized Reserve offers shall be for \$0.00/MWh. Consistent with the resource's offer to supply energy, such offers may vary hourly and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this subsection (d) of this section 1.10.1A(d), section 1.10.9B below, and the PJM Manuals, as applicable.

(ii) Determination of Available Synchronized Reserve Capability of Generation Resources

(1) For each offer to supply reserves by a synchronized resource, the Office of the Interconnection shall determine the MW of available Synchronized Reserve capability offered in the Day-ahead Energy Market and Real-time Energy Market, in accordance with the PJM Manuals; except, however, that the Office of the Interconnection will not make such determination for hydroelectric generation resources or Energy Storage Resources. Hydroelectric generation resources and Energy Storage Resources may submit offers for their available Synchronized Reserve capability as part of their offer into the Synchronized Reserve market, provided that such offer equals or exceeds 0.1 MW; however, any such resource which is subject to the must offer requirements in section 1.10.1A(j)(i) above must submit a Synchronized Reserve offer which specifies the MW of available Synchronized Reserve capability in order to remain compliant with such requirements.

(2) An on-line generation resource's available Synchronized Reserve capability, except for generation resources capable of synchronous condensing, shall be determined in accordance with the PJM Manuals and based on the resource's current performance and initial energy output and the following offer parameters submitted as part of the resource's energy offer: (A) ramp rate; (B) Economic Minimum; and (C) the lesser of Economic Maximum and Synchronized Reserve maximum MW, where Synchronized Reserve maximum MW may be lower than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Synchronized Reserves above the Synchronized Reserve maximum MW.

For generation resources capable of synchronous condensing, the resource's available Synchronized Reserve capability shall be based on the following offer parameters submitted as part of the resource's energy offer: (D) ramp rate; (E) condense to generation time constraints; (F) Economic Minimum;

and (G) the lesser of Economic Maximum and Synchronized Reserve maximum MW, where Synchronized Reserve maximum MW may be lower than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Synchronized Reserves above the Synchronized Reserve maximum MW.

(3) Any Market Seller that believes its generating unit has operating modes, limits, or conditions where the unit would not be capable of providing Synchronized Reserves in real time, can submit to the Office of the Interconnection with a copy to the Market Monitoring Unit a request for an exception from being assigned Synchronized Reserves in the Real-time Synchronized Reserve Market during time periods in which the generating unit is in those operating modes, limits, or conditions. As part of the request, the Market Seller shall supply, for each generating unit, technical information about the operational modes, limits, or conditions to support the requested exception, as further detailed in the PJM Manuals. The Office of the Interconnection shall consult with the Market Monitoring Unit, and consider any input received from the Market Monitoring Unit, in its determination of a request for such an exception. Within 60 days of the submission of the request, the Office of the Interconnection shall notify the Market Seller in writing, with a copy to the Market Monitoring Unit, whether the request is approved or denied. The effective date of any approved request will be provided in the written notification. If a Market Seller has an approved exception, the Market Seller must communicate to the Office of the Interconnection when the unit cannot provide reserves, and the Office of the Interconnection will provide a mechanism for Market Sellers with an approved exception to provide such communication to the Office of the Interconnection in real time, as further detailed in the PJM Manuals. An approved exception will remain applicable to the unit until such time as the Office of the Interconnection determines that a change is needed or the Market Seller notifies the Office of the Interconnection, with a copy to the Market Monitoring Unit, that a change is needed based on changed operational capabilities of the unit. Market Sellers must notify the Office of the Interconnection, with a copy to the Market Monitoring Unit, within 30 days of any changed operational capabilities that necessitate a change in an approved exception.

(iii) Determination of Available Non-Synchronized Reserve Capability of Generation Resources

(1) For each offer to supply reserves by an off-line generation resource, the Office of the Interconnection shall determine the MW of available Non-Synchronized Reserve capability offered in the Day-ahead Energy Market and Real-time Energy Market in accordance with the PJM Manuals; except, however, that the Office of the Interconnection will not make such determination for hydroelectric generation resources or Energy Storage Resources. Such

hydroelectric generation resources or Energy Storage Resources may submit offers for their available Non-Synchronized Reserve capability as part of their offer into the Non-Synchronized Reserve market, provided that such offer equals or exceeds 0.1 MW; however, any such resource which is subject to the must offer requirements in section 1.10.1A(j)(i) above must submit a Non-Synchronized Reserve offer which specifies the MW of available Non-Synchronized Reserve capability in order to remain compliant with such requirements.

(2) An off-line generation resource's available Non-Synchronized Reserve capability shall be determined in accordance with the PJM Manuals and based on the following offer parameters submitted as part of the resource's energy offer: (A) startup time; (B) notification time; (C) ramp rate; (D) Economic Minimum; and (E) the lesser of Economic Maximum and Synchronized Reserve maximum MW, where Synchronized Reserve maximum MW may be lower than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Non-Synchronized Reserves above its Synchronized Reserve maximum MW.

(iv) Offers to Supply Synchronized Reserves by Economic Load Response Participant Resources in the Day-ahead and Real-time Reserve Markets

(1) Economic Load Response Participants that submit offers to reduce demand into the Day-ahead Energy Market and Real-time Energy Market and wish to make their resources available to supply Synchronized Reserve may submit offers to supply Synchronized Reserve from such resources, where such offers shall specify the megawatts of Synchronized Reserve being offered, which must equal or exceed 0.1 megawatts and such other information specified by the Office of the Interconnection as may be necessary to evaluate the offer. Such offers may vary hourly, and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day.

(2) All offers to supply Synchronized Reserve offers from Economic Load Response Participant resources shall not exceed the expected value of the penalty for failing to provide Synchronized Reserve, as determined in accordance with section 1.10.1A(j)(i)(3) above. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A(d), section 1.10.9B below, and the PJM Manuals, as applicable.

(k) An Economic Load Response Participant that wishes to participate in the Day-ahead Energy Market by reducing demand shall submit an offer to reduce demand to the Office of the Interconnection for each clock hour for which the Economic Load Response Participant desires to make its resource available to the Office of the Interconnection to reduce demand. The

offer must equal or exceed 0.1 megawatts, may vary hourly, and shall specify: (i) the amount of the offered curtailment in minimum increments of .1 megawatts; (ii) the Day-ahead Locational Marginal Price above which the end-use customer will reduce load, subject to section 1.10.1A(d)(ix); and (iii) at the Economic Load Response Participant's option, shutdown costs associated with reducing load, including direct labor and equipment costs, opportunity costs, and/or a minimum of number of contiguous hours for which the load reduction must be committed. Such offers may be updated each hour, up to 65 minutes before the applicable clock hour during the Operating Day. Economic Load Response Participants submitting offers to reduce demand in the Day-ahead Energy Market may establish an incremental offer curve, provided that such offer curve shall be limited to ten price pairs (in MWs) per hour.

(l) Market Sellers owning or controlling the output of an Economic Load Response Participant resource that was committed in an FRR Capacity Plan, or that was self-supplied or that offered and cleared in a Base Residual Auction or Incremental Auction, may submit demand reduction bids for the available load reduction capability of the Economic Load Response Participant resource. The submission of demand reduction bids for Economic Load Response Participant resource increments that were not committed in an FRR Capacity Plan, or that have not cleared in a Base Residual Auction or Incremental Auction, shall be optional, but any such bids must contain the information required to be included in such bids, as specified in the PJM Economic Load Response Program. An Economic Load Response Participant resource that was committed in an FRR Capacity Plan, or that was self-supplied or offered and cleared in a Base Residual Auction or Incremental Auction, may submit a demand reduction bid in the Day-ahead Energy Market as specified in the Economic Load Response Program; provided, however, that in the event of an Emergency PJM shall require Economic Load Response Participant resources to reduce load, notwithstanding that the Zonal LMP at the time such Emergency is declared is below the price identified in the demand reduction bid.

(m) (i) Offers to Supply Secondary Reserve By Generation Resources

(1) Market Sellers owning or controlling the output of a Generation Capacity Resource that was committed in an FRR Capacity Plan, self-supplied, offered and cleared in a Base Residual Auction or Incremental Auction, or designated as replacement capacity, as specified in Tariff, Attachment DD, that is available for energy, is capable of providing Secondary Reserve, as specified in section 1.7.19A.02(a) and in the PJM Manuals, and has not been rendered unavailable by a Generator Planned Outage, a Generator Maintenance Outage, or a Generator Forced Outage shall submit offers to supply Secondary Reserve, or otherwise make their Secondary Reserve capability available. Such offers shall be for an amount equal to the resource's available energy output achievable within thirty minutes (less its energy output achievable within ten minutes) from a request of the Office of the Interconnection. Market Sellers of Generation Capacity Resources subject to this must-offer requirement that do not make the reserve capability of such resources available when such resource is able to operate with a dispatchable range (e.g. through offering a fixed output) will be in violation of this provision.

(2) Market Sellers of all other generation resources located within the metered boundaries of the PJM Region that submit offers for the supply of energy into the Day-ahead Energy Market and/or Real-time Energy Market and are capable of providing Secondary Reserve, as specified in the PJM Manuals, shall be deemed to have made their reserve capability available to provide Secondary Reserve in the Day-ahead Energy Market and/or Real-time Energy Market for each clock hour for which the Market Seller submits an available offer to supply energy; provided, however that hydroelectric generation resources and Energy Storage Resources are not automatically deemed available to provide reserves based on the submission of an available energy offer but may submit offers to supply Secondary Reserve, as applicable.

(3) Offers for the supply of Secondary Reserve shall be for \$0.00/MWh. Consistent with the resource's offer to supply energy, such offers may vary hourly and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this subsection (d) above, section 1.10.9B below, and the PJM Manuals, as applicable.

(ii) Determination of Available Secondary Reserve Capability of Generation Resources

(1) For each offer to supply Secondary Reserve by a generation resource, the Office of the Interconnection shall determine the MW of available Secondary Reserve capability offered in the Day-ahead Energy Market and Real-time Energy Market in accordance with the PJM Manuals; except, however, that the Office of the Interconnection will not make such determination for hydroelectric generation resources or Energy Storage Resources. Hydroelectric generation resources or Energy Storage Resources may submit their available Secondary Reserve capability as part of their offer into the Secondary Reserve market, provided that such offer equals or exceeds 0.1 MW; however, any such resource which is subject to the must offer requirements in section 1.10.1A(m)(i) above must submit a Secondary Reserve offer which specifies the MW of available Secondary Reserve capability in order to remain compliant with such requirements.

(2) (A) An on-line generation resource's available Secondary Reserve capability, except for generation resources capable of synchronous condensing, shall be based on the resource's current performance and initial energy output, the resource's available Synchronized Reserve capability; and the following offer parameters submitted as part of the energy offer: (i) ramp rate; (ii) Economic Minimum; and (iii) the lesser of Economic Maximum and Secondary Reserve maximum MW, where a resource's Secondary Reserve

maximum MW may be less than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Secondary Reserves above its Secondary Reserve maximum MW.

(B) For generation resources capable of synchronous condensing, the resource's available Secondary Reserve capability shall be based on the following offer parameters submitted as part of the energy offer: (i) ramp rate; (ii) condense to generation time constraints; (iii) Economic Minimum; and (iv) the lesser of Economic Maximum and Secondary Reserve maximum MW, where a resource's Secondary Reserve maximum MW may be less than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Secondary Reserves above its Secondary Reserve maximum MW.

(C) An off-line generation resource's available Secondary Reserve capability, shall be based on the resource's available Secondary Reserve capability and the following offer parameters submitted as part of the resource's energy offer: (i) startup time; (ii) notification time; (iii) ramp rate; (iv) Economic Minimum; and (v) the lesser of Economic Maximum and Secondary Reserve maximum MW, where a resource's Secondary Reserve maximum MW may be less than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Secondary Reserves above its Secondary Reserve maximum MW.

(3) Any Market Seller that believes its generating unit has operating modes, limits, or conditions where the unit would not be capable of providing Secondary Reserves in real time, can submit to the Office of the Interconnection with a copy to the Market Monitoring Unit a request for an exception from being assigned Secondary Reserves in the Real-time Secondary Reserve Market during time periods in which the generating unit is in those operating modes, limits, or conditions. As part of the request, the Market Seller shall supply, for each generating unit, technical information about the operational modes, limits, or conditions to support the requested exception, as further detailed in the PJM Manuals. The Office of the Interconnection shall consult with the Market Monitoring Unit, and consider any input received from the Market Monitoring Unit, in its determination of a request for such an exception. Within 60 days of the submission of the request, the Office of the Interconnection shall notify

the Market Seller in writing, with a copy to the Market Monitoring Unit, whether the request is approved or denied. The effective date of any approved request will be provided in the written notification. If a Market Seller has an approved exception, the Market Seller must communicate to the Office of the Interconnection when the unit cannot provide reserves, and the Office of the Interconnection will provide a mechanism for Market Sellers with an approved exception to provide such communication to the Office of the Interconnection in real time, as further detailed in the PJM Manuals. An approved exception will remain applicable to the unit until such time as the Office of the Interconnection determines that a change is needed or the Market Seller notifies the Office of the Interconnection, with a copy to the Market Monitoring Unit, that a change is needed based on changed operational capabilities of the unit. Market Sellers must notify the Office of the Interconnection, with a copy to the Market Monitoring Unit, within 30 days of any changed operational capabilities that necessitate a change in an approved exception.

(iii) Offers to Supply Secondary Reserves by Economic Load Response Participant resources

(1) Each Economic Load Response Participant that submits offers to reduce demand into the Day-ahead Energy Market and Real-time Energy Market and wishes to make their resources available to supply Secondary Reserve shall submit offers to supply Secondary Reserve from such resources, where such offers shall specify the megawatts of Secondary Reserve being offered, which must equal or exceed 0.1 megawatts and include such other information specified by the Office of the Interconnection as may be necessary to evaluate the offer. Such offers may vary hourly, and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day.

(2) All Secondary Reserve offers by Economic Load Response Participant resources shall be for \$0.00/MWh. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A(d), section 1.10.9B below, and the PJM Manuals, as applicable.

(n) A Market Participant may submit a Day-Ahead Pseudo-Tie Transaction for a Market Participant's generator within the PJM balancing authority area that is a Pseudo-Tie into the MISO balancing authority area. Day-Ahead Pseudo-Tie Transactions combine an offer to sell energy at a source with a bid to buy the same megawatt quantity of energy at a sink where such transaction specifies the maximum difference between the Locational Marginal Prices at the source and sink.

Each Day-Ahead Pseudo-Tie Transaction shall: (1) source at a Market Participant's generator within the PJM balancing authority area that Pseudo-Ties into MISO; and (2) sink at the PJM-MISO interface. A Market Participant must reserve transmission service in accordance with the PJM Tariff for each Day-Ahead Pseudo-Tie Transaction. Megawatt quantities for Day-Ahead

Pseudo-Tie Transactions shall be greater than zero and less than or equal to the transmission service reserved for the Day-Ahead Pseudo-Tie Transaction. An accepted Day-Ahead Pseudo-Tie Transaction results in scheduled injection at a specified source and scheduled withdrawal of the same megawatt quantity at a specified sink in the Day-Ahead Energy Market.

1.10.1B Demand Bid Scheduling and Screening

(a) The Office of the Interconnection shall apply Demand Bid Screening to all Demand Bids submitted in the Day-ahead Energy Market for each Load Serving Entity, separately by Zone. Using Demand Bid Screening, the Office of the Interconnection will automatically reject a Load Serving Entity's Demand Bids in any future Operating Day for which the Load Serving Entity submits bids if the total megawatt volume of such bids would exceed the Load Serving Entity's Demand Bid Limit for any hour in such Operating Day, unless the Office of the Interconnection permits an exception pursuant to subsection (d) below.

(b) On a daily basis, PJM will update and post each Load Serving Entity's Demand Bid Limit in each applicable Zone. Such Demand Bid Limit will apply to all Demand Bids submitted by that Load Serving Entity for each future Operating Day for which it submits bids. The Demand Bid Limit is calculated using the following equation:

Demand Bid Limit = greater of (Zonal Peak Demand Reference Point * 1.3), or (Zonal Peak Demand Reference Point + 10MW)

Where:

1. Zonal Peak Demand Reference Point = for each Zone: the product of (a) LSE Recent Load Share, multiplied by (b) Peak Daily Load Forecast.
2. LSE Recent Load Share is the Load Serving Entity's highest share of Network Load in each Zone for any hour over the most recently available seven Operating Days for which PJM has data.
3. Peak Daily Load Forecast is PJM's highest available peak load forecast for each applicable Zone that is calculated on a daily basis.

(c) A Load Serving Entity whose Demand Bids are rejected as a result of Demand Bid Screening may change its Demand Bids to reduce its total megawatt volume to a level that does not exceed its Demand Bid Limit, and may resubmit them subject to the applicable rules related to bid submission outlined in Tariff, Operating Agreement and PJM Manuals.

(d) PJM may allow a Load Serving Entity to submit bids in excess of its Demand Bid Limit when circumstances exist that will cause, or are reasonably expected to cause, a Load Serving Entity's actual load to exceed its Demand Bid Limit on a given Operating Day. Examples of such circumstances include, but are not limited to, changes in load commitments due to state sponsored auctions, mergers and acquisitions between PJM Members, and sales and divestitures between PJM Members. A Load Serving Entity may submit a written exception request to the Office of Interconnection for a higher Demand Bid Limit for an affected Operating Day. Such request must include a detailed explanation of the circumstances at issue and

supporting documentation that justify the Load Serving Entity's expectation that its actual load will exceed its Demand Bid Limit.

1.10.2 Pool-scheduled Resources.

Pool-scheduled resources are those resources for which Market Participants submitted offers to sell energy in the Day-ahead Energy Market and offers to reduce demand in the Day-ahead Energy Market, which the Office of the Interconnection scheduled in the Day-ahead Energy Market as well as generators committed by the Office of the Interconnection subsequent to the Day-ahead Energy Market. Such resources shall be committed to provide energy in the real-time dispatch unless the schedules for such units are revised pursuant to section 1.10.9 below or Tariff, Attachment K-Appendix, section 1.11. Pool-scheduled resources shall be governed by the following principles and procedures.

(a) Pool-scheduled resources shall be selected by the Office of the Interconnection on the basis of the prices offered for energy and demand reductions and related services, whether the resource is expected to be needed to maintain system reliability during the Operating Day, Start-up Costs, No-load Costs and cancellation fees, and the specified operating characteristics, offered by Market Sellers to the Office of the Interconnection by the offer deadline specified in section 1.10.1A above. Hydropower units can only be pool-scheduled if they are pumped storage units and scheduled by the Office of the Interconnection pursuant to the hydro optimization tool in the Day-ahead Energy Market.

(b) A resource that is scheduled by a Market Participant to support a bilateral sale, or that is self-scheduled by a Generating Market Buyer, shall not be selected by the Office of the Interconnection as a pool-scheduled resource except in an Emergency.

(c) Market Sellers offering energy from hydropower or other facilities with fuel or environmental limitations may submit data to the Office of the Interconnection that is sufficient to enable the Office of the Interconnection to determine the available operating hours of such facilities.

(d) The Market Seller of a resource selected as a pool-scheduled resource shall receive payments or credits for energy, demand reductions or related services, or for Start-up Costs and No-load Costs, from the Office of the Interconnection on behalf of the Market Buyers in accordance with Tariff, Attachment K-Appendix, section 3. Alternatively, the Market Seller shall receive, in lieu of Start-up Costs and No-load Costs, its actual costs incurred, if any, up to a cap of the resource's Start-up Costs, if the Office of the Interconnection cancels its selection of the resource as a pool-scheduled resource and so notifies the Market Seller before the resource is synchronized.

(e) Market Participants shall make available their pool-scheduled resources to the Office of the Interconnection for coordinated operation to supply the Operating Reserves needs of the applicable Control Zone.

(f) Economic Load Response Participants offering to reduce demand shall specify: (i) the amount of the offered curtailment, which must equal or exceed 0.1 megawatts, in minimum increments of 0.1 megawatts; (ii) the real-time Locational Marginal Price above which the end-use customer will reduce load; and (iii) at the Economic Load Response Participant's option, shut-down costs associated with reducing load, including direct labor and equipment costs, opportunity costs, and/or a minimum number of contiguous hours for which the load reduction must be committed. Economic Load Response Participants submitting offers to reduce demand in the Day-ahead Energy Market and/or the Real-time Energy Market may establish an incremental offer curve, provided that such offer curve shall be limited to ten price pairs (in MWs). Economic Load Response Participants offering to reduce demand shall also indicate the hours that the demand reduction is not available.

1.10.3 Self-scheduled Resources.

Self-scheduled resources shall be governed by the following principles and procedures.

(a) Each Generating Market Buyer shall use all reasonable efforts, consistent with Good Utility Practice, not to self-schedule resources in excess of its Equivalent Load.

(b) The offered prices of resources that are self-scheduled and not dispatchable by the Office of the Interconnection shall not be considered by the Office of the Interconnection in determining Locational Marginal Prices.

(c) Market Participants shall make available their self-scheduled resources to the Office of the Interconnection for coordinated operation to supply the Operating Reserves needs of the applicable Control Zone, by submitting an offer as to such resources.

(d) A Market Participant self-scheduling a resource in the Day-ahead Energy Market that does not deliver the energy in the Real-time Energy Market, shall replace the energy not delivered with energy from the Real-time Energy Market and shall pay for such energy at the applicable Real-time Price.

(e) A Market Participant self-scheduling a resource to supply Synchronized Reserve in the Day-ahead Synchronized Reserve Market that does not deliver the scheduled megawatt quantity in the applicable real-time reserve market, shall replace the Synchronized Reserve not delivered and shall pay for such Synchronized Reserve at the applicable Real-time Synchronized Reserve Market Clearing Price. Market Participants shall not self-schedule a resource to provide Secondary Reserve or Non-Synchronized Reserve.

(f) For energy, hydropower units, excluding pumped storage units, may only be self-scheduled.

(g) A resource that has been self-scheduled shall not receive payments or credits for Start-up Costs or No-load Costs.

1.10.4 Capacity Resources.

(a) A Generation Capacity Resource committed to service of PJM loads under the Reliability Pricing Model or Fixed Resource Requirement Alternative that is selected as a pool-scheduled resource shall be made available for scheduling and dispatch at the direction of the Office of the Interconnection. Such a Generation Capacity Resource that does not deliver energy as scheduled shall be deemed to have experienced a Generator Forced Outage to the extent of such energy not delivered. A Market Participant offering such Generation Capacity Resource in the Day-ahead Energy Market shall replace the energy not delivered with energy from the Real-time Energy Market and shall pay for such energy at the applicable Real-time Price.

(b) Energy from a Generation Capacity Resource committed to service of PJM loads under the Reliability Pricing Model or Fixed Resource Requirement Alternative that has not been scheduled in the Day-ahead Energy Market may be sold on a bilateral basis by the Market Seller, may be self-scheduled, or may be offered for dispatch during the Operating Day in accordance with the procedures specified in this Schedule. Such a Generation Capacity Resource that has not been scheduled in the Day-ahead Energy Market and that has been sold on a bilateral basis must be made available upon request to the Office of the Interconnection for scheduling and dispatch during the Operating Day if the Office of the Interconnection declares a Maximum Generation Emergency. Any such resource so scheduled and dispatched shall receive the applicable Real-time Price for energy delivered.

1.10.5 External Resources.

(a) External Resources may submit offers to the PJM Interchange Energy Market, in accordance with the day-ahead and real-time scheduling processes specified above. An External Resource selected as a pool-scheduled resource shall be made available for scheduling and dispatch at the direction of the Office of the Interconnection, and except as specified below shall be compensated on the same basis as other pool-scheduled resources. External Resources that are not capable of Dynamic Transfer shall, if selected by the Office of the Interconnection on the basis of the Market Seller's Offer Data, be block loaded on an hourly scheduled basis. Market Sellers shall offer External Resources to the PJM Interchange Energy Market on either a resource-specific or an aggregated resource basis. A Market Participant whose pool-scheduled resource does not deliver the energy scheduled in the Day-ahead Energy Market shall replace such energy not delivered as scheduled in the Day-ahead Energy Market with energy from the PJM Real-time Energy Market and shall pay for such energy at the applicable Real-time Price.

(b) Offers for External Resources from an aggregation of two or more generating units shall so indicate, and shall specify, in accordance with the Offer Data requirements specified by the Office of the Interconnection: (i) energy prices; (ii) hours of energy availability; (iii) a minimum dispatch level; (iv) a maximum dispatch level; and (v) unless such information has previously been made available to the Office of the Interconnection, sufficient information, as specified in the PJM Manuals, to enable the Office of the Interconnection to model the flow into the PJM Region of any energy from the External Resources scheduled in accordance with the Offer Data.

(c) Offers for External Resources on a resource-specific basis shall specify the resource being offered, along with the information specified in the Offer Data as applicable.

1.10.6 External Market Buyers.

(a) Deliveries to an External Market Buyer not subject to Dynamic Transfer by the Office of the Interconnection shall be delivered on a block loaded basis to the bus or buses at the electrical boundaries of the PJM Region, or in such area with respect to an External Market Buyer's load within such area not served by Network Service, at which the energy is delivered to or for the External Market Buyer. External Market Buyers shall be charged (which charge may be positive or negative) at either the Day-ahead Prices or Real-time Prices, whichever is applicable, for energy at the foregoing bus or buses.

(b) An External Market Buyer's hourly schedules for energy purchased from the PJM Interchange Energy Market shall conform to the ramping and other applicable requirements of the interconnection agreement between the PJM Region and the Control Area to which, whether as an intermediate or final point of delivery, the purchased energy will initially be delivered.

(c) The Office of the Interconnection shall curtail deliveries to an External Market Buyer if necessary to maintain appropriate reserve levels for a Control Zone as defined in the PJM Manuals, or to avoid shedding load in such Control Zone.

1.10.7 Bilateral Transactions.

Bilateral transactions as to which the parties have notified the Office of the Interconnection by the deadline specified in section 1.10.1A above that they elect not to be included in the Day-ahead Energy Market and that they are not willing to incur Transmission Congestion Charges in the Real-time Energy Market shall be curtailed by the Office of the Interconnection as necessary to reduce or alleviate transmission congestion. Bilateral transactions that were not included in the Day-ahead Energy Market and that are willing to incur congestion charges and bilateral transactions that were accepted in the Day-ahead Energy Market shall continue to be implemented during periods of congestion, except as may be necessary to respond to Emergencies.

1.10.8 Office of the Interconnection Responsibilities.

(a) The Office of the Interconnection shall use its best efforts to determine (i) the least-cost means of satisfying the projected hourly requirements for energy, Operating Reserves, and other ancillary services of the Market Buyers, including the reliability requirements of the PJM Region, of the Day-ahead Energy Market, and (ii) the least-cost means of satisfying the Operating Reserve and other ancillary service requirements for any portion of the load forecast of the Office of the Interconnection for the Operating Day in excess of that scheduled in the Day-ahead Energy Market. In making these determinations, the Office of the Interconnection shall take into account: (i) the Office of the Interconnection's forecasts of PJM Interchange Energy Market and PJM Region energy requirements, giving due consideration to the energy requirement forecasts and purchase requests submitted by Market Buyers and PRD Curves

properly submitted by PRD Providers; (ii) the offers submitted by Market Sellers; (iii) the availability of limited energy resources; (iv) the capacity, location, and other relevant characteristics of self-scheduled resources; (v) the objectives of each Control Zone for Operating Reserves, as specified in the PJM Manuals; (vi) the requirements of each Regulation Zone for Regulation and other ancillary services, as specified in the PJM Manuals; (vii) the benefits of avoiding or minimizing transmission constraint control operations, as specified in the PJM Manuals; and (viii) such other factors as the Office of the Interconnection reasonably concludes are relevant to the foregoing determination, including, without limitation, transmission constraints on external coordinated flowgates to the extent provided by Tariff, Attachment K-Appendix, section 1.7.6. The Office of the Interconnection shall develop a Day-ahead Energy Market based on the foregoing determination, and shall determine the Day-ahead Prices resulting from such schedule. The Office of the Interconnection shall report the planned schedule for a hydropower resource to the operator of that resource as necessary for plant safety and security, and legal limitations on pond elevations.

(b) By 1:30 p.m., or as soon as practicable thereafter, of the day before each Operating Day, or such other deadline as may be specified by the Office of the Interconnection in the PJM Manuals, the Office of the Interconnection shall: (i) post the aggregate Day-ahead Energy Market results; (ii) post the Day-ahead Prices; and (iii) inform the Market Sellers, Market Buyers, and Economic Load Response Participants of their scheduled injections, withdrawals, and demand reductions respectively. The foregoing notwithstanding, the deadlines set forth in this subsection shall not apply if the Office of the Interconnection is unable to obtain Market Participant bid/offer data due to extraordinary circumstances. For purposes of this subsection, extraordinary circumstances shall mean a technical malfunction that limits, prohibits or otherwise interferes with the ability of the Office of the Interconnection to obtain Market Participant bid/offer data prior to 11:59 p.m. on the day before the affected Operating Day. Extraordinary circumstances do not include a Market Participant's inability to submit bid/offer data to the Office of the Interconnection. If the Office of the Interconnection is unable to clear the Day-ahead Energy Market prior to 11:59 p.m. on the day before the affected Operating Day as a result of such extraordinary circumstances, the Office of the Interconnection shall notify Members as soon as practicable.

(c) Following posting of the information specified in section 1.10.8(b), and absent extraordinary circumstances preventing the clearing of the Day-ahead Energy Market, the Office of the Interconnection shall revise its schedule of generation resources to reflect updated projections of load, conditions affecting electric system operations in the PJM Region, the availability of and constraints on limited energy and other resources, transmission constraints, and other relevant factors.

(d) Market Buyers shall pay PJMSettlement and Market Sellers shall be paid by PJMSettlement for the quantities of energy scheduled in the Day-ahead Energy Market at the Day-ahead Prices when the Day-ahead Price is positive. Market Buyers shall be paid by PJMSettlement and Market Sellers shall pay PJMSettlement for the quantities of energy scheduled in the Day-ahead Energy Market at the Day-ahead Prices when the Day-ahead Price is negative. Economic Load Response Participants shall be paid for scheduled demand reductions pursuant to Tariff, Attachment K-Appendix, section 3.3A. Notwithstanding the foregoing, if the

Office of the Interconnection is unable to clear the Day-ahead Energy Market prior to 11:59 p.m. on the day before the affected Operating Day due to extraordinary circumstances as described in subsection (b) above, it will be declared a Market Suspension, and Day-ahead Prices shall be determined pursuant to Operating Agreement, Schedule 1, section 2.6.1. If the Office of the Interconnection declares a Market Suspension, it shall notify Market Participants of the Market Suspension as soon as practicable.

(e) If the Office of the Interconnection discovers a *potential* error in prices and/or cleared quantities in the Day-ahead Energy Market or Day-ahead Ancillary Services Markets, or the Real-time Energy Market or Real-time Ancillary Services Markets after it has posted the results for these markets on its Web site, the Office of the Interconnection shall notify Market Participants as soon as possible after it is found, but in no event later than 12:00 p.m. of the second Business Day following the Operating Day for the Real-time Energy Market and Real-time Ancillary Services Markets, and no later than 5:00 p.m. of the second Business Day following the initial publication of the results for the Day-ahead Energy Market and Day-ahead Ancillary Services Markets. After this initial notification, if the Office of the Interconnection determines it is necessary to post modified results, it shall provide notification of its intent to do so, *along with a description detailing the cause and scope of the error*, by no later than 5:00 p.m. of the fifth Business Day following the Operating Day for the Real-time Energy Market and Real-time Ancillary Services Markets, and no later than 5:00 p.m. of the fifth Business Day following the initial publication of the results in the Day-ahead Energy Market and Day-ahead Ancillary Services Markets. *The provided description will not contain information that is market sensitive or confidential.* Thereafter, the Office of the Interconnection must post on its Web site the corrected results by no later than 5:00 p.m. of the tenth calendar day following the Operating Day for the Day-ahead Energy Market, Real-time Energy Market, and Day-ahead Ancillary Services Markets, and Real-time Ancillary Service Markets. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced market results are under publicly noticed review by the FERC.

(f) Consistent with Operating Agreement, section 18.17.1, and notwithstanding anything to the contrary in the Operating Agreement or in the PJM Tariff, to allow the tracking of Market Participants' non-aggregated bids and offers over time as required by FERC Order No. 719, the Office of the Interconnection shall post on its Web site the non-aggregated bid data and Offer Data submitted by Market Participants (for participation in the PJM Interchange Energy Market) approximately four months after the bid or offer was submitted to the Office of the Interconnection.

1.10.9 Hourly Scheduling.

(a) Following the initial posting by the Office of the Interconnection of the Locational Marginal Prices resulting from the Day-ahead Energy Market, and subject to the right of the Office of the Interconnection to schedule and dispatch pool-scheduled resources and to direct that schedules be changed in an Emergency, and absent extraordinary circumstances preventing the clearing of the Day-ahead Energy Market, a generation rebidding period shall

exist. Typically the rebidding period shall be from the time the Office of the Interconnection posts the results of the Day-ahead Energy Market until 2:15 p.m. on the day before each Operating Day. However, should the clearing of the Day-ahead Energy Market be significantly delayed, the Office of the Interconnection may establish a revised rebidding period. During the rebidding period, Market Participants may submit revisions to generation Offer Data for the next Operating Day. Adjustments to the Day-ahead Energy Market shall be settled at the applicable Real-time Prices, and shall not affect the obligation to pay or receive payment for the quantities of energy scheduled in the Day-ahead Energy Market at the applicable Day-ahead Prices.

(b) A Market Participant may adjust the schedule of a resource under its dispatch control on an hour-to-hour basis beginning at 6:30 p.m. of the day before each Operating Day, provided that the Office of the Interconnection is notified not later than 65 minutes prior to the hour in which the adjustment is to take effect, as follows and as specified in section 1.10.9A below:

i) A Generating Market Buyer may self-schedule any of its resource increments, including hydropower resources, not previously designated as self-scheduled and not selected as a pool-scheduled resource in the Day-ahead Energy Market;

ii) A Market Participant may request the scheduling of a non-firm bilateral transaction; or

iii) A Market Participant may request the scheduling of deliveries or receipts of Spot Market Energy; or

iv) A Generating Market Buyer may remove from service a resource increment, including a hydropower resource, that it had previously designated as self-scheduled, provided that the Office of the Interconnection shall have the option to schedule energy from any such resource increment that is a Capacity Resource at the price offered in the scheduling process, with no obligation to pay any Start-Up Costs.

(c) An External Market Buyer may refuse delivery of some or all of the energy it requested to purchase in the Day-ahead Energy Market by notifying the Office of the Interconnection of the adjustment in deliveries not later than 65 minutes prior to the hour in which the adjustment is to take effect, but any such adjustment shall not affect the obligation of the External Market Buyer to pay for energy scheduled on its behalf in the Day-ahead Energy Market at the applicable Day-ahead Prices.

(d) The Office of the Interconnection shall provide External Market Buyers and External Market Sellers and parties to bilateral transactions with any revisions to their schedules resulting from the rebidding period by 6:30 p.m. on the day before each Operating Day. The Office of the Interconnection may also commit additional resources after such time as system conditions require. For each hour in the Operating Day, as soon as practicable after the deadlines specified in the foregoing subsection of this section 1.10, the Office of the Interconnection shall provide External Market Buyers and External Market Sellers and parties to bilateral transactions with any revisions to their schedules for the hour.

1.10.9A Updating Offers in Real-time

(a) Each Market Seller may submit Real-time Offers for a resource up to 65 minutes before the applicable clock hour, and such Real-time Offers shall supersede any previous offer for that resource for the clock hour, as further described in the PJM Manuals and subject to the following conditions:

(i) A market-based Real-time Offer shall not exceed the applicable energy offer caps specified in this Schedule. Once a Market Seller's resource is committed for an applicable clock hour, the Market Seller may not increase its Incremental Energy Offer and may only submit a market-based Real-time Offer that is higher than its market-based offer that was in effect at the time of commitment to reflect increases in the resource's cost-based Start-up Costs and cost-based No-load Costs. The Market Seller may elect not to have its market-based offer considered for dispatch and to have only its lowest cost-based offer considered for the remainder of the Operating Day.

(ii) Cost-based Real-time Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection's Offer Data specification, Operating Agreement, Schedule 1, sections 1.10.1A(d) and 1.10.9B, Operating Agreement, Schedule 2 and the PJM Manuals, as applicable. If a Market Seller submits a market-based Real-time Offer for a particular clock hour in accordance with subsection (c) below, or if updates to a cost-based offer are required by the Market Seller's approved Fuel Cost Policy, the Market Seller shall update its previously submitted cost-based Real-time Offer.

(iii) If a Market Seller's available cost-based offer is not compliant with Operating Agreement, Schedule 2 and the PJM Manuals at the time a Market Seller submits a market-based Real-time Offer for an applicable clock hour during the Operating Day, the Market Seller must submit an updated cost-based Real-time Offer consisting of an Incremental Energy Offer, Start-up Cost and No-load Cost for that clock hour that is compliant with Operating Agreement, Schedule 2 and the PJM Manuals.

(b) Each Market Seller may submit Real-time Offers for a resource during and through the end of the applicable clock hour to update only the following offer parameters, as further described in the PJM Manuals: (1) Economic Minimum; (2) Economic Maximum; (3) emergency minimum MW; (4) emergency maximum MW; (5) unit availability status; (6) fixed output indicator; (7) Synchronized Reserve maximum MW; and (8) Secondary Reserve maximum MW. Such Real-time Offers shall supersede any previous offer for that resource for the clock hour.

1.10.9B Offer Parameter Flexibility

(a) Market Sellers may, in accordance with sections 1.10.1A and 1.10.9A above, this section 1.10.9B, and the PJM Manuals, update offer parameters at any time up to 65 minutes before the applicable clock hour, including prior to the close of the Day-ahead Energy Market and prior to the close of the rebidding period specified in section 1.10.9, except that Market

Sellers may not update their offers for the supply of energy, Secondary Reserve, Synchronized Reserve, Non-Synchronized Reserve, or demand reduction: (1) during the period after the close the Day-ahead Energy Market and prior to the posting of the Day-ahead Energy Market results pursuant to section 1.10.8(b); or (2) during the period after close of the rebidding period and prior to PJM announcing the results of the rebidding period pursuant to section 1.10.9(d).

(b) For generation resource offers, Market Sellers may vary for each clock hour during the entire Operating Day the following offer parameters: (1) cost-based Start-up Costs; (2) cost-based No-load Costs; (3) Incremental Energy Offer; (4) Economic Minimum and Economic Maximum; (5) emergency minimum MW and emergency maximum MW; (6) ramp rate; (7) Synchronized Reserve maximum MW; (8) Secondary Reserve maximum MW; and (9) for Real-time Offers only, (i) notification time and (ii) for uncommitted hours only, Minimum Run Time.

(c) For Economic Load Response Participant resource offers, Market Sellers may vary for each clock hour during the entire Operating Day the following offer parameters: (1) shutdown costs, (2) Incremental Energy Offer; (3) Economic Minimum; (4) Economic Maximum; and (5) for Real-time Offers only, (i) notification time and (ii) for uncommitted hours only, minimum down time.

(d) After the announcement of the results of the rebidding period pursuant to section 1.10.9(d), a Market Seller may submit a Real-time Offer where offer parameters may differ from the offer originally submitted in the Day-ahead Energy Market, except that a Market Seller may not submit a Real-time Offer that changes, of the offer parameters listed in section 1.10.1A(d), the MW amounts specified in the Incremental Energy Offer, MW amounts specified in the ramp rate, maximum run time, and availability; provided, however, Market Sellers of dual-fueled resources may submit Real-time Offers for such resources that change the availability of a submitted cost-based offer.

3.2 Market Settlements.

If a dollar-per-MW-hour value is applied in a calculation under this section 3.2 where the interval of the value produced in that calculation is less than an hour, then for purposes of that calculation the dollar-per-MW hour value is divided by the number of Real-time Settlement Intervals in the hour.

3.2.1 Spot Market Energy.

(a) The Office of the Interconnection shall calculate System Energy Prices in the form of Day-ahead System Energy Prices and Real-time System Energy Prices for the PJM Region, in accordance with Tariff, Attachment K-Appendix, section 2.

(b) Each Market Participant shall be charged for all of its Market Participant Energy Withdrawals scheduled in the Day-ahead Energy Market at the Day-ahead System Energy Price to be served in the PJM Interchange Energy Market.

(c) Each Market Participant shall be paid for all of its Market Participant Energy Injections scheduled in the Day-ahead Energy Market at the Day-ahead System Energy Price to be delivered to the PJM Interchange Energy Market.

(d) For each Day-ahead Settlement Interval during an Operating Day, the Office of the Interconnection shall calculate Spot Market Energy charges for each Market Participant as the difference between the sum of its Market Participant Energy Withdrawals scheduled times the Day-ahead System Energy Price and the sum of its Market Participant Energy Injections scheduled times the Day-ahead System Energy Price.

(e) For each Real-time Settlement Interval during an Operating Day, the Office of the Interconnection shall calculate Spot Market Energy charges for each Market Participant as the difference between the sum of its real-time Market Participant Energy Withdrawals less its scheduled Market Participant Energy Withdrawals times the Real-time System Energy Price and the sum of its real-time Market Participant Energy Injections less scheduled Market Participant Energy Injections times the Real-time System Energy Price. The Revenue Data for Settlements determined for each Real-time Settlement Interval in accordance with Tariff, Attachment K-Appendix, section 3.1A shall be used in determining the real-time Market Participant Energy Withdrawals and Market Participant Energy Injections used to calculate Spot Market Energy charges under this subsection (e).

(f) For pool External Resources, the Office of the Interconnection shall model, based on an appropriate flow analysis, the megawatts of real-time energy injections to be delivered from each such resource to the corresponding Interface Pricing Point between adjacent Control Areas and the PJM Region.

3.2.2 Regulation.

(a) Each Market Participant that is a Load Serving Entity in a Regulation Zone shall have an hourly Regulation objective equal to its pro rata share of the Regulation requirements of such Regulation Zone for the hour, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Regulation Zone for the hour ("Regulation Obligation"). A Market Participant with an hourly Regulation Obligation shall be charged the pro rata share of the sum of the Regulation market performance clearing price credits and Regulation market capability clearing price credits for the Real-time Settlement Intervals in an hour.

$\text{Regulation Charge} = \text{Hourly Regulation Obligation Share} * (\text{sum of the Real-time Settlement Interval Regulation credits in an hour})$

(b) Each Market Participant supplying Regulation in a Regulation Zone at the direction of the Office of the Interconnection shall be credited for each of its resources such that the calculated credit for each increment of Regulation provided by each resource shall be the higher of: (i) the Regulation market-clearing price; or (ii) the sum of the applicable Regulation offers for a resource determined pursuant to section 3.2.2A.1 below, the unit-specific shoulder hour opportunity costs described in subsection (e) of this section, the unit-specific inter-temporal opportunity costs, and the unit-specific opportunity costs discussed in subsection (d) of this section.

(c) The total Regulation market-clearing price in each Regulation Zone shall be determined in the Real-time Price software program, which is known as the pricing run, for each Real-time Settlement Interval. The total Regulation market-clearing price shall include: (i) the performance Regulation market-clearing price in a Regulation Zone that shall be calculated in accordance with subsection (g) of this section; (ii) the capability Regulation market-clearing price that shall be calculated in accordance with subsection (h) of this section; and (iii) a Regulation resource's unit-specific opportunity costs during the 5-minute period, determined as described in subsection (d) below, divided by the unit-specific benefits factor described in subsection (j) of this section and divided by the historic accuracy score of the resource from among the resources selected to provide Regulation. A resource's Regulation offer by any Market Seller that fails the three-pivotal supplier test set forth in section 3.2.2A.1 below shall not exceed the cost of providing Regulation from such resource, plus twelve dollars, as determined pursuant to the formula in Tariff, Attachment K-Appendix, section 1.10.1A(e).

(d) In determining the Regulation 5-minute clearing price for each Regulation Zone, the estimated unit-specific opportunity costs of a generation resource offering to sell Regulation in each regulating hour, except for hydroelectric resources, shall be equal to the product of (i) the deviation of the set point of the generation resource that is expected to be required in order to provide Regulation from the generation resource's expected output level if it had been dispatched in economic merit order times, (ii) the absolute value of the difference between the expected Locational Marginal Price at the generation bus for the generation resource and the lesser of the available market-based or highest available cost-based energy offer from the

generation resource (at the megawatt level of the Regulation set point for the resource) in the PJM Interchange Energy Market.

For hydroelectric resources offering to sell Regulation in a regulating hour, the estimated unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the full value of the Locational Marginal Price at that generation bus for each megawatt of Regulation capability.

The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead megawatt commitment greater than zero shall be equal to the product of (i) the deviation of the set point of the hydroelectric resource that is expected to be required in order to provide Regulation from the hydroelectric resource's expected output level if it had been dispatched in economic merit order times (ii) the difference between the expected Locational Marginal Price at the generation bus for the hydroelectric resource and the average of the Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating. Estimated opportunity costs shall be zero for hydroelectric resources for which the average Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period, excluding those Real-time Settlement Intervals during which all available units at the hydroelectric resource were operating is higher than the actual Locational Marginal Price at the generator bus for the Real-time Settlement Interval.

The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead megawatt commitment greater than zero shall be equal to the product of (i) the deviation of the set point of the hydroelectric resource that is expected to be required in order to provide Regulation from the hydroelectric resource's expected output level if it had been dispatched in economic merit order times (ii) the difference between the average of the Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating and the expected Locational Marginal Price at the generation bus for the hydroelectric resource. Estimated opportunity costs shall be zero for hydroelectric resources for which the actual Locational Marginal Price at the generator bus for the Real-time Settlement Interval is higher than the average Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period, excluding those Real-time Settlement Intervals during which all available units at the hydroelectric resource were operating.

For the purpose of committing resources and setting Regulation market clearing prices, the Office of the Interconnection shall utilize day-ahead Locational Marginal Prices to calculate opportunity costs for hydroelectric resources. For the purposes of settlements, the Office of the Interconnection shall utilize the real-time Locational Marginal Prices to calculate opportunity costs for hydroelectric resources.

Estimated opportunity costs for Economic Load Response Participant resources to provide Regulation are zero.

(e) In determining the credit under subsection (b) to a Market Participant selected to provide Regulation in a Regulation Zone and that actively follows the Office of the Interconnection's Regulation signals and instructions, the unit-specific opportunity cost of a generation resource shall be determined for (1) each Real-time Settlement Interval that the Office of the Interconnection requires a generation resource to provide Regulation, and (2) the last three Real-time Settlement Intervals of the preceding shoulder hour and the first three Real-time Settlement Intervals of the following shoulder hour in accordance with the PJM Manuals and below.

The unit-specific opportunity cost incurred during the Real-time Settlement Interval in which the Regulation obligation is fulfilled shall be equal to the product of (i) the deviation of the generation resource's output necessary to follow the Office of the Interconnection's Regulation signals from the generation resource's expected output level if it had been dispatched in economic merit order times (ii) the absolute value of the difference between the Locational Marginal Price at the generation bus for the generation resource and the lesser of the available market-based or highest available cost-based energy offer from the generation resource (at the actual megawatt level of the resource when the actual megawatt level is within the tolerance defined in the PJM Manuals for the Regulation set point, or at the Regulation set point for the resource when it is not within the corresponding tolerance) in the PJM Interchange Energy Market. Opportunity costs for Economic Load Response Participant resources to provide Regulation are zero.

The unit-specific opportunity costs associated with uneconomic operation during each of the preceding three Real-time Settlement Intervals of the shoulder hour shall be equal to the product of (i) the deviation between the set point of the generation resource that is expected to be required in the initial regulating Real-time Settlement Interval in order to provide Regulation and the resource's expected output in each of the preceding three Real-time Settlement Intervals of the shoulder hour times (ii) the absolute value of the difference between the Locational Marginal Price at the generation bus for the generation resource in each of the preceding three Real-time Settlement Intervals of the shoulder hour and the lesser of the available market-based or highest available cost-based energy offer from the generation resource (at the megawatt level of the Regulation set point for the resource in the initial regulating Real-time Settlement Interval) in the PJM Interchange Energy Market, all as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals.

The unit-specific opportunity costs associated with uneconomic operation during each of the following three Real-time Settlement Intervals of the shoulder hour shall be equal to the product of (i) the deviation between the set point of the generation resource that is expected to be required in the final regulating Real-time Settlement Interval in order to provide Regulation and the resource's expected output in each of the following three Real-time Settlement Intervals of the shoulder hour times (ii) the absolute value of the difference between the Locational Marginal Price at the generation bus for the generation resource in each of the following three Real-time Settlement Intervals of the shoulder hour and the lesser of the available market-based or highest available cost-based energy offer from the generation resource (at the megawatt level of the Regulation set point for the resource in final regulating hour) in the PJM Interchange Energy

Market all as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals.

(f) Any amounts credited for Regulation in an hour in excess of the Regulation market-clearing price in that hour shall be allocated and charged to each Market Participant in a Regulation Zone that does not meet its hourly Regulation obligation in proportion to its purchases of Regulation in such Regulation Zone in megawatt-hours during that hour.

(g) To determine the Regulation market performance-clearing price for each Regulation Zone, the Office of the Interconnection shall adjust the submitted performance offer for each resource in accordance with the historical performance of that resource, the amount of Regulation that resource will be dispatched based on the ratio of control signals calculated by the Office of the Interconnection, and the unit-specific benefits factor described in subsection (j) of this section for which that resource is qualified. The maximum adjusted performance offer of all cleared resources will set the Regulation market performance-clearing price.

The owner of each Regulation resource that actively follows the Office of the Interconnection's Regulation signals and instructions, will be credited for Regulation performance by multiplying the assigned MW(s) by the Regulation market performance-clearing price, by the ratio between the requested mileage for the Regulation dispatch signal assigned to the Regulation resource and the Regulation dispatch signal assigned to traditional resources, and by the Regulation resource's accuracy score calculated in accordance with subsection (k) of this section.

(h) The Office of the Interconnection shall divide each Regulation resource's capability offer by the unit-specific benefits factor described in subsection (j) of this section and divided by the historic accuracy score for the resource for the purposes of committing resources and setting the market clearing prices.

The Office of the Interconnection shall calculate the Regulation market capability-clearing price for each Regulation Zone by subtracting the Regulation market performance-clearing price described in subsection (g) from the total Regulation market clearing price described in subsection (c). This residual sets the Regulation market capability-clearing price for that market Real-time Settlement Interval.

The owner of each Regulation resource that actively follows the Office of the Interconnection's Regulation signals and instructions will be credited for Regulation capability based on the assigned MW and the capability Regulation market-clearing price multiplied by the Regulation resource's accuracy score calculated in accordance with subsection (k) of this section.

(i) In accordance with the processes described in the PJM Manuals, the Office of the Interconnection shall: (i) calculate inter-temporal opportunity costs for each applicable resource; (ii) include such inter-temporal opportunity costs in each applicable resource's offer to sell frequency Regulation service; and (iii) account for such inter-temporal opportunity costs in the Regulation market-clearing price.

(j) The Office of the Interconnection shall calculate a unit-specific benefits factor for each of the dynamic Regulation signal and traditional Regulation signal in accordance with the PJM Manuals. Each resource shall be assigned a unit-specific benefits factor based on their order in the merit order stack for the applicable Regulation signal. The unit-specific benefits factor is the point on the benefits factor curve that aligns with the last megawatt, adjusted by historical performance, that resource will add to the dynamic resource stack. Resources following the dynamic Regulation signal which have a unit-specific benefits factor less than 0.1 will not be considered for the purposes of committing resources. The unit-specific benefits factor for the traditional Regulation signal shall be equal to one.

(k) The Office of the Interconnection shall calculate each Regulation resource's accuracy score. The accuracy score shall be the average of a delay score, correlation score, and energy score for each ten second interval. For purposes of setting the interval to be used for the correlation score and delay scores, PJM will use the maximum of the correlation score plus the delay score for each interval.

The Office of the Interconnection shall calculate the correlation score using the following statistical correlation function (r) that measures the delay in response between the Regulation signal and the resource change in output:

$$\text{Correlation Score} = r_{\text{Signal,Response}(\delta, \delta+5 \text{ Min})};$$

$\delta=0 \text{ to } 5 \text{ Min}$

where δ is delay.

The Office of the Interconnection shall calculate the delay score using the following equation:

$$\text{Delay Score} = \text{Abs} ((\delta - 5 \text{ Minutes}) / (5 \text{ Minutes})).$$

The Office of the Interconnection shall calculate an energy score as a function of the difference in the energy provided versus the energy requested by the Regulation signal while scaling for the number of samples. The energy score is the absolute error (ϵ) as a function of the resource's Regulation capacity using the following equations:

$$\text{Energy Score} = 1 - 1/n \sum \text{Abs} (\text{Error});$$

$$\text{Error} = \text{Average of Abs} ((\text{Response} - \text{Regulation Signal}) / (\text{Hourly Average Regulation Signal})); \text{ and}$$

n = the number of samples in the hour and the energy.

The Office of the Interconnection shall calculate an accuracy score for each Regulation resource that is the average of the delay score, correlation score, and energy score for a five-minute period using the following equation where the energy score, the delay score, and the correlation score are each weighted equally:

$$\text{Accuracy Score} = \max ((\text{Delay Score}) + (\text{Correlation Score})) + (\text{Energy Score}).$$

The historic accuracy score will be based on a rolling average of the Real-time Settlement Interval accuracy scores, with consideration of the qualification score, as defined in the PJM Manuals.

(1) During a Market Suspension where the suspension is less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Regulation, the resources providing Regulation at the direction of the Office of the Interconnection will be compensated based on a calculated Regulation market-clearing price. Regulation market-clearing prices for each Real-time Settlement Interval associated with such Market Suspension shall be the average of the Regulation market-clearing prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

During a Market Suspension where the suspension is greater than twenty-four (24) consecutive hours, if the Office of the Interconnection is assigning Regulation, resources providing Regulation at the direction of the Office of the Interconnection will be compensated based on a calculated Regulation clearing price. The Regulation clearing price for each Real-time Settlement Interval will be determined by calculating a Regulation clearing cost for the online resources providing Regulation during the Market Suspension. The resource's Regulation clearing cost is determined by the summation of their Regulation offer and opportunity cost. The opportunity cost will be based on the resource's cost-based offer and will be determined as follows:

For online resources providing Regulation on a cost-based offer at the time of the Market Suspension, that cost-based offer will be used.

For online resources providing Regulation on a price-based offer at the time of the Market Suspension, the Office of the Interconnection shall use the cheapest available cost-based offer based on the dispatch cost formula as defined in Operating Agreement, Schedule 1, section 6.4.1(g) using the available cost-based offers in the Office of the Interconnection system at the time of the Market Suspension.

The highest cost resource, based on this Regulation clearing cost, will set the Regulation market-clearing price for each hour of the Market Suspension.

During a Market Suspension, if the Office of the Interconnection is not assigning Regulation resources, then the Regulation market-clearing price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period and no resource-specific opportunity cost will be calculated.

During a Market Suspension, the following Regulation components for all Real-time Settlement Intervals in the Market Suspension period will be determined as follows:

- (i) If the regulation accuracy score cannot be calculated during a Market Suspension, the 100-hour rolling average accuracy score will be used for the Market Suspension period.
- (ii) If the regulation mileage ratio cannot be calculated during a Market Suspension, the mileage ratio will be set to one (1) for the Market Suspension period.
- (iii) If the unit-specific benefits factor cannot be calculated during a Market Suspension, the unit-specific benefits factor would be based on the historical average unit-specific benefits factor over past hours that shared the same penetration of Regulation D resources that exist for the given Market Suspension hour.

3.2.2A Offer Price Caps.

3.2.2A.1 Applicability.

(a) Each hour, the Office of the Interconnection shall conduct a three-pivotal supplier test as described in this section. Regulation offers from Market Sellers that fail the three-pivotal supplier test shall be capped in the hour in which they failed the test at their cost based offers as determined pursuant to Tariff, Attachment K-Appendix, section 1.10.1A(e). A Regulation supplier fails the three-pivotal supplier test in any hour in which such Regulation supplier and the two largest other Regulation suppliers are jointly pivotal.

(b) For the purposes of conducting the three-pivotal supplier test pursuant to this section, the following applies:

(i) The three-pivotal supplier test will include in the definition of available supply all offers from resources capable of satisfying the Regulation requirement of the PJM Region multiplied by the historic accuracy score of the resource and multiplied by the unit-specific benefits factor for which the capability cost-based offer plus the performance cost-based offer plus any eligible opportunity costs is no greater than 150 percent of the clearing price that would be calculated if all offers were limited to cost (plus eligible opportunity costs).

(ii) The three-pivotal supplier test will apply on a Regulation supplier basis (i.e. not a resource by resource basis) and only the Regulation suppliers that fail the three-pivotal supplier test will have their Regulation offers capped. A Regulation supplier for the purposes of this section includes corporate affiliates. Regulation from resources controlled by a Regulation supplier or its affiliates, whether by contract with unaffiliated third parties or otherwise, will be included as Regulation of that Regulation supplier. Regulation provided by resources owned by a Regulation supplier but controlled by an

unaffiliated third party, whether by contract or otherwise, will be included as Regulation of that third party.

(iii) Each supplier shall be ranked from the largest to the smallest offered megawatt of eligible Regulation supply adjusted by the historic performance of each resource and the unit-specific benefits factor. Suppliers are then tested in order, starting with the three largest suppliers. For each iteration of the test, the two largest suppliers are combined with a third supplier, and the combined supply is subtracted from total effective supply. The resulting net amount of eligible supply is divided by the Regulation requirement for the hour to determine the residual supply index. Where the residual supply index for three pivotal suppliers is less than or equal to 1.0, then the three suppliers are jointly pivotal and the suppliers being tested fail the three pivotal supplier test. Iterations of the test continue until the combination of the two largest suppliers and a third supplier result in a residual supply index greater than 1.0, at which point the remaining suppliers pass the test. Any resource owner that fails the three-pivotal supplier test will be offer-capped.

3.2.3 Operating Reserves.

(a) A Market Seller's pool-scheduled resources capable of providing Operating Reserves shall be credited as specified below based on the applicable offer for the operation of such resource, provided that the resource was available for the entire time specified in the Offer Data for such resource. To the extent that sections 3.2.3A, 3.2.3A.001, and 3.2.3A.01 below do not meet the Synchronized Reserve Requirements, the Primary Reserve Requirements, and the 30-minute Reserve Requirements, the Office of the Interconnection shall schedule additional Operating Reserves pursuant to Section 1.7.17 and 1.10 of Schedule 1 of this Agreement. In addition the Office of the Interconnection shall schedule Operating Reserves pursuant to those sections to satisfy any unforeseen Operating Reserve requirements that are not reflected in the day-ahead market. PJMSettlement shall be the Counterparty to the purchases and sales of Operating Reserve in the PJM Interchange Energy Market.

(b) The following determination shall be made for each pool-scheduled resource that is scheduled in the Day-ahead Energy Market: the total offered price for Start-up Costs and No-load Costs and energy, determined on the basis of the resource's scheduled output, shall be compared to the total value of that resource's energy – as determined by the Day-ahead Energy Market and the Day-ahead Prices applicable to the relevant generation bus in the Day-ahead Energy Market. PJM shall also (i) determine whether any resources were scheduled in the Day-ahead Energy Market to provide Black Start service, Reactive Services or transfer interface control during the Operating Day because they are known or expected to be needed to maintain system reliability in a Zone during the Operating Day in order to minimize the total cost of Operating Reserves associated with the provision of such services and reflect the most accurate possible expectation of real-time operating conditions in the day-ahead model, which resources would not have otherwise been committed in the day-ahead security-constrained dispatch and (ii) report on the day following the Operating Day the megawatt quantities scheduled in the Day-ahead Energy Market for the above-enumerated purposes for the entire RTO.

Except as provided in section 3.2.3(n) below, if the total offered price for Start-up Costs (shutdown costs for Economic Load Response Participant resources) and No-load Costs and energy summed over all Day-ahead Settlement Intervals exceeds the total value summed over all Day-ahead Settlement Intervals, the difference shall be credited to the Market Seller as a day-ahead Operating Reserve credit.

However, for the Day-ahead Settlement Intervals in which the resource is scheduled to provide energy in the Operating Day and the resource actually provides energy in at least one Real-time Settlement Interval in an hour that corresponds to such scheduled Day-ahead Settlement Intervals, a resource's day-ahead Operating Reserve credit shall be reduced by the greater of zero or the difference of the resource's Day-ahead Operating Reserve Target and the Balancing Operating Reserve Target, as determined below.

A resource's Day-ahead Operating Reserve Target shall be determined in accordance with the following equation:

$$(A + B) - C$$

Where:

A = Start-up Costs

B = the sum of day-ahead No-load Costs and energy over the applicable Real-time Settlement Intervals that correspond with Day-ahead Settlement Intervals in which the resource is scheduled. The day-ahead No-load Costs and energy are divided by twelve to determine the cost for each Real-time Settlement Interval.

C = the sum of the day-ahead revenues calculated for each Real-time Settlement Interval that corresponds with a Day-ahead Settlement Interval in which the resource is scheduled, where the day-ahead revenue for each such Real-time Settlement Interval equals the product of the megawatt amount of energy scheduled in the Day-ahead Energy Market and the Day-ahead Price at the applicable pricing point for the resource divided by twelve.

A resource's Balancing Operating Reserve Target shall be determined in accordance with the following equation:

$$D - (E + F)$$

Where:

D = the sum of Start-up Costs and No-load Costs and the incremental cost of energy summed over all Real-time Settlement Intervals that correspond to the Day-ahead Settlement Intervals in which the resource was scheduled;

E = [(the megawatt amount of energy provided in the Real-time Energy Market minus the megawatt amount of energy scheduled in the Day-ahead Energy Market) multiplied by the Real-time Price at the applicable pricing point for the resource] plus the sum of the day-ahead revenues as determined in part C of the above formula for determining the Day-ahead Operating Reserve Target, summed over the applicable Real-time Settlement Intervals; and

F = the sum of all revenues earned for providing Secondary Reserves, Synchronized Reserves, Non-Synchronized Reserves, and Reactive Services over the applicable Real-time Settlement Intervals.

The Office of the Interconnection shall apply any balancing Operating Reserve credits allocated pursuant to this section 3.2.3(b) to real-time deviations or real-time load share plus exports, pursuant to Tariff, Attachment K-Appendix, section 3.2.3(p), depending on whether the balancing Operating Reserve credits are related to resources scheduled during the reliability analysis for an Operating Day, or during the actual Operating Day.

(i) For resources scheduled by the Office of the Interconnection during the reliability analysis for an Operating Day, the associated balancing Operating Reserve credits shall be allocated based on the reason the resource was scheduled according to the following provisions:

(A) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to operate in real-time to augment the physical resources committed in the Day-ahead Energy Market to meet the forecasted real-time load plus the Operating Reserve requirement, the associated balancing Operating Reserve credits, identified as RA Credits for Deviations, shall be allocated to real-time deviations.

(B) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to maintain system reliability, the associated balancing Operating Reserve credits, identified as RA Credits for Reliability, shall be allocated according to ratio share of real time load plus export transactions.

(C) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource with a day-ahead schedule is required to deviate from that schedule to provide balancing Operating Reserves, the associated balancing Operating Reserve credits shall be segmented and separately allocated pursuant to subsections 3.2.3(b)(i)(A) or 3.2.3(b)(i)(B) hereof. Balancing Operating Reserve credits for such resources will be identified in the same manner as units committed during the reliability analysis pursuant to subsections 3.2.3(b)(i)(A) and 3.2.3(b)(i)(B) hereof.

(ii) For resources scheduled during an Operating Day, the associated balancing Operating Reserve credits shall be allocated according to the following provisions:

(A) If the Office of the Interconnection directs a resource to operate during an Operating Day to provide balancing Operating Reserves, the associated balancing Operating Reserve credits, identified as RT Credits for Reliability, shall be allocated according to ratio share of load plus exports. The foregoing notwithstanding, credits will be applied pursuant to this section only if the LMP at the resource's bus does not meet or exceed the applicable offer of the resource for at least four 5-minute intervals during one or more discrete clock hours during each period the resource operated and produced MWs during the relevant Operating Day. If a resource operated and produced MWs for less than four 5-minute intervals during one or more discrete clock hours during the relevant Operating Day, the credits for that resource during the hour it was operated less than four 5-minute intervals will be identified as being in the same category (RT Credits for Reliability or RT Credits for Deviations) as identified for the Operating Reserves for the other discrete clock hours.

(B) If the Office of the Interconnection directs a resource not covered by section 3.2.3(b)(ii)(A) hereof to operate in real-time during an Operating Day, the associated balancing Operating Reserve credits, identified as RT Credits for Deviations, shall be allocated according to real-time deviations from day-ahead schedules.

(iii) PJM shall post on its Web site the aggregate amount of MWs committed that meet the criteria referenced in subsections (b)(i) and (b)(ii) hereof.

(c) The sum of the foregoing credits calculated in accordance with section 3.2.3(b) plus any unallocated charges from section 3.2.3(h) and Tariff, Attachment K-Appendix, section 5.1.7, and any shortfalls paid pursuant to the Market Settlement provision of the Day-ahead Economic Load Response Program, shall be the cost of Operating Reserves in the Day-ahead Energy Market.

(d) The cost of Operating Reserves in the Day-ahead Energy Market shall be allocated and charged to each Market Participant in proportion to the sum of its (i) scheduled load (net of Behind The Meter Generation expected to be operating, but not to be less than zero), accepted Decrement Bids in the Day-ahead Energy Market in megawatt-hours for that Operating Day and accepted Up-to Congestion Transactions in the Day-ahead Energy Market in megawatt-hours for the Operating Day at the sink of the transaction; and (ii) scheduled energy sales in the Day-ahead Energy Market from within the PJM Region to load outside such region in megawatt-hours for that Operating Day, but not including its bilateral transactions that are Dynamic Transfers to load outside such area pursuant to Tariff, Attachment K-Appendix, section 1.12, except to the extent PJM scheduled resources to provide Black Start service, Reactive Services or transfer interface control. The cost of Operating Reserves in the Day-ahead Energy Market for resources scheduled to provide Black Start service for the Operating Day which resources would

not have otherwise been committed in the day-ahead security constrained dispatch shall be allocated by ratio share of the monthly transmission use of each Network Customer or Transmission Customer serving Zone Load or Non-Zone Load, as determined in accordance with the formulas contained in Tariff, Schedule 6A. The cost of Operating Reserves in the Day-ahead Energy Market for resources scheduled to provide Reactive Services or transfer interface control because they are known or expected to be needed to maintain system reliability in a Zone during the Operating Day and would not have otherwise been committed in the day-ahead security constrained dispatch shall be allocated and charged to each Market Participant in proportion to the sum of its real-time deliveries of energy to load (net of operating Behind The Meter Generation) in such Zone, served under Network Transmission Service, in megawatt-hours during that Operating Day, as compared to all such deliveries for all Market Participants in such Zone.

(e) At the end of each Operating Day, the following determination shall be made for each synchronized pool-scheduled resource of each Market Seller that operates as requested by the Office of the Interconnection. For each calendar day, pool-scheduled resources in the Real-time Energy Market shall be made whole for each of the following Segments: 1) the greater of their day-ahead schedules and minimum run time specified at the time of commitment (minimum down time specified at the time of commitment for Economic Load Response Participant resources); and 2) any block of Real-time Settlement Intervals the resource operates at PJM's direction in excess of the greater of its day-ahead schedule and minimum run time specified at the time of commitment (minimum down time specified at the time of commitment for Economic Load Response Participant resources). For each calendar day, and for each synchronized start of a generation resource or PJM-dispatched economic load reduction, there will be a maximum of two Segments for each resource. Segment 1 will be the greater of the day-ahead schedule and minimum run time specified at the time of commitment (minimum down time specified at the time of commitment for Demand Resources) and Segment 2 will include the remainder of the contiguous Real-time Settlement Intervals when the resource is operating at the direction of the Office of the Interconnection, provided that a segment is limited to the Operating Day in which it commenced and cannot include any part of the following Operating Day.

A Generation Capacity Resource that operates outside of its unit-specific parameters will not receive Operating Reserve Credits nor be made whole for such operation when not dispatched by the Office of the Interconnection, unless the Market Seller of the Generation Capacity Resource can justify to the Office of the Interconnection that operation outside of such unit-specific parameters was the result of an actual constraint. Such Market Seller shall provide to the Market Monitoring Unit and the Office of the Interconnection its request to receive Operating Reserve Credits and/or to be made whole for such operation, along with documentation explaining in detail the reasons for operating its resource outside of its unit-specific parameters, within thirty calendar days following the issuance of billing statement for the Operating Day. The Market Seller shall also respond to additional requests for information from the Market Monitoring Unit and the Office of the Interconnection. The Market Monitoring Unit shall evaluate such request for compensation and provide its determination of whether there was an exercise of market power to the Office of the Interconnection by no later than twenty-five calendar days after receiving the Market Seller's request for compensation. The Office of the Interconnection shall make its determination whether the Market Seller justified that it is entitled to receive Operating

Reserve Credits and/or be made whole for such operation of its resource for the day(s) in question, by no later than thirty calendar days after receiving the Market Seller's request for compensation.

Nuclear generation resources shall not be eligible for Operating Reserve payments unless: 1) the Office of the Interconnection directs such resources to reduce output, in which case, such units shall be compensated in accordance with Tariff, Attachment K-Appendix, section 3.2.3(f) and the parallel provision of Operating Agreement, Schedule 1, section 3.2.3(f); or 2) the resource submits a request for a risk premium to the Market Monitoring Unit under the procedures specified in Tariff, Attachment M – Appendix, section II.B. A nuclear generation resource (i) must submit a risk premium consistent with its agreement under such process, or, (ii) if it has not agreed with the Market Monitoring Unit on an appropriate risk premium, may submit its own determination of an appropriate risk premium to the Office of the Interconnection, subject to acceptance by the Office of the Interconnection, with or without prior approval from the Commission.

Credits received pursuant to this section shall be equal to the positive difference between a resource's Total Operating Reserve Offer, and the total value of the resource's energy in the Day-ahead Energy Market plus any credit or change for quantity deviations, at PJM dispatch direction (excluding quantity deviations caused by an increase in the Market Seller's Real-time Offer), from the Day-ahead Energy Market during the Operating Day at the real-time LMP(s) applicable to the relevant generation bus in the Real-time Energy Market. The foregoing notwithstanding, credits for Segment 2 shall exclude start up (shutdown costs for Economic Load Response Participant resources) costs for generation resources.

Except as provided in section 3.2.3(m), if the total offered price exceeds the total value, the difference less any credit as determined pursuant to section 3.2.3(b), and less the absolute value of any negative Synchronized Reserve lost opportunity cost credit, as determined in section 3.2.3A(f)(iv) below, and less the absolute value of any negative Non-Synchronized Reserve lost opportunity cost credit determined in section 3.2.3.A.001(d)(iii) below, and less any amounts credited for providing Reactive Services as specified in section 3.2.3B, and the absolute value of any negative Secondary Reserve lost opportunity cost credit, as determined in section 3.2.3A.01(f)(iv) below, and plus the sum of the Market Revenue Neutrality Offsets for Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve, shall be credited to the Market Seller.

Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve credits applied against Operating Reserve credits pursuant to this section shall be netted against the Operating Reserve credits earned in the corresponding Real-time Settlement Interval(s) in which the Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve credits accrued, provided that for condensing combustion turbines, Synchronized Reserve credits will be netted against the total Operating Reserve credits accrued during each Real-time Settlement Interval the unit operates in condensing and generation mode.

(f) A Market Seller of a unit not defined in subsection (f-1), (f-2), or (f-4) hereof (or self-scheduled, if operating according to Tariff, Attachment K-Appendix, section 1.10.3(c)

hereof), the output of which is reduced or suspended at the request of the Office of the Interconnection due to a transmission constraint or other reliability issue, and for which the real-time LMP at the unit's bus is higher than the unit's offer corresponding to the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override), shall be credited for each Real-time Settlement Interval in an amount equal to the product of (A) the LOC Deviation times (B) the Locational Marginal Price at the generation bus for the generating unit, minus (C) the Total Lost Opportunity Cost Offer, provided that the resulting outcome is greater than \$0.00. This equation is represented as $(A * B) - C$. If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.11.6, where the suspension is greater than twenty-four (24) consecutive hours, resources will not be compensated for lost opportunity costs.

(f-1) With the exception of Market Sellers of Flexible Resources that submit a Real-time Offer greater than their resource's Committed Offer in the Day-ahead Energy Market, a Market Seller of a Flexible Resource shall be compensated for lost opportunity cost, and shall be limited to the lesser of the unit's Economic Maximum or the unit's Generation Resource Maximum Output, if either of the following conditions occur:

- (i) if the unit output is reduced at the direction of the Office of the Interconnection and the real time LMP at the unit's bus is higher than the unit's offer corresponding to the level of output requested by the Office of the Interconnection (as directed by the PJM dispatcher), then the Market Seller shall be credited in a manner consistent with that described in section 3.2.3(f).
- (ii) If the unit is scheduled to produce energy in the Day-ahead Energy Market for a Day-ahead Settlement Interval, but the unit is not called on by the Office of the Interconnection and does not operate in the corresponding Real-time Settlement Interval(s), then the Market Seller shall be credited in an amount equal to the higher of:
 - 1) the product of (A) the amount of megawatts committed in the Day-ahead Energy Market for the generating unit, and (B) the Real-time Price at the generation bus for the generating unit, minus the sum of (C) the Total Lost Opportunity Cost Offer plus No-load Costs, plus (D) the Start-up Cost, divided by the Real-time Settlement Intervals committed for each set of contiguous hours for which the unit was scheduled in Day-ahead Energy Market. This equation is represented as $(A * B) - (C + D)$. The startup cost, (D), shall be excluded from this calculation if the unit operates in real time following the Office of the Interconnection's direction during any portion of the set of contiguous hours for which the unit was scheduled in Day-ahead Energy Market, or

- 2) the Real-time Price at the unit's bus minus the Day-ahead Price at the unit's bus, multiplied by the number of megawatts committed in the Day-ahead Energy Market for the generating unit.

(f-2) A Market Seller of a hydroelectric resource that is pool-scheduled (or self-scheduled, if operating according to Tariff, Attachment K-Appendix, section 1.10.3(c) hereof), the output of which is altered at the request of the Office of the Interconnection from the schedule submitted by the owner, due to a transmission constraint or other reliability issue, shall be compensated for lost opportunity cost in the same manner as provided in sections 3.2.2(d) and 3.2.3A(f) and further detailed in the PJM Manuals.

(f-3) If a Market Seller believes that, due to specific pre-existing binding commitments to which it is a party, and that properly should be recognized for purposes of this section, the above calculations do not accurately compensate the Market Seller for opportunity cost associated with following PJM dispatch instructions and reducing or suspending a unit's output due to a transmission constraint or other reliability issue, then the Office of the Interconnection, the Market Monitoring Unit and the individual Market Seller will discuss a mutually acceptable, modified amount of opportunity cost compensation, taking into account the specific circumstances binding on the Market Seller. Following such discussion, if the Office of the Interconnection accepts a modified amount of opportunity cost compensation, the Office of the Interconnection shall invoice the Market Seller accordingly. If the Market Monitoring Unit disagrees with the modified amount of opportunity cost compensation, as accepted by the Office of the Interconnection, it will exercise its powers to inform the Commission staff of its concerns.

(f-4) A Market Seller of a wind generating unit that is pool-scheduled or self-scheduled, has SCADA capability to transmit and receive instructions from the Office of the Interconnection, has provided data and established processes to follow PJM basepoints pursuant to the requirements for wind generating units as further detailed in this Agreement, the Tariff and the PJM Manuals, and which is operating as requested by the Office of the Interconnection, the output of which is reduced or suspended at the request of the Office of the Interconnection due to a transmission constraint or other reliability issue, and for which the , real-time LMP at the unit's bus is higher than the unit's offer corresponding to the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override), shall be credited for each Real-time Settlement Interval in an amount equal to the product of (A) the LOC Deviation times (B) the Real-time Price at the generation bus for the generating unit, minus (C) the Total Lost Opportunity Cost Offer, provided that the resulting outcome is greater than \$0.00. This equation is represented as $(A*B) - C$.

(f-5) (i) A Market Seller of a pool-scheduled resource or a dispatchable self-scheduled resource shall receive Dispatch Differential Lost Opportunity Cost credits as calculated under subsection (iv) below if the resource is dispatched to provide energy in the Real-time Energy Market, provided such resource is not committed to provide real-time ancillary services (Regulation, reserves, reactive service) or instructed to reduce or suspend output due to

a transmission constraint or other reliability issue pursuant to Tariff, Attachment K-Appendix, section 3.2.3(f-1) through Tariff, Attachment K-Appendix, section (f-4).

(ii) PJM will calculate the revenue above cost for the pricing run for each Real-time Settlement Interval in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = the resource's expected output level based on its resource parameters at the Real-time Price at the applicable pricing point;

B = the Real-time Price at the applicable pricing point; and

C = the sum of the resource's Real-time Energy Market offer integrated under the Final Offer for the resource's expected output level based on its resource parameters at the Real-time Price at the applicable pricing point.

(iii) PJM will calculate the revenue above cost for the dispatch run for each Real-time Settlement Interval in accordance with the following equation:

$$(\text{greater of } A \text{ and } B) - (\text{lesser of } C \text{ and } D)$$

Where:

A = the product of the amount of megawatts of energy dispatched in the Real-time Energy Market dispatch run for the resource in that Real-time Settlement Interval and the Real-time Price at the applicable pricing point;

B = the product of the amount of megawatts of energy the resource actually provided in that Real-time Settlement Interval and the Real-time Price at the applicable pricing point;

C = the resource's Real-time Energy Market offer integrated under the Final Offer for the amount of megawatts dispatched in the Real-time Energy Market dispatch run;

D = the resource's Real-time Energy Market offer integrated under the Final Offer for the amount of megawatts the resource actually provided in that Real-time Settlement Interval.

(iv) The Dispatch Differential Lost Opportunity Cost credit shall equal the greater of (A) the difference between the revenue above cost based on the pricing run determined in subsection (f-5)(ii) and the revenue above cost based on the dispatch run determined in subsection (f-5)(iii) or (B) zero.

(v) For each hour in an Operating Day, the total cost of the Dispatch Differential Lost Opportunity Cost credits shall be allocated and charged to each Market Participant in proportion to the sum of its (i) deliveries of energy to load ((a) net of operating Behind The Meter Generation, but not to be less than zero; and (b) excluding Direct Charging Energy) in the PJM Region, served under Network Transmission Service, in megawatt-hours; and (ii) deliveries of energy sales from within the PJM Region to load outside such region in megawatt-hours but not including its bilateral transactions that are Dynamic Transfers to load outside the PJM Region pursuant to Tariff, Attachment K-Appendix, section 1.12, as compared to the sum of all such deliveries for all Market Participants.

(g) The sum of the foregoing credits in Tariff, Attachment K-Appendix, section 3.2.3(f-1) through Tariff, Attachment K-Appendix, section 3.2.3(f-4), plus any cancellation fees paid in accordance with Tariff, Attachment K-Appendix, section 1.10.2(d), such cancellation fees to be applied to the Operating Day for which the unit was scheduled, plus any shortfalls paid pursuant to the Market Settlement provision of the real-time Economic Load Response Program, less any payments received from another Control Area for Operating Reserves shall be the cost of Operating Reserves for the Real-time Energy Market in each Operating Day.

(h) The cost of Operating Reserves for the Real-time Energy Market for each Operating Day, except those associated with the scheduling of units for Black Start service or testing of Black Start Units as provided in Tariff, Schedule 6A, shall be allocated and charged to each Market Participant based on their daily total of hourly deviations determined in accordance with the following equation:

$$\sum_h (A + B + C)$$

Where:

h = the hours in the applicable Operating Day;

A = For each Real-time Settlement Interval in an hour, the sum of the absolute value of the withdrawal deviations (in MW) between the quantities scheduled in the Day-ahead Energy Market and the Market Participant's energy withdrawals (net of operating Behind The Meter Generation) in the Real-time Energy Market, except as noted in subsection (h)(ii) below and in the PJM Manuals divided by the number of Real-time Settlement Intervals for that hour. The summation of each Real-time Settlement Interval's withdrawal deviation in an hour will be the Market Participant's total hourly withdrawal deviations. Market Participant bilateral transactions that are Dynamic Transfers to load outside the PJM Region pursuant to Tariff, Attachment K-Appendix, section 1.12 are not included in the determination of withdrawal deviations;

B = For each Real-time Settlement Interval in an hour, the sum of the absolute value of generation deviations (in MW and not including deviations in Behind The Meter Generation) as determined in subsection (o) divided by the number of Real-time Settlement Intervals for that hour;

C = For each Real-time Settlement Interval in an hour, the sum of the absolute value of the injection deviations (in MW) between the quantities scheduled in the Day-ahead Energy Market and the Market Participant's energy injections in the Real-time Energy Market divided by the number of Real-time Settlement Intervals for that hour. The summation of the injection deviations for each Real-time Settlement Interval in an hour will be the Market Participant's total hourly injection deviations. The determination of injection deviations does not include generation resources.

The Revenue Data for Settlements determined for each Real-time Settlement Interval in accordance with Tariff, Attachment K-Appendix, section 3.1A shall be used in determining the real-time withdrawal deviations, generation deviations and injection deviations used to calculate Operating Reserve under this subsection (e).

The costs associated with scheduling of units for Black Start service or testing of Black Start Units shall be allocated by ratio share of the monthly transmission use of each Network Customer or Transmission Customer serving Zone Load or Non-Zone Load, as determined in accordance with the formulas contained in Tariff, Schedule 6A.

Notwithstanding section (h)(1) above, as more fully set forth in the PJM Manuals, load deviations from the Day-ahead Energy Market shall not be assessed Operating Reserves charges to the extent attributable to reductions in the load of Price Responsive Demand that is in response to an increase in Locational Marginal Price from the Day-ahead Energy Market to the Real-time Energy Market and that is in accordance with a properly submitted PRD Curve.

Deviations that occur within a single Zone shall be associated with the Eastern or Western Region, as defined in section 3.2.3(q) below, and shall be subject to the regional balancing Operating Reserve rate determined in accordance with Section 3.2.3(q). Deviations at a hub shall be associated with the Eastern or Western Region if all the buses that define the hub are located in the region. Deviations at an Interface Pricing Point shall be associated with whichever region, the Eastern or Western Region, with which the majority of the buses that define that Interface Pricing Point are most closely electrically associated. If deviations at interfaces and hubs are associated with the Eastern or Western region, they shall be subject to the regional balancing Operating Reserve rate. Demand and supply deviations shall be based on total activity in a Zone, including all aggregates and hubs defined by buses that are wholly contained within the same Zone.

The foregoing notwithstanding, netting deviations shall be allowed for each Real-time Settlement Interval in accordance with the following provisions:

(i) Generation resources with multiple units located at a single bus shall be able to offset deviations in accordance with the PJM Manuals to determine the net deviation MW at the relevant bus.

(ii) Demand deviations will be assessed by comparing all day-ahead demand transactions, which include the components referenced in section 3.2.3(d) regarding the cost of Operating Reserves in the Day-ahead Energy Market, at a single transmission

zone, hub, or interface against the real-time demand transactions at that same transmission zone, hub, or interface; except that the positive values of demand deviations, as set forth in the PJM Manuals, will not be assessed Operating Reserve charges in the event of a Primary Reserve or Synchronized Reserve shortage in real-time or where PJM initiates the request for emergency load reductions in real-time in order to avoid a Primary Reserve or Synchronized Reserve shortage.

(iii) Supply deviations will be assessed by comparing all day-ahead transactions at a single transmission zone, hub, or interface against the real-time transactions at that same transmission zone, hub, or interface.

(iv) Bilateral transactions inside the PJM Region, as defined in Operating Agreement, Schedule 1, section 1.7.10, will not be included in the determination of Supply or Demand deviations.

(i) At the end of each Operating Day, Market Sellers shall be credited on the basis of their offered prices for synchronous condensing for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, as well as the credits calculated as specified in Section 3.2.3(b) for those generators committed solely for the purpose of providing synchronous condensing for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, at the request of the Office of the Interconnection.

(j) The sum of the foregoing credits as specified in section 3.2.3(i) shall be the cost of Operating Reserves for synchronous condensing for the PJM Region for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, or in association with post-contingency operation for the Operating Day and shall be separately determined for the PJM Region.

(k) The cost of Operating Reserves for synchronous condensing for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, or in association with post-contingency operation for each Operating Day shall be allocated and charged to each Market Participant in proportion to the sum of its (i) deliveries of energy to load (net of operating Behind The Meter Generation, but not to be less than zero) in the PJM Region, served under Network Transmission Service, in megawatt-hours during that Operating Day; and (ii) deliveries of energy sales from within the PJM Region to load outside such region in megawatt-hours during that Operating Day, but not including its bilateral transactions that are Dynamic Transfers to load outside the PJM Region pursuant to Tariff, Attachment K-Appendix, section 1.12, as compared to the sum of all such deliveries for all Market Participants.

(l) For any Operating Day in either, as applicable, the Day-ahead Energy Market or the Real-time Energy Market for which, for all or any part of such Operating Day, the Office of the Interconnection: (i) declares a Maximum Generation Emergency; (ii) issues an alert that a Maximum Generation Emergency may be declared (“Maximum Generation Emergency Alert”); or (iii) schedules units based on the anticipation of a Maximum Generation Emergency or a Maximum Generation Emergency Alert, the Operating Reserves credit otherwise provided by section 3.2.3.(b) or section 3.2.3(e) in connection with market-based offers shall be limited as

provided in subsections (n) or (m), respectively. The Office of the Interconnection shall provide timely notice on its internet site of the commencement and termination of any of the actions described in subsection (i), (ii), or (iii) of this subsection (l) (collectively referred to as “MaxGen Conditions”). Following the posting of notice of the commencement of a MaxGen Condition, a Market Seller may elect to submit a cost-based offer in accordance with Operating Agreement, Schedule 2, in which case subsections (m) and (n) shall not apply to such offer; provided, however, that such offer must be submitted in accordance with the deadlines in Tariff, Attachment K-Appendix, section 1.10 for the submission of offers in the Day-ahead Energy Market or Real-time Energy Market, as applicable. Submission of a cost-based offer under such conditions shall not be precluded by Tariff, Attachment K-Appendix, section 1.9.7(b); provided, however, that the Market Seller must return to compliance with Tariff, Attachment K-Appendix, section 1.9.7(b) when it submits its bid for the first Operating Day after termination of the MaxGen Condition.

(m) For the Real-time Energy Market, if the Effective Offer Price (as defined below) for a market-based offer is greater than \$1,000/MWh and greater than the Market Seller’s lowest available and applicable cost-based offer, the Market Seller shall not receive any credit for Operating Reserves. For purposes of this subsection (m), the Effective Offer Price shall be the amount that, absent subsections (l) and (m), would have been credited for Operating Reserves for such Operating Day pursuant to section 3.2.3(e) plus the Real-time Energy Market revenues for the Real-time Settlement Intervals that the offer is economic divided by the megawatt hours of energy provided during the Real-time Settlement Intervals that the offer is economic. The Real-time Settlement Intervals that the offer is economic shall be: (i) the Real-time Settlement Intervals that the offer price for energy is less than or equal to the Real-time Price for the relevant generation bus, (ii) the Real-time Settlement Intervals in which the offer for energy is greater than Locational Marginal Price and the unit is operated at the direction of the Office of the Interconnection that are in addition to any Real-time Settlement Intervals required due to the minimum run time or other operating constraint of the unit, and (iii) for any unit with a minimum run time of one hour or less and with more than one start available per day, any hours the unit operated at the direction of the Office of the Interconnection.

(n) For the Day-ahead Energy Market, if notice of a MaxGen Condition is provided prior to 11:00 a.m. on the day before the Operating Day for which transactions are being scheduled and the Effective Offer Price for a market-based offer is greater than \$1,000/MWh and greater than the Market Seller’s lowest available and applicable cost-based offer, the Market Seller shall not receive any credit for Operating Reserves. If notice of a MaxGen Condition is provided after 11:00 a.m. on the day before the Operating Day for which transactions are being scheduled and the Effective Offer Price is greater than \$1,000/MWh, the Market Seller shall receive credit for Operating Reserves determined in accordance with section 3.2.3(b), subject to the limit on total compensation stated below. If the Effective Offer Price is less than or equal to \$1,000/MWh, regardless of when notice of a MaxGen Condition is provided, the Market Seller shall receive credit for Operating Reserves determined in accordance with section 3.2.3(b), subject to the limit on total compensation stated below. For purposes of this subsection (n), the Effective Offer Price shall be the amount that, absent subsections (l) and (n), would have been credited for Operating Reserves for such Operating Day divided by the megawatt hours of energy offered during the Specified Hours, plus the offer for energy during such hours. The

Specified Hours shall be the lesser of: (1) the minimum run hours stated by the Market Seller in its Offer Data; and (2) either (i) for steam-electric generating units and for combined-cycle units when such units are operating in combined-cycle mode, the six consecutive hours of highest Day-ahead Price during such Operating Day when such units are running or (ii) for combustion turbine units and for combined-cycle units when such units are operating in combustion turbine mode, the two consecutive hours of highest Day-ahead Price during such Operating Day when such units are running. Notwithstanding any other provision in this subsection, the total compensation to a Market Seller on any Operating Day that includes a MaxGen Condition shall not exceed \$1,000/MWh during the Specified Hours, where such total compensation in each such hour is defined as the amount that, absent subsections (l) and (n), would have been credited for Operating Reserves for such Operating Day pursuant to section 3.2.3(b) divided by the Specified Hours, plus the Day-ahead Price for such hour, and no Operating Reserves payments shall be made for any other hour of such Operating Day. If a unit operates in real time at the direction of the Office of the Interconnection consistently with its day-ahead clearing, then subsection (m) does not apply.

(o) Dispatchable pool-scheduled generation resources and dispatchable self-scheduled generation resources that follow dispatch shall not be assessed balancing Operating Reserve deviations. Pool-scheduled generation resources and dispatchable self-scheduled generation resources that do not follow dispatch shall be assessed balancing Operating Reserve deviations in accordance with the calculations described below and in the PJM Manuals.

The Office of the Interconnection shall calculate a ramp-limited desired MW value for generation resources where the economic minimum and economic maximum are at least as far apart in real-time as they are in day-ahead according to the following parameters:

(i) real-time economic minimum \leq 105% of day-ahead economic minimum or day-ahead economic minimum plus 5 MW, whichever is greater.

(ii) real-time economic maximum \geq 95% day-ahead economic maximum or day-ahead economic maximum minus 5 MW, whichever is lower.

The ramp-limited desired MW value for a generation resource shall be equal to:

$$Ramp_Request_t = \frac{(Dispatchtarget_{t-1} - AOutput_{t-1})}{(LAtime_{t-1})}$$

$$RL_Desired_t = AOutput_{t-1} + (Ramp_Request_t * Case_Eff_time_{t-1})$$

where:

1. Dispatchtarget = Dispatch Signal for the previous approved Dispatch case
2. AOutput = Unit's achievable target MW at case solution time as defined

in the PJM Manuals

3. $L_{Time} = \text{Dispatch look ahead time}$
4. $Case_Eff_time = \text{Time between signal changes}$
5. $RL_Desired = \text{Ramp-limited desired MW}$

To determine if a generation resource is following dispatch the Office of the Interconnection shall determine the unit's MW off dispatch and % off dispatch by using the lesser of the difference between the actual output and the dispatch signal or the actual output and ramp-limited desired MW value for each Real-time Settlement Interval. If the dispatch signal and the ramp-limited desired MW for the resource are unavailable, the Office of the Interconnection will determine the unit's MW off dispatch and % off dispatch by calculating the lesser of the difference between the actual output and the dispatch LMP Desired MW for each Real-time Settlement Interval.

A pool-scheduled or dispatchable self-scheduled resource is considered to be following dispatch if its actual output is between its ramp-limited desired MW value and dispatch signal, or if its % off dispatch is ≤ 10 , or its Real-time Settlement Interval MWh is within 5% of the Real-time Settlement Interval ramp-limited desired MW. A self-scheduled generator must also be dispatched above economic minimum. The degree of deviations for resources that are not following dispatch shall be determined for each Real-time Settlement Interval in accordance with the following provisions:

- A dispatchable self-scheduled resource that is not dispatched above economic minimum shall be assessed balancing Operating Reserve deviations according to the following formula: Real-time Settlement Interval MWh – Day-Ahead MWh.
- A resource that is dispatchable day-ahead but is Fixed Gen in real-time shall be assessed balancing Operating Reserve deviations according to the following formula: Real-time Settlement Interval MWh – dispatch LMP Desired MW.
- Pool-scheduled generators that are not following dispatch shall be assessed balancing Operating Reserve deviations according to the following formula: Real-time Settlement Interval MWh – Ramp-Limited Desired MW.
- If a resource's real-time economic minimum is greater than its day-ahead economic minimum by 5% or 5 MW, whichever is greater, or its real-time economic maximum is less than its Day Ahead economic maximum by 5% or 5 MW, whichever is lower, and dispatch LMP Desired MWh for the Real-time Settlement Interval is either below the real time economic minimum or above the real time economic maximum, then balancing Operating Reserve deviations for the resource shall be assessed according to the following formula: Real time Settlement Interval MWh – dispatch LMP Desired MWh.
- If a resource is not following dispatch and its % Off Dispatch is $\leq 20\%$, balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh – Ramp-Limited Desired MW. If deviation

value is within 5% of Ramp-Limited Desired MW, balancing Operating Reserve deviations shall not be assessed.

- If a resource is not following dispatch and its % off Dispatch is > 20%, balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh – dispatch LMP Desired MWh.
- If a resource is not following dispatch, and the resource has tripped, for the Real-time Settlement Interval the resource tripped and the Real-time Settlement Intervals it remains offline throughout its day-ahead schedule balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh – Day-Ahead MWh.
- For resources that are not dispatchable in both the Day-Ahead and Real-time Energy Markets balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh - Day-ahead MWh.

If a resource has a sum of the absolute value of generator deviations for an hour that is less than 5 MWh, then the resource shall not be assessed balancing Operating Reserve deviations for that hour.

(o-1) Dispatchable economic load reduction resources that follow dispatch shall not be assessed balancing Operating Reserve deviations. Economic Load Response Participant resources that do not follow dispatch shall be assessed balancing Operating Reserve deviations as described in this subsection and as further specified in the PJM Manuals.

The Desired MW quantity for such resources for each hour shall be the hourly integrated MW quantity to which the load reduction resource was dispatched for each hour (where the hourly integrated value is the average of the dispatched values as determined by the Office of the Interconnection for the resource for each hour).

If the actual reduction quantity for the load reduction resource for a given hour deviates by no more than 20% above or below the Desired MW quantity, then no balancing Operating Reserve deviation will accrue for that hour. If the actual reduction quantity for the load reduction resource for a given hour is outside the 20% bandwidth, the balancing Operating Reserve deviations will accrue for that hour in the amount of the absolute value of (Desired MW – actual reduction quantity). For those hours where the actual reduction quantity is within the 20% bandwidth specified above, the load reduction resource will be eligible to be made whole for the total value of its offer as defined in Tariff, Attachment K-Appendix, section 3.3A. Hours for which the actual reduction quantity is outside the 20% bandwidth will not be eligible for the make-whole payment. If at least one hour is not eligible for make-whole payment based on the 20% criteria, then the resource will also not be made whole for its shutdown cost.

(p) The Office of the Interconnection shall allocate the charges assessed pursuant to Tariff, Attachment K-Appendix, section 3.2.3(h) except those associated with the scheduling of units for Black Start service or testing of Black Start Units as provided in Tariff, Schedule 6A, to

real-time deviations from day-ahead schedules or real-time load share plus exports depending on whether the underlying balancing Operating Reserve credits are related to resources scheduled during the reliability analysis for an Operating Day, or during the actual Operating Day. If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, section 1.11.6, the Office of the Interconnection shall allocate the charges to the ratio share of real-time load plus export transactions.

(i) For resources scheduled by the Office of the Interconnection during the reliability analysis for an Operating Day, the associated balancing Operating Reserve charges shall be allocated based on the reason the resource was scheduled according to the following provisions:

(A) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to operate in real-time to augment the physical resources committed in the Day-ahead Energy Market to meet the forecasted real-time load plus the Operating Reserve requirement, the associated balancing Operating Reserve charges shall be allocated to real-time deviations from day-ahead schedules.

(B) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to maintain system reliability, the associated balancing Operating Reserve charges shall be allocated according to ratio share of real time load plus export transactions.

(C) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource with a day-ahead schedule is required to deviate from that schedule to provide balancing Operating Reserves, the associated balancing Operating Reserve charges shall be allocated pursuant to (A) or (B) above.

(ii) For resources scheduled during an Operating Day, the associated balancing Operating Reserve charges shall be allocated according to the following provisions:

(A) If the Office of the Interconnection directs a resource to operate during an Operating Day to provide balancing Operating Reserves, the associated balancing Operating Reserve charges shall be allocated according to ratio share of load plus exports. The foregoing notwithstanding, charges will be assessed pursuant to this section only if the LMP at the resource's bus does not meet or exceeds the applicable offer of the resource for at least four 5-minute intervals during one or more discrete clock hours during each period the resource operated and produced MWs during the relevant Operating Day. If a resource operated and produced MWs for less than four 5-minute intervals during one or more discrete clock hours during the relevant Operating Day, the charges for that resource during the hour it was operated less than four 5-minute intervals will be

identified as being in the same category as identified for the Operating Reserves for the other discrete clock hours.

(B) If the Office of the Interconnection directs a resource not covered by Tariff, Attachment K-Appendix, section 3.2.3(h)(ii)(A) to operate in real-time during an Operating Day, the associated balancing Operating Reserve charges shall be allocated according to real-time deviations from day-ahead schedules.

(q) The Office of the Interconnection shall determine regional balancing Operating Reserve rates for the Western and Eastern Regions of the PJM Region. For the purposes of this section, the Western Region shall be the AEP, APS, ComEd, Duquesne, Dayton, ATSI, DEOK, EKPC, OVEC transmission Zones, and the Eastern Region shall be the AEC, BGE, Dominion, PENELEC, PEPCO, ME, PPL, JCPL, PECO, DPL, PSEG, RE transmission Zones. The regional balancing Operating Reserve rates shall be determined in accordance with the following provisions:

(i) The Office of the Interconnection shall calculate regional adder rates for the Eastern and Western Regions. Regional adder rates shall be equal to the total balancing Operating Reserve credits paid to generators for transmission constraints that occur on transmission system capacity equal to or less than 345kv. The regional adder rates shall be separated into reliability and deviation charges, which shall be allocated to real-time load or real-time deviations, respectively. Whether the underlying credits are designated as reliability or deviation charges shall be determined in accordance with section 3.2.3(p).

(ii) The Office of the Interconnection shall calculate RTO balancing Operating Reserve rates. RTO balancing Operating Reserve rates shall be equal to balancing Operating Reserve credits except those associated with the scheduling of units for Black Start service or testing of Black Start Units as provided in Tariff, Schedule 6A, in excess of the regional adder rates calculated pursuant to Tariff, Attachment K-Appendix, section 3.2.3(q)(i) of Schedule 1 of this Agreement. The RTO balancing Operating Reserve rates shall be separated into reliability and deviation charges, which shall be allocated to real-time load or real-time deviations, respectively. Whether the underlying credits are allocated as reliability or deviation charges shall be determined in accordance with section 3.2.3(p).

(iii) Reliability and deviation regional balancing Operating Reserve rates shall be determined by summing the relevant RTO balancing Operating Reserve rates and regional adder rates.

(iv) If the Eastern and/or Western Regions do not have regional adder rates, the relevant regional balancing Operating Reserve rate shall be the reliability and/or deviation RTO balancing Operating Reserve rate.

(r) Market Sellers that incur incremental operating costs for a generation resource that are either greater than \$1,000/MWh as determined in accordance with the Market Seller's

PJM-approved Fuel Cost Policy, Operating Agreement, Schedule 2 and PJM Manual 15, but are not verified at the time of dispatch of the resource under section 6.4.3 of this Schedule, or greater than \$2,000/MWh as determined in accordance with the Market Seller's PJM-approved Fuel Cost Policy, Operating Agreement, Schedule 2, and PJM Manual 15, will be eligible to receive credit for Operating Reserves upon review of the Market Monitoring Unit and the Office of the Interconnection, and approval of the Office of the Interconnection. Market Sellers must submit to the Office of the Interconnection and the Market Monitoring Unit all relevant documentation demonstrating the calculation of costs greater than \$2,000/MWh, and costs greater than \$1,000/MWh which were not verified at the time of dispatch of the resource under Tariff, Attachment K-Appendix, section 6.4.3. The Office of the Interconnection must approve any Operating Reserve credits paid to a Market Seller under this subsection (r).

3.2.3A Synchronized Reserve.

(a) Each Market Participant that is a Load Serving Entity that is not part of an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have an obligation for hourly Synchronized Reserve equal to its pro rata share of Synchronized Reserve requirements for the hour for each Reserve Zone and Reserve Sub-zone of the PJM Region, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Reserve Zone or Reserve Sub-zone for the hour ("Synchronized Reserve Obligation"), less any amount obtained from condensers associated with provision of Reactive Services as described in section 3.2.3B(i) and any amount obtained from condensers associated with post-contingency operations, as described in section 3.2.3C(b). Those entities that participate in an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have their reserve obligations determined based on the stipulations in such agreement. A Market Participant's hourly Synchronized Reserve Obligation shall be adjusted by any Synchronized Reserve provided on the Market Participant's behalf through a bilateral agreement. A Market Participant with an hourly Synchronized Reserve Obligation shall be charged the pro rata share of the sum of day-ahead and real-time credits for Synchronized Reserve as defined in sections 3.2.3A(b)(i) and (ii) below.

(b) A resource supplying Synchronized Reserve at the direction of the Office of the Interconnection shall be credited as follows:

i) Credits for Synchronized Reserve provided by generation and Economic Load Response Participant resources assigned to provide Synchronized Reserve by the Office of the Interconnection or self-scheduled in the Day-ahead Synchronized Reserve Market shall be equal to the product of the Day-ahead Synchronized Reserve Market Clearing Price multiplied by the megawatt amount of Synchronized Reserve such resource is assigned to provide..

ii) Credits for Synchronized Reserve provided by generation resources and Economic Load Response Participant resources assigned to provide Synchronized Reserve by the Office of the Interconnection or self-scheduled in the Real-time Synchronized Reserve Market shall be determined for each operating hour based on the sum of their hourly total of Real-time Settlement Interval deviations determined in accordance with the following equation:

$$\sum_i ((A - B) * C)$$

Where:

i = the Real-time Settlement Intervals in the applicable operating hour;

A = For each Real-time Settlement Interval, the megawatts of Synchronized Reserve from that resource assigned by the Office of the Interconnection or self-scheduled in the Real-time Synchronized Reserve Market. The megawatt value is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements of the resource for each Real-time Settlement Interval where there is not a Synchronized Reserve event;

B = For each Real-time Settlement Interval, the megawatts of Synchronized Reserve from that resource assigned by the Office of the Interconnection or self-scheduled in the Day-ahead Synchronized Reserve Market; and

C = For each Real-time Settlement Interval, the Real-time Synchronized Reserve Market Clearing Price.

If a Synchronized Reserve Event is initiated by the Office of the Interconnection and the Economic Load Response Participant resource reduced its load in response to the event, the resource shall be eligible to receive a credit for the fixed costs associated with achieving the load reduction, as specified in the PJM Manuals.

iii) Pool-scheduled resources shall be credited a Synchronized Reserve lost opportunity cost credit, where positive, as described in subsection (f)(iv) below.

(c) [Reserved for future use]

(d) Synchronized Reserve Market Clearing Prices

(i) For the Day-ahead Synchronized Reserve Market, the Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection for each hour of the Operating Day. The Day-ahead Synchronized Reserve Market Clearing Price shall be calculated as the price of serving the next increment of demand for Synchronized Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Synchronized Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Synchronized Reserve established in accordance with Tariff, Attachment K-Appendix, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Synchronized Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute and (B) the price of serving the next increment of demand for Primary Reserve and 30-minute Reserve for each Reserve Zone or Reserve

Sub-zone to which the next increment of demand for Synchronized Reserve can contribute, provided that the Synchronized Reserve Market Clearing Price shall be less than or equal to the sum of no more than two of the Reserve Penalty Factors for the Synchronized Reserve Requirement, the Primary Reserve Requirement, and the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.10.8(d), Day-ahead Synchronized Reserve Market Clearing Prices shall be set to zero dollars per megawatt-hour and for purposes of settlements for such Operating Day, the Office of the Interconnection shall utilize a scheduled megawatt quantity and Day-ahead Synchronized Reserve Market Clearing Price of zero dollars per megawatt-hour and all settlements will be based on the Real-time Synchronized Reserve market quantities and prices as determined pursuant to subsection (d)(ii) hereof.

(ii) For the Real-time Synchronized Reserve Market, the Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection in the Real-time Price software program, which is known as the pricing run, for each Real-time Settlement Interval of the Operating Day. Each 5-minute clearing price shall be calculated as the price of serving the next increment of demand for Synchronized Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Synchronized Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Synchronized Reserve established in accordance with Tariff, Attachment K-Appendix, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Synchronized Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute and (B) the price of serving the next increment of demand for Primary Reserve and 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute, provided that the Synchronized Reserve Market Clearing Price shall be less than or equal to the sum of no more than two of the Reserve Penalty Factors for the Synchronized Reserve Requirement, the Primary Reserve Requirement, and the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, and the Office of the Interconnection is not assigning Synchronized Reserves, then the Synchronized Reserve Market Clearing Price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, where the real-time Market Suspension is less than or equal to six (6) consecutive hours, which may span up to two Operating Days, and the

Office of the Interconnection is assigning Synchronized Reserves, then the Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than six (6) consecutive hours but less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are cleared Day-ahead Synchronized Reserve Market Clearing Prices for the affected Operating Day, then the Real-time Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the Day-ahead Synchronized Reserve Market Clearing Prices for each corresponding hour. If no such Day-ahead Synchronized Reserve Market Clearing Prices exist, then the Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than twenty-four (24) consecutive hours, and the Office of the Interconnection is assigning Synchronized Reserves, the Office of the Interconnection will set the Synchronized Reserve Market Clearing Price to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period. Resources will be compensated for lost opportunity cost per subsection (f) hereof using the energy price as determined in Operating Agreement, Schedule 1, section 2.5.2.iii. The opportunity cost shall be zero for all resources self-scheduled to provide Synchronized Reserve, synchronous condensers and Economic Load Response Participant resources.

If the Office of the Interconnection has initiated in a Reserve Zone or Reserve Sub-zone either a Voltage Reduction Action as described in the PJM Manuals or a Manual Load Dump Action as described in the PJM Manuals, the Real-time Synchronized Reserve Market Clearing Price shall be the sum of the Reserve Penalty Factors for the Primary Reserve Requirement, and the Synchronized Reserve Requirement for that Reserve Zone or Reserve Sub-zone.

(iii) The Reserve Penalty Factor for the Synchronized Reserve Requirement shall be \$850/MWh.

The Reserve Penalty Factor for the Extended Synchronized Reserve Requirement shall be \$300/MWh.

(iv) By no later than April 30 of each year, the Office of the Interconnection will analyze Market Participants' response to prices exceeding \$1,000/MWh on an annual basis and will provide its analysis to PJM stakeholders. The Office of the Interconnection will also review this analysis to determine whether any changes to the Synchronized Reserve Penalty Factors are warranted for subsequent Delivery Year(s).

(e) (i) For determining the Synchronized Reserve Market Clearing Price in each hour of the Day-ahead Synchronized Reserve Market, the estimated resource-specific opportunity cost for a generation resource or Economic Load Response Participant resource shall be the difference between the Locational Marginal Price at the generation or Economic Load Response Participant resource bus and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) or offer price to reduce energy from the Economic Load Response Participant resource in the PJM Interchange Energy Market when the Locational Marginal Price at the generation or Economic Load Participant resource bus is greater than the offer price for energy from the generation resource or the offer price to reduce energy from the Economic Load Response Participant resource.

However, the opportunity costs shall be zero for resources self-scheduled to provide Synchronized Reserve and for synchronous condensers and for Economic Load Response Participant resources that do not receive a day-ahead commitment to provide energy in the same operating hour in which such resource is committed to provide Synchronized Reserve.

(ii) For determining the Synchronized Reserve Market Clearing Price for each Real-time Settlement Interval in the Real-time Synchronized Reserve Market, the estimated unit-specific opportunity cost for a generation resource that is not a hydroelectric resource shall be the difference between the Locational Marginal Price at the generation bus for the generation resource and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) in the PJM Interchange Energy Market when the Locational Marginal Price at the generation bus is greater than the offer price for energy from the generation resource.

For hydroelectric resources, the estimated unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the expected real-time Locational Marginal Price at that generation bus. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions, as defined in the PJM Manuals, and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the expected real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average day-ahead Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

The opportunity costs shall be zero for all resources self-scheduled to provide Synchronized Reserve, synchronous condensers and Economic Load Response Participant resources.

(f) (i) In determining the credit under subsection (b) to a generation resource, except a generation resource that is operating as a synchronous condenser, selected to provide Synchronized Reserve in the Day-ahead Synchronized Reserve Market, or an Economic Load Response Participant resource that is selected to provide Synchronized Reserve in the Day-ahead Synchronized Reserve Market for the same operating hour in which such resource receives a day-ahead commitment to provide energy, the opportunity cost of a resource shall be determined for each operating hour that the Office of the Interconnection requires a resource to provide Synchronized Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Day-ahead Locational Marginal Price at the generation bus of the generation resource or the applicable pricing point for the Economic Load Response Participant resource;

B = The deviation of the resource's energy output or load reduction necessary to supply a Day-ahead Synchronized Reserve assignment from the resource's energy expected output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load; and

C = The Day-ahead Energy market offer integrated under the applicable energy offer curve for the resource's energy output or load reduction necessary to provide a Day-ahead Synchronized Reserve Market assignment from the resource's expected energy output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load.

For a generation resource that is operating as a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: [energy use for providing synchronous condensing multiplied by A] plus [the applicable condense start-up cost divided by the number of hours the resource is assigned Synchronized Reserve].

(ii) In determining the credit under subsection (b) to a generation resource, except a generation resource that is operating as a synchronous condenser, selected to provide Synchronized Reserve in the Real-time Synchronized Reserve Market in excess of the resource's Day-ahead Synchronized Reserve Market assignment and that actively follows the Office of the Interconnection's signals and instructions, the unit-specific opportunity cost of that generation resource shall be determined for each Real-time Settlement Interval that the Office of the Interconnection requires that generation resource to provide Synchronized Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Real-time Locational Marginal Price at the generation bus of the generation resource;

B = The deviation of the generation resource's output necessary to supply Synchronized Reserve in real-time, ~~eapped at~~ reduced by the amount of Synchronized Reserve the resource failed to ~~responded~~ during a Synchronized Reserve Event during the Operating Day, in excess of its Day-ahead Synchronized Reserve Market assignment and follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy; and

C = The energy offer integrated under the applicable energy offer curve for the generation resource's output necessary to supply Synchronized Reserve in real-time from the lesser of the generation resource's output necessary to provide a Day-ahead Synchronized Reserve Market assignment or follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy.

For a generation resource that is a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: [additional energy use in excess of day-ahead energy use for providing synchronous condensing in real-time multiplied by A] plus [any applicable condense start-up costs due to additional condense start-ups in real-time in excess of day-ahead condense start-ups allocated to each Real-time Settlement Interval as described in PJM Manuals].

For hydroelectric resources, the unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the real-time Locational Marginal Price at that generation bus multiplied by the additional megawatts assigned to supply Synchronized Reserve in real-time in excess of its Day-ahead Synchronized Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average real-time Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating multiplied by the additional megawatts assigned to supply the hourly Synchronized Reserve in real-time in excess of its Day-ahead Synchronized Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

(iii) For each Real-time Settlement Interval, a Market Revenue Neutrality Offset is calculated for each resource, if eligible. If there is a decrease in the resource's real-time reserve MW from a day-ahead market assignment in more than one market for that Real-time Settlement Interval, the total Market Revenue Neutrality Offset is allocated to the Synchronized Reserve market based on the ratio of the opportunity cost owed due to a reduction in assignment in real-time within the Synchronized Reserve market and the total opportunity cost owed due to a reduction in assignment in real-time from all reserve markets, not to exceed the resource's opportunity cost owed in the Synchronized Reserve market.

A resource is not eligible for Market Revenue Neutrality Offset for Synchronized Reserve in a Real-time Settlement Interval for any of the following conditions:

(A) A resource's real-time Synchronized Reserve assignment decreases due to the resource being self-scheduled to provide energy or Regulation;

(B) A resource reduces its flexibility in real-time such that the resource no longer qualifies to provide Synchronized Reserve in real-time;

(C) A resource's Final Offer is less than its Committed Offer;

(D) A resource trips offline or otherwise becomes unavailable in real-time;

(E) A resource does not follow dispatch as described in section 3.2.3(o) above and section 3.2.3(o-1) above; or

(F) A resource increases its Synchronized Reserve offer price in the Real-time Synchronized Reserve Market from its offer price in the Day-ahead Synchronized Reserve Market.

(iv) A Synchronized Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:

$$(A + B + C + D) - (E + F + G + H)$$

Where:

A = day-ahead Synchronized Reserve offer price times the Synchronized Reserve MW assignment;

B = real-time Synchronized Reserve offer price times the Synchronized Reserve MW assigned in real-time in excess of the Synchronized Reserve MW assigned day-ahead, where the Synchronized Reserve MW assigned is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus

the Revenue Data for Settlements of the resource for each Real-time Settlement Interval where there is not a Synchronized Reserve event;

C = day-ahead opportunity cost as determined in subsection (f)(i) above;

D = real-time opportunity cost as determined in subsection (f)(ii) above;

E = day-ahead clearing price credits as determined in subsection (b)(i) above;

F = real-time clearing price credits as determined in subsection (b)(ii) above less any applicable charges for failure to respond to a Synchronized Reserve Event as determined in subsection (j) below;

G = the applicable Market Revenue Neutrality Offset as determined in subsection (f)(iii) above; and

H = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A(f)(iii) above if not eligible for Market Revenue Neutrality Offset.

(v) The opportunity costs for an Economic Load Response Participant resource assigned Synchronized Reserve in real-time or any resource self-scheduled for Synchronized Reserves shall be zero.

(g) [Reserved for future use]

(h) For each operating hour, the sum of the Synchronized Reserve lost opportunity cost credits credited in accordance with subsection (b)(iii) above shall be allocated and charged to each Market Participant that does not meet its hourly Synchronized Reserve Obligation in proportion to its real-time purchases of Synchronized Reserve in megawatt-hours during that hour.

(i) [Reserved for future use]

(j) In the event a generation resource or Economic Load Response Participant Resource that either has been assigned by the Office of the Interconnection or self-scheduled to provide Synchronized Reserve in real-time fails to provide the assigned or self-scheduled amount of Synchronized Reserve in response to a Synchronized Reserve Event, the resource will be charged at the Real-time Synchronized Reserve Market Clearing Price for the real-time Synchronized Reserve assignment, ~~which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements for the resource,~~ in excess of amount that actually responded for all Real-time Settlement Intervals the resource was assigned or self-scheduled Synchronized Reserve real-time, which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements for the resource on the Operating Day during which the event

occurred. The determination of the amount of Synchronized Reserve credited to a resource shall be on an individual resource basis, not on an aggregate basis.

The resource shall refund payments received for Synchronized Reserve it failed to provide. For purposes of determining the amount of the payments to be refunded by a Market Participant, the Office of the Interconnection shall calculate the shortfall of Synchronized Reserve on an individual resource basis unless the Market Participant had multiple resources that were assigned or self-scheduled to provide Synchronized Reserve, in which case the shortfall will be determined on an aggregate basis. For performance determined on an aggregate basis, the response of any resource that provided more Synchronized Reserve than it was assigned or self-scheduled to provide will be used to offset the performance of other resources that provided less Synchronized Reserve than they were assigned or self-scheduled to provide during a Synchronized Reserve Event, as calculated in the PJM Manuals. The determination of a Market Participant's aggregate response shall not be taken into consideration in the determination of the amount of Synchronized Reserve credited to each individual resource.

The amount refunded shall be determined by multiplying the retroactive penalty megawatts by the Real-time Synchronized Reserve Market Clearing Price for all intervals the resource was assigned or self-scheduled to provide Synchronized Reserve for a period of time immediately preceding the Synchronized Reserve Event equal to the lesser of the average number of days between Synchronized Reserve Events, or the number of days since the resource last failed to provide the amount of Synchronized Reserve it was assigned or self-scheduled to provide in response to a Synchronized Reserve Event. The retroactive penalty megawatts for each interval shall be the lesser of the amount of the shortfall of Synchronized Reserve, measured in megawatts, and the real-time Synchronized Reserve assignment for each interval, which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements for the resource. The average number of days between Synchronized Reserve Events for purposes of this calculation shall be determined by an annual review of the twenty-four month period ending October 31 of the calendar year in which the review is performed, and shall be rounded down to a whole day value. The Office of the Interconnection shall report the results of its annual review to stakeholders by no later than December 31, and the average number of days between Synchronized Reserve Events shall be effective as of the following January 1. The refunded charges shall be allocated as credits to Market Participants based on its pro rata share of the Synchronized Reserve Obligation megawatts in the hour(s) of the Synchronized Reserve Event for the Reserve Sub-zone or Reserve Zone, except that Market Participants that incur a refund obligation and also have an applicable Synchronized Reserve Obligation during the hour(s) of the Synchronized Reserve Event shall not be included in the allocation of such refund credits. If the event spans multiple hours, the refund credits will be prorated hourly based on the duration of the event within each clock hour.

(k) The magnitude of response to a Synchronized Reserve Event by a generation resource or an Economic Load Response Participant resource, except for Batch Load Economic Load Response Participant resources covered by section 3.2.3A(1), is the difference between the generation resource's output or the Economic Load Response Participant resource's consumption at the start of the event and its output or consumption 10 minutes after the start of the event. In

order to allow for small fluctuations and possible telemetry delays, generation resource output or Economic Load Response Participant resource consumption at the start of the event is defined as the lowest telemetered generator resource output or greatest Economic Load Response Participant resource consumption between one minute prior to and one minute following the start of the event. Similarly, a generation resource's output or an Economic Load Response Participant resource's consumption 10 minutes after the event is defined as the greatest generator resource output or lowest Economic Load Response Participant resource consumption achieved between 9 and 11 minutes after the start of the event. The response actually credited to a generation resource will be reduced by the amount the megawatt output of the generation resource falls below the level achieved after 10 minutes by either the end of the event or after 30 minutes from the start of the event, whichever is shorter. The response actually credited to an Economic Load Response Participant resource will be reduced by the amount the megawatt consumption of the Economic Load Response Participant resource exceeds the level achieved after 10 minutes by either the end of the event or after 30 minutes from the start of the event, whichever is shorter.

(l) The magnitude of response by a Batch Load Economic Load Response Participant resource that is at the stage in its production cycle when its energy consumption is less than the level of megawatts in its offer at the start of a Synchronized Reserve Event shall be the difference between (i) the Batch Load Economic Load Response Participant resource's consumption at the end of the Synchronized Reserve Event and (ii) the Batch Load Economic Load Response Participant resource's consumption during the minute within the ten minutes after the end of the Synchronized Reserve Event in which the Batch Load Economic Load Response Participant resource's consumption was highest and for which its consumption in all subsequent minutes within the ten minutes was not less than fifty percent of the consumption in such minute; provided that, the magnitude of the response shall be zero if, when the Synchronized Reserve Event commences, the scheduled off-cycle stage of the production cycle is greater than ten minutes. .

3.2.3A.001 Non-Synchronized Reserve.

(a) Each Market Participant that is a Load Serving Entity that is not part of an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have an obligation for hourly Non-Synchronized Reserve equal to its pro rata share of Non-Synchronized Reserve assigned for the hour for each Reserve Zone and Reserve Sub-zone of the PJM Region, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Reserve Zone and Reserve Sub-zone for the hour ("Non-Synchronized Reserve Obligation"). Those entities that participate in an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have their reserve obligations determined based on the stipulations in such agreement. A Market Participant's hourly Non-Synchronized Reserve Obligation shall be adjusted by any Non-Synchronized Reserve provided on the Market Participant's behalf through a bilateral agreement. A Market Participant with an hourly Non-Synchronized Reserve Obligation shall be charged the pro rata share of the sum day-ahead and real-time credits for Non-Synchronized Reserve as defined in sections 3.2.3A.001(b)(i) and (ii) below.

(b) Resources assigned to provide Non-Synchronized Reserve at the direction of the Office of the Interconnection shall be credited as follows:

(i) Credits for Non-Synchronized Reserve provided by generation resources assigned to provide Non-Synchronized Reserve by the Office of the Interconnection in the Day-ahead Non-Synchronized Reserve Market shall be equal to the product of the Day-ahead Non-Synchronized Market Clearing Price multiplied by the megawatt amount of Non-Synchronized Reserve such resource is assigned to provide.

(ii) Credits for Non-Synchronized Reserve provided by generation resources assigned to provide Non-Synchronized Reserve by the Office of the Interconnection in the Real-time Non-Synchronized Reserve Market shall be determined for each operating hour based on the sum on their hourly total of Real-time Settlement Interval deviations determined in accordance with the following equation:

$$\sum_i ((A - B) * C)$$

Where:

i = the Real-time Settlement Intervals in the applicable operating hour;

A = For each Real-time Settlement Interval, the megawatts of Non-Synchronized Reserve from that resource assigned by the Office of the Interconnection in the Real-time Non-Synchronized Reserve Market;

B = For each Real-time Settlement Interval, the megawatts of Non-Synchronized Reserve from that resource assigned by the Office of the Interconnection in the Day-ahead Non-Synchronized Reserve Market; and

C = For each Real-time Settlement Interval, the Real-time Non-Synchronized Reserve Market Clearing Price.

(iii) Pool-scheduled generation resources assigned to provide Non-Synchronized Reserve in the Day-ahead Non-Synchronized Reserve Market shall be credited a Non-Synchronized Reserve lost opportunity cost credit, where positive, as determined in accordance with subsection (d)(iii) below, to recover any net monetary loss to the Market Seller of such resource associated with the purchase of Non-Synchronized Reserve in the Real-time Non-Synchronized Reserve Market as a result of following the dispatch direction of the Office of the Interconnection.

(c) Non-Synchronized Reserve Market Clearing Prices

(i) For the Day-ahead Non-Synchronized Reserve Market, the Non-Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection for each hour of the Operating Day. The Day-ahead Non-Synchronized Reserve Market Clearing Price shall be

calculated as the price of serving the next increment of demand for Primary Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Non-Synchronized Reserve offer prices and the applicable Operating Reserve Demand Curve for Non-Synchronized Reserve established in accordance with Tariff, Attachment K-Appendix, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Primary Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for Primary Reserve can contribute and (B) the price of serving the next increment of demand for 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Primary Reserve can contribute, provided that the Non-Synchronized Reserve Market Clearing Price shall be less than or equal to the product of 1.5 multiplied by the Reserve Penalty Factor for the Primary Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Non-Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.10.8(d), Day-ahead Non-Synchronized Reserve Market Clearing Prices shall be set to zero dollars per megawatt-hour and for purposes of settlements for such Operating Day, the Office of the Interconnection shall utilize a scheduled megawatt quantity and Day-ahead Non-Synchronized Reserve Market Clearing Price of zero dollars per megawatt-hour and all settlements will be based on the Real-time Non-Synchronized Reserve market quantities and prices as determined pursuant to subsection (c)(ii) hereof.

(ii) For the Real-time Non-Synchronized Reserve Market, the Non-Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection in the Real-time Price software program, which is known as the pricing run, for each Real-time Settlement Interval of the Operating Day. Each 5-minute clearing price shall be calculated as the price of serving the next increment of demand for Primary Reserve in a Reserve Zone or Reserve Sub-zone determined by the interaction between a supply curve formed using Non-Synchronized Reserve offer prices and the applicable Operating Reserve Demand Curve for Non-Synchronized Reserve established in accordance with Tariff, Attachment K-Appendix, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Primary Reserve for any other Reserve Zone or Reserve Subzone to which the next increment of demand for Primary Reserve can contribute and (B) the price of serving the next increment of demand for 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Primary Reserve can contribute, provided that the Non-Synchronized Reserve Market Clearing Price shall be less than or equal to the product of 1.5 multiplied by the Reserve Penalty Factor for the Primary Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Non-Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, and the Office of the Interconnection is not

assigning Non-Synchronized Reserves, then the Non-Synchronized Reserve Clearing Price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, where the real-time Market Suspension is less than or equal to six (6) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Non-Synchronized Reserves, then the Non-Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Non-Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than six (6) consecutive hours but less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are cleared Day-ahead Non-Synchronized Reserve Market Clearing Prices for the affected Operating Day, then the Real-time Non-Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the Day-ahead Non-Synchronized Reserve Market Clearing Prices for each corresponding hour. If no such Day-ahead Non-Synchronized Reserve Market Clearing Prices exist, then the Non-Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Non-Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than twenty-four (24) consecutive hours, the Non-Synchronized Reserve Market Clearing Price will be set to zero dollars per megawatt-hour regardless of whether the Office of the Interconnection is assigning Non-Synchronized Reserves.

If the Office of the Interconnection has initiated in a Reserve Zone or Reserve Sub-zone either a Voltage Reduction Action as described in the PJM Manuals or a Manual Load Dump Action as described in the PJM Manuals, the Real-time Non-Synchronized Reserve Market Clearing Price shall be the product of 1.5 multiplied by the Reserve Penalty Factor for the Primary Reserve Requirement for that Reserve Zone or Reserve Sub-zone.

(iii) The Reserve Penalty Factor for the Primary Reserve Requirement shall be \$850/MWh.

The Reserve Penalty Factor for the Extended Primary Reserve Requirement shall be \$300/MWh.

(iv) By no later than April 30 of each year, the Office of the Interconnection will analyze Market Participants' response to prices exceeding \$1,000/MWh on an annual basis and will provide its analysis to PJM stakeholders. The Office of the

Interconnection will also review this analysis to determine whether any changes to the Primary Reserve Penalty Factors are warranted for subsequent Delivery Year(s).

(d) (i) For determining the Non-Synchronized Reserve clearing price for each hour in the Day-ahead Non- Synchronized Reserve Market and for each Real-time Settlement Interval in the Real-time Non-Synchronized Reserve Market, including during a declaration of a Market Suspension, the unit-specific opportunity cost for a generation resource that is not providing energy because they are providing Non-Synchronized Reserves will be zero.

(ii) For each Real-time Settlement Interval, a total Market Revenue Neutrality Offset is calculated for each resource, if eligible. If there is a decrease in real-time reserve MW from a day-ahead market assignment in more than one market for that Real-time Settlement Interval, the total Market Revenue Neutrality Offset is allocated to the Non-Synchronized Reserve market based on the ratio of the opportunity cost owed due to a reduction in assignment in real-time within the Non-Synchronized Reserve market and the total opportunity cost owed due to a reduction in assignment in real-time from all reserve markets, not to exceed the resource's opportunity cost owed in the Non-Synchronized Reserve market.

A resource is not eligible for Market Revenue Neutrality Offset for Non-Synchronized Reserve in a Real-time Settlement Interval for any of the following conditions:

(A) A resource's real-time Non-Synchronized Reserve assignment decreases due to the resource being self-scheduled to provide energy, Synchronized Reserve, or Regulation;

(B) A resource reduces flexibility in real-time such that the resource no longer qualifies to provide Non-Synchronized Reserve in real-time;

(C) A resource's Final Offer is less than its Committed Offer;

(D) A resource trips offline or otherwise becomes unavailable in real-time; or

(E) A resource does not follow dispatch as described in section 3.2.3(o) above and section 3.2.3(o-1) above.

(iii) A Non-Synchronized Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:

$$(\text{zero}) - (A + B + C + D)$$

Where:

A = day-ahead clearing price credits as determined in subsection (b)(i) above;

B = real-time clearing price credits as determined in subsection (b)(ii) above;

C = the applicable Market Revenue Neutrality Offset as determined in subsection (d)(ii) above; and

D = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A.001(d)(ii) above if not eligible for Market Revenue Neutrality Offset.

(e) [Reserved for future use]

(f) For each operating hour, the sum of the Non-Synchronized Reserve lost opportunity cost credits credited in subsection (b)(iii) above shall be allocated and charged to each Market Participant that does not meet its hourly Non-Synchronized Reserve Obligation in proportion to its real-time purchases of Non-Synchronized Reserve in megawatt-hours during that hour.

(g) The magnitude of response to a Non-Synchronized Reserve Event by a generation resource is the difference between the generation resource's output at the start of the event and its output 10 minutes after the start of the event. In order to allow for small fluctuations and possible telemetry delays, generation resource output at the start of the event is defined as the lowest telemetered generator resource output between one minute prior to and one minute following the start of the event. Similarly, a generation resource's output 10 minutes after the start of the event is defined as the greatest generator resource output achieved between 9 and 11 minutes after the start of the event. The response actually credited to a generation resource will be reduced by the amount the megawatt output of the generation resource falls below the level achieved after 10 minutes by either the end of the event or after 30 minutes from the start of the event, whichever is shorter.

(h) In the event a generation resource that has been assigned by the Office of the Interconnection to provide Non-Synchronized Reserve fails to provide the assigned amount of Non-Synchronized Reserve in response to a Non-Synchronized Reserve Event, the resource will be credited for Non-Synchronized Reserve capacity in the amount that actually responded for the contiguous Real-time Settlement Interval the resource was assigned Non-Synchronized Reserve during which the event occurred.

3.2.3A.01 Secondary Reserve.

(a) Each Market Participant that is a Load Serving Entity shall have an obligation for hourly Secondary Reserve equal to its pro rata share of Secondary Reserve assigned for the hour for each Reserve Zone and Reserve Sub-zone of the PJM Region, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than

zero) in such Reserve Zone and Reserve Sub-zone for the hour (“Secondary Reserve Obligation”). A Market Participant’s hourly Secondary Reserve Obligation shall be adjusted by any Secondary Reserve provided on the Market Participant’s behalf through a bilateral agreement. A Market Participant with an hourly Secondary Reserve Obligation shall be charged the pro rata share of the sum of day-ahead and real-time credits for Secondary Reserve as defined in sections 3.2.3A.01(b)(i) and (ii) below.

(b) Resources assigned to provide Secondary Reserve at the direction of the Office of the Interconnection shall be credited as follows:

(i) Credits for Secondary Reserve provided by generation resources and Economic Load Response Participant resources assigned to provide Secondary Reserve by the Office of the Interconnection in the Day-ahead Secondary Reserve Market shall be equal to the product of the Day-ahead Secondary Reserve Market Clearing Price multiplied by the megawatt amount of Secondary Reserve such resource is scheduled to provide.

(ii) Credits for Secondary Reserve provided by generation resources and Economic Load Response Participant resources scheduled to provide Secondary Reserve by the Office of the Interconnection in the Real-time Secondary Reserve Market shall be determined for each operating hour based on the sum of their hourly total of Real-time Settlement Interval deviations determined in accordance with the following equation:

$$\sum_i ((A - B) * C)$$

Where:

i = the Real-time Settlement Intervals in the applicable operating hour;

A = For each Real-time Settlement Interval, the megawatts of Secondary Reserve from that resource assigned by the Office of the Interconnection in the Real-time Secondary Reserve Market. The megawatt value is capped at the lesser of the Economic Maximum or Secondary Reserve maximum MW minus the Revenue Data for Settlements of the resource for each Real-time Settlement Interval minus the Real-time Synchronized Reserve assignment;

B = For each Real-time Settlement Interval, the megawatts of Secondary Reserve from that resource scheduled by the Office of the Interconnection in the Day-ahead Secondary Reserve Market; and

C = For each Real-time Settlement Interval, the Real-time Secondary Reserve Market Clearing Price.

(iii) Pool-scheduled resources and Economic Load Response Participant resources shall be credited a Secondary Reserve lost opportunity cost credit, where positive, as described in subsection (f)(iv) below.

(c) [Reserved for future use]

(d) Secondary Reserve Market Clearing Prices

(i) For the Day-ahead Secondary Reserve Market, the Secondary Reserve Market Clearing Price shall be determined for each Reserve Zone and, as applicable, Reserve Sub-zone by the Office of the Interconnection for each hour of the Operating Day. The Day-ahead Secondary Reserve Market Clearing Price shall be calculated as the price of serving the next increment of demand for 30-minute Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Secondary Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Secondary Reserve established in accordance with Tariff, Attachment K-Appendix, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus the price of serving the next increment of demand for 30-minute Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute, but the Secondary Reserve Market Clearing Price shall not exceed the Reserve Penalty Factor for the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.10.8(d), Day-ahead Secondary Reserve Market Clearing Prices shall be set to zero dollars per megawatt-hour and for purposes of settlements for such Operating Day, the Office of the Interconnection shall utilize a scheduled megawatt quantity and Day-ahead Secondary Reserve Market Clearing Price of zero dollars per megawatt-hour and all settlements will be based on the Real-time Secondary Reserve market quantities and prices as determined pursuant to subsection (d)(ii) hereof.

(ii) For the Real-time Secondary Reserve Market, the Secondary Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection for each Real-time Settlement Interval of the Operating Day. Each 5-minute clearing price shall be calculated as the price of serving the next increment of demand for 30-minute Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Secondary Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Secondary Reserve established in accordance with Tariff, Attachment K-Appendix, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus the price of serving the next increment of demand for 30-minute Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute but the Secondary Reserve Market Clearing Price shall not exceed the Reserve Penalty Factor for the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, as per Operating

Agreement, Schedule 1, section 2.5.2, and the Office of the Interconnection is not assigning Secondary Reserves, then the Secondary Reserve Clearing Price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, where the real-time Market Suspension is less than or equal to six (6) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Secondary Reserves, then the Secondary Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Secondary Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than six (6) consecutive hours but less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are cleared Day-ahead Secondary Reserve Market Clearing Prices for the affected Operating Day, then the Real-time Secondary Reserve Market Clearing Prices associated with such Market Suspension shall be the Day-ahead Secondary Reserve Market Clearing Prices for each corresponding hour. If no such Day-ahead Secondary Reserve Market Clearing Prices exist, then the Secondary Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Secondary Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than twenty-four (24) consecutive hours, and the Office of the Interconnection is assigning Secondary Reserves, the Secondary Reserve Market Clearing Price will be set to zero dollars per megawatt-hour. Resources will be compensated for lost opportunity cost per subsection (f) hereof using the energy price as determined in Operating Agreement, Schedule 1, section 2.5.2.iii.

If the Office of the Interconnection has initiated in a Reserve Zone or Reserve Sub-zone either a Voltage Reduction Action or a Manual Load Dump Action as described in the PJM Manuals, the Real-time Secondary Reserve Market Clearing Price for a given Reserve Zone or Sub-zone shall be the Reserve Penalty Factor for the 30-minute Reserve Requirements for that Reserve Zone or Reserve Sub-zone.

(iii) The Reserve Penalty Factor for the 30-minute Reserve Requirement shall be \$850/MWh.

The Reserve Penalty Factor for the Extended 30-minute Reserve Requirement shall be \$300/MWh.

(iv) By no later than April 30 of each year, the Office of the Interconnection will analyze Market Participants' response to prices exceeding \$1,000/MWh on an annual basis and will provide its analysis to PJM stakeholders. The Office of the Interconnection will also review this analysis to determine whether any changes to the

Reserve Penalty Factor for 30-minute Reserve are warranted for subsequent Delivery Year(s).

(e) (i) For determining the Secondary Reserve Market Clearing Price for each hour in the Day-ahead Secondary Reserve Market, the estimated resource-specific opportunity cost for a generation resource or Economic Load Response Participant resources shall be the difference between the Locational Marginal Price at the generation or Economic Load Response Participant resource bus and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) or offer price to reduce energy from the Economic Load Response Participant resource in the PJM Interchange Energy Market when the Locational Marginal Price at the Economic Load Response Participant resource bus is greater than the offer price for energy from the generation resource or the offer price to reduce energy from the Economic Load Response Participant resource.

However, opportunity costs shall be zero for resources self-scheduled to provide Synchronized Reserve, and for synchronous condensers and for Economic Load Response Participant resources that do not receive a day-ahead commitment to provide energy in the same operating hour in which such resource is committed to provide Secondary Reserve.

(ii) For determining the Secondary Reserve Market Clearing Price for each Real-time Settlement Interval in the Real-time Secondary Reserve Market, the estimated unit-specific opportunity cost for a generation resource that is not a hydroelectric resource shall be the difference between the Locational Marginal Price at the generation bus for the generation resource and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) in the PJM Interchange Energy Market when the Locational Marginal Price at the generation bus is greater than the offer price for energy from the generation resource.

For hydroelectric resources, the estimated unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the expected real-time Locational Marginal Price at that generation bus. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the expected real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average day-ahead Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

However, the opportunity costs shall be zero for resources self-scheduled to provide Synchronized Reserve, and for synchronous condensers and Economic Load Response Participant resources.

(f) (i) In determining the credit under subsection (b) to a generation resource, except a generation resource that is a synchronous condenser, selected to provide Secondary Reserve in the Day-ahead Secondary Reserve Market or an Economic Load Response Participant resource that is selected to provide Secondary Reserve in the Day-ahead Secondary Reserve Market in the same operating hour in which such resource receives a day-ahead commitment to provide energy, the opportunity cost of a resource shall be determined for each operating hour that the Office of the Interconnection requires a resource to provide Secondary Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Day-ahead Locational Marginal Price at the generation bus of the generation resource or the applicable pricing point for the Economic Load Response Participant resource;

B= The deviation of the resource's energy output or load reduction necessary to supply a Day-ahead Secondary Reserve assignment from the resource's expected energy output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load less any Day-ahead Synchronized Reserve Market assignment; and

C = The Day-ahead Energy Market offer integrated under the applicable energy offer curve for the resource's energy output or load reduction necessary to provide a Day-ahead Secondary Reserve Market assignment from the resource's expected energy output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load less any Day-ahead Synchronized Reserve Market assignment.

For a generation resource that is a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: [energy use for providing synchronous condensing multiplied by A] plus [the applicable condense start-up cost divided by the number of hours the resource is assigned Secondary Reserve].

(ii) In determining the credit under subsection (b) to a generation resource, except a generation that is a synchronous condenser, selected to provide Secondary Reserve in the Real-time Secondary Reserve Market in excess of the resource's Day-ahead Secondary Reserve Market assignment and that actively follows the Office of the Interconnection's signals and instructions, the unit-specific opportunity cost of that generation resource shall be determined for each Real-time Settlement Interval that the

Office of the Interconnection requires that generation resource to provide Secondary Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Real-time Locational Marginal Price at the generation bus of the generation resource;

B= The deviation of the generation resource's output necessary to supply Secondary Reserve in real-time in excess of its Day-ahead Secondary Reserve Market assignment and follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy less any Real-time Synchronized Reserve Market assignment; and

C = The energy offer integrated under the applicable energy offer curve for the generation resource's output necessary to supply Secondary Reserve in real-time from the lesser of the generation resource's output necessary to provide a Day-ahead Secondary Reserve Market assignment or follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy less any Real-time Synchronized Reserve Market assignment.

For hydroelectric resources, the unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the real-time Locational Marginal Price at that generation bus multiplied by the additional megawatts assigned to supply Synchronized Reserve in real-time in excess of its Day-ahead Secondary Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average real-time Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating multiplied by the additional megawatts assigned to supply Secondary Reserve in real-time in excess of its Day-ahead Secondary Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

For a generation resource that is a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: additional energy use in excess of day-ahead energy use for providing synchronous condensing in real-time multiplied by A plus [any applicable condense start-up costs due to additional condense start-ups in real-time in excess of day-ahead condense start-ups allocated to each Real-time Settlement Interval as described in PJM Manuals]. If the generation resource is operating as a synchronous condenser and also has a Real-time Synchronized Reserve assignment, resource's unit-specific opportunity cost in the Secondary Reserve Market shall be zero,

(iii) For each Real-time Settlement Interval, a total Market Revenue Neutrality Offset is calculated for each resource, if eligible. If there is a decrease in real-time reserve MW from a day-ahead market assignment in more than one market for that real-time settlement interval, the total Market Revenue Neutrality Offset is allocated to the Secondary Reserve market based on the ratio of the opportunity cost owed due to a reduction in assignment in real-time within the Secondary Reserve market and the total opportunity cost owed due to a reduction in assignment in real-time from all reserve markets, not to exceed the resource's opportunity cost owed in the Secondary Reserve market.

A resource is not eligible for Market Revenue Neutrality Offset for Secondary Reserve in a Real-time Settlement Interval for any of the following conditions:

(A) A resource's real-time Secondary Reserve assignment decreases due to the resource being self-scheduled to provide energy, Synchronized Reserve, or Regulation;

(B) A resource reduces flexibility in real-time such that the resource no longer qualifies to provide Secondary Reserve in real-time;

(C) A resource's Final Offer is less than its Committed Offer;

(D) A resource trips offline or otherwise becomes unavailable in real-time;

(E) A resource does not follow dispatch as described in section 3.2.3(o) above and section 3.2.3(o-1) above; or

(F) A resource that fails to come online and reach Economic Minimum output within 30 minutes as described in section 3.2.3A.01(h)(i) below.

(iv) A Secondary Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:

$$(A + B) - (C + D + E + F)$$

Where:

A = day-ahead opportunity cost as determined in subsection (f)(i) above;

B = real-time opportunity cost as determined in subsection (f)(ii) above;

C = day-ahead clearing price credits as determined in subsection (b)(i) above;

D = real-time clearing price credits as determined subsection (b)(ii) above;

E = the applicable Market Revenue Neutrality Offset as determined in subsection (f)(iii) above; and

F = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A.01(f)(iii) above if not eligible for Market Revenue Neutrality Offset.

(v) The opportunity costs for Economic Load Response Participant resources and generation resources not synchronized to the grid shall be zero, except that Economic Load Response Participant resources may have a day-ahead opportunity cost, as determined in subsection (f)(i) above.

(g) For each operating hour, the sum of the Secondary Reserve lost opportunity cost credits credited in accordance with subsection (b)(iii) above shall be allocated and charged to each Market Participant that does not meet its hourly Secondary Reserve Obligation in proportion to its real-time purchases of Secondary Reserve in megawatt-hours during that hour.

(h) (i) In the event an offline generation resource has been assigned by the Office of the Interconnection to provide Secondary Reserve in real-time and is subsequently dispatched by the Office of the Interconnection to supply energy during that Operating Day and the resource qualifies as a Secondary Reserve resource at the time it is dispatched to provide energy, the Office of the Interconnection will assess the resource's performance as follows:

For each generation resource that fails to come online and reach Economic Minimum output within 30 minutes as instructed by the Office of the Interconnection, the resource's Real-time Secondary Reserve assignment will be set to zero megawatts for that interval and for all prior intervals in which the resource was assigned to provide Secondary Reserve in the Real-time Secondary Reserve Market starting at the later of (A) the last interval the resource was online or (B) the beginning of that Operating Day and continuing up to the interval the resource failed to come online. This results in the resource buying back the day-ahead assignment at the Real-time Secondary Reserve Market Clearing Price, or if solely assigned in real-time not being paid for the assigned MW.

(ii) In the event an Economic Load Response Participant resource has been assigned by the Office of the Interconnection to provide Secondary Reserve in real-time and is subsequently dispatched to supply the Secondary Reserve assignment as a load reduction, the Office of the Interconnection will assess the resource's performance as follows:

For the purposes of this subsection, a resource's starting MW usage shall be the greatest telemetered consumption between one minute prior to and one minute following the issuance of a dispatch instruction from the Office of the Interconnection, and a resource's ending MW usage shall be the lowest consumption between 29 and 31 minutes after the issuance of a dispatch instruction from the Office of the Interconnection.

For each Economic Load Response Participant resource that fails to reduce load by at least the Economic Minimum, where the measured response is the difference between the resource's starting MW usage and the resource's ending MW usage as described above, within 30 minutes as instructed by the Office of the Interconnection, the resource's Real-time Secondary Reserve assignment will be set to zero megawatts for that interval, and for all prior intervals in which the resource was assigned to provide Secondary Reserve in the Real-time Secondary Reserve Market between such non-performance event starting at the later of (A) the last interval the resource reduced load at the instruction of the Office of the Interconnection or (B) the beginning of that Operating Day, and for all subsequent intervals through the earlier of (C) the next interval in which the resource is dispatched to reduce load or (D) the end of the Operating Day. This results in the resource buying back the day-ahead assignment at the Real-time Secondary Reserve Market Clearing Price, or if solely assigned in real-time, refunding all payments due for Secondary Reserve during such period.

(iii) For Batch Load Economic Load Response Participant Resources, a second method of verification will be used for instances where a Secondary Reserve assignment dispatched as an energy load reduction is initiated and the resource is operating at the minimum consumption level of its duty cycle. In this case, the magnitude of the response will be measured as the difference between (A) the minimum of the resource's consumption between the minute before and the minute after the end of the last settlement interval the resource reduced load at the instruction of the Office of the Interconnection and (B) the maximum consumption within a ten (10) minute period following the end of the last settlement interval the resource reduced load provided that all subsequent minutes following that minute are no less than 50% of the consumption in that minute.

For each Batch Load Economic Load Response Participant Resource that fails to reduce load by at least the Economic Minimum, where the measured response is the difference between the resource's starting MW usage and the resource's ending MW usage as described in section (ii) above or the difference between (A) and (B) as described in section (iii) above, within 30 minutes as instructed by the Office of the Interconnection, the resource's Real-time Secondary Reserve assignment will be set to zero megawatts for that interval, and for all prior intervals in which the resource was

assigned to provide Secondary Reserve in either the Day-ahead or Real-time Secondary Reserve Markets between such non-performance event starting at the later of (A) the last interval the resource reduced load at the instruction of the Office of the Interconnection or (B) the beginning of that Operating Day, and for all subsequent intervals through the earlier of (C) the next interval in which the resource is dispatched to reduce load or (D) the end of the Operating Day. This results in the resource buying back the day-ahead assignment at the Real-time Secondary Reserve Market Clearing Price, or if solely assigned in real-time, refunding all payments due for Secondary Reserve during such period.

3.2.3A.02 Operating Reserve Demand Curves

The Office of the Interconnection shall establish Operating Reserve Demand Curves for clearing 30-minute Reserve, Primary Reserve, and Synchronized Reserve, for, as applicable, each Reserve Zone or Reserve Sub-zone to procure sufficient reserves to meet, as applicable, (a) 30-minute Reserve Requirement and Extended 30-minute Reserve Requirement; (b) Primary Reserve Requirement and Extended Primary Reserve Requirement; and (c) Synchronized Reserve Requirement and Extended Synchronized Reserve Requirement. The Operating Reserve Demand Curves established for each reserve type shall be used to commit such reserves in both the day-ahead and real-time reserve markets. The Operating Reserve Demand Curves shall be determined in accordance with the applicable Reserve Penalty Factors and PJM Manuals.

3.2.3B Reactive Services.

(a) A Market Seller providing Reactive Services at the direction of the Office of the Interconnection shall be credited as specified below for the operation of its resource. These provisions are intended to provide payments to generating units when the LMP dispatch algorithms would not result in the dispatch needed for the required reactive service. LMP will be used to compensate generators that are subject to redispatch for reactive transfer limits.

(b) At the end of each Operating Day, where the active energy output of a Market Seller's resource is reduced or suspended at the request of the Office of the Interconnection for the purpose of maintaining reactive reliability within the PJM Region, the Market Seller shall be credited according to sections 3.2.3B(c) & 3.2.3B(d).

(c) A Market Seller providing Reactive Services from either a steam-electric generating unit or combined cycle unit operating in combined cycle mode, where such unit is pool-scheduled (or self-scheduled, if operating according to Tariff, Attachment K-Appendix, section 1.10.3 (c) hereof), and where the real time LMP at the unit's bus is higher than the price offered by the Market Seller for energy from the unit at the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override) shall be compensated for lost opportunity cost by receiving a credit for each Real-time Settlement Interval in an amount equal to the product of (A) the deviation of the generating unit's output necessary to follow the Office of the Interconnection's signals and the generating unit's expected output level if it had been dispatched in economic merit order, times

(B) the Real-time Price at the generation bus for the generating unit, minus (C) the Total Lost Opportunity Cost Offer, provided that the resulting outcome is greater than \$0.00. This equation is represented as $(A*B) - C$.

(d) A Market Seller providing Reactive Services from either a combustion turbine unit or combined cycle unit operating in simple cycle mode that is pool scheduled (or self-scheduled, if operating according to Tariff, Attachment K-Appendix, section 1.10.3 (c) hereof), operated as requested by the Office of the Interconnection, shall be compensated for lost opportunity cost for each Real-time Settlement Interval, limited to the lesser of the unit's Economic Maximum or the unit's Generation Resource Maximum Output, if the unit output is reduced at the direction of the Office of the Interconnection and the real time LMP at the unit's bus is higher than the price offered by the Market Seller for energy from the unit at the level of output requested by the Office of the Interconnection as directed by the PJM dispatcher, then the Market Seller shall be credited in a manner consistent with that described above in section 3.2.3B(c) for a steam unit or a combined cycle unit operating in combined cycle mode.

(e) At the end of each Operating Day, where the active energy output of a Market Seller's unit is increased at the request of the Office of the Interconnection for the purpose of maintaining reactive reliability within the PJM Region and the offered price of the energy is above the real-time LMP at the unit's bus, the Market Seller shall be credited according to section 3.2.3B(f).

(f) A Market Seller providing Reactive Services from either a steam-electric generating unit, combined cycle unit or combustion turbine unit, where such unit is pool scheduled (or self-scheduled, if operating according to Tariff, Attachment K-Appendix, section 1.10.3 (c) hereof), and where the real time LMP at the unit's bus is lower than the price offered by the Market Seller for energy from the unit at the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override), shall receive a credit in an amount equal to $\{(AG - LMPDMW) \times (UB - URTLMP)\}$ where:

AG equals the actual output of the unit;

LMPDMW equals the level of output for the unit determined according to the point on the scheduled offer curve on which the unit was operating corresponding to the real time LMP at the unit's bus and adjusted for any Regulation or Tier 2 Synchronized Reserve assignments;

UB equals the unit offer for that unit for which output is increased, determined according to the lesser of the Final Offer or Committed Offer;

URLTMP equals the real time LMP at the unit's bus; and

where $UB - URTLMP$ shall not be negative.

(g) A Market Seller providing Reactive Services from a hydroelectric resource where such resource is pool scheduled (or self-scheduled, if operating according to Tariff, Attachment K-Appendix, section 1.10.3 (c) hereof), and where the output of such resource is altered from the schedule submitted by the Market Seller for the purpose of maintaining reactive reliability at the request of the Office of the Interconnection, shall be compensated for lost opportunity cost in the same manner as provided in sections 3.2.2(d) and 3.2.3A(f) and further detailed in the PJM Manuals.

(h) If a Market Seller believes that, due to specific pre-existing binding commitments to which it is a party, and that properly should be recognized for purposes of this section, the above calculations do not accurately compensate the Market Seller for lost opportunity cost associated with following the Office of the Interconnection's dispatch instructions to reduce or suspend a unit's output for the purpose of maintaining reactive reliability, then the Office of the Interconnection, the Market Monitoring Unit and the individual Market Seller will discuss a mutually acceptable, modified amount of such alternate lost opportunity cost compensation, taking into account the specific circumstances binding on the Market Seller. Following such discussion, if the Office of the Interconnection accepts a modified amount of alternate lost opportunity cost compensation, the Office of the Interconnection shall invoice the Market Participant accordingly. If the Market Monitoring Unit disagrees with the modified amount of alternate lost opportunity cost compensation, as accepted by the Office of the Interconnection, it will exercise its powers to inform the Commission staff of its concerns.

(i) The amount of Synchronized Reserve provided by generating units maintaining reactive reliability shall be counted as Synchronized Reserve satisfying the overall PJM Synchronized Reserve requirements. Operators of these generating units shall be notified of such provision, and to the extent a generating unit's operator indicates that the generating unit is capable of providing Synchronized Reserve, shall be subject to the same requirements contained in section 3.2.3A regarding provision of Synchronized Reserve. At the end of each Operating Day, to the extent a condenser operated to provide Reactive Services also provided Synchronized Reserve, a Market Seller shall be credited for providing synchronous condensing for the purpose of maintaining reactive reliability at the request of the Office of the Interconnection, in an amount equal to the higher of (i) the Synchronized Reserve Market Clearing Price for each Real-time Settlement Interval a generating unit provided synchronous condensing multiplied by the amount of Synchronized reserve provided by the synchronous condenser or (ii) the sum of (A) the generating unit's cost to provide synchronous condensing, calculated in accordance with the PJM Manuals, (B) the product of MW energy usage for providing synchronous condensing multiplied by the real time LMP at the generating unit's bus, (C) the generating unit's startup-cost of providing synchronous condensing, and (D) the unit-specific lost opportunity cost of the generating resource supplying the increment of Synchronized Reserve as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals. To the extent a condenser operated to provide Reactive Services was not also providing Synchronized Reserve, the Market Seller shall be credited only for the generating unit's cost to condense, as described in (ii) above. The total Synchronized Reserve Obligations of all Load Serving Entities under section 3.2.3A(a) in the zone where these condensers are located shall be reduced by the amount counted as satisfying the PJM Synchronized Reserve requirements. The Synchronized Reserve Obligation of each Load Serving Entity in the zone under section

3.2.3A(a) shall be reduced to the same extent that the costs of such condensers counted as Synchronized Reserve are allocated to such Load Serving Entity pursuant to subsection (l) below.

(j) A Market Seller's pool scheduled steam-electric generating unit or combined cycle unit operating in combined cycle mode, that is not committed to operate in the Day-ahead Market, but that is directed by the Office of the Interconnection to operate solely for the purpose of maintaining reactive reliability, at the request of the Office of the Interconnection, shall be credited in the amount of the unit's offered price for start-up and no-load fees. The unit also shall receive, if applicable, compensation in accordance with Sections 3.2.3B(e)-(f).

(k) The sum of the foregoing credits as specified in Sections 3.2.3B(b)-(j) shall be the cost of Reactive Services for the purpose of maintaining reactive reliability for the Operating Day and shall be separately determined for each transmission zone in the PJM Region based on whether the resource was dispatched for the purpose of maintaining reactive reliability in such transmission zone.

(l) The cost of Reactive Services for the purpose of maintaining reactive reliability in a transmission zone in the PJM Region for each Operating Day shall be allocated and charged to each Market Participant in proportion to its deliveries of energy to load (net of operating Behind The Meter Generation) in such transmission zone, served under Network Transmission Service, in megawatt-hours during that Operating Day, as compared to all such deliveries for all Market Participants in such transmission zone.

(m) Generating units receiving dispatch instructions from the Office of the Interconnection under the expectation of increased actual or reserve reactive shall inform the Office of the Interconnection dispatcher if the requested reactive capability is not achievable. Should the operator of a unit receiving such instructions realize at any time during which said instruction is effective that the unit is not, or likely would not be able to, provide the requested amount of reactive support, the operator shall as soon as practicable inform the Office of the Interconnection dispatcher of the unit's inability, or expected inability, to provide the required reactive support, so that the associated dispatch instruction may be cancelled. PJM Performance Compliance personnel will audit operations after-the-fact to determine whether a unit that has altered its active power output at the request of the Office of the Interconnection has provided the actual reactive support or the reactive reserve capability requested by the Office of the Interconnection. PJM shall utilize data including, but not limited to, historical reactive performance and stated reactive capability curves in order to make this determination, and may withhold such compensation as described above if reactive support as requested by the Office of the Interconnection was not or could not have been provided.

3.2.3C Synchronous Condensing for Post-Contingency Operation.

(a) Under normal circumstances, PJM operates generation out of merit order to control contingency overloads when the flow on the monitored element for loss of the contingent element ("contingency flow") exceeds the long-term emergency rating for that facility, typically a 4-hour or 2-hour rating. At times however, and under certain, specific system conditions, PJM

does not operate generation out of merit order for certain contingency overloads until the contingency flow on the monitored element exceeds the 30-minute rating for that facility (“post-contingency operation”). In conjunction with such operation, when the contingency flow on such element exceeds the long-term emergency rating, PJM operates synchronous condensers in the areas affected by such constraints, to the extent they are available, to provide greater certainty that such resources will be capable of producing energy in sufficient time to reduce the flow on the monitored element below the normal rating should such contingency occur.

(b) The amount of Synchronized Reserve provided by synchronous condensers associated with post-contingency operation shall be counted as Synchronized Reserve satisfying the applicable Synchronized Reserve Requirements. Operators of these generation units shall be notified of such provision, and to the extent a generation unit’s operator indicates that the generation unit is capable of providing Synchronized Reserve, shall be subject to the same requirements contained in section 3.2.3A regarding provision of Synchronized Reserve. At the end of each Operating Day, to the extent a condenser operated in conjunction with post-contingency operation also provided Synchronized Reserve, a Market Seller shall be credited for providing synchronous condensing in conjunction with post-contingency operation at the request of the Office of the Interconnection, in an amount equal to the higher of (i) the Real-time Synchronized Reserve Market Clearing Price for each applicable interval a generation resource provided synchronous condensing multiplied by the amount of Synchronized Reserve provided by the synchronous condenser or (ii) the sum of (A) the generation resource’s applicable interval cost to provide synchronous condensing, calculated in accordance with the PJM Manuals, (B) the applicable interval product of the megawatts of energy used to provide synchronous condensing multiplied by the real-time LMP at the generation bus of the generation resource, (C) the generation resource’s start-up cost of providing synchronous condensing, and (D) the unit-specific lost opportunity cost of the generation resource supplying the increment of Synchronized Reserve as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals. To the extent a condenser operated in association with post-contingency constraint control was not also providing Synchronized Reserve, the Market Seller shall be credited only for the generation unit’s cost to condense, as described in (ii) above. The total Synchronized Reserve Obligations of all Load Serving Entities under section 3.2.3A(a) in the zone where these condensers are located shall be reduced by the amount counted as satisfying the PJM Synchronized Reserve requirements. The Synchronized Reserve Obligation of each Load Serving Entity in the zone under section 3.2.3A(a) shall be reduced to the same extent that the costs of such condensers counted as Synchronized Reserve are allocated to such Load Serving Entity pursuant to subsection (d) below.

(c) The sum of the foregoing credits as specified in section 3.2.3C(b) shall be the cost of synchronous condensers associated with post-contingency operations for the Operating Day and shall be separately determined for each transmission zone in the PJM Region based on whether the resource was dispatched in association with post-contingency operation in such transmission zone.

(d) The cost of synchronous condensers associated with post-contingency operations in a transmission zone in the PJM Region for each Operating Day shall be allocated and charged to each Market Participant in proportion to its deliveries of energy to load (net of operating

Behind The Meter Generation) in such transmission zone, served under Network Transmission Service, in megawatt-hours during that Operating Day, as compared to all such deliveries for all Market Participants in such transmission zone.

3.2.4 Transmission Congestion Charges.

Each Market Buyer shall be assessed Transmission Congestion Charges as specified in Tariff, Attachment K-Appendix, section 5.

3.2.5 Transmission Loss Charges.

Each Market Buyer shall be assessed Transmission Loss Charges as specified in Tariff, Attachment K-Appendix, section 5.

3.2.6 Emergency Energy.

(a) When the Office of the Interconnection has implemented Emergency procedures, resources offering Emergency energy are eligible to set real-time Locational Marginal Prices, capped at the energy offer cap plus sum of the applicable Reserve Penalty Factors for the Synchronized Reserved Requirement and Primary Reserve Requirement, provided that the Emergency energy is needed to meet demand in the PJM Region.

(b) Market Participants shall be allocated a proportionate share of the net cost of Emergency energy purchased by the Office of the Interconnection. Such allocated share during each applicable interval of such Emergency energy purchase shall be in proportion to the amount of each Market Participant's real-time deviation from its net withdrawals and injections in the Day-ahead Energy Market, whenever that deviation increases the Market Participant's spot market purchases or decreases its spot market sales. This deviation shall not include any reduction or suspension of output of pool scheduled resources requested by PJM to manage an Emergency within the PJM Region.

(c) Net revenues in excess of Real-time Prices attributable to sales of energy in connection with Emergencies to other Control Areas shall be credited to Market Participants during each applicable interval of such Emergency energy sale in proportion to the sum of (i) each Market Participant's real-time deviation from its net withdrawals and injections in the Day-ahead Energy Market, whenever that deviation increases the Market Participant's spot market purchases or decreases its spot market sales, and (ii) each Market Participant's energy sales from within the PJM Region to entities outside the PJM Region that have been curtailed by PJM.

(d) The net costs or net revenues associated with sales or purchases of energy in connection with a Minimum Generation Emergency in the PJM Region, or in another Control Area, shall be allocated during each applicable interval of such Emergency sale or purchase to each Market Participant in proportion to the amount of each Market Participant's real-time deviation from its net withdrawals and injections in the Day-ahead Market, whenever that deviation increases the Market Participant's spot market sales or decreases its spot market purchases.

3.2.7 Billing.

(a) PJMSettlement shall prepare a billing statement each billing cycle for each Market Participant in accordance with the charges and credits specified in Tariff, Attachment K-Appendix, sections 3.2.1 through 3.2.6, and showing the net amount to be paid or received by the Market Participant. Billing statements shall provide sufficient detail, as specified in the PJM Manuals, to allow verification of the billing amounts and completion of the Market Participant's internal accounting.

(b) If deliveries to a Market Participant that has PJM Interchange meters in accordance with Operating Agreement, section 14 include amounts delivered for a Market Participant that does not have PJM Interchange meters separate from those of the metered Market Participant, PJMSettlement shall prepare a separate billing statement for the unmetered Market Participant based on the allocation of deliveries agreed upon between the Market Participant and the unmetered Market Participant specified by them to the Office of the Interconnection.

7.1 Auctions of Financial Transmission Rights.

Annual, periodic and long-term auctions to allow Market Participants to acquire or sell Financial Transmission Rights shall be conducted by the Office of the Interconnection in accordance with the provisions of this Section. PJMSettlement shall be the Counterparty to the purchases and sales of Financial Transmission Rights arising from such auctions; provided however, that PJMSettlement shall not be a contracting party to any subsequent bilateral transfer of Financial Transmission Rights between Market Participants. The conversion of an Auction Revenue Right to a Financial Transmission Right pursuant to this section 7 shall not constitute a purchase or sale transaction to which PJMSettlement is a contracting party.

7.1.1 Auction Period and Scope of Auctions.

(a) The periods covered by auctions shall be: (1) the one-year period beginning the month after the final round of an annual auction; and (2) any single calendar month period remaining in the Planning Period. With the exception of FTRs allocated pursuant to Operating Agreement, Schedule 1, section 5.2.2 (e) and the Financial Transmission Rights awarded as a result of the exercise of the conversion option pursuant to Operating Agreement, Schedule 1, section 7.1.1(b), in the annual auction, the Office of the Interconnection, on behalf of PJMSettlement, shall offer for sale the entire Financial Transmission Rights capability for the year in four rounds with 25 percent of the capability offered in each round. In the monthly auction, the Office of the Interconnection, on behalf of PJMSettlement, shall offer for sale in the auction any remaining Financial Transmission Rights capability for the months remaining in the Planning Period after taking into account all of the Financial Transmission Rights already outstanding at the time of the auction. In addition, any holder of a Financial Transmission Right for the period covered by an auction may offer such Financial Transmission Right for sale in such auction. Weekend on-peak, weekday on-peak, off-peak and 24-hour Financial Transmission Rights, as those products are described in Tariff, Attachment K-Appendix, section 7.3.4, will be offered in the annual and monthly auctions. FTRs will be offered as Financial Transmission Right Obligations and Financial Transmission Right Options, provided that such Financial Transmission Right Obligations and Financial Transmission Right Options shall be awarded based only on the residual system capability that remains after the allocation of Financial Transmission Rights pursuant to Operating Agreement, Schedule 1, section 5.2.2(e) and the award of Financial Transmission Rights pursuant to Operating Agreement, Schedule 1, section 7.1.1(b). Market Participants may bid for and acquire any number of Financial Transmission Rights, provided that all Financial Transmission Rights awarded are simultaneously feasible with each other and with all Financial Transmission Rights outstanding at the time of the auction and not sold into the auction. An ARR holder may self-schedule an FTR on the same path in the Annual FTR auction according to the rules described in the PJM Manuals.

(b) An Auction Revenue Rights holder may convert Auction Revenue Rights to Financial Transmission Rights, and such conversion shall not be considered a purchase or sale of Financial Transmission Rights in the auction. Such Financial Transmission Rights must (i) have the same source and sink points as the Auction Revenue Rights; and (ii) be Financial Transmission Right Obligations. The Auction Revenue Rights holder must inform the Office of the Interconnection

in accordance with the procedures established by the Office of the Interconnection that it intends to exercise the conversion option prior to close of round one of the annual Financial Transmission Rights auction. Once the conversion option is exercised, it will remain in effect for the entire Financial Transmission Rights auction. The Office of the Interconnection will designate twenty-five percent of the megawatt amount of the Auction Revenue Rights to be converted as price-taker bids in each of the four rounds of the Financial Transmission Rights auction. An Auction Revenue Rights holder that converts its Auction Revenue Rights may not designate a price bid for its converted Financial Transmission Rights and will receive a price equal to the clearing price set by other bids in the annual Financial Transmission Right auction. To the extent a market participant seeks to obtain FTRs in the annual auction through such conversion, the FTRs sought will not be included in the calculation of such market participant's credit requirement for such annual FTR auction.

7.1.2 Frequency and Time of Auctions.

Subject to Operating Agreement, Schedule 1, section 7.1.1, annual Financial Transmission Rights auctions shall offer the entire FTR capability of the PJM system in four rounds with 25 percent of the capability offered in each round. All four rounds of the annual Financial Transmission Rights auction shall occur within the two-month period (April – May) preceding the start of the PJM Planning Period. Each round shall occur over five Business Days and shall be conducted sequentially. Each round shall begin with the ~~bidding and offer~~ period. The ~~bidding and offer~~ period for annual Financial Transmission Rights auctions shall be open for three consecutive Business Days, opening the first day at 12:00 midnight (Eastern Prevailing Time) and closing the third day at 5:00 p.m. (Eastern Prevailing Time), subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e). Monthly Financial Transmission Rights auctions shall be held each month. The ~~bidding and offer~~ period for monthly Financial Transmission Rights auctions shall be open for three consecutive Business Days in the month preceding the first month for which Financial Transmission Rights are being auctioned, opening the first day at 12:00 midnight (Eastern Prevailing Time) and closing the third day at 5:00 p.m. (Eastern Prevailing Time), subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e).

7.1.3 Duration of Financial Transmission Rights.

Each Financial Transmission Right acquired in a Financial Transmission Rights auction shall entitle the holder to credits of Day-ahead Energy Market Transmission Congestion Charges for the period that was specified in the corresponding auction.

7.1A Long-Term Financial Transmission Rights Auctions.

7.1A.1 Auctions.

(i) Subsequent to each annual Financial Transmission Rights auction conducted pursuant to Operating Agreement, Schedule 1, section 7.1, the Office of the Interconnection shall conduct a long-term Financial Transmission Rights auction for the three consecutive Planning Periods immediately subsequent to the Planning Period during which the long-term Financial Transmission Rights auction is conducted. PJMSettlement shall be the Counterparty to the purchases and sales of Financial Transmission Rights arising from such long-term Financial Transmission Rights auctions, provided however, that PJMSettlement shall not be a contracting party to any subsequent bilateral transfers of Financial Transmission Rights between Market Participants. The conversion of an Auction Revenue Right to a Financial Transmission Right pursuant to this section 7 shall not constitute a purchase or sale transaction to which PJMSettlement is a contracting party.

(ii) The capacity offered for sale in long-term Financial Transmission Rights auctions shall be the residual system capability after the annual Auction Revenue Rights allocations and the annual Financial Transmission Rights auction. In determining the residual capability the Office of the Interconnection shall assume that all Auction Revenue Rights allocated in the immediately prior annual Auction Revenue Rights allocation process, including Auction Revenue Rights made available in which transmission facilities which were modeled out of service in the annual Auction Revenue Rights allocations return to service, are self-scheduled into Financial Transmission Rights, which shall be modeled as fixed injections and withdrawals in the long-term Financial Transmission Rights auction. Additionally, residual annual Auction Revenue Rights that become available through incremental capability created by future transmission upgrades as further described in the PJM Manuals shall be modeled as fixed injections and withdrawals in the long-term Financial Transmission Rights auction. The long-term Financial Transmission Rights auction model shall include all upgrades planned to be placed into service on or before June 30th of the first Planning Period within the three year period covered by the auction. The transmission upgrades to be modeled for this purpose shall only include those upgrades that, individually, or together, have 10% or more impact on the transmission congestion on an individual constraint or constraints with congestion of \$5 million or more affecting a common congestion path. Transmission upgrades modeled for this purpose also will be modeled in the subsequent long-term Financial Transmission Rights auction, as further detailed in the PJM Manuals. Residual Auction Revenue Rights created by an increase in transmission capability due to future transmission upgrades, as specified above, are determined only for modeling purposes and will not be allocated to Market Participants.

7.1A.2 Frequency and Timing.

The long-term Financial Transmission Rights auction process shall consist of five rounds. The first round shall be conducted by the Office of the Interconnection approximately 11 months prior to the start of the three Planning Period term covered by the relevant long-term Financial Transmission Rights auction. The second round shall be conducted approximately 2 months

after the first round. The third round shall be conducted approximately 2 months after the second round. The fourth round shall be conducted approximately 2 months after the third round, and the fifth round shall be conducted approximately 3 months after the fourth round. In each round 20 percent of total capacity available in the long-term Financial Transmission Rights auction shall be offered for sale. Eligible entities may submit bids to purchase and offers to sell Financial Transmission Rights at the start of the bidding period in each round. The bidding period shall be three Business Days ending at 5:00 p.m. on the last day, subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e). PJM performs the Financial Transmission Rights auction clearing analysis for each round and posts the auction results on the market user interface within five Business Days after the close of the bidding period for each round unless circumstances beyond PJM's control prevent PJM from meeting the applicable deadline. Under such circumstances, PJM will post the auction results at the earliest possible opportunity. If the Office of the Interconnection discovers a potential error in the results posted for a long-term Financial Transmission Rights auction, the Office of the Interconnection shall notify Market Participants as soon as possible after it is found, but in no event later than 5:00 p.m. of the Business Day immediately following the initial publication of the results for that auction. After this initial notification, if the Office of the Interconnection determines it is necessary to post modified auction results, it shall provide notification of its intent to do so, along with a description detailing the cause and scope of the error, by no later than 5:00 p.m. of the second Business Day following the initial publication of prices for that auction. The provided description will not contain information that is market sensitive or confidential. Thereafter, the Office of the Interconnection must post the corrected prices by no later than 5:00 p.m. of the fourth calendar day following the initial publication of prices in the auction. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced auction results are under publicly noticed review by the FERC.

7.1A.3 Products.

(i) The periods covered by long-term Financial Transmission Rights auctions shall be any single Planning Period within the three Planning Period term covered by the relevant auction.

(ii) Weekend on-peak, weekday on-peak, off-peak and 24-hour Financial Transmission Rights, as those products are described in Tariff, Attachment K-Appendix, section 7.3.4, shall be offered in long-term Financial Transmission Rights auctions; Financial Transmission Rights options shall not be offered.

7.1A.4 Participation Eligibility.

(i) To participate in long-term Financial Transmission Rights auctions an entity shall be a PJM Member or a PJM Transmission Customer. Eligible entities may submit bids or offers in long-term Financial Transmission Rights auctions, provided they own Financial Transmission Rights offered for sale.

7.1A.5 Specified Receipt and Delivery Points.

The Office of the Interconnection will post a list of available receipt and delivery points for each long-term Financial Transmission Rights auction. Eligible receipt and delivery points in long-term Financial Transmission Rights auctions shall be limited to the posted available hubs, Zones, aggregates, generators, and Interface Pricing Points.

7.3 Auction Procedures.

7.3.1 Role of the Office of the Interconnection.

Financial Transmission Rights auctions shall be conducted by the Office of the Interconnection in accordance with standards and procedures set forth in the PJM Manuals, such standards and procedures to be consistent with the requirements of this Schedule. PJMSettlement shall be the Counterparty to the purchases and sales of Financial Transmission Rights arising from such auctions, provided however, that PJMSettlement shall not be a contracting party to any subsequent bilateral transfers of Financial Transmission Rights between Market Participants. The conversion of an Auction Revenue Right to a Financial Transmission Right pursuant to this section 7 shall not constitute a purchase or sale transaction to which PJMSettlement is a contracting party. Any Financial Transmission Rights auctions conducted to liquidate a defaulting Member's Financial Transmission Rights portfolio shall be conducted by the Office of the Interconnection in accordance with the procedures set forth in section 7.3.9 below, and as may be further described in the PJM Manuals.

7.3.2 Notice of Offer.

A holder of a Financial Transmission Right wishing to offer the Financial Transmission Right for sale shall notify the Office of the Interconnection of any Financial Transmission Rights to be offered. Each Financial Transmission Right sold in an auction shall, at the end of the period for which the Financial Transmission Rights were auctioned, revert to the offering holder or the entity to which the offering holder has transferred such Financial Transmission Right, subject to the term of the Financial Transmission Right itself and to the right of such holder or transferee to offer the Financial Transmission Right in the next or any subsequent auction during the term of the Financial Transmission Right.

7.3.3 Pending Applications for Firm Service.

(a) [Reserved.]

(b) Financial Transmission Rights may be assigned to entities requesting Network Transmission Service or Firm Point-to-Point Transmission Service pursuant to Operating Agreement, Schedule 1, section 5.2.2 (e), and the parallel provisions of Tariff, Attachment K-Appendix, section 5.2.2(e), only if such Financial Transmission Rights are simultaneously feasible with all outstanding Financial Transmission Rights, including Financial Transmission Rights effective for the then-current auction period. If an assignment of Financial Transmission Rights pursuant to a pending application for Network Transmission Service or Firm Point-to-Point Transmission Service cannot be completed prior to an auction, Financial Transmission Rights attributable to such transmission service shall not be assigned for the then-current auction period. If a Financial Transmission Right cannot be assigned for this reason, the applicant may withdraw its application, or request that the Financial Transmission Right be assigned effective with the start of the next auction period.

7.3.4 Weekend On-Peak, Weekday On-Peak, Off-Peak and 24-Hour Periods.

Weekend on-peak, weekday on-peak, off-peak and 24-hour Financial Transmission Rights will be offered in the annual, long-term, and monthly auctions. Weekend on-peak Financial Transmission Rights shall cover the periods from 7:00 a.m. up to the hour ending 11:00 p.m. on Saturdays, Sundays, and holidays as defined in the PJM Manuals. Weekday on-peak Financial Transmission Rights shall cover the periods from 7:00 a.m. up to the hour ending at 11:00 p.m. on Mondays through Fridays, except holidays as defined in the PJM Manuals. Off-Peak Financial Transmission Rights shall cover the periods from 11:00 p.m. up to the hour ending 7:00 a.m. on all days. The 24-hour period shall cover the period from hour ending 1:00 a.m. to the hour ending 12:00 midnight on all days. Each bid shall specify whether it is for a weekend on-peak, weekday on-peak, off-peak, or 24-hour period.

7.3.5 Offers and Bids.

(a) Offers to sell and bids to purchase Financial Transmission Rights shall be submitted during the period set forth in Operating Agreement, Schedule 1, section 7.1.2, and the parallel provisions of Tariff, Attachment K-Appendix, section 7.1.2, and shall be in the form specified by the Office of the Interconnection in accordance with the requirements set forth below.

(b) Offers to sell shall identify the specific Financial Transmission Right, by term, megawatt quantity and receipt and delivery points, offered for sale. An offer to sell a specified megawatt quantity of Financial Transmission Rights shall constitute an offer to sell a quantity of Financial Transmission Rights equal to or less than the specified quantity. An offer to sell may not specify a minimum quantity being offered. Each offer may specify a reservation price, below which the offeror does not wish to sell the Financial Transmission Right. Offers submitted by entities holding rights to Financial Transmission Rights shall be subject to such reasonable standards for the verification of the rights of the offeror as may be established by the Office of the Interconnection. Offers shall be subject to such reasonable standards for the creditworthiness of the offeror or for the posting of security for performance as the Office of the Interconnection shall establish.

(c) Bids to purchase shall specify the term, megawatt quantity, price per megawatt, and receipt and delivery points of the Financial Transmission Right that the bidder wishes to purchase. A bid to purchase a specified megawatt quantity of Financial Transmission Rights shall constitute a bid to purchase a quantity of Financial Transmission Rights equal to or less than the specified quantity. A bid to purchase may not specify a minimum quantity that the bidder wishes to purchase. A bid may specify receipt and delivery points in accordance with Operating Agreement, Schedule 1, section 7.2.2, and the parallel provisions of Tariff, Attachment K-Appendix, section 7.2.2, and may include Financial Transmission Rights for which the associated Transmission Congestion Credits may have negative values. Bids shall be subject to such reasonable standards for the creditworthiness of the bidder or for the posting of security for performance as the Office of the Interconnection shall establish.

(d) Bids and offers shall be specified to the nearest tenth of a megawatt and shall be greater than zero. The Office of the Interconnection may require that a market participant shall not submit in excess of 5000 bids and offers for any single monthly auction, or for any single round

of the annual auction, when the Office of the Interconnection determines that such limit is required to avoid or mitigate significant system performance problems related to bid/offer volume. Notice of the need to impose such limit shall be provided prior to the start of the bidding period if possible. Where such notice is provided after the start of the bidding period, market participants shall be required within one day to reduce their bids and offers for such auction below 5000, and the bidding period in such cases shall be extended by one day.

(e) In the event of extraordinary circumstances affecting the submission of bids within the bidding period in which the Office of the Interconnection determines it necessary to extend the bidding period, the Office of the Interconnection shall notify Market Participants as soon as possible of the new bidding period ending day and time.

7.3.6 Determination of Winning Bids and Clearing Price.

(a) At the close of each bidding period, the Office of the Interconnection will create a base Financial Transmission Rights power flow model that includes all outstanding Financial Transmission Rights that have been approved and confirmed for any portion of the month for which the auction was conducted and that were not offered for sale in the auction. The base Financial Transmission Rights model also will include estimated uncompensated parallel flows into each interface point of the PJM Region and estimated scheduled transmission outages.

(b) In accordance with the requirements of Operating Agreement, Schedule 1, section 7.5, and the parallel provisions of Tariff, Attachment K-Appendix, section 7.5, and subject to all applicable transmission constraints and reliability requirements, the Office of the Interconnection shall determine the simultaneous feasibility of all outstanding Financial Transmission Rights not offered for sale in the auction and of all Financial Transmission Rights that could be awarded in the auction for which bids were submitted. The winning bids shall be determined from an appropriate linear programming model that, while respecting transmission constraints and the maximum MW quantities of the bids and offers, selects the set of simultaneously feasible Financial Transmission Rights with the highest net total auction value as determined by the bids of buyers and taking into account the reservation prices of the sellers. In the event that there are two or more identical bids for the selected Financial Transmission Rights and there are insufficient Financial Transmission Rights to accommodate all of the identical bids, then each such bidder will receive a pro rata share of the Financial Transmission Rights that can be awarded.

(c) Financial Transmission Rights shall be sold at the market-clearing price for Financial Transmission Rights between specified pairs of receipt and delivery points, as determined by the bid value of the marginal Financial Transmission Right that could not be awarded because it would not be simultaneously feasible. The linear programming model shall determine the clearing prices of all Financial Transmission Rights paths based on the bid value of the marginal Financial Transmission Rights, which are those Financial Transmission Rights with the highest bid values that could not be awarded fully because they were not simultaneously feasible, and based on the flow sensitivities of each Financial Transmission Rights path relative to the marginal Financial Transmission Rights paths flow sensitivities on the binding transmission constraints. Financial Transmission Rights with a zero clearing price will only be awarded if

there is a minimum of one binding constraint in the auction period for which the Financial Transmission Rights path sensitivity is non-zero. Financial Transmission Right Options with a market-clearing price less than one dollar will not be awarded.

7.3.7 Announcement of Winners and Prices.

Within two (2) Business Days after the close of the ~~bidding and offer~~ period for an annual Financial Transmission Rights auction round, and within five (5) Business Days after the close of the ~~bidding and offer~~ period for a monthly Financial Transmission Rights auction, the Office of the Interconnection shall post the winning bidders, the megawatt quantity, the term and the receipt and delivery points for each Financial Transmission Right awarded in the auction and the price at which each Financial Transmission Right was awarded unless circumstances beyond PJM's control prevent PJM from meeting the applicable deadline. Under such circumstances, PJM will post the auction results at the earliest possible opportunity. The Office of the Interconnection shall not disclose the price specified in any bid to purchase or the reservation price specified in any offer to sell. If the Office of the Interconnection discovers an error in the results posted for a Financial Transmission Rights auction (or a given round of the annual Financial Transmission Rights auction), the Office of the Interconnection shall notify Market Participants of the error as soon as possible after it is found, but in no event later than 5:00 p.m. of the Business Day following the initial publication of the results of the auction or round of the annual auction. After this initial notification, if the Office of the Interconnection determines that it is necessary to post modified results, it shall provide notification of its intent to do so, together with all available supporting documentation, by no later than 5:00 p.m. of the second Business Day following the initial publication of the results of that auction or round of the annual auction. Thereafter, the Office of the Interconnection must post any corrected results by no later than 5:00 p.m. of the fourth calendar day following the initial publication of the results of the auction or round of the annual auction. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced auction results are under publicly noticed review by the FERC.

7.3.8 Auction Settlements.

All buyers and sellers of Financial Transmission Rights between the same points of receipt and delivery shall pay PJM Settlement or be paid by PJM Settlement the market-clearing price, as determined in the auction, for such Financial Transmission Rights.

For a Market Suspension where the suspension is greater than twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are no Day-Ahead Prices available for the affected Operating Day, the Financial Transmission Right auction costs would be zero in proportion to the number of hours of the Market Suspension in the Operating Day.

7.3.9 Addressing Defaulting Member's Financial Transmission Rights.

In the event a Member fails to meet creditworthiness requirements or make timely payments when due pursuant to the Operating Agreement or Tariff, the Office of the Interconnection shall,

as soon as practicable after declaring the Member to be in default as provided in Operating Agreement, section 15.1.5, use reasonable efforts to initiate within two applicable auctions the following procedures to settle, liquidate or otherwise resolve each Financial Transmission Rights position held by the defaulting Member:

a) The Office of the Interconnection shall unilaterally terminate all of the defaulting Member's rights with respect to forward Financial Transmission Rights positions as of the date of the Member's default.

b) As to each Financial Transmission Rights position held by the defaulting Member immediately prior to the termination of the defaulting Member's rights under subsection (a) above, the Office of the Interconnection shall determine and execute an appropriate course of action for addressing such Financial Transmission Rights position, based on the specific circumstances of the default as determined by the Office of the Interconnection in exercise of its reasonable judgment, such as (1) liquidating the position by offering it for sale in an upcoming applicable Financial Transmission Rights auction, (2) liquidating the position by offering it for sale in an auction called and scheduled for the specific purpose of liquidating one or more positions held by the defaulting Member ("Special Auction"), (3) allowing the position to go to settlement, or (4) another course of action the Office of the Interconnection determines to be appropriate under the circumstances that is designed to minimize potential losses to PJM Members. The Office of the Interconnection will provide reasonable advance notice to PJM Members of the approach or course of action it has determined to be appropriate prior to implementing that approach or course of action. The Office of the Interconnection is not required to apply a single approach to the defaulting Member's entire Financial Transmission Rights portfolio, and may determine that the appropriate course of action for addressing a defaulting Member's portfolio includes a combination of the above approaches as applied to different positions within the defaulting Member's overall Financial Transmission Rights portfolio.

c) The Office of the Interconnection will seek to minimize the losses to PJM Members associated with settling, liquidating or otherwise resolving the defaulting Member's Financial Transmission Rights portfolio and may base its determination in subsection (b) above on several factors, including but not limited to, the following:

- 1) the Office of the Interconnection's assessment of which approach will provide the greatest degree of protection to the financial integrity of the PJM Markets;
- 2) the size of the defaulting Member's Financial Transmission Rights portfolio, both in absolute terms and relative to overall market volume;
- 3) the term of the Financial Transmission Rights positions held by the defaulting Member as considered for a single position or on a portfolio basis;

- 4) whether liquidation is feasible or not, and on what timeline, due to the cessation or curtailment of trading at PJM for all Financial Transmission Rights or a subset of Financial Transmission Rights positions;
- 5) prevailing market conditions, such as but not limited to market liquidity and volatility; and
- 6) timing of the default and the actions taken to address the default.

d) Special Auctions. The Office of the Interconnection shall administer each Special Auction provided for in subsection (b)(2) above according to the procedures set forth in the Tariff and PJM Manuals for FTR auctions to the extent appropriate in the Office of the Interconnection's sole discretion, and may adopt special rules for each Special Auction to accommodate the unique circumstances underlying the particular default and particular Financial Transmission Rights positions being liquidated, with the terms and conditions of such auction being determined with the goal of facilitating a successful auction in light of the particular positions to be auctioned, the prevailing market conditions for such open positions (including the depth, scope, and nature of participation in such markets), and such other factors as the Office of the Interconnection determines appropriate, including those factors enumerated in subsection (c) above. The Office of the Interconnection shall provide reasonable advance notice to FTR Participants of a Special Auction and the terms and conditions under which it will be conducted.

e) All liquidations made pursuant to subsection (b) above shall be for the account of the defaulting Member (and all amounts owed PJM in respect thereof shall be included in amounts owed by the defaulting Member as part of its default).

f) Notwithstanding subsections 7.3.9(a) and (b) above, the actual net charges or credits resulting from the defaulting Member's Financial Transmission Rights positions for which PJMSettlement acted as counterparty as calculated through the normal settlement processes shall be included in calculating the Default Allocation Assessment charges as described in Operating Agreement, section 15.2.2.

ATTACHMENT Q

CREDIT RISK MANAGEMENT POLICY

I. INTRODUCTION

It is the policy of PJM that prior to an entity participating in any PJM Markets or in order to take Transmission Service, the entity must demonstrate its ability to meet the requirements in this Attachment Q. This Attachment Q also sets forth PJM's authority to deny, reject, or terminate a Participant's right to participate in any PJM Markets in order to protect the PJM Markets and PJM Members from unreasonable credit risk from any Participant's activities. Given the interconnectedness and overlapping of their responsibilities, PJM Interconnection, L.L.C. and PJM Settlement, Inc. are referred to both individually and collectively herein as "PJM."

PURPOSE

PJMSettlement is the counterparty to transactions in the PJM Markets. As a consequence, if a Participant defaults on its obligations under this Attachment Q, or PJM determines a Participant represents unreasonable credit risk to the PJM Markets, and the Participant does not post Collateral, additional Collateral or Restricted Collateral in response to a Collateral Call, the result is that the Participant represents unsecured credit risk to the PJM Markets. For this reason, PJM must have the authority to monitor and manage credit risk on an ongoing basis, and to act promptly to mitigate or reduce any unsecured credit risk, in order to protect the PJM Markets and PJM Members from losses.

This Attachment Q describes requirements for: (1) eligibility to be a Market Participant, (2) establishment and maintenance of credit by Market Participants, and (3) collateral requirements and forms of credit support that will be deemed as acceptable to mitigate risk to any PJM Markets.

This Attachment Q also sets forth (1) PJM's authority to monitor and manage credit risk that a Participant may represent to the PJM Markets and/or PJM membership in general, (2) the basis for establishing limits that will be imposed on a Market Participant in order to minimize risk, and (3) various obligations and requirements the violation of which will result in an Event of Default pursuant to this Attachment Q and the Agreements.

Attachment Q describes the types of data and information PJM will review in order to determine whether an Applicant or Market Participant presents an unreasonable risk to any PJM Markets and/or PJM membership in general, and the steps PJM may take in order to address that risk.

APPLICABILITY

This Attachment Q applies to all Applicants and Market Participants who take Transmission Service under this Tariff, or participate in any PJM Markets or market activities under the Agreements. Notwithstanding anything to the contrary in this Attachment Q, simply taking

transmission service or procuring Ancillary Services via market-based rates does not imply market participation for purposes of applicability of this Attachment Q.

II. RISK EVALUATION PROCESS

PJM will conduct a risk evaluation to determine eligibility to become and/or remain a Market Participant or Guarantor that: (1) assesses the entity's financial strength, risk profile, creditworthiness, and other relevant factors; (2) determines an Unsecured Credit Allowance, if appropriate; (3) determines appropriate levels of Collateral; and (4) evaluates any Credit Support, including Guaranties or Letters of Credit.

A. Initial Risk Evaluation

PJM will perform an initial risk evaluation of each Applicant and/or its Guarantor. As part of the initial risk evaluation, PJM will consider certain Minimum Participation Requirements, assign an Internal Risk Score, establish an Unsecured Credit Allowance if appropriate, and make a determination regarding required levels of Collateral, creditworthiness, credit support, Restricted Collateral and other assurances for participation in certain PJM Markets.

Each Applicant and/or its Guarantor must provide the information set forth below at the time of its initial application pursuant to this Attachment Q and on an ongoing basis in order to remain eligible to participate in any PJM Markets. The same quantitative and qualitative factors will be used to evaluate Participants whether or not they have rated debt.

1. Rating Agency Reports

PJM will review Rating Agency reports from Standard & Poor's, Moody's Investors Service, Fitch Ratings, or other Nationally Recognized Statistical Rating Organization for each Applicant and/or Guarantor. The review will focus on the Applicant's or its Guarantor's senior unsecured debt ratings. If senior unsecured debt ratings are not available, PJM may consider other ratings, including issuer ratings, corporate ratings and/or an implied rating based on an internally derived Internal Credit Score pursuant to section II.A.3 below.

2. Financial Statements and Related Information

Each Applicant and/or its Guarantor must submit, or cause to be submitted, audited financial statements, except as otherwise indicated below, prepared in accordance with United States Generally Accepted Accounting Principles ("US GAAP") or any other format acceptable to PJM for the three (3) fiscal years most recently ended, or the period of existence of the Applicant and/or its Guarantor, if shorter. Applicants and/or their Guarantors must submit, or cause to be submitted, financial statements, which may be unaudited, for each completed fiscal quarter of the current fiscal year. All audited financial statements provided by the Applicant and/or its Guarantor must be audited by an Independent Auditor.

The information should include, but not be limited to, the following:

- (a) If the Applicant and/or its Guarantor has publicly traded securities:
- (i) Annual reports on Form 10-K, together with any amendments thereto;
 - (ii) Quarterly reports on Form 10-Q, together with any amendments thereto;
 - (iii) Form 8-K reports, if any, that have been filed since the most recent Form 10-K;
 - (iv) A summary provided by the Principal responsible, or to be responsible, for PJM Market activity of: (1) the Participant's primary purpose(s) of activity or anticipated activity in the PJM Markets (investment, trading or "hedging or mitigating commercial risks," as such phrase has meaning in the CFTC's regulations regarding the end-user exception to clearing); (2) the experience of the Participant (and its Principals) in managing risks in similar markets, including other organized RTO/ISO markets or on regulated commodity exchanges; and (3) a high level overview of the Participant's intended participation in the PJM Markets.
 - (v) All audited financial statements provided by an Applicant with publicly traded securities and/or its Guarantor with publicly traded securities must be audited by an Independent Auditor that satisfies the requirements set forth in the Sarbanes-Oxley Act of 2002.
- (b) If the Applicant and/or its Guarantor does not have publicly-traded securities:
- (i) Annual Audited Financial Statements or equivalent independently audited financials, and quarterly financial statements, generally found on:
 - Balance Sheets
 - Income Statements
 - Statements of Cash Flows
 - Statements of Stockholder's or Member's Equity or Net Worth;
 - (ii) Notes to Annual Audited Financial Statements, and notes to quarterly financial statements if any, including disclosures of any material changes from the last report;
 - (iii) Disclosure equivalent to a Management's Discussion & Analysis, including an executive overview of operating results and outlook, and compliance with debt covenants and indentures, and off balance sheet arrangements, if any;
 - (iv) Auditor's Report with an unqualified opinion or written letter from auditor containing the opinion whether the annual audited financial statements comply with the US GAAP or any other format acceptable to PJM; and

- (v) A summary provided by the Principal responsible or to be responsible for PJM Market activity of: (1) the Participant’s primary purpose(s) of activity or anticipated activity in the PJM Markets (investment, trading or “hedging or mitigating commercial risks,” as such phrase has meaning in the CFTC’s regulations regarding the end-user exception to clearing); (2) the experience of the Participant (and its Principals) in managing risks in similar markets, including other organized RTO/ISO markets or on regulated commodity exchanges; and (3) a high level overview of the Participant’s intended participation in the PJM Markets.
- (c) If Applicant and/or Guarantor is newly formed, does not yet have three (3) years of audited financials, or does not routinely prepare audited financial statements, PJM may specify other information to allow it to assess the entity’s creditworthiness, including but not limited to:
 - (i) Equivalent financial information traditionally found in:
 - Balance Sheets
 - Income Statements
 - Statements of Cash Flows
 - (ii) Disclosure equivalent to a Management’s Discussion & Analysis, including an executive overview of operating results and outlook, and compliance with debt covenants and indentures, and off balance sheet arrangements, if any; and
 - (iii) A summary provided by the Principal responsible or to be responsible for PJM Market activity of: (1) the Participant’s primary purpose(s) of activity or anticipated activity in the PJM Markets (investment, trading or “hedging or mitigating commercial risks,” as such phrase has meaning in the CFTC’s regulations regarding the end-user exception to clearing); (2) the experience of the Participant (and its Principals) in managing risks in similar markets, including other organized RTO/ISO markets or on regulated commodity exchanges; and (3) a high level overview of the Participant’s intended participation in the PJM Markets.
- (d) During a two year transition period from June 1, 2020 to May 31, 2022, the Applicant or Guarantor may provide a combination of audited financial statements and/or equivalent financial information.

If any of the above information in this section II.A.2 is available on the internet, the Applicant and/or its Guarantor may provide a letter stating where such statements can be located and retrieved by PJM. If an Applicant and/or its Guarantor files Form 10-K, Form 10-Q, or Form 8-K with the SEC, then the Applicant and/or its Guarantor will be deemed to have satisfied the requirement by indicating to PJM where the information in this section II.A.2 can be located on the internet.

If the Applicant and/or its Guarantor fails, for any reason, to provide the information required above in this section II.A.2, PJM has the right to (1) request Collateral and/or Restricted Collateral to cover the amount of risk reasonably associated with the Applicant and/or its Guarantor's expected activity in any PJM Markets, and/or (2) restrict the Applicant from participating in certain PJM Markets, including but not limited to restricting the positions the Applicant (once it becomes a Market Participant) takes in the market.

For certain Applicants and/or their Guarantors, some of the above submittals may not be applicable and alternate requirements for compliant submittals may be specified by PJM. In the credit evaluation of Municipalities and Cooperatives, PJM may also request additional information as part of the initial and ongoing review process and will consider other qualitative factors in determining financial strength and creditworthiness.

3. Credit Rating and Internal Credit Score

PJM will use credit risk scoring methodologies as a tool in determining an Unsecured Credit Allowance for each Applicant and/or its Guarantor. As its source for calculating the Unsecured Credit Allowance, PJM will rely on the ratings from a Rating Agency, if any, on the Applicant's or Guarantor's senior unsecured debt or their issuer ratings or corporate ratings if senior unsecured debt ratings are not available. If there is a split rating between the Rating Agencies, the lower of the ratings shall apply. If no external credit rating is available PJM will utilize its Internal Credit Score in order to calculate the Unsecured Credit Allowance.

The model used to develop the Internal Credit Score will be quantitative, based on financial data found in the income statement, balance sheet, and cash flow statement, and it will be qualitative based on relevant factors that may be internal or external to a particular Applicant and/or its Guarantor.

PJM will employ a framework, as outlined in Tables 1-5 below, based on metrics internal to the Applicant and/or its Guarantor, including capital and leverage, cash flow coverage of fixed obligations, liquidity, profitability, and other qualitative factors. The particular metrics and scoring rules differ according to the Applicant's or Guarantor's line of business and the PJM Markets in which it anticipates participating, in order to account for varying sources and degrees of risk to the PJM Markets and PJM members.

The formulation of each metric will be consistently applied to all Applicants and Guarantors across industries with slight variations based on identifiable differences in entity type, anticipated market activity, and risks to the PJM Markets and PJM members. In instances where the external credit rating is used to calculate the unsecured credit allowance, PJM may also use the Internal Credit Score as an input into determining the overall risk profile of an Applicant and/or its Guarantor.

Table 1. Quantitative Metrics by Line of Business: Leverage and Capital Structure	Investor-Owned Utilities	Municipal Utilities	Co-Operative Utilities	Power Transmission	Merchant Power	Project Developers	Exploration & Production	Financial Institutions	Commodity Trading	Private Equity
Debt / Total Capitalization (%)										
FFO / Debt (%)										
Debt / EBITDA (x)										
Debt / Property, Plant & Equipment (%)										
Retained Earnings / Total Assets (%)										
Debt / Avg Daily Production or Kwh (\$)										
Tangible Net Worth (\$)										
Core Capital / Total Assets (%)										
Risk-Based Capital / RWA (%)										
Tier 1 Capital / RWA (%)										
Equity / Investments (%)										
Debt / Investments (%)										

primary metric secondary metric FFO = Funds From Operations RWA = Risk-Weighted Assets

Table 2. Quantitative Metrics by Line of Business: Fixed Charge Coverage and Funding	Investor-Owned Utilities	Municipal Utilities	Co-Operative Utilities	Power Transmission	Merchant Power	Project Developers	Exploration & Production	Financial Institutions	Commodity Trading	Private Equity
EBIT / Interest Expense (x)										
EBITDA / Interest Expense (x)										
EBITDA / [Interest Exp + CPLTD] (x)										
[FFO + Interest Exp] / Interest Exp (x)										
Loans / Total Deposits (%)										
NPL / Gross Loans (%)										
NPL / [Net Worth + LLR] (%)										
Market Funding / Tangible Bank Assets (%)										

primary metric secondary metric CPLTD = Current Portion of Long-Term Debt EBIT = Earnings Before Interest and Taxes EBITDA = Earnings Before Interest, Taxes, Depreciation and Amortization LLR = Loan Loss Reserves NPL = Non-Performing Loans

Table 3. Quantitative Metrics by Line of Business: Liquidity	Investor- Owned	Municipal Utilities	Co- Operative	Power Transmission Merchant Power	Project Developers	Exploration & Production	Financial Institutions	Commodity Trading	Private Equity
CFFO / Total Debt (x)									
Current Assets / Current Liabilities (x)									
Liquid Assets / Tangible Bank Assets (%)									
Sources / Uses of Funds (x)									
Weighted Avg Maturity of Debt (yrs)									
Floating Rate Debt / Total Debt (%)									

primary metric secondary metric

CFFO = Cash Flow From Operations

Table 4. Quantitative Metrics by Line of Business: Profitability	Investor- Owned	Municipal Utilities	Co- Operative	Power Transmission Merchant Power	Project Developers	Exploration & Production	Financial Institutions	Commodity Trading	Private Equity
Return on Assets (%)									
Return on Equity (%)									
Profit Volatility (%)									
Return on Revenue (%)									
Net Income / Tangible Assets (%)									
Net Profit (\$)									
Net Income / Dividends (x)									

primary metric secondary metric

Table 5. Qualitative Factors: Industry Level	Sample Referenc e Metrics	Investor-Owned Utilities	Municipal Utilities	Co-Operative Utilities	Power Transmission	Merchant Power	Project Developers	Exploration & Production	Financial Institutions	Commodity Trading	Private Equity

Need for PJM Markets to Achieve Business Goals	Rating Agency criteria or other industry analysis	High	High	High	High	Med	Low	Med	Low	Low	N/A
Ability to Grow/Enter Markets other than PJM	Rating Agency criteria or other industry analysis	Very Low	Very Low	Very Low	Very Low	High	High	Med	Med	High	N/A
Other Participants' Ability to Serve Customers	Rating Agency criteria or other industry analysis	Low	Low	Low	Low	Low	Med	Low	Low	High	N/A
Regulation of Participant's Business	RRA regulatory climate scores, S&P BICRA	PUCS	Govt	N/A	FERC PUCS	N/A	N/A	N/A	N/A	N/A	N/A
Primary Purpose of PJM Activity	Investment ("Inv.)/ Trading ("Trade")/ Hedging or Mitigating Commercial Risk of Operations ("CRH")	CRH	CRH	CRH	CRH/Trade	CRH/Trade	CRH/Trade	CRH/Trade	Inv./Trade	Inv./Trade	Inv./Trade

RRA = Regulatory Research Associates, a division of S&P Global, Inc. BICRA = Bank Industry Country Risk Assessment

The scores developed will range from 1-6, with the following mappings:

- 1 = Very Low Risk (S&P/Fitch: AAA to AA-; Moody's: Aaa to Aa3)
- 2 = Low Risk (S&P/Fitch: A+ to BBB+; Moody's: A1 to Baa1)
- 3 = Low to Medium Risk (S&P/Fitch: BBB; Moody's: Baa2)
- 4 = Medium Risk (S&P/Fitch: BBB-; Moody's: Baa3)
- 5 = Medium to High Risk (S&P/Fitch: BB+ to BB; Moody's Ba1 to Ba2)
- 6 = High Risk (S&P/Fitch: BB- and below; Moody's: Ba3 and below)

4. Trade References

If deemed necessary by PJM, whether because the Applicant is newly or recently formed or for any other reason, each Applicant and/or its Guarantor shall provide at least one (1) bank reference and three (3) Trade References to provide PJM with evidence of Applicant's understanding of the markets in which the Applicant is seeking to participate and the Applicant's experience and ability to manage risk. PJM may contact the bank references and Trade References provided by the Applicant to verify their business experience with the Applicant.

5. Litigation and Contingencies

Unless prohibited by law, each Applicant and Guarantor is also required to disclose and provide information as to the occurrence of, within the five (5) years prior to the submission of the information to PJM (i) any litigation, arbitration, investigation (formal inquiry initiated by a governmental or regulatory entity), or proceeding, pending or, to the knowledge of the involving, Applicant or its Guarantor or any of their Principals that would likely have a material adverse impact on its financial condition and/or would likely materially affect the risk of non-payment by the Applicant or Guarantor, or (ii) any finding of material defalcation, market manipulation or fraud by or involving the Applicant, Guarantor, or any of their Principals, predecessors, subsidiaries, or Credit Affiliates that participate in any United States power markets based upon a final adjudication of regulatory and/or legal proceedings, (iii) any bankruptcy declarations or petitions by or against an Applicant and/or Guarantor, or (iv) any violation by any of the foregoing of any federal or state regulations or laws regarding energy commodities, U.S. Commodity Futures Trading Commission ("CFTC") or FERC requirements, the rules of any exchange monitored by the National Futures Association, any self-regulatory organization or any other governing, regulatory, or standards body responsible for regulating activity in North American markets for electricity, natural gas or electricity-related commodity products. Each Applicant and Guarantor shall take reasonable measures to obtain permission to disclose information related to a non-public investigation. These disclosures shall be made by Applicant and Guarantor upon application, and within ten (10) Business Days of any material change with respect to any of the above matters.

6. History of Defaults in Energy Projects

Each Applicant and Guarantor shall disclose their current default status and default history for any energy related generation or transmission project (e.g. generation, solar, development), and within any wholesale or retail energy market, including but not limited to within PJM, any Independent System Operator or Regional Transmission Organization, and exchange that has not been cured within the past five (5) years. Defaults of a non-recourse project financed entity may not be included in the default history.

7. Other Disclosures and Additional Information

Each Applicant and Guarantor is required to disclose any Credit Affiliates that are currently Members of PJM, applying for membership with PJM, Transmission Customers, Participants, applying to become Market Participants, or that participate directly or indirectly in any PJM Markets or any other North American markets for electricity, natural gas or electricity-related commodity products. Each Applicant and Guarantor shall also provide a copy of its limited

liability company agreement or equivalent agreement, certification of formation, articles of incorporation or other similar organization document, offering memo or equivalent, the names of its five (5) most senior Principals, and information pertaining to any non-compliance with debt covenants and indentures.

Applicants shall provide PJM the credit application referenced in section III.A and any other information or documentation reasonably required for PJM to perform the initial risk evaluation of Applicant's or Guarantor's creditworthiness and ability to comply with the requirements contained in the Agreements related to settlements, billing, credit requirements, and other financial matters.

B. Supplemental Risk Evaluation Process

As described in section VI below, PJM will conduct a supplemental risk evaluation process for Applicants, Participants, and Guarantors applying to conduct virtual and export transactions or participate in any PJM Markets.

C. Unsecured Credit Allowance

A Market Participant may request that PJM consider it for an Unsecured Credit Allowance pursuant to the provisions herein. Notwithstanding the foregoing, an FTR Participant shall not be considered for an Unsecured Credit Allowance for participation in the FTR markets.

1. Unsecured Credit Allowance Evaluation

PJM will perform a credit evaluation on each Participant that has requested an Unsecured Credit Allowance, both initially and at least annually thereafter. PJM shall determine the amount of Unsecured Credit Allowance, if any, that can be provided to the Market Participant in accordance with the creditworthiness and other requirements set forth in this Attachment Q. In completing the credit evaluation, PJM will consider:

(a) Rating Agency Reports

PJM will review Rating Agency reports as for each Market Participant on the same basis as described in section II.A.1 above and section II.E.1 below.

(b) Financial Statements and Related Information

All financial statements and related information considered for an Unsecured Credit Allowance must satisfy all of the same requirements described in section II.A.2 above and section II.E.2 below.

2. Material Adverse Changes

Each Market Participant is responsible for informing PJM, in writing, of any Material Adverse Change in its financial condition (or the financial condition of its Guarantor) since the date of the Market Participant or Guarantor's most recent annual financial statements provided to PJM, pursuant to the requirements reflected in section II.A.2 above and section II.E.3 below.

In the event that PJM determines that a Material Adverse Change in the financial condition of a Market Participant warrants a requirement to provide Collateral, additional Collateral or Restricted Collateral, PJM shall comply with the process and requirements described in section II.A above and section II.E below.

3. Other Disclosures

Each Market Participant desiring an Unsecured Credit Allowance is required to make the disclosures and upon the same requirements reflected in section II.A.7 above and section II.E.7 below.

D. Determination of Unreasonable Credit Risk

Unreasonable credit risk shall be determined by the likelihood that an Applicant will default on a financial obligation arising from its participation in any PJM Markets. Indicators of potentially unreasonable credit risk include, but are not limited to, a history of market manipulation based upon a final adjudication of regulatory and/or legal proceedings, a history of financial defaults, a history of bankruptcy or insolvency within the past five (5) years, or a combination of current market and financial risk factors such as low capitalization, a reasonably likely future material financial liability, a low Internal Credit Score (derived pursuant to section II.A.3 above) and/or a low externally derived credit score. PJM's determination will be based on, but not limited to, information and material provided to PJM during its initial risk evaluation process, information and material provided to PJM in the Officer's Certification, and/or information gleaned by PJM from public and non-public sources.

If PJM determines that an Applicant poses an unreasonable credit risk to the PJM Markets, PJM may require Collateral, additional Collateral, or Restricted Collateral commensurate with the Applicant's risk of financial default, reject an application, and/or limit or deny Applicant's participation in the PJM Markets, to the extent and for the time period it determines is necessary to mitigate the unreasonable credit risk to the PJM Markets. PJM will reject an application if it determines that Collateral, additional Collateral, or Restricted Collateral cannot address the risk.

PJM will communicate its concerns regarding whether the Applicant presents an unreasonable credit risk, if any, in writing to the Applicant and attempt to better understand the circumstances surrounding that Applicant's financial and credit position before making its determination. In the event PJM determines that an Applicant presents an unreasonable credit risk that warrants a requirement to provide Collateral of any type, or some action to mitigate risk, PJM shall provide the Applicant with a written explanation of why such determination was made.

E. Ongoing Risk Evaluation

In addition to the initial risk evaluation set forth in sections II.A through II.D above and the annual certification requirements set forth in section III.A below, each Market Participant and/or its Guarantor has an ongoing obligation to provide PJM with the information required in section IV.A described in more detail below. PJM may also review public information regarding a

Market Participant and/or its Guarantor as part of its ongoing risk evaluation. If appropriate, PJM will revise the Market Participant's Unsecured Credit Allowance and/or change its determination of creditworthiness, credit support, Restricted Collateral, required Collateral or other assurances pursuant to PJM's ongoing risk evaluation process.

Each Market Participant and/or its Guarantor must provide the information set forth below on an ongoing basis in order to remain eligible to participate in any PJM Markets. The same quantitative and qualitative factors will be used to evaluate Market Participants whether or not they have rated debt.

1. Rating Agency Reports

PJM will review Rating Agency reports for each Market Participant and/or Guarantor on the same basis as described in section II.A.1 above.

2. Financial Statements and Related Information

On an ongoing basis, Market Participants and/or their Guarantors shall provide the information they are required to provide as described in section II.A.2 above, pursuant to the schedule reflected below, with one exception. With regard to the summary that is required to be provided by the Principal responsible for PJM Market activity, with respect to experience of the Participant or its Principals in managing risks in similar markets, the Principal only needs to provide that information for a new Principal that was not serving in the position when the prior summary was provided. PJM will review financial statements and related information for each Market Participant and/or Guarantor on the same basis as described in section II.A.2 above.

Each Market Participant and/or its Guarantor must submit, or cause to be submitted, annual audited financial statements, except as otherwise indicated below, prepared in accordance with US GAAP or any other format acceptable to PJM for the fiscal year most recently ended within ten (10) calendar days of the financial statements becoming available and no later than one hundred twenty (120) calendar days after its fiscal year end. Market Participants and/or their Guarantors must submit, or cause to be submitted, financial statements, which may be unaudited, for each completed fiscal quarter of the current fiscal year, promptly upon their issuance, but no later than sixty (60) calendar days after the end of each fiscal quarter. All audited financial statements provided by the Market Participant and/or its Guarantor must be audited by an Independent Auditor.

Notwithstanding the foregoing, PJM may upon request, grant a Market Participant or Guarantor an extension of time, if the financials are not available within the time frame stated above.

3. Material Adverse Changes

Each Market Participant and each Guarantor is responsible for informing PJM, in writing, of any Material Adverse Change in its or its Guarantor's financial condition within five (5) Business Days of any Principal becoming aware of the occurrence of a Material Adverse Change since the date of the Market Participant or Guarantor's most recent annual financial statements provided to

PJM. However, PJM may also independently establish from available information that a Participant and/or its Guarantor has experienced a Material Adverse Change in its financial condition without regard to whether such Market Participant or Guarantor has informed PJM of the same.

For the purposes of this Attachment Q, a Material Adverse Change in financial condition may include, but is not be limited to, any of the following:

- (a) a bankruptcy filing;
- (b) insolvency;
- (c) a significant decrease in market capitalization;
- (d) restatement of prior financial statements unless required due to regulatory changes;
- (e) the resignation or removal of a Principal unless there is a new Principal appointed or expected to be appointed, a transition plan in place pending the appointment of a new Principal, or a planned restructuring of such roles;
- (f) the filing of a lawsuit or initiation of an arbitration, investigation, or other proceeding that would likely have a material adverse effect on any current or future financial results or financial condition or increase the likelihood of non-payment;
- (g) a material financial default in any other organized energy, ancillary service, financial transmission rights and/or capacity markets including but not limited to those of another Regional Transmission Organization or Independent System Operator, or on any commodity exchange, futures exchange or clearing house, that has not been cured or remedied after any required notice has been given and any cure period has elapsed;
- (h) a revocation of a license or other authority by any Federal or State regulatory agency; where such license or authority is necessary or important to the Participant's continued business, for example, FERC market-based rate authority, or State license to serve retail load;
- (i) a significant change in credit default swap spreads, market capitalization, or other market-based risk measurement criteria, such as a recent increase in Moody's KMV Expected Default Frequency (EDFtm) that is materially greater than the increase in its peers' EDFtm rates, or a collateral default swap (CDS) premium normally associated with an entity rated lower than investment grade;
- (j) a confirmed, undisputed material financial default in a bilateral arrangement with another Participant or counterparty that has not been cured or remedied after any required notice has been given and any cure period has elapsed;
- (k) the sale by a Participant of all or substantially all of its bilateral position(s) in the PJM Markets;
- (l) any adverse changes in financial condition which, individually, or in the aggregate, are material; and,
- (m) any adverse changes, events or occurrences which, individually or in the aggregate, could affect the ability of the entity to pay its debts as they become due or could reasonably be expected to have a material adverse effect on any current or future financial results or financial condition.

Upon identification of a Material Adverse Change, PJM shall evaluate the financial strength and risk profile of the Market Participant and/or its Guarantor at that time and may do so on a more frequent basis going forward. If the result of such evaluation identifies unreasonable credit risk to any PJM Market as further described in section II.E.8 below, PJM will take steps to mitigate the financial exposure to the PJM Markets. These steps include, but are not limited to requiring the Market Participant and/or each Guarantor to provide Collateral, additional Collateral or additional Restricted Collateral that is commensurate with the amount of risk in which the Market Participant wants to engage, and/or limiting the Market Participant's ability to participate in any PJM Market to the extent, and for the time-period necessary to mitigate the unreasonable credit risk. In the event PJM determines that a Material Adverse Change in the financial condition or risk profile of a Market Participant and/or Guarantor, warrants a requirement to provide Collateral of any type, or some action to mitigate risk, PJM shall provide the Market Participant and/or Guarantor, a written explanation of why such determination was made. Conversely, in the event PJM determines there has been an improvement in the financial condition or risk profile of a Market Participant and/or Guarantor such that the amount of Collateral needed for that Market Participant and/or Guarantor can be reduced, PJM shall provide a written explanation why such determination was made, including the amount of the Collateral reduction and indicating when and how the reduction will be made.

4. Litigation and Contingencies

Each Market Participant and/or Guarantor is required to disclose and provide information regarding litigation and contingencies as outlined in section II.A.5 above.

5. History of Defaults in Energy Projects

Each Market Participant and/or Guarantor is required to disclose current default status and default history as outlined in section II.A.6 above.

6. Internal Credit Score

As part of its ongoing risk evaluation, PJM will use credit risk scoring methodologies as a tool in determining an Internal Credit Score for each Market Participant and/or Guarantor, utilizing the same model and framework outlined in section II.A.3 above.

7. Other Disclosures and Additional Information

Each Market Participant and/or Guarantor is required to make other disclosures and provide additional information outlined in section II.A.7 above.

PJM will monitor each Market Participant's use of services and associated financial obligations on a regular basis to determine their total potential financial exposure and for credit monitoring purposes, and may require the Market Participant and/or Guarantor to provide additional information, pursuant to the terms and provisions described herein.

Market Participants shall provide PJM, upon request, any information or documentation reasonably required for PJM to monitor and evaluate a Market Participant's creditworthiness and compliance with the Agreements related to settlements, billing, credit requirements, and other financial matters.

8. Unreasonable Credit Risk

If PJM has reasonable grounds to believe that a Market Participant and/or its Guarantor poses an unreasonable credit risk to any PJM Markets, PJM may immediately notify the Market Participant of such unreasonable credit risk and (1) issue a Collateral Call to demand Collateral, additional Collateral, or Restricted Collateral or other assurances commensurate with the Market Participant's and/or its Guarantor's risk of financial default or other risk posed by the Market Participant's or Guarantor's financial condition or risk profile to the PJM Markets and PJM members, or (2) limit or suspend the Market Participant's participation in any PJM Markets, to the extent and for such time period PJM determines is necessary to mitigate the unreasonable credit risk to any PJM Markets. PJM will only limit or suspend a Market Participant's market participation if Collateral, additional Collateral or Restricted Collateral cannot address the unreasonable credit risk.

PJM's determination will be based on, but not limited to, information and material provided to PJM during its ongoing risk evaluation process or in the Officer's Certification, and/or information gleaned by PJM from public and non-public sources. PJM will communicate its concerns, if any, in writing to the Market Participant and attempt to better understand the circumstances surrounding the Market Participant's financial and credit position before making its determination. At PJM's request or upon its own initiative, the Market Participant or its Guarantor may provide supplemental information to PJM that would allow PJM to consider reducing the additional Collateral requested or reducing the severity of limitations or other restrictions designed to mitigate the Market Participant's credit risk. Such information shall include, but not be limited to: (i) the Market Participant's estimated exposure, (ii) explanations for any recent change in the Market Participant's market activity, (iii) any relevant new load or unit outage information; or (iv) any default or supply contract expiration, termination or suspension.

The Market Participant shall have five (5) Business Days to respond to PJM's request for supplemental information. If the requested information is provided in full to PJM's satisfaction during said period, the additional Collateral requirement shall reflect the Market Participant's anticipated exposure based on the information provided. Notwithstanding the foregoing, any additional Collateral requested by PJM in a Collateral Call must be provided by the Market Participant within the applicable cure period.

In the event PJM determines that an Market Participant and/or its Guarantor presents an unreasonable credit risk, as described above, that warrants a requirement to provide Collateral of any type, or some action to mitigate risk, PJM shall provide the Market Participant with a written explanation of why such final determination was made.

PJM has the right at any time to modify any Unsecured Credit Allowance and/or require additional Collateral as may be deemed reasonably necessary to support current or anticipated market activity as set forth in Tariff, Attachment Q, sections II.A.2 and II.C.1.b. Failure to remit the required amount of additional Collateral within the applicable cure period shall constitute an Event of Default.

F. Collateral and Credit Restrictions

PJM may establish certain restrictions on available credit by requiring that some amounts of credit, i.e. Restricted Collateral, may not be available to satisfy credit requirements. Such designations shall be construed to be applicable to the calculation of credit requirements only, and shall not restrict PJM's ability to apply such designated credit to any obligation(s) in case of a default. Any such Restricted Collateral will be held by PJM, as applicable. Such Restricted Collateral will not be returned to the Participant until PJM has determined that the risk for which such Restricted Collateral is being held has subsided or been resolved.

PJM may post on PJM's web site, and may reference on OASIS, a supplementary document which contains additional business practices (such as algorithms for credit scoring) that are not included in this Attachment Q. Changes to the supplementary document will be subject to stakeholder review and comment prior to implementation. PJM may specify a required compliance date, not less than fifteen (15) calendar days from notification, by which time all Participants and their Guarantors must comply with provisions that have been revised in the supplementary document.

PJM will regularly post each Participant's and/or its Guarantor's credit requirements and credit provisions on the PJM web site in a secure, password-protected location. Each Participant and/or its Guarantor is responsible for monitoring such information, and maintaining sufficient credit to satisfy the credit requirements described herein. Failure to maintain credit sufficient to satisfy the credit requirements of the Attachment Q shall constitute a Credit Breach, and the Participant will be subject to the remedies established herein and in any of the Agreements.

G. Unsecured Credit Allowance Calculation

The external rating from a Rating Agency will be used as the source for calculating the Unsecured Credit Allowance, unless no external credit rating is available in which case PJM will utilize its Internal Credit Score for such purposes. If there is a split rating between the Rating Agencies, the lower of the ratings shall apply.

Where two or more entities, including Participants, are considered Credit Affiliates, Unsecured Credit Allowances will be established for each individual Participant, subject to an aggregate maximum amount for all Credit Affiliates as provided for in Attachment Q, section II.G.3.

In its credit evaluation of Municipalities and Cooperatives, PJM may request additional information as part of the ongoing risk evaluation process and will also consider qualitative factors in determining financial strength and creditworthiness.

1. Credit Rating and Internal Credit Score

As previously described in section II.A.3 above, PJM will determine the Internal Credit Score for an Applicant, Market Participant and/or its Guarantor using the credit risk scoring methodologies contained therein. Internal Credit Scores, ranging from 1-6, for each Applicant, Market Participant and/or its Guarantor, will be determined with the following mappings:

- 1 = Very Low Risk (S&P/Fitch: AAA to AA-; Moody's: Aaa to Aa3)
- 2 = Low Risk (S&P/Fitch: A+ to BBB+; Moody's: A1 to Baa1)
- 3 = Low to Medium Risk (S&P/Fitch: BBB; Moody's: Baa2)
- 4 = Medium Risk (S&P/Fitch: BBB-; Moody's: Baa3)
- 5 = Medium to High Risk (S&P/Fitch: BB+ to BB; Moody's Ba1 to Ba2)
- 6 = High Risk (S&P/Fitch: BB- and below; Moody's: Ba3 and below)

In instances where the external credit rating is used to calculate the unsecured credit allowance, PJM may also use the Internal Credit Score as an input into its determination of the overall risk profile of an Applicant and/or its Guarantor

2. Unsecured Credit Allowance

PJM will determine a Participant's Unsecured Credit Allowance based on its external rating or its Internal Credit Score, as applicable, and the parameters in the table below. The maximum Unsecured Credit Allowance is the lower of:

- (a) A percentage of the Participant's Tangible Net Worth, as stated in the table below, with the percentage based on the Participant's external rating or Internal Credit Score, as applicable; and
- (b) A dollar cap based on the external rating or Internal Credit Score, as applicable, as stated in the table below:

Internal Credit Score	Risk Ranking	Tangible Net Worth Factor	Maximum Unsecured Credit Allowance (\$ Million)
1.00 – 1.99	1 – Very Low (AAA to AA-)	Up to 10.00%	\$50
2.00 – 2.99	2 – Low (A+ to BBB+)	Up to 8.00%	\$42
3.00 – 3.49	3 – Low to Medium (BBB)	Up to 6.00%	\$33
3.50 – 4.49	4 – Medium (BBB-)	Up to 5.00%	\$7
4.50 – 5.49	5 – Medium to High (BB+ to BB)	0%	\$0
> 5.49	6 – High (BB- and below)	0%	\$0

If a Corporate Guaranty is utilized to establish an Unsecured Credit Allowance for a Participant, the value of a Corporate Guaranty will be the lesser of:

- (a) The limit imposed in the Corporate Guaranty;
- (b) The Unsecured Credit Allowance calculated for the Guarantor; and
- (c) A portion of the Unsecured Credit Allowance calculated for the Guarantor in the case of Credit Affiliates.

PJM has the right at any time to modify any Unsecured Credit Allowance and/or require additional Collateral as may be deemed reasonably necessary to support current market activity. Failure to remit the required amount of additional Collateral within the applicable cure period shall be deemed an Event of Default.

PJM will maintain a posting of each Participant's Unsecured Credit Allowance, along with certain other credit related parameters, on the PJM website in a secure, password-protected location. Each Participant will be responsible for monitoring such information and recognizing changes that may occur.

3. Unsecured Credit Limits For Credit Affiliates

If two or more Participants are Credit Affiliates and have requested an Unsecured Credit Allowance, PJM will consider the overall creditworthiness of the Credit Affiliates when determining the Unsecured Credit Allowances in order not to establish more Unsecured Credit for the Credit Affiliates collectively than the overall corporate family could support.

Example: Participants A and B each have a \$10.0 million Corporate Guaranty from their common parent, a holding company with an Unsecured Credit Allowance calculation of \$12.0 million. PJM may limit the Unsecured Credit Allowance for each Participant to \$6.0 million, so the total Unsecured Credit Allowance does not exceed the corporate family total of \$12.0 million.

PJM will work with the Credit Affiliates to allocate the total Unsecured Credit Allowance among the Credit Affiliates while assuring that no individual Participant, nor common guarantor, exceeds the Unsecured Credit Allowance appropriate for its credit strength. The aggregate Unsecured Credit for a Participant, including Unsecured Credit Allowance granted based on its own creditworthiness and risk profile, and any Unsecured Credit Allowance conveyed through a Guaranty shall not exceed \$50 million. The aggregate Unsecured Credit for a Credit Affiliates corporate family shall not exceed \$50 million. A Credit Affiliate corporate family subject to this cap shall request PJM to allocate the maximum Unsecured Credit amongst the corporate family, assuring that no individual Participant or common guarantor, shall exceed the Unsecured Credit level appropriate for its credit strength and activity.

H. Contesting an Unsecured Credit Evaluation

PJM will provide to a Participant, upon request, a written explanation for any determination of or change in Unsecured Credit or credit requirement within ten (10) Business Days of receiving such request.

If a Participant believes that either its level of Unsecured Credit or its credit requirement has been incorrectly determined, according to this Attachment Q, then the Participant may send a request for reconsideration in writing to PJM. Such a request should include:

- (1) A citation to the applicable section(s) of this Attachment Q along with an explanation of how the respective provisions of this Attachment Q were not carried out in the determination as made; and
- (2) A calculation of what the Participant believes should be the appropriate Unsecured Credit or Collateral requirement, according to terms of this Attachment Q.

PJM will provide a written response as promptly as practical, but no more than ten (10) Business Days after receipt of the request. If the Participant still feels that the determination is incorrect, then the Participant may contest that determination. Such contest should be in written form, addressed to PJM, and should contain:

- (1) A complete copy of the Participant's earlier request for reconsideration, including citations and calculations;
- (2) A copy of PJM's written response to its request for reconsideration; and
- (3) An explanation of why it believes that the determination still does not comply with this Attachment Q.

PJM will investigate and will respond to the Participant with a final determination on the matter as promptly as practical, but no more than twenty (20) Business Days after receipt of the request.

Neither requesting reconsideration nor contesting the determination following such request shall relieve or delay Participant's responsibility to comply with all provisions of this Attachment Q, including without limitation posting Collateral, additional Collateral or Restricted Collateral in response to a Collateral Call.

If a Corporate Guaranty is being utilized to establish credit for a Participant, the Guarantor will be evaluated and the Unsecured Credit Allowance granted, if any, based on the financial strength and creditworthiness, and risk profile of the Guarantor. Any utilization of a Corporate Guaranty will only be applicable to non-FTR credit requirements, and will not be applicable to cover FTR credit requirements.

PJM will identify any necessary Collateral requirements and establish a Working Credit Limit for each Participant. Any Unsecured Credit Allowance will only be applicable to non-FTR credit requirements, for positions in PJM Markets other than the FTR market, because all FTR credit requirements must be satisfied by posting Collateral.

III. MINIMUM PARTICIPATION REQUIREMENTS

A Participant seeking to participate in any PJM Markets shall submit to PJM any information or documentation reasonably required for PJM to evaluate its experience and resources. If PJM determines, based on its review of the relevant information and after consultation with the Participant, that the Participant's participation in any PJM Markets presents an unreasonable credit risk, PJM may reject the Participant's application to become a Market Participant, notwithstanding applicant's ability to meet other minimum participation criteria, registration requirements and creditworthiness requirements.

A. Annual Certification

Before they are eligible to transact in any PJM Market, all Applicants shall provide to PJM (i) an executed copy of a credit application and (ii) a copy of the annual certification set forth in Attachment Q, Appendix 1. As a condition to continued eligibility to transact in any PJM Market, Market Participants shall provide to PJM the annual certification set forth in Attachment Q, Appendix 1.

After the initial submission, the annual certification must be submitted each calendar year by all Market Participants between January 1 and April 30. PJM will accept such certifications as a matter of course and the Market Participants will not need further notice from PJM before commencing or maintaining their eligibility to participate in any PJM Markets.

A Market Participant that fails to provide its annual certification by April 30 shall be ineligible to transact in any PJM Markets and PJM will disable the Market Participant's access to any PJM Markets until such time as PJM receives the certification. In addition, failure to provide an executed annual certification in a form acceptable to PJM and by the specified deadlines may result in a default under the Tariff.

Market Participants acknowledge and understand that the annual certification constitutes a representation upon which PJM will rely. Such representation is additionally made under the Tariff, filed with and accepted by FERC, and any false, misleading or incomplete statement knowingly made by the Market Participant and that is material to the Market Participant's ability to perform may be considered a violation of the Tariff and subject the Market Participant to action by FERC. Failure to comply with any of the criteria or requirements listed herein or in the certification may result in suspension or limitation of a Market Participant's transaction rights in any PJM Markets.

Applicants and Market Participants shall submit to PJM, upon request, any information or documentation reasonably and/or legally required to confirm Applicant's or Market Participant's compliance with the Agreements and the annual certification.

B. PJM Market Participation Eligibility Requirements

PJM may conduct periodic verification to confirm that Applicants and Market Participants can demonstrate that they meet the definition of “appropriate person” to further ensure minimum criteria are in place. Such demonstration will consist of the submission of evidence and an executed Annual Officer Certification form as set forth in Attachment Q, Appendix 1 in a form acceptable to PJM. If an Applicant or Market Participant does not provide sufficient evidence for verification to PJM within five (5) Business Days of written request, then such Applicant or Market Participant may result in a default under this Tariff. Demonstration of “appropriate person” status and support of other certifications on the annual certification is one part of the Minimum Participation Requirements for any PJM Markets and does not obviate the need to meet the other Minimum Participation Requirements such as those for minimum capitalization and risk profile as set forth in this Attachment Q.

To be eligible to transact in any PJM Markets, an Applicant or Participant must demonstrate in accordance with the Risk Management and Verification processes set forth below that it qualifies in one of the following ways:

1. an “appropriate person,” as that term is defined under Commodity Exchange Act, section 4(c)(3), or successor provision, or;
2. an “eligible contract participant,” as that term is defined in Commodity Exchange Act, section 1a(18), or successor provision, or;
3. a business entity or person who is in the business of: (1) generating, transmitting, or distributing electric energy, or (2) providing electric energy services that are necessary to support the reliable operation of the transmission system, or;
4. an Applicant or Market Participant seeking eligibility as an “appropriate person” providing an unlimited Corporate Guaranty in a form acceptable to PJM as described in section V below from a Guarantor that has demonstrated it is an “appropriate person,” and has at least \$1 million of total net worth or \$5 million of total assets per Applicant and Market Participant for which the Guarantor has issued an unlimited Corporate Guaranty, or;
5. an Applicant or Market Participant providing a Letter of Credit of at least \$5 million to PJM in a form acceptable to PJM as described in section V below, that the Applicant or Market Participant acknowledges is separate from, and cannot be applied to meet, its credit requirements to PJM, or;
6. an Applicant or Market Participant providing a surety bond of at least \$5 million to PJM in a form acceptable to PJM as described in section V below, that the Applicant or Market Participant acknowledges is separate from, and cannot be applied to meet, its credit requirements to PJM.

If, at any time, a Market Participant cannot meet the eligibility requirements set forth above, it shall immediately notify PJM and immediately cease conducting transactions in any PJM Markets. PJM may terminate a Market Participant’s transaction rights in any PJM Markets if, at

any time, it becomes aware that the Market Participant does not meet the minimum eligibility requirements set forth above.

In the event that a Market Participant is no longer able to demonstrate it meets the minimum eligibility requirements set forth above, and possesses, obtains or has rights to possess or obtain, any open or forward positions in any PJM Markets, PJM may take any such action it deems necessary with respect to such open or forward positions, including, but not limited to, liquidation, transfer, assignment or sale; provided, however, that the Market Participant will, notwithstanding its ineligibility to participate in any PJM Markets, be entitled to any positive market value of those positions, net of any obligations due and owing to PJM.

C. Risk Management and Verification

All Market Participants must maintain current written risk management policies, procedures, or controls to address how market and credit risk is managed, and are required to submit to PJM (at the time they make their annual certification) a copy of their current governing risk control policies, procedures and controls applicable to their market activities. PJM will review such documentation to verify that it appears generally to conform to prudent risk management practices for entities participating in any PJM Markets.

All Market Participants subject to this provision shall make a one-time payment of \$1,500.00 to PJM to cover administrative costs. Thereafter, if such Participant's risk policies, procedures and controls applicable to its market activities change substantively, it shall submit such modified documentation, with applicable administrative charge determined by PJM, to PJM for review and verification at the time it makes its annual certification. All Market Participant's continued eligibility to participate in any PJM Markets is conditioned on PJM notifying a Participant that its annual certification, including the submission of its risk policies, procedures and controls, has been accepted by PJM. PJM may retain outside expertise to perform the review and verification function described in this section, however, in all circumstances, PJM and any third-party it may retain will treat as confidential the documentation provided by a Participant under this section, consistent with the applicable provisions of the Operating Agreement.

Participants must demonstrate that they have implemented prudent risk management policies and procedures in order to be eligible to participate in any PJM Markets. Participants must demonstrate on at least an annual basis that they have implemented and maintained prudent risk management policies and procedures in order to continue to participate in any PJM Markets. Upon written request, the Participant will have fourteen (14) calendar days to provide to PJM current governing risk management policies, procedures, or controls applicable to Participant's activities in any PJM Markets.

D. Capitalization

In advance of certification, Applicants shall meet the minimum capitalization requirements below. In addition to the annual certification requirements in Attachment Q, Appendix 1, a Market Participant shall satisfy the minimum capitalization requirements on an annual basis thereafter. A Participant must demonstrate that it meets the minimum financial requirements

appropriate for the PJM Markets in which it transacts by satisfying either the minimum capitalization or the provision of Collateral requirements listed below:

1. Minimum Capitalization

Minimum capitalization may be met by demonstrating minimum levels of Tangible Net Worth or tangible assets. FTR Participants must demonstrate a Tangible Net Worth in excess of \$1 million or tangible assets in excess of \$10 million. Other Market Participants must demonstrate a Tangible Net Worth in excess of \$500,000 or tangible assets in excess of \$5 million.

(a) Consideration of tangible assets and Tangible Net Worth shall exclude assets which PJM reasonably believes to be restricted, highly risky, or potentially unavailable to settle a claim in the event of default. Examples include, but are not limited to, restricted assets, derivative assets, goodwill, and other intangible assets.

(b) Demonstration of “tangible” assets and Tangible Net Worth may be satisfied through presentation of an acceptable Corporate Guaranty, provided that both:

- (i) the Guarantor is a Credit Affiliate company that satisfies the Tangible Net Worth or tangible assets requirements herein, and;
- (ii) the Corporate Guaranty is either unlimited or at least \$500,000.

If the Corporate Guaranty presented by the Participant to satisfy these capitalization requirements is limited in value, then the Participant’s resulting Unsecured Credit Allowance shall be the lesser of:

- (1) the applicable Unsecured Credit Allowance available to the Participant by the Corporate Guaranty pursuant to the creditworthiness provisions of this Attachment Q, or,
- (2) the face value of the Corporate Guaranty, reduced by \$500,000 and further reduced by 10%. (For example, a \$10.5 million Corporate Guaranty would be reduced first by \$500,000 to \$10 million and then further reduced 10% more to \$9 million. The resulting \$9 million would be the Participant’s Unsecured Credit Allowance available through the Corporate Guaranty).

In the event that a Participant provides Collateral in addition to a limited Corporate Guaranty to increase its available credit, the value of such Collateral shall be reduced by 10%. This reduced value shall be considered the amount available to satisfy requirements of this Attachment Q.

(c) Demonstrations of minimum capitalization (minimum Tangible Net Worth or tangible assets) must be presented in the form of audited financial statements for the Participant's most recent fiscal year during the initial risk evaluation process and ongoing risk evaluation process.

2. Provision of Collateral

If a Participant does not demonstrate compliance with its applicable minimum capitalization requirements above, it may still qualify to participate in any PJM Markets by posting Collateral, additional Collateral, and/or Restricted Collateral, subject to the terms and conditions set forth herein.

Any Collateral provided by a Participant unable to satisfy the minimum capitalization requirements above will also be restricted in the following manner:

- (a) Collateral provided by Market Participants that engage in FTR transactions shall be reduced by an amount of the current risk plus any future risk to any PJM Markets and PJM membership in general, and may coincide with limitations on market participation. The amount of this Restricted Collateral shall not be available to cover any credit requirements from market activity. The remaining value shall be considered the amount available to satisfy requirements of this Attachment Q.
- (b) Collateral provided by other Participants that engage in Virtual Transactions or Export Transactions shall be reduced by \$200,000 and then further reduced by 10%. The amount of this Restricted Collateral shall not be available to cover any credit requirements from market activity. The remaining value shall be considered the amount available to satisfy requirements of this Attachment Q.
- (c) Collateral provided by other Participants that do not engage in Virtual Transactions or Export Transactions shall be reduced by 10%. The amount of this Restricted Collateral shall not be available to cover any credit requirements from market activity. The remaining value shall be considered the amount available to satisfy requirements of this Attachment Q.

In the event a Participant that satisfies the minimum capital requirement through provision of Collateral also provides a Corporate Guaranty to increase its available credit, then the Participant's resulting Unsecured Credit Allowance conveyed through such Corporate Guaranty shall be the lesser of:

- (a) the applicable Unsecured Credit Allowance available to the Participant by the Corporate Guaranty pursuant to the creditworthiness provisions of this Attachment Q; or
- (b) the face value of the Corporate Guaranty, reduced commensurate with the amount of the current risk plus any anticipated future risk to any PJM Markets and PJM membership in general, and may coincide with limitations on market participation.

IV. ONGOING COVENANTS

A. Ongoing Obligation to Provide Information to PJM

So long as a Participant is eligible to participate, or participates or holds positions, in any PJM Markets, it shall deliver to PJM, in form and detail satisfactory to PJM:

- (1) All financial statements and other financial disclosures as required by section II.E.2 by the deadline set forth therein;
- (2) Notice, within five (5) Business Days, of any Principal becoming aware that the Participant does not meet the Minimum Participation Requirements set forth in section III;
- (3) Notice when any Principal becomes aware of any matter that has resulted or would reasonably be expected to result in a Material Adverse Change in the financial condition of the Participant or its Guarantor, if any, a description of such Material Adverse Change in detail reasonable to allow PJM to determine its potential effect on, or any change in, the Participant's risk profile as a participant in any PJM Markets, by the deadline set forth in section II.E.3 above;
- (4) Notice, within the deadline set forth therein, of any Principal becoming aware of a litigation or contingency event described in section II.E.4, or of a Material Adverse Change in any such litigation or contingency event previously disclosed to PJM, information in detail reasonable to allow PJM to determine its potential effect on, or any change in, the Market Participant's risk profile as a participant in any PJM Markets by the deadline set forth therein;
- (5) Notice, within two (2) Business Days after any Principal becomes aware of a Credit Breach, Financial Default, or Credit Support Default, that includes a description of such default or event and the Participant's proposals for addressing the default or event;
- (6) As soon as available but not later than April 30th of any calendar year, the annual Certification described in section III.A in a form set forth in Attachment Q, Appendix 1;
- (7) Concurrently with submission of the annual certification, demonstration that the Participant meets the minimum capitalization requirements set forth in section III.D;
- (8) Concurrently with submission of the annual certification and within the applicable deadline of any substantive change, or within the applicable deadline of a request from PJM, a copy of the Participant's written risk management policies, procedures or controls addressing how the Participant manages market and credit risk in the PJM Markets in which it participates, as well as a high level summary by the chief risk officer or other Principal regarding any material violations, breaches, or compliance or disciplinary actions related to the risk management policies, by the Participant under the policies, procedures or controls within the prior 12 months, as set forth in section VI.B below;
- (9) Within five (5) Business Days of request by PJM, evidence demonstrating the Participant meets the definition of "appropriate person" or "eligible contract participant," as those terms are defined in the Commodity Exchange Act and the CFTC regulations promulgated thereunder, or of any other certification in the annual Certification; or

- (10) Within a reasonable time after PJM requests, any other information or documentation reasonably and/or legally required by PJM to confirm Participant's compliance with the Tariff and its eligibility to participate in any PJM Markets.

Participants acknowledge and understand that the deliveries constitute representations upon which PJM will rely in allowing the Participant to continue to participate in its markets, with the Internal Credit Score and Unsecured Credit Allowance, if any, previously determined by PJM.

B. Risk Management Review

PJM shall also conduct a periodic compliance verification process to review and verify, as applicable, Participants' risk management policies, practices, and procedures pertaining to the Participant's activities in any PJM Markets. PJM shall review such documentation to verify that it appears generally to conform to prudent risk management practices for entities trading in any PJM Markets. Participant shall also provide a high level summary by the chief risk officer or other Principal regarding any material violations, breaches, or compliance or disciplinary actions in connection with such risk management policies, practices and procedures within the prior twelve (12) months.

If a third-party industry association publishes or modifies principles or best practices relating to risk management in North American markets for electricity, natural gas or electricity-related commodity products, PJM may, following stakeholder discussion and with no less than six (6) months prior notice to stakeholders, consider such principles or best practices in evaluating the Participant's risk controls.

PJM will prioritize the verification of risk management policies based on a number of criteria, including but not limited to how long the entity has been in business, the Participant's and its Principals' history of participation in any PJM Markets, and any other information obtained in determining the risk profile of the Participant.

Each Participant's continued eligibility to participate in any PJM Markets is conditioned upon PJM notifying the Participant of successful completion of PJM's verification of the Participant's risk management policies, practices and procedures, as discussed herein. However, if PJM notifies the Participant in writing that it could not successfully complete the verification process, PJM shall allow such Participant fourteen (14) calendar days to provide sufficient evidence for verification prior to declaring the Participant as ineligible to continue to participate in any PJM Markets, which declaration shall be in writing with an explanation of why PJM could not complete the verification. If the Participant does not provide sufficient evidence for verification to PJM within the required cure period, such Participant will be considered in default under this Tariff. PJM may retain outside expertise to perform the review and verification function described in this paragraph. PJM and any third party it may retain will treat as confidential the documentation provided by a Participant under this paragraph, consistent with the applicable provisions of the Agreements. If PJM retains such outside expertise, a Participant may direct in writing that PJM perform the risk management review and verification for such Participant instead of utilizing a third party, provided however, that employees and contract employees of PJM and PJM shall not be considered to be such outside expertise or third parties.

Participants are solely responsible for the positions they take and the obligations they assume in any PJM Markets. PJM hereby disclaims any and all responsibility to any Participant or PJM

Member associated with Participant's submitting or failure to submit its annual certification or PJM's review and verification of a Participant's risk policies, procedures and controls. Such review and verification is limited to demonstrating basic compliance by a Participant showing the existence of written policies, procedures and controls to limit its risk in any PJM Markets and does not constitute an endorsement of the efficacy of such policies, procedures or controls.

V. FORMS OF CREDIT SUPPORT

In order to satisfy their PJM credit requirements Participants may provide credit support in a PJM-approved form and amount pursuant to the guidelines herein, provided that, notwithstanding anything to the contrary in this section, a Market Participant in PJM's FTR markets shall meet its credit support requirements related to those FTR markets with either cash or Letters of Credit.

Unless otherwise restricted by PJM, credit support provided may be used by PJM to secure the payment of Participant's financial obligations under the Agreements.

Collateral which may no longer be required to be maintained under provisions of the Agreements, shall be returned at the request of a Participant, no later than two (2) Business Days following determination by PJM within a commercially reasonable period of time that such Collateral is not required.

Except when an Event of Default has occurred, a Participant may substitute an approved PJM form of Collateral for another PJM approved form of Collateral of equal value.

A. Cash Deposit

Cash provided by a Participant as Collateral will be held in a depository account by PJM. Interest shall accrue to the benefit of the Participant, provided that PJM may require Participants to provide appropriate tax and other information in order to accrue such interest credits.

PJM may establish an array of investment options among which a Participant may choose to invest its cash deposited as Collateral. The depository account shall be held in PJM's name in a banking or financial institution acceptable to PJM. Where practicable, PJM may establish a means for the Participant to communicate directly with the bank or financial institution to permit the Participant to direct certain activity in the PJM account in which its Collateral is held. PJM will establish and publish procedural rules, identifying the investment options and respective discounts in Collateral value that will be taken to reflect any liquidation, market and/or credit risk presented by such investments.

Cash Collateral may not be pledged or in any way encumbered or restricted from full and timely use by PJM in accordance with terms of the Agreements.

PJM has the right to liquidate all or a portion of the Collateral account balance at its discretion to satisfy a Participant's Total Net Obligation to PJM in the Event of Default under this Attachment Q or one or more of the Agreements.

B. Letter of Credit

An unconditional, irrevocable standby Letter of Credit can be utilized to meet the Collateral requirement. As stated below, the form, substance, and provider of the Letter of Credit must all be acceptable to PJM.

- (1) The Letter of Credit will only be accepted from U.S.-based financial institutions or U.S. branches of foreign financial institutions (“financial institutions”) that have a minimum corporate debt rating of “A” by Standard & Poor’s or Fitch Ratings, or “A2” from Moody’s Investors Service, or an equivalent short term rating from one of these agencies. PJM will consider the lowest applicable rating to be the rating of the financial institution. If the rating of a financial institution providing a Letter of Credit is lowered below A/A2 by any Rating Agency, then PJM may require the Participant to provide a Letter of Credit from another financial institution that is rated A/A2 or better, or to provide a cash deposit. If a Letter of Credit is provided from a U.S. branch of a foreign institution, the U.S. branch must itself comply with the terms of this Attachment Q, including having its own acceptable credit rating.
- (2) The Letter of Credit shall state that it shall renew automatically for successive one-year periods, until terminated upon at least ninety (90) calendar days prior written notice from the issuing financial institution. If PJM or PJM receives notice from the issuing financial institution that the current Letter of Credit is being cancelled or expiring, the Participant will be required to provide evidence, acceptable to PJM, that such Letter of Credit will be replaced with appropriate Collateral, effective as of the cancellation date of the Letter of Credit, no later than thirty (30) calendar days before the cancellation date of the Letter of Credit, and no later than ninety (90) calendar days after the notice of cancellation. Failure to do so will constitute a default under this Attachment Q and one or more of the Agreements.
- (3) PJM will post on its web site an acceptable standard form of a Letter of Credit that should be utilized by a Participant choosing to submit a Letter of Credit to establish credit at PJM. If the Letter of Credit varies in any way from the standard format, it must first be reviewed and approved by PJM. All costs associated with obtaining and maintaining a Letter of Credit and meeting the Attachment Q provisions are the responsibility of the Participant.
- (4) PJM may accept a Letter of Credit from a financial institution that does not meet the credit standards of this Attachment Q provided that the Letter of Credit has third-party support, in a form acceptable to PJM, from a financial institution that does meet the credit standards of this Attachment Q.

C. Corporate Guaranty

An irrevocable and unconditional Corporate Guaranty may be utilized to establish an Unsecured Credit Allowance for a Participant. Such credit will be considered a transfer of Unsecured Credit from the Guarantor to the Participant, and will not be considered a form of Collateral.

PJM will post on its web site an acceptable form that should be utilized by a Participant choosing to establish its credit with a Corporate Guaranty. If the Corporate Guaranty varies in any way from the PJM format, it must first be reviewed and approved by PJM before it may be applied to satisfy the Participant's credit requirements.

The Corporate Guaranty must be signed by an officer of the Guarantor, and must demonstrate that it is duly authorized in a manner acceptable to PJM. Such demonstration may include either a corporate seal on the Corporate Guaranty itself, or an accompanying executed and sealed secretary's certificate from the Guarantor's corporate secretary noting that the Guarantor was duly authorized to provide such Corporate Guaranty and that the person signing the Corporate Guaranty is duly authorized, or other manner acceptable to PJM.

PJM will evaluate the creditworthiness of a Guarantor and will establish any Unsecured Credit granted through a Corporate Guaranty using the methodology and requirements established for Participants requesting an Unsecured Credit Allowance as described herein. Foreign Guaranties and Canadian Guaranties shall be subject to additional requirements as established herein. If PJM determines at any time that a Material Adverse Change in the financial condition of the Guarantor has occurred, or if the Corporate Guaranty comes within thirty (30) calendar days of expiring without renewal, PJM may reduce or eliminate any Unsecured Credit afforded to the Participant through the guaranty. Such reduction or elimination may require the Participant to provide Collateral within the applicable cure period. If the Participant fails to provide the required Collateral, the Participant shall be in default under this Attachment Q.

All costs associated with obtaining and maintaining a Corporate Guaranty and meeting the Attachment Q provisions are the responsibility of the Participant.

1. Foreign Guaranties

A Foreign Guaranty is a Corporate Guaranty that is provided by a Credit Affiliate entity that is domiciled in a country other than the United States or Canada. The entity providing a Foreign Guaranty on behalf of a Participant is a Foreign Guarantor. A Participant may provide a Foreign Guaranty in satisfaction of part of its credit obligations or voluntary credit provision at PJM provided that all of the following conditions are met:

PJM reserves the right to deny, reject, or terminate acceptance of any Foreign Guaranty at any time, including for material adverse circumstances or occurrences.

- (a) A Foreign Guaranty:
 - (i) Must contain provisions equivalent to those contained in PJM's standard form of Foreign Guaranty with any modifications subject to review and approval by PJM counsel.
 - (ii) Must be denominated in US currency.
 - (iii) Must be written and executed solely in English, including any duplicate originals.
 - (iv) Will not be accepted towards a Participant's Unsecured Credit Allowance for more than the following limits, depending on the Foreign Guarantor's credit rating:

Rating of Foreign Guarantor	Maximum Accepted Guaranty if Country Rating is AAA	Maximum Accepted Guaranty if Country Rating is AA+
A- and above	USD50,000,000	USD30,000,000
BBB+	USD30,000,000	USD20,000,000
BBB	USD10,000,000	USD10,000,000
BBB- or below	USD 0	USD 0

- (v) May not exceed 50% of the Participant’s total credit, if the Foreign Grantor is rated less than BBB+.
- (b) A Foreign Guarantor:
- (i) Must satisfy all provisions of this Attachment Q applicable to domestic Guarantors.
 - (ii) Must be a Credit Affiliate of the Participant.
 - (iii) Must maintain an agent for acceptance of service of process in the United States; such agent shall be situated in the Commonwealth of Pennsylvania, absent legal constraint.
 - (iv) Must be rated by at least one Rating Agency acceptable to PJM; the credit strength of a Foreign Guarantor may not be determined based on an evaluation of its audited financial statements without an actual credit rating as well.
 - (v) Must have a senior unsecured (or equivalent, in PJM’s sole discretion) rating of BBB (one notch above BBB-) or greater by any and all agencies that provide rating coverage of the entity.
 - (vi) Must provide audited financial statements, in US GAAP format or any other format acceptable to PJM, with clear representation of net worth, intangible assets, and any other information PJM may require in order to determine the entity’s Unsecured Credit Allowance.
 - (vii) Must provide a Secretary’s Certificate from the Participant’s corporate secretary certifying the adoption of Corporate Resolutions:
 1. Authorizing and approving the Guaranty; and
 2. Authorizing the Officers to execute and deliver the Guaranty on behalf of the Guarantor.
 - (viii) Must be domiciled in a country with a minimum long-term sovereign (or equivalent) rating of AA+/Aa1, with the following conditions:
 1. Sovereign ratings must be available from at least two rating agencies acceptable to PJM (e.g. S&P, Moody’s, Fitch, DBRS).
 2. Each agency’s sovereign rating for the domicile will be considered to be the lowest of: country ceiling, senior unsecured government debt, long-term foreign currency sovereign rating, long-term local currency sovereign rating, or other equivalent measures, at PJM’s sole discretion.
 3. Whether ratings are available from two or three agencies, the lowest of the two or three will be used.
 - (ix) Must be domiciled in a country that recognizes and enforces judgments of US courts.

- (x) Must demonstrate financial commitment to activity in the United States as evidenced by one of the following:
 1. American Depository Receipts (ADR) are traded on the New York Stock Exchange, American Stock Exchange, or NASDAQ.
 2. Equity ownership worth over USD 100,000,000 in the wholly-owned or majority owned subsidiaries in the United States.
- (xi) Must satisfy all other applicable provisions of the PJM Tariff and/or Operating Agreement, including this Attachment Q.
- (xii) Must pay for all expenses incurred by PJM related to reviewing and accepting a foreign guaranty beyond nominal in-house credit and legal review.
- (xiii) Must, at its own cost, provide PJM with independent legal opinion from an attorney/solicitor of PJM's choosing and licensed to practice law in the United States and/or Guarantor's domicile, in form and substance acceptable to PJM in its sole discretion, confirming the enforceability of the Foreign Guaranty, the Guarantor's legal authorization to grant the Guaranty, the conformance of the Guaranty, Guarantor, and Guarantor's domicile to all of these requirements, and such other matters as PJM may require in its sole discretion.

2. Canadian Guaranties

The entity providing a Canadian Guaranty on behalf of a Participant is a Canadian Guarantor. A Participant may provide a Canadian Guaranty in satisfaction of part of its credit obligations or voluntary credit provision at PJM provided that all of the following conditions are met.

PJM reserves the right to deny, reject, or terminate acceptance of any Canadian Guaranty at any time for reasonable cause, including material adverse circumstances or occurrences.

- (a) A Canadian Guaranty:
 - (i) Must contain provisions equivalent to those contained in PJM's standard form of Foreign Guaranty with any modifications subject to review and approval by PJM counsel.
 - (ii) Must be denominated in US currency.
 - (iii) Must be written and executed solely in English, including any duplicate originals.
- (b) A Canadian Guarantor:
 - (i) Must be a Credit Affiliate of the Participant.
 - (ii) Must satisfy all provisions of this Attachment Q applicable to domestic Guarantors.
 - (iii) Must maintain an agent for acceptance of service of process in the United States; such agent shall be situated in the Commonwealth of Pennsylvania, absent legal constraint.
 - (iv) Must be rated by at least one Rating Agency acceptable to PJM; the credit strength of a Canadian Guarantor may not be determined based on an evaluation of its audited financial statements without an actual credit rating as well.
 - (v) Must provide audited financial statements, in US GAAP format or any other format acceptable to PJM with clear representation of net worth, intangible assets,

and any other information PJM may require in order to determine the entity's Unsecured Credit Allowance.

- (vi) Must satisfy all other applicable provisions of the PJM Tariff and/or Operating Agreement, including this Attachment Q.

D. Surety Bond

An unconditional, irrevocable surety bond can be utilized to meet the Collateral requirement for Participants. As stated below, the form, substance, and provider of the surety bond must all be acceptable to PJM.

- (i) An acceptable surety bond must be payable immediately upon demand without prior demonstration of the validity of the demand. The surety bond will only be accepted from a U.S. Treasury-listed approved surety that has either (i) a minimum corporate debt rating of “A” by Standard & Poor’s or Fitch Ratings, or “A2” from Moody’s Investors Service, or an equivalent short term rating from one of these agencies, or (ii) a minimum insurer rating of “A” by A.M. Best. PJMSettlement will consider the lowest applicable rating to be the rating of the surety. If the rating of a surety providing a surety bond is lowered below A/A2 by any rating agency, then PJMSettlement may require the Participant to provide a surety bond from another surety that is rated A/A2 or better, or to provide another form of Collateral.
- (ii) The surety bond shall have an initial period of at least one year, and shall state that it shall renew automatically for successive one-year periods, until terminated upon at least ninety (90) days prior written notice from the issuing surety. If PJM receives notice from the issuing surety that the current surety bond is being cancelled, the Participant will be required to provide evidence, acceptable to PJM, that such surety bond will be replaced with appropriate Collateral, effective as of the cancellation date of the surety bond, no later than thirty (30) days before the cancellation date of the surety bond, and no later than ninety (90) days after the notice of cancellation. Failure to do so will constitute a default under this Attachment Q and one of more of the Agreements enabling PJM to immediately demand payment of the full value of the surety bond.
- (iii) PJM will post on its web site an acceptable standard form of a surety bond that should be utilized by a Participant choosing to submit a surety bond to establish credit at PJM. The acceptable standard form of surety bond will include non-negotiable provisions, including but not be limited to, a payment on demand feature, requirement that the bond be construed pursuant to Pennsylvania law, making the surety’s obligation to pay out on the bond absolute and unconditional irrespective of the principal’s (Market Participant’s) bankruptcy, terms of any other agreements, investigation of the Market Participant by any entity or governmental authority, or PJM first attempting to collect payment from the Market Participant, and will require, among other things, that (a) the surety waive **all** rights that would be available to a principal or surety under the law, including

but not limited to any right to investigate or verify any matter related to a demand for payment, rights to set-off amounts due by PJM to the Market Participant, and all counterclaims, (b) the surety expressly waive **all** of its and the principal's defenses, including illegality, fraud in the inducement, reliance on statements or representations of PJM and every other typically available defense; (c) the language of the bond that is determinative of the surety's obligation, and not the underlying agreement or arrangement between the principal and the obligee; (d) the bond shall not be conditioned on PJM first resorting to any other means of security or collateral, or pursuing any other remedies it may have; and (e) the surety acknowledge the continuing nature of its obligations in the event of termination or nonrenewal of the surety bond to make clear the surety remains liable for any obligations that arose before the effective date of its notice of cancellation of the surety bond. If the surety bond varies in any way from the standard format, it must first be reviewed and approved by PJM. PJM shall not accept any surety bond that varies in any material way from the standard format.

- (iv) All costs associated with obtaining and maintaining a surety bond and meeting the Attachment Q provisions are the responsibility of the Participant.
- (v) PJM shall not accept surety bonds with an aggregate value greater than \$10 million dollars (\$10,000,000) issued by any individual surety on behalf of any individual Participant.
- (vi) PJM shall not accept surety bonds with an aggregate value greater than \$50 million dollars (\$50,000,000) issued by any individual surety.

E. PJM Administrative Charges

Collateral or credit support held by PJM shall also secure obligations to PJM for PJM administrative charges, and may be liquidated to satisfy all such obligations in an Event of Default.

F. Collateral and Credit Support Held by PJM

Collateral or credit support submitted by Participants and held by PJM shall be held by PJM for the benefit of PJM.

VI. SUPPLEMENTAL CREDIT REQUIREMENTS FOR SCREENED TRANSACTIONS

A. Virtual and Export Transaction Screening

1. Credit for Virtual and Export Transactions

Export Transactions and Virtual Transactions both utilize Credit Available for Virtual Transactions to support their credit requirements.

PJM does not require a Market Participant to establish separate or additional credit for submitting Virtual or Export Transactions; however, once transactions are submitted and accepted by PJM, PJM may require credit supporting those transactions to be held until the transactions are completed and their financial impact incorporated into the Market Participant's Obligations. If a Market Participant chooses to establish additional Collateral and/or Unsecured Credit Allowance in order to increase its Credit Available for Virtual Transactions, the Market Participant's Working Credit Limit for Virtual Transactions shall be increased in accordance with the definition thereof. The Collateral and/or Unsecured Credit Allowance available to increase a Market Participant's Credit Available for Virtual Transactions shall be the amount of Collateral and/or Unsecured Credit Allowance available after subtracting any credit required for Minimum Participation Requirements, FTR, RPM or other credit requirement determinants defined in this Attachment Q, as applicable.

If a Market Participant chooses to provide additional Collateral in order to increase its Credit Available for Virtual Transactions PJM may establish a reasonable timeframe, not to exceed three months, for which such Collateral must be maintained. PJM will not impose such restriction on a deposit unless a Market Participant is notified prior to making the deposit. Such restriction, if applied, shall be applied to all future deposits by all Market Participants engaging in Virtual Transactions.

A Market Participant may increase its Credit Available for Virtual Transactions by providing additional Collateral to PJM. PJM will make a good faith effort to make new Collateral available as Credit Available for Virtual Transactions as soon as practicable after confirmation of receipt. In any event, however, Collateral received and confirmed by noon on a Business Day will be applied (as provided under this Attachment Q) to Credit Available for Virtual Transactions no later than 10:00 am on the following Business Day. Receipt and acceptance of wired funds for cash deposit shall mean actual receipt by PJM's bank, deposit into PJM's customer deposit account, confirmation by PJM that such wire has been received and deposited, and entry into PJM's credit system. Receipt and acceptance of letters of credit or surety bonds shall mean receipt of the original Letter of Credit or surety bond, or amendment thereto, confirmation from PJM's credit and legal staffs that such Letter of Credit or surety bond, or amendment thereto conforms to PJM's requirements, which confirmation shall be made in a reasonable and practicable timeframe, and entry into PJM's credit system. To facilitate this process, bidders submitting additional Collateral for the purpose of increasing their Credit Available for Virtual Transactions are advised to submit such Collateral well in advance of the desired time, and to specifically notify PJM of such submission.

A Market Participant wishing to submit Virtual or Export Transactions must allocate within PJM's credit system the appropriate amount of Credit Available for Virtual Transactions to the virtual and export allocation sections within each customer account in which it wishes to submit such transactions.

2. Virtual Transaction Screening

All Virtual Transactions submitted to PJM shall be subject to a credit screen prior to acceptance in the Day-ahead Energy Market. The credit screen is applied separately for each of a Market Participant's customer accounts. The credit screen process will automatically reject Virtual Transactions submitted by the Market Participant in a customer account if the Market Participant's Credit Available for Virtual Transactions, allocated on a customer account basis, is exceeded by the Virtual Credit Exposure that is calculated based on the Market Participant's Virtual Transactions submitted, as described below.

A Market Participant's Virtual Credit Exposure will be calculated separately for each customer account on a daily basis for all Virtual Transactions submitted by the Market Participant for the next Operating Day using the following equation:

Virtual Credit Exposure = INC and DEC Exposure + Up-to Congestion Exposure
Where:

(a) INC and DEC Exposure for each customer account is calculated as:

(i) ((the total MWh bid or offered, whichever is greater, hourly at each node) x the Nodal Reference Price x 1 day) summed over all nodes and all hours; plus (ii) ((the difference between the total bid MWh cleared and total offered MWh cleared hourly at each node) x Nodal Reference Price) summed over all nodes and all hours for the previous cleared Day-ahead Energy Market.

(b) Up-to Congestion Exposure for each customer account is calculated as:

(i) Total MWh bid hourly for each Up-to Congestion Transaction x (price bid – Up-to Congestion Reference Price) summed over all Up-to Congestion Transactions and all hours; plus (ii) Total MWh cleared hourly for each Up-to Congestion Transaction x (cleared price – Up-to Congestion Reference Price) summed over all Up-to Congestion Transactions and all hours for the previous cleared Day-ahead Energy Market, provided that hours for which the calculation for an Up-to Congestion Transaction is negative, it shall be deemed to have a zero contribution to the sum.

3. Export Transaction Screening

Export Transactions in the Real-time Energy Market shall be subject to Export Transaction Screening. Export Transaction Screening may be performed either for the duration of the entire Export Transaction, or separately for each time interval comprising an Export Transaction. PJM will deny or curtail all or a portion (based on the relevant time interval) of an Export Transaction if that Export Transaction, or portion thereof, would otherwise cause the Market Participant's Export Credit Exposure to exceed its Credit Available for Export Transactions. Export Transaction Screening shall be applied separately for each Operating Day and shall also be applied to each Export Transaction one or more times prior to the market clearing process for each relevant time interval. Export Transaction Screening shall not apply to transactions established directly by and between PJM and a neighboring Balancing Authority for the purpose of maintaining reliability.

A Market Participant's credit exposure for an individual Export Transaction shall be the MWh volume of the Export Transaction for each relevant time interval multiplied by each relevant Export Transaction Price Factor and summed over all relevant time intervals of the Export Transaction.

B. RPM Auction and Price Responsive Demand Credit Requirements

Settlement during any Delivery Year of cleared positions resulting or expected to result from any RPM Auction shall be included as appropriate in Peak Market Activity, and the provisions of this Attachment Q shall apply to any such activity and obligations arising therefrom. In addition, the provisions of this section shall apply to any entity seeking to participate in any RPM Auction, to address credit risks unique to such auctions. The provisions of this section also shall apply under certain circumstances to PRD Providers that seek to commit Price Responsive Demand pursuant to the provisions of the Reliability Assurance Agreement.

Credit requirements described herein for RPM Auctions and RPM bilateral transactions are applied separately for each customer account of a Market Participant. Market Participants wishing to participate in an RPM Auction or enter into RPM bilateral transactions must designate the appropriate amount of credit to each account in which their offers are submitted.

1. Applicability

A Market Participant seeking to submit a Sell Offer in any RPM Auction based on any Capacity Resource for which there is a materially increased risk of nonperformance must satisfy the credit requirement specified herein before submitting such Sell Offer. A PRD Provider seeking to commit Price Responsive Demand for which there is a materially increased risk of non-performance must satisfy the credit requirement specified herein before it may commit the Price Responsive Demand. Credit must be maintained until such risk of non-performance is substantially eliminated, but may be reduced commensurate with the reduction in such risk, as set forth in section VI.B.3 below.

For purposes of this provision, a resource for which there is a materially increased risk of nonperformance shall mean: (i) a Planned Generation Capacity Resource; (ii) a Planned Demand Resource or an Energy Efficiency Resource; (iii) a Qualifying Transmission Upgrade; (iv) an existing or Planned Generation Capacity Resource located outside the PJM Region that at the time it is submitted in a Sell Offer has not secured firm transmission service to the border of the PJM Region sufficient to satisfy the deliverability requirements of the Reliability Assurance Agreement; or (v) Price Responsive Demand to the extent the responsible PRD Provider has not registered PRD-eligible load at a PRD Substation level to satisfy its Nominal PRD Value commitment, in accordance with Reliability Assurance Agreement, Schedule 6.1.

2. Reliability Pricing Model Auction and Price Responsive Demand Credit Requirement

Except as provided for Credit-Limited Offers below, for any resource specified in section VI.B.1 above, other than Price Responsive Demand, the credit requirement shall be the RPM Auction Credit Rate, as provided in section VI.B.4 below, times the megawatts to be offered for sale from such resource in an RPM Auction. For Qualified Transmission Upgrades, the credit requirements shall be based on the Locational Deliverability Area in which such upgrade was to increase the Capacity Emergency Transfer Limit. However, the credit requirement for Planned Financed Generation Capacity Resources and Planned External Financed Generation Capacity Resources shall be one half of the product of the RPM Auction Credit Rate, as provided in section VI.B.4 below, times the megawatts to be offered for sale from such resource in a Reliability Pricing Model Auction. The RPM Auction Credit Requirement for each Market Participant shall be determined on a customer account basis, separately for each customer account of a Market Participant, and shall be the sum of the credit requirements for all such resources to be offered by such Market Participant in the auction or, as applicable, cleared by such Market Participant in the relevant auctions. For Price Responsive Demand, the credit requirement shall be based on the Nominal PRD Value (stated in Unforced Capacity terms) times the Price Responsive Demand Credit Rate as set forth in section VI.B.5 below. Except for Credit-Limited Offers, the RPM Auction Credit requirement for a Market Participant will be reduced for any Delivery Year to the extent less than all of such Market Participant's offers clear in the Base Residual Auction or any Incremental Auction for such Delivery Year. Such reduction shall be proportional to the quantity, in megawatts, that failed to clear in such Delivery Year.

A Sell Offer based on a Planned Generation Capacity Resource, Planned Demand Resource, or Energy Efficiency Resource may be submitted as a Credit-Limited Offer. A Market Participant electing this option shall specify a maximum amount of Unforced Capacity, in megawatts, and a maximum credit requirement, in dollars, applicable to the Sell Offer. A Credit-Limited Offer shall clear the RPM Auction in which it is submitted (to the extent it otherwise would clear based on the other offer parameters and the system's need for the offered capacity) only to the extent of the lesser of: (i) the quantity of Unforced Capacity that is the quotient of the division of the specified maximum credit requirement by the Auction Credit Rate resulting from section VI.B.4.b. below; and (ii) the maximum amount of Unforced Capacity specified in the Sell Offer. For a Market Participant electing this alternative, the RPM Auction Credit requirement applicable prior to the posting of results of the auction shall be the maximum credit requirement specified in its Credit-Limited Offer, and the RPM Auction Credit requirement subsequent to posting of the results will be the Auction Credit Rate, as provided in section VI.B.4.b, c. or d. of this Attachment Q, as applicable, times the amount of Unforced Capacity from such Sell Offer that cleared in the auction. The availability and operational details of Credit-Limited Offers shall be as described in the PJM Manuals.

As set forth in section VI.B.4 below, a Market Participant's Auction Credit requirement shall be determined separately for each Delivery Year.

3. Reduction in Credit Requirement

As specified below, the RPM Auction Credit Rate may be reduced under certain circumstances after the auction has closed.

The Price Responsive Demand credit requirement shall be reduced as and to the extent the PRD Provider registers PRD-eligible load at a PRD Substation level to satisfy its Nominal PRD Value commitment, in accordance with Reliability Assurance Agreement, Schedule 6.1.

In addition, the RPM Auction Credit requirement for a Market Participant for any given Delivery Year shall be reduced periodically, after the Market Participant has provided PJM a written request for each reduction, accompanied by documentation sufficient for PJM to verify attainment of required milestones or satisfaction of other requirements, and PJM has verified that the Market Participant has successfully met progress milestones for its Capacity Resource that reduce the risk of non-performance, as follows:

(a) For Planned Demand Resources and Energy Efficiency Resources, the RPM Auction Credit requirement will be reduced in direct proportion to the megawatts of such Demand Resource that the Resource Provider qualifies as a Capacity Resource, in accordance with the procedures established under the Reliability Assurance Agreement.

(b) For Existing Generation Capacity Resources located outside the PJM Region that have not secured sufficient firm transmission to the border of the PJM Region prior to the auction in which such resource is first offered, the RPM Auction Credit requirement shall be reduced in direct proportion to the megawatts of firm transmission service secured by the Market Participant

that qualify such resource under the deliverability requirements of the Reliability Assurance Agreement.

(c) For Planned Generation Capacity Resources located in the PJM Region, the RPM Auction Credit requirement shall be reduced as the Capacity Resource attains the milestones stated in the following table and as further described in the PJM Manuals.

Milestones	Increment of reduction from initial RPM Auction Credit requirement
Effective Date of Interconnection Service Agreement	50%
Financial Close	15%
Full Notice to Proceed and Commencement of Construction (e.g., footers poured)	5%
Main Power Generating Equipment Delivered	5%
Commencement of Interconnection Service	25%

For externally financed projects, the Market Participant must submit with its request for reduction a sworn, notarized certification of a duly authorized independent engineer for the Financial Close, Full Notice to Proceed and Commencement of Construction, and Main Power Generating Equipment Delivered milestones.

For internally financed projects, the Market Participant must submit with its request for reduction a sworn, notarized certification of a duly authorized officer of the Market Participant for the Financial Close milestone and either a duly authorized independent engineer or Professional Engineer for the Full Notice to Proceed and Commencement of Construction and the Main Power Generating Equipment Delivered milestones.

The required certifications must be in a form acceptable to PJM, certifying that the engineer or officer, as applicable, has personal knowledge, or has engaged in a diligent inquiry to determine, that the milestone has been achieved and that, based on its review of the relevant project information, the engineer or officer, as applicable, is not aware of any information that could reasonably cause it to believe that the Capacity Resource will not be in-service by the beginning of the applicable Delivery Year. The Market Participant shall, if requested by PJM, supply to PJM on a confidential basis all records and documents relating to the engineer's and/or officer's certifications.

(d) For Planned External Generation Capacity Resources, the RPM Auction Credit requirement shall be reduced as the Capacity Resource attains the milestones stated in the following table and as further described in the PJM Manuals; provided, however, that the total percentage reduction in the RPM Auction Credit requirement shall be no greater than the quotient of (i) the MWs of firm transmission service that the Market Participant has secured for the complete transmission path divided by (ii) the MWs of firm transmission service required to

qualify such resource under the deliverability requirements of the Reliability Assurance Agreement.

Credit Reduction Milestones for Planned External Generation Capacity Resources	
Milestones	Increment of reduction from initial RPM Auction Credit requirement
Effective Date of the equivalent of an Interconnection Service Agreement	50%
Financial Close	15%
Full Notice to Proceed and Commencement of Construction (e.g., footers poured)	5%
Main Power Generating Equipment Delivered	5%
Commencement of Interconnection Service	25%

To obtain a reduction in its RPM Auction Credit requirement, the Market Participant must demonstrate satisfaction of the applicable milestone in the same manner as set forth for Planned Generation Capacity Resources in subsection (c) above.

(e) For Planned Financed Generation Capacity Resources located in the PJM Region, the RPM Auction Credit requirement shall be reduced as the Capacity Resource attains the milestones stated in the following table and as further described in the PJM Manuals.

Credit Reduction Milestones for Planned Financed Generation Capacity Resources	
Milestones	Increment of reduction from initial RPM Auction Credit requirement
Full Notice to Proceed	50%
Commencement of Construction (e.g., footers poured)	15%
Main Power Generating Equipment Delivered	10%
Commencement of Interconnection Service	25%

To obtain a reduction in its RPM Auction Credit requirement, the Market Participant must demonstrate satisfaction of the applicable milestone in the same manner as set forth for Planned Generation Capacity Resources in subsection (c) above.

(f) For Planned External Financed Generation Capacity Resources, the RPM Auction Credit Requirement shall be reduced as the Capacity Resource attains the milestones stated in the following table and as further described in the PJM Manuals; provided, however, that the total percentage reduction in the RPM Auction Credit requirement, including the initial 50% reduction for being a Planned External Financed Generation Capacity Resources, shall be no greater than the quotient of (i) the MWs of firm transmission service that the Market Participant has secured for the complete transmission path divided by (ii) the MWs of firm transmission service required

to qualify such resource under the deliverability requirements of the Reliability Assurance Agreement.

Credit Reduction Milestones for Planned External Financed Generation Capacity	
Milestones	Increment of reduction from initial RPM Auction Credit requirement
Full Notice to Proceed	50%
Commencement of Construction (e.g., footers poured)	15%
Main Power Generating Equipment Delivered	10%
Commencement of Interconnection Service	25%

To obtain a reduction in its RPM Auction Credit requirement, the Market Participant must demonstrate satisfaction of the applicable milestone in the same manner as set forth for Planned Generation Capacity Resources in subsection (c) above.

(g) For Qualifying Transmission Upgrades, the RPM Auction Credit requirement shall be reduced to 50% of the amount calculated under section VI.B.2 above beginning as of the effective date of the latest associated Interconnection Service Agreement (or, when a project will have no such agreement, an Upgrade Construction Service Agreement), and shall be reduced to zero on the date the Qualifying Transmission Upgrade is placed in service.

4. RPM Auction Credit Rate

As set forth in the PJM Manuals, a separate Auction Credit Rate shall be calculated for each Delivery Year prior to each RPM Auction for such Delivery Year, as follows:

- (a) Prior to the posting of the results of a Base Residual Auction for a Delivery Year, the Auction Credit Rate shall be:
- (i) For all Capacity Resources other than Capacity Performance Resources, (the greater of (A) 0.3 times the Net Cost of New Entry for the PJM Region for such Delivery Year, in MW-day or (B) \$20 per MW-day) times the number of calendar days in such Delivery Year; and
 - (ii) For Capacity Performance Resources, the greater of ((A) 0.5 times the Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in MW-day or (B) \$20 per MW-day) times the number of calendar days in such Delivery Year.
 - (iii) For Seasonal Capacity Performance Resources, the same as the Auction Credit Rate for Capacity Performance Resources, but reduced to be proportional to the number of calendar days in the relevant season.

(b) Subsequent to the posting of the results from a Base Residual Auction, the Auction Credit Rate used for ongoing credit requirements for supply committed in such auction shall be:

- (i) For all Capacity Resources other than Capacity Performance Resources, (the greater of (A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the resource is located) times the number of calendar days in such Delivery Year; and
- (ii) For Capacity Performance Resources, the (greater of [(A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the resource is located) or (C) the lesser of (1) 0.5 times the Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day or (2) 1.5 times the Net Cost of New Entry (stated on an installed capacity basis) for the PJM Region for such Delivery year or for the Relevant LDA, in \$/MW-day minus (the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the resource is located)] times the number of calendar days in such Delivery Year).
- (iii) For Seasonal Capacity Performance Resources, the same as the Auction Credit Rate for Capacity Performance Resources, but reduced to be proportional to the number of calendar days in the relevant season.

(c) For any resource not previously committed for a Delivery Year that seeks to participate in an Incremental Auction, the Auction Credit Rate shall be:

(i) For all Capacity Resources other than Capacity Performance Resources, (the greater of (A) 0.3 times the Net Cost of New Entry for the PJM Region for such Delivery Year, in MW-day or (B) 0.24 times the Capacity Resource Clearing Price in the Base Residual Auction for such Delivery Year for the Locational Deliverability Area within which the resource is located or (C) \$20 per MW-day) times the number of calendar days in such Delivery Year; and

(ii) For Capacity Performance Resources, the (greater of (A) 0.5 times Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA or (B) \$20/MW-day) times the number of calendar days in such Delivery Year.

(d) Subsequent to the posting of the results of an Incremental Auction, the Auction Credit Rate used for ongoing credit requirements for supply committed in such auction shall be:

- (i) For Base Capacity Resources: (the greater of (A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the resource is located) times the number of calendar days in such Delivery Year, but no greater than the Auction Credit Rate previously established for such resource's participation in such Incremental Auction pursuant to subsection (c) above) times the number of calendar days in such Delivery Year;

- (ii) For Capacity Performance Resources, the greater of [(A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the resource is located or (C) the lesser of (1) 0.5 times the Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day or (2) 1.5 times the Net Cost of New Entry (stated on an installed capacity basis) for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day minus (the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the resource is located)] times the number of calendar days in such Delivery Year); and
- (iii) For Seasonal Capacity Performance Resources, the same as the Auction Credit Rate for Capacity Performance Resources, but reduced to be proportional to the number of calendar days in the relevant season.

(e) For the purposes of this section VI.B.4 and section VI.B.5 below, “Relevant LDA” means the Locational Deliverability Area in which the Capacity Performance Resource is located if a separate Variable Resource Requirement Curve has been established for that Locational Deliverability Area for the Base Residual Auction for such Delivery Year.

5. Price Responsive Demand Credit Rate

- (a) For the 2018/2019 through 2022/2023 Delivery Years:
 - (i) Prior to the posting of the results of a Base Residual Auction for a Delivery Year, the Price Responsive Demand Credit Rate shall be (the greater of (A) 0.3 times the Net Cost of New Entry for the PJM Region for such Delivery Year, in MW-day or (B) \$20 per MW-day) times the number of calendar days in such Delivery Year;
 - (ii) Subsequent to the posting of the results from a Base Residual Auction, the Price Responsive Demand Credit Rate used for ongoing credit requirements for Price Responsive Demand committed in such auction shall be (the greater of (A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the Price Responsive Demand load is located, in \$/MW-day) times the number of calendar days in such Delivery Year times a final price uncertainty factor of 1.05;
 - (iii) For any additional Price Responsive Demand that seeks to commit in a Third Incremental Auction in response to a qualifying change in the final LDA load forecast, the Price Responsive Demand Credit Rate shall be the same as the rate for Price Responsive Demand that had cleared in the Base Residual Auction; and
 - (iv) Subsequent to the posting of the results of the Third Incremental Auction, the Price Responsive Demand Credit Rate used for ongoing credit requirements for

all Price Responsive Demand, shall be (the greater of (i) \$20/MW-day or (ii) 0.2 times the Final Zonal Capacity Price for the Locational Deliverability Area within which the Price Responsive Demand is located) times the number of calendar days in such Delivery Year, but no greater than the Price Responsive Demand Credit Rate previously established under subsections (a)(i), (a)(ii), or (a)(iii) of this section for such Delivery Year.

- (b) For the 2022/2023 Delivery Year and Subsequent Delivery Years:
- (i) Prior to the posting of the results of a Base Residual Auction for a Delivery Year, the Price Responsive Demand Credit Rate shall be (the greater of (A) 0.5 times the Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day or (B) \$20 per MW-day) times the number of calendar days in such Delivery Year;
 - (ii) Subsequent to the posting of the results from a Base Residual Auction, the Price Responsive Demand Credit Rate used for ongoing credit requirements for Price Responsive Demand committed in such auction shall be (the greater of [(A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the Price Responsive Demand is located, in \$/MW-day or (C) the lesser of (1) 0.5 times the Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day or (2) 1.5 times the Net Cost of New Entry (stated on an installed capacity basis) for the PJM Region for such Delivery year or for the Relevant LDA, in \$/MW-day minus (the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the Price Responsive Demand is located)] times the number of calendar days in such Delivery Year;
 - (iii) For any additional Price Responsive Demand that seeks to commit in a Third Incremental Auction in response to a qualifying change in the final LDA load forecast, the Price Responsive Demand Credit Rate shall be (the greater of (A) 0.5 times Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day or (B) \$20/MW-day) times the number of calendar days in such Delivery Year; and
 - (iv) Subsequent to the posting of the results of the Third Incremental Auction, the Price Responsive Demand Credit Rate used for ongoing credit requirements for all Price Responsive Demand committed in such auction shall be the greater of [(A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the Price Responsive Demand is located or (C) the lesser of (1) 0.5 times the Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day or (2) 1.5 times the Net Cost of New Entry (stated on an installed capacity basis) for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day minus (the Capacity Performance Resource Clearing Price in such Incremental Auction for the Locational Deliverability Areas within which the Price

Responsive Demand is located)] times the number of calendar days in such Delivery Year.

6. RPM Seller Credit - Additional Form of Unsecured Credit for RPM

In addition to the forms of credit specified elsewhere in this Attachment Q, RPM Seller Credit shall be available to Market Participants, but solely for purposes of satisfying RPM Auction Credit requirements. If a supplier has a history of being a net seller into PJM Markets, on average, over the past 12 months, then PJM will count as available Unsecured Credit twice the average of that Market Participant's total net monthly PJM bills over the past 12 months. This RPM Seller Credit shall be subject to the cap on available Unsecured Credit as established in section II.G.3 above.

RPM Seller Credit is calculated as a single value for each Market Participant, not separately by account, and must be designated to specific customer accounts in order to be available to satisfy RPM Auction Credit requirements that are calculated in each such customer account.

7. Credit Responsibility for Traded Planned RPM Capacity Resources

PJM may require that credit and financial responsibility for planned Capacity Resources that are traded remain with the original party (which for these purposes, means the party bearing credit responsibility for the planned Capacity Resource immediately prior to trade) unless the receiving party independently establishes consistent with this Attachment Q, that it has sufficient credit with PJM and agrees by providing written notice to PJM that it will fully assume the credit responsibility associated with the traded planned Capacity Resource.

C. Financial Transmission Right Auctions

Credit requirements described herein for FTR activity are applied separately for each customer account of a Market Participant, unless specified otherwise in this section C. FTR Participants must designate the appropriate amount of credit to each separate customer account in which any activity occurs or will occur.

1. FTR Credit Limit.

Participants must maintain their FTR Credit Limit at a level equal to or greater than their FTR Credit Requirement for each applicable account. FTR Credit Limits will be established only by a Participant providing Collateral and designating the available credit to specific accounts.

2. FTR Credit Requirement.

For each Market Participant with FTR activity, PJM shall calculate an FTR Credit Requirement. The FTR Credit Requirement shall be calculated on a portfolio basis for each Market Participant based on (a) initial margin, (b) Auction Revenue Right Credits, (c) Mark-to-Auction Value, (d) application of a 10¢ per MWh minimum value adjustment, and (e) realized gains and/or losses, as set forth in subsections (a)-(e) of this subsection, employing the formula:

Max { Max (IM – ARR – MTA, Ten Cent per Mwh Minimum) – Realized Gains and/or Losses, 0}

Where IM is the initial margin, ARR is Auction Revenue Rights Credits and MTA is the Mark-to-Auction Value. The FTR Credit Requirement may be increased to reflect any change in the value of a Market Participant's portfolio requiring an increase in Collateral as further described below.

(a) Initial Margin

Initial margin shall be calculated in accordance with the following formula:

$$\text{IM} = \text{FTR Obligations IM} + \text{FTR Options IM}$$

The model will employ a confidence interval of 97 percent.

(i) FTR Obligations IM

Initial margin values for Financial Transmission Right Obligations shall be determined utilizing a historical simulation value-at-risk methodology that calculates the size and value at risk of the applicable FTR portfolio based on a defined confidence interval and subject to a weighted aggregation method that is represented by a straight sum for long term positions and a combination of straight sum (20%) and weighted root sum of squares (80%) for balance of planning period positions.

(ii) FTR Options IM

The initial margin for Financial Transmission Right Options shall be calculated as the FTR cost minus the FTR Historical Values. FTR Historical Values shall be calculated separately for weekend on-peak, weekday on-peak, off-peak, and 24-hour FTRs for each month of the year. FTR Historical Values shall be adjusted by plus or minus ten percent for cleared counter flow or prevailing flow FTRs, respectively, in order to mitigate exposure due to uncertainty and fluctuations in actual FTR value. Historical values used in the calculation of FTR Historical Values shall be adjusted when the network simulation model utilized in PJM's economic planning process indicates that transmission congestion will decrease due to certain transmission upgrades that are in effect or planned to go into effect for the following Planning Period. The transmission upgrades to be modeled for this purpose shall only include those upgrades that, individually, or together, have 10% or more impact on the transmission congestion on an individual constraint or constraints with congestion of \$5 million or more affecting a common congestion path. The adjustments to historical values shall be the dollar amount of the adjustment shown in the network simulation model.

(b) Auction Revenue Rights Credits

For a given month for which initial margin is calculated, the prorated value of any Auction Revenue Rights Credits held by a Market Participant with Financial Transmission Right Obligations shall be subtracted from the initial margin for that month. In accordance with subsection 3 below, PJM may recalculate Auction Revenue Rights Credits at any time, but shall do so no less frequently than subsequent to each annual FTR auction. If a reduction in such ARR credits at any time increases an FTR Participant's FTR Credit Requirements beyond its credit available for FTR activity, the FTR Participant must increase its Collateral or the FTR Credit Limit.

(c) Mark-to-Auction Value

A Mark-to-Auction Value shall be calculated for each Market Participant in accordance with subsection 7 below.

(d) Ten Cent (10¢) per MWh Minimum Value Adjustment

If the FTR Credit Requirement as calculated pursuant to subsections (a)-(c) above, results in a value that is less than ten cents (10¢) per MWh, the FTR Credit Requirement shall be increased to ten cents (10¢) per MWh. When calculating the portfolio MWh for this comparison, for cleared "Sell" FTRs, the MWh shall be subtracted from the portfolio total; prior to clearing, the MWh for "Sell" FTRs shall not be included in the portfolio total.

(e) Realized Gains and/or Losses

Any realized gains and/or losses resulting from the ~~sale~~-settlement of Financial Transmission Right Obligations that have not been paid out will be subtracted from the FTR Credit Requirement. A realized gain will decrease the FTR Credit Requirement (but not below \$0.00), whereas a realized loss will increase the FTR Credit Requirement.

3. Rejection of FTR Bids.

Bids submitted into an auction will be rejected if the Market Participant's FTR Credit Requirement including such submitted bids would exceed the Market Participant's FTR Credit Limit, or if the Market Participant fails to provide additional Collateral as required pursuant to provisions related to mark-to-auction.

4. FTR Credit Collateral Returns.

A Market Participant may request from PJM the return of any Collateral no longer required for the FTR markets. PJM is permitted to limit the frequency of such requested Collateral returns, provided that Collateral returns shall be made by PJM at least once per calendar quarter, if requested by a Market Participant.

5. Credit Responsibility for Bilateral Transfers of FTRs.

PJM may require that credit responsibility associated with an FTR bilaterally transferred to a new Market Participant remain with the original party (which for these purposes, means the party bearing credit responsibility for the FTR immediately prior to bilateral transfer) unless and until the receiving party independently establishes, consistent with this Attachment Q, sufficient credit with PJM and agrees through confirmation of the bilateral transfer in PJM's FTR reporting tool that it will meet in full the credit requirements associated with the transferred FTR.

6. FTR Administrative Charge Credit Requirement

In addition to any other credit requirements, PJM may apply a credit requirement to cover the maximum administrative fees that may be charged to a Market Participant for its bids and offers.

7. Mark-to-Auction

A Mark-to-Auction Value shall be calculated separately for each customer account of a Market Participant. For each such customer account, the Mark-to-Auction Value shall be a single number equal to the sum, over all months remaining in the applicable FTR period and for all cleared FTRs in the customer account, of the most recently available cleared auction price applicable to the FTR minus the original transaction price of the FTR, multiplied by the transacted quantity.

The FTR Credit Requirement, as otherwise described above, shall be increased when the Mark-to-Auction Value is negative and decreased when the Mark-to-Auction Value is positive. The increase shall equal the absolute value of the negative Mark-to-Auction Value less the value of ARR credits that are held in the customer account and have not been used to reduce the FTR Credit Requirement prior to application of the Mark-to-Auction Value. PJM shall recalculate ARR credits held by each Market Participant after each annual FTR auction and may also recalculate such ARR credits at any other additional time intervals it deems appropriate. Application of the Mark-to-Auction Value, including the effect from ARR application, shall not decrease the FTR Credit Requirement below the Ten Cent (10¢) per MWh Minimum.

For Market Participant customer accounts for which FTR bids have been submitted into the current FTR auction, if the Market Participant's FTR Credit Requirement exceeds its credit available for the Market Participant's portfolio of FTRs in the tentative cleared solution for an FTR auction (or auction round), PJM shall issue a Collateral Call to the Market Participant, and the Market Participant must fulfill such demand before 4:00 p.m. Eastern Prevailing Time on the following Business Day. If a Market Participant does not timely satisfy such Collateral Call,

PJM shall, in coordination with PJM, cause the removal of all of that Market Participant's bids in that FTR auction (or auction round), submitted from such Market Participant's customer account, and a new cleared solution shall be calculated for the FTR auction (or auction round).

If necessary, PJM shall repeat the auction clearing calculation. PJM shall repeat these mark-to-auction calculations subsequent to any secondary clearing calculation, and PJM shall require affected Market Participants to establish additional credit.

Subsequent to final clearing of an FTR auction or an annual FTR auction round, PJM shall recalculate the FTR Credit Requirement for all FTR portfolios, and, as applicable, issue to each Market Participant a request for Collateral for the total amount by which the FTR Credit Requirement exceeds the credit allocated in any of the Market Participant's accounts. The Market Participant must fulfill such demand by 4:00 p.m. Eastern Prevailing Time on the following Business Day.

If the request for Collateral is not satisfied within the applicable cure period referenced in Operating Agreement, section 15, then such Market Participant shall be restricted in all of its credit-screened transactions. Specifically, such Market Participant may not engage in any Virtual Transactions or Export Transactions, or participate in RPM Auctions or other RPM activity. Such Market Participant may engage only in the selling of open FTR positions, either in FTR auctions or bilaterally, provided such sales would reduce the Market Participant's FTR Credit Requirements. PJM shall not return any Collateral to such Market Participant, and no payment shall be due or payable to such Market Participant, until its credit shortfall is remedied. Market Participant shall allocate any excess or unallocated Collateral to any of its account in which there is a credit shortfall. Market Participants may remedy their credit shortfall at any time through provision of sufficient Collateral.

If a Market Participant fails to satisfy a request for Collateral for two consecutive auctions of overlapping periods, e.g. two balance of Planning Period auctions, an annual FTR auction and a balance of Planning Period auction, or two long term FTR auctions, (for this purpose the four rounds of an annual FTR auction shall be considered a single auction), the Market Participant shall be declared in default of this Attachment Q.

VII. PEAK MARKET ACTIVITY AND WORKING CREDIT LIMIT

A. Peak Market Activity Credit Requirement

PJM shall calculate a Peak Market Activity credit requirement for each Participant. Each Participant must maintain sufficient Unsecured Credit Allowance and/or Collateral, as applicable, and subject to the provisions herein, to satisfy its Peak Market Activity credit requirement.

Peak Market Activity for Participants will be determined semi-annually, utilizing an initial Peak Market Activity, as explained below, calculated after the first complete billing week in the months of April and October. Peak Market Activity shall be the greater of the initial Peak Market Activity, or the greatest amount invoiced for the Participant's transaction activity for all

PJM Markets and services in any rolling one, two, or three week period, ending within a respective semi-annual period. However, Peak Market Activity shall not exceed the greatest amount invoiced for the Participant's transaction activity for all PJM Markets and services in any rolling one, two or three week period in the prior 52 weeks.

Peak Market Activity shall exclude FTR Net Activity, Virtual Transactions Net Activity, and Export Transactions Net Activity.

When calculating Peak Market Activity, PJM may attribute credits for Regulation service to the days on which they were accrued, rather than including them in the month-end invoice.

The initial Peak Market Activity for Applicants will be determined by PJM based on a review of an estimate of their transactional activity for all PJM Markets and services over the next 52 weeks, which the Applicant shall provide to PJM.

The initial Peak Market Activity for Market Participants and Transmission Customers, calculated at the beginning of each semi-annual period, shall be the three-week average of all non-zero invoice totals over the previous 52 weeks. This calculation shall be performed and applied within three (3) Business Days following the day the invoice is issued for the first full billing week in the current semi-annual period.

Prepayments shall not affect Peak Market Activity unless otherwise agreed to in writing pursuant to this Attachment Q.

Peak Market Activity calculations shall take into account reductions of invoice values effectuated by early payments which are applied to reduce a Participant's Peak Market Activity as contemplated by other terms of this Attachment Q; provided that the initial Peak Market Activity shall not be less than the average value calculated using the weeks for which no early payment was made.

A Participant may reduce its Collateral requirement by agreeing in writing (in a form acceptable to PJM) to make additional payments, including prepayments, as and when necessary to ensure that such Participant's Total Net Obligation at no time exceeds such reduced Collateral requirement.

PJM may, at its discretion, adjust a Participant's Peak Market Activity requirement if PJM determines that the Peak Market Activity is not representative of such Participant's expected activity, as a consequence of known, measurable, and sustained changes. Such changes may include, but shall not be limited to when a Participant makes PJM aware of federal, state or local law that could affect the allocation of charges or credits from a Participant to another party, the loss (without replacement) of short-term load contracts, when such contracts had terms of three months or more and were acquired through state-sponsored retail load programs, but shall not include short-term buying and selling activities.

PJM may waive the credit requirements for a Participant that has no outstanding transactions and agrees in writing that it shall not, after the date of such agreement, incur obligations under any of

the Agreements. Such entity's access to all electronic transaction systems administered by PJM shall be terminated.

A Participant receiving unsecured credit may make early payments up to ten times in a rolling 52-week period in order to reduce its Peak Market Activity for credit requirement purposes. Imputed Peak Market Activity reductions for credit purposes will be applied to the billing period for which the payment was received. Payments used as the basis for such reductions must be received prior to issuance or posting of the invoice for the relevant billing period. The imputed Peak Market Activity reduction attributed to any payment may not exceed the amount of Unsecured Credit for which the Participant is eligible.

B. Working Credit Limit

PJM will establish a Working Credit Limit for each Participant against which its Total Net Obligation will be monitored.

If a Participant's Total Net Obligation approaches its Working Credit Limit, PJM may require the Participant to make an advance payment or increase its Collateral in order to maintain its Total Net Obligation below its Working Credit Limit. Except as explicitly provided herein, advance payments shall not serve to reduce the Participant's Peak Market Activity for the purpose of calculating credit requirements.

Example: After ten (10) calendar days, and with five (5) calendar days remaining before the bill is due to be paid, a Participant approaches its \$4.0 million Working Credit Limit. PJM may require a prepayment of \$2.0 million in order that the Total Net Obligation will not exceed the Working Credit Limit.

If a Participant exceeds its Working Credit Limit or is required to make advance payments more than ten times during a 52-week period, PJM may require Collateral in an amount as may be deemed reasonably necessary to support its Total Net Obligation.

When calculating Total Net Obligation, PJM may attribute credits for Regulation service to the days on which they were accrued, rather than including them in the month-end invoice.

VIII. SUSPENSION OR LIMITATION ON MARKET PARTICIPATION

If PJM determines that a Participant presents an unreasonable credit risk as determined pursuant to initial or ongoing risk evaluations, as described in section II above, or in the case of any other event which, after notice, lapse of time, or both, would result in an Event of Default, PJM will take steps to mitigate the exposure of any PJM Markets, which may include, but is not limited to, requiring Collateral, additional Collateral or Restricted Collateral or suspending or limiting the Market Participant's ability to participate in the PJM Markets commensurate to the risk to any PJM Markets.

If a Participant fails to reduce or eliminate any unreasonable credit risks to PJM's satisfaction within the applicable cure period including without limitation by posting Collateral, additional Collateral or Restricted Collateral, PJM may treat such failure as an Event of Default.

Notwithstanding the foregoing, a Participant that transacts in FTRs will be eligible to request that PJM exempt or exclude FTR transactions of such Participant from the effect of any such limitations on market activity established by PJM, and PJM may but shall not be required to so exempt or exclude, any FTR transactions that the Participant reasonably demonstrates to PJM it has entered into to “hedge or mitigate commercial risk” arising from its transactions in the PJM Interchange Energy Market that are intended to result in the actual flow of physical energy or ancillary services in the PJM Region, as the phrase “hedge or mitigate commercial risks” is defined under the CFTC’s regulations defining the end-user exception to clearing set forth in 17 C.F.R. §50.50(c).

IX. REMEDIES FOR CREDIT BREACH, FINANCIAL DEFAULT OR CREDIT SUPPORT DEFAULT; REMEDIES FOR EVENTS OF DEFAULT

If PJM determines that a Market Participant is in Credit Breach, or that a Financial Default or Credit Support Default exists, PJM may issue to the Market Participant a breach notice and/or a Collateral Call or demand for additional documentation or assurances. At such time, PJM may also suspend payments of any amounts due to the Participant and limit, restrict or rescind the Market Participant’s privileges to participate in any or all PJM Markets under the Agreements during any such cure period. Failure to remedy the Credit Breach, Financial Default or to satisfy a Collateral Call or demand for additional documentation or assurances within the applicable cure period described in Operating Agreement, section 15.1.5, shall constitute an Event of Default. If a Participant fails to meet the requirements of this Attachment Q, but then remedies the Credit Breach, Financial Default or Credit Support Default, or satisfies a Collateral Call or demand for additional documentation or assurances within the applicable cure period, then the Participant shall be deemed to again be in compliance with this Attachment Q, so long as no other Credit Breach, Financial Default, Credit Support Default or Collateral Call or demand for additional documentation or assurances has occurred and is continuing.

Only one cure period shall apply to a single event giving rise to a Credit Breach, Financial Default or Credit Support Default. Application of Collateral towards a Financial Default, Credit Breach or Credit Support Breach shall not be considered a cure of such Credit Breach, Financial Default or Credit Support Default unless the Participant is determined by PJM to be in full compliance with all requirements of this Attachment Q after such application.

When an Event of Default under this Attachment Q or one or more of the Agreements has occurred and is continuing, PJM may take such actions as may be required or permitted under the Agreements to protect the PJM Markets and the PJM Members, including but not limited to (a) suspension and/or termination of the Participant’s ongoing Transmission Service, (b) limitation, suspension and/or termination of participation in any PJM Markets, (c) close out and liquidation of the Market Participant’s market portfolio, exercising judgment in the manner in which this is achieved in any PJM Markets.

When an Event of Default under this Attachment Q or one or more of the Agreements has occurred and is continuing, PJM also has the immediate right to liquidate all or a portion of a Participant’s Collateral at its discretion to satisfy Total Net Obligations to PJM under this Attachment Q or one or more of the Agreements. No remedy for an Event of Default is or shall

be deemed to be exclusive of any other available remedy or remedies by contract or under applicable laws and regulations. Each such remedy shall be distinct, separate and cumulative, shall not be deemed inconsistent with or in exclusion of any other available remedy, and shall be in addition to and separate and distinct from every other remedy.

When an Event of Default under this Attachment Q or one or more of the Agreements has occurred and is continuing, PJM may continue to retain all payments due to a Participant as a cash security for all such Participant's obligations under the Agreements (regardless of any restrictions placed on such Participant's use of Collateral for any account, market activity or capitalization purpose); provided, however, that an Event of Default will not be deemed cured or no longer continuing because PJM is retaining amounts due the Participant, or because PJM has not yet applied Collateral or credit support to any amounts due PJM, unless PJM determines that the Participant has again satisfied all the Collateral requirements and application requirements as a new Applicant for participation in the PJM Markets, and consistent with the requirements and limitations of Operating Agreement, section 15.

In Event of Default by a Participant, PJM may exercise any remedy or action allowed or prescribed by this Attachment Q immediately or following investigation and determination of an orderly exercise of such remedy or action. Delay in exercising any allowed remedy or action shall not preclude PJM from exercising such remedy or action at a later time.

PJM may hold a defaulting Participant's Collateral for as long as such party's positions exist and consistent with this Attachment Q, in order to protect the PJM Markets and PJM's membership, and minimize or mitigate the impacts or potential impacts or risks associated with such Event of Default when an Event of Default under this Attachment Q or one or more of the Agreements has occurred and is continuing.

PJM may apply towards an ongoing Event of Default any amounts that are held or later become available or due to the defaulting Participant through PJM's markets and systems.

In order to cover the Participant's Obligations, PJM may hold a Participant's Collateral indefinitely and specifically through the end of the billing period which includes the 90th day following the last day a Participant had activity, open positions, or accruing obligations (other than reconciliations and true-ups), until such Participant has satisfactorily paid any obligations invoiced through such period and until PJM determines that the Participant's positions represent no risk exposure to the PJM Markets or the PJM Members. Obligations incurred or accrued through such period shall survive any withdrawal from PJM. When an Event of Default under this Attachment Q or one or more of the Agreements has occurred and is continuing, PJM may apply any Collateral to such Participant's Obligations, even if Participant had previously announced and effected its withdrawal from PJM.

X. FTRS UNDER THE COMMODITY EXCHANGE ACT AND THE BANKRUPTCY CODE

Under the terms of the Tariff, PJM Settlement is the counterparty to all transactions in PJM Markets, including but not limited to all FTR transactions, other than (i) any bilateral

transactions between Participants, or (ii) with respect to self-supplied or self-scheduled transactions reported to the Office of the Interconnection. Pursuant to the “Final Order in Response to a Petition From Certain Independent System Operators and Regional Transmission Organizations To Exempt Specified Transactions Authorized by a Tariff or Protocol Approved by the Federal Energy Regulatory Commission or the Public Utility Commission of Texas From Certain Provisions of the Commodity Exchange Act Pursuant to the Authority Provided in the Act” 78 Fed. Reg. 19880 (April 2, 2013) (the “CFTC RTO/ISO Order”), the Commodity Futures Trading Commission (the “CFTC”) exempts transactions offered or entered into in a market administered by PJM pursuant to the Tariff, including but not limited to FTR transactions, from the provisions of the Commodity Exchange Act and the CFTC’s rules applicable to “swaps,” with the exception of the CFTC’s general anti-fraud and anti-manipulation authority and scienter-based prohibitions.

Notwithstanding the CFTC RTO/ISO Order, for purposes of the United States Bankruptcy Code (“Bankruptcy Code”), all FTR transactions constitute “swap agreements” and/or “forward contracts,” and PJM and each FTR Participant is a “forward contract merchant” and/or a “swap participant” within the meaning of the Bankruptcy Code for purposes of FTR transactions.

Pursuant to this Attachment Q and other provisions of the Agreements, PJM already has, and shall continue to have, the following rights (among other rights) with respect to a Market Participant’s Event of Default: (a) the right to terminate and/or liquidate any FTR transaction held by that Market Participant; (b) the right to immediately proceed against any Collateral provided by the Market Participant; (c) the right to set-off any obligations due or owing to that Market Participant pursuant to any forward contract, swap agreement, or similar agreement against any amounts due and owing by that Market Participant pursuant to any forward contract, swap agreement, or similar agreement, such arrangement to constitute a “master netting agreement” within the meaning of the Bankruptcy Code; and (d) the right to suspend or limit that Market Participant from entering into further FTR transactions.

For the avoidance of doubt, upon the commencement of a voluntary or involuntary proceeding for a Participant under the Bankruptcy Code, and without limiting any other rights of PJM or obligations of any Participant under the Agreements, PJM may exercise any of its rights against such Participant, including, without limitation (1) the right to terminate and/or liquidate any FTR transaction held by that Participant, (2) the right to immediately proceed against any Collateral provided by that Participant, (3) the right to set off any obligations due and owing to that Participant pursuant to any forward contract, swap agreement and/or master netting agreement against any amounts due and owing by that Participant with respect to an FTR transaction including as a result of the actions taken by PJM pursuant to (a) above, and 4) the right to suspend or limit that Participant from entering into future FTR transactions.

For purposes of the Bankruptcy Code, all transactions, including but not limited to FTR transactions, between PJM, on the one hand, and a Market Participant, on the other hand, are intended to be part of a single integrated agreement, and together with the Agreements constitute a “master netting agreement.”

Attachment Q
Appendix 1

PJM MINIMUM PARTICIPATION CRITERIA
ANNUAL OFFICER CERTIFICATION FORM

Participant Name: _____ ("Participant")

I, _____, a duly authorized officer of Participant, understanding that PJM Interconnection, L.L.C. and PJMSettlement, Inc. (“PJMSettlement”) are relying on this certification as evidence that Participant meets the minimum requirements set forth in the PJM Open Access Transmission Tariff (“PJM Tariff”), Attachment Q hereby certify that I have full authority to represent on behalf of Participant and further represent as follows, as evidenced by my initialing each representation in the space provided below:

1. All employees or agents transacting in markets or services provided pursuant to the PJM Tariff or PJM Amended and Restated Operating Agreement (“PJM Operating Agreement”) on behalf of the Participant have received appropriate training and are authorized to transact on behalf of Participant. As used in this representation, the term “appropriate” as used with respect to training means training that is (i) comparable to generally accepted practices in the energy trading industry, and (ii) commensurate and proportional in sophistication, scope and frequency to the volume of transactions and the nature and extent of the risk taken by the participant. _____

2. Participant has written risk management policies, procedures, and controls, approved by Participant’s independent risk management function and applicable to transactions in any PJM Markets in which it participates and for which employees or agents transacting in markets or services provided pursuant to the PJM Tariff or PJM Operating Agreement have been trained, that provide an appropriate, comprehensive risk management framework that, at a minimum, clearly identifies and documents the range of risks to which Participant is exposed, including, but not limited to credit risks, liquidity risks and market risks. As used in this representation, a Participant’s “independent risk management function” can include appropriate corporate persons or bodies that are independent of the Participant’s trading functions, such as a risk management committee, a risk officer, a Participant’s board or board committee, or a board or committee of the Participant’s parent company.
 - a. Participant is providing to PJM or PJMSettlement, in accordance with Tariff, Attachment Q, section III, with this Annual Officer Certification Form, a copy of its current governing risk management policies, procedures and controls applicable to its activities in any PJM Markets pursuant to Attachment Q or because there have been substantive changes made to such policies, procedures and controls applicable to its market activities since they were last provided to PJM. _____

 - b. If the risk management policies, procedures and controls applicable to Participant’s market activities submitted to PJM or PJMSettlement were submitted prior to the current certification, Participant certifies that no substantive changes have

been made to such policies, procedures and controls applicable to its market activities since such submission. _____

3. An FTR Participant must make either the following 3.a. or 3.b. additional representations, evidenced by the undersigned officer initialing either the one 3.a. representation or the four 3.b. representations in the spaces provided below:

- a. Participant transacts in PJM's FTR markets with the sole intent to hedge congestion risk in connection with either obligations Participant has to serve load or rights Participant has to generate electricity in the PJM Region ("physical transactions") and monitors all of the Participant's FTR market activity to endeavor to ensure that its FTR positions, considering both the size and pathways of the positions, are either generally proportionate to or generally do not exceed the Participant's physical transactions, and remain generally consistent with the Participant's intention to hedge its physical transactions. _____

- b. On no less than a weekly basis, Participant values its FTR positions and engages in a probabilistic assessment of the hypothetical risk of such positions using analytically based methodologies, predicated on the use of industry accepted valuation methodologies. _____

Such valuation and risk assessment functions are performed either by persons within Participant's organization independent from those trading in PJM's FTR markets or by an outside firm qualified and with expertise in this area of risk management. _____

Having valued its FTR positions and quantified their hypothetical risks, Participant applies its written policies, procedures and controls to limit its risks using industry recognized practices, such as value-at-risk limitations, concentration limits, or other controls designed to prevent Participant from purposefully or unintentionally taking on risk that is not commensurate or proportional to Participant's financial capability to manage such risk. _____

Exceptions to Participant's written risk policies, procedures and controls applicable to Participant's FTR positions are documented and explain a reasoned basis for the granting of any exception. _____

4. Participant has appropriate personnel resources, operating procedures and technical abilities to promptly and effectively respond to all PJM and PJMSettlement communications and directions. _____
5. Participant has demonstrated compliance with the Minimum Capitalization criteria set forth in Tariff, Attachment Q that are applicable to any PJM Markets in which Participant transacts, and is not aware of any change having occurred or being imminent that would invalidate such compliance. _____

6. All Participants must certify and initial in at least one of the five sections below:
- a. I certify that Participant qualifies as an “appropriate person” as that term is defined under section 4(c)(3), or successor provision, of the Commodity Exchange Act or an “eligible contract participant” as that term is defined under section 1a(18), or successor provision, of the Commodity Exchange Act. I certify that Participant will cease transacting in any PJM Markets and notify PJM and PJMSettlement immediately if Participant no longer qualifies as an “appropriate person” or “eligible contract participant.” _____

If providing audited financial statements, which shall be in US GAAP format or any other format acceptable to PJM, to support Participant’s certification of qualification as an “appropriate person:”

I certify, to the best of my knowledge and belief, that the audited financial statements provided to PJM and/or PJMSettlement present fairly, pursuant to such disclosures in such audited financial statements, the financial position of Participant as of the date of those audited financial statements. Further, I certify that Participant continues to maintain the minimum \$1 million total net worth and/or \$5 million total asset levels reflected in these audited financial statements as of the date of this certification. I acknowledge that both PJM and PJMSettlement are relying upon my certification to maintain compliance with federal regulatory requirements. _____

If not providing audited financial statements to support Participant’s certification of qualification as an “appropriate person,” Participant certifies that they qualify as an “appropriate person” under one of the entities defined in section 4(c)(3)(A)-(J) of the Commodities Exchange Act. _____

If providing audited financial statements, which shall be in US GAAP format or any other format acceptable to PJM, to support Participant’s certification of qualification as an “eligible contract participant:”

I certify, to the best of my knowledge and belief, that the audited financial statements provided to PJM and/or PJMSettlement present fairly, pursuant to such disclosures in such audited financial statements, the financial position of Participant as of the date of those audited financial statements. Further, I certify that Participant continues to maintain the minimum \$1 million total net worth and/or \$10 million total asset levels reflected in these audited financial statements as of the date of this certification. I acknowledge that both PJM and PJMSettlement are relying upon my certification to maintain compliance with federal regulatory requirements. _____

If not providing audited financial statements to support Participant’s certification of qualification as an “eligible contract participant,” Participant certifies that they

qualify as an “eligible contract participant” under one of the entities defined in section 1a(18)(A) of the Commodities Exchange Act. _____

- b. I certify that Participant has provided an unlimited Corporate Guaranty in a form acceptable to PJM as described in Tariff, Attachment Q, section III.D from an issuer that has at least \$1 million of total net worth or \$5 million of total assets per Participant for which the issuer has issued an unlimited Corporate Guaranty. I also certify, to the best of my knowledge and belief, that the audited financial statements provided to PJM and/or PJMSettlement present fairly, pursuant to such disclosures in such audited financial statements, the financial position of the issuer as of the date of those audited financial statements. Further, I certify that Participant will cease transacting PJM’s Markets and notify PJM and PJMSettlement immediately if issuer of the unlimited Corporate Guaranty for Participant no longer has at least \$1 million of total net worth or \$5 million of total assets per Participant for which the issuer has issued an unlimited Corporate Guaranty. _____

I certify that the issuer of the unlimited Corporate Guaranty to Participant continues to have at least \$1 million of total net worth or \$5 million of total assets per Participant for which the issuer has issued an unlimited Corporate Guaranty. I acknowledge that PJM and PJMSettlement are relying upon my certifications to maintain compliance with federal regulatory requirements. _____

- c. I certify that Participant fulfills the eligibility requirements of the Commodity Futures Trading Commission exemption order (78 F.R. 19880 – April 2, 2013) by being in the business of at least one of the following in the PJM Region as indicated below (initial those applicable):

1. Generating electric energy, including Participants that resell physical energy acquired from an entity generating electric energy: _____
2. Transmitting electric energy: _____
3. Distributing electric energy delivered under Point-to-Point or Network Integration Transmission Service, including scheduled import, export and wheel through transactions: _____
4. Other electric energy services that are necessary to support the reliable operation of the transmission system: _____

Description only if c(4) is initialed:

Further, I certify that Participant will cease transacting in any PJM Markets and notify PJM and PJMSettlement immediately if Participant no longer performs at least one of the functions noted above in the PJM Region. I acknowledge that PJM and

PJMSettlement are relying on my certification to maintain compliance with federal energy regulatory requirements. _____

- d. I certify that Participant has provided a Letter of Credit of \$5 million or more to PJM or PJMSettlement in a form acceptable to PJM and/or PJMSettlement as described in Tariff, Attachment Q, section V.B that the Participant acknowledges cannot be utilized to meet its credit requirements to PJM and PJMSettlement. I acknowledge that PJM and PJMSettlement are relying on the provision of this letter of credit and my certification to maintain compliance with federal regulatory requirements. _____
 - e. I certify that Participant has provided a surety bond of \$5 million or more to PJM or PJMSettlement in a form acceptable to PJM and/or PJMSettlement as described in Tariff, Attachment Q, section V.D. that the Participant acknowledges cannot be utilized to meet its credit requirements to PJM and PJMSettlement. I acknowledge that PJM and PJMSettlement are relying on the provision of this surety bond and my certification to maintain compliance with federal regulatory requirements. _____
7. I acknowledge that I have read and understood the provisions of Tariff, Attachment Q applicable to Participant's business in any PJM Markets, including those provisions describing PJM's Minimum Participation Requirements and the enforcement actions available to PJM and PJMSettlement of a Participant not satisfying those requirements. I acknowledge that the information provided herein is true and accurate to the best of my belief and knowledge after due investigation. In addition, by signing this certification, I acknowledge the potential consequences of making incomplete or false statements in this Certification. _____

Date: _____

Participant (Signature)

Print Name: _____

Title: _____

6.4 Market Seller Offer Caps

(a) The Market Seller Offer Cap, stated in dollars per MW/day of unforced capacity, applicable to price-quantity offers within the Base Offer Segment for an Existing Generation Capacity Resource shall be the Avoidable Cost Rate for such resource, less the Projected PJM Market Revenues for such resource, stated in dollars per MW/day of unforced capacity. A Capacity Market Seller offering above \$0/MW-day must support and obtain approval of a unit-specific Market Seller Offer Cap pursuant to the procedures and standards of subsection (b) of this section 6.4 or may, at its election, if available, utilize a Market Seller Offer Cap determined using the applicable default gross Avoidable Cost Rate for the applicable resource type shown in the table below, as adjusted for Delivery Years subsequent to the 2022/2023 or 2026/2027 Delivery Year, as applicable, to reflect changes in avoidable costs, net of ~~projected~~ Projected PJM ~~market~~ Market revenues ~~Revenues~~ equal to the resource's net energy and ancillary service revenues for the resource type, as determined in accordance with Tariff, Attachment DD, section 6.8(d-1).

Existing Resource Type	Through the 2025/2026 Delivery Years: Default Gross ACR (2022/2023) (\$/MW-day) (Nameplate)	For the 2026/2027 Delivery Year and Subsequent Delivery Years: Default Gross ACR (2026/2027) (\$/MW-day) (Nameplate)
Nuclear – single	\$697	\$591
Nuclear – dual	\$445	\$537
Coal	\$80	\$94
Combined Cycle	\$56	\$113
Combustion Turbine	\$50	\$52
Steam Oil & Gas	NA	\$64
Solar PV (fixed and tracking)	\$40	\$70
Wind Onshore	\$83	\$147

The Market Seller Offer Cap for an Existing Generation Capacity Resource shall be the Opportunity Cost for such resource, if applicable, as determined in accordance with Tariff, Attachment DD, section 6.7.

(b) For each Existing Generation Capacity Resource, a potential Capacity Market Seller must provide to the Market Monitoring Unit and the Office of the Interconnection data and documentation required under section 6.7 below to establish the level of the Market Seller Offer Cap applicable to each resource by no later than one hundred twenty (120) days prior to the commencement of the offer period for the applicable RPM Auction. The Capacity Market Seller must promptly address any concerns identified by the Market Monitoring Unit regarding the data and documentation provided, review the Market Seller Offer Cap proposed by the Market Monitoring Unit, and attempt to reach agreement with the Market Monitoring Unit on the level of the Market Seller Offer Cap by no later than ninety (90) days prior to the commencement of

the offer period for the applicable RPM Auction. The Capacity Market Seller shall notify the Market Monitoring Unit in writing, with a copy to the Office of the Interconnection, whether an agreement with the Market Monitoring Unit has been reached or, if no agreement has been reached, specifying the level of Market Seller Offer Cap to which it commits by no later than eighty (80) days prior to the commencement of the offer period for the applicable RPM Auction. The Office of the Interconnection shall review the data submitted by the Capacity Market Seller, make a determination whether to accept or reject the requested unit-specific Market Seller Offer Cap, and notify the Capacity Market Seller and the Market Monitoring Unit of its determination in writing, by no later than sixty-five (65) days prior to the commencement of the offer period for the applicable RPM Auction. In the event the Office of the Interconnection rejects the Capacity Market Seller's requested unit-specific Market Seller Offer Cap for a particular Capacity Resource, the Capacity Market Seller of such Capacity Resource may submit an offer up to (1) should one exist, the default gross Avoidable Cost Rate for the applicable resource type net of ~~P~~projected PJM ~~market~~ ~~Market revenues~~ ~~Revenues~~ equal to the resource's net energy and ancillary service revenues for the resource type, or (2) the unit-specific Market Seller Offer Cap proposed by the Market Monitoring Unit upon PJM approval of such value. If the Market Monitoring Unit does not provide its determination to the Capacity Market Seller and the Office of the Interconnection by the specified deadline, by no later than sixty-five (65) days prior to the commencement of the offer period for the applicable RPM Auction the Office of the Interconnection will make the determination of the level of the Market Seller Offer Cap, which shall be deemed to be final. If the Capacity Market Seller does not notify the Market Monitoring Unit and the Office of the Interconnection of the Market Seller Offer Cap it desires to utilize by no later than eighty (80) days prior to the commencement of the offer period for the applicable RPM Auction, it shall be required to utilize a Market Seller Offer Cap determined using the applicable default Avoidable Cost Rate specified in section 6.4(a) above.

Notwithstanding the provisions of Tariff, Attachment M-Appendix, section II.E.2 and this Tariff, Attachment DD, section 6.4(b), no later than eighty (80) days prior to the commencement of the offer period for the auction, the Market Monitoring Unit and the relevant Capacity Market Seller may mutually agree on the value of such Market Seller Offer Cap. Nothing herein shall preclude the Market Monitoring Unit from modifying the Market Seller Offer Cap for a Generation Capacity Resource beyond the eighty-day (80-day) deadline prior to the commencement of the offer period for the auction, through the commencement of the offer period for the auction, so long as the Market Monitoring Unit and the relevant Capacity Market Seller mutually agree with the value of such Market Seller Offer Cap. The Capacity Market Seller shall notify the Market Monitoring Unit in writing, with a copy to the Office of the Interconnection, if such an agreement with the Market Monitoring Unit has been reached. The Office of the Interconnection shall review the Market Seller Offer Cap submitted by the Capacity Market Seller and make a determination whether the Market Seller Offer Cap complies with the tariff, and notify the Capacity Market Seller and the Market Monitoring Unit of its determination.

(c) Nothing in this section precludes the Capacity Market Seller from filing a petition with FERC seeking a determination of whether the Sell Offer complies with the requirements of the Tariff.

(d) For any Third Incremental Auction for the 2018/2019 Delivery Year or any subsequent Delivery Year, the Market Seller Offer Cap for an Existing Generation Capacity Resource offering as a Capacity Performance Resource shall be determined pursuant to subsection (a) of this Section 6.4, or if elected by the Capacity Market Seller, shall be equal to 1.1 times the Capacity Resource Clearing Price in the Base Residual Auction for the relevant LDA and Delivery Year.

6.5 Mitigation

The Office of the Interconnection shall apply market power mitigation measures in any Base Residual Auction or Incremental Auction for any LDA, Unconstrained LDA Group, or the PJM Region that fails the Market Structure Test.

(a) Mitigation for Generation Capacity Resources.

i) Existing Generation Capacity Resource

Mitigation will be applied on a unit-specific basis and only if the Sell Offer of Unforced Capacity from an Existing Generation Capacity Resource: (1) is greater than \$0/MW-day, except as described in Tariff, Attachment DD, section 6.4(a); and (2) would, absent mitigation, increase the Capacity Resource Clearing Price in the relevant auction. If such conditions are met, such Sell Offer shall be set equal to the Market Seller Offer Cap.

ii) Planned Generation Capacity Resources

(A) Sell Offers based on Planned Generation Capacity Resources (including External Planned Generation Capacity Resources) shall be presumed to be competitive and shall not be subject to market power mitigation in any Base Residual Auction or Incremental Auction for which such resource qualifies as a Planned Generation Capacity Resource, but any such Sell Offer shall be rejected if it meets the criteria set forth in subsection (C) below, unless the Capacity Market Seller obtains approval from FERC for use of such offer prior to the close of the offer period for the applicable RPM Auction.

(B) Sell Offers based on Planned Generation Capacity Resources (including Planned External Generation Capacity Resources) shall be deemed competitive and not be subject to mitigation if: (1) collectively all such Sell Offers provide Unforced Capacity in an amount equal to or greater than two times the incremental quantity of new entry required to meet the LDA Reliability Requirement; and (2) at least two unaffiliated suppliers have submitted Sell Offers for Planned Generation Capacity Resources in such LDA. Notwithstanding the foregoing, any Capacity Market Seller, together with ~~Affiliates~~affiliates, whose Sell Offers based on Planned Generation Capacity Resources in that modeled LDA are pivotal, shall be subject to mitigation.

(C) Where the two conditions stated in subsection (B) above are not met, or the Sell Offer is pivotal, the Sell Offer shall be rejected if it exceeds 140 percent of: 1) the average of location-adjusted Sell Offers for Planned Generation Capacity Resources from the same asset class as such Sell Offer, submitted (and not rejected) (Asset-Class New Plant Offers) for such Delivery Year; or 2) if there are no Asset-Class New Plant Offers

for such Delivery Year, the average of Asset-Class New Plant Offers for all prior Delivery Years; or 3) if there are no Asset-Class New Plant Offers for any prior Delivery Year, the Net CONE applicable for such Delivery Year in the LDA for which such Sell Offer was submitted. For purposes of this section, asset classes shall be as stated in section 6.7(c) below as effective for such Delivery Year, and Asset-Class New Plant Offers shall be location-adjusted by the ratio between the Net CONE effective for such Delivery Year for the LDA in which the Sell Offer subject to this section was submitted and the average, weighted by installed capacity, of the Net CONEs for all LDAs in which the units underlying such Asset Class New Plant Offers are located. Following the conduct of the applicable auction and before the final determination of clearing prices, in accordance with Section 6.2(b) above, each Capacity Market Seller whose Sell Offer is so rejected shall be notified in writing by the Office of the Interconnection by no later than one (1) Business Day after the close of the offer period for the applicable RPM Auction and allowed an opportunity to submit a revised Sell Offer that does not exceed such threshold within one (1) Business Day of the Office of the Interconnection's rejection of such Sell Offer. If such revised Sell Offer is accepted by the Office of the Interconnection, the Office of the Interconnection then shall clear the auction with such revised Sell Offer in place. Pursuant to Tariff, Attachment M-Appendix, Section II.F, the Market Monitoring Unit shall notify in writing each Capacity Market Seller whose Sell Offer has been determined to be non-competitive and subject to mitigation, with a copy to the Office of the Interconnection, by no later than one (1) Business Day after the close of the offer period for the applicable RPM Auction.

(b) Mitigation for Demand Resources

The Market Seller Offer Cap shall not be applied to Sell Offers of Demand Resources or Energy Efficiency Resources.

6.6 Offer Requirement for Capacity Resources

(a) To avoid application of subsection (h) below, all of the installed capacity of all Existing Generation Capacity Resources located in the PJM Region shall be offered by the Capacity Market Seller that owns or controls all or part of such resource (which may include submission as Self-Supply) in all RPM Auctions for each Delivery Year, less any amount determined by the Office of the Interconnection to be eligible for an exception to this RPM must-offer requirement, where installed capacity is determined as of the date on which bidding commences for each RPM Auction pursuant to Tariff, Attachment DD, section 5.6.6. The Unforced Capacity of such resources is determined using the EFORD value that is submitted by the Capacity Market Seller in its Sell Offer, which shall not exceed the maximum EFORD for that resource as defined in section 6.6(b). If a resource should be included on the list of Existing Generation Capacity Resources subject to the RPM must-offer requirement that is maintained by the Market Monitoring Unit pursuant to Tariff, Attachment M-Appendix, section II.C.1, but is omitted therefrom whether by mistake of the Market Monitoring Unit or failure of the Capacity Market Seller that owns or controls all or part of such resource to provide information about the resource to the Market Monitoring Unit, this shall not excuse such resource from the RPM must-offer requirement.

(b) For each Existing Generation Capacity Resource, a potential Capacity Market Seller must timely provide to the Market Monitoring Unit and the Office of the Interconnection all data and documentation required under this section 6.6 to establish the maximum EFORD applicable to each resource in accordance with standards and procedures specified in the PJM Manuals. The maximum EFORD that may be used in a Sell Offer for RPM Auctions held prior to the date on which the final EFORDs used for a Delivery Year are posted, is the greater of (i) the average EFORD for the five consecutive years ending on the September 30 that last precedes the Base Residual Auction, or (ii) the EFORD for the 12 months ending on the September 30 that last precedes the Base Residual Auction.

Notwithstanding the foregoing, a Capacity Market Seller may request an alternate maximum EFORD for Sell Offers submitted in such auctions if it has a documented, known reason that would result in an increase in its EFORD, by submitting a written request to the Market Monitoring Unit and Office of the Interconnection, along with data and documentation required to support the request for an alternate maximum EFORD, by no later one hundred twenty (120) days prior to the commencement of the offer period for the Base Residual Auction for the applicable Delivery Year. The Capacity Market Seller must address any concerns identified by the Market Monitoring Unit and/or the Office of the Interconnection regarding the data and documentation provided and attempt to reach agreement with the Market Monitoring Unit on the level of the alternate maximum EFORD by no later than ninety (90) days prior to the commencement of the offer period for the Base Residual Auction for the applicable Delivery Year. As further described in Tariff, Attachment M-Appendix, section II.C, the Market Monitoring Unit shall notify the Capacity Market Seller and the Office of the Interconnection in writing of its determination of the requested alternate maximum EFORD by no later than ninety (90) days prior to the commencement of the offer period for the Base Residual Auction for the applicable Delivery Year. By no later than eighty (80) days prior to the commencement of the offer period for the Base Residual Auction for the applicable Delivery Year, the Capacity Market

Seller shall notify the Office of the Interconnection and the Market Monitoring Unit in writing whether it agrees with the Market Monitoring Unit on the alternate maximum EFORd or, if no agreement has been reached, specifying the level of alternate maximum EFORd to which it commits. If a Capacity Market Seller fails to request an alternate maximum EFORd prior to the specified deadlines, the maximum EFORd for the applicable RPM Auction shall be deemed to be the default EFORd calculated pursuant to this section.

The maximum EFORd that may be used in a Sell Offer for Third Incremental Auction, and for Conditional Incremental Auctions held after the date on which the final EFORd used for a Delivery Year is posted, is the EFORd for the 12 months ending on the September 30 that last precedes the submission of such offers.

(c) [Reserved for Future Use]

(d) In the event that a Capacity Market Seller and the Market Monitoring Unit cannot agree on the maximum level of the alternate EFORd that may be used in a Sell Offer for RPM Auctions held prior to the date on which the final EFORds used for a Delivery Year are posted, the Office of the Interconnection shall make its own determination of the maximum level of the alternate EFORd based on the requirements of the Tariff and the PJM Manuals, per Tariff, Attachment DD, section 5.8, by no later than sixty-five (65) days prior to the commencement of the offer period for the Base Residual for the applicable Delivery Year, and shall notify the Capacity Market Seller and the Market Monitoring Unit in writing of such determination.

(e) Nothing in this section precludes the Capacity Market Seller from filing a petition with FERC seeking a determination of whether the EFORd complies with the requirements of the Tariff.

(f) Notwithstanding the foregoing, a Capacity Market Seller may submit an EFORd that it chooses for an RPM Auction held prior to the date on which the final EFORd used for a Delivery Year is posted, provided that (i) it has participated in good faith with the process described in this section 6.6 and in Tariff, Attachment M-Appendix, section II.C, (ii) the offer is no higher than the level defined in any agreement reached by the Capacity Market Seller and the Market Monitoring Unit that resulted from the foregoing process, and (iii) the offer is accepted by the Office of the Interconnection subject to the criteria set forth in the Tariff and the PJM Manuals.

(g) A Capacity Market Seller that owns or controls an existing generation resource in the PJM Region that is capable of qualifying as an Existing Generation Capacity Resource as of the date on which bidding commences for an RPM Auction may not avoid the rule in subsection (a) or be removed from Capacity Resource status by failing to qualify as a Generation Capacity Resource, or by attempting to remove a unit previously qualified as a Generation Capacity Resource from classification as a Capacity Resource for that RPM Auction. However, generation resource may qualify for an exception to the RPM must-offer requirement, as shown by appropriate documentation, if the Capacity Market Seller that owns or controls such resource demonstrates that it: (i) is reasonably expected to be physically unable to participate in the relevant Delivery Year; (ii) has a financially and physically firm commitment to an external sale

of its capacity, or (iii) was interconnected to the Transmission System as an Energy Resource and not subsequently converted to a Capacity Resource.

In order to establish that a resource is reasonably expected to be physically unable to participate in the relevant auction as set forth in (i) above, the Capacity Market Seller must demonstrate that:

- A. It has a documented plan in place to retire the resource prior to or during the Delivery Year, and has submitted a notice of Deactivation to the Office of the Interconnection consistent with Tariff, Part V, section 113.1, without regard to whether the Office of the Interconnection has requested the Capacity Market Seller to continue to operate the resource beyond its desired deactivation date in accordance with Tariff, Part V, section 113.2 for the purpose of maintaining the reliability of the PJM Transmission System and the Capacity Market Seller has agreed to do so;
- B. Significant physical operational restrictions cause long term or permanent changes to the installed capacity value of the resource, or the resource is under major repair that will extend into the applicable Delivery Year, that will result in the imposition of RPM performance penalties pursuant to Tariff, Attachment DD;
- C. The Capacity Market Seller is involved in an ongoing regulatory proceeding (e.g. – regarding potential environmental restrictions) specific to the resource and has received an order, decision, final rule, opinion or other final directive from the regulatory authority that will result in the retirement of the resource; or
- D. A resource considered an Existing Generating Capacity Resource because it cleared an RPM Auction for a Delivery Year prior to the Delivery Year of the relevant auction, but which is not yet in service, is unable to achieve full commercial operation prior to the Delivery Year of the relevant auction. The Capacity Market Seller must submit to the Office of the Interconnection and the Market Monitoring Unit a written sworn, notarized statement of a corporate officer certifying that the resource will not be in full commercial operation prior to the referenced Delivery Year.

In order to establish that a resource has a financially and physically firm commitment to an external sale of its capacity as set forth in (ii) above, the Capacity Market Seller must demonstrate that it has entered into a unit-specific bilateral transaction for service to load located outside the PJM Region, by a demonstration that such resource is identified on a unit-specific basis as a network resource under the transmission tariff for the control area applicable to such external load, or by an equivalent demonstration of a financially and physically firm commitment to an external sale. The Capacity Market Seller additionally shall identify the megawatt amount, export zone, and time period (in days) of the export.

A Capacity Market Seller that seeks approval for an exception to the RPM must-offer requirement, for any reason other than the reason specified in Paragraph A above, shall first submit such request in writing, along with all supporting data and documentation, to the Market Monitoring Unit for evaluation, notifying the Office of the Interconnection by copy of the same,

by no later than one hundred twenty (120) days prior to the commencement of the offer period for the applicable RPM Auction.

In order to obtain an exception to the RPM must-offer requirement for the reason specified in Paragraph A above, a Capacity Market Seller shall first submit a preliminary exception request in writing, along with supporting data and documentation indicating the reasons and conditions upon which the Capacity Market Seller is relying in its analysis of whether to retire such resource, to the Market Monitoring Unit for evaluation, notifying the Office of the Interconnection by copy of the same, by no later than (a) November 1, 2013 for the Base Residual Auction for the 2017/2018 Delivery Year, (b) the September 1 that last precedes the Base Residual Auction for the 2018/2019 and subsequent Delivery Years, and (c) two hundred forty (240) days prior to the commencement of the offer period for the applicable Incremental Auction. By no later than five (5) Business Days after ~~receipt of the notification deadline for~~ any such preliminary exception requests, the Office of the Interconnection will post on its website a summary of the number of megawatts of Generation Capacity Resources for which it has received notification of preliminary exception requests, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.

Thereafter, as applicable, such Capacity Market Seller shall by no later than (a) the December 1 that last precedes the Base Residual Auction for the applicable Delivery Year, or (b) one hundred twenty (120) days prior to the commencement of the offer period for the applicable Incremental Auction, either (a) notify the Office of the Interconnection and the Market Monitoring Unit in writing that it is withdrawing its preliminary exception request and explaining the changes to its analysis of whether to retire such resource that support its decision to withdraw, or (b) demonstrate that it has met the requirements specified under Paragraph A above. By no later than five (5) Business Days after ~~receipt of the notification deadline for~~ such notification, the Office of the Interconnection will post on its website a revised summary of the number of megawatts of Generation Capacity Resources for which it has received requests for exceptions to the RPM must-offer requirement for the reason specified in Paragraph A above, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.

A Capacity Market Seller that seeks to remove a Generation Capacity Resource from Capacity Resource status shall first submit a preliminary request in writing, along with supporting data and documentation indicating the reasons and conditions upon which the Capacity Market Seller is relying in its analysis of whether to remove the Capacity Resource status of such resource to the Market Monitoring Unit for evaluation, notifying the Office of the Interconnection by copy of the same, by no later than (a) the September 1 that last precedes the Base Residual Auction, and (b) two hundred forty (240) days prior to the commencement of the offer period for the applicable Incremental Auction. For the Base Residual Auction for the 2023/2024 Delivery Year, a Capacity Market Seller that seeks to remove a Generation Capacity Resource from Capacity Resource status shall first submit such preliminary request by no later than November 1, 2019. By no later than five (5) Business Days after ~~receipt of the notification deadline for~~ any such preliminary requests, the Office of the Interconnection will post on its website a summary of the number of megawatts of Generation Capacity Resources for which it

has received notification of preliminary requests, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.

Thereafter, as applicable, such Capacity Market Seller shall, by no later than (a) the December 1 that last precedes the Base Residual Auction for the applicable Delivery Year, or (b) one hundred twenty (120) days prior to the commencement of the offer period for the applicable Incremental Auction, notify the Office of the Interconnection and the Market Monitoring Unit in writing that it is either (a) withdrawing its preliminary request and explaining the changes to its analysis that support its decision to withdraw, or (b) confirming its preliminary decision to remove the Generation Capacity Resource from Capacity Resource status. By no later than five (5) Business Days after ~~receipt of the notification deadline for~~ such notification, the Office of the Interconnection will post on its website a revised summary of the number of megawatts of Generation Capacity Resources for which it has received requests to remove its Capacity Resource status, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.

The Market Monitoring Unit shall analyze the effects of the proposed removal of a Generation Capacity Resource from Capacity Resource status with regard to potential market power issues and shall notify the Capacity Market Seller and the Office of the Interconnection in writing of its determination of the request to remove the Generation Capacity Resource from Capacity Resource status, and whether a market power issue has been identified, by no later than ninety (90) days prior to the commencement of the offer period for the applicable RPM Auction. Such notice shall include the specific market power impact resulting from the proposed removal of the Generation Capacity Resource from Capacity Resource status, as well as an initial assessment of any steps that could be taken to mitigate the market power impact.

A Capacity Market Seller may only remove the Generation Capacity Resource from Capacity Resource status if (i) the Market Monitoring Unit has determined that the Generation Capacity Resource meets the applicable criteria set forth in Tariff, Attachment DD, sections 5.6.6 and this section 6.6 and the Office of the Interconnection agrees with this determination, or (ii) the Commission has issued an order terminating the Capacity Resource status of the resource, or (iii) it is required as set forth in Tariff, Attachment DD, section 6.6A(c). Nothing herein shall require a Market Seller to offer its resource into an RPM Auction prior to seeking to remove a resource from Capacity Resource status, subject to satisfaction of this section 6.6. A Generation Capacity Resource that is removed from Capacity Resource status shall no longer qualify as an Existing Generation Capacity Resource, and the Capacity Interconnection Rights associated with such facility shall be subject to termination in accordance with the rules described in Tariff, Part VI, section 230.3.3. The Office of the Interconnection shall amend the applicable Interconnection Service Agreement or wholesale market participation agreement to reflect any such removal of the Capacity Interconnection Rights, and shall report the amended agreement to the Commission in the same manner as the original (e.g., FERC filing or Electronic Quarterly Reports). The Office of the Interconnection shall file the amended agreement unexecuted if the Interconnection Customer or wholesale market participant does not sign the amended Interconnection Service Agreement or wholesale market participation agreement.

If the Capacity Market Seller disagrees with the Market Monitoring Unit's determination of its request to remove a resource from Capacity Resource status or its request for an exception

to the RPM must-offer requirement, it must notify the Market Monitoring Unit in writing, with a copy to the Office of the Interconnection, of the same by no later than eighty (80) days prior to the commencement of the offer period for the applicable RPM Auction. After the Market Monitoring Unit has made its determination of whether a resource may be removed from Capacity Resource status, or whether the resource meets one of the exceptions thereto, and has notified the Capacity Market Seller and the Office of the Interconnection of the same pursuant to Tariff, Attachment M-Appendix, section II.C.4, the Office of the Interconnection shall approve or deny the request. The request shall be deemed to be approved by the Office of the Interconnection, consistent with the determination of the Market Monitoring Unit, unless the Office of the Interconnection notifies the Capacity Market Seller and Market Monitoring Unit, by no later than sixty-five (65) days prior to the date on which the offer period for the applicable RPM Auction commences, that the request is denied.

If the Market Monitoring Unit does not timely notify the Capacity Market Seller and the Office of the Interconnection of its determination of the request to remove a Generation Capacity Resource from Capacity Resource status or for an exception to the RPM must-offer requirement, the Office of the Interconnection shall make the determination whether the request shall be approved or denied, and will notify the Capacity Market Seller of its determination in writing, with a copy to the Market Monitoring Unit, by no later than sixty-five (65) days prior to the date on which the offer period for the applicable RPM Auction commences.

After the Market Monitoring Unit and the Office of the Interconnection have made their determinations of whether a resource meets the criteria to qualify for an exception to the RPM must-offer requirement, the Capacity Market Seller must notify the Market Monitoring Unit and the Office of the Interconnection whether it intends to exclude from its Sell Offer some or all of the subject capacity on the basis of an identified exception by no later than sixty-five (65) days prior to the date on which the offer period for the applicable RPM Auction commences. PJM does not make determinations of whether withholding of capacity constitutes market power. A Generation Capacity Resource that does not qualify for submission into an RPM Auction because it is not owned or controlled by the Capacity Market Seller for a full Delivery Year is not subject to the offer requirement hereunder; provided, however, that a Capacity Market Seller planning to transfer ownership or control of a Generation Capacity Resource during a Delivery Year pursuant to a sale or transfer agreement entered into after March 26, 2009 shall be required to satisfy the offer requirement hereunder for the entirety of such Delivery Year and may satisfy such requirement by providing for the assumption of this requirement by the transferee of ownership or control under such agreement.

If a Capacity Market Seller doesn't timely seek to remove a Generation Capacity Resource from Capacity Resource status or timely submit a request for an exception to the RPM must-offer requirement, the Generation Capacity Resource shall only be removed from Capacity Resource status, and may only be approved for an exception to the RPM must-offer requirement, upon the Capacity Market Seller requesting and receiving an order from FERC, prior to the close of the offer period for the applicable RPM Auction, directing the Office of the Interconnection to remove the resource from Capacity Resource status and/or granting an exception to the RPM must-offer requirement or a waiver of the RPM must-offer requirement as to such resource.

(h) Any existing generation resource located in the PJM Region that satisfies the criteria in the definition of Existing Generation Capacity Resource as of the date on which bidding commences for the Base Residual Auction for a Delivery Year, that is not offered into such Base Residual Auction, and that does not meet any of the exceptions stated in the prior subsection (g): (i) may not participate in any subsequent Incremental Auctions conducted for such Delivery Year; (ii) shall not receive any payments under Tariff, Attachment DD, section 5.14 for such Delivery Year for the capacity of such Generation Capacity Resources; and (iii) shall not be permitted to satisfy any LSE's Unforced Capacity Obligation, or any entity's obligation to obtain the commitment of Capacity Resources, for such Delivery Year.

All generation resources located in the PJM Region that satisfy the criteria in the definition of Existing Generation Capacity Resource as of the date on which bidding commences for an Incremental Auction for a particular Delivery Year, but that did not satisfy such criteria as of the date that on which bidding commenced in the Base Residual Auction for that Delivery Year, that is not offered into that Incremental Auction, and that does not meet any of the exceptions stated in the prior subsection (g): (i) may not participate in any subsequent Incremental Auctions conducted for such Delivery Year; (ii) shall not receive any payments under Tariff, Attachment DD, section 5.14 for such Delivery Year for the capacity of such Generation Capacity Resources; and (iii) shall not be permitted to satisfy any LSE's Unforced Capacity Obligation, or any entity's obligation to obtain the commitment of Capacity Resources, for such Delivery Year.

All Existing Generation Capacity Resources that are offered into a Base Residual Auction or Incremental Auction for a particular Delivery Year but do not clear in such auction, that are not offered into each subsequent Incremental Auction, and that do not meet any of the exceptions stated in the prior subsection (g): (i) may not participate in any Incremental Auctions conducted for such Delivery Year subsequent to such failure to offer; (ii) shall not receive any payments under Tariff, Attachment DD, section 5.14 for such Delivery Year for the capacity of such Generation Capacity Resources; and (iii) shall not be permitted to satisfy any LSE's Unforced Capacity Obligation, or any entity's obligation to obtain the commitment of Capacity Resources, for such Delivery Year.

Any such Existing Generation Capacity Resources may also be subject to further action by the Market Monitoring Unit under the terms of Tariff, Attachment M and Tariff, Attachment M – Appendix.

(i) In addition to the remedies set forth in subsections (g) and (h) above, if the Market Monitoring Unit determines that one or more Capacity Market Sellers' failure to offer part or all of one or more existing generation resources, for which the Office of the Interconnection has not approved an exception to the RPM must-offer requirement, into an RPM Auction as required by this Section 6.6 would result in an increase of greater than five percent in any Zonal Capacity Price determined through such auction, and the Office of the Interconnection agrees with that determination, the Office of the Interconnection shall apply to FERC for an order, on an expedited basis, directing such Capacity Market Seller to participate in the relevant RPM Auction, or for other appropriate relief, and PJM will postpone clearing the auction pending FERC's decision on the matter. If the Office of the Interconnection disagrees with the

Market Monitoring Unit's determination and does not apply to FERC for an order directing the Capacity Market Seller to participate in the auction or for other appropriate relief, the Market Monitoring Unit may exercise its powers to inform Commission staff of its concerns and to seek appropriate relief.

Definitions C - D

Capacity Resource:

“Capacity Resource” shall have the meaning provided in the Reliability Assurance Agreement.

Capacity Storage Resource:

“Capacity Storage Resource” shall mean any Energy Storage Resource that participates in the Reliability Pricing Model or is otherwise treated as capacity in PJM’s markets such as through a Fixed Resource Requirement Capacity Plan.

Catastrophic Force Majeure:

“Catastrophic Force Majeure” shall not include any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, or ~~Curtailment~~curtailment, order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, unless as a consequence of any such action, event, or combination of events, either (i) all, or substantially all, of the Transmission System is unavailable, or (ii) all, or substantially all, of the interstate natural gas pipeline network, interstate rail, interstate highway or federal waterway transportation network serving the PJM Region is unavailable. The Office of the Interconnection shall determine whether an event of Catastrophic Force Majeure has occurred for purposes of this Agreement, the PJM Tariff, and the Reliability Assurance Agreement, based on an examination of available evidence. The Office of the Interconnection’s determination is subject to review by the Commission.

Charge Economic Maximum Megawatts:

“Charge Economic Maximum Megawatts” shall mean the greatest magnitude of megawatt power consumption available for charging in economic dispatch by an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource in Continuous Mode or in Charge Mode. Charge Economic Maximum Megawatts shall be the Economic Minimum for an Energy Storage Resource or solar-storage Open-Loop Hybrid Resource in Charge Mode or in Continuous Mode.

Charge Economic Minimum Megawatts:

“Charge Economic Minimum Megawatts” shall mean the smallest magnitude of megawatt power consumption available for charging in economic dispatch by an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource in Charge Mode. Charge Economic Minimum Megawatts shall be the Economic Maximum for an Energy Storage Resource or solar-storage Open-Loop Hybrid Resource in Charge Mode.

Charge Mode:

“Charge Mode” shall mean the mode of operation of an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource that only includes negative megawatt quantities (i.e., the Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource is only withdrawing megawatts from the grid).

Charge Ramp Rate:

“Charge Ramp Rate” shall mean the Ramping Capability of an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource in Charge Mode.

Closed-Loop Hybrid Resource:

“Closed-Loop Hybrid Resource” shall mean a Hybrid Resource that is physically or contractually incapable of charging from the grid.

Cold/Warm/Hot Notification Time:

“Cold/Warm/Hot Notification Time” shall mean the time interval between PJM notification and the beginning of the start sequence for a generating unit that is currently in its cold/warm/hot temperature state. The start sequence may include steps such as any valve operation, starting feed water pumps, startup of auxiliary equipment, etc.

Cold/Warm/Hot Start-up Time:

For all generating units that are not combined cycle units, “Cold/Warm/Hot Start-up Time” shall mean the time interval, measured in hours, from the beginning of the start sequence to the point after generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero for a generating unit in its cold/warm/hot temperature state. For combined cycle units, “Cold/Warm/Hot Start-up Time” shall mean the time interval from the beginning of the start sequence to the point after first combustion turbine generator breaker closure in its cold/warm/hot temperature state, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero. For all generating units, the start sequence may include steps such as any valve operation, starting feed water pumps, startup of auxiliary equipment, etc. Other more detailed actions that could signal the beginning of the start sequence could include, but are not limited to, the operation of pumps, condensers, fans, water chemistry evaluations, checklists, valves, fuel systems, combustion turbines, starting engines or systems, maintaining stable fuel/air ratios, and other auxiliary equipment necessary for startup.

Cold Weather Alert:

“Cold Weather Alert” shall mean the notice that PJM provides to PJM Members, Transmission Owners, resource owners and operators, customers, and regulators to prepare personnel and facilities for expected extreme cold weather conditions.

Co-Located Resource:

“Co-Located Resource” shall mean a component of a Mixed Technology Facility that operates in the capacity, energy, and/or ancillary services market(s) as a separate resource from the other components of such facility.

Committed Offer:

The “Committed Offer shall mean 1) for pool-scheduled resources, an offer on which a resource was scheduled by the Office of the Interconnection for a particular clock hour for an Operating Day, and 2) for self-scheduled resources, either the offer on which the Market Seller has elected to schedule the resource or the applicable offer for the resource determined pursuant to Operating Agreement, Schedule 1, section 6.4, and the parallel provisions of Tariff, Attachment K-Appendix, section 6.4, or Operating Agreement, Schedule 1, section 6.6, and the parallel provisions of Tariff, Attachment K-Appendix, section 6.6, for a particular clock hour for an Operating Day.

Compliance Monitoring and Enforcement Program:

“Compliance Monitoring and Enforcement Program” shall mean the program to be used by the NERC and the Regional Entities to monitor, assess and enforce compliance with the NERC Reliability Standards. As part of a Compliance Monitoring and Enforcement Program, NERC and the Regional Entities may, among other things, conduct investigations, determine fault and assess monetary penalties.

Composite Energy Offer:

“Composite Energy Offer” for generation resources shall mean the sum (in \$/MWh) of the Incremental Energy Offer and amortized Start-Up Costs and amortized No-load Costs, and for Economic Load Response Participant resources the sum (in \$/MWh) of the Incremental Energy Offer and amortized shutdown costs, as determined in accordance with Operating Agreement, Schedule 1, section 2.4 and Operating Agreement, Schedule 1, section 2.4A and the PJM Manuals.

Congestion Price:

“Congestion Price” shall mean the congestion component of the Locational Marginal Price, which is the effect on transmission congestion costs (whether positive or negative) associated with increasing the output of a generation resource or decreasing the consumption by a Demand Resource, based on the effect of increased generation from or consumption by the resource on transmission line loadings, calculated as specified in Operating Agreement, Schedule 1, section 2, and the parallel provisions of Tariff, Attachment K-Appendix, section 2.

Consolidated Transmission Owners Agreement, PJM Transmission Owners Agreement or Transmission Owners Agreement:

“Consolidated Transmission Owners Agreement,” “PJM Transmission Owners Agreement” or “Transmission Owners Agreement” shall mean that certain Consolidated Transmission Owners Agreement, dated as of December 15, 2005, by and among the Transmission Owners and by and between the Transmission Owners and PJM Interconnection, L.L.C. on file with the Commission, as amended from time to time.

Continuous Mode:

“Continuous Mode” shall mean the mode of operation of an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource that includes both negative and positive megawatt quantities (i.e., the Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource is capable of continually and immediately transitioning from withdrawing megawatt quantities from the grid to injecting megawatt quantities onto the grid or injecting megawatts to withdrawing megawatts). Energy Storage Resource Model Participants or solar-storage Open-Loop Hybrid Resource operating in Continuous Mode are considered to have an unlimited ramp rate. Continuous Mode requires Discharge Economic Maximum Megawatts to be zero or correspond to an injection, and Charge Economic Maximum Megawatts to be zero or correspond to a withdrawal.

Control Area:

“Control Area” shall mean an electric power system or combination of electric power systems bounded by interconnection metering and telemetry to which a common automatic generation control scheme is applied in order to:

- (a) match the power output of the generators within the electric power system(s) and energy purchased from entities outside the electric power system(s), with the load within the electric power system(s);
- (b) maintain scheduled interchange with other Control Areas, within the limits of Good Utility Practice;
- (c) maintain the frequency of the electric power system(s) within reasonable limits in accordance with Good Utility Practice and the criteria of NERC and each Applicable Regional Entity;
- (d) maintain power flows on transmission facilities within appropriate limits to preserve reliability; and
- (e) provide sufficient generating capacity to maintain operating reserves in accordance with Good Utility Practice.

Control Zone:

“Control Zone” shall mean one Zone or multiple contiguous Zones, as designated in the PJM Manuals.

Coordinated External Transaction:

“Coordinated External Transaction” shall mean a transaction to simultaneously purchase and sell energy on either side of a CTS Enabled Interface in accordance with the procedures of Operating Agreement, Schedule 1, section 1.13 and the parallel provisions of Tariff, Attachment K-Appendix, section 1.13.

Coordinated Transaction Scheduling:

“Coordinated Transaction Scheduling” or “CTS” shall mean the scheduling of Coordinated External Transactions at a CTS Enabled Interface in accordance with the procedures of Operating Agreement, Schedule 1, section 1.13, and the parallel provisions of Tariff, Attachment K-Appendix, section 1.13.

Counterparty:

“Counterparty” shall mean PJMSettlement as the contracting party, in its name and own right and not as an agent, to an agreement or transaction with a Market Participant or other entities, including the agreements and transactions with customers regarding transmission service and other transactions under the PJM Tariff and this Operating Agreement. PJMSettlement shall not be a counterparty to (i) any bilateral transactions between Members, or (ii) any Member’s self-supply of energy to serve its load, or (iii) any Member’s self-schedule of energy reported to the extent that energy serves that Member’s own load.

Credit Breach:

“Credit Breach” shall mean (a) the failure of a Participant to perform, observe, meet or comply with any requirements of Tariff, Attachment Q or other provisions of the Agreements, other than a Financial Default, or (b) a determination by PJM and notice to the Participant that a Participant represents an unreasonable credit risk to the PJM Markets; that, in either event, has not been cured or remedied after any required notice has been given and any cure period has elapsed.

CTS Enabled Interface:

“CTS Enabled Interface” shall mean an interface between the PJM Control Area and an adjacent Control Area at which the Office of the Interconnection has authorized the use of Coordinated Transaction Scheduling (“CTS”). The CTS Enabled Interfaces between the PJM Control Area and the New York Independent System Operator, Inc. Control Area shall be designated in Joint Operating Agreement Among and Between New York Independent System Operator Inc. and PJM Interconnection, L.L.C. (PJM Rate Schedule FERC No. 45) Schedule A. The CTS Enabled Interfaces between the PJM Control Area and the Midcontinent Independent System Operator, Inc. shall be designated consistent with Joint Operating Agreement between Midcontinent Independent System Operator, Inc. and PJM Interconnection, L.L.C, Attachment 3, section 2.

CTS Interface Bid:

“CTS Interface Bid” shall mean a unified real-time bid to simultaneously purchase and sell energy on either side of a CTS Enabled Interface in accordance with the procedures of Operating Agreement, Schedule 1, section 1.13, and the parallel provisions of Tariff, Attachment K-Appendix, section 1.13.

Curtailment Service Provider:

“Curtailment Service Provider” or “CSP” shall mean a Member or a Special Member, which action on behalf of itself or one or more other Members or non-Members, participates in the PJM Interchange Energy Market, Ancillary Services markets, and/or Reliability Pricing Model by causing a reduction in demand.

Day-ahead Congestion Price:

“Day-ahead Congestion Price” shall mean the Congestion Price resulting from the Day-ahead Energy Market.

Day-ahead Energy Market:

“Day-ahead Energy Market” shall mean the schedule of commitments for the purchase or sale of energy and payment of Transmission Congestion Charges developed by the Office of the Interconnection as a result of the offers and specifications submitted in accordance with Operating Agreement, Schedule 1, section 1.10, and the parallel provisions of Tariff, Attachment K-Appendix, section 1.10.

Day-ahead Energy Market Injection Congestion Credits:

“Day-ahead Energy Market Injection Congestion Credits” shall mean those congestion credits paid to Market Participants for supply transactions in the Day-ahead Energy Market including generation schedules, Increment Offers, Up-to Congestion Transactions, import transactions, and Day-ahead Pseudo-Tie Transactions.

Day-ahead Energy Market Transmission Congestion Charges:

“Day-ahead Energy Market Transmission Congestion Charges” shall be equal to the sum of Day-ahead Energy Market Withdrawal Congestion Charges minus [the sum of Day-ahead Energy Market Injection Congestion Credits plus any congestion charges calculated pursuant to the Joint Operating Agreement between the Midcontinent Independent Transmission System Operator, Inc. and PJM Interconnection, L.L.C. (PJM Rate Schedule FERC No. 38), plus any congestion charges calculated pursuant to the Joint Operating Agreement Among and Between New York Independent System Operator Inc. and PJM Interconnection, L.L.C. (PJM Rate Schedule FERC No. 45), plus any congestion charges calculated pursuant to agreements between the Office of the Interconnection and other entities, as applicable].

Day-ahead Energy Market Withdrawal Congestion Charges:

“Day-ahead Energy Market Withdrawal Congestion Charges” shall mean those congestion charges collected from Market Participants for withdrawal transactions in the Day-ahead Energy Market from transactions including Demand Bids, Decrement Bids, Up-to Congestion Transactions, Export Transactions, and Day-ahead Pseudo-Tie Transactions.

Day-ahead Loss Price:

“Day-ahead Loss Price” shall mean the Loss Price resulting from the Day-ahead Energy Market.

Day-ahead Prices:

“Day-ahead Prices” shall mean the Locational Marginal Prices resulting from the Day-ahead Energy Market.

Day-Ahead Pseudo-Tie Transaction:

“Day-Ahead Pseudo-Tie Transaction” shall mean a transaction scheduled in the Day-ahead Energy Market to the PJM-MISO interface from a generator within the PJM balancing authority area that Pseudo-Ties into the MISO balancing authority area.

Day-ahead Settlement Interval:

“Day-ahead Settlement Interval” shall mean the interval used by settlements, which shall be every one clock hour.

Day-ahead System Energy Price:

“Day-ahead System Energy Price” shall mean the System Energy Price resulting from the Day-ahead Energy Market.

Decrement Bid:

“Decrement Bid” shall mean a type of Virtual Transaction that is a bid to purchase energy at a specified location in the Day-ahead Energy Market. A cleared Decrement Bid results in scheduled load at the specified location in the Day-ahead Energy Market.

Default Allocation Assessment:

“Default Allocation Assessment” shall mean the assessment determined pursuant to Operating Agreement, section 15.2.2.

Demand Bid:

“Demand Bid” shall mean a bid, submitted by a Load Serving Entity in the Day-ahead Energy Market, to purchase energy at its contracted load location, for a specified timeframe and megawatt quantity, that if cleared will result in energy being scheduled at the specified location

in the Day-ahead Energy Market and in the physical transfer of energy during the relevant Operating Day.

Demand Bid Limit:

“Demand Bid Limit” shall mean the largest MW volume of Demand Bids that may be submitted by a Load Serving Entity for any hour of an Operating Day, as determined pursuant to Operating Agreement, Schedule 1, section 1.10.1B, and the parallel provisions of Tariff, Attachment K-Appendix, section 1.10.1B.

Demand Bid Screening:

“Demand Bid Screening” shall mean the process by which Demand Bids are reviewed against the applicable Demand Bid Limit, and rejected if they would exceed that limit, as determined pursuant to Operating Agreement, Schedule 1, section 1.10.1B, and the parallel provisions of Tariff, Attachment K-Appendix, section 1.10.1B.

Demand Resource:

“Demand Resource” shall have the meaning provided in the Reliability Assurance Agreement.

Designated Entity:

“Designated Entity” shall mean an entity, including an existing Transmission Owner or Nonincumbent Developer, designated by the Office of the Interconnection with the responsibility to construct, own, operate, maintain, and finance Immediate-need Reliability Projects, Short-term Projects, Long-lead Projects, or Economic-based Enhancements or Expansions pursuant to Operating Agreement, Schedule 6, section 1.5.8.

Direct Charging Energy:

“Direct Charging Energy” shall mean the energy that an Energy Storage Resource or Open-Loop Hybrid Resource purchases from the PJM Interchange Energy Market and (i) later resells to the PJM Interchange Energy Market; or (ii) is lost to conversion inefficiencies, provided that such inefficiencies are an unavoidable component of the conversion, storage, and discharge process that is used to resell energy back to the PJM Interchange Energy Market.

Direct Load Control:

“Direct Load Control” shall mean load reduction that is controlled directly by the Curtailment Service Provider’s market operations center or its agent, in response to PJM instructions.

Discharge Economic Maximum Megawatts:

“Discharge Economic Maximum Megawatts” shall mean the maximum megawatt power output available for discharge in economic dispatch by an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource in Continuous Mode or in Discharge Mode.

Discharge Economic Maximum Megawatts shall be the Economic Maximum for an Energy Storage Resource or solar-storage Open-Loop Hybrid Resource in Discharge Mode or in Continuous Mode.

Discharge Economic Minimum Megawatts:

“Discharge Economic Minimum Megawatts” shall mean the minimum megawatt power output available for discharge in economic dispatch by an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource in Discharge Mode. Discharge Economic Minimum Megawatts shall be the Economic Minimum for an Energy Storage Resource or solar-storage Open-Loop Hybrid Resource in Discharge Mode.

Discharge Mode:

“Discharge Mode” shall mean the mode of operation of an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource that only includes positive megawatt quantities (i.e., the Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource is only injecting megawatts onto the grid).

Discharge Ramp Rate:

“Discharge Ramp Rate” shall mean the Ramping Capability of an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource in Discharge Mode.

Dispatch Rate:

“Dispatch Rate” shall mean the control signal, expressed in dollars per megawatt-hour, calculated and transmitted continuously and dynamically to direct the output level of all generation resources dispatched by the Office of the Interconnection in accordance with the Offer Data.

Dispatched Charging Energy:

“Dispatched Charging Energy” shall mean Direct Charging Energy that an Energy Storage Resource Model Participant or Open-Loop Hybrid Resource receives from the electric grid pursuant to PJM dispatch while providing one of the following services in the PJM markets: Energy Imbalance Service pursuant to Tariff, Schedule 4; Regulation; Tier 2 Synchronized Reserves; or Reactive Service. Energy Storage Resource Model Participants and Open-Loop Hybrid Resource shall be considered to be providing Energy Imbalance Service when they are dispatchable by PJM in real-time.

Dynamic Schedule:

“Dynamic Schedule” shall have the same meaning set forth in the NERC Glossary of Terms Used in NERC Reliability Standards.

Dynamic Transfer:

“Dynamic Transfer” shall mean a Pseudo-Tie or Dynamic Schedule.

14B.2 Payments:

(a) **Monthly Bills.** Net amounts due to PJMSettlement, in its own name or as agent for the LLC, as applicable, pursuant to a monthly bill shall be due and payable by the Member or other entity no later than noon Eastern Prevailing Time on the due date of the first weekly bill issued for activity in the month that the monthly bill is issued. It is possible, due to the timing of holidays, that the billing and payment cycle for monthly bills stated here would call for payment of a monthly bill on a Friday that occurs less than three Business Days after the issuance of the bill by PJM. Where this occurs, the payment period of the monthly bill will be extended such that payment will be due when payment for the second weekly bill is due.

(b) **Weekly Bills.** Net amounts due to PJMSettlement, in its own name or as agent for the LLC, as applicable, pursuant to a weekly bill shall be due and payable by the Member or other entity no later than noon Eastern Prevailing Time on the third Business Day following the issuance of the weekly bill. Weekly bills issued after 5:00 p.m. Eastern Prevailing Time shall be considered to be issued the following Business Day.

(i) Municipal Electric Systems.

Recognizing that municipal electric systems may, at times, face unique circumstances that could temporarily prevent their ability to make payments on a weekly bill issued pursuant to Section 14B.1 when due, the LLC may allow a municipal electric system to make arrangements with PJM whereby PJM would extend trade credit to the municipal electric system sufficient to enable it to make payment on a weekly bill provided that the following conditions are met:

- (a) the LLC determines, in its sole discretion, that it has sufficient excess working capital available to complete financial settlement with other market participants;
- (b) the municipal electric system reimburses PJM for the actual cost of such working capital;
- (c) the municipal electric system provides PJM with a binding representation that it has all legal right and authority to enter into the arrangement with PJM;
- (d) PJMSettlement will continue to issue weekly bills to the municipal electric system in accordance with Section 14B.1 above and the municipal electric system will make payment as due under the weekly bills using the proceeds it obtains under its arrangement with PJM. Reimbursement of these amounts, including PJM's actual costs of working capital, shall be due from the municipal electric system at the time payment is due for the invoice issued under Section 14B.2(a);
- (e) the aggregate of all financed amounts and accrued obligations shall not exceed the Working Credit Limit available to the municipal electric system;

(f) the municipal electric system provides the LLC with at least one week of notice (though PJM may waive this provision), and;

(g) the accumulated duration of such postponed payments shall not exceed three months in a rolling twelve-month period.

PJM may terminate this payment option at any time it determines its excess working capital is no longer sufficient to allow further or continued extension financing. In such cases, PJM shall attempt to give five Business Days, but not less than three Business Days notice to the affected municipal electric system, and may call for immediate reimbursement of any outstanding amounts owed by the municipal electric system.

(c) Form of Payments. All payments tendered in satisfaction of a Member's or other entity's obligations to PJMSettlement or the LLC shall be made in the form of immediately available funds payable to PJMSettlement, or by wire transfer to a bank named by PJMSettlement.

(d) Payments by PJMSettlement. Unless delayed by unforeseen events, payments made by PJMSettlement, in its own name or as agent for the LLC, for amounts due to Members and other entities shall be paid no later than 5:00 p.m. Eastern Prevailing Time on the Business Day following the payment due date for net amounts owed to PJMSettlement, in its own name or as agent for the LLC, as specified above.

(e) Payment Calendar. A comprehensive billing and settlement calendar will be posted on the LLC's website prior to March 31 for the upcoming June – May annual period to communicate the schedule of holidays for settlement and billing purposes.

(f) Late Payments. In the event that a Member, or other entity, is delinquent in paying the amount set forth in its weekly or monthly bill two or more times within any rolling twelve (12) month period, PJMSettlement, in its own name or as agent for the LLC, may assess, in addition to the interest on each late payment as provided for in Section 7.2 of this Tariff, a late payment charge for a second and any subsequent failure to pay on time during such twelve (12) month period (a "Late Payment Charge"). The applicable Late Payment Charge will be assessed in an amount equal to the greater of: (i) two percent (2%) of the total amount set forth in the monthly or weekly bill that the Transmission Customer or other entity has been late in paying, or (ii) \$1,000; up to a maximum of \$100,000 per late bill payment. For the sole purpose of application of this Section 7.1A(f), weekly and monthly bills that are due on the same date shall be considered to be one bill; moreover, the term "on time" shall mean payment received on the date due; and "delinquent" shall mean any payment received on a day subsequent to the date due.

Late Payment Charges that are collected pursuant to this Section 7.1A(f) shall be credited to PJMSettlement administrative costs ~~and will be included in any applicable stated rate refund calculations as~~ contemplated under Schedule 9 of this Tariff.

1.10 Scheduling.

1.10.1 General.

(a) The Office of the Interconnection shall administer scheduling processes to implement a Day-ahead Energy Market and a Real-time Energy Market. PJMSettlement shall be the Counterparty to the purchases and sales of energy that clear the Day-ahead Energy Market and the Real-time Energy Market; provided that PJMSettlement shall not be a contracting party to bilateral transactions between Market Participants or with respect to a Generating Market Buyer's self-schedule or self-supply of its generation resources up to that Generating Market Buyer's Equivalent Load.

(b) The Day-ahead Energy Market shall enable Market Participants to purchase and sell energy through the PJM Interchange Energy Market at Day-ahead Prices and enable Transmission Customers to reserve transmission service with Transmission Congestion Charges and Transmission Loss Charges based on locational differences in Day-ahead Prices. Up-to Congestion Transactions submitted in the Day-ahead Energy Market shall not require transmission service and Transmission Customers shall not reserve transmission service for such Up-to Congestion Transactions. Market Participants whose purchases and sales, and Transmission Customers whose transmission uses are scheduled in the Day-ahead Energy Market, shall be obligated to purchase or sell energy, or pay Transmission Congestion Charges and Transmission Loss Charges, at the applicable Day-ahead Prices for the amounts scheduled.

(c) (i) In the Real-time Energy Market, Market Participants that deviate from the amounts of energy purchases or sales scheduled in the Day-ahead Energy Market shall be obligated to purchase or sell energy for the amount of the deviations at the applicable Real-time Prices or price differences, unless otherwise specified by this Schedule.

(ii) In the Real-time Energy Market, Transmission Customers that deviate from the transmission uses, scheduled in the Day-ahead Energy Market shall be obligated to pay Transmission Congestion Charges and Transmission Loss Charges for the amount of the deviations at the applicable Real-time Prices or price differences, unless otherwise specified by this Schedule.

(iii) Market Participants that deviate in real-time from the amounts of Secondary Reserve, Non-Synchronized Reserve, or Synchronized Reserve sales, scheduled day-ahead shall be obligated to purchase Secondary Reserve, Non-Synchronized Reserve, or Synchronized Reserve for the amount of the deviations at the applicable Real-time Prices or price differences, unless otherwise specified by this Schedule.

(d) The following scheduling procedures and principles shall govern the commitment of resources to the Day-ahead Energy Market and the Real-time Energy Market over a period extending from one week to one hour prior to the real-time dispatch. Scheduling encompasses the day-ahead and hourly scheduling process, through which the Office of the Interconnection determines the Day-ahead Energy Market and determines, based on changing forecasts of conditions and actions by Market Participants and system constraints, a plan to serve the hourly

energy and reserve requirements of the Internal Market Buyers and the purchase requests of the External Market Buyers in the least costly manner, subject to maintaining the reliability of the PJM Region. Scheduling does not encompass Coordinated External Transactions, which are subject to the procedures of Operating Agreement, Schedule 1, section 1.13. Scheduling shall be conducted as specified in section 1.10.1A below, subject to the following condition. If the Office of the Interconnection's forecast for the next seven days projects a likelihood of Emergency conditions, the Office of the Interconnection may commit, for all or part of such seven day period, to the use of generation resources with notification or start-up times greater than one day as necessary in order to alleviate or mitigate such Emergency, in accordance with the Market Sellers' offers for such units for such periods and the specifications in the PJM Manuals. Such resources committed by the Office of the Interconnection to alleviate or mitigate an Emergency will not receive Operating Reserve Credits nor otherwise be made whole for its hours of operation for the duration of any portion of such commitment that exceeds the maximum start-up and notification times for such resources during Hot Weather Alerts and Cold Weather Alerts, consistent with Operating Agreement, Schedule 1, section 3.2.3 and Operating Agreement, Schedule 1, section 6.6.

1.10.1A Day-ahead and Real-time Energy Market Scheduling.

The following actions shall occur not later than 11:00 a.m. on the day before the Operating Day for which transactions are being scheduled, or such other deadline as may be specified by the Office of the Interconnection in order to comply with the practical requirements and the economic and efficiency objectives of the scheduling process specified in this Schedule.

(a) Each Market Participant may submit to the Office of the Interconnection specifications of the amount and location of its customer loads and/or energy purchases to be included in the Day-ahead Energy Market for each hour of the next Operating Day, such specifications to comply with the requirements set forth in the PJM Manuals. Each Market Buyer shall inform the Office of the Interconnection of the prices, if any, at which it desires not to include its load in the Day-ahead Energy Market rather than pay the Day-ahead Price. PRD Providers that have committed Price Responsive Demand in accordance with the Reliability Assurance Agreement shall submit to the Office of the Interconnection, in accordance with procedures specified in the PJM Manuals, any desired updates to their previously submitted PRD Curves, provided that such updates are consistent with their Price Responsive Demand commitments, and provided further that PRD Providers that are not Load Serving Entities for the Price Responsive Demand at issue may only submit PRD Curves for the Real-time Energy Market. Price Responsive Demand that has been committed in accordance with the Reliability Assurance Agreement shall be presumed available for the next Operating Day in accordance with the most recently submitted PRD Curve unless the PRD Curve is updated to indicate otherwise. PRD Providers may also submit PRD Curves for any Price Responsive Demand that is not committed in accordance with the Reliability Assurance Agreement; provided that PRD Providers that are not Load Serving Entities for the Price Responsive Demand at issue may only submit PRD Curves for the Real-time Energy Market. All PRD Curves shall be on a PRD Substation basis, and shall specify the maximum time period required to implement load reductions.

(b) Each Generating Market Buyer shall submit to the Office of the Interconnection:
(i) hourly schedules for resource increments, including hydropower units, self-scheduled by the Market Buyer to meet its Equivalent Load; and (ii) the Dispatch Rate at which each such self-scheduled resource will disconnect or reduce output, or confirmation of the Market Buyer's intent not to reduce output.

(c) All Market Participants shall submit to the Office of the Interconnection schedules for any energy exports, energy imports, and wheel through transactions involving use of generation or Transmission Facilities as specified below, and shall inform the Office of the Interconnection if the transaction is to be scheduled in the Day-ahead Energy Market. Any Market Participant that elects to schedule an export, import or wheel through transaction in the Day-ahead Energy Market may specify the price (such price not to exceed \$2,000/MWh), if any, at which the export, import or wheel through transaction will be wholly or partially curtailed. The foregoing price specification shall apply to the applicable interface pricing point. Any Market Participant that elects not to schedule its export, import or wheel through transaction in the Day-ahead Energy Market shall inform the Office of the Interconnection if the parties to the transaction are not willing to incur Transmission Congestion and Loss Charges in the Real-time Energy Market in order to complete any such scheduled transaction. Such transactions in the Real-time Energy Market, other than Coordinated Transaction Schedules and emergency energy sales and purchases, may specify a price up to \$2,000/MWh. Scheduling of such transactions shall be conducted in accordance with the specifications in the PJM Manuals and the following requirements:

- i) Market Participants shall submit schedules for all energy purchases for delivery within the PJM Region, whether from resources inside or outside the PJM Region;
- ii) Market Participants shall submit schedules for exports for delivery outside the PJM Region from resources within the PJM Region that are not Dynamic Transfers to such entities pursuant to Operating Agreement, Schedule 1, section 1.12; and
- iii) In addition to the foregoing schedules for exports, imports and wheel through transactions, Market Participants shall submit confirmations of each scheduled transaction from each other party to the transaction in addition to the party submitting the schedule, or the adjacent Control Area.

(c-1) A Market Participant may elect to submit in the Day-ahead Energy Market a form of Virtual Transaction that combines an offer to sell energy at a source, with a bid to buy the same megawatt quantity of energy at a sink where such transaction specifies the maximum difference between the Locational Marginal Prices at the source and sink. The Office of Interconnection will schedule these transactions only to the extent this difference in Locational Marginal Prices is within the maximum amount specified by the Market Participant. A Virtual Transaction of this type is referred to as an "Up-to Congestion Transaction." Such Up-to Congestion Transactions may be wholly or partially scheduled depending on the price difference between the source and sink locations in the Day-ahead Energy Market. The maximum difference between the source

and sink prices that a participant may specify shall be limited to +/- \$50/MWh. The foregoing price specification shall apply to the price difference between the specified source and sink in the day-ahead scheduling process only. An accepted Up-to Congestion Transaction results in scheduled injection at a specified source and scheduled withdrawal of the same megawatt quantity at a specified sink in the Day-ahead Energy Market.

(c-2) A Market Participant may elect to submit an Increment Offer and/or Decrement Bid form of Virtual Transaction in the Day-ahead Energy Market and shall specify the price for such transaction which shall be limited to \$2,000/megawatt-hour.

(c-3) Up-to Congestion Transactions may only be submitted at hubs, Residual Metered Load and interfaces not described in Tariff, Attachment K-Appendix, section 2.6A(b). Increment Offers and Decrement Bids may be only submitted at hubs, nodes at which physical generation or load is settled, Residual Metered Load and interfaces not described in Tariff, Attachment K-Appendix, section 2.6A(b).

(d) Market Sellers in the Day-ahead Energy Market shall submit offers for the supply of energy, demand reductions, or other services for the following Operating Day for each clock hour for which the Market Seller desires or is required to make its resource available to the Office of the Interconnection. Offers for the supply of energy may be cost-based, market-based, or both, and may vary hourly. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A(d), section 1.10.9B below, Operating Agreement, Schedule 2, and the PJM Manuals, as applicable. Market Sellers owning or controlling the output of a Generation Capacity Resource that is committed as a Capacity Resource under Tariff, Attachment DD or RAA, Schedule 8.1, and that has not been rendered unavailable by a Generator Planned Outage, a Generator Maintenance Outage, or a Generator Forced Outage shall submit offers for the available capacity of such Generation Capacity Resource, including any portion that is self-scheduled by the Generating Market Buyer. Such offers shall be based on the ICAP equivalent of the Market Seller's cleared UCAP capacity commitment, provided, however, where the underlying resource is a Capacity Storage Resource or an Intermittent Resource, the Market Seller shall satisfy the must offer requirement by either self-scheduling or offering the unit as a dispatchable resource, in accordance with the PJM Manuals, where the hourly day-ahead self-scheduled values for such Capacity Storage Resources and Intermittent Resources may vary hour to hour from the capacity commitment. Any offer not designated as a Maximum Emergency offer shall be considered available for scheduling and dispatch under both Emergency and non-Emergency conditions. Offers may only be designated as Maximum Emergency offers to the extent that the Generation Capacity Resource falls into at least one of the following categories:

- i) Environmental limits. If the resource has a limit on its run hours imposed by a federal, state, or other governmental agency that will significantly limit its availability, on either a temporary or long-term basis. This includes a resource that is limited to operating only during declared PJM capacity emergencies by a governmental authority.

- ii) Fuel limits. If physical events beyond the control of the resource owner result in the temporary interruption of fuel supply and there is limited on-site fuel storage. A fuel supplier's exercise of a contractual right to interrupt supply or delivery under an interruptible service agreement shall not qualify as an event beyond the control of the resource owner.
- iii) Temporary emergency conditions at the unit. If temporary emergency physical conditions at the resource significantly limit its availability.
- iv) Temporary megawatt additions. If a resource can provide additional megawatts on a temporary basis by oil topping, boiler over-pressure, or similar techniques, and such megawatts are not ordinarily otherwise available.

The submission of offers for resource increments that are not committed as a Capacity Resource under Tariff, Attachment DD or RAA, Schedule 8.1 shall be optional, but any such offers must contain the information specified in the Office of the Interconnection's Offer Data specification, Operating Agreement, Schedule 1, sections 1.10.1A(d) and 1.10.9B, Operating Agreement, Schedule 2, and the PJM Manuals, as applicable. Energy offered from generation resources that are not committed as a Capacity Resource under Tariff, Attachment DD or RAA, Schedule 8.1 shall not be supplied from resources that are included in or otherwise committed to supply the Operating Reserves of a Control Area outside the PJM Region.

The foregoing offers:

- i) Shall specify the Generation Capacity Resource or Economic Load Response Participant resource and energy or demand reduction amount, respectively, for each clock hour in the offer period;
- ii) Shall specify the amounts and prices for each clock hour during the entire Operating Day for each resource component offered by the Market Seller to the Office of the Interconnection;
- iii) May specify for generation resources offer parameters for each clock hour during the entire Operating Day, as applicable and in accordance with section 1.10.9B below, including: (1) Minimum Run Time; (2) maximum run time; (3) Start-up Costs; (4) No-load Costs; (5) Incremental Energy Offer; (6) notification time; (7) availability; (8) ramp rate; (9) Economic Minimum; (10) Economic Maximum; (11) emergency minimum MW; (12) emergency maximum MW; (13) Synchronized Reserve maximum MW; (14) Secondary Reserve maximum MW; and (15) condense to generation time constraints, and may specify offer parameters for Economic Load Response Participant resources for each clock hour during the entire Operating Day, as applicable and in accordance with section 1.10.9B below, including: (1) minimum down time; (2) shutdown costs;

(3) Incremental Energy Offer; (4) notification time; (5) Economic Minimum; and (6) Economic Maximum;

- iv) Shall set forth any special conditions upon which the Market Seller proposes to supply a resource increment, including any curtailment rate specified in a bilateral contract for the output of the resource, or any cancellation fees;
- v) May include a schedule of offers for prices and operating data contingent on acceptance by the deadline specified in this Schedule, with additional schedules applicable if accepted after the foregoing deadline;
- vi) Shall constitute an offer to submit the resource increment to the Office of the Interconnection for scheduling and dispatch in accordance with the terms of the offer for the clock hour, which offer shall remain open through the Operating Day, for which the offer is submitted, unless the Market Seller a) submits a Real-time Offer for the applicable clock hour, or b) updates the availability of its offer for that hour, as further described in the PJM Manuals;
- vii) Shall be final as to the price or prices at which the Market Seller proposes to supply energy or other services to the PJM Interchange Energy Market, such price or prices being guaranteed by the Market Seller for the period extending through the end of the following Operating Day, unless modified after the close of the Day-ahead Energy Market as permitted pursuant to sections 1.10.9A or 1.10.9B below;
- viii) Shall not exceed an energy offer price of \$1,000/megawatt-hour for all generation resources, except (1) when a Market Seller's cost-based offer is above \$1,000/megawatt-hour and less than or equal to \$2,000/megawatt-hour, then its market-based offer must be less than or equal to the cost-based offer; and (2) when a Market Seller's cost-based offer is greater than \$2,000/megawatt-hour, then its market-based offer must be less than or equal to \$2,000/megawatt-hour;
- ix) Shall not exceed a demand reduction offer price of \$1,000/megawatt-hour, except when an Economic Load Response Participant submits a cost-based offer that includes an incremental cost component that is above \$1,000/megawatt-hour, then its market-based offer must be less than or equal to the cost-based offer but in no event greater than \$2,000/megawatt-hour;
- x) Shall not exceed an offer price as follows for Emergency Load Response and Pre-Emergency Load Response participants with:
 - a) a 30 minute lead time, pursuant to Tariff, Attachment DD-1,

section A.2 and the parallel provision of RAA, Schedule 6, \$1,000/megawatt-hour, plus the applicable Reserve Penalty Factor for the Primary Reserve Requirement, minus \$1.00;

b) an approved 60 minute lead time, pursuant to Tariff, Attachment DD-1, section A.2 and the parallel provision of RAA, Schedule 6, \$1,000/megawatt-hour, plus [the applicable Reserve Penalty Factor for the Primary Reserve Requirement divided by 2]; and

c) an approved 120 minute lead time, pursuant to Tariff, Attachment DD-1, section A.2 and the parallel provisions of RAA, Schedule 6, \$1,100/megawatt-hour; and

xi) Shall not exceed an energy offer price of \$0.00/MWh for pumped storage hydropower units scheduled by the Office of the Interconnection pursuant to the hydro optimization tool in the Day-ahead Energy Market.

(e) A Market Seller that wishes to make a resource available to sell Regulation service shall submit an offer for Regulation for each clock hour for which the Market Seller desires to make its resource available to the Office of the Interconnection to provide Regulation that shall specify the megawatts of Regulation being offered, which must equal or exceed 0.1 megawatts, the Regulation Zone for which such Regulation is offered, the price of the capability offer in dollars per MW, the price of the performance offer in Dollars per change in MW, and such other information specified by the Office of the Interconnection as may be necessary to evaluate the offer and the resource's opportunity costs. Such offers may vary hourly, and may be updated each hour, up to 65 minutes before the applicable clock hour during the Operating Day. The total of the performance offer multiplied by the historical average mileage used in the market clearing plus the capability offer shall not exceed \$100/megawatt-hour in the case of Regulation offered for all Regulation Zones. In addition to any market-based offer for Regulation, the Market Seller also shall submit a cost-based offer. A cost-based offer must be in the form specified in the PJM Manuals and consist of the following components as well as any other components specified in the PJM Manuals:

i. The costs (in \$/MW) of the fuel cost increase due to the steady-state heat rate increase resulting from operating the unit at lower megawatt output incurred from the provision of Regulation shall apply to the capability offer;

ii. The cost increase (in \$/ΔMW) in costs associated with movement of the regulation resource incurred from the provision of Regulation shall apply to the performance offer; and

iii. An adder of up to \$12.00 per megawatt of Regulation provided applied to the capability offer.

Qualified Regulation capability must satisfy the measurement and verification tests specified in the PJM Manuals.

(f) Each Market Seller owning or controlling the output of a Generation Capacity Resource committed to service of PJM loads under the Reliability Pricing Model or Fixed Resource Requirement Alternative shall submit a forecast of the availability of each such Generation Capacity Resource for the next seven days. A Market Seller (i) may submit a non-binding forecast of the price at which it expects to offer a generation resource increment to the Office of the Interconnection over the next seven days, and (ii) shall submit a binding offer for energy, along with Start-up Costs and No-load Costs, if any, for the next seven days or part thereof, for any generation resource with minimum notification or start-up requirement greater than 24 hours. Such resources committed by the Office of the Interconnection will not receive Operating Reserve Credits nor otherwise be made whole for its hours of operation for the duration of any portion of such commitment that exceeds the maximum start-up and notification times for such resources during Hot Weather Alerts and Cold Weather Alerts, consistent with Operating Agreement, Schedule 1, section 3.2.3 and Operating Agreement, Schedule 1, section 6.6.

(g) Each component of an offer by a Market Seller of a Generation Capacity Resource that is constant for the entire Operating Day and does not vary hour to hour shall remain in effect for subsequent Operating Days until superseded or canceled.

(h) The Office of the Interconnection shall post the total hourly loads scheduled in the Day-ahead Energy Market, as well as, its estimate of the combined hourly load of the Market Buyers for the next four days, and peak load forecasts for an additional three days.

(i) Except for Economic Load Response Participants, all Market Participants may submit Virtual Transactions that apply to the Day-ahead Energy Market only. Such Virtual Transactions must comply with the requirements set forth in the PJM Manuals and must specify amount, location and price, if any, at which the Market Participant desires to purchase or sell energy in the Day-ahead Energy Market. The Office of the Interconnection may require that a market participant shall not submit in excess of a defined number of bid/offer segments in the Day-ahead Energy Market, as specified in the PJM Manuals, when the Office of the Interconnection determines that such limit is required to avoid or mitigate significant system performance problems related to bid/offer volume. Notice of the need to impose such limit shall be provided prior to 10:00 a.m. EPT on the day that the Day-ahead Energy Market will clear. For purposes of this provision, a bid/offer segment is each pairing of price and megawatt quantity submitted as part of an Increment Offer or Decrement Bid. For purposes of applying this provision to an Up-to Congestion Transaction, a bid/offer segment shall refer to the pairing of a source and sink designation, as well as price and megawatt quantity, that comprise each Up-to Congestion Transaction.

(j) (i) Offers to Supply Synchronized and Non-Synchronized Reserves By Generation Resources in the Day-ahead and Real-time Reserve Markets

(1) Market Sellers owning or controlling the output of a Generation Capacity Resource that was committed in an FRR Capacity Plan, self-supplied, offered and

cleared in a Base Residual Auction or Incremental Auction, or designated as replacement capacity, as specified in Tariff, Attachment DD, is capable of providing Synchronized Reserve or Non-Synchronized Reserve as specified in section 1.7.19A(a), in section 1.7.19A.01(a) and in the PJM Manuals, and has not been rendered unavailable by a Generator Planned Outage, a Generator Maintenance Outage, or a Generator Forced Outage, shall submit offers or otherwise make their 10-minute reserve capability available to supply Synchronized Reserve or, as applicable, Non-Synchronized Reserve, including any portion that is self-scheduled by the Generating Market Buyer, in an amount equal to the available 10-minute reserve capability of such Generation Capacity Resource. Market Sellers of Generation Capacity Resources subject to this must-offer requirement that do not make the reserve capability of such resources available when such resource is able to operate with a dispatchable range (e.g. through offering a fixed output) will be in violation of this provision.

(2) Market Sellers of all other generation resources that (A) are capable of providing Synchronized Reserve or Non-Synchronized Reserve, as specified in section 1.7.19A(a), in section 1.7.19A.01(a) and in the PJM Manuals, (B) are located within the metered boundaries of the PJM Region, and (C) have submitted offers for the supply of energy into the Day-ahead Energy Market and/or Real-time Energy Market shall be deemed to have made their reserve capability available to provide Synchronized Reserve or Non-Synchronized Reserve in the Day-ahead Energy Market and/or Real-time Energy Market for each clock hour for which the Market Seller submits an available offer to supply energy; provided, however that hydroelectric generation resources and Energy Storage Resources are not automatically deemed available to provide reserves based on the submission of an available energy offer but may submit offers to supply Synchronized Reserve and Non-Synchronized Reserve, as applicable.

(3) Offers for the supply of Synchronized Reserve by all generation resources must be cost-based. Consistent with the resource's offer to supply energy, such offers may vary hourly and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A, section 1.10.9B below, and the PJM Manuals, as applicable. For offers to supply Synchronized Reserve, the offer price shall not exceed the expected value of the penalty for failing to provide Synchronized Reserve, where such expected value shall be recalculated annually, in accordance with the PJM Manuals, and posted on PJM's website. The expected value of the penalty is calculated as the product of: (A) the average penalty, expressed in \$/MWh, multiplied by (B) the average rate of non-performance during Synchronized Reserve events multiplied by (C) the probability a Synchronized Reserve event that will qualify for non-performance assessments will occur.

The expected value of the penalty shall be determined by an annual review of the twelve-month period ending October 31 of the calendar year in which the review is performed. The Office of the Interconnection shall post the results of its annual review by no later than December 15, and the revised offer price cap shall be effective as of the following January 1; provided, however, that at the time of implementation of this rule the expected value of the penalty shall be \$0.02/MWh, and for the period from the second month after implementation through the second ~~January 1~~ December 31 following such date of implementation, the expected value of the penalty shall be recalculated on a monthly basis using data from the implementation date of this rule through the 15th day of the current month, and the revised value shall be effective the 1st day of the following month.

(4) All Non-Synchronized Reserve offers shall be for \$0.00/MWh. Consistent with the resource's offer to supply energy, such offers may vary hourly and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this subsection (d) of this section 1.10.1A(d), section 1.10.9B below, and the PJM Manuals, as applicable.

(ii) Determination of Available Synchronized Reserve Capability of Generation Resources

(1) For each offer to supply reserves by a synchronized resource, the Office of the Interconnection shall determine the MW of available Synchronized Reserve capability offered in the Day-ahead Energy Market and Real-time Energy Market, in accordance with the PJM Manuals; except, however, that the Office of the Interconnection will not make such determination for hydroelectric generation resources or Energy Storage Resources. Hydroelectric generation resources and Energy Storage Resources may submit offers for their available Synchronized Reserve capability as part of their offer into the Synchronized Reserve market, provided that such offer equals or exceeds 0.1 MW; however, any such resource which is subject to the must offer requirements in section 1.10.1A(j)(i) above must submit a Synchronized Reserve offer which specifies the MW of available Synchronized Reserve capability in order to remain compliant with such requirements.

(2) An on-line generation resource's available Synchronized Reserve capability, except for generation resources capable of synchronous condensing, shall be determined in accordance with the PJM Manuals and based on the resource's current performance and initial energy output and the following offer parameters submitted as part of the resource's energy offer: (A) ramp rate; (B) Economic Minimum; and (C) the lesser of Economic Maximum and Synchronized Reserve maximum MW, where Synchronized Reserve maximum MW may be lower than the Economic Maximum only where the Market Seller

has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Synchronized Reserves above the Synchronized Reserve maximum MW.

For generation resources capable of synchronous condensing, the resource's available Synchronized Reserve capability shall be based on the following offer parameters submitted as part of the resource's energy offer: (D) ramp rate; (E) condense to generation time constraints; (F) Economic Minimum; and (G) the lesser of Economic Maximum and Synchronized Reserve maximum MW, where Synchronized Reserve maximum MW may be lower than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Synchronized Reserves above the Synchronized Reserve maximum MW.

(3) Any Market Seller that believes its generating unit has operating modes, limits, or conditions where the unit would not be capable of providing Synchronized Reserves in real time, can submit to the Office of the Interconnection with a copy to the Market Monitoring Unit a request for an exception from being assigned Synchronized Reserves in the Real-time Synchronized Reserve Market during time periods in which the generating unit is in those operating modes, limits, or conditions. As part of the request, the Market Seller shall supply, for each generating unit, technical information about the operational modes, limits, or conditions to support the requested exception, as further detailed in the PJM Manuals. The Office of the Interconnection shall consult with the Market Monitoring Unit, and consider any input received from the Market Monitoring Unit, in its determination of a request for such an exception. Within 60 days of the submission of the request, the Office of the Interconnection shall notify the Market Seller in writing, with a copy to the Market Monitoring Unit, whether the request is approved or denied. The effective date of any approved request will be provided in the written notification. If a Market Seller has an approved exception, the Market Seller must communicate to the Office of the Interconnection when the unit cannot provide reserves, and the Office of the Interconnection will provide a mechanism for Market Sellers with an approved exception to provide such communication to the Office of the Interconnection in real time, as further detailed in the PJM Manuals. An approved exception will remain applicable to the unit until such time as the Office of the Interconnection determines that a change is needed or the Market Seller notifies the Office of the Interconnection, with a copy to the Market Monitoring Unit, that a change is needed based on changed operational capabilities of the unit. Market Sellers must notify the Office of the Interconnection, with a copy to the Market Monitoring Unit, within 30 days of any changed operational capabilities that necessitate a change in an approved exception.

(iii) Determination of Available Non-Synchronized Reserve Capability of Generation Resources

(1) For each offer to supply reserves by an off-line generation resource, the Office of the Interconnection shall determine the MW of available Non-Synchronized Reserve capability offered in the Day-ahead Energy Market and Real-time Energy Market in accordance with the PJM Manuals; except, however, that the Office of the Interconnection will not make such determination for hydroelectric generation resources or Energy Storage Resources. Such hydroelectric generation resources or Energy Storage Resources may submit offers for their available Non-Synchronized Reserve capability as part of their offer into the Non-Synchronized Reserve market, provided that such offer equals or exceeds 0.1 MW; however, any such resource which is subject to the must offer requirements in section 1.10.1A(j)(i) above must submit a Non-Synchronized Reserve offer which specifies the MW of available Non-Synchronized Reserve capability in order to remain compliant with such requirements.

(2) An off-line generation resource's available Non-Synchronized Reserve capability shall be determined in accordance with the PJM Manuals and based on the following offer parameters submitted as part of the resource's energy offer: (A) startup time; (B) notification time; (C) ramp rate; (D) Economic Minimum; and (E) the lesser of Economic Maximum and Synchronized Reserve maximum MW, where Synchronized Reserve maximum MW may be lower than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Non-Synchronized Reserves above its Synchronized Reserve maximum MW.

(iv) Offers to Supply Synchronized Reserves by Economic Load Response Participant Resources in the Day-ahead and Real-time Reserve Markets

(1) Economic Load Response Participants that submit offers to reduce demand into the Day-ahead Energy Market and Real-time Energy Market and wish to make their resources available to supply Synchronized Reserve may submit offers to supply Synchronized Reserve from such resources, where such offers shall specify the megawatts of Synchronized Reserve being offered, which must equal or exceed 0.1 megawatts and such other information specified by the Office of the Interconnection as may be necessary to evaluate the offer. Such offers may vary hourly, and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day.

(2) All offers to supply Synchronized Reserve offers from Economic Load Response Participant resources shall not exceed the expected value of the penalty for failing to provide Synchronized Reserve, as determined in accordance with

section 1.10.1A(j)(i)(3) above. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A(d), section 1.10.9B below, and the PJM Manuals, as applicable.

(k) An Economic Load Response Participant that wishes to participate in the Day-ahead Energy Market by reducing demand shall submit an offer to reduce demand to the Office of the Interconnection for each clock hour for which the Economic Load Response Participant desires to make its resource available to the Office of the Interconnection to reduce demand. The offer must equal or exceed 0.1 megawatts, may vary hourly, and shall specify: (i) the amount of the offered curtailment in minimum increments of .1 megawatts; (ii) the Day-ahead Locational Marginal Price above which the end-use customer will reduce load, subject to section 1.10.1A(d)(ix); and (iii) at the Economic Load Response Participant's option, shutdown costs associated with reducing load, including direct labor and equipment costs, opportunity costs, and/or a minimum of number of contiguous hours for which the load reduction must be committed. Such offers may be updated each hour, up to 65 minutes before the applicable clock hour during the Operating Day. Economic Load Response Participants submitting offers to reduce demand in the Day-ahead Energy Market may establish an incremental offer curve, provided that such offer curve shall be limited to ten price pairs (in MWs) per hour.

(l) Market Sellers owning or controlling the output of an Economic Load Response Participant resource that was committed in an FRR Capacity Plan, or that was self-supplied or that offered and cleared in a Base Residual Auction or Incremental Auction, may submit demand reduction bids for the available load reduction capability of the Economic Load Response Participant resource. The submission of demand reduction bids for Economic Load Response Participant resource increments that were not committed in an FRR Capacity Plan, or that have not cleared in a Base Residual Auction or Incremental Auction, shall be optional, but any such bids must contain the information required to be included in such bids, as specified in the PJM Economic Load Response Program. An Economic Load Response Participant resource that was committed in an FRR Capacity Plan, or that was self-supplied or offered and cleared in a Base Residual Auction or Incremental Auction, may submit a demand reduction bid in the Day-ahead Energy Market as specified in the Economic Load Response Program; provided, however, that in the event of an Emergency PJM shall require Economic Load Response Participant resources to reduce load, notwithstanding that the Zonal LMP at the time such Emergency is declared is below the price identified in the demand reduction bid.

(m) (i) Offers to Supply Secondary Reserve By Generation Resources

(1) Market Sellers owning or controlling the output of a Generation Capacity Resource that was committed in an FRR Capacity Plan, self-supplied, offered and cleared in a Base Residual Auction or Incremental Auction, or designated as replacement capacity, as specified in Tariff, Attachment DD, that is available for energy, is capable of providing Secondary Reserve, as specified in section 1.7.19A.02(a) and in the PJM Manuals, and has not been rendered unavailable by a Generator Planned Outage, a Generator Maintenance Outage, or a Generator

Forced Outage shall submit offers to supply Secondary Reserve, or otherwise make their Secondary Reserve capability available. Such offers shall be for an amount equal to the resource's available energy output achievable within thirty minutes (less its energy output achievable within ten minutes) from a request of the Office of the Interconnection. Market Sellers of Generation Capacity Resources subject to this must-offer requirement that do not make the reserve capability of such resources available when such resource is able to operate with a dispatchable range (e.g. through offering a fixed output) will be in violation of this provision.

(2) Market Sellers of all other generation resources located within the metered boundaries of the PJM Region that submit offers for the supply of energy into the Day-ahead Energy Market and/or Real-time Energy Market and are capable of providing Secondary Reserve, as specified in the PJM Manuals, shall be deemed to have made their reserve capability available to provide Secondary Reserve in the Day-ahead Energy Market and/or Real-time Energy Market for each clock hour for which the Market Seller submits an available offer to supply energy; provided, however that hydroelectric generation resources and Energy Storage Resources are not automatically deemed available to provide reserves based on the submission of an available energy offer but may submit offers to supply Secondary Reserve, as applicable.

(3) Offers for the supply of Secondary Reserve shall be for \$0.00/MWh. Consistent with the resource's offer to supply energy, such offers may vary hourly and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this subsection (d) above, section 1.10.9B below, and the PJM Manuals, as applicable.

(ii) Determination of Available Secondary Reserve Capability of Generation Resources

(1) For each offer to supply Secondary Reserve by a generation resource, the Office of the Interconnection shall determine the MW of available Secondary Reserve capability offered in the Day-ahead Energy Market and Real-time Energy Market in accordance with the PJM Manuals; except, however, that the Office of the Interconnection will not make such determination for hydroelectric generation resources or Energy Storage Resources. Hydroelectric generation resources or Energy Storage Resources may submit their available Secondary Reserve capability as part of their offer into the Secondary Reserve market, provided that such offer equals or exceeds 0.1 MW; however, any such resource which is subject to the must offer requirements in section 1.10.1A(m)(i) above must submit a Secondary Reserve offer which specifies the MW of available Secondary Reserve capability in order to remain compliant with such requirements.

(2) (A) An on-line generation resource's available Secondary Reserve capability, except for generation resources capable of synchronous condensing, shall be based on the resource's current performance and initial energy output, the resource's available Synchronized Reserve capability; and the following offer parameters submitted as part of the energy offer: (i) ramp rate; (ii) Economic Minimum; and (iii) the lesser of Economic Maximum and Secondary Reserve maximum MW, where a resource's Secondary Reserve maximum MW may be less than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Secondary Reserves above its Secondary Reserve maximum MW.

(B) For generation resources capable of synchronous condensing, the resource's available Secondary Reserve capability shall be based on the following offer parameters submitted as part of the energy offer: (i) ramp rate; (ii) condense to generation time constraints; (iii) Economic Minimum; and (iv) the lesser of Economic Maximum and Secondary Reserve maximum MW, where a resource's Secondary Reserve maximum MW may be less than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Secondary Reserves above its Secondary Reserve maximum MW.

(C) An off-line generation resource's available Secondary Reserve capability, shall be based on the resource's available Secondary Reserve capability and the following offer parameters submitted as part of the resource's energy offer: (i) startup time; (ii) notification time; (iii) ramp rate; (iv) Economic Minimum; and (v) the lesser of Economic Maximum and Secondary Reserve maximum MW, where a resource's Secondary Reserve maximum MW may be less than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Secondary Reserves above its Secondary Reserve maximum MW.

(3) Any Market Seller that believes its generating unit has operating modes, limits, or conditions where the unit would not be capable of providing Secondary Reserves in real time, can submit to the Office of the Interconnection with a copy to the Market Monitoring Unit a request for an exception from being assigned Secondary Reserves in the Real-time

Secondary Reserve Market during time periods in which the generating unit is in those operating modes, limits, or conditions. As part of the request, the Market Seller shall supply, for each generating unit, technical information about the operational modes, limits, or conditions to support the requested exception, as further detailed in the PJM Manuals. The Office of the Interconnection shall consult with the Market Monitoring Unit, and consider any input received from the Market Monitoring Unit, in its determination of a request for such an exception. Within 60 days of the submission of the request, the Office of the Interconnection shall notify the Market Seller in writing, with a copy to the Market Monitoring Unit, whether the request is approved or denied. The effective date of any approved request will be provided in the written notification. If a Market Seller has an approved exception, the Market Seller must communicate to the Office of the Interconnection when the unit cannot provide reserves, and the Office of the Interconnection will provide a mechanism for Market Sellers with an approved exception to provide such communication to the Office of the Interconnection in real time, as further detailed in the PJM Manuals. An approved exception will remain applicable to the unit until such time as the Office of the Interconnection determines that a change is needed or the Market Seller notifies the Office of the Interconnection, with a copy to the Market Monitoring Unit, that a change is needed based on changed operational capabilities of the unit. Market Sellers must notify the Office of the Interconnection, with a copy to the Market Monitoring Unit, within 30 days of any changed operational capabilities that necessitate a change in an approved exception.

(iii) Offers to Supply Secondary Reserves by Economic Load Response Participant resources

(1) Each Economic Load Response Participant that submits offers to reduce demand into the Day-ahead Energy Market and Real-time Energy Market and wishes to make their resources available to supply Secondary Reserve shall submit offers to supply Secondary Reserve from such resources, where such offers shall specify the megawatts of Secondary Reserve being offered, which must equal or exceed 0.1 megawatts and include such other information specified by the Office of the Interconnection as may be necessary to evaluate the offer. Such offers may vary hourly, and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day.

(2) All Secondary Reserve offers by Economic Load Response Participant resources shall be for \$0.00/MWh. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A(d), section 1.10.9B below, and the PJM Manuals, as applicable.

(n) A Market Participant may submit a Day-Ahead Pseudo-Tie Transaction for a Market Participant's generator within the PJM balancing authority area that is a Pseudo-Tie into the MISO balancing authority area. Day-Ahead Pseudo-Tie Transactions combine an offer to sell energy at a source with a bid to buy the same megawatt quantity of energy at a sink where such transaction specifies the maximum difference between the Locational Marginal Prices at the source and sink.

Each Day-Ahead Pseudo-Tie Transaction shall: (1) source at a Market Participant's generator within the PJM balancing authority area that Pseudo-Ties into MISO; and (2) sink at the PJM-MISO interface. A Market Participant must reserve transmission service in accordance with the PJM Tariff for each Day-Ahead Pseudo-Tie Transaction. Megawatt quantities for Day-Ahead Pseudo-Tie Transactions shall be greater than zero and less than or equal to the transmission service reserved for the Day-Ahead Pseudo-Tie Transaction. An accepted Day-Ahead Pseudo-Tie Transaction results in scheduled injection at a specified source and scheduled withdrawal of the same megawatt quantity at a specified sink in the Day-Ahead Energy Market.

1.10.1B Demand Bid Scheduling and Screening

(a) The Office of the Interconnection shall apply Demand Bid Screening to all Demand Bids submitted in the Day-ahead Energy Market for each Load Serving Entity, separately by Zone. Using Demand Bid Screening, the Office of the Interconnection will automatically reject a Load Serving Entity's Demand Bids in any future Operating Day for which the Load Serving Entity submits bids if the total megawatt volume of such bids would exceed the Load Serving Entity's Demand Bid Limit for any hour in such Operating Day, unless the Office of the Interconnection permits an exception pursuant to subsection (d) below.

(b) On a daily basis, PJM will update and post each Load Serving Entity's Demand Bid Limit in each applicable Zone. Such Demand Bid Limit will apply to all Demand Bids submitted by that Load Serving Entity for each future Operating Day for which it submits bids. The Demand Bid Limit is calculated using the following equation:

Demand Bid Limit = greater of (Zonal Peak Demand Reference Point * 1.3), or (Zonal Peak Demand Reference Point + 10MW)

Where:

1. Zonal Peak Demand Reference Point = for each Zone: the product of (a) LSE Recent Load Share, multiplied by (b) Peak Daily Load Forecast.
2. LSE Recent Load Share is the Load Serving Entity's highest share of Network Load in each Zone for any hour over the most recently available seven Operating Days for which PJM has data.
3. Peak Daily Load Forecast is PJM's highest available peak load forecast for each applicable Zone that is calculated on a daily basis.

(c) A Load Serving Entity whose Demand Bids are rejected as a result of Demand Bid Screening may change its Demand Bids to reduce its total megawatt volume to a level that does

not exceed its Demand Bid Limit, and may resubmit them subject to the applicable rules related to bid submission outlined in Tariff, Operating Agreement and PJM Manuals.

(d) PJM may allow a Load Serving Entity to submit bids in excess of its Demand Bid Limit when circumstances exist that will cause, or are reasonably expected to cause, a Load Serving Entity's actual load to exceed its Demand Bid Limit on a given Operating Day. Examples of such circumstances include, but are not limited to, changes in load commitments due to state sponsored auctions, mergers and acquisitions between PJM Members, and sales and divestitures between PJM Members. A Load Serving Entity may submit a written exception request to the Office of Interconnection for a higher Demand Bid Limit for an affected Operating Day. Such request must include a detailed explanation of the circumstances at issue and supporting documentation that justify the Load Serving Entity's expectation that its actual load will exceed its Demand Bid Limit.

1.10.2 Pool-scheduled Resources.

Pool-scheduled resources are those resources for which Market Participants submitted offers to sell energy in the Day-ahead Energy Market and offers to reduce demand in the Day-ahead Energy Market, which the Office of the Interconnection scheduled in the Day-ahead Energy Market as well as generators committed by the Office of the Interconnection subsequent to the Day-ahead Energy Market. Such resources shall be committed to provide energy in the real-time dispatch unless the schedules for such units are revised pursuant to section 1.10.9 below or Operating Agreement, Schedule 1, section 1.11. Pool-scheduled resources shall be governed by the following principles and procedures.

(a) Pool-scheduled resources shall be selected by the Office of the Interconnection on the basis of the prices offered for energy and demand reductions and related services, whether the resource is expected to be needed to maintain system reliability during the Operating Day, Start-up Costs, No-load Costs, and cancellation fees, and the specified operating characteristics, offered by Market Sellers to the Office of the Interconnection by the offer deadline specified in section 1.10.1A above. Hydropower units can only be pool-scheduled if they are pumped storage units and scheduled by the Office of the Interconnection pursuant to the hydro optimization tool in the Day-ahead Energy Market.

(b) A resource that is scheduled by a Market Participant to support a bilateral sale, or that is self-scheduled by a Generating Market Buyer, shall not be selected by the Office of the Interconnection as a pool-scheduled resource except in an Emergency.

(c) Market Sellers offering energy from hydropower or other facilities with fuel or environmental limitations may submit data to the Office of the Interconnection that is sufficient to enable the Office of the Interconnection to determine the available operating hours of such facilities.

(d) The Market Seller of a resource selected as a pool-scheduled resource shall receive payments or credits for energy, demand reductions or related services, or for Start-up Costs and

No-load Costs, from the Office of the Interconnection on behalf of the Market Buyers in accordance with Operating Agreement, Schedule 1, section 3. Alternatively, the Market Seller shall receive, in lieu of Start-up Costs and No-load Costs, its actual costs incurred, if any, up to a cap of the resource's Start-up Costs, if the Office of the Interconnection cancels its selection of the resource as a pool-scheduled resource and so notifies the Market Seller before the resource is synchronized.

(e) Market Participants shall make available their pool-scheduled resources to the Office of the Interconnection for coordinated operation to supply the Operating Reserves needs of the applicable Control Zone.

(f) Economic Load Response Participants offering to reduce demand shall specify: (i) the amount of the offered curtailment, which must equal or exceed 0.1 megawatts, in minimum increments of 0.1 megawatts; (ii) the real-time Locational Marginal Price above which the end-use customer will reduce load; and (iii) at the Economic Load Response Participant's option, shut-down costs associated with reducing load, including direct labor and equipment costs, opportunity costs, and/or a minimum number of contiguous hours for which the load reduction must be committed. Economic Load Response Participants submitting offers to reduce demand in the Day-ahead Energy Market and/or the Real-time Energy Market may establish an incremental offer curve, provided that such offer curve shall be limited to ten price pairs (in MWs). Economic Load Response Participants offering to reduce demand shall also indicate the hours that the demand reduction is not available.

1.10.3 Self-scheduled Resources.

Self-scheduled resources shall be governed by the following principles and procedures.

(a) Each Generating Market Buyer shall use all reasonable efforts, consistent with Good Utility Practice, not to self-schedule resources in excess of its Equivalent Load.

(b) The offered prices of resources that are self-scheduled and not dispatchable by the Office of the Interconnection shall not be considered by the Office of the Interconnection in determining Locational Marginal Prices.

(c) Market Participants shall make available their self-scheduled resources to the Office of the Interconnection for coordinated operation to supply the Operating Reserves needs of the applicable Control Zone, by submitting an offer as to such resources.

(d) A Market Participant self-scheduling a resource in the Day-ahead Energy Market that does not deliver the energy in the Real-time Energy Market, shall replace the energy not delivered with energy from the Real-time Energy Market and shall pay for such energy at the applicable Real-time Price.

(e) A Market Participant self-scheduling a resource to supply Synchronized Reserve in the Day-ahead Synchronized Reserve Market that does not deliver the scheduled megawatt quantity in the applicable real-time reserve market, shall replace the Synchronized Reserve not delivered

and shall pay for such Synchronized Reserve at the applicable Real-time Synchronized Reserve Market Clearing Price. Market Participants shall not self-schedule a resource to provide Secondary Reserve or Non-Synchronized Reserve.

(f) For energy, hydropower units, excluding pumped storage units, may only be self-scheduled.

(g) A resource that has been self-scheduled shall not receive payments or credits for Start-up Costs or No-load Costs.

1.10.4 Capacity Resources.

(a) A Generation Capacity Resource committed to service of PJM loads under the Reliability Pricing Model or Fixed Resource Requirement Alternative that is selected as a pool-scheduled resource shall be made available for scheduling and dispatch at the direction of the Office of the Interconnection. Such a Generation Capacity Resource that does not deliver energy as scheduled shall be deemed to have experienced a Generator Forced Outage to the extent of such energy not delivered. A Market Participant offering such Generation Capacity Resource in the Day-ahead Energy Market shall replace the energy not delivered with energy from the Real-time Energy Market and shall pay for such energy at the applicable Real-time Price.

(b) Energy from a Generation Capacity Resource committed to service of PJM loads under the Reliability Pricing Model or Fixed Resource Requirement Alternative that has not been scheduled in the Day-ahead Energy Market may be sold on a bilateral basis by the Market Seller, may be self-scheduled, or may be offered for dispatch during the Operating Day in accordance with the procedures specified in this Schedule. Such a Generation Capacity Resource that has not been scheduled in the Day-ahead Energy Market and that has been sold on a bilateral basis must be made available upon request to the Office of the Interconnection for scheduling and dispatch during the Operating Day if the Office of the Interconnection declares a Maximum Generation Emergency. Any such resource so scheduled and dispatched shall receive the applicable Real-time Price for energy delivered.

1.10.5 External Resources.

(a) External Resources may submit offers to the PJM Interchange Energy Market, in accordance with the day-ahead and real-time scheduling processes specified above. An External Resource selected as a pool-scheduled resource shall be made available for scheduling and dispatch at the direction of the Office of the Interconnection, and except as specified below shall be compensated on the same basis as other pool-scheduled resources. External Resources that are not capable of Dynamic Transfer shall, if selected by the Office of the Interconnection on the basis of the Market Seller's Offer Data, be block loaded on an hourly scheduled basis. Market Sellers shall offer External Resources to the PJM Interchange Energy Market on either a resource-specific or an aggregated resource basis. A Market Participant whose pool-scheduled resource does not deliver the energy scheduled in the Day-ahead Energy Market shall replace

such energy not delivered as scheduled in the Day-ahead Energy Market with energy from the PJM Real-time Energy Market and shall pay for such energy at the applicable Real-time Price.

(b) Offers for External Resources from an aggregation of two or more generating units shall so indicate, and shall specify, in accordance with the Offer Data requirements specified by the Office of the Interconnection: (i) energy prices; (ii) hours of energy availability; (iii) a minimum dispatch level; (iv) a maximum dispatch level; and (v) unless such information has previously been made available to the Office of the Interconnection, sufficient information, as specified in the PJM Manuals, to enable the Office of the Interconnection to model the flow into the PJM Region of any energy from the External Resources scheduled in accordance with the Offer Data.

(c) Offers for External Resources on a resource-specific basis shall specify the resource being offered, along with the information specified in the Offer Data as applicable.

1.10.6 External Market Buyers.

(a) Deliveries to an External Market Buyer not subject to Dynamic Transfer by the Office of the Interconnection shall be delivered on a block loaded basis to the bus or buses at the electrical boundaries of the PJM Region, or in such area with respect to an External Market Buyer's load within such area not served by Network Service, at which the energy is delivered to or for the External Market Buyer. External Market Buyers shall be charged (which charge may be positive or negative) at either the Day-ahead Prices or Real-time Prices, whichever is applicable, for energy at the foregoing bus or buses.

(b) An External Market Buyer's hourly schedules for energy purchased from the PJM Interchange Energy Market shall conform to the ramping and other applicable requirements of the interconnection agreement between the PJM Region and the Control Area to which, whether as an intermediate or final point of delivery, the purchased energy will initially be delivered.

(c) The Office of the Interconnection shall curtail deliveries to an External Market Buyer if necessary to maintain appropriate reserve levels for a Control Zone as defined in the PJM Manuals, or to avoid shedding load in such Control Zone.

1.10.7 Bilateral Transactions.

Bilateral transactions as to which the parties have notified the Office of the Interconnection by the deadline specified in section 1.10.1A above that they elect not to be included in the Day-ahead Energy Market and that they are not willing to incur Transmission Congestion Charges in the Real-time Energy Market shall be curtailed by the Office of the Interconnection as necessary to reduce or alleviate transmission congestion. Bilateral transactions that were not included in the Day-ahead Energy Market and that are willing to incur congestion charges and bilateral transactions that were accepted in the Day-ahead Energy Market shall continue to be implemented during periods of congestion, except as may be necessary to respond to Emergencies.

1.10.8 Office of the Interconnection Responsibilities.

(a) The Office of the Interconnection shall use its best efforts to determine (i) the least-cost means of satisfying the projected hourly requirements for energy, Operating Reserves, and other ancillary services of the Market Buyers, including the reliability requirements of the PJM Region, of the Day-ahead Energy Market, and (ii) the least-cost means of satisfying the Operating Reserve and other ancillary service requirements for any portion of the load forecast of the Office of the Interconnection for the Operating Day in excess of that scheduled in the Day-ahead Energy Market. In making these determinations, the Office of the Interconnection shall take into account: (i) the Office of the Interconnection's forecasts of PJM Interchange Energy Market and PJM Region energy requirements, giving due consideration to the energy requirement forecasts and purchase requests submitted by Market Buyers and PRD Curves properly submitted by PRD Providers; (ii) the offers submitted by Market Sellers; (iii) the availability of limited energy resources; (iv) the capacity, location, and other relevant characteristics of self-scheduled resources; (v) the objectives of each Control Zone for Operating Reserves, as specified in the PJM Manuals; (vi) the requirements of each Regulation Zone for Regulation and other ancillary services, as specified in the PJM Manuals; (vii) the benefits of avoiding or minimizing transmission constraint control operations, as specified in the PJM Manuals; and (viii) such other factors as the Office of the Interconnection reasonably concludes are relevant to the foregoing determination, including, without limitation, transmission constraints on external coordinated flowgates to the extent provided by Operating Agreement, Schedule 1, section 1.7.6. The Office of the Interconnection shall develop a Day-ahead Energy Market based on the foregoing determination, and shall determine the Day-ahead Prices resulting from such schedule. The Office of the Interconnection shall report the planned schedule for a hydropower resource to the operator of that resource as necessary for plant safety and security, and legal limitations on pond elevations.

(b) By 1:30 p.m., or as soon as practicable thereafter, of the day before each Operating Day, or such other deadline as may be specified by the Office of the Interconnection in the PJM Manuals, the Office of the Interconnection shall: (i) post the aggregate Day-ahead Energy Market results; (ii) post the Day-ahead Prices; and (iii) inform the Market Sellers, Market Buyers, and Economic Load Response Participants of their scheduled injections, withdrawals, and demand reductions respectively. The foregoing notwithstanding, the deadlines set forth in this subsection shall not apply if the Office of the Interconnection is unable to obtain Market Participant bid/offer data due to extraordinary circumstances. For purposes of this subsection, extraordinary circumstances shall mean a technical malfunction that limits, prohibits or otherwise interferes with the ability of the Office of the Interconnection to obtain Market Participant bid/offer data prior to 11:59 p.m. on the day before the affected Operating Day. Extraordinary circumstances do not include a Market Participant's inability to submit bid/offer data to the Office of the Interconnection. If the Office of the Interconnection is unable to clear the Day-ahead Energy Market prior to 11:59 p.m. on the day before the affected Operating Day as a result of such extraordinary circumstances, the Office of the Interconnection shall notify Members as soon as practicable.

(c) Following posting of the information specified in section 1.10.8(b), and absent extraordinary circumstances preventing the clearing of the Day-ahead Energy Market, the Office of the Interconnection shall revise its schedule of generation resources to reflect updated

projections of load, conditions affecting electric system operations in the PJM Region, the availability of and constraints on limited energy and other resources, transmission constraints, and other relevant factors.

(d) Market Buyers shall pay PJMSettlement and Market Sellers shall be paid by PJMSettlement for the quantities of energy scheduled in the Day-ahead Energy Market at the Day-ahead Prices when the Day-ahead Price is positive. Market Buyers shall be paid by PJMSettlement and Market Sellers shall pay PJMSettlement for the quantities of energy scheduled in the Day-ahead Energy Market at the Day-ahead Prices when the Day-ahead Price is negative. Economic Load Response Participants shall be paid for scheduled demand reductions pursuant to Operating Agreement, Schedule 1, section 3.3A. Notwithstanding the foregoing, if the Office of the Interconnection is unable to clear the Day-ahead Energy Market prior to 11:59 p.m. on the day before the affected Operating Day due to extraordinary circumstances as described in subsection (b) above, it will be declared a Market Suspension, and Day-ahead Prices shall be determined pursuant to Operating Agreement, Schedule 1, section 2.6.1. If the Office of the Interconnection declares a Market Suspension, it shall notify Market Participants of the Market Suspension as soon as practicable.

(e) If the Office of the Interconnection discovers a *potential* error in prices and/or cleared quantities in the Day-ahead Energy Market or Day-ahead Ancillary Services Markets, or the Real-time Energy Market or Real-time Ancillary Services Markets after it has posted the results for these markets on its Web site, the Office of the Interconnection shall notify Market Participants as soon as possible after it is found, but in no event later than 12:00 p.m. of the second Business Day following the Operating Day for the Real-time Energy Market and Real-time Ancillary Services Markets, and no later than 5:00 p.m. of the second Business Day following the initial publication of the results for the Day-ahead Energy Market and Day-ahead Ancillary Services Markets. After this initial notification, if the Office of the Interconnection determines it is necessary to post modified results, it shall provide notification of its intent to do so, *along with a description detailing the cause and scope of the error*, by no later than 5:00 p.m. of the fifth Business Day following the Operating Day for the Real-time Energy Market and Real-time Ancillary Services Markets, and no later than 5:00 p.m. of the fifth Business Day following the initial publication of the results in the Day-ahead Energy Market and Day-ahead Ancillary Services Markets. *The provided description will not contain information that is market sensitive or confidential.* Thereafter, the Office of the Interconnection must post on its Web site the corrected results by no later than 5:00 p.m. of the tenth calendar day following the Operating Day for the Day-ahead Energy Market, Real-time Energy Market, and Day-ahead Ancillary Services Markets, and Real-time Ancillary Service Markets. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced market results are under publicly noticed review by the FERC.

(f) Consistent with Operating Agreement, section 18.17.1, and notwithstanding anything to the contrary in the Operating Agreement or in the PJM Tariff, to allow the tracking of Market Participants' non-aggregated bids and offers over time as required by FERC Order No. 719, the Office of the Interconnection shall post on its Web site the non-aggregated bid data and Offer

Data submitted by Market Participants (for participation in the PJM Interchange Energy Market) approximately four months after the bid or offer was submitted to the Office of the Interconnection.

1.10.9 Hourly Scheduling.

(a) Following the initial posting by the Office of the Interconnection of the Locational Marginal Prices resulting from the Day-ahead Energy Market, and subject to the right of the Office of the Interconnection to schedule and dispatch pool-scheduled resources and to direct that schedules be changed in an Emergency, and absent extraordinary circumstances preventing the clearing of the Day-ahead Energy Market, a generation rebidding period shall exist. Typically the rebidding period shall be from the time the Office of the Interconnection posts the results of the Day-ahead Energy Market until 2:15 p.m. on the day before each Operating Day. However, should the clearing of the Day-ahead Energy Market be significantly delayed, the Office of the Interconnection may establish a revised rebidding period. During the rebidding period, Market Participants may submit revisions to generation Offer Data for the next Operating Day. Adjustments to the Day-ahead Energy Market shall be settled at the applicable Real-time Prices, and shall not affect the obligation to pay or receive payment for the quantities of energy scheduled in the Day-ahead Energy Market at the applicable Day-ahead Prices.

(b) A Market Participant may adjust the schedule of a resource under its dispatch control on an hour-to-hour basis beginning at 6:30 p.m. of the day before each Operating Day, provided that the Office of the Interconnection is notified not later than 65 minutes prior to the hour in which the adjustment is to take effect, as follows and as specified in section 1.10.9A below:

- i) A Generating Market Buyer may self-schedule any of its resource increments, including hydropower resources, not previously designated as self-scheduled and not selected as a pool-scheduled resource in the Day-ahead Energy Market;
- ii) A Market Participant may request the scheduling of a non-firm bilateral transaction; or
- iii) A Market Participant may request the scheduling of deliveries or receipts of Spot Market Energy; or
- iv) A Generating Market Buyer may remove from service a resource increment, including a hydropower resource, that it had previously designated as self-scheduled, provided that the Office of the Interconnection shall have the option to schedule energy from any such resource increment that is a Capacity Resource at the price offered in the scheduling process, with no obligation to pay any Start-Up Costs.

(c) An External Market Buyer may refuse delivery of some or all of the energy it requested to purchase in the Day-ahead Energy Market by notifying the Office of the Interconnection of the adjustment in deliveries not later than 65 minutes prior to the hour in which the adjustment is

to take effect, but any such adjustment shall not affect the obligation of the External Market Buyer to pay for energy scheduled on its behalf in the Day-ahead Energy Market at the applicable Day-ahead Prices.

(d) The Office of the Interconnection shall provide External Market Buyers and External Market Sellers and parties to bilateral transactions with any revisions to their schedules resulting from the rebidding period by 6:30 p.m. on the day before each Operating Day. The Office of the Interconnection may also commit additional resources after such time as system conditions require. For each hour in the Operating Day, as soon as practicable after the deadlines specified in the foregoing subsection of this section 1.10, the Office of the Interconnection shall provide External Market Buyers and External Market Sellers and parties to bilateral transactions with any revisions to their schedules for the hour.

1.10.9A Updating Offers in Real-time

(a) Each Market Seller may submit Real-time Offers for a resource up to 65 minutes before the applicable clock hour, and such Real-time Offers shall supersede any previous offer for that resource for the clock hour, as further described in the PJM Manuals and subject to the following conditions:

(i) A market-based Real-time Offer shall not exceed the applicable energy offer caps specified in this Schedule. Once a Market Seller's resource is committed for an applicable clock hour, the Market Seller may not increase its Incremental Energy Offer and may only submit a market-based Real-time Offer that is higher than its market-based offer that was in effect at the time of commitment to reflect increases in the resource's cost-based Start-up Costs and cost-based No-load Costs. The Market Seller may elect not to have its market-based offer considered for dispatch and to have only its lowest cost-based offer considered for the remainder of the Operating Day.

(ii) Cost-based Real-time Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection's Offer Data specification, Operating Agreement, Schedule 1, sections 1.10.1A(d) and 1.10.9B, Operating Agreement, Schedule 2 and the PJM Manuals, as applicable. If a Market Seller submits a market-based Real-time Offer for a particular clock hour in accordance with subsection (c) below, or if updates to a cost-based offer are required by the Market Seller's approved Fuel Cost Policy, the Market Seller shall update its previously submitted cost-based Real-time Offer.

(iii) If a Market Seller's available cost-based offer is not compliant with Operating Agreement, Schedule 2 and the PJM Manuals at the time a Market Seller submits a market-based Real-time Offer for an applicable clock hour during the Operating Day, the Market Seller must submit an updated cost-based Real-time Offer consisting of an Incremental Energy Offer, Start-up Cost, and No-load Cost for that clock hour that is compliant with Operating Agreement, Schedule 2 and the PJM Manuals.

(b) Each Market Seller may submit Real-time Offers for a resource during and through the end of the applicable clock hour to update only the following offer parameters, as further described in the PJM Manuals: (1) Economic Minimum; (2) Economic Maximum; (3) emergency minimum MW; (4) emergency maximum MW; (5) unit availability status; (6) fixed output indicator; (7) Synchronized Reserve maximum MW; and (8) Secondary Reserve maximum MW. Such Real-time Offers shall supersede any previous offer for that resource for the clock hour.

1.10.9B Offer Parameter Flexibility

(a) Market Sellers may, in accordance with sections 1.10.1A and 1.10.9A above, this section 1.10.9B, and the PJM Manuals, update offer parameters at any time up to 65 minutes before the applicable clock hour, including prior to the close of the Day-ahead Energy Market and prior to the close of the rebidding period specified in section 1.10.9, except that Market Sellers may not update their offers for the supply of energy, Secondary Reserve, Synchronized Reserve, Non-Synchronized Reserve, or demand reduction: (1) during the period after the close the Day-ahead Energy Market and prior to the posting of the Day-ahead Energy Market results pursuant to section 1.10.8(b); or (2) during the period after close of the rebidding period and prior to PJM announcing the results of the rebidding period pursuant to section 1.10.9(d).

(b) For generation resource offers, Market Sellers may vary for each clock hour during the entire Operating Day the following offer parameters: (1) cost-based Start-up Costs; (2) cost-based No-load Costs; (3) Incremental Energy Offer; (4) Economic Minimum and Economic Maximum; (5) emergency minimum MW and emergency maximum MW; (6) ramp rate; (7) Synchronized Reserve maximum MW; (8) Secondary Reserve maximum MW; and (9) for Real-time Offers only, (i) notification time and (ii) for uncommitted hours only, Minimum Run Time.

(c) For Economic Load Response Participant resource offers, Market Sellers may vary for each clock hour during the entire Operating Day the following offer parameters: (1) shutdown costs, (2) Incremental Energy Offer; (3) Economic Minimum; (4) Economic Maximum; and (5) for Real-time Offers only, (i) notification time and (ii) for uncommitted hours only, minimum down time.

(d) After the announcement of the results of the rebidding period pursuant to section 1.10.9(d), a Market Seller may submit a Real-time Offer where offer parameters may differ from the offer originally submitted in the Day-ahead Energy Market, except that a Market Seller may not submit a Real-time Offer that changes, of the offer parameters listed in section 1.10.1A(d), the MW amounts specified in the Incremental Energy Offer, MW amounts specified in the ramp rate, maximum run time, and availability; provided, however, Market Sellers of dual-fueled resources may submit Real-time Offers for such resources that change the availability of a submitted cost-based offer.

3.2 Market Settlements.

If a dollar-per-MW-hour value is applied in a calculation under this section 3.2 where the interval of the value produced in that calculation is less than an hour, then for purposes of that calculation the dollar-per-MW hour value is divided by the number of Real-time Settlement Intervals in the hour.

3.2.1 Spot Market Energy.

(a) The Office of the Interconnection shall calculate System Energy Prices in the form of Day-ahead System Energy Prices and Real-time System Energy Prices for the PJM Region, in accordance with Operating Agreement, Schedule 1, section 2.

(b) Each Market Participant shall be charged for all of its Market Participant Energy Withdrawals scheduled in the Day-ahead Energy Market at the Day-ahead System Energy Price to be served in the PJM Interchange Energy Market.

(c) Each Market Participant shall be paid for all of its Market Participant Energy Injections scheduled in the Day-ahead Energy Market at the Day-ahead System Energy Price to be delivered to the PJM Interchange Energy Market.

(d) For each Day-ahead Settlement Interval during an Operating Day, the Office of the Interconnection shall calculate Spot Market Energy charges for each Market Participant as the difference between the sum of its Market Participant Energy Withdrawals scheduled times the Day-ahead System Energy Price and the sum of its Market Participant Energy Injections scheduled times the Day-ahead System Energy Price.

(e) For each Real-time Settlement Interval during an Operating Day, the Office of the Interconnection shall calculate Spot Market Energy charges for each Market Participant as the difference between the sum of its real-time Market Participant Energy Withdrawals less its scheduled Market Participant Energy Withdrawals times the Real-time System Energy Price and the sum of its real-time Market Participant Energy Injections less scheduled Market Participant Energy Injections times the Real-time System Energy Price. The Revenue Data for Settlements determined for each Real-time Settlement Interval in accordance with Operating Agreement, Schedule 1, section 3.1A shall be used in determining the real-time Market Participant Energy Withdrawals and Market Participant Energy Injections used to calculate Spot Market Energy charges under this subsection (e).

(f) For pool External Resources, the Office of the Interconnection shall model, based on an appropriate flow analysis, the megawatts of real-time energy injections to be delivered from each such resource to the corresponding Interface Pricing Point between adjacent Control Areas and the PJM Region.

3.2.2 Regulation.

(a) Each Market Participant that is a Load Serving Entity in a Regulation Zone shall have an hourly Regulation objective equal to its pro rata share of the Regulation requirements of such Regulation Zone for the hour, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Regulation Zone for the hour ("Regulation Obligation"). A Market Participant with an hourly Regulation Obligation shall be charged the pro rata share of the sum of the Regulation market performance clearing price credits and Regulation market capability clearing price credits for the Real-time Settlement Intervals in an hour.

$\text{Regulation Charge} = \text{Hourly Regulation Obligation Share} * (\text{sum of the Real-time Settlement Interval Regulation credits in an hour})$

(b) Each Market Participant supplying Regulation in a Regulation Zone at the direction of the Office of the Interconnection shall be credited for each of its resources such that the calculated credit for each increment of Regulation provided by each resource shall be the higher of: (i) the Regulation market-clearing price; or (ii) the sum of the applicable Regulation offers for a resource determined pursuant to section 3.2.2A.1 below, the unit-specific shoulder hour opportunity costs described in subsection (e) of this section, the unit-specific inter-temporal opportunity costs, and the unit-specific opportunity costs discussed in subsection (d) of this section.

(c) The total Regulation market-clearing price in each Regulation Zone shall be determined in the Real-time Price software program, which is known as the pricing run, for each Real-time Settlement Interval. The total Regulation market-clearing price shall include: (i) the performance Regulation market-clearing price in a Regulation Zone that shall be calculated in accordance with subsection (g) of this section; (ii) the capability Regulation market-clearing price that shall be calculated in accordance with subsection (h) of this section; and (iii) a Regulation resource's unit-specific opportunity costs during the 5-minute period, determined as described in subsection (d) below, divided by the unit-specific benefits factor described in subsection (j) of this section and divided by the historic accuracy score of the resource from among the resources selected to provide Regulation. A resource's Regulation offer by any Market Seller that fails the three-pivotal supplier test set forth in section 3.2.2A.1 below shall not exceed the cost of providing Regulation from such resource, plus twelve dollars, as determined pursuant to the formula in Operating Agreement, Schedule 1, section 1.10.1A(e).

(d) In determining the Regulation 5-minute clearing price for each Regulation Zone, the estimated unit-specific opportunity costs of a generation resource offering to sell Regulation in each regulating hour, except for hydroelectric resources, shall be equal to the product of (i) the deviation of the set point of the generation resource that is expected to be required in order to provide Regulation from the generation resource's expected output level if it had been dispatched in economic merit order times, (ii) the absolute value of the difference between the expected Locational Marginal Price at the generation bus for the generation resource and the lesser of the available market-based or highest available cost-based energy offer from the

generation resource (at the megawatt level of the Regulation set point for the resource) in the PJM Interchange Energy Market.

For hydroelectric resources offering to sell Regulation in a regulating hour, the estimated unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the full value of the Locational Marginal Price at that generation bus for each megawatt of Regulation capability.

The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead megawatt commitment greater than zero shall be equal to the product of (i) the deviation of the set point of the hydroelectric resource that is expected to be required in order to provide Regulation from the hydroelectric resource's expected output level if it had been dispatched in economic merit order times (ii) the difference between the expected Locational Marginal Price at the generation bus for the hydroelectric resource and the average of the Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating. Estimated opportunity costs shall be zero for hydroelectric resources for which the average Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period, excluding those Real-time Settlement Intervals during which all available units at the hydroelectric resource were operating is higher than the actual Locational Marginal Price at the generator bus for the Real-time Settlement Interval.

The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead megawatt commitment greater than zero shall be equal to the product of (i) the deviation of the set point of the hydroelectric resource that is expected to be required in order to provide Regulation from the hydroelectric resource's expected output level if it had been dispatched in economic merit order times (ii) the difference between the average of the Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating and the expected Locational Marginal Price at the generation bus for the hydroelectric resource. Estimated opportunity costs shall be zero for hydroelectric resources for which the actual Locational Marginal Price at the generator bus for the Real-time Settlement Interval is higher than the average Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period, excluding those Real-time Settlement Intervals during which all available units at the hydroelectric resource were operating.

For the purpose of committing resources and setting Regulation market clearing prices, the Office of the Interconnection shall utilize day-ahead Locational Marginal Prices to calculate opportunity costs for hydroelectric resources. For the purposes of settlements, the Office of the Interconnection shall utilize the real-time Locational Marginal Prices to calculate opportunity costs for hydroelectric resources.

Estimated opportunity costs for Economic Load Response Participant resources to provide Regulation are zero.

(e) In determining the credit under subsection (b) to a Market Participant selected to provide Regulation in a Regulation Zone and that actively follows the Office of the Interconnection's Regulation signals and instructions, the unit-specific opportunity cost of a generation resource shall be determined for (1) each Real-time Settlement Interval that the Office of the Interconnection requires a generation resource to provide Regulation, and (2) the last three Real-time Settlement Intervals of the preceding shoulder hour and the first three Real-time Settlement Intervals of the following shoulder hour in accordance with the PJM Manuals and below.

The unit-specific opportunity cost incurred during the Real-time Settlement Interval in which the Regulation obligation is fulfilled shall be equal to the product of (i) the deviation of the generation resource's output necessary to follow the Office of the Interconnection's Regulation signals from the generation resource's expected output level if it had been dispatched in economic merit order times (ii) the absolute value of the difference between the Locational Marginal Price at the generation bus for the generation resource and the lesser of the available market-based or highest available cost-based energy offer from the generation resource (at the actual megawatt level of the resource when the actual megawatt level is within the tolerance defined in the PJM Manuals for the Regulation set point, or at the Regulation set point for the resource when it is not within the corresponding tolerance) in the PJM Interchange Energy Market. Opportunity costs for Economic Load Response Participant resources to provide Regulation are zero.

The unit-specific opportunity costs associated with uneconomic operation during each of the preceding three Real-time Settlement Intervals of the shoulder hour shall be equal to the product of (i) the deviation between the set point of the generation resource that is expected to be required in the initial regulating Real-time Settlement Interval in order to provide Regulation and the resource's expected output in each of the preceding three Real-time Settlement Intervals of the shoulder hour times (ii) the absolute value of the difference between the Locational Marginal Price at the generation bus for the generation resource in each of the preceding three Real-time Settlement Intervals of the shoulder hour and the lesser of the available market-based or highest available cost-based energy offer from the generation resource (at the megawatt level of the Regulation set point for the resource in the initial regulating Real-time Settlement Interval) in the PJM Interchange Energy Market, all as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals.

The unit-specific opportunity costs associated with uneconomic operation during each of the following three Real-time Settlement Intervals of the shoulder hour shall be equal to the product of (i) the deviation between the set point of the generation resource that is expected to be required in the final regulating Real-time Settlement Interval in order to provide Regulation and the resource's expected output in each of the following three Real-time Settlement Intervals of the shoulder hour times (ii) the absolute value of the difference between the Locational Marginal Price at the generation bus for the generation resource in each of the following three Real-time Settlement Intervals of the shoulder hour and the lesser of the available market-based or highest available cost-based energy offer from the generation resource (at the megawatt level of the Regulation set point for the resource in final regulating hour) in the PJM Interchange Energy

Market all as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals.

(f) Any amounts credited for Regulation in an hour in excess of the Regulation market-clearing price in that hour shall be allocated and charged to each Market Participant in a Regulation Zone that does not meet its hourly Regulation obligation in proportion to its purchases of Regulation in such Regulation Zone in megawatt-hours during that hour.

(g) To determine the Regulation market performance-clearing price for each Regulation Zone, the Office of the Interconnection shall adjust the submitted performance offer for each resource in accordance with the historical performance of that resource, the amount of Regulation that resource will be dispatched based on the ratio of control signals calculated by the Office of the Interconnection, and the unit-specific benefits factor described in subsection (j) of this section for which that resource is qualified. The maximum adjusted performance offer of all cleared resources will set the Regulation market performance-clearing price.

The owner of each Regulation resource that actively follows the Office of the Interconnection's Regulation signals and instructions, will be credited for Regulation performance by multiplying the assigned MW(s) by the Regulation market performance-clearing price, by the ratio between the requested mileage for the Regulation dispatch signal assigned to the Regulation resource and the Regulation dispatch signal assigned to traditional resources, and by the Regulation resource's accuracy score calculated in accordance with subsection (k) of this section.

(h) The Office of the Interconnection shall divide each Regulation resource's capability offer by the unit-specific benefits factor described in subsection (j) of this section and divided by the historic accuracy score for the resource for the purposes of committing resources and setting the market clearing prices.

The Office of the Interconnection shall calculate the Regulation market capability-clearing price for each Regulation Zone by subtracting the Regulation market performance-clearing price described in subsection (g) from the total Regulation market clearing price described in subsection (c). This residual sets the Regulation market capability-clearing price for that market Real-time Settlement Interval.

The owner of each Regulation resource that actively follows the Office of the Interconnection's Regulation signals and instructions will be credited for Regulation capability based on the assigned MW and the capability Regulation market-clearing price multiplied by the Regulation resource's accuracy score calculated in accordance with subsection (k) of this section.

(i) In accordance with the processes described in the PJM Manuals, the Office of the Interconnection shall: (i) calculate inter-temporal opportunity costs for each applicable resource; (ii) include such inter-temporal opportunity costs in each applicable resource's offer to sell frequency Regulation service; and (iii) account for such inter-temporal opportunity costs in the Regulation market-clearing price.

(j) The Office of the Interconnection shall calculate a unit-specific benefits factor for each of the dynamic Regulation signal and traditional Regulation signal in accordance with the PJM Manuals. Each resource shall be assigned a unit-specific benefits factor based on their order in the merit order stack for the applicable Regulation signal. The unit-specific benefits factor is the point on the benefits factor curve that aligns with the last megawatt, adjusted by historical performance, that resource will add to the dynamic resource stack. Resources following the dynamic Regulation signal which have a unit-specific benefits factor less than 0.1 will not be considered for the purposes of committing resources. The unit-specific benefits factor for the traditional Regulation signal shall be equal to one.

(k) The Office of the Interconnection shall calculate each Regulation resource's accuracy score. The accuracy score shall be the average of a delay score, correlation score, and energy score for each ten second interval. For purposes of setting the interval to be used for the correlation score and delay scores, PJM will use the maximum of the correlation score plus the delay score for each interval.

The Office of the Interconnection shall calculate the correlation score using the following statistical correlation function (r) that measures the delay in response between the Regulation signal and the resource change in output:

$$\text{Correlation Score} = r_{\text{Signal,Response}(\delta, \delta+5 \text{ Min})};$$

$\delta=0 \text{ to } 5 \text{ Min}$

where δ is delay.

The Office of the Interconnection shall calculate the delay score using the following equation:

$$\text{Delay Score} = \text{Abs} ((\delta - 5 \text{ Minutes}) / (5 \text{ Minutes})).$$

The Office of the Interconnection shall calculate an energy score as a function of the difference in the energy provided versus the energy requested by the Regulation signal while scaling for the number of samples. The energy score is the absolute error (ϵ) as a function of the resource's Regulation capacity using the following equations:

$$\text{Energy Score} = 1 - 1/n \sum \text{Abs} (\text{Error});$$

$$\text{Error} = \text{Average of Abs} ((\text{Response} - \text{Regulation Signal}) / (\text{Hourly Average Regulation Signal})); \text{ and}$$

n = the number of samples in the hour and the energy.

The Office of the Interconnection shall calculate an accuracy score for each Regulation resource that is the average of the delay score, correlation score, and energy score for a five-minute period using the following equation where the energy score, the delay score, and the correlation score are each weighted equally:

$$\text{Accuracy Score} = \max ((\text{Delay Score}) + (\text{Correlation Score})) + (\text{Energy Score}).$$

The historic accuracy score will be based on a rolling average of the Real-time Settlement Interval accuracy scores, with consideration of the qualification score, as defined in the PJM Manuals.

(1) During a Market Suspension where the suspension is less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Regulation, the resources providing Regulation at the direction of the Office of the Interconnection will be compensated based on a calculated Regulation market-clearing price. Regulation market-clearing prices for each Real-time Settlement Interval associated with such Market Suspension shall be the average of the Regulation market-clearing prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

During a Market Suspension where the suspension is greater than twenty-four (24) consecutive hours, if the Office of the Interconnection is assigning Regulation, resources providing Regulation at the direction of the Office of the Interconnection will be compensated based on a calculated Regulation clearing price. The Regulation clearing price for each Real-time Settlement Interval will be determined by calculating a Regulation clearing cost for the online resources providing Regulation during the Market Suspension. The resource's Regulation clearing cost is determined by the summation of their Regulation offer and opportunity cost. The opportunity cost will be based on the resource's cost-based offer and will be determined as follows:

For online resources providing Regulation on a cost-based offer at the time of the Market Suspension, that cost-based offer will be used.

For online resources providing Regulation on a price-based offer at the time of the Market Suspension, the Office of the Interconnection shall use the cheapest available cost-based offer based on the dispatch cost formula as defined in Operating Agreement, Schedule 1, section 6.4.1(g) using the available cost-based offers in the Office of the Interconnection system at the time of the Market Suspension.

The highest cost resource, based on this Regulation clearing cost, will set the Regulation market-clearing price for each hour of the Market Suspension.

During a Market Suspension, if the Office of the Interconnection is not assigning Regulation resources, then the Regulation market-clearing price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period and no resource-specific opportunity cost will be calculated.

During a Market Suspension, the following Regulation components for all Real-time Settlement Intervals in the Market Suspension period will be determined as follows:

- (i) If the regulation accuracy score cannot be calculated during a Market Suspension, the 100-hour rolling average accuracy score will be used for the Market Suspension period.
- (ii) If the regulation mileage ratio cannot be calculated during a Market Suspension, the mileage ratio will be set to one (1) for the Market Suspension period.
- (iii) If the unit-specific benefits factor cannot be calculated during a Market Suspension, the unit-specific benefits factor would be based on the historical average unit-specific benefits factor over past hours that shared the same penetration of Regulation D resources that exist for the given Market Suspension hour.

3.2.2A Offer Price Caps.

3.2.2A.1 Applicability.

(a) Each hour, the Office of the Interconnection shall conduct a three-pivotal supplier test as described in this section. Regulation offers from Market Sellers that fail the three-pivotal supplier test shall be capped in the hour in which they failed the test at their cost based offers as determined pursuant to Operating Agreement, Schedule 1, section 1.10.1A(e). A Regulation supplier fails the three-pivotal supplier test in any hour in which such Regulation supplier and the two largest other Regulation suppliers are jointly pivotal.

(b) For the purposes of conducting the three-pivotal supplier test pursuant to this section, the following applies:

(i) The three-pivotal supplier test will include in the definition of available supply all offers from resources capable of satisfying the Regulation requirement of the PJM Region multiplied by the historic accuracy score of the resource and multiplied by the unit-specific benefits factor for which the capability cost-based offer plus the performance cost-based offer plus any eligible opportunity costs is no greater than 150 percent of the clearing price that would be calculated if all offers were limited to cost (plus eligible opportunity costs).

(ii) The three-pivotal supplier test will apply on a Regulation supplier basis (i.e. not a resource by resource basis) and only the Regulation suppliers that fail the three-pivotal supplier test will have their Regulation offers capped. A Regulation supplier for the purposes of this section includes corporate affiliates. Regulation from resources controlled by a Regulation supplier or its affiliates, whether by contract with unaffiliated third parties or otherwise, will be included as Regulation of that Regulation supplier. Regulation provided by resources owned by a Regulation supplier but controlled by an unaffiliated third party, whether by contract or otherwise, will be included as Regulation of that third party.

(iii) Each supplier shall be ranked from the largest to the smallest offered megawatt of eligible Regulation supply adjusted by the historic performance of each resource and the unit-specific benefits factor. Suppliers are then tested in order, starting with the three largest suppliers. For each iteration of the test, the two largest suppliers are combined with a third supplier, and the combined supply is subtracted from total effective supply. The resulting net amount of eligible supply is divided by the Regulation requirement for the hour to determine the residual supply index. Where the residual supply index for three pivotal suppliers is less than or equal to 1.0, then the three suppliers are jointly pivotal and the suppliers being tested fail the three pivotal supplier test. Iterations of the test continue until the combination of the two largest suppliers and a third supplier result in a residual supply index greater than 1.0, at which point the remaining suppliers pass the test. Any resource owner that fails the three-pivotal supplier test will be offer-capped.

3.2.3 Operating Reserves.

(a) A Market Seller's pool-scheduled resources capable of providing Operating Reserves shall be credited as specified below based on the applicable offer for the operation of such resource, provided that the resource was available for the entire time specified in the Offer Data for such resource. To the extent that sections 3.2.3A, 3.2.3A.001, and 3.2.3A.01 below do not meet the Synchronized Reserve Requirements, the Primary Reserve Requirements, and the 30-minute Reserve Requirements, the Office of the Interconnection shall schedule additional Operating Reserves pursuant to Section 1.7.17 and 1.10 of Schedule 1 of this Agreement. In addition the Office of the Interconnection shall schedule Operating Reserves pursuant to those sections to satisfy any unforeseen Operating Reserve requirements that are not reflected in the day-ahead market. PJMSettlement shall be the Counterparty to the purchases and sales of Operating Reserve in the PJM Interchange Energy Market.

(b) The following determination shall be made for each pool-scheduled resource that is scheduled in the Day-ahead Energy Market: the total offered price for Start-up Costs and No-load Costs and energy, determined on the basis of the resource's scheduled output, shall be compared to the total value of that resource's energy – as determined by the Day-ahead Energy Market and the Day-ahead Prices applicable to the relevant generation bus in the Day-ahead Energy Market. PJM shall also (i) determine whether any resources were scheduled in the Day-ahead Energy Market to provide Black Start service, Reactive Services or transfer interface control during the Operating Day because they are known or expected to be needed to maintain system reliability in a Zone during the Operating Day in order to minimize the total cost of Operating Reserves associated with the provision of such services and reflect the most accurate possible expectation of real-time operating conditions in the day-ahead model, which resources would not have otherwise been committed in the day-ahead security-constrained dispatch and (ii) report on the day following the Operating Day the megawatt quantities scheduled in the Day-ahead Energy Market for the above-enumerated purposes for the entire RTO.

Except as provided in section 3.2.3(n) below, if the total offered price for Start-up Costs (shutdown costs for Economic Load Response Participant resources) and No-load Costs and energy summed over all Day-ahead Settlement Intervals exceeds the total value summed over all

Day-ahead Settlement Intervals, the difference shall be credited to the Market Seller as a day-ahead Operating Reserve credit.

However, for the Day-ahead Settlement Intervals in which the resource is scheduled to provide energy in the Operating Day and the resource actually provides energy in at least one Real-time Settlement Interval in an hour that corresponds to such scheduled Day-ahead Settlement Intervals, a resource's day-ahead Operating Reserve credit shall be reduced by the greater of zero or the difference of the resource's Day-ahead Operating Reserve Target and the Balancing Operating Reserve Target, as determined below.

A resource's Day-ahead Operating Reserve Target shall be determined in accordance with the following equation:

$$(A + B) - C$$

Where:

A = Start-up Costs

B = the sum of day-ahead No-load Costs and energy over the applicable Real-time Settlement Intervals that correspond with Day-ahead Settlement Intervals in which the resource is scheduled. The day-ahead No-load Costs and energy are divided by twelve to determine the cost for each Real-time Settlement Interval.

C = the sum of the day-ahead revenues calculated for each Real-time Settlement Interval that corresponds with a Day-ahead Settlement Interval in which the resource is scheduled, where the day-ahead revenue for each such Real-time Settlement Interval equals the product of the megawatt amount of energy scheduled in the Day-ahead Energy Market and the Day-ahead Price at the applicable pricing point for the resource divided by twelve.

A resource's Balancing Operating Reserve Target shall be determined in accordance with the following equation:

$$D - (E + F)$$

Where:

D = the sum of Start-up Costs and No-load Costs and the incremental cost of energy summed over all Real-time Settlement Intervals that correspond to the Day-ahead Settlement Intervals in which the resource was scheduled;

E = [(the megawatt amount of energy provided in the Real-time Energy Market minus the megawatt amount of energy scheduled in the Day-ahead Energy Market) multiplied by the Real-time Price at the applicable pricing point for the resource] plus the sum of the day-ahead revenues as determined in part C of the above formula for determining the

Day-ahead Operating Reserve Target, summed over the applicable Real-time Settlement Intervals; and

F = the sum of all revenues earned for providing Secondary Reserves, Synchronized Reserves, Non-Synchronized Reserves, and Reactive Services over the applicable Real-time Settlement Intervals.

The Office of the Interconnection shall apply any balancing Operating Reserve credits allocated pursuant to this section 3.2.3(b) to real-time deviations or real-time load share plus exports, pursuant to Operating Agreement, Schedule 1, section 3.2.3(p), depending on whether the balancing Operating Reserve credits are related to resources scheduled during the reliability analysis for an Operating Day, or during the actual Operating Day.

(i) For resources scheduled by the Office of the Interconnection during the reliability analysis for an Operating Day, the associated balancing Operating Reserve credits shall be allocated based on the reason the resource was scheduled according to the following provisions:

(A) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to operate in real-time to augment the physical resources committed in the Day-ahead Energy Market to meet the forecasted real-time load plus the Operating Reserve requirement, the associated balancing Operating Reserve credits, identified as RA Credits for Deviations, shall be allocated to real-time deviations.

(B) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to maintain system reliability, the associated balancing Operating Reserve credits, identified as RA Credits for Reliability, shall be allocated according to ratio share of real time load plus export transactions.

(C) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource with a day-ahead schedule is required to deviate from that schedule to provide balancing Operating Reserves, the associated balancing Operating Reserve credits shall be segmented and separately allocated pursuant to subsections 3.2.3(b)(i)(A) or 3.2.3(b)(i)(B) hereof. Balancing Operating Reserve credits for such resources will be identified in the same manner as units committed during the reliability analysis pursuant to subsections 3.2.3(b)(i)(A) and 3.2.3(b)(i)(B) hereof.

(ii) For resources scheduled during an Operating Day, the associated balancing Operating Reserve credits shall be allocated according to the following provisions:

(A) If the Office of the Interconnection directs a resource to operate during an Operating Day to provide balancing Operating Reserves, the associated

balancing Operating Reserve credits, identified as RT Credits for Reliability, shall be allocated according to ratio share of load plus exports. The foregoing notwithstanding, credits will be applied pursuant to this section only if the LMP at the resource's bus does not meet or exceed the applicable offer of the resource for at least four 5-minute intervals during one or more discrete clock hours during each period the resource operated and produced MWs during the relevant Operating Day. If a resource operated and produced MWs for less than four 5-minute intervals during one or more discrete clock hours during the relevant Operating Day, the credits for that resource during the hour it was operated less than four 5-minute intervals will be identified as being in the same category (RT Credits for Reliability or RT Credits for Deviations) as identified for the Operating Reserves for the other discrete clock hours.

(B) If the Office of the Interconnection directs a resource not covered by section 3.2.3(b)(ii)(A) hereof to operate in real-time during an Operating Day, the associated balancing Operating Reserve credits, identified as RT Credits for Deviations, shall be allocated according to real-time deviations from day-ahead schedules.

(iii) PJM shall post on its Web site the aggregate amount of MWs committed that meet the criteria referenced in subsections (b)(i) and (b)(ii) hereof.

(c) The sum of the foregoing credits calculated in accordance with section 3.2.3(b) plus any unallocated charges from section 3.2.3(h) and Operating Agreement, Schedule 1, section 5.1.7, and any shortfalls paid pursuant to the Market Settlement provision of the Day-ahead Economic Load Response Program, shall be the cost of Operating Reserves in the Day-ahead Energy Market.

(d) The cost of Operating Reserves in the Day-ahead Energy Market shall be allocated and charged to each Market Participant in proportion to the sum of its (i) scheduled load (net of Behind The Meter Generation expected to be operating, but not to be less than zero), accepted Decrement Bids in the Day-ahead Energy Market in megawatt-hours for that Operating Day and accepted Up-to Congestion Transactions in the Day-ahead Energy Market in megawatt-hours for the Operating Day at the sink of the transaction; and (ii) scheduled energy sales in the Day-ahead Energy Market from within the PJM Region to load outside such region in megawatt-hours for that Operating Day, but not including its bilateral transactions that are Dynamic Transfers to load outside such area pursuant to Operating Agreement, Schedule 1, section 1.12, except to the extent PJM scheduled resources to provide Black Start service, Reactive Services or transfer interface control. The cost of Operating Reserves in the Day-ahead Energy Market for resources scheduled to provide Black Start service for the Operating Day which resources would not have otherwise been committed in the day-ahead security constrained dispatch shall be allocated by ratio share of the monthly transmission use of each Network Customer or Transmission Customer serving Zone Load or Non-Zone Load, as determined in accordance with the formulas contained in Tariff, Schedule 6A. The cost of Operating Reserves in the Day-ahead Energy Market for resources scheduled to provide Reactive Services or transfer interface control because they are known or expected to be needed to maintain system reliability in a Zone during

the Operating Day and would not have otherwise been committed in the day-ahead security constrained dispatch shall be allocated and charged to each Market Participant in proportion to the sum of its real-time deliveries of energy to load (net of operating Behind The Meter Generation) in such Zone, served under Network Transmission Service, in megawatt-hours during that Operating Day, as compared to all such deliveries for all Market Participants in such Zone.

(e) At the end of each Operating Day, the following determination shall be made for each synchronized pool-scheduled resource of each Market Seller that operates as requested by the Office of the Interconnection. For each calendar day, pool-scheduled resources in the Real-time Energy Market shall be made whole for each of the following Segments: 1) the greater of their day-ahead schedules and minimum run time specified at the time of commitment (minimum down time specified at the time of commitment for Economic Load Response Participant resources); and 2) any block of Real-time Settlement Intervals the resource operates at PJM's direction in excess of the greater of its day-ahead schedule and minimum run time specified at the time of commitment (minimum down time specified at the time of commitment for Economic Load Response Participant resources). For each calendar day, and for each synchronized start of a generation resource or PJM-dispatched economic load reduction, there will be a maximum of two Segments for each resource. Segment 1 will be the greater of the day-ahead schedule and minimum run time specified at the time of commitment (minimum down time specified at the time of commitment for Demand Resources) and Segment 2 will include the remainder of the contiguous Real-time Settlement Intervals when the resource is operating at the direction of the Office of the Interconnection, provided that a segment is limited to the Operating Day in which it commenced and cannot include any part of the following Operating Day.

A Generation Capacity Resource that operates outside of its unit-specific parameters will not receive Operating Reserve Credits nor be made whole for such operation when not dispatched by the Office of the Interconnection, unless the Market Seller of the Generation Capacity Resource can justify to the Office of the Interconnection that operation outside of such unit-specific parameters was the result of an actual constraint. Such Market Seller shall provide to the Market Monitoring Unit and the Office of the Interconnection its request to receive Operating Reserve Credits and/or to be made whole for such operation, along with documentation explaining in detail the reasons for operating its resource outside of its unit-specific parameters, within thirty calendar days following the issuance of billing statement for the Operating Day. The Market Seller shall also respond to additional requests for information from the Market Monitoring Unit and the Office of the Interconnection. The Market Monitoring Unit shall evaluate such request for compensation and provide its determination of whether there was an exercise of market power to the Office of the Interconnection by no later than twenty-five calendar days after receiving the Market Seller's request for compensation. The Office of the Interconnection shall make its determination whether the Market Seller justified that it is entitled to receive Operating Reserve Credits and/or be made whole for such operation of its resource for the day(s) in question, by no later than thirty calendar days after receiving the Market Seller's request for compensation.

Nuclear generation resources shall not be eligible for Operating Reserve payments unless: 1) the Office of the Interconnection directs such resources to reduce output, in which case, such units

shall be compensated in accordance with Tariff, Attachment K-Appendix, section 3.2.3(f) and the parallel provision of Operating Agreement, Schedule 1, section 3.2.3(f); or 2) the resource submits a request for a risk premium to the Market Monitoring Unit under the procedures specified in Tariff, Attachment M – Appendix, section II.B. A nuclear generation resource (i) must submit a risk premium consistent with its agreement under such process, or, (ii) if it has not agreed with the Market Monitoring Unit on an appropriate risk premium, may submit its own determination of an appropriate risk premium to the Office of the Interconnection, subject to acceptance by the Office of the Interconnection, with or without prior approval from the Commission.

Credits received pursuant to this section shall be equal to the positive difference between a resource's Total Operating Reserve Offer, and the total value of the resource's energy in the Day-ahead Energy Market plus any credit or change for quantity deviations, at PJM dispatch direction (excluding quantity deviations caused by an increase in the Market Seller's Real-time Offer), from the Day-ahead Energy Market during the Operating Day at the real-time LMP(s) applicable to the relevant generation bus in the Real-time Energy Market. The foregoing notwithstanding, credits for Segment 2 shall exclude start up (shutdown costs for Economic Load Response Participant resources) costs for generation resources.

Except as provided in section 3.2.3(m), if the total offered price exceeds the total value, the difference less any credit as determined pursuant to section 3.2.3(b), and less the absolute value of any negative Synchronized Reserve lost opportunity cost credit, as determined in section 3.2.3A(f)(iv) below, and less the absolute value of any negative Non-Synchronized Reserve lost opportunity cost credit determined in section 3.2.3.A.001(d)(iii) below, and less any amounts credited for providing Reactive Services as specified in section 3.2.3B, and the absolute value of any negative Secondary Reserve lost opportunity cost credit, as determined in section 3.2.3A.01(f)(iv) below, and plus the sum of the Market Revenue Neutrality Offsets for Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve, shall be credited to the Market Seller.

Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve credits applied against Operating Reserve credits pursuant to this section shall be netted against the Operating Reserve credits earned in the corresponding Real-time Settlement Interval(s) in which the Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve credits accrued, provided that for condensing combustion turbines, Synchronized Reserve credits will be netted against the total Operating Reserve credits accrued during each Real-time Settlement Interval the unit operates in condensing and generation mode.

(f) A Market Seller of a unit not defined in subsection (f-1), (f-2), or (f-4) hereof (or self-scheduled, if operating according to Operating Agreement, Schedule 1, section 1.10.3(c) hereof), the output of which is reduced or suspended at the request of the Office of the Interconnection due to a transmission constraint or other reliability issue, and for which the real-time LMP at the unit's bus is higher than the unit's offer corresponding to the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override), shall be credited for each Real-time Settlement Interval in an

amount equal to the product of (A) the LOC Deviation times (B) the Locational Marginal Price at the generation bus for the generating unit, minus (C) the Total Lost Opportunity Cost Offer, provided that the resulting outcome is greater than \$0.00. This equation is represented as $(A*B) - C$. If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.11.6, where the suspension is greater than twenty-four (24) consecutive hours, resources will not be compensated for lost opportunity costs.

(f-1) With the exception of Market Sellers of Flexible Resources that submit a Real-time Offer greater than their resource's Committed Offer in the Day-ahead Energy Market, a Market Seller of a Flexible Resource shall be compensated for lost opportunity cost, and shall be limited to the lesser of the unit's Economic Maximum or the unit's Generation Resource Maximum Output, if either of the following conditions occur:

- (i) if the unit output is reduced at the direction of the Office of the Interconnection and the real time LMP at the unit's bus is higher than the unit's offer corresponding to the level of output requested by the Office of the Interconnection (as directed by the PJM dispatcher), then the Market Seller shall be credited in a manner consistent with that described in section 3.2.3(f).
- (ii) If the unit is scheduled to produce energy in the Day-ahead Energy Market for a Day-ahead Settlement Interval, but the unit is not called on by the Office of the Interconnection and does not operate in the corresponding Real-time Settlement Interval(s), then the Market Seller shall be credited in an amount equal to the higher of:
 - 1) the product of (A) the amount of megawatts committed in the Day-ahead Energy Market for the generating unit, and (B) the Real-time Price at the generation bus for the generating unit, minus the sum of (C) the Total Lost Opportunity Cost Offer plus No-load Costs, plus (D) the Start-up Cost, divided by the Real-time Settlement Intervals committed for each set of contiguous hours for which the unit was scheduled in Day-ahead Energy Market. This equation is represented as $(A*B) - (C+D)$. The startup cost, (D), shall be excluded from this calculation if the unit operates in real time following the Office of the Interconnection's direction during any portion of the set of contiguous hours for which the unit was scheduled in Day-ahead Energy Market, or
 - 2) the Real-time Price at the unit's bus minus the Day-ahead Price at the unit's bus, multiplied by the number of megawatts committed in the Day-ahead Energy Market for the generating unit.

(f-2) A Market Seller of a hydroelectric resource that is pool-scheduled (or self-scheduled, if operating according to Operating Agreement, Schedule 1, section 1.10.3(c) hereof),

the output of which is altered at the request of the Office of the Interconnection from the schedule submitted by the owner, due to a transmission constraint or other reliability issue, shall be compensated for lost opportunity cost in the same manner as provided in sections 3.2.2(d) and 3.2.3A(f) and further detailed in the PJM Manuals.

(f-3) If a Market Seller believes that, due to specific pre-existing binding commitments to which it is a party, and that properly should be recognized for purposes of this section, the above calculations do not accurately compensate the Market Seller for opportunity cost associated with following PJM dispatch instructions and reducing or suspending a unit's output due to a transmission constraint or other reliability issue, then the Office of the Interconnection, the Market Monitoring Unit and the individual Market Seller will discuss a mutually acceptable, modified amount of opportunity cost compensation, taking into account the specific circumstances binding on the Market Seller. Following such discussion, if the Office of the Interconnection accepts a modified amount of opportunity cost compensation, the Office of the Interconnection shall invoice the Market Seller accordingly. If the Market Monitoring Unit disagrees with the modified amount of opportunity cost compensation, as accepted by the Office of the Interconnection, it will exercise its powers to inform the Commission staff of its concerns.

(f-4) A Market Seller of a wind generating unit that is pool-scheduled or self-scheduled, has SCADA capability to transmit and receive instructions from the Office of the Interconnection, has provided data and established processes to follow PJM basepoints pursuant to the requirements for wind generating units as further detailed in this Agreement, the Tariff and the PJM Manuals, and which is operating as requested by the Office of the Interconnection, the output of which is reduced or suspended at the request of the Office of the Interconnection due to a transmission constraint or other reliability issue, and for which the , real-time LMP at the unit's bus is higher than the unit's offer corresponding to the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override), shall be credited for each Real-time Settlement Interval in an amount equal to the product of (A) the LOC Deviation times (B) the Real-time Price at the generation bus for the generating unit, minus (C) the Total Lost Opportunity Cost Offer, provided that the resulting outcome is greater than \$0.00. This equation is represented as $(A*B) - C$.

(f-5) (i) A Market Seller of a pool-scheduled resource or a dispatchable self-scheduled resource shall receive Dispatch Differential Lost Opportunity Cost credits as calculated under subsection (iv) below if the resource is dispatched to provide energy in the Real-time Energy Market, provided such resource is not committed to provide real-time ancillary services (Regulation, reserves, reactive service) or instructed to reduce or suspend output due to a transmission constraint or other reliability issue pursuant to Operating Agreement, Schedule 1, section 3.2.3(f-1) through Operating Agreement, Schedule 1, section (f-4).

(ii) PJM will calculate the revenue above cost for the pricing run for each Real-time Settlement Interval in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = the resource's expected output level based on its resource parameters at the Real-time Price at the applicable pricing point;

B = the Real-time Price at the applicable pricing point; and

C = the sum of the resource's Real-time Energy Market offer integrated under the Final Offer for the resource's expected output level based on its resource parameters at the Real-time Price at the applicable pricing point.

(iii) PJM will calculate the revenue above cost for the dispatch run for each Real-time Settlement Interval in accordance with the following equation:

$$(\text{greater of A and B}) - (\text{lesser of C and D})$$

Where:

A = the product of the amount of megawatts of energy dispatched in the Real-time Energy Market dispatch run for the resource in that Real-time Settlement Interval and the Real-time Price at the applicable pricing point;

B = the product of the amount of megawatts of energy the resource actually provided in that Real-time Settlement Interval and the Real-time Price at the applicable pricing point;

C = the resource's Real-time Energy Market offer integrated under the Final Offer for the amount of megawatts dispatched in the Real-time Energy Market dispatch run;

D = the resource's Real-time Energy Market offer integrated under the Final Offer for the amount of megawatts the resource actually provided in that Real-time Settlement Interval.

(iv) The Dispatch Differential Lost Opportunity Cost credit shall equal the greater of (A) the difference between the revenue above cost based on the pricing run determined in subsection (f-5)(ii) and the revenue above cost based on the dispatch run determined in subsection (f-5)(iii) or (B) zero.

(v) For each hour in an Operating Day, the total cost of the Dispatch Differential Lost Opportunity Cost credits shall be allocated and charged to each Market Participant in proportion to the sum of its (i) deliveries of energy to load ((a) net of operating Behind The Meter Generation, but not to be less than zero; and (b) excluding Direct Charging Energy) in the PJM Region, served under Network Transmission Service, in megawatt-hours; and (ii) deliveries of energy sales from within the PJM Region to load outside such region in megawatt-hours but not including its bilateral transactions that are Dynamic Transfers to load

outside the PJM Region pursuant to Operating Agreement, Schedule 1, section 1.12, as compared to the sum of all such deliveries for all Market Participants.

(g) The sum of the foregoing credits in Operating Agreement, Schedule 1, section 3.2.3(f-1) through Operating Agreement, Schedule 1, section 3.2.3(f-4), plus any cancellation fees paid in accordance with Operating Agreement, Schedule 1, section 1.10.2(d), such cancellation fees to be applied to the Operating Day for which the unit was scheduled, plus any shortfalls paid pursuant to the Market Settlement provision of the real-time Economic Load Response Program, less any payments received from another Control Area for Operating Reserves shall be the cost of Operating Reserves for the Real-time Energy Market in each Operating Day.

(h) The cost of Operating Reserves for the Real-time Energy Market for each Operating Day, except those associated with the scheduling of units for Black Start service or testing of Black Start Units as provided in Tariff, Schedule 6A, shall be allocated and charged to each Market Participant based on their daily total of hourly deviations determined in accordance with the following equation:

$$\sum_h (A + B + C)$$

Where:

h = the hours in the applicable Operating Day;

A = For each Real-time Settlement Interval in an hour, the sum of the absolute value of the withdrawal deviations (in MW) between the quantities scheduled in the Day-ahead Energy Market and the Market Participant's energy withdrawals (net of operating Behind The Meter Generation) in the Real-time Energy Market, except as noted in subsection (h)(ii) below and in the PJM Manuals divided by the number of Real-time Settlement Intervals for that hour. The summation of each Real-time Settlement Interval's withdrawal deviation in an hour will be the Market Participant's total hourly withdrawal deviations. Market Participant bilateral transactions that are Dynamic Transfers to load outside the PJM Region pursuant to Operating Agreement, Schedule 1, section 1.12 are not included in the determination of withdrawal deviations;

B = For each Real-time Settlement Interval in an hour, the sum of the absolute value of generation deviations (in MW and not including deviations in Behind The Meter Generation) as determined in subsection (o) divided by the number of Real-time Settlement Intervals for that hour;

C = For each Real-time Settlement Interval in an hour, the sum of the absolute value of the injection deviations (in MW) between the quantities scheduled in the Day-ahead Energy Market and the Market Participant's energy injections in the Real-time Energy Market divided by the number of Real-time Settlement Intervals for that hour. The summation of the injection deviations for each Real-time Settlement Interval in an hour

will be the Market Participant's total hourly injection deviations. The determination of injection deviations does not include generation resources.

The Revenue Data for Settlements determined for each Real-time Settlement Interval in accordance with Operating Agreement, Schedule 1, section 3.1A shall be used in determining the real-time withdrawal deviations, generation deviations and injection deviations used to calculate Operating Reserve under this subsection (e).

The costs associated with scheduling of units for Black Start service or testing of Black Start Units shall be allocated by ratio share of the monthly transmission use of each Network Customer or Transmission Customer serving Zone Load or Non-Zone Load, as determined in accordance with the formulas contained in Tariff, Schedule 6A.

Notwithstanding section (h)(1) above, as more fully set forth in the PJM Manuals, load deviations from the Day-ahead Energy Market shall not be assessed Operating Reserves charges to the extent attributable to reductions in the load of Price Responsive Demand that is in response to an increase in Locational Marginal Price from the Day-ahead Energy Market to the Real-time Energy Market and that is in accordance with a properly submitted PRD Curve.

Deviations that occur within a single Zone shall be associated with the Eastern or Western Region, as defined in section 3.2.3(q) below, and shall be subject to the regional balancing Operating Reserve rate determined in accordance with Section 3.2.3(q). Deviations at a hub shall be associated with the Eastern or Western Region if all the buses that define the hub are located in the region. Deviations at an Interface Pricing Point shall be associated with whichever region, the Eastern or Western Region, with which the majority of the buses that define that Interface Pricing Point are most closely electrically associated. If deviations at interfaces and hubs are associated with the Eastern or Western region, they shall be subject to the regional balancing Operating Reserve rate. Demand and supply deviations shall be based on total activity in a Zone, including all aggregates and hubs defined by buses that are wholly contained within the same Zone.

The foregoing notwithstanding, netting deviations shall be allowed for each Real-time Settlement Interval in accordance with the following provisions:

(i) Generation resources with multiple units located at a single bus shall be able to offset deviations in accordance with the PJM Manuals to determine the net deviation MW at the relevant bus.

(ii) Demand deviations will be assessed by comparing all day-ahead demand transactions, which include the components referenced in section 3.2.3(d) regarding the cost of Operating Reserves in the Day-ahead Energy Market, at a single transmission zone, hub, or interface against the real-time demand transactions at that same transmission zone, hub, or interface; except that the positive values of demand deviations, as set forth in the PJM Manuals, will not be assessed Operating Reserve charges in the event of a Primary Reserve or Synchronized Reserve shortage in real-time or where PJM initiates the request for emergency load reductions in real-time in order to avoid a Primary Reserve or Synchronized Reserve shortage.

(iii) Supply deviations will be assessed by comparing all day-ahead transactions at a single transmission zone, hub, or interface against the real-time transactions at that same transmission zone, hub, or interface.

(iv) Bilateral transactions inside the PJM Region, as defined in Operating Agreement, Schedule 1, section 1.7.10, will not be included in the determination of Supply or Demand deviations.

(i) At the end of each Operating Day, Market Sellers shall be credited on the basis of their offered prices for synchronous condensing for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, as well as the credits calculated as specified in Section 3.2.3(b) for those generators committed solely for the purpose of providing synchronous condensing for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, at the request of the Office of the Interconnection.

(j) The sum of the foregoing credits as specified in section 3.2.3(i) shall be the cost of Operating Reserves for synchronous condensing for the PJM Region for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, or in association with post-contingency operation for the Operating Day and shall be separately determined for the PJM Region.

(k) The cost of Operating Reserves for synchronous condensing for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, or in association with post-contingency operation for each Operating Day shall be allocated and charged to each Market Participant in proportion to the sum of its (i) deliveries of energy to load (net of operating Behind The Meter Generation, but not to be less than zero) in the PJM Region, served under Network Transmission Service, in megawatt-hours during that Operating Day; and (ii) deliveries of energy sales from within the PJM Region to load outside such region in megawatt-hours during that Operating Day, but not including its bilateral transactions that are Dynamic Transfers to load outside the PJM Region pursuant to Operating Agreement, Schedule 1, section 1.12, as compared to the sum of all such deliveries for all Market Participants.

(l) For any Operating Day in either, as applicable, the Day-ahead Energy Market or the Real-time Energy Market for which, for all or any part of such Operating Day, the Office of the Interconnection: (i) declares a Maximum Generation Emergency; (ii) issues an alert that a Maximum Generation Emergency may be declared (“Maximum Generation Emergency Alert”); or (iii) schedules units based on the anticipation of a Maximum Generation Emergency or a Maximum Generation Emergency Alert, the Operating Reserves credit otherwise provided by section 3.2.3.(b) or section 3.2.3.(e) in connection with market-based offers shall be limited as provided in subsections (n) or (m), respectively. The Office of the Interconnection shall provide timely notice on its internet site of the commencement and termination of any of the actions described in subsection (i), (ii), or (iii) of this subsection (l) (collectively referred to as “MaxGen Conditions”). Following the posting of notice of the commencement of a MaxGen Condition, a Market Seller may elect to submit a cost-based offer in accordance with Operating Agreement, Schedule 2, in which case subsections (m) and (n) shall not apply to such offer; provided,

however, that such offer must be submitted in accordance with the deadlines in Operating Agreement, Schedule 1, section 1.10 for the submission of offers in the Day-ahead Energy Market or Real-time Energy Market, as applicable. Submission of a cost-based offer under such conditions shall not be precluded by Operating Agreement, Schedule 1, section 1.9.7(b); provided, however, that the Market Seller must return to compliance with Operating Agreement, Schedule 1, section 1.9.7(b) when it submits its bid for the first Operating Day after termination of the MaxGen Condition.

(m) For the Real-time Energy Market, if the Effective Offer Price (as defined below) for a market-based offer is greater than \$1,000/MWh and greater than the Market Seller's lowest available and applicable cost-based offer, the Market Seller shall not receive any credit for Operating Reserves. For purposes of this subsection (m), the Effective Offer Price shall be the amount that, absent subsections (l) and (m), would have been credited for Operating Reserves for such Operating Day pursuant to section 3.2.3(e) plus the Real-time Energy Market revenues for the Real-time Settlement Intervals that the offer is economic divided by the megawatt hours of energy provided during the Real-time Settlement Intervals that the offer is economic. The Real-time Settlement Intervals that the offer is economic shall be: (i) the Real-time Settlement Intervals that the offer price for energy is less than or equal to the Real-time Price for the relevant generation bus, (ii) the Real-time Settlement Intervals in which the offer for energy is greater than Locational Marginal Price and the unit is operated at the direction of the Office of the Interconnection that are in addition to any Real-time Settlement Intervals required due to the minimum run time or other operating constraint of the unit, and (iii) for any unit with a minimum run time of one hour or less and with more than one start available per day, any hours the unit operated at the direction of the Office of the Interconnection.

(n) For the Day-ahead Energy Market, if notice of a MaxGen Condition is provided prior to 11:00 a.m. on the day before the Operating Day for which transactions are being scheduled and the Effective Offer Price for a market-based offer is greater than \$1,000/MWh and greater than the Market Seller's lowest available and applicable cost-based offer, the Market Seller shall not receive any credit for Operating Reserves. If notice of a MaxGen Condition is provided after 11:00 a.m. on the day before the Operating Day for which transactions are being scheduled and the Effective Offer Price is greater than \$1,000/MWh, the Market Seller shall receive credit for Operating Reserves determined in accordance with section 3.2.3(b), subject to the limit on total compensation stated below. If the Effective Offer Price is less than or equal to \$1,000/MWh, regardless of when notice of a MaxGen Condition is provided, the Market Seller shall receive credit for Operating Reserves determined in accordance with section 3.2.3(b), subject to the limit on total compensation stated below. For purposes of this subsection (n), the Effective Offer Price shall be the amount that, absent subsections (l) and (n), would have been credited for Operating Reserves for such Operating Day divided by the megawatt hours of energy offered during the Specified Hours, plus the offer for energy during such hours. The Specified Hours shall be the lesser of: (1) the minimum run hours stated by the Market Seller in its Offer Data; and (2) either (i) for steam-electric generating units and for combined-cycle units when such units are operating in combined-cycle mode, the six consecutive hours of highest Day-ahead Price during such Operating Day when such units are running or (ii) for combustion turbine units and for combined-cycle units when such units are operating in combustion turbine mode, the two consecutive hours of highest Day-ahead Price during such Operating Day when

such units are running. Notwithstanding any other provision in this subsection, the total compensation to a Market Seller on any Operating Day that includes a MaxGen Condition shall not exceed \$1,000/MWh during the Specified Hours, where such total compensation in each such hour is defined as the amount that, absent subsections (l) and (n), would have been credited for Operating Reserves for such Operating Day pursuant to section 3.2.3(b) divided by the Specified Hours, plus the Day-ahead Price for such hour, and no Operating Reserves payments shall be made for any other hour of such Operating Day. If a unit operates in real time at the direction of the Office of the Interconnection consistently with its day-ahead clearing, then subsection (m) does not apply.

(o) Dispatchable pool-scheduled generation resources and dispatchable self-scheduled generation resources that follow dispatch shall not be assessed balancing Operating Reserve deviations. Pool-scheduled generation resources and dispatchable self-scheduled generation resources that do not follow dispatch shall be assessed balancing Operating Reserve deviations in accordance with the calculations described below and in the PJM Manuals.

The Office of the Interconnection shall calculate a ramp-limited desired MW value for generation resources where the economic minimum and economic maximum are at least as far apart in real-time as they are in day-ahead according to the following parameters:

(i) real-time economic minimum \leq 105% of day-ahead economic minimum or day-ahead economic minimum plus 5 MW, whichever is greater.

(ii) real-time economic maximum \geq 95% day-ahead economic maximum or day-ahead economic maximum minus 5 MW, whichever is lower.

The ramp-limited desired MW value for a generation resource shall be equal to:

$$Ramp_Request_t = \frac{(Dispatchtarget_{t-1} - AOutput_{t-1})}{(LAtime_{t-1})}$$

$$RL_Desired_t = AOutput_{t-1} + (Ramp_Request_t * Case_Eff_time_{t-1})$$

where:

1. Dispatchtarget = Dispatch Signal for the previous approved Dispatch case
2. AOutput = Unit's achievable target MW at case solution time as defined in the PJM Manuals
3. LAtime = Dispatch look ahead time
4. Case_Eff_time = Time between signal changes
5. RL_Desired = Ramp-limited desired MW

To determine if a generation resource is following dispatch the Office of the Interconnection shall determine the unit's MW off dispatch and % off dispatch by using the lesser of the difference between the actual output and the dispatch signal or the actual output and ramp-limited desired MW value for each Real-time Settlement Interval. If the dispatch signal and the ramp-limited desired MW for the resource are unavailable, the Office of the Interconnection will determine the unit's MW off dispatch and % off dispatch by calculating the lesser of the difference between the actual output and the dispatch LMP Desired MW for each Real-time Settlement Interval.

A pool-scheduled or dispatchable self-scheduled resource is considered to be following dispatch if its actual output is between its ramp-limited desired MW value and dispatch signal, or if its % off dispatch is ≤ 10 , or its Real-time Settlement Interval MWh is within 5% of the Real-time Settlement Interval ramp-limited desired MW. A self-scheduled generator must also be dispatched above economic minimum. The degree of deviations for resources that are not following dispatch shall be determined for each Real-time Settlement Interval in accordance with the following provisions:

- A dispatchable self-scheduled resource that is not dispatched above economic minimum shall be assessed balancing Operating Reserve deviations according to the following formula: Real-time Settlement Interval MWh – Day-Ahead MWh.
- A resource that is dispatchable day-ahead but is Fixed Gen in real-time shall be assessed balancing Operating Reserve deviations according to the following formula: Real-time Settlement Interval MWh – dispatch LMP Desired MW.
- Pool-scheduled generators that are not following dispatch shall be assessed balancing Operating Reserve deviations according to the following formula: Real-time Settlement Interval MWh – Ramp-Limited Desired MW.
- If a resource's real-time economic minimum is greater than its day-ahead economic minimum by 5% or 5 MW, whichever is greater, or its real-time economic maximum is less than its Day Ahead economic maximum by 5% or 5 MW, whichever is lower, and dispatch LMP Desired MWh for the Real-time Settlement Interval is either below the real time economic minimum or above the real time economic maximum, then balancing Operating Reserve deviations for the resource shall be assessed according to the following formula: Real time Settlement Interval MWh – dispatch LMP Desired MWh.
- If a resource is not following dispatch and its % Off Dispatch is $\leq 20\%$, balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh – Ramp-Limited Desired MW. If deviation value is within 5% of Ramp-Limited Desired MW, balancing Operating Reserve deviations shall not be assessed.

- If a resource is not following dispatch and its % off Dispatch is > 20%, balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh – dispatch LMP Desired MWh.
- If a resource is not following dispatch, and the resource has tripped, for the Real-time Settlement Interval the resource tripped and the Real-time Settlement Intervals it remains offline throughout its day-ahead schedule balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh – Day-Ahead MWh.
- For resources that are not dispatchable in both the Day-Ahead and Real-time Energy Markets balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh - Day-ahead MWh.

If a resource has a sum of the absolute value of generator deviations for an hour that is less than 5 MWh, then the resource shall not be assessed balancing Operating Reserve deviations for that hour.

(o-1) Dispatchable economic load reduction resources that follow dispatch shall not be assessed balancing Operating Reserve deviations. Economic Load Response Participant resources that do not follow dispatch shall be assessed balancing Operating Reserve deviations as described in this subsection and as further specified in the PJM Manuals.

The Desired MW quantity for such resources for each hour shall be the hourly integrated MW quantity to which the load reduction resource was dispatched for each hour (where the hourly integrated value is the average of the dispatched values as determined by the Office of the Interconnection for the resource for each hour).

If the actual reduction quantity for the load reduction resource for a given hour deviates by no more than 20% above or below the Desired MW quantity, then no balancing Operating Reserve deviation will accrue for that hour. If the actual reduction quantity for the load reduction resource for a given hour is outside the 20% bandwidth, the balancing Operating Reserve deviations will accrue for that hour in the amount of the absolute value of (Desired MW – actual reduction quantity). For those hours where the actual reduction quantity is within the 20% bandwidth specified above, the load reduction resource will be eligible to be made whole for the total value of its offer as defined in Operating Agreement, Schedule 1, section 3.3A. Hours for which the actual reduction quantity is outside the 20% bandwidth will not be eligible for the make-whole payment. If at least one hour is not eligible for make-whole payment based on the 20% criteria, then the resource will also not be made whole for its shutdown cost.

(p) The Office of the Interconnection shall allocate the charges assessed pursuant to Operating Agreement, Schedule 1, section 3.2.3(h) except those associated with the scheduling of units for Black Start service or testing of Black Start Units as provided in Tariff, Schedule 6A, to real-time deviations from day-ahead schedules or real-time load share plus exports depending on whether the underlying balancing Operating Reserve credits are related to resources scheduled during the reliability analysis for an Operating Day, or during the actual Operating

Day. If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, section 1.11.6, the Office of the Interconnection shall allocate the charges to the ratio share of real-time load plus export transactions.

(i) For resources scheduled by the Office of the Interconnection during the reliability analysis for an Operating Day, the associated balancing Operating Reserve charges shall be allocated based on the reason the resource was scheduled according to the following provisions:

(A) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to operate in real-time to augment the physical resources committed in the Day-ahead Energy Market to meet the forecasted real-time load plus the Operating Reserve requirement, the associated balancing Operating Reserve charges shall be allocated to real-time deviations from day-ahead schedules.

(B) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to maintain system reliability, the associated balancing Operating Reserve charges shall be allocated according to ratio share of real time load plus export transactions.

(C) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource with a day-ahead schedule is required to deviate from that schedule to provide balancing Operating Reserves, the associated balancing Operating Reserve charges shall be allocated pursuant to (A) or (B) above.

(ii) For resources scheduled during an Operating Day, the associated balancing Operating Reserve charges shall be allocated according to the following provisions:

(A) If the Office of the Interconnection directs a resource to operate during an Operating Day to provide balancing Operating Reserves, the associated balancing Operating Reserve charges shall be allocated according to ratio share of load plus exports. The foregoing notwithstanding, charges will be assessed pursuant to this section only if the LMP at the resource's bus does not meet or exceeds the applicable offer of the resource for at least four-5-minute intervals during one or more discrete clock hours during each period the resource operated and produced MWs during the relevant Operating Day. If a resource operated and produced MWs for less than four 5-minute intervals during one or more discrete clock hours during the relevant Operating Day, the charges for that resource during the hour it was operated less than four 5-minute intervals will be identified as being in the same category as identified for the Operating Reserves for the other discrete clock hours.

(B) If the Office of the Interconnection directs a resource not covered by Operating Agreement, Schedule 1, section 3.2.3(h)(ii)(A) to operate in real-time during an Operating Day, the associated balancing Operating Reserve charges shall be allocated according to real-time deviations from day-ahead schedules.

(q) The Office of the Interconnection shall determine regional balancing Operating Reserve rates for the Western and Eastern Regions of the PJM Region. For the purposes of this section, the Western Region shall be the AEP, APS, ComEd, Duquesne, Dayton, ATSI, DEOK, EKPC, OVEC transmission Zones, and the Eastern Region shall be the AEC, BGE, Dominion, PENELEC, PEPCO, ME, PPL, JCPL, PECO, DPL, PSEG, RE transmission Zones. The regional balancing Operating Reserve rates shall be determined in accordance with the following provisions:

(i) The Office of the Interconnection shall calculate regional adder rates for the Eastern and Western Regions. Regional adder rates shall be equal to the total balancing Operating Reserve credits paid to generators for transmission constraints that occur on transmission system capacity equal to or less than 345kv. The regional adder rates shall be separated into reliability and deviation charges, which shall be allocated to real-time load or real-time deviations, respectively. Whether the underlying credits are designated as reliability or deviation charges shall be determined in accordance with section 3.2.3(p).

(ii) The Office of the Interconnection shall calculate RTO balancing Operating Reserve rates. RTO balancing Operating Reserve rates shall be equal to balancing Operating Reserve credits except those associated with the scheduling of units for Black Start service or testing of Black Start Units as provided in Tariff, Schedule 6A, in excess of the regional adder rates calculated pursuant to Operating Agreement, Schedule 1, section 3.2.3(q)(i) of Schedule 1 of this Agreement. The RTO balancing Operating Reserve rates shall be separated into reliability and deviation charges, which shall be allocated to real-time load or real-time deviations, respectively. Whether the underlying credits are allocated as reliability or deviation charges shall be determined in accordance with section 3.2.3(p).

(iii) Reliability and deviation regional balancing Operating Reserve rates shall be determined by summing the relevant RTO balancing Operating Reserve rates and regional adder rates.

(iv) If the Eastern and/or Western Regions do not have regional adder rates, the relevant regional balancing Operating Reserve rate shall be the reliability and/or deviation RTO balancing Operating Reserve rate.

(r) Market Sellers that incur incremental operating costs for a generation resource that are either greater than \$1,000/MWh as determined in accordance with the Market Seller's PJM-approved Fuel Cost Policy, Operating Agreement, Schedule 2 and PJM Manual 15, but are not verified at the time of dispatch of the resource under section 6.4.3 of this Schedule, or greater

than \$2,000/MWh as determined in accordance with the Market Seller’s PJM-approved Fuel Cost Policy, Operating Agreement, Schedule 2, and PJM Manual 15, will be eligible to receive credit for Operating Reserves upon review of the Market Monitoring Unit and the Office of the Interconnection, and approval of the Office of the Interconnection. Market Sellers must submit to the Office of the Interconnection and the Market Monitoring Unit all relevant documentation demonstrating the calculation of costs greater than \$2,000/MWh, and costs greater than \$1,000/MWh which were not verified at the time of dispatch of the resource under Operating Agreement, Schedule 1, section 6.4.3. The Office of the Interconnection must approve any Operating Reserve credits paid to a Market Seller under this subsection (r).

3.2.3A Synchronized Reserve.

(a) Each Market Participant that is a Load Serving Entity that is not part of an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have an obligation for hourly Synchronized Reserve equal to its pro rata share of Synchronized Reserve requirements for the hour for each Reserve Zone and Reserve Sub-zone of the PJM Region, based on the Market Participant’s total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Reserve Zone or Reserve Sub-zone for the hour (“Synchronized Reserve Obligation”), less any amount obtained from condensers associated with provision of Reactive Services as described in section 3.2.3B(i) and any amount obtained from condensers associated with post-contingency operations, as described in section 3.2.3C(b). Those entities that participate in an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have their reserve obligations determined based on the stipulations in such agreement. A Market Participant’s hourly Synchronized Reserve Obligation shall be adjusted by any Synchronized Reserve provided on the Market Participant’s behalf through a bilateral agreement. A Market Participant with an hourly Synchronized Reserve Obligation shall be charged the pro rata share of the sum of day-ahead and real-time credits for Synchronized Reserve as defined in sections 3.2.3A(b)(i) and (ii) below.

(b) A resource supplying Synchronized Reserve at the direction of the Office of the Interconnection shall be credited as follows:

i) Credits for Synchronized Reserve provided by generation and Economic Load Response Participant resources assigned to provide Synchronized Reserve by the Office of the Interconnection or self-scheduled in the Day-ahead Synchronized Reserve Market shall be equal to the product of the Day-ahead Synchronized Reserve Market Clearing Price multiplied by the megawatt amount of Synchronized Reserve such resource is assigned to provide..

ii) Credits for Synchronized Reserve provided by generation resources and Economic Load Response Participant resources assigned to provide Synchronized Reserve by the Office of the Interconnection or self-scheduled in the Real-time Synchronized Reserve Market shall be determined for each operating hour based on the sum of their hourly total of Real-time Settlement Interval deviations determined in accordance with the following equation:

$$\sum_i ((A - B) * C)$$

Where:

i = the Real-time Settlement Intervals in the applicable operating hour;

A = For each Real-time Settlement Interval, the megawatts of Synchronized Reserve from that resource assigned by the Office of the Interconnection or self-scheduled in the Real-time Synchronized Reserve Market. The megawatt value is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements of the resource for each Real-time Settlement Interval where there is not a Synchronized Reserve event;

B = For each Real-time Settlement Interval, the megawatts of Synchronized Reserve from that resource assigned by the Office of the Interconnection or self-scheduled in the Day-ahead Synchronized Reserve Market; and

C = For each Real-time Settlement Interval, the Real-time Synchronized Reserve Market Clearing Price.

If a Synchronized Reserve Event is initiated by the Office of the Interconnection and the Economic Load Response Participant resource reduced its load in response to the event, the resource shall be eligible to receive a credit for the fixed costs associated with achieving the load reduction, as specified in the PJM Manuals.

iii) Pool-scheduled resources shall be credited a Synchronized Reserve lost opportunity cost credit, where positive, as described in subsection (f)(iv) below.

(c) [Reserved for future use]

(d) Synchronized Reserve Market Clearing Prices

(i) For the Day-ahead Synchronized Reserve Market, the Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection for each hour of the Operating Day. The Day-ahead Synchronized Reserve Market Clearing Price shall be calculated as the price of serving the next increment of demand for Synchronized Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Synchronized Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Synchronized Reserve established in accordance with Operating Agreement, Schedule 1, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Synchronized Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute and (B) the price of serving the next increment of demand for Primary Reserve and 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute, provided that the Synchronized Reserve Market Clearing Price shall be

less than or equal to the sum of no more than two of the Reserve Penalty Factors for the Synchronized Reserve Requirement, the Primary Reserve Requirement, and the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.10.8(d), Day-ahead Synchronized Reserve Market Clearing Prices shall be set to zero dollars per megawatt-hour and for purposes of settlements for such Operating Day, the Office of the Interconnection shall utilize a scheduled megawatt quantity and Day-ahead Synchronized Reserve Market Clearing Price of zero dollars per megawatt-hour and all settlements will be based on the Real-time Synchronized Reserve market quantities and prices as determined pursuant to subsection (d)(ii) hereof.

(ii) For the Real-time Synchronized Reserve Market, the Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection in the Real-time Price software program, which is known as the pricing run, for each Real-time Settlement Interval of the Operating Day. Each 5-minute clearing price shall be calculated as the price of serving the next increment of demand for Synchronized Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Synchronized Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Synchronized Reserve established in accordance with Operating Agreement, Schedule 1, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Synchronized Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute and (B) the price of serving the next increment of demand for Primary Reserve and 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute, provided that the Synchronized Reserve Market Clearing Price shall be less than or equal to the sum of no more than two of the Reserve Penalty Factors for the Synchronized Reserve Requirement, the Primary Reserve Requirement, and the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, and the Office of the Interconnection is not assigning Synchronized Reserves, then the Synchronized Reserve Market Clearing Price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, where the real-time Market Suspension is less than or equal to six (6) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Synchronized Reserves, then the Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the

average of the Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than six (6) consecutive hours but less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are cleared Day-ahead Synchronized Reserve Market Clearing Prices for the affected Operating Day, then the Real-time Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the Day-ahead Synchronized Reserve Market Clearing Prices for each corresponding hour. If no such Day-ahead Synchronized Reserve Market Clearing Prices exist, then the Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than twenty-four (24) consecutive hours, and the Office of the Interconnection is assigning Synchronized Reserves, the Office of the Interconnection will set the Synchronized Reserve Market Clearing Price to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period. Resources will be compensated for lost opportunity cost per subsection (f) hereof using the energy price as determined in Operating Agreement, Schedule 1, section 2.5.2.iii. The opportunity cost shall be zero for all resources self-scheduled to provide Synchronized Reserve, synchronous condensers and Economic Load Response Participant resources.

If the Office of the Interconnection has initiated in a Reserve Zone or Reserve Sub-zone either a Voltage Reduction Action as described in the PJM Manuals or a Manual Load Dump Action as described in the PJM Manuals, the Real-time Synchronized Reserve Market Clearing Price shall be the sum of the Reserve Penalty Factors for the Primary Reserve Requirement, and the Synchronized Reserve Requirement for that Reserve Zone or Reserve Sub-zone.

(iii) The Reserve Penalty Factor for the Synchronized Reserve Requirement shall be \$850/MWh.

The Reserve Penalty Factor for the Extended Synchronized Reserve Requirement shall be \$300/MWh.

(iv) By no later than April 30 of each year, the Office of the Interconnection will analyze Market Participants' response to prices exceeding \$1,000/MWh on an annual basis and will provide its analysis to PJM stakeholders. The Office of the Interconnection will also review this analysis to determine whether any changes to the Synchronized Reserve Penalty Factors are warranted for subsequent Delivery Year(s).

(e) (i) For determining the Synchronized Reserve Market Clearing Price in each hour of the Day-ahead Synchronized Reserve Market, the estimated resource-specific opportunity cost for a generation resource or Economic Load Response Participant resource shall be the difference between the Locational Marginal Price at the generation or Economic Load Response Participant resource bus and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) or offer price to reduce energy from the Economic Load Response Participant resource in the PJM Interchange Energy Market when the Locational Marginal Price at the generation or Economic Load Participant resource bus is greater than the offer price for energy from the generation resource or the offer price to reduce energy from the Economic Load Response Participant resource.

However, the opportunity costs shall be zero for resources self-scheduled to provide Synchronized Reserve and for synchronous condensers and for Economic Load Response Participant resources that do not receive a day-ahead commitment to provide energy in the same operating hour in which such resource is committed to provide Synchronized Reserve.

(ii) For determining the Synchronized Reserve Market Clearing Price for each Real-time Settlement Interval in the Real-time Synchronized Reserve Market, the estimated unit-specific opportunity cost for a generation resource that is not a hydroelectric resource shall be the difference between the Locational Marginal Price at the generation bus for the generation resource and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) in the PJM Interchange Energy Market when the Locational Marginal Price at the generation bus is greater than the offer price for energy from the generation resource.

For hydroelectric resources, the estimated unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the expected real-time Locational Marginal Price at that generation bus. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions, as defined in the PJM Manuals, and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the expected real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average day-ahead Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

The opportunity costs shall be zero for all resources self-scheduled to provide Synchronized Reserve, synchronous condensers and Economic Load Response Participant resources.

(f) (i) In determining the credit under subsection (b) to a generation resource, except a generation resource that is operating as a synchronous condenser, selected to provide Synchronized Reserve in the Day-ahead Synchronized Reserve Market, or an Economic Load Response Participant resource that is selected to provide Synchronized Reserve in the Day-ahead Synchronized Reserve Market for the same operating hour in which such resource receives a day-ahead commitment to provide energy, the opportunity cost of a resource shall be determined for each operating hour that the Office of the Interconnection requires a resource to provide Synchronized Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Day-ahead Locational Marginal Price at the generation bus of the generation resource or the applicable pricing point for the Economic Load Response Participant resource;

B = The deviation of the resource's energy output or load reduction necessary to supply a Day-ahead Synchronized Reserve assignment from the resource's energy expected output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load; and

C = The Day-ahead Energy market offer integrated under the applicable energy offer curve for the resource's energy output or load reduction necessary to provide a Day-ahead Synchronized Reserve Market assignment from the resource's expected energy output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load.

For a generation resource that is operating as a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: [energy use for providing synchronous condensing multiplied by A] plus [the applicable condense start-up cost divided by the number of hours the resource is assigned Synchronized Reserve].

(ii) In determining the credit under subsection (b) to a generation resource, except a generation resource that is operating as a synchronous condenser, selected to provide Synchronized Reserve in the Real-time Synchronized Reserve Market in excess of the resource's Day-ahead Synchronized Reserve Market assignment and that actively follows the Office of the Interconnection's signals and instructions, the unit-specific opportunity cost of that generation resource shall be determined for each Real-time Settlement Interval that the Office of the Interconnection requires that generation resource to provide Synchronized Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Real-time Locational Marginal Price at the generation bus of the generation resource;

B = The deviation of the generation resource's output necessary to supply Synchronized Reserve in real-time, ~~eapped at~~reduced by the amount of Synchronized Reserve the resource failed to ~~responded~~ during a Synchronized Reserve Event during the Operating Day, in excess of its Day-ahead Synchronized Reserve Market assignment and follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy; and

C = The energy offer integrated under the applicable energy offer curve for the generation resource's output necessary to supply Synchronized Reserve in real-time from the lesser of the generation resource's output necessary to provide a Day-ahead Synchronized Reserve Market assignment or follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy.

For a generation resource that is a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: [additional energy use in excess of day-ahead energy use for providing synchronous condensing in real-time multiplied by A] plus [any applicable condense start-up costs due to additional condense start-ups in real-time in excess of day-ahead condense start-ups allocated to each Real-time Settlement Interval as described in PJM Manuals].

For hydroelectric resources, the unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the real-time Locational Marginal Price at that generation bus multiplied by the additional megawatts assigned to supply Synchronized Reserve in real-time in excess of its Day-ahead Synchronized Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average real-time Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating multiplied by the additional megawatts assigned to supply the hourly Synchronized Reserve in real-time in excess of its Day-ahead Synchronized Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

(iii) For each Real-time Settlement Interval, a Market Revenue Neutrality Offset is calculated for each resource, if eligible. If there is a decrease in the resource's real-time reserve MW from a day-ahead market assignment in more than one market for that Real-time Settlement Interval, the total Market Revenue Neutrality Offset is allocated to the Synchronized Reserve market based on the ratio of the opportunity cost owed due to a reduction in assignment in real-time within the Synchronized Reserve market and the total opportunity cost owed due to a reduction in assignment in real-time from all reserve markets, not to exceed the resource's opportunity cost owed in the Synchronized Reserve market.

A resource is not eligible for Market Revenue Neutrality Offset for Synchronized Reserve in a Real-time Settlement Interval for any of the following conditions:

(A) A resource's real-time Synchronized Reserve assignment decreases due to the resource being self-scheduled to provide energy or Regulation;

(B) A resource reduces its flexibility in real-time such that the resource no longer qualifies to provide Synchronized Reserve in real-time;

(C) A resource's Final Offer is less than its Committed Offer;

(D) A resource trips offline or otherwise becomes unavailable in real-time;

(E) A resource does not follow dispatch as described in section 3.2.3(o) above and section 3.2.3(o-1) above; or

(F) A resource increases its Synchronized Reserve offer price in the Real-time Synchronized Reserve Market from its offer price in the Day-ahead Synchronized Reserve Market.

(iv) A Synchronized Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:

$$(A + B + C + D) - (E + F + G + H)$$

Where:

A = day-ahead Synchronized Reserve offer price times the Synchronized Reserve MW assignment;

B = real-time Synchronized Reserve offer price times the Synchronized Reserve MW assigned in real-time in excess of the Synchronized Reserve MW assigned day-ahead, where the Synchronized Reserve MW assigned is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus

the Revenue Data for Settlements of the resource for each Real-time Settlement Interval where there is not a Synchronized Reserve event;

C = day-ahead opportunity cost as determined in subsection (f)(i) above;

D = real-time opportunity cost as determined in subsection (f)(ii) above;

E = day-ahead clearing price credits as determined in subsection (b)(i) above;

F = real-time clearing price credits as determined in subsection (b)(ii) above less any applicable charges for failure to respond to a Synchronized Reserve Event as determined in subsection (j) below;

G = the applicable Market Revenue Neutrality Offset as determined in subsection (f)(iii) above; and

H = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A(f)(iii) above if not eligible for Market Revenue Neutrality Offset.

(v) The opportunity costs for an Economic Load Response Participant resource assigned Synchronized Reserve in real-time or any resource self-scheduled for Synchronized Reserves shall be zero.

(g) [Reserved for future use]

(h) For each operating hour, the sum of the Synchronized Reserve lost opportunity cost credits credited in accordance with subsection (b)(iii) above shall be allocated and charged to each Market Participant that does not meet its hourly Synchronized Reserve Obligation in proportion to its real-time purchases of Synchronized Reserve in megawatt-hours during that hour.

(i) [Reserved for future use]

(j) In the event a generation resource or Economic Load Response Participant Resource that either has been assigned by the Office of the Interconnection or self-scheduled to provide Synchronized Reserve in real-time fails to provide the assigned or self-scheduled amount of Synchronized Reserve in response to a Synchronized Reserve Event, the resource will be charged at the Real-time Synchronized Reserve Market Clearing Price for the real-time Synchronized Reserve assignment, ~~which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements for the resource,~~ in excess of amount that actually responded for all Real-time Settlement Intervals the resource was assigned or self-scheduled Synchronized Reserve real-time, which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements for the resource on the Operating Day during which the event

occurred. The determination of the amount of Synchronized Reserve credited to a resource shall be on an individual resource basis, not on an aggregate basis.

The resource shall refund payments received for Synchronized Reserve it failed to provide. For purposes of determining the amount of the payments to be refunded by a Market Participant, the Office of the Interconnection shall calculate the shortfall of Synchronized Reserve on an individual resource basis unless the Market Participant had multiple resources that were assigned or self-scheduled to provide Synchronized Reserve, in which case the shortfall will be determined on an aggregate basis. For performance determined on an aggregate basis, the response of any resource that provided more Synchronized Reserve than it was assigned or self-scheduled to provide will be used to offset the performance of other resources that provided less Synchronized Reserve than they were assigned or self-scheduled to provide during a Synchronized Reserve Event, as calculated in the PJM Manuals. The determination of a Market Participant's aggregate response shall not be taken into consideration in the determination of the amount of Synchronized Reserve credited to each individual resource.

The amount refunded shall be determined by multiplying the retroactive penalty megawatts by the Real-time Synchronized Reserve Market Clearing Price for all intervals the resource was assigned or self-scheduled to provide Synchronized Reserve for a period of time immediately preceding the Synchronized Reserve Event equal to the lesser of the average number of days between Synchronized Reserve Events, or the number of days since the resource last failed to provide the amount of Synchronized Reserve it was assigned or self-scheduled to provide in response to a Synchronized Reserve Event. The retroactive penalty megawatts for each interval shall be the lesser of the amount of the shortfall of Synchronized Reserve, measured in megawatts, and the real-time Synchronized Reserve assignment for each interval, which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements for the resource. The average number of days between Synchronized Reserve Events for purposes of this calculation shall be determined by an annual review of the twenty-four month period ending October 31 of the calendar year in which the review is performed, and shall be rounded down to a whole day value. The Office of the Interconnection shall report the results of its annual review to stakeholders by no later than December 31, and the average number of days between Synchronized Reserve Events shall be effective as of the following January 1. The refunded charges shall be allocated as credits to Market Participants based on its pro rata share of the Synchronized Reserve Obligation megawatts in the hour(s) of the Synchronized Reserve Event for the Reserve Sub-zone or Reserve Zone, except that Market Participants that incur a refund obligation and also have an applicable Synchronized Reserve Obligation during the hour(s) of the Synchronized Reserve Event shall not be included in the allocation of such refund credits. If the event spans multiple hours, the refund credits will be prorated hourly based on the duration of the event within each clock hour.

(k) The magnitude of response to a Synchronized Reserve Event by a generation resource or an Economic Load Response Participant resource, except for Batch Load Economic Load Response Participant resources covered by section 3.2.3A(l), is the difference between the generation resource's output or the Economic Load Response Participant resource's consumption at the start of the event and its output or consumption 10 minutes after the start of the event. In

order to allow for small fluctuations and possible telemetry delays, generation resource output or Economic Load Response Participant resource consumption at the start of the event is defined as the lowest telemetered generator resource output or greatest Economic Load Response Participant resource consumption between one minute prior to and one minute following the start of the event. Similarly, a generation resource's output or an Economic Load Response Participant resource's consumption 10 minutes after the event is defined as the greatest generator resource output or lowest Economic Load Response Participant resource consumption achieved between 9 and 11 minutes after the start of the event. The response actually credited to a generation resource will be reduced by the amount the megawatt output of the generation resource falls below the level achieved after 10 minutes by either the end of the event or after 30 minutes from the start of the event, whichever is shorter. The response actually credited to an Economic Load Response Participant resource will be reduced by the amount the megawatt consumption of the Economic Load Response Participant resource exceeds the level achieved after 10 minutes by either the end of the event or after 30 minutes from the start of the event, whichever is shorter.

(l) The magnitude of response by a Batch Load Economic Load Response Participant resource that is at the stage in its production cycle when its energy consumption is less than the level of megawatts in its offer at the start of a Synchronized Reserve Event shall be the difference between (i) the Batch Load Economic Load Response Participant resource's consumption at the end of the Synchronized Reserve Event and (ii) the Batch Load Economic Load Response Participant resource's consumption during the minute within the ten minutes after the end of the Synchronized Reserve Event in which the Batch Load Economic Load Response Participant resource's consumption was highest and for which its consumption in all subsequent minutes within the ten minutes was not less than fifty percent of the consumption in such minute; provided that, the magnitude of the response shall be zero if, when the Synchronized Reserve Event commences, the scheduled off-cycle stage of the production cycle is greater than ten minutes. .

3.2.3A.001 Non-Synchronized Reserve.

(a) Each Market Participant that is a Load Serving Entity that is not part of an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have an obligation for hourly Non-Synchronized Reserve equal to its pro rata share of Non-Synchronized Reserve assigned for the hour for each Reserve Zone and Reserve Sub-zone of the PJM Region, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Reserve Zone and Reserve Sub-zone for the hour ("Non-Synchronized Reserve Obligation"). Those entities that participate in an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have their reserve obligations determined based on the stipulations in such agreement. A Market Participant's hourly Non-Synchronized Reserve Obligation shall be adjusted by any Non-Synchronized Reserve provided on the Market Participant's behalf through a bilateral agreement. A Market Participant with an hourly Non-Synchronized Reserve Obligation shall be charged the pro rata share of the sum day-ahead and real-time credits for Non-Synchronized Reserve as defined in sections 3.2.3A.001(b)(i) and (ii) below.

(b) Resources assigned to provide Non-Synchronized Reserve at the direction of the Office of the Interconnection shall be credited as follows:

(i) Credits for Non-Synchronized Reserve provided by generation resources assigned to provide Non-Synchronized Reserve by the Office of the Interconnection in the Day-ahead Non-Synchronized Reserve Market shall be equal to the product of the Day-ahead Non-Synchronized Market Clearing Price multiplied by the megawatt amount of Non-Synchronized Reserve such resource is assigned to provide.

(ii) Credits for Non-Synchronized Reserve provided by generation resources assigned to provide Non-Synchronized Reserve by the Office of the Interconnection in the Real-time Non-Synchronized Reserve Market shall be determined for each operating hour based on the sum on their hourly total of Real-time Settlement Interval deviations determined in accordance with the following equation:

$$\sum_i ((A - B) * C)$$

Where:

i = the Real-time Settlement Intervals in the applicable operating hour;

A = For each Real-time Settlement Interval, the megawatts of Non-Synchronized Reserve from that resource assigned by the Office of the Interconnection in the Real-time Non-Synchronized Reserve Market;

B = For each Real-time Settlement Interval, the megawatts of Non-Synchronized Reserve from that resource assigned by the Office of the Interconnection in the Day-ahead Non-Synchronized Reserve Market; and

C = For each Real-time Settlement Interval, the Real-time Non-Synchronized Reserve Market Clearing Price.

(iii) Pool-scheduled generation resources assigned to provide Non-Synchronized Reserve in the Day-ahead Non-Synchronized Reserve Market shall be credited a Non-Synchronized Reserve lost opportunity cost credit, where positive, as determined in accordance with subsection (d)(iii) below, to recover any net monetary loss to the Market Seller of such resource associated with the purchase of Non-Synchronized Reserve in the Real-time Non-Synchronized Reserve Market as a result of following the dispatch direction of the Office of the Interconnection.

(c) Non-Synchronized Reserve Market Clearing Prices

(i) For the Day-ahead Non-Synchronized Reserve Market, the Non-Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection for each hour of the Operating Day. The Day-ahead Non-Synchronized Reserve Market Clearing Price shall be

calculated as the price of serving the next increment of demand for Primary Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Non-Synchronized Reserve offer prices and the applicable Operating Reserve Demand Curve for Non-Synchronized Reserve established in accordance with Operating Agreement, Schedule 1, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Primary Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for Primary Reserve can contribute and (B) the price of serving the next increment of demand for 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Primary Reserve can contribute, provided that the Non-Synchronized Reserve Market Clearing Price shall be less than or equal to the product of 1.5 multiplied by the Reserve Penalty Factor for the Primary Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Non-Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.10.8(d), Day-ahead Non-Synchronized Reserve Market Clearing Prices shall be set to zero dollars per megawatt-hour and for purposes of settlements for such Operating Day, the Office of the Interconnection shall utilize a scheduled megawatt quantity and Day-ahead Non-Synchronized Reserve Market Clearing Price of zero dollars per megawatt-hour and all settlements will be based on the Real-time Non-Synchronized Reserve market quantities and prices as determined pursuant to subsection (c)(ii) hereof.

(ii) For the Real-time Non-Synchronized Reserve Market, the Non-Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection in the Real-time Price software program, which is known as the pricing run, for each Real-time Settlement Interval of the Operating Day. Each 5-minute clearing price shall be calculated as the price of serving the next increment of demand for Primary Reserve in a Reserve Zone or Reserve Sub-zone determined by the interaction between a supply curve formed using Non-Synchronized Reserve offer prices and the applicable Operating Reserve Demand Curve for Non-Synchronized Reserve established in accordance with Operating Agreement, Schedule 1, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Primary Reserve for any other Reserve Zone or Reserve Subzone to which the next increment of demand for Primary Reserve can contribute and (B) the price of serving the next increment of demand for 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Primary Reserve can contribute, provided that the Non-Synchronized Reserve Market Clearing Price shall be less than or equal to the product of 1.5 multiplied by the Reserve Penalty Factor for the Primary Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Non-Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, and the Office of the Interconnection is not

assigning Non-Synchronized Reserves, then the Non-Synchronized Reserve Clearing Price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, where the real-time Market Suspension is less than or equal to six (6) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Non-Synchronized Reserves, then the Non-Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Non-Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than six (6) consecutive hours but less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are cleared Day-ahead Non-Synchronized Reserve Market Clearing Prices for the affected Operating Day, then the Real-time Non-Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the Day-ahead Non-Synchronized Reserve Market Clearing Prices for each corresponding hour. If no such Day-ahead Non-Synchronized Reserve Market Clearing Prices exist, then the Non-Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Non-Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than twenty-four (24) consecutive hours, the Non-Synchronized Reserve Market Clearing Price will be set to zero dollars per megawatt-hour regardless of whether the Office of the Interconnection is assigning Non-Synchronized Reserves.

If the Office of the Interconnection has initiated in a Reserve Zone or Reserve Sub-zone either a Voltage Reduction Action as described in the PJM Manuals or a Manual Load Dump Action as described in the PJM Manuals, the Real-time Non-Synchronized Reserve Market Clearing Price shall be the product of 1.5 multiplied by the Reserve Penalty Factor for the Primary Reserve Requirement for that Reserve Zone or Reserve Sub-zone.

(iii) The Reserve Penalty Factor for the Primary Reserve Requirement shall be \$850/MWh.

The Reserve Penalty Factor for the Extended Primary Reserve Requirement shall be \$300/MWh.

(iv) By no later than April 30 of each year, the Office of the Interconnection will analyze Market Participants' response to prices exceeding \$1,000/MWh on an annual basis and will provide its analysis to PJM stakeholders. The Office of the

Interconnection will also review this analysis to determine whether any changes to the Primary Reserve Penalty Factors are warranted for subsequent Delivery Year(s).

(d) (i) For determining the Non-Synchronized Reserve clearing price for each hour in the Day-ahead Non- Synchronized Reserve Market and for each Real-time Settlement Interval in the Real-time Non-Synchronized Reserve Market, including during a declaration of a Market Suspension, the unit-specific opportunity cost for a generation resource that is not providing energy because they are providing Non-Synchronized Reserves will be zero.

(ii) For each Real-time Settlement Interval, a total Market Revenue Neutrality Offset is calculated for each resource, if eligible. If there is a decrease in real-time reserve MW from a day-ahead market assignment in more than one market for that Real-time Settlement Interval, the total Market Revenue Neutrality Offset is allocated to the Non-Synchronized Reserve market based on the ratio of the opportunity cost owed due to a reduction in assignment in real-time within the Non-Synchronized Reserve market and the total opportunity cost owed due to a reduction in assignment in real-time from all reserve markets, not to exceed the resource's opportunity cost owed in the Non-Synchronized Reserve market.

A resource is not eligible for Market Revenue Neutrality Offset for Non-Synchronized Reserve in a Real-time Settlement Interval for any of the following conditions:

(A) A resource's real-time Non-Synchronized Reserve assignment decreases due to the resource being self-scheduled to provide energy, Synchronized Reserve, or Regulation;

(B) A resource reduces flexibility in real-time such that the resource no longer qualifies to provide Non-Synchronized Reserve in real-time;

(C) A resource's Final Offer is less than its Committed Offer;

(D) A resource trips offline or otherwise becomes unavailable in real-time; or

(E) A resource does not follow dispatch as described in section 3.2.3(o) above and section 3.2.3(o-1) above.

(iii) A Non-Synchronized Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:

$$(\text{zero}) - (A + B + C + D)$$

Where:

A = day-ahead clearing price credits as determined in subsection (b)(i) above;

B = real-time clearing price credits as determined in subsection (b)(ii) above;

C = the applicable Market Revenue Neutrality Offset as determined in subsection (d)(ii) above; and

D = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A.001(d)(ii) above if not eligible for Market Revenue Neutrality Offset.

(e) [Reserved for future use]

(f) For each operating hour, the sum of the Non-Synchronized Reserve lost opportunity cost credits credited in subsection (b)(iii) above shall be allocated and charged to each Market Participant that does not meet its hourly Non-Synchronized Reserve Obligation in proportion to its real-time purchases of Non-Synchronized Reserve in megawatt-hours during that hour.

(g) The magnitude of response to a Non-Synchronized Reserve Event by a generation resource is the difference between the generation resource's output at the start of the event and its output 10 minutes after the start of the event. In order to allow for small fluctuations and possible telemetry delays, generation resource output at the start of the event is defined as the lowest telemetered generator resource output between one minute prior to and one minute following the start of the event. Similarly, a generation resource's output 10 minutes after the start of the event is defined as the greatest generator resource output achieved between 9 and 11 minutes after the start of the event. The response actually credited to a generation resource will be reduced by the amount the megawatt output of the generation resource falls below the level achieved after 10 minutes by either the end of the event or after 30 minutes from the start of the event, whichever is shorter.

(h) In the event a generation resource that has been assigned by the Office of the Interconnection to provide Non-Synchronized Reserve fails to provide the assigned amount of Non-Synchronized Reserve in response to a Non-Synchronized Reserve Event, the resource will be credited for Non-Synchronized Reserve capacity in the amount that actually responded for the contiguous Real-time Settlement Interval the resource was assigned Non-Synchronized Reserve during which the event occurred.

3.2.3A.01 Secondary Reserve.

(a) Each Market Participant that is a Load Serving Entity shall have an obligation for hourly Secondary Reserve equal to its pro rata share of Secondary Reserve assigned for the hour for each Reserve Zone and Reserve Sub-zone of the PJM Region, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than

zero) in such Reserve Zone and Reserve Sub-zone for the hour (“Secondary Reserve Obligation”). A Market Participant’s hourly Secondary Reserve Obligation shall be adjusted by any Secondary Reserve provided on the Market Participant’s behalf through a bilateral agreement. A Market Participant with an hourly Secondary Reserve Obligation shall be charged the pro rata share of the sum of day-ahead and real-time credits for Secondary Reserve as defined in sections 3.2.3A.01(b)(i) and (ii) below.

(b) Resources assigned to provide Secondary Reserve at the direction of the Office of the Interconnection shall be credited as follows:

(i) Credits for Secondary Reserve provided by generation resources and Economic Load Response Participant resources assigned to provide Secondary Reserve by the Office of the Interconnection in the Day-ahead Secondary Reserve Market shall be equal to the product of the Day-ahead Secondary Reserve Market Clearing Price multiplied by the megawatt amount of Secondary Reserve such resource is scheduled to provide.

(ii) Credits for Secondary Reserve provided by generation resources and Economic Load Response Participant resources scheduled to provide Secondary Reserve by the Office of the Interconnection in the Real-time Secondary Reserve Market shall be determined for each operating hour based on the sum of their hourly total of Real-time Settlement Interval deviations determined in accordance with the following equation:

$$\sum_i ((A - B) * C)$$

Where:

i = the Real-time Settlement Intervals in the applicable operating hour;

A = For each Real-time Settlement Interval, the megawatts of Secondary Reserve from that resource assigned by the Office of the Interconnection in the Real-time Secondary Reserve Market. The megawatt value is capped at the lesser of the Economic Maximum or Secondary Reserve maximum MW minus the Revenue Data for Settlements of the resource for each Real-time Settlement Interval minus the Real-time Synchronized Reserve assignment;

B = For each Real-time Settlement Interval, the megawatts of Secondary Reserve from that resource scheduled by the Office of the Interconnection in the Day-ahead Secondary Reserve Market; and

C = For each Real-time Settlement Interval, the Real-time Secondary Reserve Market Clearing Price.

(iii) Pool-scheduled resources and Economic Load Response Participant resources shall be credited a Secondary Reserve lost opportunity cost credit, where positive, as described in subsection (f)(iv) below.

(c) [Reserved for future use]

(d) Secondary Reserve Market Clearing Prices

(i) For the Day-ahead Secondary Reserve Market, the Secondary Reserve Market Clearing Price shall be determined for each Reserve Zone and, as applicable, Reserve Sub-zone by the Office of the Interconnection for each hour of the Operating Day. The Day-ahead Secondary Reserve Market Clearing Price shall be calculated as the price of serving the next increment of demand for 30-minute Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Secondary Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Secondary Reserve established in accordance with Operating Agreement, Schedule 1, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus the price of serving the next increment of demand for 30-minute Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute, but the Secondary Reserve Market Clearing Price shall not exceed the Reserve Penalty Factor for the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.10.8(d), Day-ahead Secondary Reserve Market Clearing Prices shall be set to zero dollars per megawatt-hour and for purposes of settlements for such Operating Day, the Office of the Interconnection shall utilize a scheduled megawatt quantity and Day-ahead Secondary Reserve Market Clearing Price of zero dollars per megawatt-hour and all settlements will be based on the Real-time Secondary Reserve market quantities and prices as determined pursuant to subsection (d)(ii) hereof.

(ii) For the Real-time Secondary Reserve Market, the Secondary Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection for each Real-time Settlement Interval of the Operating Day. Each 5-minute clearing price shall be calculated as the price of serving the next increment of demand for 30-minute Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Secondary Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Secondary Reserve established in accordance with Operating Agreement, Schedule 1, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus the price of serving the next increment of demand for 30-minute Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute but the Secondary Reserve Market Clearing Price shall not exceed the Reserve Penalty Factor for the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, and the Office of the Interconnection is not assigning Secondary Reserves, then the Secondary Reserve Clearing Price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, where the real-time Market Suspension is less than or equal to six (6) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Secondary Reserves, then the Secondary Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Secondary Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than six (6) consecutive hours but less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are cleared Day-ahead Secondary Reserve Market Clearing Prices for the affected Operating Day, then the Real-time Secondary Reserve Market Clearing Prices associated with such Market Suspension shall be the Day-ahead Secondary Reserve Market Clearing Prices for each corresponding hour. If no such Day-ahead Secondary Reserve Market Clearing Prices exist, then the Secondary Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Secondary Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than twenty-four (24) consecutive hours, and the Office of the Interconnection is assigning Secondary Reserves, the Secondary Reserve Market Clearing Price will be set to zero dollars per megawatt-hour. Resources will be compensated for lost opportunity cost per subsection (f) hereof using the energy price as determined in Operating Agreement, Schedule 1, section 2.5.2.iii.

If the Office of the Interconnection has initiated in a Reserve Zone or Reserve Sub-zone either a Voltage Reduction Action or a Manual Load Dump Action as described in the PJM Manuals, the Real-time Secondary Reserve Market Clearing Price for a given Reserve Zone or Sub-zone shall be the Reserve Penalty Factor for the 30-minute Reserve Requirements for that Reserve Zone or Reserve Sub-zone

(iii) The Reserve Penalty Factor for the 30-minute Reserve Requirement shall be \$850/MWh.

The Reserve Penalty Factor for the Extended 30-minute Reserve Requirement shall be \$300/MWh.

(iv) By no later than April 30 of each year, the Office of the Interconnection will analyze Market Participants' response to prices exceeding \$1,000/MWh on an annual basis and will provide its analysis to PJM stakeholders. The Office of the Interconnection will also review this

analysis to determine whether any changes to the Reserve Penalty Factor for 30-minute Reserve are warranted for subsequent Delivery Year(s).

(e) (i) For determining the Secondary Reserve Market Clearing Price for each hour in the Day-ahead Secondary Reserve Market, the estimated resource-specific opportunity cost for a generation resource or Economic Load Response Participant resources shall be the difference between the Locational Marginal Price at the generation or Economic Load Response Participant resource bus and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) or offer price to reduce energy from the Economic Load Response Participant resource in the PJM Interchange Energy Market when the Locational Marginal Price at the Economic Load Response Participant resource bus is greater than the offer price for energy from the generation resource or the offer price to reduce energy from the Economic Load Response Participant resource.

However, opportunity costs shall be zero for resources self-scheduled to provide Synchronized Reserve, and for synchronous condensers and for Economic Load Response Participant resources that do not receive a day-ahead commitment to provide energy in the same operating hour in which such resource is committed to provide Secondary Reserve.

(ii) For determining the Secondary Reserve Market Clearing Price for each Real-time Settlement Interval in the Real-time Secondary Reserve Market, the estimated unit-specific opportunity cost for a generation resource that is not a hydroelectric resource shall be the difference between the Locational Marginal Price at the generation bus for the generation resource and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) in the PJM Interchange Energy Market when the Locational Marginal Price at the generation bus is greater than the offer price for energy from the generation resource.

For hydroelectric resources, the estimated unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the expected real-time Locational Marginal Price at that generation bus. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the expected real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average day-ahead Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

However, the opportunity costs shall be zero for resources self-scheduled to provide Synchronized Reserve, and for synchronous condensers and Economic Load Response Participant resources.

(f) (i) In determining the credit under subsection (b) to a generation resource, except a generation resource that is a synchronous condenser, selected to provide Secondary Reserve in the Day-ahead Secondary Reserve Market or an Economic Load Response Participant resource that is selected to provide Secondary Reserve in the Day-ahead Secondary Reserve Market in the same operating hour in which such resource receives a day-ahead commitment to provide energy, the opportunity cost of a resource shall be determined for each operating hour that the Office of the Interconnection requires a resource to provide Secondary Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Day-ahead Locational Marginal Price at the generation bus of the generation resource or the applicable pricing point for the Economic Load Response Participant resource;

B= The deviation of the resource's energy output or load reduction necessary to supply a Day-ahead Secondary Reserve assignment from the resource's expected energy output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load less any Day-ahead Synchronized Reserve Market assignment; and

C = The Day-ahead Energy Market offer integrated under the applicable energy offer curve for the resource's energy output or load reduction necessary to provide a Day-ahead Secondary Reserve Market assignment from the resource's expected energy output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load less any Day-ahead Synchronized Reserve Market assignment.

For a generation resource that is a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: [energy use for providing synchronous condensing multiplied by A] plus [the applicable condense start-up cost divided by the number of hours the resource is assigned Secondary Reserve].

(ii) In determining the credit under subsection (b) to a generation resource, except a generation that is a synchronous condenser, selected to provide Secondary Reserve in the Real-time Secondary Reserve Market in excess of the resource's Day-ahead Secondary Reserve Market assignment and that actively follows the Office of the Interconnection's signals and instructions, the unit-specific opportunity cost of that generation resource shall be determined for each Real-time Settlement Interval that the Office of the Interconnection requires that generation resource to provide Secondary Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Real-time Locational Marginal Price at the generation bus of the generation resource;

B= The deviation of the generation resource's output necessary to supply Secondary Reserve in real-time in excess of its Day-ahead Secondary Reserve Market assignment and follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy less any Real-time Synchronized Reserve Market assignment; and

C = The energy offer integrated under the applicable energy offer curve for the generation resource's output necessary to supply Secondary Reserve in real-time from the lesser of the generation resource's output necessary to provide a Day-ahead Secondary Reserve Market assignment or follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy less any Real-time Synchronized Reserve Market assignment.

For hydroelectric resources, the unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the real-time Locational Marginal Price at that generation bus multiplied by the additional megawatts assigned to supply Synchronized Reserve in real-time in excess of its Day-ahead Secondary Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average real-time Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating multiplied by the additional megawatts assigned to supply Secondary Reserve in real-time in excess of its Day-ahead Secondary Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

For a generation resource that is a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: additional energy use in excess of day-ahead energy use for providing synchronous condensing in real-time multiplied by A plus [any applicable condense start-up costs due to additional condense start-ups in

real-time in excess of day-ahead condense start-ups allocated to each Real-time Settlement Interval as described in PJM Manuals]. If the generation resource is operating as a synchronous condenser and also has a Real-time Synchronized Reserve assignment, resource's unit-specific opportunity cost in the Secondary Reserve Market shall be zero,

(iii) For each Real-time Settlement Interval, a total Market Revenue Neutrality Offset is calculated for each resource, if eligible. If there is a decrease in real-time reserve MW from a day-ahead market assignment in more than one market for that real-time settlement interval, the total Market Revenue Neutrality Offset is allocated to the Secondary Reserve market based on the ratio of the opportunity cost owed due to a reduction in assignment in real-time within the Secondary Reserve market and the total opportunity cost owed due to a reduction in assignment in real-time from all reserve markets, not to exceed the resource's opportunity cost owed in the Secondary Reserve market.

A resource is not eligible for Market Revenue Neutrality Offset for Secondary Reserve in a Real-time Settlement Interval for any of the following conditions:

(A) A resource's real-time Secondary Reserve assignment decreases due to the resource being self-scheduled to provide energy, Synchronized Reserve, or Regulation;

(B) A resource reduces flexibility in real-time such that the resource no longer qualifies to provide Secondary Reserve in real-time;

(C) A resource's Final Offer is less than its Committed Offer;

(D) A resource trips offline or otherwise becomes unavailable in real-time;

(E) A resource does not follow dispatch as described in section 3.2.3(o) above and section 3.2.3(o-1) above; or

(F) A resource that fails to come online and reach Economic Minimum output within 30 minutes as described in section 3.2.3A.01(h)(i) below.

(iv) A Secondary Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:

$$(A + B) - (C + D + E + F)$$

Where:

A = day-ahead opportunity cost as determined in subsection (f)(i) above;

B = real-time opportunity cost as determined in subsection (f)(ii) above;

C = day-ahead clearing price credits as determined in subsection (b)(i) above;

D = real-time clearing price credits as determined subsection (b)(ii) above;

E = the applicable Market Revenue Neutrality Offset as determined in subsection (f)(iii) above; and

F = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A.01(f)(iii) above if not eligible for Market Revenue Neutrality Offset.

(v) The opportunity costs for Economic Load Response Participant resources and generation resources not synchronized to the grid shall be zero, except that Economic Load Response Participant resources may have a day-ahead opportunity cost, as determined in subsection (f)(i) above.

(g) For each operating hour, the sum of the Secondary Reserve lost opportunity cost credits credited in accordance with subsection (b)(iii) above shall be allocated and charged to each Market Participant that does not meet its hourly Secondary Reserve Obligation in proportion to its real-time purchases of Secondary Reserve in megawatt-hours during that hour.

(h) (i) In the event an offline generation resource has been assigned by the Office of the Interconnection to provide Secondary Reserve in real-time and is subsequently dispatched by the Office of the Interconnection to supply energy during that Operating Day and the resource qualifies as a Secondary Reserve resource at the time it is dispatched to provide energy, the Office of the Interconnection will assess the resource's performance as follows:

For each generation resource that fails to come online and reach Economic Minimum output within 30 minutes as instructed by the Office of the Interconnection, the resource's Real-time Secondary Reserve assignment will be set to zero megawatts for that interval and for all prior intervals in which the resource was assigned to provide Secondary Reserve in the Real-time Secondary Reserve Market starting at the later of (A) the last interval the resource was online or (B) the beginning of that Operating Day and continuing up to the interval the resource failed to come online. This results in the resource buying back the day-ahead assignment at the Real-time Secondary Reserve Market Clearing Price, or if solely assigned in real-time not being paid for the assigned MW.

(ii) In the event an Economic Load Response Participant resource has been assigned by the Office of the Interconnection to provide Secondary Reserve in real-time and is subsequently dispatched to supply the Secondary Reserve assignment as a load reduction, the Office of the Interconnection will assess the resource's performance as follows:

For the purposes of this subsection, a resource's starting MW usage shall be the greatest telemetered consumption between one minute prior to and one minute following the issuance of a dispatch instruction from the Office of the Interconnection, and a resource's ending MW usage shall be the lowest consumption between 29 and 31 minutes after the issuance of a dispatch instruction from the Office of the Interconnection.

For each Economic Load Response Participant resource that fails to reduce load by at least the Economic Minimum, where the measured response is the difference between the resource's starting MW usage and the resource's ending MW usage as described above, within 30 minutes as instructed by the Office of the Interconnection, the resource's Real-time Secondary Reserve assignment will be set to zero megawatts for that interval, and for all prior intervals in which the resource was assigned to provide Secondary Reserve in the Real-time Secondary Reserve Market between such non-performance event starting at the later of (A) the last interval the resource reduced load at the instruction of the Office of the Interconnection or (B) the beginning of that Operating Day, and for all subsequent intervals through the earlier of (C) the next interval in which the resource is dispatched to reduce load or (D) the end of the Operating Day. This results in the resource buying back the day-ahead assignment at the Real-time Secondary Reserve Market Clearing Price, or if solely assigned in real-time, refunding all payments due for Secondary Reserve during such period.

(iii) For Batch Load Economic Load Response Participant Resources, a second method of verification will be used for instances where a Secondary Reserve assignment dispatched as an energy load reduction is initiated and the resource is operating at the minimum consumption level of its duty cycle. In this case, the magnitude of the response will be measured as the difference between (A) the minimum of the resource's consumption between the minute before and the minute after the end of the last settlement interval the resource reduced load at the instruction of the Office of the Interconnection and (B) the maximum consumption within a ten (10) minute period following the end of the last settlement interval the resource reduced load provided that all subsequent minutes following that minute are no less than 50% of the consumption in that minute.

For each Batch Load Economic Load Response Participant Resource that fails to reduce load by at least the Economic Minimum, where the measured response is the difference between the resource's starting MW usage and the resource's ending MW usage as described in section (ii) above or the difference between (A) and (B) as described in section (iii) above, within 30 minutes as instructed by the Office of the Interconnection, the resource's Real-time Secondary Reserve assignment will be set to zero megawatts for that interval, and for all prior intervals in which the resource was assigned to provide Secondary Reserve in either the Day-ahead or Real-time Secondary Reserve Markets between such non-performance event starting at the later of (A) the last interval the resource reduced load at the instruction of the Office of the Interconnection or (B) the beginning of that Operating Day, and for all subsequent intervals through the earlier of (C) the next interval in which the resource is dispatched to reduce load or (D) the end of the Operating Day. This results in the resource buying back the day-ahead assignment at the Real-

time Secondary Reserve Market Clearing Price, or if solely assigned in real-time, refunding all payments due for Secondary Reserve during such period.

3.2.3A.02 Operating Reserve Demand Curves

The Office of the Interconnection shall establish Operating Reserve Demand Curves for clearing 30-minute Reserve, Primary Reserve, and Synchronized Reserve, for, as applicable, each Reserve Zone or Reserve Sub-zone to procure sufficient reserves to meet, as applicable, (a) 30-minute Reserve Requirement and Extended 30-minute Reserve Requirement; (b) Primary Reserve Requirement and Extended Primary Reserve Requirement; and (c) Synchronized Reserve Requirement and Extended Synchronized Reserve Requirement. The Operating Reserve Demand Curves established for each reserve type shall be used to commit such reserves in both the day-ahead and real-time reserve markets. The Operating Reserve Demand Curves shall be determined in accordance with the applicable Reserve Penalty Factors and PJM Manuals.

3.2.3B Reactive Services.

(a) A Market Seller providing Reactive Services at the direction of the Office of the Interconnection shall be credited as specified below for the operation of its resource. These provisions are intended to provide payments to generating units when the LMP dispatch algorithms would not result in the dispatch needed for the required reactive service. LMP will be used to compensate generators that are subject to redispatch for reactive transfer limits.

(b) At the end of each Operating Day, where the active energy output of a Market Seller's resource is reduced or suspended at the request of the Office of the Interconnection for the purpose of maintaining reactive reliability within the PJM Region, the Market Seller shall be credited according to sections 3.2.3B(c) & 3.2.3B(d).

(c) A Market Seller providing Reactive Services from either a steam-electric generating unit or combined cycle unit operating in combined cycle mode, where such unit is pool-scheduled (or self-scheduled, if operating according to Operating Agreement, Schedule 1, section 1.10.3 (c) hereof), and where the real time LMP at the unit's bus is higher than the price offered by the Market Seller for energy from the unit at the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override) shall be compensated for lost opportunity cost by receiving a credit for each Real-time Settlement Interval in an amount equal to the product of (A) the deviation of the generating unit's output necessary to follow the Office of the Interconnection's signals and the generating unit's expected output level if it had been dispatched in economic merit order, times (B) the Real-time Price at the generation bus for the generating unit, minus (C) the Total Lost Opportunity Cost Offer, provided that the resulting outcome is greater than \$0.00. This equation is represented as $(A*B) - C$.

(d) A Market Seller providing Reactive Services from either a combustion turbine unit or combined cycle unit operating in simple cycle mode that is pool scheduled (or self-scheduled, if operating according to Operating Agreement, Schedule 1, section 1.10.3 (c)

hereof), operated as requested by the Office of the Interconnection, shall be compensated for lost opportunity cost for each Real-time Settlement Interval, limited to the lesser of the unit's Economic Maximum or the unit's Generation Resource Maximum Output, if the unit output is reduced at the direction of the Office of the Interconnection and the real time LMP at the unit's bus is higher than the price offered by the Market Seller for energy from the unit at the level of output requested by the Office of the Interconnection as directed by the PJM dispatcher, then the Market Seller shall be credited in a manner consistent with that described above in section 3.2.3B(c) for a steam unit or a combined cycle unit operating in combined cycle mode.

(e) At the end of each Operating Day, where the active energy output of a Market Seller's unit is increased at the request of the Office of the Interconnection for the purpose of maintaining reactive reliability within the PJM Region and the offered price of the energy is above the real-time LMP at the unit's bus, the Market Seller shall be credited according to section 3.2.3B(f).

(f) A Market Seller providing Reactive Services from either a steam-electric generating unit, combined cycle unit or combustion turbine unit, where such unit is pool scheduled (or self-scheduled, if operating according to Operating Agreement, Schedule 1, section 1.10.3 (c) hereof), and where the real time LMP at the unit's bus is lower than the price offered by the Market Seller for energy from the unit at the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override), shall receive a credit in an amount equal to $\{(AG - LMP_{DMW}) \times (UB - URTLMP)\}$ where:

AG equals the actual output of the unit;

LMP_{DMW} equals the level of output for the unit determined according to the point on the scheduled offer curve on which the unit was operating corresponding to the real time LMP at the unit's bus and adjusted for any Regulation or Tier 2 Synchronized Reserve assignments;

UB equals the unit offer for that unit for which output is increased, determined according to the lesser of the Final Offer or Committed Offer;

URTLMP equals the real time LMP at the unit's bus; and

where $UB - URTLMP$ shall not be negative.

(g) A Market Seller providing Reactive Services from a hydroelectric resource where such resource is pool scheduled (or self-scheduled, if operating according to Operating Agreement, Schedule 1, section 1.10.3 (c) hereof), and where the output of such resource is altered from the schedule submitted by the Market Seller for the purpose of maintaining reactive reliability at the request of the Office of the Interconnection, shall be compensated for lost opportunity cost in the same manner as provided in sections 3.2.2(d) and 3.2.3A(f) and further detailed in the PJM Manuals.

(h) If a Market Seller believes that, due to specific pre-existing binding commitments to which it is a party, and that properly should be recognized for purposes of this section, the above calculations do not accurately compensate the Market Seller for lost opportunity cost associated with following the Office of the Interconnection's dispatch instructions to reduce or suspend a unit's output for the purpose of maintaining reactive reliability, then the Office of the Interconnection, the Market Monitoring Unit and the individual Market Seller will discuss a mutually acceptable, modified amount of such alternate lost opportunity cost compensation, taking into account the specific circumstances binding on the Market Seller. Following such discussion, if the Office of the Interconnection accepts a modified amount of alternate lost opportunity cost compensation, the Office of the Interconnection shall invoice the Market Participant accordingly. If the Market Monitoring Unit disagrees with the modified amount of alternate lost opportunity cost compensation, as accepted by the Office of the Interconnection, it will exercise its powers to inform the Commission staff of its concerns.

(i) The amount of Synchronized Reserve provided by generating units maintaining reactive reliability shall be counted as Synchronized Reserve satisfying the overall PJM Synchronized Reserve requirements. Operators of these generating units shall be notified of such provision, and to the extent a generating unit's operator indicates that the generating unit is capable of providing Synchronized Reserve, shall be subject to the same requirements contained in section 3.2.3A regarding provision of Synchronized Reserve. At the end of each Operating Day, to the extent a condenser operated to provide Reactive Services also provided Synchronized Reserve, a Market Seller shall be credited for providing synchronous condensing for the purpose of maintaining reactive reliability at the request of the Office of the Interconnection, in an amount equal to the higher of (i) the Synchronized Reserve Market Clearing Price for each Real-time Settlement Interval a generating unit provided synchronous condensing multiplied by the amount of Synchronized reserve provided by the synchronous condenser or (ii) the sum of (A) the generating unit's cost to provide synchronous condensing, calculated in accordance with the PJM Manuals, (B) the product of MW energy usage for providing synchronous condensing multiplied by the real time LMP at the generating unit's bus, (C) the generating unit's startup-cost of providing synchronous condensing, and (D) the unit-specific lost opportunity cost of the generating resource supplying the increment of Synchronized Reserve as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals. To the extent a condenser operated to provide Reactive Services was not also providing Synchronized Reserve, the Market Seller shall be credited only for the generating unit's cost to condense, as described in (ii) above. The total Synchronized Reserve Obligations of all Load Serving Entities under section 3.2.3A(a) in the zone where these condensers are located shall be reduced by the amount counted as satisfying the PJM Synchronized Reserve requirements. The Synchronized Reserve Obligation of each Load Serving Entity in the zone under section 3.2.3A(a) shall be reduced to the same extent that the costs of such condensers counted as Synchronized Reserve are allocated to such Load Serving Entity pursuant to subsection (l) below.

(j) A Market Seller's pool scheduled steam-electric generating unit or combined cycle unit operating in combined cycle mode, that is not committed to operate in the Day-ahead Market, but that is directed by the Office of the Interconnection to operate solely for the purpose of maintaining reactive reliability, at the request of the Office of the Interconnection, shall be

credited in the amount of the unit's offered price for start-up and no-load fees. The unit also shall receive, if applicable, compensation in accordance with Sections 3.2.3B(e)-(f).

(k) The sum of the foregoing credits as specified in Sections 3.2.3B(b)-(j) shall be the cost of Reactive Services for the purpose of maintaining reactive reliability for the Operating Day and shall be separately determined for each transmission zone in the PJM Region based on whether the resource was dispatched for the purpose of maintaining reactive reliability in such transmission zone.

(l) The cost of Reactive Services for the purpose of maintaining reactive reliability in a transmission zone in the PJM Region for each Operating Day shall be allocated and charged to each Market Participant in proportion to its deliveries of energy to load (net of operating Behind The Meter Generation) in such transmission zone, served under Network Transmission Service, in megawatt-hours during that Operating Day, as compared to all such deliveries for all Market Participants in such transmission zone.

(m) Generating units receiving dispatch instructions from the Office of the Interconnection under the expectation of increased actual or reserve reactive shall inform the Office of the Interconnection dispatcher if the requested reactive capability is not achievable. Should the operator of a unit receiving such instructions realize at any time during which said instruction is effective that the unit is not, or likely would not be able to, provide the requested amount of reactive support, the operator shall as soon as practicable inform the Office of the Interconnection dispatcher of the unit's inability, or expected inability, to provide the required reactive support, so that the associated dispatch instruction may be cancelled. PJM Performance Compliance personnel will audit operations after-the-fact to determine whether a unit that has altered its active power output at the request of the Office of the Interconnection has provided the actual reactive support or the reactive reserve capability requested by the Office of the Interconnection. PJM shall utilize data including, but not limited to, historical reactive performance and stated reactive capability curves in order to make this determination, and may withhold such compensation as described above if reactive support as requested by the Office of the Interconnection was not or could not have been provided.

3.2.3C Synchronous Condensing for Post-Contingency Operation.

(a) Under normal circumstances, PJM operates generation out of merit order to control contingency overloads when the flow on the monitored element for loss of the contingent element ("contingency flow") exceeds the long-term emergency rating for that facility, typically a 4-hour or 2-hour rating. At times however, and under certain, specific system conditions, PJM does not operate generation out of merit order for certain contingency overloads until the contingency flow on the monitored element exceeds the 30-minute rating for that facility ("post-contingency operation"). In conjunction with such operation, when the contingency flow on such element exceeds the long-term emergency rating, PJM operates synchronous condensers in the areas affected by such constraints, to the extent they are available, to provide greater certainty that such resources will be capable of producing energy in sufficient time to reduce the flow on the monitored element below the normal rating should such contingency occur.

(b) The amount of Synchronized Reserve provided by synchronous condensers associated with post-contingency operation shall be counted as Synchronized Reserve satisfying the applicable Synchronized Reserve Requirements. Operators of these generation units shall be notified of such provision, and to the extent a generation unit's operator indicates that the generation unit is capable of providing Synchronized Reserve, shall be subject to the same requirements contained in section 3.2.3A regarding provision of Synchronized Reserve. At the end of each Operating Day, to the extent a condenser operated in conjunction with post-contingency operation also provided Synchronized Reserve, a Market Seller shall be credited for providing synchronous condensing in conjunction with post-contingency operation at the request of the Office of the Interconnection, in an amount equal to the higher of (i) the Real-time Synchronized Reserve Market Clearing Price for each applicable interval a generation resource provided synchronous condensing multiplied by the amount of Synchronized Reserve provided by the synchronous condenser or (ii) the sum of (A) the generation resource's applicable interval cost to provide synchronous condensing, calculated in accordance with the PJM Manuals, (B) the applicable interval product of the megawatts of energy used to provide synchronous condensing multiplied by the real-time LMP at the generation bus of the generation resource, (C) the generation resource's start-up cost of providing synchronous condensing, and (D) the unit-specific lost opportunity cost of the generation resource supplying the increment of Synchronized Reserve as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals. To the extent a condenser operated in association with post-contingency constraint control was not also providing Synchronized Reserve, the Market Seller shall be credited only for the generation unit's cost to condense, as described in (ii) above. The total Synchronized Reserve Obligations of all Load Serving Entities under section 3.2.3A(a) in the zone where these condensers are located shall be reduced by the amount counted as satisfying the PJM Synchronized Reserve requirements. The Synchronized Reserve Obligation of each Load Serving Entity in the zone under section 3.2.3A(a) shall be reduced to the same extent that the costs of such condensers counted as Synchronized Reserve are allocated to such Load Serving Entity pursuant to subsection (d) below.

(c) The sum of the foregoing credits as specified in section 3.2.3C(b) shall be the cost of synchronous condensers associated with post-contingency operations for the Operating Day and shall be separately determined for each transmission zone in the PJM Region based on whether the resource was dispatched in association with post-contingency operation in such transmission zone.

(d) The cost of synchronous condensers associated with post-contingency operations in a transmission zone in the PJM Region for each Operating Day shall be allocated and charged to each Market Participant in proportion to its deliveries of energy to load (net of operating Behind The Meter Generation) in such transmission zone, served under Network Transmission Service, in megawatt-hours during that Operating Day, as compared to all such deliveries for all Market Participants in such transmission zone.

3.2.4 Transmission Congestion Charges.

Each Market Buyer shall be assessed Transmission Congestion Charges as specified in Operating Agreement, Schedule 1, section 5.

3.2.5 Transmission Loss Charges.

Each Market Buyer shall be assessed Transmission Loss Charges as specified in Operating Agreement, Schedule 1, section 5.

3.2.6 Emergency Energy.

(a) When the Office of the Interconnection has implemented Emergency procedures, resources offering Emergency energy are eligible to set real-time Locational Marginal Prices, capped at the energy offer cap plus the sum of the applicable Reserve Penalty Factors for the Synchronized Reserve Requirement and Primary Reserve Requirement, provided that the Emergency energy is needed to meet demand in the PJM Region.

(b) Market Participants shall be allocated a proportionate share of the net cost of Emergency energy purchased by the Office of the Interconnection. Such allocated share during each applicable interval of such Emergency energy purchase shall be in proportion to the amount of each Market Participant's real-time deviation from its net withdrawals and injections in the Day-ahead Energy Market, whenever that deviation increases the Market Participant's spot market purchases or decreases its spot market sales. This deviation shall not include any reduction or suspension of output of pool scheduled resources requested by PJM to manage an Emergency within the PJM Region.

(c) Net revenues in excess of Real-time Prices attributable to sales of energy in connection with Emergencies to other Control Areas shall be credited to Market Participants during each applicable interval of such Emergency energy sale in proportion to the sum of (i) each Market Participant's real-time deviation from its net withdrawals and injections in the Day-ahead Energy Market, whenever that deviation increases the Market Participant's spot market purchases or decreases its spot market sales, and (ii) each Market Participant's energy sales from within the PJM Region to entities outside the PJM Region that have been curtailed by PJM.

(d) The net costs or net revenues associated with sales or purchases of energy in connection with a Minimum Generation Emergency in the PJM Region, or in another Control Area, shall be allocated during each applicable interval of such Emergency sale or purchase to each Market Participant in proportion to the amount of each Market Participant's real-time deviation from its net withdrawals and injections in the Day-ahead Market, whenever that deviation increases the Market Participant's spot market sales or decreases its spot market purchases.

3.2.7 Billing.

(a) PJM Settlement shall prepare a billing statement each billing cycle for each Market Participant in accordance with the charges and credits specified in Operating Agreement, Schedule 1, sections 3.2.1 through 3.2.6, and showing the net amount to be paid or received by the Market Participant. Billing statements shall provide sufficient detail, as specified in the PJM Manuals, to allow verification of the billing amounts and completion of the Market Participant's internal accounting.

(b) If deliveries to a Market Participant that has PJM Interchange meters in accordance with Operating Agreement, section 14 include amounts delivered for a Market Participant that does not have PJM Interchange meters separate from those of the metered Market Participant, PJMSettlement shall prepare a separate billing statement for the unmetered Market Participant based on the allocation of deliveries agreed upon between the Market Participant and the unmetered Market Participant specified by them to the Office of the Interconnection.

7.1 Auctions of Financial Transmission Rights.

Annual, periodic and long-term auctions to allow Market Participants to acquire or sell Financial Transmission Rights shall be conducted by the Office of the Interconnection in accordance with the provisions of this Section. PJMSettlement shall be the Counterparty to the purchases and sales of Financial Transmission Rights arising from such auctions; provided however, that PJMSettlement shall not be a contracting party to any subsequent bilateral transfer of Financial Transmission Rights between Market Participants. The conversion of an Auction Revenue Right to a Financial Transmission Right pursuant to this section 7 shall not constitute a purchase or sale transaction to which PJMSettlement is a contracting party.

7.1.1 Auction Period and Scope of Auctions.

(a) The periods covered by auctions shall be: (1) the one-year period beginning the month after the final round of an annual auction; and (2) any single calendar month period remaining in the Planning Period. With the exception of FTRs allocated pursuant to Operating Agreement, Schedule 1, section 5.2.2 (e) and the Financial Transmission Rights awarded as a result of the exercise of the conversion option pursuant to Operating Agreement, Schedule 1, section 7.1.1(b), in the annual auction, the Office of the Interconnection, on behalf of PJMSettlement, shall offer for sale the entire Financial Transmission Rights capability for the year in four rounds with 25 percent of the capability offered in each round. In the monthly auction, the Office of the Interconnection, on behalf of PJMSettlement, shall offer for sale in the auction any remaining Financial Transmission Rights capability for the months remaining in the Planning Period after taking into account all of the Financial Transmission Rights already outstanding at the time of the auction. In addition, any holder of a Financial Transmission Right for the period covered by an auction may offer such Financial Transmission Right for sale in such auction. Weekend on-peak, weekday on-peak, off-peak and 24-hour Financial Transmission Rights, as those products are described in Operating Agreement, Schedule 1, section 7.3.4, will be offered in the annual and monthly auctions. FTRs will be offered as Financial Transmission Right Obligations and Financial Transmission Right Options, provided that such Financial Transmission Right Obligations and Financial Transmission Right Options shall be awarded based only on the residual system capability that remains after the allocation of Financial Transmission Rights pursuant to Operating Agreement, Schedule 1, section 5.2.2(e) and the award of Financial Transmission Rights pursuant to Operating Agreement, Schedule 1, section 7.1.1(b). Market Participants may bid for and acquire any number of Financial Transmission Rights, provided that all Financial Transmission Rights awarded are simultaneously feasible with each other and with all Financial Transmission Rights outstanding at the time of the auction and not sold into the auction. An ARR holder may self-schedule an FTR on the same path in the Annual FTR auction according to the rules described in the PJM Manuals.

(b) An Auction Revenue Rights holder may convert Auction Revenue Rights to Financial Transmission Rights, and such conversion shall not be considered a purchase or sale of Financial Transmission Rights in the auction. Such Financial Transmission Rights must (i) have the same source and sink points as the Auction Revenue Rights; and (ii) be Financial Transmission Right Obligations. The Auction Revenue Rights holder must inform the Office of the Interconnection

in accordance with the procedures established by the Office of the Interconnection that it intends to exercise the conversion option prior to close of round one of the annual Financial Transmission Rights auction. Once the conversion option is exercised, it will remain in effect for the entire Financial Transmission Rights auction. The Office of the Interconnection will designate twenty-five percent of the megawatt amount of the Auction Revenue Rights to be converted as price-taker bids in each of the four rounds of the Financial Transmission Rights auction. An Auction Revenue Rights holder that converts its Auction Revenue Rights may not designate a price bid for its converted Financial Transmission Rights and will receive a price equal to the clearing price set by other bids in the annual Financial Transmission Right auction. To the extent a market participant seeks to obtain FTRs in the annual auction through such conversion, the FTRs sought will not be included in the calculation of such market participant's credit requirement for such annual FTR auction.

7.1.2 Frequency and Time of Auctions.

Subject to Operating Agreement, Schedule 1, section 7.1.1, annual Financial Transmission Rights auctions shall offer the entire FTR capability of the PJM system in four rounds with 25 percent of the capability offered in each round. All four rounds of the annual Financial Transmission Rights auction shall occur within the two-month period (April – May) preceding the start of the PJM Planning Period. Each round shall occur over five Business Days and shall be conducted sequentially. Each round shall begin with the ~~bidding and offer~~ period. The ~~bidding and offer~~ period for annual Financial Transmission Rights auctions shall be open for three consecutive Business Days, opening the first day at 12:00 midnight (Eastern Prevailing Time) and closing the third day at 5:00 p.m. (Eastern Prevailing Time), subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e). Monthly Financial Transmission Rights auctions shall be held each month. The ~~bidding and offer~~ period for monthly Financial Transmission Rights auctions shall be open for three consecutive Business Days in the month preceding the first month for which Financial Transmission Rights are being auctioned, opening the first day at 12:00 midnight (Eastern Prevailing Time) and closing the third day at 5:00 p.m. (Eastern Prevailing Time), subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e).

7.1.3 Duration of Financial Transmission Rights.

Each Financial Transmission Right acquired in a Financial Transmission Rights auction shall entitle the holder to credits of Day-ahead Energy Market Transmission Congestion Charges for the period that was specified in the corresponding auction.

7.1A Long-Term Financial Transmission Rights Auctions.

7.1A.1 Auctions.

(i) Subsequent to each annual Financial Transmission Rights auction conducted pursuant to Operating Agreement, Schedule 1, section 7.1, the Office of the Interconnection shall conduct a long-term Financial Transmission Rights auction for the three consecutive Planning Periods immediately subsequent to the Planning Period during which the long-term Financial Transmission Rights auction is conducted. PJMSettlement shall be the Counterparty to the purchases and sales of Financial Transmission Rights arising from such long-term Financial Transmission Rights auctions, provided however, that PJMSettlement shall not be a contracting party to any subsequent bilateral transfers of Financial Transmission Rights between Market Participants. The conversion of an Auction Revenue Right to a Financial Transmission Right pursuant to this section 7 shall not constitute a purchase or sale transaction to which PJMSettlement is a contracting party.

(ii) The capacity offered for sale in long-term Financial Transmission Rights auctions shall be the residual system capability after the annual Auction Revenue Rights allocations and the annual Financial Transmission Rights auction. In determining the residual capability the Office of the Interconnection shall assume that all Auction Revenue Rights allocated in the immediately prior annual Auction Revenue Rights allocation process, including Auction Revenue Rights made available in which transmission facilities which were modeled out of service in the annual Auction Revenue Rights allocations return to service, are self-scheduled into Financial Transmission Rights, which shall be modeled as fixed injections and withdrawals in the long-term Financial Transmission Rights auction. Additionally, residual annual Auction Revenue Rights that become available through incremental capability created by future transmission upgrades as further described in the PJM Manuals shall be modeled as fixed injections and withdrawals in the long-term Financial Transmission Rights auction. The long-term Financial Transmission Rights auction model shall include all upgrades planned to be placed into service on or before June 30th of the first Planning Period within the three year period covered by the auction. The transmission upgrades to be modeled for this purpose shall only include those upgrades that, individually, or together, have 10% or more impact on the transmission congestion on an individual constraint or constraints with congestion of \$5 million or more affecting a common congestion path. Transmission upgrades modeled for this purpose also will be modeled in the subsequent long-term Financial Transmission Rights auction, as further detailed in the PJM Manuals. Residual Auction Revenue Rights created by an increase in transmission capability due to future transmission upgrades, as specified above, are determined only for modeling purposes and will not be allocated to Market Participants.

7.1A.2 Frequency and Timing.

The long-term Financial Transmission Rights auction process shall consist of five rounds. The first round shall be conducted by the Office of the Interconnection approximately 11 months prior to the start of the three Planning Period term covered by the relevant long-term Financial Transmission Rights auction. The second round shall be conducted approximately 2 months

after the first round. The third round shall be conducted approximately 2 months after the second round. The fourth round shall be conducted approximately 2 months after the third round, and the fifth round shall be conducted approximately 3 months after the fourth round. In each round 20 percent of total capacity available in the long-term Financial Transmission Rights auction shall be offered for sale. Eligible entities may submit bids to purchase and offers to sell Financial Transmission Rights at the start of the bidding period in each round. The bidding period shall be three Business Days ending at 5:00 p.m. on the last day, subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e). PJM performs the Financial Transmission Rights auction clearing analysis for each round and posts the auction results on the market user interface within five Business Days after the close of the bidding period for each round unless circumstances beyond PJM's control prevent PJM from meeting the applicable deadline. Under such circumstances, PJM will post the auction results at the earliest possible opportunity. If the Office of the Interconnection discovers a potential error in the results posted for a long-term Financial Transmission Rights auction, the Office of the Interconnection shall notify Market Participants as soon as possible after it is found, but in no event later than 5:00 p.m. of the Business Day immediately following the initial publication of the results for that auction. After this initial notification, if the Office of the Interconnection determines it is necessary to post modified auction results, it shall provide notification of its intent to do so, along with a description detailing the cause and scope of the error, by no later than 5:00 p.m. of the second Business Day following the initial publication of prices for that auction. The provided description will not contain information that is market sensitive or confidential. Thereafter, the Office of the Interconnection must post the corrected prices by no later than 5:00 p.m. of the fourth calendar day following the initial publication of prices in the auction. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced auction results are under publicly noticed review by the FERC.

7.1A.3 Products.

- (i) The periods covered by long-term Financial Transmission Rights auctions shall be any single Planning Period within the three Planning Period term covered by the relevant auction.
- (ii) Weekend on-peak, weekday on-peak, off-peak and 24-hour Financial Transmission Rights, as those products are described in Operating Agreement, Schedule 1, section 7.3.4, shall be offered in long-term Financial Transmission Rights auctions; Financial Transmission Rights options shall not be offered.

7.1A.4 Participation Eligibility.

- (i) To participate in long-term Financial Transmission Rights auctions an entity shall be a PJM Member or a PJM Transmission Customer. Eligible entities may submit bids or offers in long-term Financial Transmission Rights auctions, provided they own Financial Transmission Rights offered for sale.

7.1A.5 Specified Receipt and Delivery Points.

The Office of the Interconnection will post a list of available receipt and delivery points for each long-term Financial Transmission Rights auction. Eligible receipt and delivery points in long-term Financial Transmission Rights auctions shall be limited to the posted available hubs, Zones, aggregates, generators, and Interface Pricing Points.

7.3 Auction Procedures.

7.3.1 Role of the Office of the Interconnection.

Financial Transmission Rights auctions shall be conducted by the Office of the Interconnection in accordance with standards and procedures set forth in the PJM Manuals, such standards and procedures to be consistent with the requirements of this Schedule. PJMSettlement shall be the Counterparty to the purchases and sales of Financial Transmission Rights arising from such auctions, provided however, that PJMSettlement shall not be a contracting party to any subsequent bilateral transfers of Financial Transmission Rights between Market Participants. The conversion of an Auction Revenue Right to a Financial Transmission Right pursuant to this section 7 shall not constitute a purchase or sale transaction to which PJMSettlement is a contracting party. Any Financial Transmission Rights auctions conducted to liquidate a defaulting Member's Financial Transmission Rights portfolio shall be conducted by the Office of the Interconnection in accordance with the procedures set forth in section 7.3.9 below, and as may be further described in the PJM Manuals.

7.3.2 Notice of Offer.

A holder of a Financial Transmission Right wishing to offer the Financial Transmission Right for sale shall notify the Office of the Interconnection of any Financial Transmission Rights to be offered. Each Financial Transmission Right sold in an auction shall, at the end of the period for which the Financial Transmission Rights were auctioned, revert to the offering holder or the entity to which the offering holder has transferred such Financial Transmission Right, subject to the term of the Financial Transmission Right itself and to the right of such holder or transferee to offer the Financial Transmission Right in the next or any subsequent auction during the term of the Financial Transmission Right.

7.3.3 Pending Applications for Firm Service.

(a) [Reserved.]

(b) Financial Transmission Rights may be assigned to entities requesting Network Transmission Service or Firm Point-to-Point Transmission Service pursuant to Operating Agreement, Schedule 1, section 5.2.2 (e), and the parallel provisions of Tariff, Attachment K-Appendix, section 5.2.2(e), only if such Financial Transmission Rights are simultaneously feasible with all outstanding Financial Transmission Rights, including Financial Transmission Rights effective for the then-current auction period. If an assignment of Financial Transmission Rights pursuant to a pending application for Network Transmission Service or Firm Point-to-Point Transmission Service cannot be completed prior to an auction, Financial Transmission Rights attributable to such transmission service shall not be assigned for the then-current auction period. If a Financial Transmission Right cannot be assigned for this reason, the applicant may withdraw its application, or request that the Financial Transmission Right be assigned effective with the start of the next auction period.

7.3.4 Weekend On-Peak, Weekday On-Peak, Off-Peak and 24-Hour Periods.

Weekend on-peak, weekday on-peak, off-peak and 24-hour Financial Transmission Rights will be offered in the annual , long-term, and monthly auctions. Weekend on-peak Financial Transmission Rights shall cover the periods from 7:00 a.m. up to the hour ending 11:00 p.m. on Saturdays, Sundays, and holidays as defined in the PJM Manuals. Weekday on-peak Financial Transmission Rights shall cover the periods from 7:00 a.m. up to the hour ending at 11:00 p.m. on Mondays through Fridays, except holidays as defined in the PJM Manuals. Off-Peak Financial Transmission Rights shall cover the periods from 11:00 p.m. up to the hour ending 7:00 a.m. on all days. The 24-hour period shall cover the period from hour ending 1:00 a.m. to the hour ending 12:00 midnight on all days. Each bid shall specify whether it is for a weekend on-peak, weekday on-peak, off-peak, or 24-hour period.

7.3.5 Offers and Bids.

(a) Offers to sell and bids to purchase Financial Transmission Rights shall be submitted during the period set forth in Operating Agreement, Schedule 1, section 7.1.2, and the parallel provisions of Tariff, Attachment K-Appendix, section 7.1.2, and shall be in the form specified by the Office of the Interconnection in accordance with the requirements set forth below.

(b) Offers to sell shall identify the specific Financial Transmission Right, by term, megawatt quantity and receipt and delivery points, offered for sale. An offer to sell a specified megawatt quantity of Financial Transmission Rights shall constitute an offer to sell a quantity of Financial Transmission Rights equal to or less than the specified quantity. An offer to sell may not specify a minimum quantity being offered. Each offer may specify a reservation price, below which the offeror does not wish to sell the Financial Transmission Right. Offers submitted by entities holding rights to Financial Transmission Rights shall be subject to such reasonable standards for the verification of the rights of the offeror as may be established by the Office of the Interconnection. Offers shall be subject to such reasonable standards for the creditworthiness of the offeror or for the posting of security for performance as the Office of the Interconnection shall establish.

(c) Bids to purchase shall specify the term, megawatt quantity, price per megawatt, and receipt and delivery points of the Financial Transmission Right that the bidder wishes to purchase. A bid to purchase a specified megawatt quantity of Financial Transmission Rights shall constitute a bid to purchase a quantity of Financial Transmission Rights equal to or less than the specified quantity. A bid to purchase may not specify a minimum quantity that the bidder wishes to purchase. A bid may specify receipt and delivery points in accordance with Operating Agreement, Schedule 1, section 7.2.2, and the parallel provisions of Tariff, Attachment K-Appendix, section 7.2.2, and may include Financial Transmission Rights for which the associated Transmission Congestion Credits may have negative values. Bids shall be subject to such reasonable standards for the creditworthiness of the bidder or for the posting of security for performance as the Office of the Interconnection shall establish.

(d) Bids and offers shall be specified to the nearest tenth of a megawatt and shall be greater than zero. The Office of the Interconnection may require that a market participant shall

not submit in excess of 5000 bids and offers for any single monthly auction, or for any single round of the annual auction, when the Office of the Interconnection determines that such limit is required to avoid or mitigate significant system performance problems related to bid/offer volume. Notice of the need to impose such limit shall be provided prior to the start of the bidding period if possible. Where such notice is provided after the start of the bidding period, market participants shall be required within one day to reduce their bids and offers for such auction below 5000, and the bidding period in such cases shall be extended by one day.

(e) In the event of extraordinary circumstances affecting the submission of bids within the bidding period in which the Office of the Interconnection determines it necessary to extend the bidding period, the Office of the Interconnection shall notify Market Participants as soon as possible of the new bidding period ending day and time.

7.3.6 Determination of Winning Bids and Clearing Price.

(a) At the close of each bidding period, the Office of the Interconnection will create a base Financial Transmission Rights power flow model that includes all outstanding Financial Transmission Rights that have been approved and confirmed for any portion of the month for which the auction was conducted and that were not offered for sale in the auction. The base Financial Transmission Rights model also will include estimated uncompensated parallel flows into each interface point of the PJM Region and estimated scheduled transmission outages.

(b) In accordance with the requirements of Operating Agreement, Schedule 1, section 7.5, and the parallel provisions of Tariff, Attachment K-Appendix, section 7.5, and subject to all applicable transmission constraints and reliability requirements, the Office of the Interconnection shall determine the simultaneous feasibility of all outstanding Financial Transmission Rights not offered for sale in the auction and of all Financial Transmission Rights that could be awarded in the auction for which bids were submitted. The winning bids shall be determined from an appropriate linear programming model that, while respecting transmission constraints and the maximum MW quantities of the bids and offers, selects the set of simultaneously feasible Financial Transmission Rights with the highest net total auction value as determined by the bids of buyers and taking into account the reservation prices of the sellers. In the event that there are two or more identical bids for the selected Financial Transmission Rights and there are insufficient Financial Transmission Rights to accommodate all of the identical bids, then each such bidder will receive a pro rata share of the Financial Transmission Rights that can be awarded.

(c) Financial Transmission Rights shall be sold at the market-clearing price for Financial Transmission Rights between specified pairs of receipt and delivery points, as determined by the bid value of the marginal Financial Transmission Right that could not be awarded because it would not be simultaneously feasible. The linear programming model shall determine the clearing prices of all Financial Transmission Rights paths based on the bid value of the marginal Financial Transmission Rights, which are those Financial Transmission Rights with the highest bid values that could not be awarded fully because they were not simultaneously feasible, and based on the flow sensitivities of each Financial Transmission Rights path relative to the marginal Financial Transmission Rights paths flow sensitivities on the binding

transmission constraints. Financial Transmission Rights with a zero clearing price will only be awarded if there is a minimum of one binding constraint in the auction period for which the Financial Transmission Rights path sensitivity is non-zero. Financial Transmission Right Options with a market-clearing price less than one dollar will not be awarded.

7.3.7 Announcement of Winners and Prices.

Within two (2) Business Days after the close of the ~~bidding and offer~~ period for an annual Financial Transmission Rights auction round, and within five (5) Business Days after the close of the ~~bidding and offer~~ period for a monthly Financial Transmission Rights auction, the Office of the Interconnection shall post the winning bidders, the megawatt quantity, the term and the receipt and delivery points for each Financial Transmission Right awarded in the auction and the price at which each Financial Transmission Right was awarded unless circumstances beyond PJM's control prevent PJM from meeting the applicable deadline. Under such circumstances, PJM will post the auction results at the earliest possible opportunity. The Office of the Interconnection shall not disclose the price specified in any bid to purchase or the reservation price specified in any offer to sell. If the Office of the Interconnection discovers an error in the results posted for a Financial Transmission Rights auction (or a given round of the annual Financial Transmission Rights auction), the Office of the Interconnection shall notify Market Participants of the error as soon as possible after it is found, but in no event later than 5:00 p.m. of the Business Day following the initial publication of the results of the auction or round of the annual auction. After this initial notification, if the Office of the Interconnection determines that it is necessary to post modified results, it shall provide notification of its intent to do so, together with all available supporting documentation, by no later than 5:00 p.m. of the second Business Day following the initial publication of the results of that auction or round of the annual auction. Thereafter, the Office of the Interconnection must post any corrected results by no later than 5:00 p.m. of the fourth calendar day following the initial publication of the results of the auction or round of the annual auction. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced auction results are under publicly noticed review by the FERC.

7.3.8 Auction Settlements.

All buyers and sellers of Financial Transmission Rights between the same points of receipt and delivery shall pay PJM Settlement or be paid by PJM Settlement the market-clearing price, as determined in the auction, for such Financial Transmission Rights.

For a Market Suspension where the suspension is greater than twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are no Day-Ahead Prices available for the affected Operating Day, the Financial Transmission Right auction costs would be zero in proportion to the number of hours of the Market Suspension in the Operating Day.

7.3.9 Addressing Defaulting Member's Financial Transmission Rights.

In the event a Member fails to meet creditworthiness requirements or make timely payments when due pursuant to the Operating Agreement or Tariff, the Office of the Interconnection shall, as soon as practicable after declaring the Member to be in default as provided in Operating Agreement, section 15.1.5, use reasonable efforts to initiate within two applicable auctions the following procedures to settle, liquidate or otherwise resolve each Financial Transmission Rights position held by the defaulting Member:

a) The Office of the Interconnection shall unilaterally terminate all of the defaulting Member's rights with respect to forward Financial Transmission Rights positions as of the date of the Member's default.

b) As to each Financial Transmission Rights position held by the defaulting Member immediately prior to the termination of the defaulting Member's rights under subsection (a) above, the Office of the Interconnection shall determine and execute an appropriate course of action for addressing such Financial Transmission Rights position, based on the specific circumstances of the default as determined by the Office of the Interconnection in exercise of its reasonable judgment, such as (1) liquidating the position by offering it for sale in an upcoming applicable Financial Transmission Rights auction, (2) liquidating the position by offering it for sale in an auction called and scheduled for the specific purpose of liquidating one or more positions held by the defaulting Member ("Special Auction"), (3) allowing the position to go to settlement, or (4) another course of action the Office of the Interconnection determines to be appropriate under the circumstances that is designed to minimize potential losses to PJM Members. The Office of the Interconnection will provide reasonable advance notice to PJM Members of the approach or course of action it has determined to be appropriate prior to implementing that approach or course of action. The Office of the Interconnection is not required to apply a single approach to the defaulting Member's entire Financial Transmission Rights portfolio, and may determine that the appropriate course of action for addressing a defaulting Member's portfolio includes a combination of the above approaches as applied to different positions within the defaulting Member's overall Financial Transmission Rights portfolio.

c) The Office of the Interconnection will seek to minimize the losses to PJM Members associated with settling, liquidating or otherwise resolving the defaulting Member's Financial Transmission Rights portfolio and may base its determination in subsection (b) above on several factors, including but not limited to, the following:

- 1) the Office of the Interconnection's assessment of which approach will provide the greatest degree of protection to the financial integrity of the PJM Markets;
- 2) the size of the defaulting Member's Financial Transmission Rights portfolio, both in absolute terms and relative to overall market volume;
- 3) the term of the Financial Transmission Rights positions held by the defaulting Member as considered for a single position or on a portfolio basis;

- 4) whether liquidation is feasible or not, and on what timeline, due to the cessation or curtailment of trading at PJM for all Financial Transmission Rights or a subset of Financial Transmission Rights positions;
- 5) prevailing market conditions, such as but not limited to market liquidity and volatility; and
- 6) timing of the default and the actions taken to address the default.

d) Special Auctions. The Office of the Interconnection shall administer each Special Auction provided for in subsection (b)(2) above according to the procedures set forth in the Tariff and PJM Manuals for FTR auctions to the extent appropriate in the Office of the Interconnection's sole discretion, and may adopt special rules for each Special Auction to accommodate the unique circumstances underlying the particular default and particular Financial Transmission Rights positions being liquidated, with the terms and conditions of such auction being determined with the goal of facilitating a successful auction in light of the particular positions to be auctioned, the prevailing market conditions for such open positions (including the depth, scope, and nature of participation in such markets), and such other factors as the Office of the Interconnection determines appropriate, including those factors enumerated in subsection (c) above. The Office of the Interconnection shall provide reasonable advance notice to FTR Participants of a Special Auction and the terms and conditions under which it will be conducted.

e) All liquidations made pursuant to subsection (b) above shall be for the account of the defaulting Member (and all amounts owed PJM in respect thereof shall be included in amounts owed by the defaulting Member as part of its default).

f) Notwithstanding subsections 7.3.9(a) and (b) above, the actual net charges or credits resulting from the defaulting Member's Financial Transmission Rights positions for which PJM Settlement acted as counterparty as calculated through the normal settlement processes shall be included in calculating the Default Allocation Assessment charges as described in Operating Agreement, section 15.2.2.

D. FRR Capacity Plans

1. Each FRR Entity shall submit its initial FRR Capacity Plan as required by subsection C.1 of this Schedule, and shall annually extend and update such plan by no later than one month prior to the Base Residual Auction for each succeeding Delivery Year in such plan. Each FRR Capacity Plan shall indicate the nature and current status of each resource, including the status of each Planned Generation Capacity Resource or Planned Demand Resource, the planned deactivation or retirement of any Generation Capacity Resource or Demand Resource, and the status of commitments for each sale or purchase of capacity included in such plan.

1.1 Beginning with the 2020/2021 Delivery Year and for all subsequent Delivery Years, the FRR Capacity Plan shall comprise only Capacity Performance Resources and Seasonal Capacity Performance Resources.

2. The FRR Capacity Plan of each FRR Entity that commits that it will not sell surplus Capacity Resources as a Capacity Market Seller in any auction conducted under Attachment DD of the PJM Tariff, or to any direct or indirect purchaser that uses such resource as the basis of any Sell Offer in such auction, shall designate Capacity Resources in a megawatt quantity no less than the Forecast Pool Requirement for each applicable Delivery Year times the FRR Entity's allocated share of the Preliminary Zonal Peak Load Forecast for such Delivery Year, as determined in accordance with procedures set forth in the PJM Manuals. For the 2016/2017 Delivery Year and prior Delivery Years, the set of Capacity Resources designated in the FRR Capacity Plan must meet the Minimum Annual Resource Requirement and the Minimum Extended Summer Resource Requirement associated with the FRR Entity's capacity obligation. For the 2017/2018 and 2018/2019 Delivery Years, the set of Capacity Resources designated in the FRR Capacity Plan must satisfy the Limited Resource Constraints and the Sub-Annual Resource Constraints applicable to the FRR Entity's capacity obligation. For the 2019/2020 Delivery Year, the set of Capacity Resources designated in the FRR Capacity Plan must satisfy the Base Capacity Resource Constraints and Base Capacity Demand Resource Constraints applicable to the FRR Entity's capacity obligation. If the FRR Entity is not responsible for all load within a Zone, the Preliminary Forecast Peak Load for such entity shall be the FRR Entity's Obligation Peak Load last determined prior to the Base Residual Auction for such Delivery Year, times the Base Zonal FRR Scaling Factor. The FRR Capacity Plan of each FRR Entity that does not commit that it will not sell surplus Capacity Resources as set forth above shall designate Capacity Resources at least equal to the Threshold Quantity. To the extent the FRR Entity's allocated share of the Final Zonal Peak Load Forecast exceeds the FRR Entity's allocated share of the Preliminary Zonal Peak Load Forecast, such FRR Entity's FRR Capacity Plan shall be updated to designate additional Capacity Resources in an amount no less than the Forecast Pool Requirement times such increase; provided, however, any excess megawatts of Capacity Resources included in such FRR Entity's previously designated Threshold Quantity, if any, may be used to satisfy the capacity obligation for such increased load. To the extent the FRR Entity's allocated share of the Final Zonal Peak Load Forecast is less than the FRR Entity's allocated share of the Preliminary Zonal Peak Load Forecast, such FRR Entity's FRR Capacity Plan may be updated to release previously designated Capacity Resources in an amount no greater than the Forecast Pool Requirement times such decrease. Peak load values referenced in this section shall be adjusted as necessary to take into account any applicable Nominal PRD Values approved

pursuant to Schedule 6.1 of this Agreement. Any FRR Entity seeking an adjustment to peak load for Price Responsive Demand must submit a separate PRD Plan in compliance with Section 6.1 (provided that the FRR Entity shall not specify any PRD Reservation Price), and shall register all PRD-eligible load needed to satisfy its PRD commitment and be subject to compliance charges as set forth in that Schedule under the circumstances specified therein; provided that for non-compliance by an FRR Entity, the compliance charge rate shall be equal to 1.20 times the Capacity Resource Clearing Price resulting from all RPM Auctions for such Delivery Year for the LDA encompassing the FRR Entity's Zone, weight-averaged for the Delivery Year based on the prices established and quantities cleared in the RPM auctions for such Delivery Year; and provided further that an alternative PRD Provider may provide PRD in an FRR Service Area by agreement with the FRR Entity responsible for the load in such FRR Service Area, subject to the same terms and conditions as if the FRR Entity had provided the PRD.

3. As to any FRR Entity, the Base Zonal FRR Scaling Factor for each Zone in which it serves load for a Delivery Year shall equal $ZPLDY/ZWNSP$, where:

$ZPLDY$ = Preliminary Zonal Peak Load Forecast for such Zone for such Delivery Year; and

$ZWNSP$ = Zonal Weather-Normalized Summer Peak Load for such Zone for the summer concluding four years prior to the commencement of such Delivery Year.

4. Capacity Resources identified and committed in an FRR Capacity Plan shall meet all requirements under this Agreement, the PJM Tariff, and the PJM Operating Agreement applicable to Capacity Resources, including, as applicable, requirements and milestones for Planned Generation Capacity Resources and Planned Demand Resources. A Capacity Resource submitted in an FRR Capacity Plan must be on a unit-specific basis, and may not include "slice of system" or similar agreements that are not unit specific. An FRR Capacity Plan may include bilateral transactions that commit capacity for less than a full Delivery Year only if the resources included in such plan in the aggregate satisfy all obligations for all Delivery Years. All demand response, load management, energy efficiency, or similar programs on which such FRR Entity intends to rely for a Delivery Year must be included in the FRR Capacity Plan, subject to applicable demand resource constraints for the relevant Delivery Year, submitted three years in advance of such Delivery Year and must satisfy all requirements applicable to Demand Resources or Energy Efficiency Resources, as applicable, including, without limitation, those set forth in Schedule 6 to this Agreement and the PJM Manuals; provided, however, that previously uncommitted Unforced Capacity from such programs may be used to satisfy any increased capacity obligation for such FRR Entity resulting from a Final Zonal Peak Load Forecast applicable to such FRR Entity. Without limiting the generality of the foregoing, the FRR Entity must submit a Demand Resource Sell Offer Plan 15 business days before the deadline for submitting an FRR Capacity Plan as to any Demand Resources it intends to include in such FRR Capacity Plan and may only include in such FRR Capacity Plan Demand Resources that are approved by PJM following review of such Demand Resource Sell Offer Plan. The requirements, standards, and procedures for a Demand Resource Sell Offer Plan shall be as set forth in Schedule 6 of this Agreement, provided that all references (including deadlines) in Schedule 6, section A-1 to submission or clearing of a Demand Resource offer in an RPM Auction shall be understood for purposes of FRR Entities as referring to inclusion of a Demand

Resource in an FRR Capacity Plan, and a distinct Demand Resource Officer Certification Form shall be applicable to FRR Entities, as shown in the PJM Manuals and provided on the PJM website.

5. For each LDA for which the Office of the Interconnection is required to establish a separate Variable Resource Requirement Curve for any Delivery Year addressed by such FRR Capacity Plan, the plan must include a Percentage Internal Resources Required, subject to subsections D.1.1 and D.2 of this Schedule. The Percentage Internal Resources Required will be calculated as the LDA Reliability Requirement less the CETL for the Delivery Year, as determined by the RTEP process as set forth in the PJM Manuals. Such requirement shall be expressed as a percentage of the Unforced Capacity Obligation based on the Preliminary Zonal Peak Load Forecast multiplied by the Forecast Pool Requirement. Notwithstanding the provisions of Sections C.1 and C.2 of this Schedule 8.1, an FRR Entity may terminate its election of the FRR Alternative prior to meeting its minimum five year commitment without penalty for any Delivery Year after the first Delivery Year of its minimum five year FRR commitment for which the Office of the Interconnection will be required to establish a separate Variable Resource Requirement Curve by giving written notice two months prior to the Base Residual Auction for the Delivery Year. The Office of the Interconnection shall be deemed to be required to establish a separate Variable Resource Requirement Curve for an LDA if the LDA is the Eastern Mid-Atlantic Region (“EMAR”), Southwest Mid-Atlantic Region (“SWMAR”), or Mid-Atlantic Region (“MAR”), or for other LDAs if the separate modeling is required by Section 5.10(a)(ii)(A) or (B) of Attachment DD of the Tariff.

6. An FRR Entity may reduce the Percentage Internal Resources Required as to any LDA to the extent the FRR Entity commits to a transmission upgrade that increases the CETL for such LDA. Any such transmission upgrade shall adhere to all requirements for a Qualified Transmission Upgrade as set forth in Attachment DD to the PJM Tariff. The increase in CETL used in the FRR Capacity Plan shall be that approved by PJM prior to inclusion of any such upgrade in an FRR Capacity Plan. The FRR Entity shall designate specific additional Capacity Resources located in the LDA from which the CETL was increased, to the extent of such increase.

7. The Office of the Interconnection will review the adequacy of all submittals hereunder both as to timing and content. A Party that seeks to elect the FRR Alternative that submits an FRR Capacity Plan which, upon review by the Office of the Interconnection, is determined not to satisfy such Party’s capacity obligations hereunder, shall not be permitted to elect the FRR Alternative. If a previously approved FRR Entity submits an FRR Capacity Plan that, upon review by the Office of the Interconnection, is determined not to satisfy such Party’s capacity obligations hereunder, the Office of the Interconnection shall notify the FRR Entity, in writing, of the insufficiency within five (5) business days ~~of~~ after the submittal deadline of the FRR Capacity Plan. If the FRR Entity does not cure such insufficiency within five (5) business days after receiving such notice of insufficiency, then such FRR Entity shall be assessed an FRR Commitment Insufficiency Charge, in an amount equal to two times the Cost of New Entry for the relevant location, in \$/MW-day, times the shortfall of Capacity Resources below the FRR

Entity's capacity obligation (including any Threshold Quantity requirement) in such FRR Capacity Plan, for the remaining term of such plan.

8. In a state regulatory jurisdiction that has implemented retail choice, the FRR Entity must include in its FRR Capacity Plan all load, including expected load growth, in the FRR Service Area, notwithstanding the loss of any such load to or among alternative retail LSEs. In the case of load reflected in the FRR Capacity Plan that switches to an alternative retail LSE, where the state regulatory jurisdiction requires switching customers or the LSE to compensate the FRR Entity for its FRR capacity obligations, such state compensation mechanism will prevail. In the absence of a state compensation mechanism, the applicable alternative retail LSE shall compensate the FRR Entity at the capacity price in the unconstrained portions of the PJM Region, as determined in accordance with Attachment DD to the PJM Tariff, provided that the FRR Entity may, at any time, make a filing with FERC under Sections 205 of the Federal Power Act proposing to change the basis for compensation to a method based on the FRR Entity's cost or such other basis shown to be just and reasonable, and a retail LSE may at any time exercise its rights under Section 206 of the FPA.

9. Notwithstanding the foregoing, in lieu of providing the compensation described above, such alternative retail LSE may, for any Delivery Year subsequent to those addressed in the FRR Entity's then-current FRR Capacity Plan, provide to the FRR Entity Capacity Resources sufficient to meet the capacity obligation described in paragraph D.2 for the switched load. Such Capacity Resources shall meet all requirements applicable to Capacity Resources pursuant to this Agreement, the PJM Tariff, and the PJM Operating Agreement, all requirements applicable to resources committed to an FRR Capacity Plan under this Agreement, and shall be committed to service to the switched load under the FRR Capacity Plan of such FRR Entity. The alternative retail LSE shall provide the FRR Entity all information needed to fulfill these requirements and permit the resource to be included in the FRR Capacity Plan. The alternative retail LSE, rather than the FRR Entity, shall be responsible for any performance charges or compliance penalties related to the performance of the resources committed by such LSE to the switched load. For any Delivery Year, or portion thereof, the foregoing obligations apply to the alternative retail LSE serving the load during such time period. PJM shall manage the transfer accounting associated with such compensation and shall administer the collection and payment of amounts pursuant to the compensation mechanism.

Such load shall remain under the FRR Capacity Plan until the effective date of any termination of the FRR Alternative and, for such period, shall not be subject to Locational Reliability Charges under Section 7.2 of this Agreement.

E. Conditions on Purchases and Sales of Capacity Resources by FRR Entities

1. An FRR Entity may not include in its FRR Capacity Plan for any Delivery Year any Capacity Resource MWs that are committed to RPM ~~has cleared in any auction under Tariff, Attachment DD~~ for such Delivery Year. Nothing herein shall preclude an FRR Entity from including in its FRR Capacity Plan any uncommitted Capacity Resource MWs ~~that has not cleared such an auction~~ for such Delivery Year. Furthermore, nothing herein shall preclude an FRR Entity from including in its FRR Capacity Plan a Capacity Resource obtained from a different FRR Entity, provided, however, that each FRR Entity shall be individually responsible for meeting its capacity obligations hereunder, and provided further that the same megawatts of Unforced Capacity shall not be committed to more than one FRR Capacity Plan for any given Delivery Year.
2. An FRR Entity that designates Capacity Resources in its FRR Capacity Plan(s) for a Delivery Year based on the Threshold Quantity may offer to sell Capacity Resources in excess of that needed for the Threshold Quantity in any auction conducted under Tariff, Attachment DD for such Delivery Year, but may not offer to sell Capacity Resources in the auctions for any such Delivery Year in excess of an amount equal to the lesser of (a) 25% times the Unforced Capacity equivalent of the Installed Reserve Margin for such Delivery Year multiplied by the Preliminary Forecast Peak Load for which such FRR Entity is responsible under its FRR Capacity Plan(s) for such Delivery Year, or (b) 1300 MW.
3. An FRR Entity that designates Capacity Resources in its FRR Capacity Plan(s) for a Delivery Year based on the Threshold Quantity may not offer to sell such resources in any Reliability Pricing Model auction, but may use such resources to meet any increased capacity obligation resulting from unanticipated growth of the loads in its FRR Capacity Plan(s), subject to the limitations described in RAA, Schedule 8.1, section D, subsection D.2, or may sell such resources to serve loads located outside the PJM Region, or to another FRR Entity, subject to subsection E.1 above.
4. A Party that has selected the FRR Alternative for only part of its load in the PJM Region pursuant to RAA, Schedule 8.1, section B, subsection B.2 that designates Capacity Resources as Self-Supply in a Reliability Pricing Model Auction to meet such Party's expected Daily Unforced Capacity Obligation under RAA, Schedule 8 shall not be required, solely as a result of such designation, to identify Capacity Resources in its FRR Capacity Plan(s) based on the Threshold Quantity; provided, however, that such Party may not so designate Capacity Resources in an amount in excess of the lesser of (a) 25% times such Party's total expected Unforced Capacity obligation (under both RAA, Schedule 8 and RAA, Schedule 8.1), or (b) 200 MW. A Party that wishes to avoid the foregoing limitation must identify Capacity Resources in its FRR Capacity Plan(s) based on the Threshold Quantity.

Attachment B

Revisions to the
PJM Open Access Transmission Tariff,
PJM Operating Agreement
and PJM Reliability Assurance Agreement

(Clean Format)

Definitions – L – M – N

Legacy Policy:

“Legacy Policy” shall mean any legislative, executive, or regulatory action that specifically directs a payment outside of PJM Markets to a designated or prospective Generation Capacity Resource and the enactment of such action predates October 1, 2021, regardless of when any implementing governmental action to effectuate the action to direct payment outside of PJM Markets occurs.

Limited Demand Resource:

“Limited Demand Resource” shall have the meaning specified in the Reliability Assurance Agreement.

Limited Demand Resource Reliability Target:

“Limited Demand Resource Reliability Target” for the PJM Region or an LDA, shall mean the maximum amount of Limited Demand Resources determined by PJM to be consistent with the maintenance of reliability, stated in Unforced Capacity that shall be used to calculate the Minimum Extended Summer Demand Resource Requirement for Delivery Years through May 31, 2017 and the Limited Resource Constraint for the 2017/2018 and 2018/2019 Delivery Years for the PJM Region or such LDA. As more fully set forth in the PJM Manuals, PJM calculates the Limited Demand Resource Reliability Target by first: i) testing the effects of the ten-interruption requirement by comparing possible loads on peak days under a range of weather conditions (from the daily load forecast distributions for the Delivery Year in question) against possible generation capacity on such days under a range of conditions (using the cumulative capacity distributions employed in the Installed Reserve Margin study for the PJM Region and in the Capacity Emergency Transfer Objective study for the relevant LDAs for such Delivery Year) and, by varying the assumed amounts of DR that is committed and displaces committed generation, determines the DR penetration level at which there is a ninety percent probability that DR will not be called (based on the applicable operating reserve margin for the PJM Region and for the relevant LDAs) more than ten times over those peak days; ii) testing the six-hour duration requirement by calculating the MW difference between the highest hourly unrestricted peak load and seventh highest hourly unrestricted peak load on certain high peak load days (e.g., the annual peak, loads above the weather normalized peak, or days where load management was called) in recent years, then dividing those loads by the forecast peak for those years and averaging the result; and (iii) (for the 2016/2017 and 2017/2018 Delivery Years) testing the effects of the six-hour duration requirement by comparing possible hourly loads on peak days under a range of weather conditions (from the daily load forecast distributions for the Delivery Year in question) against possible generation capacity on such days under a range of conditions (using a Monte Carlo model of hourly capacity levels that is consistent with the capacity model employed in the Installed Reserve Margin study for the PJM Region and in the Capacity Emergency Transfer Objective study for the relevant LDAs for such Delivery Year) and, by varying the assumed amounts of DR that is committed and displaces committed generation, determines the DR penetration level at which there is a ninety percent probability that DR will

not be called (based on the applicable operating reserve margin for the PJM Region and for the relevant LDAs) for more than six hours over any one or more of the tested peak days. Second, PJM adopts the lowest result from these three tests as the Limited Demand Resource Reliability Target. The Limited Demand Resource Reliability Target shall be expressed as a percentage of the forecasted peak load of the PJM Region or such LDA and is converted to Unforced Capacity by multiplying [the reliability target percentage] times [the Forecast Pool Requirement] times [the DR Factor] times [the forecasted peak load of the PJM Region or such LDA, reduced by the amount of load served under the FRR Alternative].

Limited Resource Constraint:

“Limited Resource Constraint” shall mean, for the 2017/2018 Delivery Year and for FRR Capacity Plans the 2017/2018 and Delivery Years, for the PJM Region or each LDA for which the Office of the Interconnection is required under Tariff, Attachment DD, section 5.10(a) to establish a separate VRR Curve for a Delivery Year, a limit on the total amount of Unforced Capacity that can be committed as Limited Demand Resources for the 2017/2018 Delivery Year in the PJM Region or in such LDA, calculated as the Limited Demand Resource Reliability Target for the PJM Region or such LDA, respectively, minus the Short Term Resource Procurement Target for the PJM Region or such LDA, respectively.

Limited Resource Price Decrement:

“Limited Resource Price Decrement” shall mean, for the 2017/2018 Delivery Year, a difference between the clearing price for Limited Demand Resources and the clearing price for Extended Summer Demand Resources and Annual Resources, representing the cost to procure additional Extended Summer Demand Resources or Annual Resources out of merit order when the Limited Resource Constraint is binding.

List of Approved Contractors:

“List of Approved Contractors” shall mean a list developed by each Transmission Owner and published in a PJM Manual of (a) contractors that the Transmission Owner considers to be qualified to install or construct new facilities and/or upgrades or modifications to existing facilities on the Transmission Owner’s system, provided that such contractors may include, but need not be limited to, contractors that, in addition to providing construction services, also provide design and/or other construction-related services, and (b) manufacturers or vendors of major transmission-related equipment (e.g., high-voltage transformers, transmission line, circuit breakers) whose products the Transmission Owner considers acceptable for installation and use on its system.

Load Interest:

“Load Interest” shall mean, for the purposes of the minimum offer price rule, responsibility for serving load within the PJM Region, whether by the Capacity Market Seller, an affiliate of the Capacity Market Seller, or by an entity with which the Capacity Market Seller is in contractual privity with respect to the subject Generation Capacity Resource.

Load Management:

“Load Management” shall mean a Demand Resource (“DR”) as defined in the Reliability Assurance Agreement.

Load Management Event:

“Load Management Event” shall mean a) a single temporally contiguous dispatch of Demand Resources in a Compliance Aggregation Area during an Operating Day, or b) multiple dispatches of Demand Resources in a Compliance Aggregation Area during an Operating Day that are temporally contiguous.

Load Ratio Share:

“Load Ratio Share” shall mean the ratio of a Transmission Customer’s Network Load to the Transmission Provider’s total load.

Load Reduction Event:

“Load Reduction Event” shall mean a reduction in demand by a Member or Special Member for the purpose of participating in the PJM Interchange Energy Market.

Load Serving Charging Energy:

“Load Serving Charging Energy” shall mean energy that is purchased from the PJM Interchange Energy Market and stored in an Energy Storage Resource for later resale to end-use load.

Load Serving Entity (LSE):

“Load Serving Entity” or “LSE” shall have the meaning specified in the Reliability Assurance Agreement.

Load Shedding:

“Load Shedding” shall mean the systematic reduction of system demand by temporarily decreasing load in response to transmission system or area capacity shortages, system instability, or voltage control considerations under Tariff, Part II or Part III.

Local Upgrades:

“Local Upgrades” shall mean modifications or additions of facilities to abate any local thermal loading, voltage, short circuit, stability or similar engineering problem caused by the interconnection and delivery of generation to the Transmission System. Local Upgrades shall include:

(i) Direct Connection Local Upgrades which are Local Upgrades that only serve the Customer Interconnection Facility and have no impact or potential impact on the Transmission System until the final tie-in is complete; and

(ii) Non-Direct Connection Local Upgrades which are parallel flow Local Upgrades that are not Direct Connection Local Upgrades.

Location:

“Location” as used in the Economic Load Response rules shall mean an end-use customer site as defined by the relevant electric distribution company account number.

LOC Deviation:

“LOC Deviation,” shall mean, for units other than wind units, the LOC Deviation shall equal the desired megawatt amount for the resource determined according to the point on the Final Offer curve corresponding to the Real-time Settlement Interval real-time Locational Marginal Price at the resource’s bus and adjusted for any reduction in megawatts due to Regulation, Synchronized Reserve, or Secondary Reserve assignments and limited to the lesser of the unit’s Economic Maximum or the unit’s Generation Resource Maximum Output, minus the actual output of the unit. For wind units, the LOC Deviation shall mean the deviation of the generating unit’s output equal to the lesser of the PJM forecasted output for the unit or the desired megawatt amount for the resource determined according to the point on the Final Offer curve corresponding to the Real-time Settlement Interval integrated real-time Locational Marginal Price at the resource’s bus, and shall be limited to the lesser of the unit’s Economic Maximum or the unit’s Generation Resource Maximum Output, minus the actual output of the unit.

Locational Deliverability Area (LDA):

“Locational Deliverability Area” or “LDA” shall mean a geographic area within the PJM Region that has limited transmission capability to import capacity to satisfy such area’s reliability requirement, as determined by the Office of the Interconnection in connection with preparation of the Regional Transmission Expansion Plan, and as specified in Reliability Assurance Agreement, Schedule 10.1.

Locational Deliverability Area Reliability Requirement:

“Locational Deliverability Area Reliability Requirement” shall mean the projected internal capacity in the Locational Deliverability Area plus the Capacity Emergency Transfer Objective for the Delivery Year, as determined by the Office of the Interconnection in connection with preparation of the Regional Transmission Expansion Plan, less the minimum internal resources required for all FRR Entities in such Locational Deliverability Area. Notwithstanding the foregoing, effective with the 2024/2025 Delivery Year, during the auction process, the Office of Interconnection shall exclude from the Locational Deliverability Area Reliability Requirement any Planned Generation Capacity Resource in an LDA that does not participate in the relevant RPM Auction as projected internal capacity and in the Capacity Emergency Transfer Objective

model where the Locational Deliverability Area Reliability Requirement for the Base Residual Auction increases by more than one percent over the reliability requirement used from the prior Delivery Year's Base Residual Auction (for Incremental Auctions the Locational Deliverability Area Reliability Requirement would be compared with the reliability requirement used in the prior relevant RPM Auction associated with the same Delivery Year) for that LDA due to the cumulative addition of such Planned Generation Capacity Resources.

Locational Price Adder:

“Locational Price Adder” shall mean an addition to the marginal value of Unforced Capacity within an LDA as necessary to reflect the price of Capacity Resources required to relieve applicable binding locational constraints.

Locational Reliability Charge:

“Locational Reliability Charge” shall have the meaning specified in the Reliability Assurance Agreement.

Locational UCAP:

“Locational UCAP” shall mean unforced capacity that a Member with available uncommitted capacity sells in a bilateral transaction to a Member that previously committed capacity through an RPM Auction but now requires replacement capacity to fulfill its RPM Auction commitment. The Locational UCAP Seller retains responsibility for performance of the resource providing such replacement capacity.

Locational UCAP Seller:

“Locational UCAP Seller” shall mean a Member that sells Locational UCAP.

Long-lead Project:

“Long-lead Project” shall have the same meaning provided in the Operating Agreement.

Long-Term Firm Point-To-Point Transmission Service:

“Long-Term Firm Point-To-Point Transmission Service” shall mean firm Point-To-Point Transmission Service under Tariff, Part II with a term of one year or more.

Loss Price:

“Loss Price” shall mean the loss component of the Locational Marginal Price, which is the effect on transmission loss costs (whether positive or negative) associated with increasing the output of a generation resource or decreasing the consumption by a Demand Resource based on the effect of increased generation from or consumption by the resource on transmission losses, calculated

as specified in Operating Agreement, Schedule 1, section 2, and the parallel provisions of Tariff, Attachment K-Appendix, section 2.

M2M Flowgate:

“M2M Flowgate” shall have the meaning provided in the Joint Operating Agreement between the Midcontinent Independent Transmission System Operator, Inc. and PJM Interconnection, L.L.C.

Maintenance Adder:

“Maintenance Adder” shall mean an adder that may be included to account for variable operation and maintenance expenses in a Market Seller’s Fuel Cost Policy. The Maintenance Adder is calculated in accordance with the applicable provisions of PJM Manual 15, and may only include expenses incurred as a result of electric production.

Manual Load Dump Action:

“Manual Load Dump Action” shall mean an Operating Instruction, as defined by NERC, from PJM to shed firm load when the PJM Region cannot provide adequate capacity to meet the PJM Region’s load and tie schedules, or to alleviate critically overloaded transmission lines or other equipment.

Manual Load Dump Warning:

“Manual Load Dump Warning” shall mean a notification from PJM to warn Members of an increasingly critical condition of present operations that may require manually shedding load.

Marginal Value:

“Marginal Value” shall mean the incremental change in system dispatch costs, measured as a \$/MW value incurred by providing one additional MW of relief to the transmission constraint.

Market Monitor:

“Market Monitor” means the head of the Market Monitoring Unit.

Market Monitoring Unit or MMU:

“Market Monitoring Unit” or “MMU” means the independent Market Monitoring Unit defined in 18 CFR § 35.28(a)(7) and established under the PJM Market Monitoring Plan (Attachment M) to the PJM Tariff that is responsible for implementing the Market Monitoring Plan, including the Market Monitor. The Market Monitoring Unit may also be referred to as the IMM or Independent Market Monitor for PJM

Market Monitoring Unit Advisory Committee or MMU Advisory Committee:

“Market Monitoring Unit Advisory Committee” or “MMU Advisory Committee” shall mean the committee established under Tariff, Attachment M, section III.H.

Market Operations Center:

“Market Operations Center” shall mean the equipment, facilities and personnel used by or on behalf of a Market Participant to communicate and coordinate with the Office of the Interconnection in connection with transactions in the PJM Interchange Energy Market or the operation of the PJM Region.

Market Participant:

“Market Participant” shall mean a Market Buyer, a Market Seller, an Economic Load Response Participant, or all three, except when such term is used in Tariff, Attachment M, in which case Market Participant shall mean an entity that generates, transmits, distributes, purchases, or sells electricity, ancillary services, or any other product or service provided under the PJM Tariff or Operating Agreement within, into, out of, or through the PJM Region, but it shall not include an Authorized Government Agency that consumes energy for its own use but does not purchase or sell energy at wholesale.

Market Participant Energy Injection:

“Market Participant Energy Injection” shall mean transactions in the Day-ahead Energy Market and Real-time Energy Market, including but not limited to Day-ahead generation schedules, real-time generation output, Increment Offers, internal bilateral transactions and import transactions, as further described in the PJM Manuals.

Market Participant Energy Withdrawal:

“Market Participant Energy Withdrawal” shall mean transactions in the Day-ahead Energy Market and Real-time Energy Market, including but not limited to Demand Bids, Decrement Bids, real-time load (net of Behind The Meter Generation expected to be operating, but not to be less than zero), internal bilateral transactions and Export Transactions, as further described in the PJM Manuals.

Market Revenue Neutrality Offset:

“Market Revenue Neutrality Offset” shall mean the revenue in excess of the cost for a resource from the energy, Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve markets realized from an increase in real-time market megawatt assignment from a day-ahead market megawatt assignment in any of these markets due to the decrease in the real-time reserve market megawatt assignment from a day-ahead reserve market megawatt assignment in any of the reserve markets.

Market Seller Offer Cap:

“Market Seller Offer Cap” shall mean a maximum offer price applicable to certain Market Sellers under certain conditions, as determined in accordance with Tariff, Attachment DD. section 6 and Tariff, Attachment M-Appendix, section II.E.

Market Suspension:

“Market Suspension” shall mean the inability of the Office of the Interconnection to clear the Day-ahead Energy Market prior to 11:59 p.m. on the day before the affected Operating Day due to extraordinary circumstances, as further described in Operating Agreement, Schedule 1, section 1.10.8(d) and the parallel provisions of Tariff, Attachment K-Appendix, section 1.10.8(d), or the inability of the Office of the Interconnection to produce Zonal Dispatch Rates for a total of seven (7) or more Real-time Settlement Intervals within a clock hour, for the purposes of the Real-time Energy Market, as further described in Operating Agreement, Schedule 1, section 1.11.6 and the parallel provisions of Tariff, Attachment K-Appendix, section 1.11.6.

Market Violation:

“Market Violation” shall mean a tariff violation, violation of a Commission-approved order, rule or regulation, market manipulation, or inappropriate dispatch that creates substantial concerns regarding unnecessary market inefficiencies, as defined in 18 C.F.R. § 35.28(b)(8).

Material Modification:

“Material Modification” shall mean any modification to an Interconnection Request that has a material adverse effect on the cost or timing of Interconnection Studies related to, or any Network Upgrades or Local Upgrades needed to accommodate, any Interconnection Request with a later Queue Position.

Maximum Daily Starts:

“Maximum Daily Starts” shall mean the maximum number of times that a generating unit can be started in an Operating Day under normal operating conditions.

Maximum Emergency:

“Maximum Emergency” shall mean the designation of all or part of the output of a generating unit for which the designated output levels may require extraordinary procedures and therefore are available to the Office of the Interconnection only when the Office of the Interconnection declares a Maximum Generation Emergency and requests generation designated as Maximum Emergency to run. The Office of the Interconnection shall post on the PJM website the aggregate amount of megawatts that are classified as Maximum Emergency.

Maximum Facility Output:

“Maximum Facility Output” shall mean the maximum (not nominal) net electrical power output in megawatts, specified in the Interconnection Service Agreement, after supply of any parasitic or host facility loads, that a Generation Interconnection Customer’s Customer Facility is expected to produce, provided that the specified Maximum Facility Output shall not exceed the output of the proposed Customer Facility that Transmission Provider utilized in the System Impact Study.

Maximum Generation Emergency:

“Maximum Generation Emergency” shall mean an Emergency declared by the Office of the Interconnection to address either a generation or transmission emergency in which the Office of the Interconnection anticipates requesting one or more Generation Capacity Resources, or Non-Retail Behind The Meter Generation resources to operate at its maximum net or gross electrical power output, subject to the equipment stress limits for such Generation Capacity Resource or Non-Retail Behind The Meter resource in order to manage, alleviate, or end the Emergency.

Maximum Generation Emergency Alert:

“Maximum Generation Emergency Alert” shall mean an alert issued by the Office of the Interconnection to notify PJM Members, Transmission Owners, resource owners and operators, customers, and regulators that a Maximum Generation Emergency may be declared, for any Operating Day in either, as applicable, the Day-ahead Energy Market or the Real-time Energy Market, for all or any part of such Operating Day.

Maximum Run Time:

“Maximum Run Time” shall mean the maximum number of hours a generating unit can run over the course of an Operating Day, as measured by PJM’s State Estimator.

Maximum Weekly Starts:

“Maximum Weekly Starts” shall mean the maximum number of times that a generating unit can be started in one week, defined as the 168 hour period starting Monday 0001 hour, under normal operating conditions.

Member:

“Member” shall have the meaning provided in the Operating Agreement.

Merchant A.C. Transmission Facilities:

“Merchant A.C. Transmission Facility” shall mean Merchant Transmission Facilities that are alternating current (A.C.) transmission facilities, other than those that are Controllable A.C. Merchant Transmission Facilities.

Merchant D.C. Transmission Facilities:

“Merchant D.C. Transmission Facilities” shall mean direct current (D.C.) transmission facilities that are interconnected with the Transmission System pursuant to Tariff, Part IV and Part VI.

Merchant Network Upgrades:

“Merchant Network Upgrades” shall mean additions to, or modifications or replacements of, physical facilities of the Interconnected Transmission Owner that, on the date of the pertinent Transmission Interconnection Customer’s Upgrade Request, are part of the Transmission System or are included in the Regional Transmission Expansion Plan.

Merchant Transmission Facilities:

“Merchant Transmission Facilities” shall mean A.C. or D.C. transmission facilities that are interconnected with or added to the Transmission System pursuant to Tariff, Part IV and Part VI and that are so identified in Tariff, Attachment T, provided, however, that Merchant Transmission Facilities shall not include (i) any Customer Interconnection Facilities, (ii) any physical facilities of the Transmission System that were in existence on or before March 20, 2003 ; (iii) any expansions or enhancements of the Transmission System that are not identified as Merchant Transmission Facilities in the Regional Transmission Expansion Plan and Attachment T to the Tariff, or (iv) any transmission facilities that are included in the rate base of a public utility and on which a regulated return is earned.

Merchant Transmission Provider:

“Merchant Transmission Provider” shall mean an Interconnection Customer that (1) owns, controls, or controls the rights to use the transmission capability of, Merchant D.C. Transmission Facilities and/or Controllable A.C. Merchant Transmission Facilities that connect the Transmission System with another control area, (2) has elected to receive Transmission Injection Rights and Transmission Withdrawal Rights associated with such facility pursuant to Tariff, Part IV, section 36, and (3) makes (or will make) the transmission capability of such facilities available for use by third parties under terms and conditions approved by the Commission and stated in the Tariff, consistent with Tariff, section 38.

Metering Equipment:

“Metering Equipment” shall mean all metering equipment installed at the metering points designated in the appropriate appendix to an Interconnection Service Agreement.

Minimum Annual Resource Requirement:

“Minimum Annual Resource Requirement” shall mean, for Delivery Years through May 31, 2017, the minimum amount of capacity that PJM will seek to procure from Annual Resources for the PJM Region and for each Locational Deliverability Area for which the Office of the Interconnection is required under Tariff, Attachment DD, section 5.10(a) to establish a separate VRR Curve for such Delivery Year. For the PJM Region, the Minimum Annual Resource

Requirement shall be equal to the RTO Reliability Requirement minus [the Sub-Annual Resource Reliability Target for the RTO in Unforced Capacity]. For an LDA, the Minimum Annual Resource Requirement shall be equal to the LDA Reliability Requirement minus [the LDA CETL] minus [the Sub-Annual Resource Reliability Target for such LDA in Unforced Capacity]. The LDA CETL may be adjusted pro rata for the amount of load served under the FRR Alternative.

Minimum Down Time:

For all generating units that are not combined cycle units, “Minimum Down Time” shall mean the minimum number of hours under normal operating conditions between unit shutdown and unit startup, calculated as the shortest time difference between the unit’s generator breaker opening and after the unit’s generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero. For combined cycle units, “Minimum Down Time” shall mean the minimum number of hours between the last generator breaker opening and after first combustion turbine generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero.

Minimum Extended Summer Resource Requirement:

“Minimum Extended Summer Resource Requirement” shall mean, for Delivery Years through May 31, 2017, the minimum amount of capacity that PJM will seek to procure from Extended Summer Demand Resources and Annual Resources for the PJM Region and for each Locational Deliverability Area for which the Office of the Interconnection is required under Tariff, Attachment DD, section 5.10(a) to establish a separate VRR Curve for such Delivery Year. For the PJM Region, the Minimum Extended Summer Resource Requirement shall be equal to the RTO Reliability Requirement minus [the Limited Demand Resource Reliability Target for the PJM Region in Unforced Capacity]. For an LDA, the Minimum Extended Summer Resource Requirement shall be equal to the LDA Reliability Requirement minus [the LDA CETL] minus [the Limited Demand Resource Reliability Target for such LDA in Unforced Capacity]. The LDA CETL may be adjusted pro rata for the amount of load served under the FRR Alternative.

Minimum Generation Emergency:

“Minimum Generation Emergency” shall mean an Emergency declared by the Office of the Interconnection in which the Office of the Interconnection anticipates requesting one or more generating resources to operate at or below Normal Minimum Generation, in order to manage, alleviate, or end the Emergency.

Minimum Participation Requirements:

“Minimum Participation Requirements” shall mean a set of minimum training, risk management, communication and capital or collateral requirements required for Participants in the PJM Markets, as set forth herein and in the Form of Annual Certification set forth as Tariff, Attachment Q, Appendix 1. Participants transacting in FTRs in certain circumstances will be

required to demonstrate additional risk management procedures and controls as further set forth in the Annual Certification found in Tariff, Attachment Q, Appendix 1.

Minimum Run Time:

For all generating units that are not combined cycle units, “Minimum Run Time” shall mean the minimum number of hours a unit must run, in real-time operations, from the time after generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero, to the time of generator breaker opening, as measured by PJM's State Estimator. For combined cycle units, “Minimum Run Time” shall mean the time period after the first combustion turbine generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero to the time of the last generator breaker opening as measured by PJM’s State Estimator.

MISO:

“MISO” shall mean the Midcontinent Independent System Operator, Inc. or any successor thereto.

Mixed Technology Facility:

“Mixed Technology Facility” shall mean a facility composed of distinct generation and/or electric storage technology types behind the same Point of Interconnection. Co-Located Resources and Hybrid Resources form all or part of Mixed Technology Facilities.

MOPR Floor Offer Price:

“MOPR Floor Offer Price” shall mean a minimum offer price applicable to certain Market Seller’s Capacity Resources under certain conditions, as determined in accordance with Tariff, Attachment DD, sections 5.14(h), 5.14(h-1), and 5.14(h-2).

Multi-Driver Project:

“Multi-Driver Project” shall have the same meaning provided in the Operating Agreement.

Native Load Customers:

“Native Load Customers” shall mean the wholesale and retail power customers of a Transmission Owner on whose behalf the Transmission Owner, by statute, franchise, regulatory requirement, or contract, has undertaken an obligation to construct and operate the Transmission Owner’s system to meet the reliable electric needs of such customers.

NERC:

“NERC” shall mean the North American Electric Reliability Corporation or any successor thereto.

NERC Interchange Distribution Calculator:

“NERC Interchange Distribution Calculator” shall mean the NERC mechanism that is in effect and being used to calculate the distribution of energy, over specific transmission interfaces, from energy transactions.

Net Benefits Test:

“Net Benefits Test” shall mean a calculation to determine whether the benefits of a reduction in price resulting from the dispatch of Economic Load Response exceeds the cost to other loads resulting from the billing unit effects of the load reduction, as specified in Operating Agreement, Schedule 1, section 3.3A.4 and the parallel provisions of Tariff, Attachment K-Appendix, section 3.3A.4.

Net Cost of New Entry:

“Net Cost of New Entry” shall mean the Cost of New Entry minus the Net Energy and Ancillary Service Revenue Offset.

Net Obligation:

“Net Obligation” shall mean the amount owed to PJMSettlement and PJM for purchases from the PJM Markets, Transmission Service, (under Tariff, Parts II and III , and other services pursuant to the Agreements, after applying a deduction for amounts owed to a Participant by PJMSettlement as it pertains to monthly market activity and services. Should other markets be formed such that Participants may incur future Obligations in those markets, then the aggregate amount of those Obligations will also be added to the Net Obligation.

Net Sell Position:

“Net Sell Position” shall mean the amount of Net Obligation when Net Obligation is negative.

Network Customer:

“Network Customer” shall mean an entity receiving transmission service pursuant to the terms of the Transmission Provider’s Network Integration Transmission Service under Tariff, Part III.

Network External Designated Transmission Service:

“Network External Designated Transmission Service” shall have the meaning set forth in Reliability Assurance Agreement, Article I.

Network Integration Transmission Service:

“Network Integration Transmission Service” shall mean the transmission service provided under Tariff, Part III.

Network Load:

“Network Load” shall mean the load that a Network Customer designates for Network Integration Transmission Service under Tariff, Part III. The Network Customer’s Network Load shall include all load (including losses, Non-Dispatched Charging Energy, and Load Serving Charging Energy) served by the output of any Network Resources designated by the Network Customer. A Network Customer may elect to designate less than its total load as Network Load but may not designate only part of the load at a discrete Point of Delivery. Where an Eligible Customer has elected not to designate a particular load at discrete points of delivery as Network Load, the Eligible Customer is responsible for making separate arrangements under Tariff, Part II for any Point-To-Point Transmission Service that may be necessary for such non-designated load. Network Load shall not include Dispatched Charging Energy.

Network Operating Agreement:

“Network Operating Agreement” shall mean an executed agreement that contains the terms and conditions under which the Network Customer shall operate its facilities and the technical and operational matters associated with the implementation of Network Integration Transmission Service under Tariff, Part III.

Network Operating Committee:

“Network Operating Committee” shall mean a group made up of representatives from the Network Customer(s) and the Transmission Provider established to coordinate operating criteria and other technical considerations required for implementation of Network Integration Transmission Service under Tariff, Part III.

Network Resource:

“Network Resource” shall mean any designated generating resource owned, purchased, or leased by a Network Customer under the Network Integration Transmission Service Tariff. Network Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Network Customer’s Network Load on a non-interruptible basis, except for purposes of fulfilling obligations under a reserve sharing program.

Network Service User:

“Network Service User” shall mean an entity using Network Transmission Service.

Network Transmission Service:

“Network Transmission Service” shall mean transmission service provided pursuant to the rates, terms and conditions set forth in Tariff, Part III, or transmission service comparable to such service that is provided to a Load Serving Entity that is also a Transmission Owner.

Network Upgrades:

“Network Upgrades” shall mean modifications or additions to transmission-related facilities that are integrated with and support the Transmission Provider’s overall Transmission System for the general benefit of all users of such Transmission System. Network Upgrades shall include:

(i) **Direct Connection Network Upgrades** which are Network Upgrades that are not part of an Affected System; only serve the Customer Interconnection Facility; and have no impact or potential impact on the Transmission System until the final tie-in is complete. Both Transmission Provider and Interconnection Customer must agree as to what constitutes Direct Connection Network Upgrades and identify them in the Interconnection Construction Service Agreement, Schedule D. If the Transmission Provider and Interconnection Customer disagree about whether a particular Network Upgrade is a Direct Connection Network Upgrade, the Transmission Provider must provide the Interconnection Customer a written technical explanation outlining why the Transmission Provider does not consider the Network Upgrade to be a Direct Connection Network Upgrade within 15 days of its determination.

(ii) **Non-Direct Connection Network Upgrades** which are parallel flow Network Upgrades that are not Direct Connection Network Upgrades.

Neutral Party:

“Neutral Party” shall have the meaning provided in Tariff, Part I, section 9.3(v).

New Entry Capacity Resource with State Subsidy:

“New Entry Capacity Resource with State Subsidy” shall mean (1) starting with the 2022/2023 Delivery Year, the MWs (in installed capacity) comprising a Capacity Resource with State Subsidy that have not cleared in an RPM Auction pursuant to its Sell Offer at or above its resource-specific MOPR Floor Offer Price or the applicable default New Entry MOPR Floor Offer Price or (2) starting with the Base Residual Auction for the 2022/2023 Delivery Year, any of those MWs (in installed capacity) comprising a Capacity Resource with State Subsidy that was not included in an FRR Capacity Plan at the time of the Base Residual Auction or the subject of a Sell Offer in a Base Residual Auction occurring for a Delivery Year after it last cleared an RPM Auction and since then has yet to clear an RPM Auction pursuant to its Sell Offer at or above its resource-specific MOPR Floor Offer Price or the applicable default New Entry MOPR Floor Offer Price. Notwithstanding the foregoing, any Capacity Resource that previously cleared an RPM Auction before it became entitled to receive a State Subsidy shall not be deemed a New Entry Capacity Resource, unless, starting with the Base Residual Auction for the 2022/2023 Delivery Year, the Capacity Resource with State Subsidy was not the subject of a Sell Offer in a Base Residual Auction or included in an FRR Capacity Plan at the time of the Base Residual Auction for a Delivery Year after it last cleared an RPM Auction.

New PJM Zone(s):

“New PJM Zone(s)” shall mean the Zone included in the Tariff, along with applicable Schedules and Attachments, for Commonwealth Edison Company, The Dayton Power and Light Company and the AEP East Operating Companies (Appalachian Power Company, Columbus Southern Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company).

New Service Customers:

“New Service Customers” shall mean all customers that submit an Interconnection Request, a Completed Application, or an Upgrade Request that is pending in the New Services Queue.

New Service Request:

“New Service Request” shall mean an Interconnection Request, a Completed Application, or an Upgrade Request.

New Services Queue:

“New Services Queue” shall mean all Interconnection Requests, Completed Applications, and Upgrade Requests that are received within each six-month period ending on March 31 and September 30 of each year shall collectively comprise a New Services Queue.

New York ISO or NYISO:

“New York ISO” or “NYISO” shall mean the New York Independent System Operator, Inc. or any successor thereto.

Nodal Reference Price:

The “Nodal Reference Price” at each location shall mean the 97th percentile price differential between day-ahead and real-time prices experienced over the corresponding two-month reference period in the prior calendar year. Reference periods will be Jan-Feb, Mar-Apr, May-Jun, Jul-Aug, Sept-Oct, Nov-Dec. For any given current-year month, the reference period months will be the set of two months in the prior calendar year that include the month corresponding to the current month. For example, July and August 2003 would each use July-August 2002 as their reference period.

No-load Cost:

“No-load Cost” shall mean the hourly cost required to theoretically operate a synchronized unit at zero MW. It consists primarily of the cost of fuel, as determined by the unit’s no load heat (adjusted by the performance factor) times the fuel cost. It also includes operating costs, Maintenance Adders, and emissions allowances.

Nominal Rated Capability:

“Nominal Rated Capability” shall mean the nominal maximum rated capability in megawatts of a Transmission Interconnection Customer’s Customer Facility or the nominal increase in transmission capability in megawatts of the Transmission System resulting from the interconnection or addition of a Transmission Interconnection Customer’s Customer Facility, as determined in accordance with pertinent Applicable Standards and specified in the Interconnection Service Agreement.

Nominated Demand Resource Value:

“Nominated Demand Resource Value” shall mean the amount of load reduction that a Demand Resource commits to provide either through direct load control, firm service level or guaranteed load drop programs. For existing Demand Resources, the maximum Nominated Demand Resource Value is limited, in accordance with the PJM Manuals, to the value appropriate for the method by which the load reduction would be accomplished, at the time the Base Residual Auction or Incremental Auction is being conducted.

Nominated Energy Efficiency Value:

“Nominated Energy Efficiency Value” shall mean the amount of load reduction that an Energy Efficiency Resource commits to provide through installation of more efficient devices or equipment or implementation of more efficient processes or systems.

Non-Dispatched Charging Energy:

“Non-Dispatched Charging Energy” shall mean all Direct Charging Energy that an Energy Storage Resource Model Participant receives from the electric grid that is not otherwise Dispatched Charging Energy.

Non-Firm Point-To-Point Transmission Service:

“Non-Firm Point-To-Point Transmission Service” shall mean Point-To-Point Transmission Service under the Tariff that is reserved and scheduled on an as-available basis and is subject to Curtailment or Interruption as set forth in Tariff, Part II, section 14.7. Non-Firm Point-To-Point Transmission Service is available on a stand-alone basis for periods ranging from one hour to one month.

Non-Firm Sale:

“Non-Firm Sale” shall mean an energy sale for which receipt or delivery may be interrupted for any reason or no reason, without liability on the part of either the buyer or seller.

Non-Firm Transmission Withdrawal Rights:

“No-Firm Transmission Withdrawal Rights” shall mean the rights to schedule energy withdrawals from a specified point on the Transmission System. Non-Firm Transmission Withdrawal Rights may be awarded only to a Merchant D.C. Transmission Facility that connects the Transmission System to another control area. Withdrawals scheduled using Non-Firm Transmission Withdrawal Rights have rights similar to those under Non-Firm Point-to-Point Transmission Service.

Non-Performance Charge:

“Non-Performance Charge” shall mean the charge applicable to Capacity Performance Resources as defined in Tariff, Attachment DD, section 10A(e).

Nonincumbent Developer:

“Nonincumbent Developer” shall have the same meaning provided in the Operating Agreement.

Non-Regulatory Opportunity Cost:

“Non-Regulatory Opportunity Cost” shall mean the difference between (a) the forecasted cost to operate a specific generating unit when the unit only has a limited number of starts or available run hours resulting from (i) the physical equipment limitations of the unit, for up to one year, due to original equipment manufacturer recommendations or insurance carrier restrictions, (ii) a fuel supply limitation, for up to one year, resulting from an event of Catastrophic Force Majeure; and, (b) the forecasted future Locational Marginal Price at which the generating unit could run while not violating such limitations. Non-Regulatory Opportunity Cost therefore is the value associated with a specific generating unit’s lost opportunity to produce energy during a higher valued period of time occurring within the same period of time in which the unit is bound by the referenced restrictions, and is reflected in the rules set forth in PJM Manual 15. Non-Regulatory Opportunity Costs shall be limited to those resources which are specifically delineated in Operating Agreement, Schedule 2.

Non-Retail Behind The Meter Generation:

“Non-Retail Behind The Meter Generation” shall mean Behind the Meter Generation that is used by municipal electric systems, electric cooperatives, or electric distribution companies to serve load.

Non-Synchronized Reserve:

“Non-Synchronized Reserve” shall mean the reserve capability of non-emergency generation resources that can be converted fully into energy within ten minutes of a request from the Office of the Interconnection dispatcher, and is provided by equipment that is not electrically synchronized to the Transmission System.

Non-Synchronized Reserve Event:

“Non-Synchronized Reserve Event” shall mean a request from the Office of the Interconnection to generation resources able and assigned to provide Non-Synchronized Reserve in one or more specified Reserve Zones or Reserve Sub-zones, within ten minutes to increase the energy output by the amount of assigned Non-Synchronized Reserve capability.

Non-Variable Loads:

“Non-Variable Loads” shall have the meaning specified in Operating Agreement, Schedule 1, section 1.5A.6, and the parallel provisions of Tariff, Attachment K-Appendix, section 1.5A.6.

Non-Zone Network Load:

“Non-Zone Network Load shall mean Network Load that is located outside of the PJM Region.

Normal Maximum Generation:

“Normal Maximum Generation” shall mean the highest output level of a generating resource under normal operating conditions.

Normal Minimum Generation:

“Normal Minimum Generation” shall mean the lowest output level of a generating resource under normal operating conditions.

1.10 Scheduling.

1.10.1 General.

(a) The Office of the Interconnection shall administer scheduling processes to implement a Day-ahead Energy Market and a Real-time Energy Market. PJMSettlement shall be the Counterparty to the purchases and sales of energy that clear the Day-ahead Energy Market and the Real-time Energy Market; provided that PJMSettlement shall not be a contracting party to bilateral transactions between Market Participants or with respect to a Generating Market Buyer's self-schedule or self-supply of its generation resources up to that Generating Market Buyer's Equivalent Load.

(b) The Day-ahead Energy Market shall enable Market Participants to purchase and sell energy through the PJM Interchange Energy Market at Day-ahead Prices and enable Transmission Customers to reserve transmission service with Transmission Congestion Charges and Transmission Loss Charges based on locational differences in Day-ahead Prices. Up-to Congestion Transactions submitted in the Day-ahead Energy Market shall not require transmission service and Transmission Customers shall not reserve transmission service for such Up-to Congestion Transactions. Market Participants whose purchases and sales, and Transmission Customers whose transmission uses are scheduled in the Day-ahead Energy Market, shall be obligated to purchase or sell energy, or pay Transmission Congestion Charges and Transmission Loss Charges, at the applicable Day-ahead Prices for the amounts scheduled.

(c) (i) In the Real-time Energy Market, Market Participants that deviate from the amounts of energy purchases or sales scheduled in the Day-ahead Energy Market shall be obligated to purchase or sell energy for the amount of the deviations at the applicable Real-time Prices or price differences, unless otherwise specified by this Schedule.

(ii) In the Real-time Energy Market, Transmission Customers that deviate from the transmission uses, scheduled in the Day-ahead Energy Market shall be obligated to pay Transmission Congestion Charges and Transmission Loss Charges for the amount of the deviations at the applicable Real-time Prices or price differences, unless otherwise specified by this Schedule.

(iii) Market Participants that deviate in real-time from the amounts of Secondary Reserve, Non-Synchronized Reserve, or Synchronized Reserve sales, scheduled day-ahead shall be obligated to purchase Secondary Reserve, Non-Synchronized Reserve, or Synchronized Reserve for the amount of the deviations at the applicable Real-time Prices or price differences, unless otherwise specified by this Schedule.

(d) The following scheduling procedures and principles shall govern the commitment of resources to the Day-ahead Energy Market and the Real-time Energy Market over a period extending from one week to one hour prior to the real-time dispatch. Scheduling encompasses the day-ahead and hourly scheduling process, through which the Office of the Interconnection determines the Day-ahead Energy Market and determines, based on changing forecasts of

conditions and actions by Market Participants and system constraints, a plan to serve the hourly energy and reserve requirements of the Internal Market Buyers and the purchase requests of the External Market Buyers in the least costly manner, subject to maintaining the reliability of the PJM Region. Scheduling does not encompass Coordinated External Transactions, which are subject to the procedures of Tariff, Attachment K-Appendix, section 1.13. Scheduling shall be conducted as specified in section 1.10.1A below, subject to the following condition. If the Office of the Interconnection's forecast for the next seven days projects a likelihood of Emergency conditions, the Office of the Interconnection may commit, for all or part of such seven day period, to the use of generation resources with notification or start-up times greater than one day as necessary in order to alleviate or mitigate such Emergency, in accordance with the Market Sellers' offers for such units for such periods and the specifications in the PJM Manuals. Such resources committed by the Office of the Interconnection to alleviate or mitigate an Emergency will not receive Operating Reserve Credits nor otherwise be made whole for its hours of operation for the duration of any portion of such commitment that exceeds the maximum start-up and notification times for such resources during Hot Weather Alerts and Cold Weather Alerts, consistent with Tariff, Attachment K-Appendix, section 3.2.3 and Tariff, Attachment K-Appendix, section 6.6.

1.10.1A Day-ahead and Real-time Energy Market Scheduling.

The following actions shall occur not later than 11:00 a.m. on the day before the Operating Day for which transactions are being scheduled, or such other deadline as may be specified by the Office of the Interconnection in order to comply with the practical requirements and the economic and efficiency objectives of the scheduling process specified in this Schedule.

(a) Each Market Participant may submit to the Office of the Interconnection specifications of the amount and location of its customer loads and/or energy purchases to be included in the Day-ahead Energy Market for each hour of the next Operating Day, such specifications to comply with the requirements set forth in the PJM Manuals. Each Market Buyer shall inform the Office of the Interconnection of the prices, if any, at which it desires not to include its load in the Day-ahead Energy Market rather than pay the Day-ahead Price. PRD Providers that have committed Price Responsive Demand in accordance with the Reliability Assurance Agreement shall submit to the Office of the Interconnection, in accordance with procedures specified in the PJM Manuals, any desired updates to their previously submitted PRD Curves, provided that such updates are consistent with their Price Responsive Demand commitments, and provided further that PRD Providers that are not Load Serving Entities for the Price Responsive Demand at issue may only submit PRD Curves for the Real-time Energy Market. Price Responsive Demand that has been committed in accordance with the Reliability Assurance Agreement shall be presumed available for the next Operating Day in accordance with the most recently submitted PRD Curve unless the PRD Curve is updated to indicate otherwise. PRD Providers may also submit PRD Curves for any Price Responsive Demand that is not committed in accordance with the Reliability Assurance Agreement; provided that PRD Providers that are not Load Serving Entities for the Price Responsive Demand at issue may only submit PRD Curves for the Real-time Energy Market. All PRD Curves shall be on a PRD Substation basis, and shall specify the maximum time period required to implement load reductions.

(b) Each Generating Market Buyer shall submit to the Office of the Interconnection: (i) hourly schedules for resource increments, including hydropower units, self-scheduled by the Market Buyer to meet its Equivalent Load; and (ii) the Dispatch Rate at which each such self-scheduled resource will disconnect or reduce output, or confirmation of the Market Buyer's intent not to reduce output.

(c) All Market Participants shall submit to the Office of the Interconnection schedules for any energy exports, energy imports, and wheel through transactions involving use of generation or Transmission Facilities as specified below, and shall inform the Office of the Interconnection if the transaction is to be scheduled in the Day-ahead Energy Market. Any Market Participant that elects to schedule an export, import or wheel through transaction in the Day-ahead Energy Market may specify the price (such price not to exceed \$2,000/MWh), if any, at which the export, import or wheel through transaction will be wholly or partially curtailed. The foregoing price specification shall apply to the applicable interface pricing point. Any Market Participant that elects not to schedule its export, import or wheel through transaction in the Day-ahead Energy Market shall inform the Office of the Interconnection if the parties to the transaction are not willing to incur Transmission Congestion and Loss Charges in the Real-time Energy Market in order to complete any such scheduled transaction. Such transactions in the Real-time Energy Market, other than Coordinated Transaction Schedules and emergency energy sales and purchases, may specify a price up to \$2,000/MWh. Scheduling of such transactions shall be conducted in accordance with the specifications in the PJM Manuals and the following requirements:

i) Market Participants shall submit schedules for all energy purchases for delivery within the PJM Region, whether from resources inside or outside the PJM Region;

ii) Market Participants shall submit schedules for exports for delivery outside the PJM Region from resources within the PJM Region that are not Dynamic Transfers to such entities pursuant to Tariff, Attachment K-Appendix, section 1.12; and

iii) In addition to the foregoing schedules for exports, imports and wheel through transactions, Market Participants shall submit confirmations of each scheduled transaction from each other party to the transaction in addition to the party submitting the schedule, or the adjacent Control Area.

(c-1) A Market Participant may elect to submit in the Day-ahead Energy Market a form of Virtual Transaction that combines an offer to sell energy at a source, with a bid to buy the same megawatt quantity of energy at a sink where such transaction specifies the maximum difference between the Locational Marginal Prices at the source and sink. The Office of Interconnection will schedule these transactions only to the extent this difference in Locational Marginal Prices is within the maximum amount specified by the Market Participant. A Virtual Transaction of this type is referred to as an "Up-to Congestion Transaction." Such Up-to Congestion Transactions may be wholly or partially scheduled depending on the price difference between the source and sink locations in the Day-ahead Energy Market. The maximum

difference between the source and sink prices that a participant may specify shall be limited to +/- \$50/MWh. The foregoing price specification shall apply to the price difference between the specified source and sink in the day-ahead scheduling process only. An accepted Up-to Congestion Transaction results in scheduled injection at a specified source and scheduled withdrawal of the same megawatt quantity at a specified sink in the Day-ahead Energy Market.

(c-2) A Market Participant may elect to submit an Increment Offer and/or Decrement Bid form of Virtual Transaction in the Day-ahead Energy Market and shall specify the price for such transaction which shall be limited to \$2,000/megawatt-hour.

(c-3) Up-to Congestion Transactions may only be submitted at hubs, Residual Metered Load and interfaces not described in Tariff, Attachment K-Appendix, section 2.6A(b). Increment Offers and Decrement Bids may be only submitted at hubs, nodes at which physical generation or load is settled, Residual Metered Load and interfaces not described in Tariff, Attachment K-Appendix, section 2.6A(b).

(d) Market Sellers in the Day-ahead Energy Market shall submit offers for the supply of energy, demand reductions, or other services for the following Operating Day for each clock hour for which the Market Seller desires or is required to make its resource available to the Office of the Interconnection. Offers for the supply of energy may be cost-based, market-based, or both, and may vary hourly. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A(d), section 1.10.9B below, Operating Agreement, Schedule 2, and the PJM Manuals, as applicable. Market Sellers owning or controlling the output of a Generation Capacity Resource that is committed as a Capacity Resource under Tariff, Attachment DD or RAA, Schedule 8.1, and that has not been rendered unavailable by a Generator Planned Outage, a Generator Maintenance Outage, or a Generator Forced Outage shall submit offers for the available capacity of such Generation Capacity Resource, including any portion that is self-scheduled by the Generating Market Buyer. Such offers shall be based on the ICAP equivalent of the Market Seller's cleared UCAP capacity commitment, provided, however, where the underlying resource is a Capacity Storage Resource or an Intermittent Resource, the Market Seller shall satisfy the must offer requirement by either self-scheduling or offering the unit as a dispatchable resource, in accordance with the PJM Manuals, where the hourly day-ahead self-scheduled values for such Capacity Storage Resources and Intermittent Resources may vary hour to hour from the capacity commitment. Any offer not designated as a Maximum Emergency offer shall be considered available for scheduling and dispatch under both Emergency and non-Emergency conditions. Offers may only be designated as Maximum Emergency offers to the extent that the Generation Capacity Resource falls into at least one of the following categories:

i) Environmental limits. If the resource has a limit on its run hours imposed by a federal, state, or other governmental agency that will significantly limit its availability, on either a temporary or long-term basis. This includes a resource that is limited to operating only during declared PJM capacity emergencies by a governmental authority.

ii) Fuel limits. If physical events beyond the control of the resource owner result in the temporary interruption of fuel supply and there is limited on-site fuel storage. A fuel supplier's exercise of a contractual right to interrupt supply or delivery under an interruptible service agreement shall not qualify as an event beyond the control of the resource owner.

iii) Temporary emergency conditions at the unit. If temporary emergency physical conditions at the resource significantly limit its availability.

iv) Temporary megawatt additions. If a resource can provide additional megawatts on a temporary basis by oil topping, boiler over-pressure, or similar techniques, and such megawatts are not ordinarily otherwise available.

The submission of offers for resource increments that are not committed as a Capacity Resource under Tariff, Attachment DD or RAA, Schedule 8.1 shall be optional, but any such offers must contain the information specified in the Office of the Interconnection's Offer Data specification, Operating Agreement, Schedule 1, sections 1.10.1A(d) and 1.10.9B, Operating Agreement, Schedule 2, and the PJM Manuals, as applicable. Energy offered from generation resources that are not committed as a Capacity Resource under Tariff, Attachment DD or RAA, Schedule 8.1 shall not be supplied from resources that are included in or otherwise committed to supply the Operating Reserves of a Control Area outside the PJM Region.

The foregoing offers:

i) Shall specify the Generation Capacity Resource or Economic Load Response Participant resource and energy or demand reduction amount, respectively, for each clock hour in the offer period;

ii) Shall specify the amounts and prices for each clock hour during the entire Operating Day for each resource component offered by the Market Seller to the Office of the Interconnection;

iii) May specify for generation resources offer parameters for each clock hour during the entire Operating Day, as applicable and in accordance with section 1.10.9B below, including: (1) Minimum Run Time; (2) maximum run time; (3) Start-up Costs; (4) No-load Costs; (5) Incremental Energy Offer; (6) notification time; (7) availability; (8) ramp rate; (9) Economic Minimum; (10) Economic Maximum; (11) emergency minimum MW; (12) emergency maximum MW; (13) Synchronized Reserve maximum MW; (14) Secondary Reserve maximum MW; and (15) condense to generation time constraints, and may specify offer parameters for Economic Load Response Participant resources for each clock hour during the entire Operating Day, as applicable and in accordance with section 1.10.9B below, including: (1) minimum down time; (2) shutdown costs; (3) Incremental Energy Offer; (4) notification time; (5) Economic Minimum; and (6) Economic Maximum;

iv) Shall set forth any special conditions upon which the Market Seller proposes to supply a resource increment, including any curtailment rate specified in a bilateral contract for the output of the resource, or any cancellation fees;

v) May include a schedule of offers for prices and operating data contingent on acceptance by the deadline specified in this Schedule, with additional schedules applicable if accepted after the foregoing deadline;

vi) Shall constitute an offer to submit the resource increment to the Office of the Interconnection for scheduling and dispatch in accordance with the terms of the offer for the clock hour, which offer shall remain open through the Operating Day, for which the offer is submitted, unless the Market Seller a) submits a Real-time Offer for the applicable clock hour, or b) updates the availability of its offer for that hour, as further described in the PJM Manuals;

vii) Shall be final as to the price or prices at which the Market Seller proposes to supply energy or other services to the PJM Interchange Energy Market, such price or prices being guaranteed by the Market Seller for the period extending through the end of the following Operating Day, unless modified after the close of the Day-ahead Energy Market as permitted pursuant to sections 1.10.9A or 1.10.9B below;

viii) Shall not exceed an energy offer price of \$1,000/megawatt-hour for all generation resources, except (1) when a Market Seller's cost-based offer is above \$1,000/megawatt-hour and less than or equal to \$2,000/megawatt-hour, then its market-based offer must be less than or equal to the cost-based offer; and (2) when a Market Seller's cost-based offer is greater than \$2,000/megawatt-hour, then its market-based offer must be less than or equal to \$2,000/megawatt-hour;

ix) Shall not exceed a demand reduction offer price of \$1,000/megawatt-hour, except when an Economic Load Response Participant submits a cost-based offer that includes an incremental cost component that is above \$1,000/megawatt-hour, then its market-based offer must be less than or equal to the cost-based offer but in no event greater than \$2,000/megawatt-hour;

x) Shall not exceed an offer price as follows for Emergency Load Response and Pre-Emergency Load Response participants with:

a) a 30 minute lead time, pursuant to Tariff, Attachment DD-1, section A.2 and the parallel provision of RAA, Schedule 6, \$1,000/megawatt-hour, plus the applicable Reserve Penalty Factor for the Primary Reserve Requirement, minus \$1.00;

b) an approved 60 minute lead time, pursuant to Tariff, Attachment DD-1, section A.2 and the parallel provision of RAA, Schedule 6, \$1,000/megawatt hour, plus [the applicable Reserve Penalty Factor for the Primary Reserve Requirement divided by 2]; and

c) an approved 120 minute lead time, pursuant to Tariff, Attachment DD-1, section A.2 and the parallel provisions of RAA, Schedule 6, \$1,100/megawatt-hour; and

xi) Shall not exceed an energy offer price of \$0.00/MWh for pumped storage hydropower units scheduled by the Office of the Interconnection pursuant to the hydro optimization tool in the Day-ahead Energy Market.

(e) A Market Seller that wishes to make a resource available to sell Regulation service shall submit an offer for Regulation for each clock hour for which the Market Seller desires to make its resource available to the Office of the Interconnection to provide Regulation that shall specify the megawatts of Regulation being offered, which must equal or exceed 0.1 megawatts, the Regulation Zone for which such Regulation is offered, the price of the capability offer in dollars per MW, the price of the performance offer in Dollars per change in MW, and such other information specified by the Office of the Interconnection as may be necessary to evaluate the offer and the resource's opportunity costs. Such offers may vary hourly, and may be updated each hour, up to 65 minutes before the applicable clock hour during the Operating Day. The total of the performance offer multiplied by the historical average mileage used in the market clearing plus the capability offer shall not exceed \$100/megawatt-hour in the case of Regulation offered for all Regulation Zones. In addition to any market-based offer for Regulation, the Market Seller also shall submit a cost-based offer. A cost-based offer must be in the form specified in the PJM Manuals and consist of the following components as well as any other components specified in the PJM Manuals:

i. The costs (in \$/MW) of the fuel cost increase due to the steady-state heat rate increase resulting from operating the unit at lower megawatt output incurred from the provision of Regulation shall apply to the capability offer;

ii. The cost increase (in $\$/\Delta\text{MW}$) in costs associated with movement of the regulation resource incurred from the provision of Regulation shall apply to the performance offer; and

iii. An adder of up to \$12.00 per megawatt of Regulation provided applied to the capability offer.

Qualified Regulation capability must satisfy the measurement and verification tests specified in the PJM Manuals.

(f) Each Market Seller owning or controlling the output of a Generation Capacity Resource committed to service of PJM loads under the Reliability Pricing Model or Fixed Resource Requirement Alternative shall submit a forecast of the availability of each such Generation Capacity Resource for the next seven days. A Market Seller (i) may submit a non-binding forecast of the price at which it expects to offer a generation resource increment to the Office of the Interconnection over the next seven days, and (ii) shall submit a binding offer for energy, along with Start-up Costs and No-load Costs, if any, for the next seven days or part

thereof, for any generation resource with minimum notification or start-up requirement greater than 24 hours. Such resources committed by the Office of the Interconnection will not receive Operating Reserve Credits nor otherwise be made whole for its hours of operation for the duration of any portion of such commitment that exceeds the maximum start-up and notification times for such resources during Hot Weather Alerts and Cold Weather Alerts, consistent with Tariff, Attachment K-Appendix, section 3.2.3 and Tariff, Attachment K-Appendix, section 6.6.

(g) Each component of an offer by a Market Seller of a Generation Capacity Resource that is constant for the entire Operating Day and does not vary hour to hour shall remain in effect for subsequent Operating Days until superseded or canceled.

(h) The Office of the Interconnection shall post the total hourly loads scheduled in the Day-ahead Energy Market, as well as, its estimate of the combined hourly load of the Market Buyers for the next four days, and peak load forecasts for an additional three days.

(i) Except for Economic Load Response Participants, all Market Participants may submit Virtual Transactions that apply to the Day-ahead Energy Market only. Such Virtual Transactions must comply with the requirements set forth in the PJM Manuals and must specify amount, location and price, if any, at which the Market Participant desires to purchase or sell energy in the Day-ahead Energy Market. The Office of the Interconnection may require that a market participant shall not submit in excess of a defined number of bid/offer segments in the Day-ahead Energy Market, as specified in the PJM Manuals, when the Office of the Interconnection determines that such limit is required to avoid or mitigate significant system performance problems related to bid/offer volume. Notice of the need to impose such limit shall be provided prior to 10:00 a.m. EPT on the day that the Day-ahead Energy Market will clear. For purposes of this provision, a bid/offer segment is each pairing of price and megawatt quantity submitted as part of an Increment Offer or Decrement Bid. For purposes of applying this provision to an Up-to Congestion Transaction, a bid/offer segment shall refer to the pairing of a source and sink designation, as well as price and megawatt quantity, that comprise each Up-to Congestion Transaction.

(j) (i) Offers to Supply Synchronized and Non-Synchronized Reserves By Generation Resources in the Day-ahead and Real-time Reserve Markets

(1) Market Sellers owning or controlling the output of a Generation Capacity Resource that was committed in an FRR Capacity Plan, self-supplied, offered and cleared in a Base Residual Auction or Incremental Auction, or designated as replacement capacity, as specified in Tariff, Attachment DD, is capable of providing Synchronized Reserve or Non-Synchronized Reserve as specified in section 1.7.19A(a), in section 1.7.19A.01(a) and in the PJM Manuals, and has not been rendered unavailable by a Generator Planned Outage, a Generator Maintenance Outage, or a Generator Forced Outage, shall submit offers or otherwise make their 10-minute reserve capability available to supply Synchronized Reserve or, as applicable, Non-Synchronized Reserve, including any portion that is self-scheduled by the Generating Market Buyer, in an amount equal to the available 10-minute reserve capability of such Generation Capacity

Resource. Market Sellers of Generation Capacity Resources subject to this must-offer requirement that do not make the reserve capability of such resources available when such resource is able to operate with a dispatchable range (e.g. through offering a fixed output) will be in violation of this provision.

(2) Market Sellers of all other generation resources that (A) are capable of providing Synchronized Reserve or Non-Synchronized Reserve, as specified in section 1.7.19A(a), in section 1.7.19A.01(a) and in the PJM Manuals, (B) are located within the metered boundaries of the PJM Region, and (C) have submitted offers for the supply of energy into the Day-ahead Energy Market and/or Real-time Energy Market shall be deemed to have made their reserve capability available to provide Synchronized Reserve or Non-Synchronized Reserve in the Day-ahead Energy Market and/or Real-time Energy Market for each clock hour for which the Market Seller submits an available offer to supply energy; provided, however that hydroelectric generation resources and Energy Storage Resources are not automatically deemed available to provide reserves based on the submission of an available energy offer but may submit offers to supply Synchronized Reserve and Non-Synchronized Reserve, as applicable.

(3) Offers for the supply of Synchronized Reserve by all generation resources must be cost-based. Consistent with the resource's offer to supply energy, such offers may vary hourly and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A, section 1.10.9B below, and the PJM Manuals, as applicable. For offers to supply Synchronized Reserve, the offer price shall not exceed the expected value of the penalty for failing to provide Synchronized Reserve, where such expected value shall be recalculated annually, in accordance with the PJM Manuals, and posted on PJM's website. The expected value of the penalty is calculated as the product of: (A) the average penalty, expressed in \$/MWh, multiplied by (B) the average rate of non-performance during Synchronized Reserve events multiplied by (C) the probability a Synchronized Reserve event that will qualify for non-performance assessments will occur.

The expected value of the penalty shall be determined by an annual review of the twelve-month period ending October 31 of the calendar year in which the review is performed. The Office of the Interconnection shall post the results of its annual review by no later than December 15, and the revised offer price cap shall be effective as of the following January 1; provided, however, that at the time of implementation of this rule the expected value of the penalty shall be \$0.02/MWh, and for the period from the second month after implementation through the second December 31 following such date of implementation, the expected value of the penalty shall be recalculated on a monthly basis using data from the

implementation date of this rule through the 15th day of the current month, and the revised value shall be effective the 1st day of the following month.

(4) All Non-Synchronized Reserve offers shall be for \$0.00/MWh. Consistent with the resource's offer to supply energy, such offers may vary hourly and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this subsection (d) of this section 1.10.1A(d), section 1.10.9B below, and the PJM Manuals, as applicable.

(ii) Determination of Available Synchronized Reserve Capability of Generation Resources

(1) For each offer to supply reserves by a synchronized resource, the Office of the Interconnection shall determine the MW of available Synchronized Reserve capability offered in the Day-ahead Energy Market and Real-time Energy Market, in accordance with the PJM Manuals; except, however, that the Office of the Interconnection will not make such determination for hydroelectric generation resources or Energy Storage Resources. Hydroelectric generation resources and Energy Storage Resources may submit offers for their available Synchronized Reserve capability as part of their offer into the Synchronized Reserve market, provided that such offer equals or exceeds 0.1 MW; however, any such resource which is subject to the must offer requirements in section 1.10.1A(j)(i) above must submit a Synchronized Reserve offer which specifies the MW of available Synchronized Reserve capability in order to remain compliant with such requirements.

(2) An on-line generation resource's available Synchronized Reserve capability, except for generation resources capable of synchronous condensing, shall be determined in accordance with the PJM Manuals and based on the resource's current performance and initial energy output and the following offer parameters submitted as part of the resource's energy offer: (A) ramp rate; (B) Economic Minimum; and (C) the lesser of Economic Maximum and Synchronized Reserve maximum MW, where Synchronized Reserve maximum MW may be lower than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Synchronized Reserves above the Synchronized Reserve maximum MW.

For generation resources capable of synchronous condensing, the resource's available Synchronized Reserve capability shall be based on the following offer parameters submitted as part of the resource's energy offer: (D) ramp rate; (E) condense to generation time constraints; (F) Economic Minimum;

and (G) the lesser of Economic Maximum and Synchronized Reserve maximum MW, where Synchronized Reserve maximum MW may be lower than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Synchronized Reserves above the Synchronized Reserve maximum MW.

(3) Any Market Seller that believes its generating unit has operating modes, limits, or conditions where the unit would not be capable of providing Synchronized Reserves in real time, can submit to the Office of the Interconnection with a copy to the Market Monitoring Unit a request for an exception from being assigned Synchronized Reserves in the Real-time Synchronized Reserve Market during time periods in which the generating unit is in those operating modes, limits, or conditions. As part of the request, the Market Seller shall supply, for each generating unit, technical information about the operational modes, limits, or conditions to support the requested exception, as further detailed in the PJM Manuals. The Office of the Interconnection shall consult with the Market Monitoring Unit, and consider any input received from the Market Monitoring Unit, in its determination of a request for such an exception. Within 60 days of the submission of the request, the Office of the Interconnection shall notify the Market Seller in writing, with a copy to the Market Monitoring Unit, whether the request is approved or denied. The effective date of any approved request will be provided in the written notification. If a Market Seller has an approved exception, the Market Seller must communicate to the Office of the Interconnection when the unit cannot provide reserves, and the Office of the Interconnection will provide a mechanism for Market Sellers with an approved exception to provide such communication to the Office of the Interconnection in real time, as further detailed in the PJM Manuals. An approved exception will remain applicable to the unit until such time as the Office of the Interconnection determines that a change is needed or the Market Seller notifies the Office of the Interconnection, with a copy to the Market Monitoring Unit, that a change is needed based on changed operational capabilities of the unit. Market Sellers must notify the Office of the Interconnection, with a copy to the Market Monitoring Unit, within 30 days of any changed operational capabilities that necessitate a change in an approved exception.

(iii) Determination of Available Non-Synchronized Reserve Capability of Generation Resources

(1) For each offer to supply reserves by an off-line generation resource, the Office of the Interconnection shall determine the MW of available Non-Synchronized Reserve capability offered in the Day-ahead Energy Market and Real-time Energy Market in accordance with the PJM Manuals; except, however, that the Office of the Interconnection will not make such determination for hydroelectric generation resources or Energy Storage Resources. Such

hydroelectric generation resources or Energy Storage Resources may submit offers for their available Non-Synchronized Reserve capability as part of their offer into the Non-Synchronized Reserve market, provided that such offer equals or exceeds 0.1 MW; however, any such resource which is subject to the must offer requirements in section 1.10.1A(j)(i) above must submit a Non-Synchronized Reserve offer which specifies the MW of available Non-Synchronized Reserve capability in order to remain compliant with such requirements.

(2) An off-line generation resource's available Non-Synchronized Reserve capability shall be determined in accordance with the PJM Manuals and based on the following offer parameters submitted as part of the resource's energy offer: (A) startup time; (B) notification time; (C) ramp rate; (D) Economic Minimum; and (E) the lesser of Economic Maximum and Synchronized Reserve maximum MW, where Synchronized Reserve maximum MW may be lower than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Non-Synchronized Reserves above its Synchronized Reserve maximum MW.

(iv) Offers to Supply Synchronized Reserves by Economic Load Response Participant Resources in the Day-ahead and Real-time Reserve Markets

(1) Economic Load Response Participants that submit offers to reduce demand into the Day-ahead Energy Market and Real-time Energy Market and wish to make their resources available to supply Synchronized Reserve may submit offers to supply Synchronized Reserve from such resources, where such offers shall specify the megawatts of Synchronized Reserve being offered, which must equal or exceed 0.1 megawatts and such other information specified by the Office of the Interconnection as may be necessary to evaluate the offer. Such offers may vary hourly, and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day.

(2) All offers to supply Synchronized Reserve offers from Economic Load Response Participant resources shall not exceed the expected value of the penalty for failing to provide Synchronized Reserve, as determined in accordance with section 1.10.1A(j)(i)(3) above. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A(d), section 1.10.9B below, and the PJM Manuals, as applicable.

(k) An Economic Load Response Participant that wishes to participate in the Day-ahead Energy Market by reducing demand shall submit an offer to reduce demand to the Office of the Interconnection for each clock hour for which the Economic Load Response Participant desires to make its resource available to the Office of the Interconnection to reduce demand. The

offer must equal or exceed 0.1 megawatts, may vary hourly, and shall specify: (i) the amount of the offered curtailment in minimum increments of .1 megawatts; (ii) the Day-ahead Locational Marginal Price above which the end-use customer will reduce load, subject to section 1.10.1A(d)(ix); and (iii) at the Economic Load Response Participant's option, shutdown costs associated with reducing load, including direct labor and equipment costs, opportunity costs, and/or a minimum of number of contiguous hours for which the load reduction must be committed. Such offers may be updated each hour, up to 65 minutes before the applicable clock hour during the Operating Day. Economic Load Response Participants submitting offers to reduce demand in the Day-ahead Energy Market may establish an incremental offer curve, provided that such offer curve shall be limited to ten price pairs (in MWs) per hour.

(l) Market Sellers owning or controlling the output of an Economic Load Response Participant resource that was committed in an FRR Capacity Plan, or that was self-supplied or that offered and cleared in a Base Residual Auction or Incremental Auction, may submit demand reduction bids for the available load reduction capability of the Economic Load Response Participant resource. The submission of demand reduction bids for Economic Load Response Participant resource increments that were not committed in an FRR Capacity Plan, or that have not cleared in a Base Residual Auction or Incremental Auction, shall be optional, but any such bids must contain the information required to be included in such bids, as specified in the PJM Economic Load Response Program. An Economic Load Response Participant resource that was committed in an FRR Capacity Plan, or that was self-supplied or offered and cleared in a Base Residual Auction or Incremental Auction, may submit a demand reduction bid in the Day-ahead Energy Market as specified in the Economic Load Response Program; provided, however, that in the event of an Emergency PJM shall require Economic Load Response Participant resources to reduce load, notwithstanding that the Zonal LMP at the time such Emergency is declared is below the price identified in the demand reduction bid.

(m) (i) Offers to Supply Secondary Reserve By Generation Resources

(1) Market Sellers owning or controlling the output of a Generation Capacity Resource that was committed in an FRR Capacity Plan, self-supplied, offered and cleared in a Base Residual Auction or Incremental Auction, or designated as replacement capacity, as specified in Tariff, Attachment DD, that is available for energy, is capable of providing Secondary Reserve, as specified in section 1.7.19A.02(a) and in the PJM Manuals, and has not been rendered unavailable by a Generator Planned Outage, a Generator Maintenance Outage, or a Generator Forced Outage shall submit offers to supply Secondary Reserve, or otherwise make their Secondary Reserve capability available. Such offers shall be for an amount equal to the resource's available energy output achievable within thirty minutes (less its energy output achievable within ten minutes) from a request of the Office of the Interconnection. Market Sellers of Generation Capacity Resources subject to this must-offer requirement that do not make the reserve capability of such resources available when such resource is able to operate with a dispatchable range (e.g. through offering a fixed output) will be in violation of this provision.

(2) Market Sellers of all other generation resources located within the metered boundaries of the PJM Region that submit offers for the supply of energy into the Day-ahead Energy Market and/or Real-time Energy Market and are capable of providing Secondary Reserve, as specified in the PJM Manuals, shall be deemed to have made their reserve capability available to provide Secondary Reserve in the Day-ahead Energy Market and/or Real-time Energy Market for each clock hour for which the Market Seller submits an available offer to supply energy; provided, however that hydroelectric generation resources and Energy Storage Resources are not automatically deemed available to provide reserves based on the submission of an available energy offer but may submit offers to supply Secondary Reserve, as applicable.

(3) Offers for the supply of Secondary Reserve shall be for \$0.00/MWh. Consistent with the resource's offer to supply energy, such offers may vary hourly and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this subsection (d) above, section 1.10.9B below, and the PJM Manuals, as applicable.

(ii) Determination of Available Secondary Reserve Capability of Generation Resources

(1) For each offer to supply Secondary Reserve by a generation resource, the Office of the Interconnection shall determine the MW of available Secondary Reserve capability offered in the Day-ahead Energy Market and Real-time Energy Market in accordance with the PJM Manuals; except, however, that the Office of the Interconnection will not make such determination for hydroelectric generation resources or Energy Storage Resources. Hydroelectric generation resources or Energy Storage Resources may submit their available Secondary Reserve capability as part of their offer into the Secondary Reserve market, provided that such offer equals or exceeds 0.1 MW; however, any such resource which is subject to the must offer requirements in section 1.10.1A(m)(i) above must submit a Secondary Reserve offer which specifies the MW of available Secondary Reserve capability in order to remain compliant with such requirements.

(2) (A) An on-line generation resource's available Secondary Reserve capability, except for generation resources capable of synchronous condensing, shall be based on the resource's current performance and initial energy output, the resource's available Synchronized Reserve capability; and the following offer parameters submitted as part of the energy offer: (i) ramp rate; (ii) Economic Minimum; and (iii) the lesser of Economic Maximum and Secondary Reserve maximum MW, where a resource's Secondary Reserve

maximum MW may be less than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Secondary Reserves above its Secondary Reserve maximum MW.

(B) For generation resources capable of synchronous condensing, the resource's available Secondary Reserve capability shall be based on the following offer parameters submitted as part of the energy offer: (i) ramp rate; (ii) condense to generation time constraints; (iii) Economic Minimum; and (iv) the lesser of Economic Maximum and Secondary Reserve maximum MW, where a resource's Secondary Reserve maximum MW may be less than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Secondary Reserves above its Secondary Reserve maximum MW.

(C) An off-line generation resource's available Secondary Reserve capability, shall be based on the resource's available Secondary Reserve capability and the following offer parameters submitted as part of the resource's energy offer: (i) startup time; (ii) notification time; (iii) ramp rate; (iv) Economic Minimum; and (v) the lesser of Economic Maximum and Secondary Reserve maximum MW, where a resource's Secondary Reserve maximum MW may be less than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Secondary Reserves above its Secondary Reserve maximum MW.

(3) Any Market Seller that believes its generating unit has operating modes, limits, or conditions where the unit would not be capable of providing Secondary Reserves in real time, can submit to the Office of the Interconnection with a copy to the Market Monitoring Unit a request for an exception from being assigned Secondary Reserves in the Real-time Secondary Reserve Market during time periods in which the generating unit is in those operating modes, limits, or conditions. As part of the request, the Market Seller shall supply, for each generating unit, technical information about the operational modes, limits, or conditions to support the requested exception, as further detailed in the PJM Manuals. The Office of the Interconnection shall consult with the Market Monitoring Unit, and consider any input received from the Market Monitoring Unit, in its determination of a request for such an exception. Within 60 days of the submission of the request, the Office of the Interconnection shall notify

the Market Seller in writing, with a copy to the Market Monitoring Unit, whether the request is approved or denied. The effective date of any approved request will be provided in the written notification. If a Market Seller has an approved exception, the Market Seller must communicate to the Office of the Interconnection when the unit cannot provide reserves, and the Office of the Interconnection will provide a mechanism for Market Sellers with an approved exception to provide such communication to the Office of the Interconnection in real time, as further detailed in the PJM Manuals. An approved exception will remain applicable to the unit until such time as the Office of the Interconnection determines that a change is needed or the Market Seller notifies the Office of the Interconnection, with a copy to the Market Monitoring Unit, that a change is needed based on changed operational capabilities of the unit. Market Sellers must notify the Office of the Interconnection, with a copy to the Market Monitoring Unit, within 30 days of any changed operational capabilities that necessitate a change in an approved exception.

(iii) Offers to Supply Secondary Reserves by Economic Load Response Participant resources

(1) Each Economic Load Response Participant that submits offers to reduce demand into the Day-ahead Energy Market and Real-time Energy Market and wishes to make their resources available to supply Secondary Reserve shall submit offers to supply Secondary Reserve from such resources, where such offers shall specify the megawatts of Secondary Reserve being offered, which must equal or exceed 0.1 megawatts and include such other information specified by the Office of the Interconnection as may be necessary to evaluate the offer. Such offers may vary hourly, and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day.

(2) All Secondary Reserve offers by Economic Load Response Participant resources shall be for \$0.00/MWh. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A(d), section 1.10.9B below, and the PJM Manuals, as applicable.

(n) A Market Participant may submit a Day-Ahead Pseudo-Tie Transaction for a Market Participant's generator within the PJM balancing authority area that is a Pseudo-Tie into the MISO balancing authority area. Day-Ahead Pseudo-Tie Transactions combine an offer to sell energy at a source with a bid to buy the same megawatt quantity of energy at a sink where such transaction specifies the maximum difference between the Locational Marginal Prices at the source and sink.

Each Day-Ahead Pseudo-Tie Transaction shall: (1) source at a Market Participant's generator within the PJM balancing authority area that Pseudo-Ties into MISO; and (2) sink at the PJM-MISO interface. A Market Participant must reserve transmission service in accordance with the PJM Tariff for each Day-Ahead Pseudo-Tie Transaction. Megawatt quantities for Day-Ahead

Pseudo-Tie Transactions shall be greater than zero and less than or equal to the transmission service reserved for the Day-Ahead Pseudo-Tie Transaction. An accepted Day-Ahead Pseudo-Tie Transaction results in scheduled injection at a specified source and scheduled withdrawal of the same megawatt quantity at a specified sink in the Day-Ahead Energy Market.

1.10.1B Demand Bid Scheduling and Screening

(a) The Office of the Interconnection shall apply Demand Bid Screening to all Demand Bids submitted in the Day-ahead Energy Market for each Load Serving Entity, separately by Zone. Using Demand Bid Screening, the Office of the Interconnection will automatically reject a Load Serving Entity's Demand Bids in any future Operating Day for which the Load Serving Entity submits bids if the total megawatt volume of such bids would exceed the Load Serving Entity's Demand Bid Limit for any hour in such Operating Day, unless the Office of the Interconnection permits an exception pursuant to subsection (d) below.

(b) On a daily basis, PJM will update and post each Load Serving Entity's Demand Bid Limit in each applicable Zone. Such Demand Bid Limit will apply to all Demand Bids submitted by that Load Serving Entity for each future Operating Day for which it submits bids. The Demand Bid Limit is calculated using the following equation:

Demand Bid Limit = greater of (Zonal Peak Demand Reference Point * 1.3), or (Zonal Peak Demand Reference Point + 10MW)

Where:

1. Zonal Peak Demand Reference Point = for each Zone: the product of (a) LSE Recent Load Share, multiplied by (b) Peak Daily Load Forecast.
2. LSE Recent Load Share is the Load Serving Entity's highest share of Network Load in each Zone for any hour over the most recently available seven Operating Days for which PJM has data.
3. Peak Daily Load Forecast is PJM's highest available peak load forecast for each applicable Zone that is calculated on a daily basis.

(c) A Load Serving Entity whose Demand Bids are rejected as a result of Demand Bid Screening may change its Demand Bids to reduce its total megawatt volume to a level that does not exceed its Demand Bid Limit, and may resubmit them subject to the applicable rules related to bid submission outlined in Tariff, Operating Agreement and PJM Manuals.

(d) PJM may allow a Load Serving Entity to submit bids in excess of its Demand Bid Limit when circumstances exist that will cause, or are reasonably expected to cause, a Load Serving Entity's actual load to exceed its Demand Bid Limit on a given Operating Day. Examples of such circumstances include, but are not limited to, changes in load commitments due to state sponsored auctions, mergers and acquisitions between PJM Members, and sales and divestitures between PJM Members. A Load Serving Entity may submit a written exception request to the Office of Interconnection for a higher Demand Bid Limit for an affected Operating Day. Such request must include a detailed explanation of the circumstances at issue and

supporting documentation that justify the Load Serving Entity's expectation that its actual load will exceed its Demand Bid Limit.

1.10.2 Pool-scheduled Resources.

Pool-scheduled resources are those resources for which Market Participants submitted offers to sell energy in the Day-ahead Energy Market and offers to reduce demand in the Day-ahead Energy Market, which the Office of the Interconnection scheduled in the Day-ahead Energy Market as well as generators committed by the Office of the Interconnection subsequent to the Day-ahead Energy Market. Such resources shall be committed to provide energy in the real-time dispatch unless the schedules for such units are revised pursuant to section 1.10.9 below or Tariff, Attachment K-Appendix, section 1.11. Pool-scheduled resources shall be governed by the following principles and procedures.

(a) Pool-scheduled resources shall be selected by the Office of the Interconnection on the basis of the prices offered for energy and demand reductions and related services, whether the resource is expected to be needed to maintain system reliability during the Operating Day, Start-up Costs, No-load Costs and cancellation fees, and the specified operating characteristics, offered by Market Sellers to the Office of the Interconnection by the offer deadline specified in section 1.10.1A above. Hydropower units can only be pool-scheduled if they are pumped storage units and scheduled by the Office of the Interconnection pursuant to the hydro optimization tool in the Day-ahead Energy Market.

(b) A resource that is scheduled by a Market Participant to support a bilateral sale, or that is self-scheduled by a Generating Market Buyer, shall not be selected by the Office of the Interconnection as a pool-scheduled resource except in an Emergency.

(c) Market Sellers offering energy from hydropower or other facilities with fuel or environmental limitations may submit data to the Office of the Interconnection that is sufficient to enable the Office of the Interconnection to determine the available operating hours of such facilities.

(d) The Market Seller of a resource selected as a pool-scheduled resource shall receive payments or credits for energy, demand reductions or related services, or for Start-up Costs and No-load Costs, from the Office of the Interconnection on behalf of the Market Buyers in accordance with Tariff, Attachment K-Appendix, section 3. Alternatively, the Market Seller shall receive, in lieu of Start-up Costs and No-load Costs, its actual costs incurred, if any, up to a cap of the resource's Start-up Costs, if the Office of the Interconnection cancels its selection of the resource as a pool-scheduled resource and so notifies the Market Seller before the resource is synchronized.

(e) Market Participants shall make available their pool-scheduled resources to the Office of the Interconnection for coordinated operation to supply the Operating Reserves needs of the applicable Control Zone.

(f) Economic Load Response Participants offering to reduce demand shall specify: (i) the amount of the offered curtailment, which must equal or exceed 0.1 megawatts, in minimum increments of 0.1 megawatts; (ii) the real-time Locational Marginal Price above which the end-use customer will reduce load; and (iii) at the Economic Load Response Participant's option, shut-down costs associated with reducing load, including direct labor and equipment costs, opportunity costs, and/or a minimum number of contiguous hours for which the load reduction must be committed. Economic Load Response Participants submitting offers to reduce demand in the Day-ahead Energy Market and/or the Real-time Energy Market may establish an incremental offer curve, provided that such offer curve shall be limited to ten price pairs (in MWs). Economic Load Response Participants offering to reduce demand shall also indicate the hours that the demand reduction is not available.

1.10.3 Self-scheduled Resources.

Self-scheduled resources shall be governed by the following principles and procedures.

(a) Each Generating Market Buyer shall use all reasonable efforts, consistent with Good Utility Practice, not to self-schedule resources in excess of its Equivalent Load.

(b) The offered prices of resources that are self-scheduled and not dispatchable by the Office of the Interconnection shall not be considered by the Office of the Interconnection in determining Locational Marginal Prices.

(c) Market Participants shall make available their self-scheduled resources to the Office of the Interconnection for coordinated operation to supply the Operating Reserves needs of the applicable Control Zone, by submitting an offer as to such resources.

(d) A Market Participant self-scheduling a resource in the Day-ahead Energy Market that does not deliver the energy in the Real-time Energy Market, shall replace the energy not delivered with energy from the Real-time Energy Market and shall pay for such energy at the applicable Real-time Price.

(e) A Market Participant self-scheduling a resource to supply Synchronized Reserve in the Day-ahead Synchronized Reserve Market that does not deliver the scheduled megawatt quantity in the applicable real-time reserve market, shall replace the Synchronized Reserve not delivered and shall pay for such Synchronized Reserve at the applicable Real-time Synchronized Reserve Market Clearing Price. Market Participants shall not self-schedule a resource to provide Secondary Reserve or Non-Synchronized Reserve.

(f) For energy, hydropower units, excluding pumped storage units, may only be self-scheduled.

(g) A resource that has been self-scheduled shall not receive payments or credits for Start-up Costs or No-load Costs.

1.10.4 Capacity Resources.

(a) A Generation Capacity Resource committed to service of PJM loads under the Reliability Pricing Model or Fixed Resource Requirement Alternative that is selected as a pool-scheduled resource shall be made available for scheduling and dispatch at the direction of the Office of the Interconnection. Such a Generation Capacity Resource that does not deliver energy as scheduled shall be deemed to have experienced a Generator Forced Outage to the extent of such energy not delivered. A Market Participant offering such Generation Capacity Resource in the Day-ahead Energy Market shall replace the energy not delivered with energy from the Real-time Energy Market and shall pay for such energy at the applicable Real-time Price.

(b) Energy from a Generation Capacity Resource committed to service of PJM loads under the Reliability Pricing Model or Fixed Resource Requirement Alternative that has not been scheduled in the Day-ahead Energy Market may be sold on a bilateral basis by the Market Seller, may be self-scheduled, or may be offered for dispatch during the Operating Day in accordance with the procedures specified in this Schedule. Such a Generation Capacity Resource that has not been scheduled in the Day-ahead Energy Market and that has been sold on a bilateral basis must be made available upon request to the Office of the Interconnection for scheduling and dispatch during the Operating Day if the Office of the Interconnection declares a Maximum Generation Emergency. Any such resource so scheduled and dispatched shall receive the applicable Real-time Price for energy delivered.

1.10.5 External Resources.

(a) External Resources may submit offers to the PJM Interchange Energy Market, in accordance with the day-ahead and real-time scheduling processes specified above. An External Resource selected as a pool-scheduled resource shall be made available for scheduling and dispatch at the direction of the Office of the Interconnection, and except as specified below shall be compensated on the same basis as other pool-scheduled resources. External Resources that are not capable of Dynamic Transfer shall, if selected by the Office of the Interconnection on the basis of the Market Seller's Offer Data, be block loaded on an hourly scheduled basis. Market Sellers shall offer External Resources to the PJM Interchange Energy Market on either a resource-specific or an aggregated resource basis. A Market Participant whose pool-scheduled resource does not deliver the energy scheduled in the Day-ahead Energy Market shall replace such energy not delivered as scheduled in the Day-ahead Energy Market with energy from the PJM Real-time Energy Market and shall pay for such energy at the applicable Real-time Price.

(b) Offers for External Resources from an aggregation of two or more generating units shall so indicate, and shall specify, in accordance with the Offer Data requirements specified by the Office of the Interconnection: (i) energy prices; (ii) hours of energy availability; (iii) a minimum dispatch level; (iv) a maximum dispatch level; and (v) unless such information has previously been made available to the Office of the Interconnection, sufficient information, as specified in the PJM Manuals, to enable the Office of the Interconnection to model the flow into the PJM Region of any energy from the External Resources scheduled in accordance with the Offer Data.

(c) Offers for External Resources on a resource-specific basis shall specify the resource being offered, along with the information specified in the Offer Data as applicable.

1.10.6 External Market Buyers.

(a) Deliveries to an External Market Buyer not subject to Dynamic Transfer by the Office of the Interconnection shall be delivered on a block loaded basis to the bus or buses at the electrical boundaries of the PJM Region, or in such area with respect to an External Market Buyer's load within such area not served by Network Service, at which the energy is delivered to or for the External Market Buyer. External Market Buyers shall be charged (which charge may be positive or negative) at either the Day-ahead Prices or Real-time Prices, whichever is applicable, for energy at the foregoing bus or buses.

(b) An External Market Buyer's hourly schedules for energy purchased from the PJM Interchange Energy Market shall conform to the ramping and other applicable requirements of the interconnection agreement between the PJM Region and the Control Area to which, whether as an intermediate or final point of delivery, the purchased energy will initially be delivered.

(c) The Office of the Interconnection shall curtail deliveries to an External Market Buyer if necessary to maintain appropriate reserve levels for a Control Zone as defined in the PJM Manuals, or to avoid shedding load in such Control Zone.

1.10.7 Bilateral Transactions.

Bilateral transactions as to which the parties have notified the Office of the Interconnection by the deadline specified in section 1.10.1A above that they elect not to be included in the Day-ahead Energy Market and that they are not willing to incur Transmission Congestion Charges in the Real-time Energy Market shall be curtailed by the Office of the Interconnection as necessary to reduce or alleviate transmission congestion. Bilateral transactions that were not included in the Day-ahead Energy Market and that are willing to incur congestion charges and bilateral transactions that were accepted in the Day-ahead Energy Market shall continue to be implemented during periods of congestion, except as may be necessary to respond to Emergencies.

1.10.8 Office of the Interconnection Responsibilities.

(a) The Office of the Interconnection shall use its best efforts to determine (i) the least-cost means of satisfying the projected hourly requirements for energy, Operating Reserves, and other ancillary services of the Market Buyers, including the reliability requirements of the PJM Region, of the Day-ahead Energy Market, and (ii) the least-cost means of satisfying the Operating Reserve and other ancillary service requirements for any portion of the load forecast of the Office of the Interconnection for the Operating Day in excess of that scheduled in the Day-ahead Energy Market. In making these determinations, the Office of the Interconnection shall take into account: (i) the Office of the Interconnection's forecasts of PJM Interchange Energy Market and PJM Region energy requirements, giving due consideration to the energy requirement forecasts and purchase requests submitted by Market Buyers and PRD Curves

properly submitted by PRD Providers; (ii) the offers submitted by Market Sellers; (iii) the availability of limited energy resources; (iv) the capacity, location, and other relevant characteristics of self-scheduled resources; (v) the objectives of each Control Zone for Operating Reserves, as specified in the PJM Manuals; (vi) the requirements of each Regulation Zone for Regulation and other ancillary services, as specified in the PJM Manuals; (vii) the benefits of avoiding or minimizing transmission constraint control operations, as specified in the PJM Manuals; and (viii) such other factors as the Office of the Interconnection reasonably concludes are relevant to the foregoing determination, including, without limitation, transmission constraints on external coordinated flowgates to the extent provided by Tariff, Attachment K-Appendix, section 1.7.6. The Office of the Interconnection shall develop a Day-ahead Energy Market based on the foregoing determination, and shall determine the Day-ahead Prices resulting from such schedule. The Office of the Interconnection shall report the planned schedule for a hydropower resource to the operator of that resource as necessary for plant safety and security, and legal limitations on pond elevations.

(b) By 1:30 p.m., or as soon as practicable thereafter, of the day before each Operating Day, or such other deadline as may be specified by the Office of the Interconnection in the PJM Manuals, the Office of the Interconnection shall: (i) post the aggregate Day-ahead Energy Market results; (ii) post the Day-ahead Prices; and (iii) inform the Market Sellers, Market Buyers, and Economic Load Response Participants of their scheduled injections, withdrawals, and demand reductions respectively. The foregoing notwithstanding, the deadlines set forth in this subsection shall not apply if the Office of the Interconnection is unable to obtain Market Participant bid/offer data due to extraordinary circumstances. For purposes of this subsection, extraordinary circumstances shall mean a technical malfunction that limits, prohibits or otherwise interferes with the ability of the Office of the Interconnection to obtain Market Participant bid/offer data prior to 11:59 p.m. on the day before the affected Operating Day. Extraordinary circumstances do not include a Market Participant's inability to submit bid/offer data to the Office of the Interconnection. If the Office of the Interconnection is unable to clear the Day-ahead Energy Market prior to 11:59 p.m. on the day before the affected Operating Day as a result of such extraordinary circumstances, the Office of the Interconnection shall notify Members as soon as practicable.

(c) Following posting of the information specified in section 1.10.8(b), and absent extraordinary circumstances preventing the clearing of the Day-ahead Energy Market, the Office of the Interconnection shall revise its schedule of generation resources to reflect updated projections of load, conditions affecting electric system operations in the PJM Region, the availability of and constraints on limited energy and other resources, transmission constraints, and other relevant factors.

(d) Market Buyers shall pay PJMSettlement and Market Sellers shall be paid by PJMSettlement for the quantities of energy scheduled in the Day-ahead Energy Market at the Day-ahead Prices when the Day-ahead Price is positive. Market Buyers shall be paid by PJMSettlement and Market Sellers shall pay PJMSettlement for the quantities of energy scheduled in the Day-ahead Energy Market at the Day-ahead Prices when the Day-ahead Price is negative. Economic Load Response Participants shall be paid for scheduled demand reductions pursuant to Tariff, Attachment K-Appendix, section 3.3A. Notwithstanding the foregoing, if the

Office of the Interconnection is unable to clear the Day-ahead Energy Market prior to 11:59 p.m. on the day before the affected Operating Day due to extraordinary circumstances as described in subsection (b) above, it will be declared a Market Suspension, and Day-ahead Prices shall be determined pursuant to Operating Agreement, Schedule 1, section 2.6.1. If the Office of the Interconnection declares a Market Suspension, it shall notify Market Participants of the Market Suspension as soon as practicable.

(e) If the Office of the Interconnection discovers a *potential* error in prices and/or cleared quantities in the Day-ahead Energy Market or Day-ahead Ancillary Services Markets, or the Real-time Energy Market or Real-time Ancillary Services Markets after it has posted the results for these markets on its Web site, the Office of the Interconnection shall notify Market Participants as soon as possible after it is found, but in no event later than 12:00 p.m. of the second Business Day following the Operating Day for the Real-time Energy Market and Real-time Ancillary Services Markets, and no later than 5:00 p.m. of the second Business Day following the initial publication of the results for the Day-ahead Energy Market and Day-ahead Ancillary Services Markets. After this initial notification, if the Office of the Interconnection determines it is necessary to post modified results, it shall provide notification of its intent to do so, *along with a description detailing the cause and scope of the error*, by no later than 5:00 p.m. of the fifth Business Day following the Operating Day for the Real-time Energy Market and Real-time Ancillary Services Markets, and no later than 5:00 p.m. of the fifth Business Day following the initial publication of the results in the Day-ahead Energy Market and Day-ahead Ancillary Services Markets. *The provided description will not contain information that is market sensitive or confidential.* Thereafter, the Office of the Interconnection must post on its Web site the corrected results by no later than 5:00 p.m. of the tenth calendar day following the Operating Day for the Day-ahead Energy Market, Real-time Energy Market, and Day-ahead Ancillary Services Markets, and Real-time Ancillary Service Markets. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced market results are under publicly noticed review by the FERC.

(f) Consistent with Operating Agreement, section 18.17.1, and notwithstanding anything to the contrary in the Operating Agreement or in the PJM Tariff, to allow the tracking of Market Participants' non-aggregated bids and offers over time as required by FERC Order No. 719, the Office of the Interconnection shall post on its Web site the non-aggregated bid data and Offer Data submitted by Market Participants (for participation in the PJM Interchange Energy Market) approximately four months after the bid or offer was submitted to the Office of the Interconnection.

1.10.9 Hourly Scheduling.

(a) Following the initial posting by the Office of the Interconnection of the Locational Marginal Prices resulting from the Day-ahead Energy Market, and subject to the right of the Office of the Interconnection to schedule and dispatch pool-scheduled resources and to direct that schedules be changed in an Emergency, and absent extraordinary circumstances preventing the clearing of the Day-ahead Energy Market, a generation rebidding period shall

exist. Typically the rebidding period shall be from the time the Office of the Interconnection posts the results of the Day-ahead Energy Market until 2:15 p.m. on the day before each Operating Day. However, should the clearing of the Day-ahead Energy Market be significantly delayed, the Office of the Interconnection may establish a revised rebidding period. During the rebidding period, Market Participants may submit revisions to generation Offer Data for the next Operating Day. Adjustments to the Day-ahead Energy Market shall be settled at the applicable Real-time Prices, and shall not affect the obligation to pay or receive payment for the quantities of energy scheduled in the Day-ahead Energy Market at the applicable Day-ahead Prices.

(b) A Market Participant may adjust the schedule of a resource under its dispatch control on an hour-to-hour basis beginning at 6:30 p.m. of the day before each Operating Day, provided that the Office of the Interconnection is notified not later than 65 minutes prior to the hour in which the adjustment is to take effect, as follows and as specified in section 1.10.9A below:

i) A Generating Market Buyer may self-schedule any of its resource increments, including hydropower resources, not previously designated as self-scheduled and not selected as a pool-scheduled resource in the Day-ahead Energy Market;

ii) A Market Participant may request the scheduling of a non-firm bilateral transaction; or

iii) A Market Participant may request the scheduling of deliveries or receipts of Spot Market Energy; or

iv) A Generating Market Buyer may remove from service a resource increment, including a hydropower resource, that it had previously designated as self-scheduled, provided that the Office of the Interconnection shall have the option to schedule energy from any such resource increment that is a Capacity Resource at the price offered in the scheduling process, with no obligation to pay any Start-Up Costs.

(c) An External Market Buyer may refuse delivery of some or all of the energy it requested to purchase in the Day-ahead Energy Market by notifying the Office of the Interconnection of the adjustment in deliveries not later than 65 minutes prior to the hour in which the adjustment is to take effect, but any such adjustment shall not affect the obligation of the External Market Buyer to pay for energy scheduled on its behalf in the Day-ahead Energy Market at the applicable Day-ahead Prices.

(d) The Office of the Interconnection shall provide External Market Buyers and External Market Sellers and parties to bilateral transactions with any revisions to their schedules resulting from the rebidding period by 6:30 p.m. on the day before each Operating Day. The Office of the Interconnection may also commit additional resources after such time as system conditions require. For each hour in the Operating Day, as soon as practicable after the deadlines specified in the foregoing subsection of this section 1.10, the Office of the Interconnection shall provide External Market Buyers and External Market Sellers and parties to bilateral transactions with any revisions to their schedules for the hour.

1.10.9A Updating Offers in Real-time

(a) Each Market Seller may submit Real-time Offers for a resource up to 65 minutes before the applicable clock hour, and such Real-time Offers shall supersede any previous offer for that resource for the clock hour, as further described in the PJM Manuals and subject to the following conditions:

(i) A market-based Real-time Offer shall not exceed the applicable energy offer caps specified in this Schedule. Once a Market Seller's resource is committed for an applicable clock hour, the Market Seller may not increase its Incremental Energy Offer and may only submit a market-based Real-time Offer that is higher than its market-based offer that was in effect at the time of commitment to reflect increases in the resource's cost-based Start-up Costs and cost-based No-load Costs. The Market Seller may elect not to have its market-based offer considered for dispatch and to have only its lowest cost-based offer considered for the remainder of the Operating Day.

(ii) Cost-based Real-time Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection's Offer Data specification, Operating Agreement, Schedule 1, sections 1.10.1A(d) and 1.10.9B, Operating Agreement, Schedule 2 and the PJM Manuals, as applicable. If a Market Seller submits a market-based Real-time Offer for a particular clock hour in accordance with subsection (c) below, or if updates to a cost-based offer are required by the Market Seller's approved Fuel Cost Policy, the Market Seller shall update its previously submitted cost-based Real-time Offer.

(iii) If a Market Seller's available cost-based offer is not compliant with Operating Agreement, Schedule 2 and the PJM Manuals at the time a Market Seller submits a market-based Real-time Offer for an applicable clock hour during the Operating Day, the Market Seller must submit an updated cost-based Real-time Offer consisting of an Incremental Energy Offer, Start-up Cost and No-load Cost for that clock hour that is compliant with Operating Agreement, Schedule 2 and the PJM Manuals.

(b) Each Market Seller may submit Real-time Offers for a resource during and through the end of the applicable clock hour to update only the following offer parameters, as further described in the PJM Manuals: (1) Economic Minimum; (2) Economic Maximum; (3) emergency minimum MW; (4) emergency maximum MW; (5) unit availability status; (6) fixed output indicator; (7) Synchronized Reserve maximum MW; and (8) Secondary Reserve maximum MW. Such Real-time Offers shall supersede any previous offer for that resource for the clock hour.

1.10.9B Offer Parameter Flexibility

(a) Market Sellers may, in accordance with sections 1.10.1A and 1.10.9A above, this section 1.10.9B, and the PJM Manuals, update offer parameters at any time up to 65 minutes before the applicable clock hour, including prior to the close of the Day-ahead Energy Market and prior to the close of the rebidding period specified in section 1.10.9, except that Market

Sellers may not update their offers for the supply of energy, Secondary Reserve, Synchronized Reserve, Non-Synchronized Reserve, or demand reduction: (1) during the period after the close the Day-ahead Energy Market and prior to the posting of the Day-ahead Energy Market results pursuant to section 1.10.8(b); or (2) during the period after close of the rebidding period and prior to PJM announcing the results of the rebidding period pursuant to section 1.10.9(d).

(b) For generation resource offers, Market Sellers may vary for each clock hour during the entire Operating Day the following offer parameters: (1) cost-based Start-up Costs; (2) cost-based No-load Costs; (3) Incremental Energy Offer; (4) Economic Minimum and Economic Maximum; (5) emergency minimum MW and emergency maximum MW; (6) ramp rate; (7) Synchronized Reserve maximum MW; (8) Secondary Reserve maximum MW; and (9) for Real-time Offers only, (i) notification time and (ii) for uncommitted hours only, Minimum Run Time.

(c) For Economic Load Response Participant resource offers, Market Sellers may vary for each clock hour during the entire Operating Day the following offer parameters: (1) shutdown costs, (2) Incremental Energy Offer; (3) Economic Minimum; (4) Economic Maximum; and (5) for Real-time Offers only, (i) notification time and (ii) for uncommitted hours only, minimum down time.

(d) After the announcement of the results of the rebidding period pursuant to section 1.10.9(d), a Market Seller may submit a Real-time Offer where offer parameters may differ from the offer originally submitted in the Day-ahead Energy Market, except that a Market Seller may not submit a Real-time Offer that changes, of the offer parameters listed in section 1.10.1A(d), the MW amounts specified in the Incremental Energy Offer, MW amounts specified in the ramp rate, maximum run time, and availability; provided, however, Market Sellers of dual-fueled resources may submit Real-time Offers for such resources that change the availability of a submitted cost-based offer.

3.2 Market Settlements.

If a dollar-per-MW-hour value is applied in a calculation under this section 3.2 where the interval of the value produced in that calculation is less than an hour, then for purposes of that calculation the dollar-per-MW hour value is divided by the number of Real-time Settlement Intervals in the hour.

3.2.1 Spot Market Energy.

(a) The Office of the Interconnection shall calculate System Energy Prices in the form of Day-ahead System Energy Prices and Real-time System Energy Prices for the PJM Region, in accordance with Tariff, Attachment K-Appendix, section 2.

(b) Each Market Participant shall be charged for all of its Market Participant Energy Withdrawals scheduled in the Day-ahead Energy Market at the Day-ahead System Energy Price to be served in the PJM Interchange Energy Market.

(c) Each Market Participant shall be paid for all of its Market Participant Energy Injections scheduled in the Day-ahead Energy Market at the Day-ahead System Energy Price to be delivered to the PJM Interchange Energy Market.

(d) For each Day-ahead Settlement Interval during an Operating Day, the Office of the Interconnection shall calculate Spot Market Energy charges for each Market Participant as the difference between the sum of its Market Participant Energy Withdrawals scheduled times the Day-ahead System Energy Price and the sum of its Market Participant Energy Injections scheduled times the Day-ahead System Energy Price.

(e) For each Real-time Settlement Interval during an Operating Day, the Office of the Interconnection shall calculate Spot Market Energy charges for each Market Participant as the difference between the sum of its real-time Market Participant Energy Withdrawals less its scheduled Market Participant Energy Withdrawals times the Real-time System Energy Price and the sum of its real-time Market Participant Energy Injections less scheduled Market Participant Energy Injections times the Real-time System Energy Price. The Revenue Data for Settlements determined for each Real-time Settlement Interval in accordance with Tariff, Attachment K-Appendix, section 3.1A shall be used in determining the real-time Market Participant Energy Withdrawals and Market Participant Energy Injections used to calculate Spot Market Energy charges under this subsection (e).

(f) For pool External Resources, the Office of the Interconnection shall model, based on an appropriate flow analysis, the megawatts of real-time energy injections to be delivered from each such resource to the corresponding Interface Pricing Point between adjacent Control Areas and the PJM Region.

3.2.2 Regulation.

(a) Each Market Participant that is a Load Serving Entity in a Regulation Zone shall have an hourly Regulation objective equal to its pro rata share of the Regulation requirements of such Regulation Zone for the hour, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Regulation Zone for the hour ("Regulation Obligation"). A Market Participant with an hourly Regulation Obligation shall be charged the pro rata share of the sum of the Regulation market performance clearing price credits and Regulation market capability clearing price credits for the Real-time Settlement Intervals in an hour.

$\text{Regulation Charge} = \text{Hourly Regulation Obligation Share} * (\text{sum of the Real-time Settlement Interval Regulation credits in an hour})$

(b) Each Market Participant supplying Regulation in a Regulation Zone at the direction of the Office of the Interconnection shall be credited for each of its resources such that the calculated credit for each increment of Regulation provided by each resource shall be the higher of: (i) the Regulation market-clearing price; or (ii) the sum of the applicable Regulation offers for a resource determined pursuant to section 3.2.2A.1 below, the unit-specific shoulder hour opportunity costs described in subsection (e) of this section, the unit-specific inter-temporal opportunity costs, and the unit-specific opportunity costs discussed in subsection (d) of this section.

(c) The total Regulation market-clearing price in each Regulation Zone shall be determined in the Real-time Price software program, which is known as the pricing run, for each Real-time Settlement Interval. The total Regulation market-clearing price shall include: (i) the performance Regulation market-clearing price in a Regulation Zone that shall be calculated in accordance with subsection (g) of this section; (ii) the capability Regulation market-clearing price that shall be calculated in accordance with subsection (h) of this section; and (iii) a Regulation resource's unit-specific opportunity costs during the 5-minute period, determined as described in subsection (d) below, divided by the unit-specific benefits factor described in subsection (j) of this section and divided by the historic accuracy score of the resource from among the resources selected to provide Regulation. A resource's Regulation offer by any Market Seller that fails the three-pivotal supplier test set forth in section 3.2.2A.1 below shall not exceed the cost of providing Regulation from such resource, plus twelve dollars, as determined pursuant to the formula in Tariff, Attachment K-Appendix, section 1.10.1A(e).

(d) In determining the Regulation 5-minute clearing price for each Regulation Zone, the estimated unit-specific opportunity costs of a generation resource offering to sell Regulation in each regulating hour, except for hydroelectric resources, shall be equal to the product of (i) the deviation of the set point of the generation resource that is expected to be required in order to provide Regulation from the generation resource's expected output level if it had been dispatched in economic merit order times, (ii) the absolute value of the difference between the expected Locational Marginal Price at the generation bus for the generation resource and the lesser of the available market-based or highest available cost-based energy offer from the

generation resource (at the megawatt level of the Regulation set point for the resource) in the PJM Interchange Energy Market.

For hydroelectric resources offering to sell Regulation in a regulating hour, the estimated unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the full value of the Locational Marginal Price at that generation bus for each megawatt of Regulation capability.

The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead megawatt commitment greater than zero shall be equal to the product of (i) the deviation of the set point of the hydroelectric resource that is expected to be required in order to provide Regulation from the hydroelectric resource's expected output level if it had been dispatched in economic merit order times (ii) the difference between the expected Locational Marginal Price at the generation bus for the hydroelectric resource and the average of the Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating. Estimated opportunity costs shall be zero for hydroelectric resources for which the average Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period, excluding those Real-time Settlement Intervals during which all available units at the hydroelectric resource were operating is higher than the actual Locational Marginal Price at the generator bus for the Real-time Settlement Interval.

The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead megawatt commitment greater than zero shall be equal to the product of (i) the deviation of the set point of the hydroelectric resource that is expected to be required in order to provide Regulation from the hydroelectric resource's expected output level if it had been dispatched in economic merit order times (ii) the difference between the average of the Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating and the expected Locational Marginal Price at the generation bus for the hydroelectric resource. Estimated opportunity costs shall be zero for hydroelectric resources for which the actual Locational Marginal Price at the generator bus for the Real-time Settlement Interval is higher than the average Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period, excluding those Real-time Settlement Intervals during which all available units at the hydroelectric resource were operating.

For the purpose of committing resources and setting Regulation market clearing prices, the Office of the Interconnection shall utilize day-ahead Locational Marginal Prices to calculate opportunity costs for hydroelectric resources. For the purposes of settlements, the Office of the Interconnection shall utilize the real-time Locational Marginal Prices to calculate opportunity costs for hydroelectric resources.

Estimated opportunity costs for Economic Load Response Participant resources to provide Regulation are zero.

(e) In determining the credit under subsection (b) to a Market Participant selected to provide Regulation in a Regulation Zone and that actively follows the Office of the Interconnection's Regulation signals and instructions, the unit-specific opportunity cost of a generation resource shall be determined for (1) each Real-time Settlement Interval that the Office of the Interconnection requires a generation resource to provide Regulation, and (2) the last three Real-time Settlement Intervals of the preceding shoulder hour and the first three Real-time Settlement Intervals of the following shoulder hour in accordance with the PJM Manuals and below.

The unit-specific opportunity cost incurred during the Real-time Settlement Interval in which the Regulation obligation is fulfilled shall be equal to the product of (i) the deviation of the generation resource's output necessary to follow the Office of the Interconnection's Regulation signals from the generation resource's expected output level if it had been dispatched in economic merit order times (ii) the absolute value of the difference between the Locational Marginal Price at the generation bus for the generation resource and the lesser of the available market-based or highest available cost-based energy offer from the generation resource (at the actual megawatt level of the resource when the actual megawatt level is within the tolerance defined in the PJM Manuals for the Regulation set point, or at the Regulation set point for the resource when it is not within the corresponding tolerance) in the PJM Interchange Energy Market. Opportunity costs for Economic Load Response Participant resources to provide Regulation are zero.

The unit-specific opportunity costs associated with uneconomic operation during each of the preceding three Real-time Settlement Intervals of the shoulder hour shall be equal to the product of (i) the deviation between the set point of the generation resource that is expected to be required in the initial regulating Real-time Settlement Interval in order to provide Regulation and the resource's expected output in each of the preceding three Real-time Settlement Intervals of the shoulder hour times (ii) the absolute value of the difference between the Locational Marginal Price at the generation bus for the generation resource in each of the preceding three Real-time Settlement Intervals of the shoulder hour and the lesser of the available market-based or highest available cost-based energy offer from the generation resource (at the megawatt level of the Regulation set point for the resource in the initial regulating Real-time Settlement Interval) in the PJM Interchange Energy Market, all as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals.

The unit-specific opportunity costs associated with uneconomic operation during each of the following three Real-time Settlement Intervals of the shoulder hour shall be equal to the product of (i) the deviation between the set point of the generation resource that is expected to be required in the final regulating Real-time Settlement Interval in order to provide Regulation and the resource's expected output in each of the following three Real-time Settlement Intervals of the shoulder hour times (ii) the absolute value of the difference between the Locational Marginal Price at the generation bus for the generation resource in each of the following three Real-time Settlement Intervals of the shoulder hour and the lesser of the available market-based or highest available cost-based energy offer from the generation resource (at the megawatt level of the Regulation set point for the resource in final regulating hour) in the PJM Interchange Energy

Market all as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals.

(f) Any amounts credited for Regulation in an hour in excess of the Regulation market-clearing price in that hour shall be allocated and charged to each Market Participant in a Regulation Zone that does not meet its hourly Regulation obligation in proportion to its purchases of Regulation in such Regulation Zone in megawatt-hours during that hour.

(g) To determine the Regulation market performance-clearing price for each Regulation Zone, the Office of the Interconnection shall adjust the submitted performance offer for each resource in accordance with the historical performance of that resource, the amount of Regulation that resource will be dispatched based on the ratio of control signals calculated by the Office of the Interconnection, and the unit-specific benefits factor described in subsection (j) of this section for which that resource is qualified. The maximum adjusted performance offer of all cleared resources will set the Regulation market performance-clearing price.

The owner of each Regulation resource that actively follows the Office of the Interconnection's Regulation signals and instructions, will be credited for Regulation performance by multiplying the assigned MW(s) by the Regulation market performance-clearing price, by the ratio between the requested mileage for the Regulation dispatch signal assigned to the Regulation resource and the Regulation dispatch signal assigned to traditional resources, and by the Regulation resource's accuracy score calculated in accordance with subsection (k) of this section.

(h) The Office of the Interconnection shall divide each Regulation resource's capability offer by the unit-specific benefits factor described in subsection (j) of this section and divided by the historic accuracy score for the resource for the purposes of committing resources and setting the market clearing prices.

The Office of the Interconnection shall calculate the Regulation market capability-clearing price for each Regulation Zone by subtracting the Regulation market performance-clearing price described in subsection (g) from the total Regulation market clearing price described in subsection (c). This residual sets the Regulation market capability-clearing price for that market Real-time Settlement Interval.

The owner of each Regulation resource that actively follows the Office of the Interconnection's Regulation signals and instructions will be credited for Regulation capability based on the assigned MW and the capability Regulation market-clearing price multiplied by the Regulation resource's accuracy score calculated in accordance with subsection (k) of this section.

(i) In accordance with the processes described in the PJM Manuals, the Office of the Interconnection shall: (i) calculate inter-temporal opportunity costs for each applicable resource; (ii) include such inter-temporal opportunity costs in each applicable resource's offer to sell frequency Regulation service; and (iii) account for such inter-temporal opportunity costs in the Regulation market-clearing price.

(j) The Office of the Interconnection shall calculate a unit-specific benefits factor for each of the dynamic Regulation signal and traditional Regulation signal in accordance with the PJM Manuals. Each resource shall be assigned a unit-specific benefits factor based on their order in the merit order stack for the applicable Regulation signal. The unit-specific benefits factor is the point on the benefits factor curve that aligns with the last megawatt, adjusted by historical performance, that resource will add to the dynamic resource stack. Resources following the dynamic Regulation signal which have a unit-specific benefits factor less than 0.1 will not be considered for the purposes of committing resources. The unit-specific benefits factor for the traditional Regulation signal shall be equal to one.

(k) The Office of the Interconnection shall calculate each Regulation resource's accuracy score. The accuracy score shall be the average of a delay score, correlation score, and energy score for each ten second interval. For purposes of setting the interval to be used for the correlation score and delay scores, PJM will use the maximum of the correlation score plus the delay score for each interval.

The Office of the Interconnection shall calculate the correlation score using the following statistical correlation function (r) that measures the delay in response between the Regulation signal and the resource change in output:

$$\text{Correlation Score} = r_{\text{Signal,Response}(\delta, \delta+5 \text{ Min})};$$

$\delta=0 \text{ to } 5 \text{ Min}$

where δ is delay.

The Office of the Interconnection shall calculate the delay score using the following equation:

$$\text{Delay Score} = \text{Abs} ((\delta - 5 \text{ Minutes}) / (5 \text{ Minutes})).$$

The Office of the Interconnection shall calculate an energy score as a function of the difference in the energy provided versus the energy requested by the Regulation signal while scaling for the number of samples. The energy score is the absolute error (ϵ) as a function of the resource's Regulation capacity using the following equations:

$$\text{Energy Score} = 1 - 1/n \sum \text{Abs} (\text{Error});$$

$$\text{Error} = \text{Average of Abs} ((\text{Response} - \text{Regulation Signal}) / (\text{Hourly Average Regulation Signal})); \text{ and}$$

n = the number of samples in the hour and the energy.

The Office of the Interconnection shall calculate an accuracy score for each Regulation resource that is the average of the delay score, correlation score, and energy score for a five-minute period using the following equation where the energy score, the delay score, and the correlation score are each weighted equally:

$$\text{Accuracy Score} = \max ((\text{Delay Score}) + (\text{Correlation Score})) + (\text{Energy Score}).$$

The historic accuracy score will be based on a rolling average of the Real-time Settlement Interval accuracy scores, with consideration of the qualification score, as defined in the PJM Manuals.

(1) During a Market Suspension where the suspension is less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Regulation, the resources providing Regulation at the direction of the Office of the Interconnection will be compensated based on a calculated Regulation market-clearing price. Regulation market-clearing prices for each Real-time Settlement Interval associated with such Market Suspension shall be the average of the Regulation market-clearing prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

During a Market Suspension where the suspension is greater than twenty-four (24) consecutive hours, if the Office of the Interconnection is assigning Regulation, resources providing Regulation at the direction of the Office of the Interconnection will be compensated based on a calculated Regulation clearing price. The Regulation clearing price for each Real-time Settlement Interval will be determined by calculating a Regulation clearing cost for the online resources providing Regulation during the Market Suspension. The resource's Regulation clearing cost is determined by the summation of their Regulation offer and opportunity cost. The opportunity cost will be based on the resource's cost-based offer and will be determined as follows:

For online resources providing Regulation on a cost-based offer at the time of the Market Suspension, that cost-based offer will be used.

For online resources providing Regulation on a price-based offer at the time of the Market Suspension, the Office of the Interconnection shall use the cheapest available cost-based offer based on the dispatch cost formula as defined in Operating Agreement, Schedule 1, section 6.4.1(g) using the available cost-based offers in the Office of the Interconnection system at the time of the Market Suspension.

The highest cost resource, based on this Regulation clearing cost, will set the Regulation market-clearing price for each hour of the Market Suspension.

During a Market Suspension, if the Office of the Interconnection is not assigning Regulation resources, then the Regulation market-clearing price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period and no resource-specific opportunity cost will be calculated.

During a Market Suspension, the following Regulation components for all Real-time Settlement Intervals in the Market Suspension period will be determined as follows:

- (i) If the regulation accuracy score cannot be calculated during a Market Suspension, the 100-hour rolling average accuracy score will be used for the Market Suspension period.
- (ii) If the regulation mileage ratio cannot be calculated during a Market Suspension, the mileage ratio will be set to one (1) for the Market Suspension period.
- (iii) If the unit-specific benefits factor cannot be calculated during a Market Suspension, the unit-specific benefits factor would be based on the historical average unit-specific benefits factor over past hours that shared the same penetration of Regulation D resources that exist for the given Market Suspension hour.

3.2.2A Offer Price Caps.

3.2.2A.1 Applicability.

(a) Each hour, the Office of the Interconnection shall conduct a three-pivotal supplier test as described in this section. Regulation offers from Market Sellers that fail the three-pivotal supplier test shall be capped in the hour in which they failed the test at their cost based offers as determined pursuant to Tariff, Attachment K-Appendix, section 1.10.1A(e). A Regulation supplier fails the three-pivotal supplier test in any hour in which such Regulation supplier and the two largest other Regulation suppliers are jointly pivotal.

(b) For the purposes of conducting the three-pivotal supplier test pursuant to this section, the following applies:

(i) The three-pivotal supplier test will include in the definition of available supply all offers from resources capable of satisfying the Regulation requirement of the PJM Region multiplied by the historic accuracy score of the resource and multiplied by the unit-specific benefits factor for which the capability cost-based offer plus the performance cost-based offer plus any eligible opportunity costs is no greater than 150 percent of the clearing price that would be calculated if all offers were limited to cost (plus eligible opportunity costs).

(ii) The three-pivotal supplier test will apply on a Regulation supplier basis (i.e. not a resource by resource basis) and only the Regulation suppliers that fail the three-pivotal supplier test will have their Regulation offers capped. A Regulation supplier for the purposes of this section includes corporate affiliates. Regulation from resources controlled by a Regulation supplier or its affiliates, whether by contract with unaffiliated third parties or otherwise, will be included as Regulation of that Regulation supplier. Regulation provided by resources owned by a Regulation supplier but controlled by an

unaffiliated third party, whether by contract or otherwise, will be included as Regulation of that third party.

(iii) Each supplier shall be ranked from the largest to the smallest offered megawatt of eligible Regulation supply adjusted by the historic performance of each resource and the unit-specific benefits factor. Suppliers are then tested in order, starting with the three largest suppliers. For each iteration of the test, the two largest suppliers are combined with a third supplier, and the combined supply is subtracted from total effective supply. The resulting net amount of eligible supply is divided by the Regulation requirement for the hour to determine the residual supply index. Where the residual supply index for three pivotal suppliers is less than or equal to 1.0, then the three suppliers are jointly pivotal and the suppliers being tested fail the three pivotal supplier test. Iterations of the test continue until the combination of the two largest suppliers and a third supplier result in a residual supply index greater than 1.0, at which point the remaining suppliers pass the test. Any resource owner that fails the three-pivotal supplier test will be offer-capped.

3.2.3 Operating Reserves.

(a) A Market Seller's pool-scheduled resources capable of providing Operating Reserves shall be credited as specified below based on the applicable offer for the operation of such resource, provided that the resource was available for the entire time specified in the Offer Data for such resource. To the extent that sections 3.2.3A, 3.2.3A.001, and 3.2.3A.01 below do not meet the Synchronized Reserve Requirements, the Primary Reserve Requirements, and the 30-minute Reserve Requirements, the Office of the Interconnection shall schedule additional Operating Reserves pursuant to Section 1.7.17 and 1.10 of Schedule 1 of this Agreement. In addition the Office of the Interconnection shall schedule Operating Reserves pursuant to those sections to satisfy any unforeseen Operating Reserve requirements that are not reflected in the day-ahead market. PJMSettlement shall be the Counterparty to the purchases and sales of Operating Reserve in the PJM Interchange Energy Market.

(b) The following determination shall be made for each pool-scheduled resource that is scheduled in the Day-ahead Energy Market: the total offered price for Start-up Costs and No-load Costs and energy, determined on the basis of the resource's scheduled output, shall be compared to the total value of that resource's energy – as determined by the Day-ahead Energy Market and the Day-ahead Prices applicable to the relevant generation bus in the Day-ahead Energy Market. PJM shall also (i) determine whether any resources were scheduled in the Day-ahead Energy Market to provide Black Start service, Reactive Services or transfer interface control during the Operating Day because they are known or expected to be needed to maintain system reliability in a Zone during the Operating Day in order to minimize the total cost of Operating Reserves associated with the provision of such services and reflect the most accurate possible expectation of real-time operating conditions in the day-ahead model, which resources would not have otherwise been committed in the day-ahead security-constrained dispatch and (ii) report on the day following the Operating Day the megawatt quantities scheduled in the Day-ahead Energy Market for the above-enumerated purposes for the entire RTO.

Except as provided in section 3.2.3(n) below, if the total offered price for Start-up Costs (shutdown costs for Economic Load Response Participant resources) and No-load Costs and energy summed over all Day-ahead Settlement Intervals exceeds the total value summed over all Day-ahead Settlement Intervals, the difference shall be credited to the Market Seller as a day-ahead Operating Reserve credit.

However, for the Day-ahead Settlement Intervals in which the resource is scheduled to provide energy in the Operating Day and the resource actually provides energy in at least one Real-time Settlement Interval in an hour that corresponds to such scheduled Day-ahead Settlement Intervals, a resource's day-ahead Operating Reserve credit shall be reduced by the greater of zero or the difference of the resource's Day-ahead Operating Reserve Target and the Balancing Operating Reserve Target, as determined below.

A resource's Day-ahead Operating Reserve Target shall be determined in accordance with the following equation:

$$(A + B) - C$$

Where:

A = Start-up Costs

B = the sum of day-ahead No-load Costs and energy over the applicable Real-time Settlement Intervals that correspond with Day-ahead Settlement Intervals in which the resource is scheduled. The day-ahead No-load Costs and energy are divided by twelve to determine the cost for each Real-time Settlement Interval.

C = the sum of the day-ahead revenues calculated for each Real-time Settlement Interval that corresponds with a Day-ahead Settlement Interval in which the resource is scheduled, where the day-ahead revenue for each such Real-time Settlement Interval equals the product of the megawatt amount of energy scheduled in the Day-ahead Energy Market and the Day-ahead Price at the applicable pricing point for the resource divided by twelve.

A resource's Balancing Operating Reserve Target shall be determined in accordance with the following equation:

$$D - (E + F)$$

Where:

D = the sum of Start-up Costs and No-load Costs and the incremental cost of energy summed over all Real-time Settlement Intervals that correspond to the Day-ahead Settlement Intervals in which the resource was scheduled;

E = [(the megawatt amount of energy provided in the Real-time Energy Market minus the megawatt amount of energy scheduled in the Day-ahead Energy Market) multiplied by the Real-time Price at the applicable pricing point for the resource] plus the sum of the day-ahead revenues as determined in part C of the above formula for determining the Day-ahead Operating Reserve Target, summed over the applicable Real-time Settlement Intervals; and

F = the sum of all revenues earned for providing Secondary Reserves, Synchronized Reserves, Non-Synchronized Reserves, and Reactive Services over the applicable Real-time Settlement Intervals.

The Office of the Interconnection shall apply any balancing Operating Reserve credits allocated pursuant to this section 3.2.3(b) to real-time deviations or real-time load share plus exports, pursuant to Tariff, Attachment K-Appendix, section 3.2.3(p), depending on whether the balancing Operating Reserve credits are related to resources scheduled during the reliability analysis for an Operating Day, or during the actual Operating Day.

(i) For resources scheduled by the Office of the Interconnection during the reliability analysis for an Operating Day, the associated balancing Operating Reserve credits shall be allocated based on the reason the resource was scheduled according to the following provisions:

(A) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to operate in real-time to augment the physical resources committed in the Day-ahead Energy Market to meet the forecasted real-time load plus the Operating Reserve requirement, the associated balancing Operating Reserve credits, identified as RA Credits for Deviations, shall be allocated to real-time deviations.

(B) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to maintain system reliability, the associated balancing Operating Reserve credits, identified as RA Credits for Reliability, shall be allocated according to ratio share of real time load plus export transactions.

(C) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource with a day-ahead schedule is required to deviate from that schedule to provide balancing Operating Reserves, the associated balancing Operating Reserve credits shall be segmented and separately allocated pursuant to subsections 3.2.3(b)(i)(A) or 3.2.3(b)(i)(B) hereof. Balancing Operating Reserve credits for such resources will be identified in the same manner as units committed during the reliability analysis pursuant to subsections 3.2.3(b)(i)(A) and 3.2.3(b)(i)(B) hereof.

(ii) For resources scheduled during an Operating Day, the associated balancing Operating Reserve credits shall be allocated according to the following provisions:

(A) If the Office of the Interconnection directs a resource to operate during an Operating Day to provide balancing Operating Reserves, the associated balancing Operating Reserve credits, identified as RT Credits for Reliability, shall be allocated according to ratio share of load plus exports. The foregoing notwithstanding, credits will be applied pursuant to this section only if the LMP at the resource's bus does not meet or exceed the applicable offer of the resource for at least four 5-minute intervals during one or more discrete clock hours during each period the resource operated and produced MWs during the relevant Operating Day. If a resource operated and produced MWs for less than four 5-minute intervals during one or more discrete clock hours during the relevant Operating Day, the credits for that resource during the hour it was operated less than four 5-minute intervals will be identified as being in the same category (RT Credits for Reliability or RT Credits for Deviations) as identified for the Operating Reserves for the other discrete clock hours.

(B) If the Office of the Interconnection directs a resource not covered by section 3.2.3(b)(ii)(A) hereof to operate in real-time during an Operating Day, the associated balancing Operating Reserve credits, identified as RT Credits for Deviations, shall be allocated according to real-time deviations from day-ahead schedules.

(iii) PJM shall post on its Web site the aggregate amount of MWs committed that meet the criteria referenced in subsections (b)(i) and (b)(ii) hereof.

(c) The sum of the foregoing credits calculated in accordance with section 3.2.3(b) plus any unallocated charges from section 3.2.3(h) and Tariff, Attachment K-Appendix, section 5.1.7, and any shortfalls paid pursuant to the Market Settlement provision of the Day-ahead Economic Load Response Program, shall be the cost of Operating Reserves in the Day-ahead Energy Market.

(d) The cost of Operating Reserves in the Day-ahead Energy Market shall be allocated and charged to each Market Participant in proportion to the sum of its (i) scheduled load (net of Behind The Meter Generation expected to be operating, but not to be less than zero), accepted Decrement Bids in the Day-ahead Energy Market in megawatt-hours for that Operating Day and accepted Up-to Congestion Transactions in the Day-ahead Energy Market in megawatt-hours for the Operating Day at the sink of the transaction; and (ii) scheduled energy sales in the Day-ahead Energy Market from within the PJM Region to load outside such region in megawatt-hours for that Operating Day, but not including its bilateral transactions that are Dynamic Transfers to load outside such area pursuant to Tariff, Attachment K-Appendix, section 1.12, except to the extent PJM scheduled resources to provide Black Start service, Reactive Services or transfer interface control. The cost of Operating Reserves in the Day-ahead Energy Market for resources scheduled to provide Black Start service for the Operating Day which resources would

not have otherwise been committed in the day-ahead security constrained dispatch shall be allocated by ratio share of the monthly transmission use of each Network Customer or Transmission Customer serving Zone Load or Non-Zone Load, as determined in accordance with the formulas contained in Tariff, Schedule 6A. The cost of Operating Reserves in the Day-ahead Energy Market for resources scheduled to provide Reactive Services or transfer interface control because they are known or expected to be needed to maintain system reliability in a Zone during the Operating Day and would not have otherwise been committed in the day-ahead security constrained dispatch shall be allocated and charged to each Market Participant in proportion to the sum of its real-time deliveries of energy to load (net of operating Behind The Meter Generation) in such Zone, served under Network Transmission Service, in megawatt-hours during that Operating Day, as compared to all such deliveries for all Market Participants in such Zone.

(e) At the end of each Operating Day, the following determination shall be made for each synchronized pool-scheduled resource of each Market Seller that operates as requested by the Office of the Interconnection. For each calendar day, pool-scheduled resources in the Real-time Energy Market shall be made whole for each of the following Segments: 1) the greater of their day-ahead schedules and minimum run time specified at the time of commitment (minimum down time specified at the time of commitment for Economic Load Response Participant resources); and 2) any block of Real-time Settlement Intervals the resource operates at PJM's direction in excess of the greater of its day-ahead schedule and minimum run time specified at the time of commitment (minimum down time specified at the time of commitment for Economic Load Response Participant resources). For each calendar day, and for each synchronized start of a generation resource or PJM-dispatched economic load reduction, there will be a maximum of two Segments for each resource. Segment 1 will be the greater of the day-ahead schedule and minimum run time specified at the time of commitment (minimum down time specified at the time of commitment for Demand Resources) and Segment 2 will include the remainder of the contiguous Real-time Settlement Intervals when the resource is operating at the direction of the Office of the Interconnection, provided that a segment is limited to the Operating Day in which it commenced and cannot include any part of the following Operating Day.

A Generation Capacity Resource that operates outside of its unit-specific parameters will not receive Operating Reserve Credits nor be made whole for such operation when not dispatched by the Office of the Interconnection, unless the Market Seller of the Generation Capacity Resource can justify to the Office of the Interconnection that operation outside of such unit-specific parameters was the result of an actual constraint. Such Market Seller shall provide to the Market Monitoring Unit and the Office of the Interconnection its request to receive Operating Reserve Credits and/or to be made whole for such operation, along with documentation explaining in detail the reasons for operating its resource outside of its unit-specific parameters, within thirty calendar days following the issuance of billing statement for the Operating Day. The Market Seller shall also respond to additional requests for information from the Market Monitoring Unit and the Office of the Interconnection. The Market Monitoring Unit shall evaluate such request for compensation and provide its determination of whether there was an exercise of market power to the Office of the Interconnection by no later than twenty-five calendar days after receiving the Market Seller's request for compensation. The Office of the Interconnection shall make its determination whether the Market Seller justified that it is entitled to receive Operating

Reserve Credits and/or be made whole for such operation of its resource for the day(s) in question, by no later than thirty calendar days after receiving the Market Seller's request for compensation.

Nuclear generation resources shall not be eligible for Operating Reserve payments unless: 1) the Office of the Interconnection directs such resources to reduce output, in which case, such units shall be compensated in accordance with Tariff, Attachment K-Appendix, section 3.2.3(f) and the parallel provision of Operating Agreement, Schedule 1, section 3.2.3(f); or 2) the resource submits a request for a risk premium to the Market Monitoring Unit under the procedures specified in Tariff, Attachment M – Appendix, section II.B. A nuclear generation resource (i) must submit a risk premium consistent with its agreement under such process, or, (ii) if it has not agreed with the Market Monitoring Unit on an appropriate risk premium, may submit its own determination of an appropriate risk premium to the Office of the Interconnection, subject to acceptance by the Office of the Interconnection, with or without prior approval from the Commission.

Credits received pursuant to this section shall be equal to the positive difference between a resource's Total Operating Reserve Offer, and the total value of the resource's energy in the Day-ahead Energy Market plus any credit or change for quantity deviations, at PJM dispatch direction (excluding quantity deviations caused by an increase in the Market Seller's Real-time Offer), from the Day-ahead Energy Market during the Operating Day at the real-time LMP(s) applicable to the relevant generation bus in the Real-time Energy Market. The foregoing notwithstanding, credits for Segment 2 shall exclude start up (shutdown costs for Economic Load Response Participant resources) costs for generation resources.

Except as provided in section 3.2.3(m), if the total offered price exceeds the total value, the difference less any credit as determined pursuant to section 3.2.3(b), and less the absolute value of any negative Synchronized Reserve lost opportunity cost credit, as determined in section 3.2.3A(f)(iv) below, and less the absolute value of any negative Non-Synchronized Reserve lost opportunity cost credit determined in section 3.2.3.A.001(d)(iii) below, and less any amounts credited for providing Reactive Services as specified in section 3.2.3B, and the absolute value of any negative Secondary Reserve lost opportunity cost credit, as determined in section 3.2.3A.01(f)(iv) below, and plus the sum of the Market Revenue Neutrality Offsets for Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve, shall be credited to the Market Seller.

Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve credits applied against Operating Reserve credits pursuant to this section shall be netted against the Operating Reserve credits earned in the corresponding Real-time Settlement Interval(s) in which the Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve credits accrued, provided that for condensing combustion turbines, Synchronized Reserve credits will be netted against the total Operating Reserve credits accrued during each Real-time Settlement Interval the unit operates in condensing and generation mode.

(f) A Market Seller of a unit not defined in subsection (f-1), (f-2), or (f-4) hereof (or self-scheduled, if operating according to Tariff, Attachment K-Appendix, section 1.10.3(c)

hereof), the output of which is reduced or suspended at the request of the Office of the Interconnection due to a transmission constraint or other reliability issue, and for which the real-time LMP at the unit's bus is higher than the unit's offer corresponding to the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override), shall be credited for each Real-time Settlement Interval in an amount equal to the product of (A) the LOC Deviation times (B) the Locational Marginal Price at the generation bus for the generating unit, minus (C) the Total Lost Opportunity Cost Offer, provided that the resulting outcome is greater than \$0.00. This equation is represented as $(A * B) - C$. If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.11.6, where the suspension is greater than twenty-four (24) consecutive hours, resources will not be compensated for lost opportunity costs.

(f-1) With the exception of Market Sellers of Flexible Resources that submit a Real-time Offer greater than their resource's Committed Offer in the Day-ahead Energy Market, a Market Seller of a Flexible Resource shall be compensated for lost opportunity cost, and shall be limited to the lesser of the unit's Economic Maximum or the unit's Generation Resource Maximum Output, if either of the following conditions occur:

- (i) if the unit output is reduced at the direction of the Office of the Interconnection and the real time LMP at the unit's bus is higher than the unit's offer corresponding to the level of output requested by the Office of the Interconnection (as directed by the PJM dispatcher), then the Market Seller shall be credited in a manner consistent with that described in section 3.2.3(f).
- (ii) If the unit is scheduled to produce energy in the Day-ahead Energy Market for a Day-ahead Settlement Interval, but the unit is not called on by the Office of the Interconnection and does not operate in the corresponding Real-time Settlement Interval(s), then the Market Seller shall be credited in an amount equal to the higher of:
 - 1) the product of (A) the amount of megawatts committed in the Day-ahead Energy Market for the generating unit, and (B) the Real-time Price at the generation bus for the generating unit, minus the sum of (C) the Total Lost Opportunity Cost Offer plus No-load Costs, plus (D) the Start-up Cost, divided by the Real-time Settlement Intervals committed for each set of contiguous hours for which the unit was scheduled in Day-ahead Energy Market. This equation is represented as $(A * B) - (C + D)$. The startup cost, (D), shall be excluded from this calculation if the unit operates in real time following the Office of the Interconnection's direction during any portion of the set of contiguous hours for which the unit was scheduled in Day-ahead Energy Market, or

- 2) the Real-time Price at the unit's bus minus the Day-ahead Price at the unit's bus, multiplied by the number of megawatts committed in the Day-ahead Energy Market for the generating unit.

(f-2) A Market Seller of a hydroelectric resource that is pool-scheduled (or self-scheduled, if operating according to Tariff, Attachment K-Appendix, section 1.10.3(c) hereof), the output of which is altered at the request of the Office of the Interconnection from the schedule submitted by the owner, due to a transmission constraint or other reliability issue, shall be compensated for lost opportunity cost in the same manner as provided in sections 3.2.2(d) and 3.2.3A(f) and further detailed in the PJM Manuals.

(f-3) If a Market Seller believes that, due to specific pre-existing binding commitments to which it is a party, and that properly should be recognized for purposes of this section, the above calculations do not accurately compensate the Market Seller for opportunity cost associated with following PJM dispatch instructions and reducing or suspending a unit's output due to a transmission constraint or other reliability issue, then the Office of the Interconnection, the Market Monitoring Unit and the individual Market Seller will discuss a mutually acceptable, modified amount of opportunity cost compensation, taking into account the specific circumstances binding on the Market Seller. Following such discussion, if the Office of the Interconnection accepts a modified amount of opportunity cost compensation, the Office of the Interconnection shall invoice the Market Seller accordingly. If the Market Monitoring Unit disagrees with the modified amount of opportunity cost compensation, as accepted by the Office of the Interconnection, it will exercise its powers to inform the Commission staff of its concerns.

(f-4) A Market Seller of a wind generating unit that is pool-scheduled or self-scheduled, has SCADA capability to transmit and receive instructions from the Office of the Interconnection, has provided data and established processes to follow PJM basepoints pursuant to the requirements for wind generating units as further detailed in this Agreement, the Tariff and the PJM Manuals, and which is operating as requested by the Office of the Interconnection, the output of which is reduced or suspended at the request of the Office of the Interconnection due to a transmission constraint or other reliability issue, and for which the , real-time LMP at the unit's bus is higher than the unit's offer corresponding to the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override), shall be credited for each Real-time Settlement Interval in an amount equal to the product of (A) the LOC Deviation times (B) the Real-time Price at the generation bus for the generating unit, minus (C) the Total Lost Opportunity Cost Offer, provided that the resulting outcome is greater than \$0.00. This equation is represented as $(A*B) - C$.

(f-5) (i) A Market Seller of a pool-scheduled resource or a dispatchable self-scheduled resource shall receive Dispatch Differential Lost Opportunity Cost credits as calculated under subsection (iv) below if the resource is dispatched to provide energy in the Real-time Energy Market, provided such resource is not committed to provide real-time ancillary services (Regulation, reserves, reactive service) or instructed to reduce or suspend output due to

a transmission constraint or other reliability issue pursuant to Tariff, Attachment K-Appendix, section 3.2.3(f-1) through Tariff, Attachment K-Appendix, section (f-4).

(ii) PJM will calculate the revenue above cost for the pricing run for each Real-time Settlement Interval in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = the resource's expected output level based on its resource parameters at the Real-time Price at the applicable pricing point;

B = the Real-time Price at the applicable pricing point; and

C = the sum of the resource's Real-time Energy Market offer integrated under the Final Offer for the resource's expected output level based on its resource parameters at the Real-time Price at the applicable pricing point.

(iii) PJM will calculate the revenue above cost for the dispatch run for each Real-time Settlement Interval in accordance with the following equation:

$$(\text{greater of } A \text{ and } B) - (\text{lesser of } C \text{ and } D)$$

Where:

A = the product of the amount of megawatts of energy dispatched in the Real-time Energy Market dispatch run for the resource in that Real-time Settlement Interval and the Real-time Price at the applicable pricing point;

B = the product of the amount of megawatts of energy the resource actually provided in that Real-time Settlement Interval and the Real-time Price at the applicable pricing point;

C = the resource's Real-time Energy Market offer integrated under the Final Offer for the amount of megawatts dispatched in the Real-time Energy Market dispatch run;

D = the resource's Real-time Energy Market offer integrated under the Final Offer for the amount of megawatts the resource actually provided in that Real-time Settlement Interval.

(iv) The Dispatch Differential Lost Opportunity Cost credit shall equal the greater of (A) the difference between the revenue above cost based on the pricing run determined in subsection (f-5)(ii) and the revenue above cost based on the dispatch run determined in subsection (f-5)(iii) or (B) zero.

(v) For each hour in an Operating Day, the total cost of the Dispatch Differential Lost Opportunity Cost credits shall be allocated and charged to each Market Participant in proportion to the sum of its (i) deliveries of energy to load ((a) net of operating Behind The Meter Generation, but not to be less than zero; and (b) excluding Direct Charging Energy) in the PJM Region, served under Network Transmission Service, in megawatt-hours; and (ii) deliveries of energy sales from within the PJM Region to load outside such region in megawatt-hours but not including its bilateral transactions that are Dynamic Transfers to load outside the PJM Region pursuant to Tariff, Attachment K-Appendix, section 1.12, as compared to the sum of all such deliveries for all Market Participants.

(g) The sum of the foregoing credits in Tariff, Attachment K-Appendix, section 3.2.3(f-1) through Tariff, Attachment K-Appendix, section 3.2.3(f-4), plus any cancellation fees paid in accordance with Tariff, Attachment K-Appendix, section 1.10.2(d), such cancellation fees to be applied to the Operating Day for which the unit was scheduled, plus any shortfalls paid pursuant to the Market Settlement provision of the real-time Economic Load Response Program, less any payments received from another Control Area for Operating Reserves shall be the cost of Operating Reserves for the Real-time Energy Market in each Operating Day.

(h) The cost of Operating Reserves for the Real-time Energy Market for each Operating Day, except those associated with the scheduling of units for Black Start service or testing of Black Start Units as provided in Tariff, Schedule 6A, shall be allocated and charged to each Market Participant based on their daily total of hourly deviations determined in accordance with the following equation:

$$\sum_h (A + B + C)$$

Where:

h = the hours in the applicable Operating Day;

A = For each Real-time Settlement Interval in an hour, the sum of the absolute value of the withdrawal deviations (in MW) between the quantities scheduled in the Day-ahead Energy Market and the Market Participant's energy withdrawals (net of operating Behind The Meter Generation) in the Real-time Energy Market, except as noted in subsection (h)(ii) below and in the PJM Manuals divided by the number of Real-time Settlement Intervals for that hour. The summation of each Real-time Settlement Interval's withdrawal deviation in an hour will be the Market Participant's total hourly withdrawal deviations. Market Participant bilateral transactions that are Dynamic Transfers to load outside the PJM Region pursuant to Tariff, Attachment K-Appendix, section 1.12 are not included in the determination of withdrawal deviations;

B = For each Real-time Settlement Interval in an hour, the sum of the absolute value of generation deviations (in MW and not including deviations in Behind The Meter Generation) as determined in subsection (o) divided by the number of Real-time Settlement Intervals for that hour;

C = For each Real-time Settlement Interval in an hour, the sum of the absolute value of the injection deviations (in MW) between the quantities scheduled in the Day-ahead Energy Market and the Market Participant's energy injections in the Real-time Energy Market divided by the number of Real-time Settlement Intervals for that hour. The summation of the injection deviations for each Real-time Settlement Interval in an hour will be the Market Participant's total hourly injection deviations. The determination of injection deviations does not include generation resources.

The Revenue Data for Settlements determined for each Real-time Settlement Interval in accordance with Tariff, Attachment K-Appendix, section 3.1A shall be used in determining the real-time withdrawal deviations, generation deviations and injection deviations used to calculate Operating Reserve under this subsection (e).

The costs associated with scheduling of units for Black Start service or testing of Black Start Units shall be allocated by ratio share of the monthly transmission use of each Network Customer or Transmission Customer serving Zone Load or Non-Zone Load, as determined in accordance with the formulas contained in Tariff, Schedule 6A.

Notwithstanding section (h)(1) above, as more fully set forth in the PJM Manuals, load deviations from the Day-ahead Energy Market shall not be assessed Operating Reserves charges to the extent attributable to reductions in the load of Price Responsive Demand that is in response to an increase in Locational Marginal Price from the Day-ahead Energy Market to the Real-time Energy Market and that is in accordance with a properly submitted PRD Curve.

Deviations that occur within a single Zone shall be associated with the Eastern or Western Region, as defined in section 3.2.3(q) below, and shall be subject to the regional balancing Operating Reserve rate determined in accordance with Section 3.2.3(q). Deviations at a hub shall be associated with the Eastern or Western Region if all the buses that define the hub are located in the region. Deviations at an Interface Pricing Point shall be associated with whichever region, the Eastern or Western Region, with which the majority of the buses that define that Interface Pricing Point are most closely electrically associated. If deviations at interfaces and hubs are associated with the Eastern or Western region, they shall be subject to the regional balancing Operating Reserve rate. Demand and supply deviations shall be based on total activity in a Zone, including all aggregates and hubs defined by buses that are wholly contained within the same Zone.

The foregoing notwithstanding, netting deviations shall be allowed for each Real-time Settlement Interval in accordance with the following provisions:

(i) Generation resources with multiple units located at a single bus shall be able to offset deviations in accordance with the PJM Manuals to determine the net deviation MW at the relevant bus.

(ii) Demand deviations will be assessed by comparing all day-ahead demand transactions, which include the components referenced in section 3.2.3(d) regarding the cost of Operating Reserves in the Day-ahead Energy Market, at a single transmission

zone, hub, or interface against the real-time demand transactions at that same transmission zone, hub, or interface; except that the positive values of demand deviations, as set forth in the PJM Manuals, will not be assessed Operating Reserve charges in the event of a Primary Reserve or Synchronized Reserve shortage in real-time or where PJM initiates the request for emergency load reductions in real-time in order to avoid a Primary Reserve or Synchronized Reserve shortage.

(iii) Supply deviations will be assessed by comparing all day-ahead transactions at a single transmission zone, hub, or interface against the real-time transactions at that same transmission zone, hub, or interface.

(iv) Bilateral transactions inside the PJM Region, as defined in Operating Agreement, Schedule 1, section 1.7.10, will not be included in the determination of Supply or Demand deviations.

(i) At the end of each Operating Day, Market Sellers shall be credited on the basis of their offered prices for synchronous condensing for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, as well as the credits calculated as specified in Section 3.2.3(b) for those generators committed solely for the purpose of providing synchronous condensing for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, at the request of the Office of the Interconnection.

(j) The sum of the foregoing credits as specified in section 3.2.3(i) shall be the cost of Operating Reserves for synchronous condensing for the PJM Region for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, or in association with post-contingency operation for the Operating Day and shall be separately determined for the PJM Region.

(k) The cost of Operating Reserves for synchronous condensing for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, or in association with post-contingency operation for each Operating Day shall be allocated and charged to each Market Participant in proportion to the sum of its (i) deliveries of energy to load (net of operating Behind The Meter Generation, but not to be less than zero) in the PJM Region, served under Network Transmission Service, in megawatt-hours during that Operating Day; and (ii) deliveries of energy sales from within the PJM Region to load outside such region in megawatt-hours during that Operating Day, but not including its bilateral transactions that are Dynamic Transfers to load outside the PJM Region pursuant to Tariff, Attachment K-Appendix, section 1.12, as compared to the sum of all such deliveries for all Market Participants.

(l) For any Operating Day in either, as applicable, the Day-ahead Energy Market or the Real-time Energy Market for which, for all or any part of such Operating Day, the Office of the Interconnection: (i) declares a Maximum Generation Emergency; (ii) issues an alert that a Maximum Generation Emergency may be declared (“Maximum Generation Emergency Alert”); or (iii) schedules units based on the anticipation of a Maximum Generation Emergency or a Maximum Generation Emergency Alert, the Operating Reserves credit otherwise provided by section 3.2.3.(b) or section 3.2.3(e) in connection with market-based offers shall be limited as

provided in subsections (n) or (m), respectively. The Office of the Interconnection shall provide timely notice on its internet site of the commencement and termination of any of the actions described in subsection (i), (ii), or (iii) of this subsection (l) (collectively referred to as “MaxGen Conditions”). Following the posting of notice of the commencement of a MaxGen Condition, a Market Seller may elect to submit a cost-based offer in accordance with Operating Agreement, Schedule 2, in which case subsections (m) and (n) shall not apply to such offer; provided, however, that such offer must be submitted in accordance with the deadlines in Tariff, Attachment K-Appendix, section 1.10 for the submission of offers in the Day-ahead Energy Market or Real-time Energy Market, as applicable. Submission of a cost-based offer under such conditions shall not be precluded by Tariff, Attachment K-Appendix, section 1.9.7(b); provided, however, that the Market Seller must return to compliance with Tariff, Attachment K-Appendix, section 1.9.7(b) when it submits its bid for the first Operating Day after termination of the MaxGen Condition.

(m) For the Real-time Energy Market, if the Effective Offer Price (as defined below) for a market-based offer is greater than \$1,000/MWh and greater than the Market Seller’s lowest available and applicable cost-based offer, the Market Seller shall not receive any credit for Operating Reserves. For purposes of this subsection (m), the Effective Offer Price shall be the amount that, absent subsections (l) and (m), would have been credited for Operating Reserves for such Operating Day pursuant to section 3.2.3(e) plus the Real-time Energy Market revenues for the Real-time Settlement Intervals that the offer is economic divided by the megawatt hours of energy provided during the Real-time Settlement Intervals that the offer is economic. The Real-time Settlement Intervals that the offer is economic shall be: (i) the Real-time Settlement Intervals that the offer price for energy is less than or equal to the Real-time Price for the relevant generation bus, (ii) the Real-time Settlement Intervals in which the offer for energy is greater than Locational Marginal Price and the unit is operated at the direction of the Office of the Interconnection that are in addition to any Real-time Settlement Intervals required due to the minimum run time or other operating constraint of the unit, and (iii) for any unit with a minimum run time of one hour or less and with more than one start available per day, any hours the unit operated at the direction of the Office of the Interconnection.

(n) For the Day-ahead Energy Market, if notice of a MaxGen Condition is provided prior to 11:00 a.m. on the day before the Operating Day for which transactions are being scheduled and the Effective Offer Price for a market-based offer is greater than \$1,000/MWh and greater than the Market Seller’s lowest available and applicable cost-based offer, the Market Seller shall not receive any credit for Operating Reserves. If notice of a MaxGen Condition is provided after 11:00 a.m. on the day before the Operating Day for which transactions are being scheduled and the Effective Offer Price is greater than \$1,000/MWh, the Market Seller shall receive credit for Operating Reserves determined in accordance with section 3.2.3(b), subject to the limit on total compensation stated below. If the Effective Offer Price is less than or equal to \$1,000/MWh, regardless of when notice of a MaxGen Condition is provided, the Market Seller shall receive credit for Operating Reserves determined in accordance with section 3.2.3(b), subject to the limit on total compensation stated below. For purposes of this subsection (n), the Effective Offer Price shall be the amount that, absent subsections (l) and (n), would have been credited for Operating Reserves for such Operating Day divided by the megawatt hours of energy offered during the Specified Hours, plus the offer for energy during such hours. The

Specified Hours shall be the lesser of: (1) the minimum run hours stated by the Market Seller in its Offer Data; and (2) either (i) for steam-electric generating units and for combined-cycle units when such units are operating in combined-cycle mode, the six consecutive hours of highest Day-ahead Price during such Operating Day when such units are running or (ii) for combustion turbine units and for combined-cycle units when such units are operating in combustion turbine mode, the two consecutive hours of highest Day-ahead Price during such Operating Day when such units are running. Notwithstanding any other provision in this subsection, the total compensation to a Market Seller on any Operating Day that includes a MaxGen Condition shall not exceed \$1,000/MWh during the Specified Hours, where such total compensation in each such hour is defined as the amount that, absent subsections (l) and (n), would have been credited for Operating Reserves for such Operating Day pursuant to section 3.2.3(b) divided by the Specified Hours, plus the Day-ahead Price for such hour, and no Operating Reserves payments shall be made for any other hour of such Operating Day. If a unit operates in real time at the direction of the Office of the Interconnection consistently with its day-ahead clearing, then subsection (m) does not apply.

(o) Dispatchable pool-scheduled generation resources and dispatchable self-scheduled generation resources that follow dispatch shall not be assessed balancing Operating Reserve deviations. Pool-scheduled generation resources and dispatchable self-scheduled generation resources that do not follow dispatch shall be assessed balancing Operating Reserve deviations in accordance with the calculations described below and in the PJM Manuals.

The Office of the Interconnection shall calculate a ramp-limited desired MW value for generation resources where the economic minimum and economic maximum are at least as far apart in real-time as they are in day-ahead according to the following parameters:

(i) real-time economic minimum \leq 105% of day-ahead economic minimum or day-ahead economic minimum plus 5 MW, whichever is greater.

(ii) real-time economic maximum \geq 95% day-ahead economic maximum or day-ahead economic maximum minus 5 MW, whichever is lower.

The ramp-limited desired MW value for a generation resource shall be equal to:

$$Ramp_Request_t = \frac{(Dispatchtarget_{t-1} - AOutput_{t-1})}{(LAtime_{t-1})}$$

$$RL_Desired_t = AOutput_{t-1} + (Ramp_Request_t * Case_Eff_time_{t-1})$$

where:

1. Dispatchtarget = Dispatch Signal for the previous approved Dispatch case
2. AOutput = Unit's achievable target MW at case solution time as defined

in the PJM Manuals

3. $L_{Time} = \text{Dispatch look ahead time}$
4. $Case_Eff_time = \text{Time between signal changes}$
5. $RL_Desired = \text{Ramp-limited desired MW}$

To determine if a generation resource is following dispatch the Office of the Interconnection shall determine the unit's MW off dispatch and % off dispatch by using the lesser of the difference between the actual output and the dispatch signal or the actual output and ramp-limited desired MW value for each Real-time Settlement Interval. If the dispatch signal and the ramp-limited desired MW for the resource are unavailable, the Office of the Interconnection will determine the unit's MW off dispatch and % off dispatch by calculating the lesser of the difference between the actual output and the dispatch LMP Desired MW for each Real-time Settlement Interval.

A pool-scheduled or dispatchable self-scheduled resource is considered to be following dispatch if its actual output is between its ramp-limited desired MW value and dispatch signal, or if its % off dispatch is ≤ 10 , or its Real-time Settlement Interval MWh is within 5% of the Real-time Settlement Interval ramp-limited desired MW. A self-scheduled generator must also be dispatched above economic minimum. The degree of deviations for resources that are not following dispatch shall be determined for each Real-time Settlement Interval in accordance with the following provisions:

- A dispatchable self-scheduled resource that is not dispatched above economic minimum shall be assessed balancing Operating Reserve deviations according to the following formula: Real-time Settlement Interval MWh – Day-Ahead MWh.
- A resource that is dispatchable day-ahead but is Fixed Gen in real-time shall be assessed balancing Operating Reserve deviations according to the following formula: Real-time Settlement Interval MWh – dispatch LMP Desired MW.
- Pool-scheduled generators that are not following dispatch shall be assessed balancing Operating Reserve deviations according to the following formula: Real-time Settlement Interval MWh – Ramp-Limited Desired MW.
- If a resource's real-time economic minimum is greater than its day-ahead economic minimum by 5% or 5 MW, whichever is greater, or its real-time economic maximum is less than its Day Ahead economic maximum by 5% or 5 MW, whichever is lower, and dispatch LMP Desired MWh for the Real-time Settlement Interval is either below the real time economic minimum or above the real time economic maximum, then balancing Operating Reserve deviations for the resource shall be assessed according to the following formula: Real time Settlement Interval MWh – dispatch LMP Desired MWh.
- If a resource is not following dispatch and its % Off Dispatch is $\leq 20\%$, balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh – Ramp-Limited Desired MW. If deviation

value is within 5% of Ramp-Limited Desired MW, balancing Operating Reserve deviations shall not be assessed.

- If a resource is not following dispatch and its % off Dispatch is > 20%, balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh – dispatch LMP Desired MWh.
- If a resource is not following dispatch, and the resource has tripped, for the Real-time Settlement Interval the resource tripped and the Real-time Settlement Intervals it remains offline throughout its day-ahead schedule balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh – Day-Ahead MWh.
- For resources that are not dispatchable in both the Day-Ahead and Real-time Energy Markets balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh - Day-ahead MWh.

If a resource has a sum of the absolute value of generator deviations for an hour that is less than 5 MWh, then the resource shall not be assessed balancing Operating Reserve deviations for that hour.

(o-1) Dispatchable economic load reduction resources that follow dispatch shall not be assessed balancing Operating Reserve deviations. Economic Load Response Participant resources that do not follow dispatch shall be assessed balancing Operating Reserve deviations as described in this subsection and as further specified in the PJM Manuals.

The Desired MW quantity for such resources for each hour shall be the hourly integrated MW quantity to which the load reduction resource was dispatched for each hour (where the hourly integrated value is the average of the dispatched values as determined by the Office of the Interconnection for the resource for each hour).

If the actual reduction quantity for the load reduction resource for a given hour deviates by no more than 20% above or below the Desired MW quantity, then no balancing Operating Reserve deviation will accrue for that hour. If the actual reduction quantity for the load reduction resource for a given hour is outside the 20% bandwidth, the balancing Operating Reserve deviations will accrue for that hour in the amount of the absolute value of (Desired MW – actual reduction quantity). For those hours where the actual reduction quantity is within the 20% bandwidth specified above, the load reduction resource will be eligible to be made whole for the total value of its offer as defined in Tariff, Attachment K-Appendix, section 3.3A. Hours for which the actual reduction quantity is outside the 20% bandwidth will not be eligible for the make-whole payment. If at least one hour is not eligible for make-whole payment based on the 20% criteria, then the resource will also not be made whole for its shutdown cost.

(p) The Office of the Interconnection shall allocate the charges assessed pursuant to Tariff, Attachment K-Appendix, section 3.2.3(h) except those associated with the scheduling of units for Black Start service or testing of Black Start Units as provided in Tariff, Schedule 6A, to

real-time deviations from day-ahead schedules or real-time load share plus exports depending on whether the underlying balancing Operating Reserve credits are related to resources scheduled during the reliability analysis for an Operating Day, or during the actual Operating Day. If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, section 1.11.6, the Office of the Interconnection shall allocate the charges to the ratio share of real-time load plus export transactions.

(i) For resources scheduled by the Office of the Interconnection during the reliability analysis for an Operating Day, the associated balancing Operating Reserve charges shall be allocated based on the reason the resource was scheduled according to the following provisions:

(A) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to operate in real-time to augment the physical resources committed in the Day-ahead Energy Market to meet the forecasted real-time load plus the Operating Reserve requirement, the associated balancing Operating Reserve charges shall be allocated to real-time deviations from day-ahead schedules.

(B) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to maintain system reliability, the associated balancing Operating Reserve charges shall be allocated according to ratio share of real time load plus export transactions.

(C) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource with a day-ahead schedule is required to deviate from that schedule to provide balancing Operating Reserves, the associated balancing Operating Reserve charges shall be allocated pursuant to (A) or (B) above.

(ii) For resources scheduled during an Operating Day, the associated balancing Operating Reserve charges shall be allocated according to the following provisions:

(A) If the Office of the Interconnection directs a resource to operate during an Operating Day to provide balancing Operating Reserves, the associated balancing Operating Reserve charges shall be allocated according to ratio share of load plus exports. The foregoing notwithstanding, charges will be assessed pursuant to this section only if the LMP at the resource's bus does not meet or exceeds the applicable offer of the resource for at least four 5-minute intervals during one or more discrete clock hours during each period the resource operated and produced MWs during the relevant Operating Day. If a resource operated and produced MWs for less than four 5-minute intervals during one or more discrete clock hours during the relevant Operating Day, the charges for that resource during the hour it was operated less than four 5-minute intervals will be

identified as being in the same category as identified for the Operating Reserves for the other discrete clock hours.

(B) If the Office of the Interconnection directs a resource not covered by Tariff, Attachment K-Appendix, section 3.2.3(h)(ii)(A) to operate in real-time during an Operating Day, the associated balancing Operating Reserve charges shall be allocated according to real-time deviations from day-ahead schedules.

(q) The Office of the Interconnection shall determine regional balancing Operating Reserve rates for the Western and Eastern Regions of the PJM Region. For the purposes of this section, the Western Region shall be the AEP, APS, ComEd, Duquesne, Dayton, ATSI, DEOK, EKPC, OVEC transmission Zones, and the Eastern Region shall be the AEC, BGE, Dominion, PENELEC, PEPCO, ME, PPL, JCPL, PECO, DPL, PSEG, RE transmission Zones. The regional balancing Operating Reserve rates shall be determined in accordance with the following provisions:

(i) The Office of the Interconnection shall calculate regional adder rates for the Eastern and Western Regions. Regional adder rates shall be equal to the total balancing Operating Reserve credits paid to generators for transmission constraints that occur on transmission system capacity equal to or less than 345kv. The regional adder rates shall be separated into reliability and deviation charges, which shall be allocated to real-time load or real-time deviations, respectively. Whether the underlying credits are designated as reliability or deviation charges shall be determined in accordance with section 3.2.3(p).

(ii) The Office of the Interconnection shall calculate RTO balancing Operating Reserve rates. RTO balancing Operating Reserve rates shall be equal to balancing Operating Reserve credits except those associated with the scheduling of units for Black Start service or testing of Black Start Units as provided in Tariff, Schedule 6A, in excess of the regional adder rates calculated pursuant to Tariff, Attachment K-Appendix, section 3.2.3(q)(i) of Schedule 1 of this Agreement. The RTO balancing Operating Reserve rates shall be separated into reliability and deviation charges, which shall be allocated to real-time load or real-time deviations, respectively. Whether the underlying credits are allocated as reliability or deviation charges shall be determined in accordance with section 3.2.3(p).

(iii) Reliability and deviation regional balancing Operating Reserve rates shall be determined by summing the relevant RTO balancing Operating Reserve rates and regional adder rates.

(iv) If the Eastern and/or Western Regions do not have regional adder rates, the relevant regional balancing Operating Reserve rate shall be the reliability and/or deviation RTO balancing Operating Reserve rate.

(r) Market Sellers that incur incremental operating costs for a generation resource that are either greater than \$1,000/MWh as determined in accordance with the Market Seller's

PJM-approved Fuel Cost Policy, Operating Agreement, Schedule 2 and PJM Manual 15, but are not verified at the time of dispatch of the resource under section 6.4.3 of this Schedule, or greater than \$2,000/MWh as determined in accordance with the Market Seller's PJM-approved Fuel Cost Policy, Operating Agreement, Schedule 2, and PJM Manual 15, will be eligible to receive credit for Operating Reserves upon review of the Market Monitoring Unit and the Office of the Interconnection, and approval of the Office of the Interconnection. Market Sellers must submit to the Office of the Interconnection and the Market Monitoring Unit all relevant documentation demonstrating the calculation of costs greater than \$2,000/MWh, and costs greater than \$1,000/MWh which were not verified at the time of dispatch of the resource under Tariff, Attachment K-Appendix, section 6.4.3. The Office of the Interconnection must approve any Operating Reserve credits paid to a Market Seller under this subsection (r).

3.2.3A Synchronized Reserve.

(a) Each Market Participant that is a Load Serving Entity that is not part of an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have an obligation for hourly Synchronized Reserve equal to its pro rata share of Synchronized Reserve requirements for the hour for each Reserve Zone and Reserve Sub-zone of the PJM Region, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Reserve Zone or Reserve Sub-zone for the hour ("Synchronized Reserve Obligation"), less any amount obtained from condensers associated with provision of Reactive Services as described in section 3.2.3B(i) and any amount obtained from condensers associated with post-contingency operations, as described in section 3.2.3C(b). Those entities that participate in an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have their reserve obligations determined based on the stipulations in such agreement. A Market Participant's hourly Synchronized Reserve Obligation shall be adjusted by any Synchronized Reserve provided on the Market Participant's behalf through a bilateral agreement. A Market Participant with an hourly Synchronized Reserve Obligation shall be charged the pro rata share of the sum of day-ahead and real-time credits for Synchronized Reserve as defined in sections 3.2.3A(b)(i) and (ii) below.

(b) A resource supplying Synchronized Reserve at the direction of the Office of the Interconnection shall be credited as follows:

i) Credits for Synchronized Reserve provided by generation and Economic Load Response Participant resources assigned to provide Synchronized Reserve by the Office of the Interconnection or self-scheduled in the Day-ahead Synchronized Reserve Market shall be equal to the product of the Day-ahead Synchronized Reserve Market Clearing Price multiplied by the megawatt amount of Synchronized Reserve such resource is assigned to provide..

ii) Credits for Synchronized Reserve provided by generation resources and Economic Load Response Participant resources assigned to provide Synchronized Reserve by the Office of the Interconnection or self-scheduled in the Real-time Synchronized Reserve Market shall be determined for each operating hour based on the sum of their hourly total of Real-time Settlement Interval deviations determined in accordance with the following equation:

$$\sum_i ((A - B) * C)$$

Where:

i = the Real-time Settlement Intervals in the applicable operating hour;

A = For each Real-time Settlement Interval, the megawatts of Synchronized Reserve from that resource assigned by the Office of the Interconnection or self-scheduled in the Real-time Synchronized Reserve Market. The megawatt value is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements of the resource for each Real-time Settlement Interval where there is not a Synchronized Reserve event;

B = For each Real-time Settlement Interval, the megawatts of Synchronized Reserve from that resource assigned by the Office of the Interconnection or self-scheduled in the Day-ahead Synchronized Reserve Market; and

C = For each Real-time Settlement Interval, the Real-time Synchronized Reserve Market Clearing Price.

If a Synchronized Reserve Event is initiated by the Office of the Interconnection and the Economic Load Response Participant resource reduced its load in response to the event, the resource shall be eligible to receive a credit for the fixed costs associated with achieving the load reduction, as specified in the PJM Manuals.

iii) Pool-scheduled resources shall be credited a Synchronized Reserve lost opportunity cost credit, where positive, as described in subsection (f)(iv) below.

(c) [Reserved for future use]

(d) Synchronized Reserve Market Clearing Prices

(i) For the Day-ahead Synchronized Reserve Market, the Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection for each hour of the Operating Day. The Day-ahead Synchronized Reserve Market Clearing Price shall be calculated as the price of serving the next increment of demand for Synchronized Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Synchronized Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Synchronized Reserve established in accordance with Tariff, Attachment K-Appendix, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Synchronized Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute and (B) the price of serving the next increment of demand for Primary Reserve and 30-minute Reserve for each Reserve Zone or Reserve

Sub-zone to which the next increment of demand for Synchronized Reserve can contribute, provided that the Synchronized Reserve Market Clearing Price shall be less than or equal to the sum of no more than two of the Reserve Penalty Factors for the Synchronized Reserve Requirement, the Primary Reserve Requirement, and the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.10.8(d), Day-ahead Synchronized Reserve Market Clearing Prices shall be set to zero dollars per megawatt-hour and for purposes of settlements for such Operating Day, the Office of the Interconnection shall utilize a scheduled megawatt quantity and Day-ahead Synchronized Reserve Market Clearing Price of zero dollars per megawatt-hour and all settlements will be based on the Real-time Synchronized Reserve market quantities and prices as determined pursuant to subsection (d)(ii) hereof.

(ii) For the Real-time Synchronized Reserve Market, the Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection in the Real-time Price software program, which is known as the pricing run, for each Real-time Settlement Interval of the Operating Day. Each 5-minute clearing price shall be calculated as the price of serving the next increment of demand for Synchronized Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Synchronized Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Synchronized Reserve established in accordance with Tariff, Attachment K-Appendix, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Synchronized Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute and (B) the price of serving the next increment of demand for Primary Reserve and 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute, provided that the Synchronized Reserve Market Clearing Price shall be less than or equal to the sum of no more than two of the Reserve Penalty Factors for the Synchronized Reserve Requirement, the Primary Reserve Requirement, and the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, and the Office of the Interconnection is not assigning Synchronized Reserves, then the Synchronized Reserve Market Clearing Price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, where the real-time Market Suspension is less than or equal to six (6) consecutive hours, which may span up to two Operating Days, and the

Office of the Interconnection is assigning Synchronized Reserves, then the Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than six (6) consecutive hours but less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are cleared Day-ahead Synchronized Reserve Market Clearing Prices for the affected Operating Day, then the Real-time Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the Day-ahead Synchronized Reserve Market Clearing Prices for each corresponding hour. If no such Day-ahead Synchronized Reserve Market Clearing Prices exist, then the Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than twenty-four (24) consecutive hours, and the Office of the Interconnection is assigning Synchronized Reserves, the Office of the Interconnection will set the Synchronized Reserve Market Clearing Price to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period. Resources will be compensated for lost opportunity cost per subsection (f) hereof using the energy price as determined in Operating Agreement, Schedule 1, section 2.5.2.iii. The opportunity cost shall be zero for all resources self-scheduled to provide Synchronized Reserve, synchronous condensers and Economic Load Response Participant resources.

If the Office of the Interconnection has initiated in a Reserve Zone or Reserve Sub-zone either a Voltage Reduction Action as described in the PJM Manuals or a Manual Load Dump Action as described in the PJM Manuals, the Real-time Synchronized Reserve Market Clearing Price shall be the sum of the Reserve Penalty Factors for the Primary Reserve Requirement, and the Synchronized Reserve Requirement for that Reserve Zone or Reserve Sub-zone.

(iii) The Reserve Penalty Factor for the Synchronized Reserve Requirement shall be \$850/MWh.

The Reserve Penalty Factor for the Extended Synchronized Reserve Requirement shall be \$300/MWh.

(iv) By no later than April 30 of each year, the Office of the Interconnection will analyze Market Participants' response to prices exceeding \$1,000/MWh on an annual basis and will provide its analysis to PJM stakeholders. The Office of the Interconnection will also review this analysis to determine whether any changes to the Synchronized Reserve Penalty Factors are warranted for subsequent Delivery Year(s).

(e) (i) For determining the Synchronized Reserve Market Clearing Price in each hour of the Day-ahead Synchronized Reserve Market, the estimated resource-specific opportunity cost for a generation resource or Economic Load Response Participant resource shall be the difference between the Locational Marginal Price at the generation or Economic Load Response Participant resource bus and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) or offer price to reduce energy from the Economic Load Response Participant resource in the PJM Interchange Energy Market when the Locational Marginal Price at the generation or Economic Load Participant resource bus is greater than the offer price for energy from the generation resource or the offer price to reduce energy from the Economic Load Response Participant resource.

However, the opportunity costs shall be zero for resources self-scheduled to provide Synchronized Reserve and for synchronous condensers and for Economic Load Response Participant resources that do not receive a day-ahead commitment to provide energy in the same operating hour in which such resource is committed to provide Synchronized Reserve.

(ii) For determining the Synchronized Reserve Market Clearing Price for each Real-time Settlement Interval in the Real-time Synchronized Reserve Market, the estimated unit-specific opportunity cost for a generation resource that is not a hydroelectric resource shall be the difference between the Locational Marginal Price at the generation bus for the generation resource and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) in the PJM Interchange Energy Market when the Locational Marginal Price at the generation bus is greater than the offer price for energy from the generation resource.

For hydroelectric resources, the estimated unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the expected real-time Locational Marginal Price at that generation bus. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions, as defined in the PJM Manuals, and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the expected real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average day-ahead Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

The opportunity costs shall be zero for all resources self-scheduled to provide Synchronized Reserve, synchronous condensers and Economic Load Response Participant resources.

(f) (i) In determining the credit under subsection (b) to a generation resource, except a generation resource that is operating as a synchronous condenser, selected to provide Synchronized Reserve in the Day-ahead Synchronized Reserve Market, or an Economic Load Response Participant resource that is selected to provide Synchronized Reserve in the Day-ahead Synchronized Reserve Market for the same operating hour in which such resource receives a day-ahead commitment to provide energy, the opportunity cost of a resource shall be determined for each operating hour that the Office of the Interconnection requires a resource to provide Synchronized Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Day-ahead Locational Marginal Price at the generation bus of the generation resource or the applicable pricing point for the Economic Load Response Participant resource;

B = The deviation of the resource's energy output or load reduction necessary to supply a Day-ahead Synchronized Reserve assignment from the resource's energy expected output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load; and

C = The Day-ahead Energy market offer integrated under the applicable energy offer curve for the resource's energy output or load reduction necessary to provide a Day-ahead Synchronized Reserve Market assignment from the resource's expected energy output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load.

For a generation resource that is operating as a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: [energy use for providing synchronous condensing multiplied by A] plus [the applicable condense start-up cost divided by the number of hours the resource is assigned Synchronized Reserve].

(ii) In determining the credit under subsection (b) to a generation resource, except a generation resource that is operating as a synchronous condenser, selected to provide Synchronized Reserve in the Real-time Synchronized Reserve Market in excess of the resource's Day-ahead Synchronized Reserve Market assignment and that actively follows the Office of the Interconnection's signals and instructions, the unit-specific opportunity cost of that generation resource shall be determined for each Real-time Settlement Interval that the Office of the Interconnection requires that generation resource to provide Synchronized Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Real-time Locational Marginal Price at the generation bus of the generation resource;

B = The deviation of the generation resource's output necessary to supply Synchronized Reserve in real-time, reduced by the amount of Synchronized Reserve the resource failed to respond during a Synchronized Reserve Event during the Operating Day, in excess of its Day-ahead Synchronized Reserve Market assignment and follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy; and

C = The energy offer integrated under the applicable energy offer curve for the generation resource's output necessary to supply Synchronized Reserve in real-time from the lesser of the generation resource's output necessary to provide a Day-ahead Synchronized Reserve Market assignment or follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy.

For a generation resource that is a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: [additional energy use in excess of day-ahead energy use for providing synchronous condensing in real-time multiplied by A] plus [any applicable condense start-up costs due to additional condense start-ups in real-time in excess of day-ahead condense start-ups allocated to each Real-time Settlement Interval as described in PJM Manuals].

For hydroelectric resources, the unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the real-time Locational Marginal Price at that generation bus multiplied by the additional megawatts assigned to supply Synchronized Reserve in real-time in excess of its Day-ahead Synchronized Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average real-time Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating multiplied by the additional megawatts assigned to supply the hourly Synchronized Reserve in real-time in excess of its Day-ahead Synchronized Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

(iii) For each Real-time Settlement Interval, a Market Revenue Neutrality Offset is calculated for each resource, if eligible. If there is a decrease in the resource's real-time reserve MW from a day-ahead market assignment in more than one market for that Real-time Settlement Interval, the total Market Revenue Neutrality Offset is allocated to the Synchronized Reserve market based on the ratio of the opportunity cost owed due to a reduction in assignment in real-time within the Synchronized Reserve market and the total opportunity cost owed due to a reduction in assignment in real-time from all reserve markets, not to exceed the resource's opportunity cost owed in the Synchronized Reserve market.

A resource is not eligible for Market Revenue Neutrality Offset for Synchronized Reserve in a Real-time Settlement Interval for any of the following conditions:

(A) A resource's real-time Synchronized Reserve assignment decreases due to the resource being self-scheduled to provide energy or Regulation;

(B) A resource reduces its flexibility in real-time such that the resource no longer qualifies to provide Synchronized Reserve in real-time;

(C) A resource's Final Offer is less than its Committed Offer;

(D) A resource trips offline or otherwise becomes unavailable in real-time;

(E) A resource does not follow dispatch as described in section 3.2.3(o) above and section 3.2.3(o-1) above; or

(F) A resource increases its Synchronized Reserve offer price in the Real-time Synchronized Reserve Market from its offer price in the Day-ahead Synchronized Reserve Market.

(iv) A Synchronized Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:

$$(A + B + C + D) - (E + F + G + H)$$

Where:

A = day-ahead Synchronized Reserve offer price times the Synchronized Reserve MW assignment;

B = real-time Synchronized Reserve offer price times the Synchronized Reserve MW assigned in real-time in excess of the Synchronized Reserve MW assigned day-ahead, where the Synchronized Reserve MW assigned is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus

the Revenue Data for Settlements of the resource for each Real-time Settlement Interval where there is not a Synchronized Reserve event;

C = day-ahead opportunity cost as determined in subsection (f)(i) above;

D = real-time opportunity cost as determined in subsection (f)(ii) above;

E = day-ahead clearing price credits as determined in subsection (b)(i) above;

F = real-time clearing price credits as determined in subsection (b)(ii) above less any applicable charges for failure to respond to a Synchronized Reserve Event as determined in subsection (j) below;

G = the applicable Market Revenue Neutrality Offset as determined in subsection (f)(iii) above; and

H = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A(f)(iii) above if not eligible for Market Revenue Neutrality Offset.

(v) The opportunity costs for an Economic Load Response Participant resource assigned Synchronized Reserve in real-time or any resource self-scheduled for Synchronized Reserves shall be zero.

(g) [Reserved for future use]

(h) For each operating hour, the sum of the Synchronized Reserve lost opportunity cost credits credited in accordance with subsection (b)(iii) above shall be allocated and charged to each Market Participant that does not meet its hourly Synchronized Reserve Obligation in proportion to its real-time purchases of Synchronized Reserve in megawatt-hours during that hour.

(i) [Reserved for future use]

(j) In the event a generation resource or Economic Load Response Participant Resource that either has been assigned by the Office of the Interconnection or self-scheduled to provide Synchronized Reserve in real-time fails to provide the assigned or self-scheduled amount of Synchronized Reserve in response to a Synchronized Reserve Event, the resource will be charged at the Real-time Synchronized Reserve Market Clearing Price for the real-time Synchronized Reserve assignment, in excess of amount that actually responded for all Real-time Settlement Intervals the resource was assigned or self-scheduled Synchronized Reserve real-time, which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements for the resource on the Operating Day during which the event occurred. The determination of the amount of Synchronized Reserve credited to a resource shall be on an individual resource basis, not on an aggregate basis.

The resource shall refund payments received for Synchronized Reserve it failed to provide. For purposes of determining the amount of the payments to be refunded by a Market Participant, the Office of the Interconnection shall calculate the shortfall of Synchronized Reserve on an individual resource basis unless the Market Participant had multiple resources that were assigned or self-scheduled to provide Synchronized Reserve, in which case the shortfall will be determined on an aggregate basis. For performance determined on an aggregate basis, the response of any resource that provided more Synchronized Reserve than it was assigned or self-scheduled to provide will be used to offset the performance of other resources that provided less Synchronized Reserve than they were assigned or self-scheduled to provide during a Synchronized Reserve Event, as calculated in the PJM Manuals. The determination of a Market Participant's aggregate response shall not be taken into consideration in the determination of the amount of Synchronized Reserve credited to each individual resource.

The amount refunded shall be determined by multiplying the retroactive penalty megawatts by the Real-time Synchronized Reserve Market Clearing Price for all intervals the resource was assigned or self-scheduled to provide Synchronized Reserve for a period of time immediately preceding the Synchronized Reserve Event equal to the lesser of the average number of days between Synchronized Reserve Events, or the number of days since the resource last failed to provide the amount of Synchronized Reserve it was assigned or self-scheduled to provide in response to a Synchronized Reserve Event. The retroactive penalty megawatts for each interval shall be the lesser of the amount of the shortfall of Synchronized Reserve, measured in megawatts, and the real-time Synchronized Reserve assignment for each interval, which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements for the resource. The average number of days between Synchronized Reserve Events for purposes of this calculation shall be determined by an annual review of the twenty-four month period ending October 31 of the calendar year in which the review is performed, and shall be rounded down to a whole day value. The Office of the Interconnection shall report the results of its annual review to stakeholders by no later than December 31, and the average number of days between Synchronized Reserve Events shall be effective as of the following January 1. The refunded charges shall be allocated as credits to Market Participants based on its pro rata share of the Synchronized Reserve Obligation megawatts in the hour(s) of the Synchronized Reserve Event for the Reserve Sub-zone or Reserve Zone, except that Market Participants that incur a refund obligation and also have an applicable Synchronized Reserve Obligation during the hour(s) of the Synchronized Reserve Event shall not be included in the allocation of such refund credits. If the event spans multiple hours, the refund credits will be prorated hourly based on the duration of the event within each clock hour.

(k) The magnitude of response to a Synchronized Reserve Event by a generation resource or an Economic Load Response Participant resource, except for Batch Load Economic Load Response Participant resources covered by section 3.2.3A(1), is the difference between the generation resource's output or the Economic Load Response Participant resource's consumption at the start of the event and its output or consumption 10 minutes after the start of the event. In order to allow for small fluctuations and possible telemetry delays, generation resource output or Economic Load Response Participant resource consumption at the start of the event is defined as the lowest telemetered generator resource output or greatest Economic Load Response

Participant resource consumption between one minute prior to and one minute following the start of the event. Similarly, a generation resource's output or an Economic Load Response Participant resource's consumption 10 minutes after the event is defined as the greatest generator resource output or lowest Economic Load Response Participant resource consumption achieved between 9 and 11 minutes after the start of the event. The response actually credited to a generation resource will be reduced by the amount the megawatt output of the generation resource falls below the level achieved after 10 minutes by either the end of the event or after 30 minutes from the start of the event, whichever is shorter. The response actually credited to an Economic Load Response Participant resource will be reduced by the amount the megawatt consumption of the Economic Load Response Participant resource exceeds the level achieved after 10 minutes by either the end of the event or after 30 minutes from the start of the event, whichever is shorter.

(1) The magnitude of response by a Batch Load Economic Load Response Participant resource that is at the stage in its production cycle when its energy consumption is less than the level of megawatts in its offer at the start of a Synchronized Reserve Event shall be the difference between (i) the Batch Load Economic Load Response Participant resource's consumption at the end of the Synchronized Reserve Event and (ii) the Batch Load Economic Load Response Participant resource's consumption during the minute within the ten minutes after the end of the Synchronized Reserve Event in which the Batch Load Economic Load Response Participant resource's consumption was highest and for which its consumption in all subsequent minutes within the ten minutes was not less than fifty percent of the consumption in such minute; provided that, the magnitude of the response shall be zero if, when the Synchronized Reserve Event commences, the scheduled off-cycle stage of the production cycle is greater than ten minutes. .

3.2.3A.001 Non-Synchronized Reserve.

(a) Each Market Participant that is a Load Serving Entity that is not part of an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have an obligation for hourly Non-Synchronized Reserve equal to its pro rata share of Non-Synchronized Reserve assigned for the hour for each Reserve Zone and Reserve Sub-zone of the PJM Region, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Reserve Zone and Reserve Sub-zone for the hour ("Non-Synchronized Reserve Obligation"). Those entities that participate in an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have their reserve obligations determined based on the stipulations in such agreement. A Market Participant's hourly Non-Synchronized Reserve Obligation shall be adjusted by any Non-Synchronized Reserve provided on the Market Participant's behalf through a bilateral agreement. A Market Participant with an hourly Non-Synchronized Reserve Obligation shall be charged the pro rata share of the sum day-ahead and real-time credits for Non-Synchronized Reserve as defined in sections 3.2.3A.001(b)(i) and (ii) below.

(b) Resources assigned to provide Non-Synchronized Reserve at the direction of the Office of the Interconnection shall be credited as follows:

(i) Credits for Non-Synchronized Reserve provided by generation resources assigned to provide Non-Synchronized Reserve by the Office of the Interconnection in the Day-ahead Non-Synchronized Reserve Market shall be equal to the product of the Day-ahead Non-Synchronized Market Clearing Price multiplied by the megawatt amount of Non-Synchronized Reserve such resource is assigned to provide.

(ii) Credits for Non-Synchronized Reserve provided by generation resources assigned to provide Non-Synchronized Reserve by the Office of the Interconnection in the Real-time Non-Synchronized Reserve Market shall be determined for each operating hour based on the sum on their hourly total of Real-time Settlement Interval deviations determined in accordance with the following equation:

$$\sum_i ((A - B) * C)$$

Where:

i = the Real-time Settlement Intervals in the applicable operating hour;

A = For each Real-time Settlement Interval, the megawatts of Non-Synchronized Reserve from that resource assigned by the Office of the Interconnection in the Real-time Non-Synchronized Reserve Market;

B = For each Real-time Settlement Interval, the megawatts of Non-Synchronized Reserve from that resource assigned by the Office of the Interconnection in the Day-ahead Non-Synchronized Reserve Market; and

C = For each Real-time Settlement Interval, the Real-time Non-Synchronized Reserve Market Clearing Price.

(iii) Pool-scheduled generation resources assigned to provide Non-Synchronized Reserve in the Day-ahead Non-Synchronized Reserve Market shall be credited a Non-Synchronized Reserve lost opportunity cost credit, where positive, as determined in accordance with subsection (d)(iii) below, to recover any net monetary loss to the Market Seller of such resource associated with the purchase of Non-Synchronized Reserve in the Real-time Non-Synchronized Reserve Market as a result of following the dispatch direction of the Office of the Interconnection.

(c) Non-Synchronized Reserve Market Clearing Prices

(i) For the Day-ahead Non-Synchronized Reserve Market, the Non-Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection for each hour of the Operating Day. The Day-ahead Non-Synchronized Reserve Market Clearing Price shall be calculated as the price of serving the next increment of demand for Primary Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Non-Synchronized Reserve offer prices and the applicable Operating

Reserve Demand Curve for Non-Synchronized Reserve established in accordance with Tariff, Attachment K-Appendix, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Primary Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for Primary Reserve can contribute and (B) the price of serving the next increment of demand for 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Primary Reserve can contribute, provided that the Non-Synchronized Reserve Market Clearing Price shall be less than or equal to the product of 1.5 multiplied by the Reserve Penalty Factor for the Primary Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Non-Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.10.8(d), Day-ahead Non-Synchronized Reserve Market Clearing Prices shall be set to zero dollars per megawatt-hour and for purposes of settlements for such Operating Day, the Office of the Interconnection shall utilize a scheduled megawatt quantity and Day-ahead Non-Synchronized Reserve Market Clearing Price of zero dollars per megawatt-hour and all settlements will be based on the Real-time Non-Synchronized Reserve market quantities and prices as determined pursuant to subsection (c)(ii) hereof.

(ii) For the Real-time Non-Synchronized Reserve Market, the Non-Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection in the Real-time Price software program, which is known as the pricing run, for each Real-time Settlement Interval of the Operating Day. Each 5-minute clearing price shall be calculated as the price of serving the next increment of demand for Primary Reserve in a Reserve Zone or Reserve Sub-zone determined by the interaction between a supply curve formed using Non-Synchronized Reserve offer prices and the applicable Operating Reserve Demand Curve for Non-Synchronized Reserve established in accordance with Tariff, Attachment K-Appendix, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Primary Reserve for any other Reserve Zone or Reserve Subzone to which the next increment of demand for Primary Reserve can contribute and (B) the price of serving the next increment of demand for 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Primary Reserve can contribute, provided that the Non-Synchronized Reserve Market Clearing Price shall be less than or equal to the product of 1.5 multiplied by the Reserve Penalty Factor for the Primary Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Non-Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, and the Office of the Interconnection is not assigning Non-Synchronized Reserves, then the Non-Synchronized Reserve Clearing Price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, where the real-time Market Suspension is less than or equal to six (6) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Non-Synchronized Reserves, then the Non-Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Non-Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than six (6) consecutive hours but less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are cleared Day-ahead Non-Synchronized Reserve Market Clearing Prices for the affected Operating Day, then the Real-time Non-Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the Day-ahead Non-Synchronized Reserve Market Clearing Prices for each corresponding hour. If no such Day-ahead Non-Synchronized Reserve Market Clearing Prices exist, then the Non-Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Non-Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than twenty-four (24) consecutive hours, the Non-Synchronized Reserve Market Clearing Price will be set to zero dollars per megawatt-hour regardless of whether the Office of the Interconnection is assigning Non-Synchronized Reserves.

If the Office of the Interconnection has initiated in a Reserve Zone or Reserve Sub-zone either a Voltage Reduction Action as described in the PJM Manuals or a Manual Load Dump Action as described in the PJM Manuals, the Real-time Non-Synchronized Reserve Market Clearing Price shall be the product of 1.5 multiplied by the Reserve Penalty Factor for the Primary Reserve Requirement for that Reserve Zone or Reserve Sub-zone.

(iii) The Reserve Penalty Factor for the Primary Reserve Requirement shall be \$850/MWh.

The Reserve Penalty Factor for the Extended Primary Reserve Requirement shall be \$300/MWh.

(iv) By no later than April 30 of each year, the Office of the Interconnection will analyze Market Participants' response to prices exceeding \$1,000/MWh on an annual basis and will provide its analysis to PJM stakeholders. The Office of the Interconnection will also review this analysis to determine whether any changes to the Primary Reserve Penalty Factors are warranted for subsequent Delivery Year(s).

(d) (i) For determining the Non-Synchronized Reserve clearing price for each hour in the Day-ahead Non-Synchronized Reserve Market and for each Real-time Settlement Interval in the Real-time Non-Synchronized Reserve Market, including during a declaration of a Market Suspension, the unit-specific opportunity cost for a generation resource that is not providing energy because they are providing Non-Synchronized Reserves will be zero.

(ii) For each Real-time Settlement Interval, a total Market Revenue Neutrality Offset is calculated for each resource, if eligible. If there is a decrease in real-time reserve MW from a day-ahead market assignment in more than one market for that Real-time Settlement Interval, the total Market Revenue Neutrality Offset is allocated to the Non-Synchronized Reserve market based on the ratio of the opportunity cost owed due to a reduction in assignment in real-time within the Non-Synchronized Reserve market and the total opportunity cost owed due to a reduction in assignment in real-time from all reserve markets, not to exceed the resource's opportunity cost owed in the Non-Synchronized Reserve market.

A resource is not eligible for Market Revenue Neutrality Offset for Non-Synchronized Reserve in a Real-time Settlement Interval for any of the following conditions:

(A) A resource's real-time Non-Synchronized Reserve assignment decreases due to the resource being self-scheduled to provide energy, Synchronized Reserve, or Regulation;

(B) A resource reduces flexibility in real-time such that the resource no longer qualifies to provide Non-Synchronized Reserve in real-time;

(C) A resource's Final Offer is less than its Committed Offer;

(D) A resource trips offline or otherwise becomes unavailable in real-time; or

(E) A resource does not follow dispatch as described in section 3.2.3(o) above and section 3.2.3(o-1) above.

(iii) A Non-Synchronized Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:

$$(\text{zero}) - (A + B + C + D)$$

Where:

A = day-ahead clearing price credits as determined in subsection (b)(i) above;

B = real-time clearing price credits as determined in subsection (b)(ii) above;

C = the applicable Market Revenue Neutrality Offset as determined in subsection (d)(ii) above; and

D = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A.001(d)(ii) above if not eligible for Market Revenue Neutrality Offset.

(e) [Reserved for future use]

(f) For each operating hour, the sum of the Non-Synchronized Reserve lost opportunity cost credits credited in subsection (b)(iii) above shall be allocated and charged to each Market Participant that does not meet its hourly Non-Synchronized Reserve Obligation in proportion to its real-time purchases of Non-Synchronized Reserve in megawatt-hours during that hour.

(g) The magnitude of response to a Non-Synchronized Reserve Event by a generation resource is the difference between the generation resource's output at the start of the event and its output 10 minutes after the start of the event. In order to allow for small fluctuations and possible telemetry delays, generation resource output at the start of the event is defined as the lowest telemetered generator resource output between one minute prior to and one minute following the start of the event. Similarly, a generation resource's output 10 minutes after the start of the event is defined as the greatest generator resource output achieved between 9 and 11 minutes after the start of the event. The response actually credited to a generation resource will be reduced by the amount the megawatt output of the generation resource falls below the level achieved after 10 minutes by either the end of the event or after 30 minutes from the start of the event, whichever is shorter.

(h) In the event a generation resource that has been assigned by the Office of the Interconnection to provide Non-Synchronized Reserve fails to provide the assigned amount of Non-Synchronized Reserve in response to a Non-Synchronized Reserve Event, the resource will be credited for Non-Synchronized Reserve capacity in the amount that actually responded for the contiguous Real-time Settlement Interval the resource was assigned Non-Synchronized Reserve during which the event occurred.

3.2.3A.01 Secondary Reserve.

(a) Each Market Participant that is a Load Serving Entity shall have an obligation for hourly Secondary Reserve equal to its pro rata share of Secondary Reserve assigned for the hour for each Reserve Zone and Reserve Sub-zone of the PJM Region, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Reserve Zone and Reserve Sub-zone for the hour ("Secondary Reserve Obligation"). A Market Participant's hourly Secondary Reserve Obligation shall be adjusted by any Secondary Reserve provided on the Market Participant's behalf through a bilateral

agreement. A Market Participant with an hourly Secondary Reserve Obligation shall be charged the pro rata share of the sum of day-ahead and real-time credits for Secondary Reserve as defined in sections 3.2.3A.01(b)(i) and (ii) below.

(b) Resources assigned to provide Secondary Reserve at the direction of the Office of the Interconnection shall be credited as follows:

(i) Credits for Secondary Reserve provided by generation resources and Economic Load Response Participant resources assigned to provide Secondary Reserve by the Office of the Interconnection in the Day-ahead Secondary Reserve Market shall be equal to the product of the Day-ahead Secondary Reserve Market Clearing Price multiplied by the megawatt amount of Secondary Reserve such resource is scheduled to provide.

(ii) Credits for Secondary Reserve provided by generation resources and Economic Load Response Participant resources scheduled to provide Secondary Reserve by the Office of the Interconnection in the Real-time Secondary Reserve Market shall be determined for each operating hour based on the sum of their hourly total of Real-time Settlement Interval deviations determined in accordance with the following equation:

$$\sum_i ((A - B) * C)$$

Where:

i = the Real-time Settlement Intervals in the applicable operating hour;

A = For each Real-time Settlement Interval, the megawatts of Secondary Reserve from that resource assigned by the Office of the Interconnection in the Real-time Secondary Reserve Market. The megawatt value is capped at the lesser of the Economic Maximum or Secondary Reserve maximum MW minus the Revenue Data for Settlements of the resource for each Real-time Settlement Interval minus the Real-time Synchronized Reserve assignment;

B = For each Real-time Settlement Interval, the megawatts of Secondary Reserve from that resource scheduled by the Office of the Interconnection in the Day-ahead Secondary Reserve Market; and

C = For each Real-time Settlement Interval, the Real-time Secondary Reserve Market Clearing Price.

(iii) Pool-scheduled resources and Economic Load Response Participant resources shall be credited a Secondary Reserve lost opportunity cost credit, where positive, as described in subsection (f)(iv) below.

(c) [Reserved for future use]

(d) Secondary Reserve Market Clearing Prices

(i) For the Day-ahead Secondary Reserve Market, the Secondary Reserve Market Clearing Price shall be determined for each Reserve Zone and, as applicable, Reserve Sub-zone by the Office of the Interconnection for each hour of the Operating Day. The Day-ahead Secondary Reserve Market Clearing Price shall be calculated as the price of serving the next increment of demand for 30-minute Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Secondary Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Secondary Reserve established in accordance with Tariff, Attachment K-Appendix, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus the price of serving the next increment of demand for 30-minute Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute, but the Secondary Reserve Market Clearing Price shall not exceed the Reserve Penalty Factor for the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.10.8(d), Day-ahead Secondary Reserve Market Clearing Prices shall be set to zero dollars per megawatt-hour and for purposes of settlements for such Operating Day, the Office of the Interconnection shall utilize a scheduled megawatt quantity and Day-ahead Secondary Reserve Market Clearing Price of zero dollars per megawatt-hour and all settlements will be based on the Real-time Secondary Reserve market quantities and prices as determined pursuant to subsection (d)(ii) hereof.

(ii) For the Real-time Secondary Reserve Market, the Secondary Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection for each Real-time Settlement Interval of the Operating Day. Each 5-minute clearing price shall be calculated as the price of serving the next increment of demand for 30-minute Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Secondary Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Secondary Reserve established in accordance with Tariff, Attachment K-Appendix, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus the price of serving the next increment of demand for 30-minute Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute but the Secondary Reserve Market Clearing Price shall not exceed the Reserve Penalty Factor for the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, and the Office of the Interconnection is not assigning Secondary Reserves, then the Secondary Reserve Clearing Price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market

Suspension period.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, where the real-time Market Suspension is less than or equal to six (6) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Secondary Reserves, then the Secondary Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Secondary Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than six (6) consecutive hours but less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are cleared Day-ahead Secondary Reserve Market Clearing Prices for the affected Operating Day, then the Real-time Secondary Reserve Market Clearing Prices associated with such Market Suspension shall be the Day-ahead Secondary Reserve Market Clearing Prices for each corresponding hour. If no such Day-ahead Secondary Reserve Market Clearing Prices exist, then the Secondary Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Secondary Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than twenty-four (24) consecutive hours, and the Office of the Interconnection is assigning Secondary Reserves, the Secondary Reserve Market Clearing Price will be set to zero dollars per megawatt-hour. Resources will be compensated for lost opportunity cost per subsection (f) hereof using the energy price as determined in Operating Agreement, Schedule 1, section 2.5.2.iii.

If the Office of the Interconnection has initiated in a Reserve Zone or Reserve Sub-zone either a Voltage Reduction Action or a Manual Load Dump Action as described in the PJM Manuals, the Real-time Secondary Reserve Market Clearing Price for a given Reserve Zone or Sub-zone shall be the Reserve Penalty Factor for the 30-minute Reserve Requirements for that Reserve Zone or Reserve Sub-zone.

(iii) The Reserve Penalty Factor for the 30-minute Reserve Requirement shall be \$850/MWh.

The Reserve Penalty Factor for the Extended 30-minute Reserve Requirement shall be \$300/MWh.

(iv) By no later than April 30 of each year, the Office of the Interconnection will analyze Market Participants' response to prices exceeding \$1,000/MWh on an annual basis and will provide its analysis to PJM stakeholders. The Office of the Interconnection will also review this analysis to determine whether any changes to the Reserve Penalty Factor for 30-minute Reserve are warranted for subsequent Delivery Year(s).

(e) (i) For determining the Secondary Reserve Market Clearing Price for each hour in the Day-ahead Secondary Reserve Market, the estimated resource-specific opportunity cost for a generation resource or Economic Load Response Participant resources shall be the difference between the Locational Marginal Price at the generation or Economic Load Response Participant resource bus and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) or offer price to reduce energy from the Economic Load Response Participant resource in the PJM Interchange Energy Market when the Locational Marginal Price at the Economic Load Response Participant resource bus is greater than the offer price for energy from the generation resource or the offer price to reduce energy from the Economic Load Response Participant resource.

However, opportunity costs shall be zero for resources self-scheduled to provide Synchronized Reserve, and for synchronous condensers and for Economic Load Response Participant resources that do not receive a day-ahead commitment to provide energy in the same operating hour in which such resource is committed to provide Secondary Reserve.

(ii) For determining the Secondary Reserve Market Clearing Price for each Real-time Settlement Interval in the Real-time Secondary Reserve Market, the estimated unit-specific opportunity cost for a generation resource that is not a hydroelectric resource shall be the difference between the Locational Marginal Price at the generation bus for the generation resource and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) in the PJM Interchange Energy Market when the Locational Marginal Price at the generation bus is greater than the offer price for energy from the generation resource.

For hydroelectric resources, the estimated unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the expected real-time Locational Marginal Price at that generation bus. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the expected real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average day-ahead Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

However, the opportunity costs shall be zero for resources self-scheduled to provide Synchronized Reserve, and for synchronous condensers and Economic Load Response Participant resources.

(f) (i) In determining the credit under subsection (b) to a generation resource, except a generation resource that is a synchronous condenser, selected to provide Secondary Reserve in the Day-ahead Secondary Reserve Market or an Economic Load Response Participant resource that is selected to provide Secondary Reserve in the Day-ahead Secondary Reserve Market in the same operating hour in which such resource receives a day-ahead commitment to provide energy, the opportunity cost of a resource shall be determined for each operating hour that the Office of the Interconnection requires a resource to provide Secondary Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Day-ahead Locational Marginal Price at the generation bus of the generation resource or the applicable pricing point for the Economic Load Response Participant resource;

B= The deviation of the resource's energy output or load reduction necessary to supply a Day-ahead Secondary Reserve assignment from the resource's expected energy output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load less any Day-ahead Synchronized Reserve Market assignment; and

C = The Day-ahead Energy Market offer integrated under the applicable energy offer curve for the resource's energy output or load reduction necessary to provide a Day-ahead Secondary Reserve Market assignment from the resource's expected energy output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load less any Day-ahead Synchronized Reserve Market assignment.

For a generation resource that is a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: [energy use for providing synchronous condensing multiplied by A] plus [the applicable condense start-up cost divided by the number of hours the resource is assigned Secondary Reserve].

(ii) In determining the credit under subsection (b) to a generation resource, except a generation that is a synchronous condenser, selected to provide Secondary Reserve in the Real-time Secondary Reserve Market in excess of the resource's Day-ahead Secondary Reserve Market assignment and that actively follows the Office of the Interconnection's signals and instructions, the unit-specific opportunity cost of that generation resource shall be determined for each Real-time Settlement Interval that the Office of the Interconnection requires that generation resource to provide Secondary Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Real-time Locational Marginal Price at the generation bus of the generation resource;

B= The deviation of the generation resource's output necessary to supply Secondary Reserve in real-time in excess of its Day-ahead Secondary Reserve Market assignment and follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy less any Real-time Synchronized Reserve Market assignment; and

C = The energy offer integrated under the applicable energy offer curve for the generation resource's output necessary to supply Secondary Reserve in real-time from the lesser of the generation resource's output necessary to provide a Day-ahead Secondary Reserve Market assignment or follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy less any Real-time Synchronized Reserve Market assignment.

For hydroelectric resources, the unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the real-time Locational Marginal Price at that generation bus multiplied by the additional megawatts assigned to supply Synchronized Reserve in real-time in excess of its Day-ahead Secondary Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average real-time Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating multiplied by the additional megawatts assigned to supply Secondary Reserve in real-time in excess of its Day-ahead Secondary Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

For a generation resource that is a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: additional energy use in excess of day-ahead energy use for providing synchronous condensing in real-time multiplied by A plus [any applicable condense start-up costs due to additional condense start-ups in real-time in excess of day-ahead condense start-ups allocated to each Real-time

Settlement Interval as described in PJM Manuals]. If the generation resource is operating as a synchronous condenser and also has a Real-time Synchronized Reserve assignment, resource's unit-specific opportunity cost in the Secondary Reserve Market shall be zero,

(iii) For each Real-time Settlement Interval, a total Market Revenue Neutrality Offset is calculated for each resource, if eligible. If there is a decrease in real-time reserve MW from a day-ahead market assignment in more than one market for that real-time settlement interval, the total Market Revenue Neutrality Offset is allocated to the Secondary Reserve market based on the ratio of the opportunity cost owed due to a reduction in assignment in real-time within the Secondary Reserve market and the total opportunity cost owed due to a reduction in assignment in real-time from all reserve markets, not to exceed the resource's opportunity cost owed in the Secondary Reserve market.

A resource is not eligible for Market Revenue Neutrality Offset for Secondary Reserve in a Real-time Settlement Interval for any of the following conditions:

(A) A resource's real-time Secondary Reserve assignment decreases due to the resource being self-scheduled to provide energy, Synchronized Reserve, or Regulation;

(B) A resource reduces flexibility in real-time such that the resource no longer qualifies to provide Secondary Reserve in real-time;

(C) A resource's Final Offer is less than its Committed Offer;

(D) A resource trips offline or otherwise becomes unavailable in real-time;

(E) A resource does not follow dispatch as described in section 3.2.3(o) above and section 3.2.3(o-1) above; or

(F) A resource that fails to come online and reach Economic Minimum output within 30 minutes as described in section 3.2.3A.01(h)(i) below.

(iv) A Secondary Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:

$$(A + B) - (C + D + E + F)$$

Where:

A = day-ahead opportunity cost as determined in subsection (f)(i) above;

B = real-time opportunity cost as determined in subsection (f)(ii) above;

C = day-ahead clearing price credits as determined in subsection (b)(i) above;

D = real-time clearing price credits as determined subsection (b)(ii) above;

E = the applicable Market Revenue Neutrality Offset as determined in subsection (f)(iii) above; and

F = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A.01(f)(iii) above if not eligible for Market Revenue Neutrality Offset.

(v) The opportunity costs for Economic Load Response Participant resources and generation resources not synchronized to the grid shall be zero, except that Economic Load Response Participant resources may have a day-ahead opportunity cost, as determined in subsection (f)(i) above.

(g) For each operating hour, the sum of the Secondary Reserve lost opportunity cost credits credited in accordance with subsection (b)(iii) above shall be allocated and charged to each Market Participant that does not meet its hourly Secondary Reserve Obligation in proportion to its real-time purchases of Secondary Reserve in megawatt-hours during that hour.

(h) (i) In the event an offline generation resource has been assigned by the Office of the Interconnection to provide Secondary Reserve in real-time and is subsequently dispatched by the Office of the Interconnection to supply energy during that Operating Day and the resource qualifies as a Secondary Reserve resource at the time it is dispatched to provide energy, the Office of the Interconnection will assess the resource's performance as follows:

For each generation resource that fails to come online and reach Economic Minimum output within 30 minutes as instructed by the Office of the Interconnection, the resource's Real-time Secondary Reserve assignment will be set to zero megawatts for that interval and for all prior intervals in which the resource was assigned to provide Secondary Reserve in the Real-time Secondary Reserve Market starting at the later of (A) the last interval the resource was online or (B) the beginning of that Operating Day and continuing up to the interval the resource failed to come online. This results in the resource buying back the day-ahead assignment at the Real-time Secondary Reserve Market Clearing Price, or if solely assigned in real-time not being paid for the assigned MW.

(ii) In the event an Economic Load Response Participant resource has been assigned by the Office of the Interconnection to provide Secondary Reserve in real-time and is subsequently dispatched to supply the Secondary Reserve assignment as a load reduction, the Office of the Interconnection will assess the resource's performance as follows:

For the purposes of this subsection, a resource's starting MW usage shall be the greatest telemetered consumption between one minute prior to and one minute following the issuance of a dispatch instruction from the Office of the Interconnection, and a resource's ending MW usage shall be the lowest consumption between 29 and 31 minutes after the issuance of a dispatch instruction from the Office of the Interconnection.

For each Economic Load Response Participant resource that fails to reduce load by at least the Economic Minimum, where the measured response is the difference between the resource's starting MW usage and the resource's ending MW usage as described above, within 30 minutes as instructed by the Office of the Interconnection, the resource's Real-time Secondary Reserve assignment will be set to zero megawatts for that interval, and for all prior intervals in which the resource was assigned to provide Secondary Reserve in the Real-time Secondary Reserve Market between such non-performance event starting at the later of (A) the last interval the resource reduced load at the instruction of the Office of the Interconnection or (B) the beginning of that Operating Day, and for all subsequent intervals through the earlier of (C) the next interval in which the resource is dispatched to reduce load or (D) the end of the Operating Day. This results in the resource buying back the day-ahead assignment at the Real-time Secondary Reserve Market Clearing Price, or if solely assigned in real-time, refunding all payments due for Secondary Reserve during such period.

(iii) For Batch Load Economic Load Response Participant Resources, a second method of verification will be used for instances where a Secondary Reserve assignment dispatched as an energy load reduction is initiated and the resource is operating at the minimum consumption level of its duty cycle. In this case, the magnitude of the response will be measured as the difference between (A) the minimum of the resource's consumption between the minute before and the minute after the end of the last settlement interval the resource reduced load at the instruction of the Office of the Interconnection and (B) the maximum consumption within a ten (10) minute period following the end of the last settlement interval the resource reduced load provided that all subsequent minutes following that minute are no less than 50% of the consumption in that minute.

For each Batch Load Economic Load Response Participant Resource that fails to reduce load by at least the Economic Minimum, where the measured response is the difference between the resource's starting MW usage and the resource's ending MW usage as described in section (ii) above or the difference between (A) and (B) as described in section (iii) above, within 30 minutes as instructed by the Office of the Interconnection, the resource's Real-time Secondary Reserve assignment will be set to zero megawatts for that interval, and for all prior intervals in which the resource was assigned to provide Secondary Reserve in either the Day-ahead or Real-time Secondary Reserve Markets between such non-performance event starting at the later of (A) the last interval the resource reduced load at the instruction of the Office of the Interconnection or (B) the beginning of that Operating Day, and for all subsequent intervals through the earlier of (C) the next interval in which the resource is dispatched to reduce load or (D) the end of the Operating Day. This results in the resource buying back the day-ahead

assignment at the Real-time Secondary Reserve Market Clearing Price, or if solely assigned in real-time, refunding all payments due for Secondary Reserve during such period.

3.2.3A.02 Operating Reserve Demand Curves

The Office of the Interconnection shall establish Operating Reserve Demand Curves for clearing 30-minute Reserve, Primary Reserve, and Synchronized Reserve, for, as applicable, each Reserve Zone or Reserve Sub-zone to procure sufficient reserves to meet, as applicable, (a) 30-minute Reserve Requirement and Extended 30-minute Reserve Requirement; (b) Primary Reserve Requirement and Extended Primary Reserve Requirement; and (c) Synchronized Reserve Requirement and Extended Synchronized Reserve Requirement. The Operating Reserve Demand Curves established for each reserve type shall be used to commit such reserves in both the day-ahead and real-time reserve markets. The Operating Reserve Demand Curves shall be determined in accordance with the applicable Reserve Penalty Factors and PJM Manuals.

3.2.3B Reactive Services.

(a) A Market Seller providing Reactive Services at the direction of the Office of the Interconnection shall be credited as specified below for the operation of its resource. These provisions are intended to provide payments to generating units when the LMP dispatch algorithms would not result in the dispatch needed for the required reactive service. LMP will be used to compensate generators that are subject to redispatch for reactive transfer limits.

(b) At the end of each Operating Day, where the active energy output of a Market Seller's resource is reduced or suspended at the request of the Office of the Interconnection for the purpose of maintaining reactive reliability within the PJM Region, the Market Seller shall be credited according to sections 3.2.3B(c) & 3.2.3B(d).

(c) A Market Seller providing Reactive Services from either a steam-electric generating unit or combined cycle unit operating in combined cycle mode, where such unit is pool-scheduled (or self-scheduled, if operating according to Tariff, Attachment K-Appendix, section 1.10.3 (c) hereof), and where the real time LMP at the unit's bus is higher than the price offered by the Market Seller for energy from the unit at the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override) shall be compensated for lost opportunity cost by receiving a credit for each Real-time Settlement Interval in an amount equal to the product of (A) the deviation of the generating unit's output necessary to follow the Office of the Interconnection's signals and the generating unit's expected output level if it had been dispatched in economic merit order, times (B) the Real-time Price at the generation bus for the generating unit, minus (C) the Total Lost Opportunity Cost Offer, provided that the resulting outcome is greater than \$0.00. This equation is represented as $(A*B) - C$.

(d) A Market Seller providing Reactive Services from either a combustion turbine unit or combined cycle unit operating in simple cycle mode that is pool scheduled (or self-

scheduled, if operating according to Tariff, Attachment K-Appendix, section 1.10.3 (c) hereof), operated as requested by the Office of the Interconnection, shall be compensated for lost opportunity cost for each Real-time Settlement Interval, limited to the lesser of the unit's Economic Maximum or the unit's Generation Resource Maximum Output, if the unit output is reduced at the direction of the Office of the Interconnection and the real time LMP at the unit's bus is higher than the price offered by the Market Seller for energy from the unit at the level of output requested by the Office of the Interconnection as directed by the PJM dispatcher, then the Market Seller shall be credited in a manner consistent with that described above in section 3.2.3B(c) for a steam unit or a combined cycle unit operating in combined cycle mode.

(e) At the end of each Operating Day, where the active energy output of a Market Seller's unit is increased at the request of the Office of the Interconnection for the purpose of maintaining reactive reliability within the PJM Region and the offered price of the energy is above the real-time LMP at the unit's bus, the Market Seller shall be credited according to section 3.2.3B(f).

(f) A Market Seller providing Reactive Services from either a steam-electric generating unit, combined cycle unit or combustion turbine unit, where such unit is pool scheduled (or self-scheduled, if operating according to Tariff, Attachment K-Appendix, section 1.10.3 (c) hereof), and where the real time LMP at the unit's bus is lower than the price offered by the Market Seller for energy from the unit at the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override), shall receive a credit in an amount equal to $\{(AG - LMPDMW) \times (UB - URTLMP)\}$ where:

AG equals the actual output of the unit;

LMPDMW equals the level of output for the unit determined according to the point on the scheduled offer curve on which the unit was operating corresponding to the real time LMP at the unit's bus and adjusted for any Regulation or Tier 2 Synchronized Reserve assignments;

UB equals the unit offer for that unit for which output is increased, determined according to the lesser of the Final Offer or Committed Offer;

URTLMP equals the real time LMP at the unit's bus; and

where $UB - URTLMP$ shall not be negative.

(g) A Market Seller providing Reactive Services from a hydroelectric resource where such resource is pool scheduled (or self-scheduled, if operating according to Tariff, Attachment K-Appendix, section 1.10.3 (c) hereof), and where the output of such resource is altered from the schedule submitted by the Market Seller for the purpose of maintaining reactive reliability at the request of the Office of the Interconnection, shall be compensated for lost opportunity cost in the same manner as provided in sections 3.2.2(d) and 3.2.3A(f) and further detailed in the PJM Manuals.

(h) If a Market Seller believes that, due to specific pre-existing binding commitments to which it is a party, and that properly should be recognized for purposes of this section, the above calculations do not accurately compensate the Market Seller for lost opportunity cost associated with following the Office of the Interconnection's dispatch instructions to reduce or suspend a unit's output for the purpose of maintaining reactive reliability, then the Office of the Interconnection, the Market Monitoring Unit and the individual Market Seller will discuss a mutually acceptable, modified amount of such alternate lost opportunity cost compensation, taking into account the specific circumstances binding on the Market Seller. Following such discussion, if the Office of the Interconnection accepts a modified amount of alternate lost opportunity cost compensation, the Office of the Interconnection shall invoice the Market Participant accordingly. If the Market Monitoring Unit disagrees with the modified amount of alternate lost opportunity cost compensation, as accepted by the Office of the Interconnection, it will exercise its powers to inform the Commission staff of its concerns.

(i) The amount of Synchronized Reserve provided by generating units maintaining reactive reliability shall be counted as Synchronized Reserve satisfying the overall PJM Synchronized Reserve requirements. Operators of these generating units shall be notified of such provision, and to the extent a generating unit's operator indicates that the generating unit is capable of providing Synchronized Reserve, shall be subject to the same requirements contained in section 3.2.3A regarding provision of Synchronized Reserve. At the end of each Operating Day, to the extent a condenser operated to provide Reactive Services also provided Synchronized Reserve, a Market Seller shall be credited for providing synchronous condensing for the purpose of maintaining reactive reliability at the request of the Office of the Interconnection, in an amount equal to the higher of (i) the Synchronized Reserve Market Clearing Price for each Real-time Settlement Interval a generating unit provided synchronous condensing multiplied by the amount of Synchronized reserve provided by the synchronous condenser or (ii) the sum of (A) the generating unit's cost to provide synchronous condensing, calculated in accordance with the PJM Manuals, (B) the product of MW energy usage for providing synchronous condensing multiplied by the real time LMP at the generating unit's bus, (C) the generating unit's startup-cost of providing synchronous condensing, and (D) the unit-specific lost opportunity cost of the generating resource supplying the increment of Synchronized Reserve as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals. To the extent a condenser operated to provide Reactive Services was not also providing Synchronized Reserve, the Market Seller shall be credited only for the generating unit's cost to condense, as described in (ii) above. The total Synchronized Reserve Obligations of all Load Serving Entities under section 3.2.3A(a) in the zone where these condensers are located shall be reduced by the amount counted as satisfying the PJM Synchronized Reserve requirements. The Synchronized Reserve Obligation of each Load Serving Entity in the zone under section 3.2.3A(a) shall be reduced to the same extent that the costs of such condensers counted as Synchronized Reserve are allocated to such Load Serving Entity pursuant to subsection (l) below.

(j) A Market Seller's pool scheduled steam-electric generating unit or combined cycle unit operating in combined cycle mode, that is not committed to operate in the Day-ahead Market, but that is directed by the Office of the Interconnection to operate solely for the purpose

of maintaining reactive reliability, at the request of the Office of the Interconnection, shall be credited in the amount of the unit's offered price for start-up and no-load fees. The unit also shall receive, if applicable, compensation in accordance with Sections 3.2.3B(e)-(f).

(k) The sum of the foregoing credits as specified in Sections 3.2.3B(b)-(j) shall be the cost of Reactive Services for the purpose of maintaining reactive reliability for the Operating Day and shall be separately determined for each transmission zone in the PJM Region based on whether the resource was dispatched for the purpose of maintaining reactive reliability in such transmission zone.

(l) The cost of Reactive Services for the purpose of maintaining reactive reliability in a transmission zone in the PJM Region for each Operating Day shall be allocated and charged to each Market Participant in proportion to its deliveries of energy to load (net of operating Behind The Meter Generation) in such transmission zone, served under Network Transmission Service, in megawatt-hours during that Operating Day, as compared to all such deliveries for all Market Participants in such transmission zone.

(m) Generating units receiving dispatch instructions from the Office of the Interconnection under the expectation of increased actual or reserve reactive shall inform the Office of the Interconnection dispatcher if the requested reactive capability is not achievable. Should the operator of a unit receiving such instructions realize at any time during which said instruction is effective that the unit is not, or likely would not be able to, provide the requested amount of reactive support, the operator shall as soon as practicable inform the Office of the Interconnection dispatcher of the unit's inability, or expected inability, to provide the required reactive support, so that the associated dispatch instruction may be cancelled. PJM Performance Compliance personnel will audit operations after-the-fact to determine whether a unit that has altered its active power output at the request of the Office of the Interconnection has provided the actual reactive support or the reactive reserve capability requested by the Office of the Interconnection. PJM shall utilize data including, but not limited to, historical reactive performance and stated reactive capability curves in order to make this determination, and may withhold such compensation as described above if reactive support as requested by the Office of the Interconnection was not or could not have been provided.

3.2.3C Synchronous Condensing for Post-Contingency Operation.

(a) Under normal circumstances, PJM operates generation out of merit order to control contingency overloads when the flow on the monitored element for loss of the contingent element ("contingency flow") exceeds the long-term emergency rating for that facility, typically a 4-hour or 2-hour rating. At times however, and under certain, specific system conditions, PJM does not operate generation out of merit order for certain contingency overloads until the contingency flow on the monitored element exceeds the 30-minute rating for that facility ("post-contingency operation"). In conjunction with such operation, when the contingency flow on such element exceeds the long-term emergency rating, PJM operates synchronous condensers in the areas affected by such constraints, to the extent they are available, to provide greater certainty that such resources will be capable of producing energy in sufficient time to reduce the flow on the monitored element below the normal rating should such contingency occur.

(b) The amount of Synchronized Reserve provided by synchronous condensers associated with post-contingency operation shall be counted as Synchronized Reserve satisfying the applicable Synchronized Reserve Requirements. Operators of these generation units shall be notified of such provision, and to the extent a generation unit's operator indicates that the generation unit is capable of providing Synchronized Reserve, shall be subject to the same requirements contained in section 3.2.3A regarding provision of Synchronized Reserve. At the end of each Operating Day, to the extent a condenser operated in conjunction with post-contingency operation also provided Synchronized Reserve, a Market Seller shall be credited for providing synchronous condensing in conjunction with post-contingency operation at the request of the Office of the Interconnection, in an amount equal to the higher of (i) the Real-time Synchronized Reserve Market Clearing Price for each applicable interval a generation resource provided synchronous condensing multiplied by the amount of Synchronized Reserve provided by the synchronous condenser or (ii) the sum of (A) the generation resource's applicable interval cost to provide synchronous condensing, calculated in accordance with the PJM Manuals, (B) the applicable interval product of the megawatts of energy used to provide synchronous condensing multiplied by the real-time LMP at the generation bus of the generation resource, (C) the generation resource's start-up cost of providing synchronous condensing, and (D) the unit-specific lost opportunity cost of the generation resource supplying the increment of Synchronized Reserve as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals. To the extent a condenser operated in association with post-contingency constraint control was not also providing Synchronized Reserve, the Market Seller shall be credited only for the generation unit's cost to condense, as described in (ii) above. The total Synchronized Reserve Obligations of all Load Serving Entities under section 3.2.3A(a) in the zone where these condensers are located shall be reduced by the amount counted as satisfying the PJM Synchronized Reserve requirements. The Synchronized Reserve Obligation of each Load Serving Entity in the zone under section 3.2.3A(a) shall be reduced to the same extent that the costs of such condensers counted as Synchronized Reserve are allocated to such Load Serving Entity pursuant to subsection (d) below.

(c) The sum of the foregoing credits as specified in section 3.2.3C(b) shall be the cost of synchronous condensers associated with post-contingency operations for the Operating Day and shall be separately determined for each transmission zone in the PJM Region based on whether the resource was dispatched in association with post-contingency operation in such transmission zone.

(d) The cost of synchronous condensers associated with post-contingency operations in a transmission zone in the PJM Region for each Operating Day shall be allocated and charged to each Market Participant in proportion to its deliveries of energy to load (net of operating Behind The Meter Generation) in such transmission zone, served under Network Transmission Service, in megawatt-hours during that Operating Day, as compared to all such deliveries for all Market Participants in such transmission zone.

3.2.4 Transmission Congestion Charges.

Each Market Buyer shall be assessed Transmission Congestion Charges as specified in Tariff, Attachment K-Appendix, section 5.

3.2.5 Transmission Loss Charges.

Each Market Buyer shall be assessed Transmission Loss Charges as specified in Tariff, Attachment K-Appendix, section 5.

3.2.6 Emergency Energy.

(a) When the Office of the Interconnection has implemented Emergency procedures, resources offering Emergency energy are eligible to set real-time Locational Marginal Prices, capped at the energy offer cap plus sum of the applicable Reserve Penalty Factors for the Synchronized Reserved Requirement and Primary Reserve Requirement, provided that the Emergency energy is needed to meet demand in the PJM Region.

(b) Market Participants shall be allocated a proportionate share of the net cost of Emergency energy purchased by the Office of the Interconnection. Such allocated share during each applicable interval of such Emergency energy purchase shall be in proportion to the amount of each Market Participant's real-time deviation from its net withdrawals and injections in the Day-ahead Energy Market, whenever that deviation increases the Market Participant's spot market purchases or decreases its spot market sales. This deviation shall not include any reduction or suspension of output of pool scheduled resources requested by PJM to manage an Emergency within the PJM Region.

(c) Net revenues in excess of Real-time Prices attributable to sales of energy in connection with Emergencies to other Control Areas shall be credited to Market Participants during each applicable interval of such Emergency energy sale in proportion to the sum of (i) each Market Participant's real-time deviation from its net withdrawals and injections in the Day-ahead Energy Market, whenever that deviation increases the Market Participant's spot market purchases or decreases its spot market sales, and (ii) each Market Participant's energy sales from within the PJM Region to entities outside the PJM Region that have been curtailed by PJM.

(d) The net costs or net revenues associated with sales or purchases of energy in connection with a Minimum Generation Emergency in the PJM Region, or in another Control Area, shall be allocated during each applicable interval of such Emergency sale or purchase to each Market Participant in proportion to the amount of each Market Participant's real-time deviation from its net withdrawals and injections in the Day-ahead Market, whenever that deviation increases the Market Participant's spot market sales or decreases its spot market purchases.

3.2.7 Billing.

(a) PJMSettlement shall prepare a billing statement each billing cycle for each Market Participant in accordance with the charges and credits specified in Tariff, Attachment K-Appendix, sections 3.2.1 through 3.2.6, and showing the net amount to be paid or received by the Market Participant. Billing statements shall provide sufficient detail, as specified in the PJM

Manuals, to allow verification of the billing amounts and completion of the Market Participant's internal accounting.

(b) If deliveries to a Market Participant that has PJM Interchange meters in accordance with Operating Agreement, section 14 include amounts delivered for a Market Participant that does not have PJM Interchange meters separate from those of the metered Market Participant, PJMSettlement shall prepare a separate billing statement for the unmetered Market Participant based on the allocation of deliveries agreed upon between the Market Participant and the unmetered Market Participant specified by them to the Office of the Interconnection.

7.1 Auctions of Financial Transmission Rights.

Annual, periodic and long-term auctions to allow Market Participants to acquire or sell Financial Transmission Rights shall be conducted by the Office of the Interconnection in accordance with the provisions of this Section. PJMSettlement shall be the Counterparty to the purchases and sales of Financial Transmission Rights arising from such auctions; provided however, that PJMSettlement shall not be a contracting party to any subsequent bilateral transfer of Financial Transmission Rights between Market Participants. The conversion of an Auction Revenue Right to a Financial Transmission Right pursuant to this section 7 shall not constitute a purchase or sale transaction to which PJMSettlement is a contracting party.

7.1.1 Auction Period and Scope of Auctions.

(a) The periods covered by auctions shall be: (1) the one-year period beginning the month after the final round of an annual auction; and (2) any single calendar month period remaining in the Planning Period. With the exception of FTRs allocated pursuant to Operating Agreement, Schedule 1, section 5.2.2 (e) and the Financial Transmission Rights awarded as a result of the exercise of the conversion option pursuant to Operating Agreement, Schedule 1, section 7.1.1(b), in the annual auction, the Office of the Interconnection, on behalf of PJMSettlement, shall offer for sale the entire Financial Transmission Rights capability for the year in four rounds with 25 percent of the capability offered in each round. In the monthly auction, the Office of the Interconnection, on behalf of PJMSettlement, shall offer for sale in the auction any remaining Financial Transmission Rights capability for the months remaining in the Planning Period after taking into account all of the Financial Transmission Rights already outstanding at the time of the auction. In addition, any holder of a Financial Transmission Right for the period covered by an auction may offer such Financial Transmission Right for sale in such auction. Weekend on-peak, weekday on-peak, off-peak and 24-hour Financial Transmission Rights, as those products are described in Tariff, Attachment K-Appendix, section 7.3.4, will be offered in the annual and monthly auctions. FTRs will be offered as Financial Transmission Right Obligations and Financial Transmission Right Options, provided that such Financial Transmission Right Obligations and Financial Transmission Right Options shall be awarded based only on the residual system capability that remains after the allocation of Financial Transmission Rights pursuant to Operating Agreement, Schedule 1, section 5.2.2(e) and the award of Financial Transmission Rights pursuant to Operating Agreement, Schedule 1, section 7.1.1(b). Market Participants may bid for and acquire any number of Financial Transmission Rights, provided that all Financial Transmission Rights awarded are simultaneously feasible with each other and with all Financial Transmission Rights outstanding at the time of the auction and not sold into the auction. An ARR holder may self-schedule an FTR on the same path in the Annual FTR auction according to the rules described in the PJM Manuals.

(b) An Auction Revenue Rights holder may convert Auction Revenue Rights to Financial Transmission Rights, and such conversion shall not be considered a purchase or sale of Financial Transmission Rights in the auction. Such Financial Transmission Rights must (i) have the same source and sink points as the Auction Revenue Rights; and (ii) be Financial Transmission Right Obligations. The Auction Revenue Rights holder must inform the Office of the Interconnection

in accordance with the procedures established by the Office of the Interconnection that it intends to exercise the conversion option prior to close of round one of the annual Financial Transmission Rights auction. Once the conversion option is exercised, it will remain in effect for the entire Financial Transmission Rights auction. The Office of the Interconnection will designate twenty-five percent of the megawatt amount of the Auction Revenue Rights to be converted as price-taker bids in each of the four rounds of the Financial Transmission Rights auction. An Auction Revenue Rights holder that converts its Auction Revenue Rights may not designate a price bid for its converted Financial Transmission Rights and will receive a price equal to the clearing price set by other bids in the annual Financial Transmission Right auction. To the extent a market participant seeks to obtain FTRs in the annual auction through such conversion, the FTRs sought will not be included in the calculation of such market participant's credit requirement for such annual FTR auction.

7.1.2 Frequency and Time of Auctions.

Subject to Operating Agreement, Schedule 1, section 7.1.1, annual Financial Transmission Rights auctions shall offer the entire FTR capability of the PJM system in four rounds with 25 percent of the capability offered in each round. All four rounds of the annual Financial Transmission Rights auction shall occur within the two-month period (April – May) preceding the start of the PJM Planning Period. Each round shall occur over five Business Days and shall be conducted sequentially. Each round shall begin with the bidding period. The bidding period for annual Financial Transmission Rights auctions shall be open for three consecutive Business Days, opening the first day at 12:00 midnight (Eastern Prevailing Time) and closing the third day at 5:00 p.m. (Eastern Prevailing Time) , subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e). Monthly Financial Transmission Rights auctions shall be held each month. The bidding period for monthly Financial Transmission Rights auctions shall be open for three consecutive Business Days in the month preceding the first month for which Financial Transmission Rights are being auctioned, opening the first day at 12:00 midnight (Eastern Prevailing Time) and closing the third day at 5:00 p.m. (Eastern Prevailing Time) , subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e).

7.1.3 Duration of Financial Transmission Rights.

Each Financial Transmission Right acquired in a Financial Transmission Rights auction shall entitle the holder to credits of Day-ahead Energy Market Transmission Congestion Charges for the period that was specified in the corresponding auction.

7.1A Long-Term Financial Transmission Rights Auctions.

7.1A.1 Auctions.

(i) Subsequent to each annual Financial Transmission Rights auction conducted pursuant to Operating Agreement, Schedule 1, section 7.1, the Office of the Interconnection shall conduct a long-term Financial Transmission Rights auction for the three consecutive Planning Periods immediately subsequent to the Planning Period during which the long-term Financial Transmission Rights auction is conducted. PJMSettlement shall be the Counterparty to the purchases and sales of Financial Transmission Rights arising from such long-term Financial Transmission Rights auctions, provided however, that PJMSettlement shall not be a contracting party to any subsequent bilateral transfers of Financial Transmission Rights between Market Participants. The conversion of an Auction Revenue Right to a Financial Transmission Right pursuant to this section 7 shall not constitute a purchase or sale transaction to which PJMSettlement is a contracting party.

(ii) The capacity offered for sale in long-term Financial Transmission Rights auctions shall be the residual system capability after the annual Auction Revenue Rights allocations and the annual Financial Transmission Rights auction. In determining the residual capability the Office of the Interconnection shall assume that all Auction Revenue Rights allocated in the immediately prior annual Auction Revenue Rights allocation process, including Auction Revenue Rights made available in which transmission facilities which were modeled out of service in the annual Auction Revenue Rights allocations return to service, are self-scheduled into Financial Transmission Rights, which shall be modeled as fixed injections and withdrawals in the long-term Financial Transmission Rights auction. Additionally, residual annual Auction Revenue Rights that become available through incremental capability created by future transmission upgrades as further described in the PJM Manuals shall be modeled as fixed injections and withdrawals in the long-term Financial Transmission Rights auction. The long-term Financial Transmission Rights auction model shall include all upgrades planned to be placed into service on or before June 30th of the first Planning Period within the three year period covered by the auction. The transmission upgrades to be modeled for this purpose shall only include those upgrades that, individually, or together, have 10% or more impact on the transmission congestion on an individual constraint or constraints with congestion of \$5 million or more affecting a common congestion path. Transmission upgrades modeled for this purpose also will be modeled in the subsequent long-term Financial Transmission Rights auction, as further detailed in the PJM Manuals. Residual Auction Revenue Rights created by an increase in transmission capability due to future transmission upgrades, as specified above, are determined only for modeling purposes and will not be allocated to Market Participants.

7.1A.2 Frequency and Timing.

The long-term Financial Transmission Rights auction process shall consist of five rounds. The first round shall be conducted by the Office of the Interconnection approximately 11 months prior to the start of the three Planning Period term covered by the relevant long-term Financial Transmission Rights auction. The second round shall be conducted approximately 2 months

after the first round. The third round shall be conducted approximately 2 months after the second round. The fourth round shall be conducted approximately 2 months after the third round, and the fifth round shall be conducted approximately 3 months after the fourth round. In each round 20 percent of total capacity available in the long-term Financial Transmission Rights auction shall be offered for sale. Eligible entities may submit bids to purchase and offers to sell Financial Transmission Rights at the start of the bidding period in each round. The bidding period shall be three Business Days ending at 5:00 p.m. on the last day, subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e). PJM performs the Financial Transmission Rights auction clearing analysis for each round and posts the auction results on the market user interface within five Business Days after the close of the bidding period for each round unless circumstances beyond PJM's control prevent PJM from meeting the applicable deadline. Under such circumstances, PJM will post the auction results at the earliest possible opportunity. If the Office of the Interconnection discovers a potential error in the results posted for a long-term Financial Transmission Rights auction, the Office of the Interconnection shall notify Market Participants as soon as possible after it is found, but in no event later than 5:00 p.m. of the Business Day immediately following the initial publication of the results for that auction. After this initial notification, if the Office of the Interconnection determines it is necessary to post modified auction results, it shall provide notification of its intent to do so, along with a description detailing the cause and scope of the error, by no later than 5:00 p.m. of the second Business Day following the initial publication of prices for that auction. The provided description will not contain information that is market sensitive or confidential. Thereafter, the Office of the Interconnection must post the corrected prices by no later than 5:00 p.m. of the fourth calendar day following the initial publication of prices in the auction. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced auction results are under publicly noticed review by the FERC.

7.1A.3 Products.

(i) The periods covered by long-term Financial Transmission Rights auctions shall be any single Planning Period within the three Planning Period term covered by the relevant auction.

(ii) Weekend on-peak, weekday on-peak, off-peak and 24-hour Financial Transmission Rights, as those products are described in Tariff, Attachment K-Appendix, section 7.3.4, shall be offered in long-term Financial Transmission Rights auctions; Financial Transmission Rights options shall not be offered.

7.1A.4 Participation Eligibility.

(i) To participate in long-term Financial Transmission Rights auctions an entity shall be a PJM Member or a PJM Transmission Customer. Eligible entities may submit bids or offers in long-term Financial Transmission Rights auctions, provided they own Financial Transmission Rights offered for sale.

7.1A.5 Specified Receipt and Delivery Points.

The Office of the Interconnection will post a list of available receipt and delivery points for each long-term Financial Transmission Rights auction. Eligible receipt and delivery points in long-term Financial Transmission Rights auctions shall be limited to the posted available hubs, Zones, aggregates, generators, and Interface Pricing Points.

7.3 Auction Procedures.

7.3.1 Role of the Office of the Interconnection.

Financial Transmission Rights auctions shall be conducted by the Office of the Interconnection in accordance with standards and procedures set forth in the PJM Manuals, such standards and procedures to be consistent with the requirements of this Schedule. PJMSettlement shall be the Counterparty to the purchases and sales of Financial Transmission Rights arising from such auctions, provided however, that PJMSettlement shall not be a contracting party to any subsequent bilateral transfers of Financial Transmission Rights between Market Participants. The conversion of an Auction Revenue Right to a Financial Transmission Right pursuant to this section 7 shall not constitute a purchase or sale transaction to which PJMSettlement is a contracting party. Any Financial Transmission Rights auctions conducted to liquidate a defaulting Member's Financial Transmission Rights portfolio shall be conducted by the Office of the Interconnection in accordance with the procedures set forth in section 7.3.9 below, and as may be further described in the PJM Manuals.

7.3.2 Notice of Offer.

A holder of a Financial Transmission Right wishing to offer the Financial Transmission Right for sale shall notify the Office of the Interconnection of any Financial Transmission Rights to be offered. Each Financial Transmission Right sold in an auction shall, at the end of the period for which the Financial Transmission Rights were auctioned, revert to the offering holder or the entity to which the offering holder has transferred such Financial Transmission Right, subject to the term of the Financial Transmission Right itself and to the right of such holder or transferee to offer the Financial Transmission Right in the next or any subsequent auction during the term of the Financial Transmission Right.

7.3.3 Pending Applications for Firm Service.

(a) [Reserved.]

(b) Financial Transmission Rights may be assigned to entities requesting Network Transmission Service or Firm Point-to-Point Transmission Service pursuant to Operating Agreement, Schedule 1, section 5.2.2 (e), and the parallel provisions of Tariff, Attachment K-Appendix, section 5.2.2(e), only if such Financial Transmission Rights are simultaneously feasible with all outstanding Financial Transmission Rights, including Financial Transmission Rights effective for the then-current auction period. If an assignment of Financial Transmission Rights pursuant to a pending application for Network Transmission Service or Firm Point-to-Point Transmission Service cannot be completed prior to an auction, Financial Transmission Rights attributable to such transmission service shall not be assigned for the then-current auction period. If a Financial Transmission Right cannot be assigned for this reason, the applicant may withdraw its application, or request that the Financial Transmission Right be assigned effective with the start of the next auction period.

7.3.4 Weekend On-Peak, Weekday On-Peak, Off-Peak and 24-Hour Periods.

Weekend on-peak, weekday on-peak, off-peak and 24-hour Financial Transmission Rights will be offered in the annual, long-term, and monthly auctions. Weekend on-peak Financial Transmission Rights shall cover the periods from 7:00 a.m. up to the hour ending 11:00 p.m. on Saturdays, Sundays, and holidays as defined in the PJM Manuals. Weekday on-peak Financial Transmission Rights shall cover the periods from 7:00 a.m. up to the hour ending at 11:00 p.m. on Mondays through Fridays, except holidays as defined in the PJM Manuals. Off-Peak Financial Transmission Rights shall cover the periods from 11:00 p.m. up to the hour ending 7:00 a.m. on all days. The 24-hour period shall cover the period from hour ending 1:00 a.m. to the hour ending 12:00 midnight on all days. Each bid shall specify whether it is for a weekend on-peak, weekday on-peak, off-peak, or 24-hour period.

7.3.5 Offers and Bids.

(a) Offers to sell and bids to purchase Financial Transmission Rights shall be submitted during the period set forth in Operating Agreement, Schedule 1, section 7.1.2, and the parallel provisions of Tariff, Attachment K-Appendix, section 7.1.2, and shall be in the form specified by the Office of the Interconnection in accordance with the requirements set forth below.

(b) Offers to sell shall identify the specific Financial Transmission Right, by term, megawatt quantity and receipt and delivery points, offered for sale. An offer to sell a specified megawatt quantity of Financial Transmission Rights shall constitute an offer to sell a quantity of Financial Transmission Rights equal to or less than the specified quantity. An offer to sell may not specify a minimum quantity being offered. Each offer may specify a reservation price, below which the offeror does not wish to sell the Financial Transmission Right. Offers submitted by entities holding rights to Financial Transmission Rights shall be subject to such reasonable standards for the verification of the rights of the offeror as may be established by the Office of the Interconnection. Offers shall be subject to such reasonable standards for the creditworthiness of the offeror or for the posting of security for performance as the Office of the Interconnection shall establish.

(c) Bids to purchase shall specify the term, megawatt quantity, price per megawatt, and receipt and delivery points of the Financial Transmission Right that the bidder wishes to purchase. A bid to purchase a specified megawatt quantity of Financial Transmission Rights shall constitute a bid to purchase a quantity of Financial Transmission Rights equal to or less than the specified quantity. A bid to purchase may not specify a minimum quantity that the bidder wishes to purchase. A bid may specify receipt and delivery points in accordance with Operating Agreement, Schedule 1, section 7.2.2, and the parallel provisions of Tariff, Attachment K-Appendix, section 7.2.2, and may include Financial Transmission Rights for which the associated Transmission Congestion Credits may have negative values. Bids shall be subject to such reasonable standards for the creditworthiness of the bidder or for the posting of security for performance as the Office of the Interconnection shall establish.

(d) Bids and offers shall be specified to the nearest tenth of a megawatt and shall be greater than zero. The Office of the Interconnection may require that a market participant shall not submit in excess of 5000 bids and offers for any single monthly auction, or for any single round

of the annual auction, when the Office of the Interconnection determines that such limit is required to avoid or mitigate significant system performance problems related to bid/offer volume. Notice of the need to impose such limit shall be provided prior to the start of the bidding period if possible. Where such notice is provided after the start of the bidding period, market participants shall be required within one day to reduce their bids and offers for such auction below 5000, and the bidding period in such cases shall be extended by one day.

(e) In the event of extraordinary circumstances affecting the submission of bids within the bidding period in which the Office of the Interconnection determines it necessary to extend the bidding period, the Office of the Interconnection shall notify Market Participants as soon as possible of the new bidding period ending day and time.

7.3.6 Determination of Winning Bids and Clearing Price.

(a) At the close of each bidding period, the Office of the Interconnection will create a base Financial Transmission Rights power flow model that includes all outstanding Financial Transmission Rights that have been approved and confirmed for any portion of the month for which the auction was conducted and that were not offered for sale in the auction. The base Financial Transmission Rights model also will include estimated uncompensated parallel flows into each interface point of the PJM Region and estimated scheduled transmission outages.

(b) In accordance with the requirements of Operating Agreement, Schedule 1, section 7.5, and the parallel provisions of Tariff, Attachment K-Appendix, section 7.5, and subject to all applicable transmission constraints and reliability requirements, the Office of the Interconnection shall determine the simultaneous feasibility of all outstanding Financial Transmission Rights not offered for sale in the auction and of all Financial Transmission Rights that could be awarded in the auction for which bids were submitted. The winning bids shall be determined from an appropriate linear programming model that, while respecting transmission constraints and the maximum MW quantities of the bids and offers, selects the set of simultaneously feasible Financial Transmission Rights with the highest net total auction value as determined by the bids of buyers and taking into account the reservation prices of the sellers. In the event that there are two or more identical bids for the selected Financial Transmission Rights and there are insufficient Financial Transmission Rights to accommodate all of the identical bids, then each such bidder will receive a pro rata share of the Financial Transmission Rights that can be awarded.

(c) Financial Transmission Rights shall be sold at the market-clearing price for Financial Transmission Rights between specified pairs of receipt and delivery points, as determined by the bid value of the marginal Financial Transmission Right that could not be awarded because it would not be simultaneously feasible. The linear programming model shall determine the clearing prices of all Financial Transmission Rights paths based on the bid value of the marginal Financial Transmission Rights, which are those Financial Transmission Rights with the highest bid values that could not be awarded fully because they were not simultaneously feasible, and based on the flow sensitivities of each Financial Transmission Rights path relative to the marginal Financial Transmission Rights paths flow sensitivities on the binding transmission constraints. Financial Transmission Rights with a zero clearing price will only be awarded if

there is a minimum of one binding constraint in the auction period for which the Financial Transmission Rights path sensitivity is non-zero. Financial Transmission Right Options with a market-clearing price less than one dollar will not be awarded.

7.3.7 Announcement of Winners and Prices.

Within two (2) Business Days after the close of the bidding period for an annual Financial Transmission Rights auction round, and within five (5) Business Days after the close of the bidding period for a monthly Financial Transmission Rights auction, the Office of the Interconnection shall post the winning bidders, the megawatt quantity, the term and the receipt and delivery points for each Financial Transmission Right awarded in the auction and the price at which each Financial Transmission Right was awarded unless circumstances beyond PJM's control prevent PJM from meeting the applicable deadline. Under such circumstances, PJM will post the auction results at the earliest possible opportunity. The Office of the Interconnection shall not disclose the price specified in any bid to purchase or the reservation price specified in any offer to sell. If the Office of the Interconnection discovers an error in the results posted for a Financial Transmission Rights auction (or a given round of the annual Financial Transmission Rights auction), the Office of the Interconnection shall notify Market Participants of the error as soon as possible after it is found, but in no event later than 5:00 p.m. of the Business Day following the initial publication of the results of the auction or round of the annual auction. After this initial notification, if the Office of the Interconnection determines that it is necessary to post modified results, it shall provide notification of its intent to do so, together with all available supporting documentation, by no later than 5:00 p.m. of the second Business Day following the initial publication of the results of that auction or round of the annual auction. Thereafter, the Office of the Interconnection must post any corrected results by no later than 5:00 p.m. of the fourth calendar day following the initial publication of the results of the auction or round of the annual auction. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced auction results are under publicly noticed review by the FERC.

7.3.8 Auction Settlements.

All buyers and sellers of Financial Transmission Rights between the same points of receipt and delivery shall pay PJMSettlement or be paid by PJMSettlement the market-clearing price, as determined in the auction, for such Financial Transmission Rights.

For a Market Suspension where the suspension is greater than twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are no Day-Ahead Prices available for the affected Operating Day, the Financial Transmission Right auction costs would be zero in proportion to the number of hours of the Market Suspension in the Operating Day.

7.3.9 Addressing Defaulting Member's Financial Transmission Rights.

In the event a Member fails to meet creditworthiness requirements or make timely payments when due pursuant to the Operating Agreement or Tariff, the Office of the Interconnection shall,

as soon as practicable after declaring the Member to be in default as provided in Operating Agreement, section 15.1.5, use reasonable efforts to initiate within two applicable auctions the following procedures to settle, liquidate or otherwise resolve each Financial Transmission Rights position held by the defaulting Member:

a) The Office of the Interconnection shall unilaterally terminate all of the defaulting Member's rights with respect to forward Financial Transmission Rights positions as of the date of the Member's default.

b) As to each Financial Transmission Rights position held by the defaulting Member immediately prior to the termination of the defaulting Member's rights under subsection (a) above, the Office of the Interconnection shall determine and execute an appropriate course of action for addressing such Financial Transmission Rights position, based on the specific circumstances of the default as determined by the Office of the Interconnection in exercise of its reasonable judgment, such as (1) liquidating the position by offering it for sale in an upcoming applicable Financial Transmission Rights auction, (2) liquidating the position by offering it for sale in an auction called and scheduled for the specific purpose of liquidating one or more positions held by the defaulting Member ("Special Auction"), (3) allowing the position to go to settlement, or (4) another course of action the Office of the Interconnection determines to be appropriate under the circumstances that is designed to minimize potential losses to PJM Members. The Office of the Interconnection will provide reasonable advance notice to PJM Members of the approach or course of action it has determined to be appropriate prior to implementing that approach or course of action. The Office of the Interconnection is not required to apply a single approach to the defaulting Member's entire Financial Transmission Rights portfolio, and may determine that the appropriate course of action for addressing a defaulting Member's portfolio includes a combination of the above approaches as applied to different positions within the defaulting Member's overall Financial Transmission Rights portfolio.

c) The Office of the Interconnection will seek to minimize the losses to PJM Members associated with settling, liquidating or otherwise resolving the defaulting Member's Financial Transmission Rights portfolio and may base its determination in subsection (b) above on several factors, including but not limited to, the following:

- 1) the Office of the Interconnection's assessment of which approach will provide the greatest degree of protection to the financial integrity of the PJM Markets;
- 2) the size of the defaulting Member's Financial Transmission Rights portfolio, both in absolute terms and relative to overall market volume;
- 3) the term of the Financial Transmission Rights positions held by the defaulting Member as considered for a single position or on a portfolio basis;

- 4) whether liquidation is feasible or not, and on what timeline, due to the cessation or curtailment of trading at PJM for all Financial Transmission Rights or a subset of Financial Transmission Rights positions;
- 5) prevailing market conditions, such as but not limited to market liquidity and volatility; and
- 6) timing of the default and the actions taken to address the default.

d) Special Auctions. The Office of the Interconnection shall administer each Special Auction provided for in subsection (b)(2) above according to the procedures set forth in the Tariff and PJM Manuals for FTR auctions to the extent appropriate in the Office of the Interconnection's sole discretion, and may adopt special rules for each Special Auction to accommodate the unique circumstances underlying the particular default and particular Financial Transmission Rights positions being liquidated, with the terms and conditions of such auction being determined with the goal of facilitating a successful auction in light of the particular positions to be auctioned, the prevailing market conditions for such open positions (including the depth, scope, and nature of participation in such markets), and such other factors as the Office of the Interconnection determines appropriate, including those factors enumerated in subsection (c) above. The Office of the Interconnection shall provide reasonable advance notice to FTR Participants of a Special Auction and the terms and conditions under which it will be conducted.

e) All liquidations made pursuant to subsection (b) above shall be for the account of the defaulting Member (and all amounts owed PJM in respect thereof shall be included in amounts owed by the defaulting Member as part of its default).

f) Notwithstanding subsections 7.3.9(a) and (b) above, the actual net charges or credits resulting from the defaulting Member's Financial Transmission Rights positions for which PJM Settlement acted as counterparty as calculated through the normal settlement processes shall be included in calculating the Default Allocation Assessment charges as described in Operating Agreement, section 15.2.2.

ATTACHMENT Q

CREDIT RISK MANAGEMENT POLICY

I. INTRODUCTION

It is the policy of PJM that prior to an entity participating in any PJM Markets or in order to take Transmission Service, the entity must demonstrate its ability to meet the requirements in this Attachment Q. This Attachment Q also sets forth PJM's authority to deny, reject, or terminate a Participant's right to participate in any PJM Markets in order to protect the PJM Markets and PJM Members from unreasonable credit risk from any Participant's activities. Given the interconnectedness and overlapping of their responsibilities, PJM Interconnection, L.L.C. and PJM Settlement, Inc. are referred to both individually and collectively herein as "PJM."

PURPOSE

PJMSettlement is the counterparty to transactions in the PJM Markets. As a consequence, if a Participant defaults on its obligations under this Attachment Q, or PJM determines a Participant represents unreasonable credit risk to the PJM Markets, and the Participant does not post Collateral, additional Collateral or Restricted Collateral in response to a Collateral Call, the result is that the Participant represents unsecured credit risk to the PJM Markets. For this reason, PJM must have the authority to monitor and manage credit risk on an ongoing basis, and to act promptly to mitigate or reduce any unsecured credit risk, in order to protect the PJM Markets and PJM Members from losses.

This Attachment Q describes requirements for: (1) eligibility to be a Market Participant, (2) establishment and maintenance of credit by Market Participants, and (3) collateral requirements and forms of credit support that will be deemed as acceptable to mitigate risk to any PJM Markets.

This Attachment Q also sets forth (1) PJM's authority to monitor and manage credit risk that a Participant may represent to the PJM Markets and/or PJM membership in general, (2) the basis for establishing limits that will be imposed on a Market Participant in order to minimize risk, and (3) various obligations and requirements the violation of which will result in an Event of Default pursuant to this Attachment Q and the Agreements.

Attachment Q describes the types of data and information PJM will review in order to determine whether an Applicant or Market Participant presents an unreasonable risk to any PJM Markets and/or PJM membership in general, and the steps PJM may take in order to address that risk.

APPLICABILITY

This Attachment Q applies to all Applicants and Market Participants who take Transmission Service under this Tariff, or participate in any PJM Markets or market activities under the Agreements. Notwithstanding anything to the contrary in this Attachment Q, simply taking

transmission service or procuring Ancillary Services via market-based rates does not imply market participation for purposes of applicability of this Attachment Q.

II. RISK EVALUATION PROCESS

PJM will conduct a risk evaluation to determine eligibility to become and/or remain a Market Participant or Guarantor that: (1) assesses the entity's financial strength, risk profile, creditworthiness, and other relevant factors; (2) determines an Unsecured Credit Allowance, if appropriate; (3) determines appropriate levels of Collateral; and (4) evaluates any Credit Support, including Guaranties or Letters of Credit.

A. Initial Risk Evaluation

PJM will perform an initial risk evaluation of each Applicant and/or its Guarantor. As part of the initial risk evaluation, PJM will consider certain Minimum Participation Requirements, assign an Internal Risk Score, establish an Unsecured Credit Allowance if appropriate, and make a determination regarding required levels of Collateral, creditworthiness, credit support, Restricted Collateral and other assurances for participation in certain PJM Markets.

Each Applicant and/or its Guarantor must provide the information set forth below at the time of its initial application pursuant to this Attachment Q and on an ongoing basis in order to remain eligible to participate in any PJM Markets. The same quantitative and qualitative factors will be used to evaluate Participants whether or not they have rated debt.

1. Rating Agency Reports

PJM will review Rating Agency reports from Standard & Poor's, Moody's Investors Service, Fitch Ratings, or other Nationally Recognized Statistical Rating Organization for each Applicant and/or Guarantor. The review will focus on the Applicant's or its Guarantor's senior unsecured debt ratings. If senior unsecured debt ratings are not available, PJM may consider other ratings, including issuer ratings, corporate ratings and/or an implied rating based on an internally derived Internal Credit Score pursuant to section II.A.3 below.

2. Financial Statements and Related Information

Each Applicant and/or its Guarantor must submit, or cause to be submitted, audited financial statements, except as otherwise indicated below, prepared in accordance with United States Generally Accepted Accounting Principles ("US GAAP") or any other format acceptable to PJM for the three (3) fiscal years most recently ended, or the period of existence of the Applicant and/or its Guarantor, if shorter. Applicants and/or their Guarantors must submit, or cause to be submitted, financial statements, which may be unaudited, for each completed fiscal quarter of the current fiscal year. All audited financial statements provided by the Applicant and/or its Guarantor must be audited by an Independent Auditor.

The information should include, but not be limited to, the following:

- (a) If the Applicant and/or its Guarantor has publicly traded securities:
- (i) Annual reports on Form 10-K, together with any amendments thereto;
 - (ii) Quarterly reports on Form 10-Q, together with any amendments thereto;
 - (iii) Form 8-K reports, if any, that have been filed since the most recent Form 10-K;
 - (iv) A summary provided by the Principal responsible, or to be responsible, for PJM Market activity of: (1) the Participant's primary purpose(s) of activity or anticipated activity in the PJM Markets (investment, trading or "hedging or mitigating commercial risks," as such phrase has meaning in the CFTC's regulations regarding the end-user exception to clearing); (2) the experience of the Participant (and its Principals) in managing risks in similar markets, including other organized RTO/ISO markets or on regulated commodity exchanges; and (3) a high level overview of the Participant's intended participation in the PJM Markets.
 - (v) All audited financial statements provided by an Applicant with publicly traded securities and/or its Guarantor with publicly traded securities must be audited by an Independent Auditor that satisfies the requirements set forth in the Sarbanes-Oxley Act of 2002.
- (b) If the Applicant and/or its Guarantor does not have publicly-traded securities:
- (i) Annual Audited Financial Statements or equivalent independently audited financials, and quarterly financial statements, generally found on:
 - Balance Sheets
 - Income Statements
 - Statements of Cash Flows
 - Statements of Stockholder's or Member's Equity or Net Worth;
 - (ii) Notes to Annual Audited Financial Statements, and notes to quarterly financial statements if any, including disclosures of any material changes from the last report;
 - (iii) Disclosure equivalent to a Management's Discussion & Analysis, including an executive overview of operating results and outlook, and compliance with debt covenants and indentures, and off balance sheet arrangements, if any;
 - (iv) Auditor's Report with an unqualified opinion or written letter from auditor containing the opinion whether the annual audited financial statements comply with the US GAAP or any other format acceptable to PJM; and

- (v) A summary provided by the Principal responsible or to be responsible for PJM Market activity of: (1) the Participant's primary purpose(s) of activity or anticipated activity in the PJM Markets (investment, trading or "hedging or mitigating commercial risks," as such phrase has meaning in the CFTC's regulations regarding the end-user exception to clearing); (2) the experience of the Participant (and its Principals) in managing risks in similar markets, including other organized RTO/ISO markets or on regulated commodity exchanges; and (3) a high level overview of the Participant's intended participation in the PJM Markets.
- (c) If Applicant and/or Guarantor is newly formed, does not yet have three (3) years of audited financials, or does not routinely prepare audited financial statements, PJM may specify other information to allow it to assess the entity's creditworthiness, including but not limited to:
 - (i) Equivalent financial information traditionally found in:
 - Balance Sheets
 - Income Statements
 - Statements of Cash Flows
 - (ii) Disclosure equivalent to a Management's Discussion & Analysis, including an executive overview of operating results and outlook, and compliance with debt covenants and indentures, and off balance sheet arrangements, if any; and
 - (iii) A summary provided by the Principal responsible or to be responsible for PJM Market activity of: (1) the Participant's primary purpose(s) of activity or anticipated activity in the PJM Markets (investment, trading or "hedging or mitigating commercial risks," as such phrase has meaning in the CFTC's regulations regarding the end-user exception to clearing); (2) the experience of the Participant (and its Principals) in managing risks in similar markets, including other organized RTO/ISO markets or on regulated commodity exchanges; and (3) a high level overview of the Participant's intended participation in the PJM Markets.
- (d) During a two year transition period from June 1, 2020 to May 31, 2022, the Applicant or Guarantor may provide a combination of audited financial statements and/or equivalent financial information.

If any of the above information in this section II.A.2 is available on the internet, the Applicant and/or its Guarantor may provide a letter stating where such statements can be located and retrieved by PJM. If an Applicant and/or its Guarantor files Form 10-K, Form 10-Q, or Form 8-K with the SEC, then the Applicant and/or its Guarantor will be deemed to have satisfied the requirement by indicating to PJM where the information in this section II.A.2 can be located on the internet.

If the Applicant and/or its Guarantor fails, for any reason, to provide the information required above in this section II.A.2, PJM has the right to (1) request Collateral and/or Restricted Collateral to cover the amount of risk reasonably associated with the Applicant and/or its Guarantor's expected activity in any PJM Markets, and/or (2) restrict the Applicant from participating in certain PJM Markets, including but not limited to restricting the positions the Applicant (once it becomes a Market Participant) takes in the market.

For certain Applicants and/or their Guarantors, some of the above submittals may not be applicable and alternate requirements for compliant submittals may be specified by PJM. In the credit evaluation of Municipalities and Cooperatives, PJM may also request additional information as part of the initial and ongoing review process and will consider other qualitative factors in determining financial strength and creditworthiness.

3. Credit Rating and Internal Credit Score

PJM will use credit risk scoring methodologies as a tool in determining an Unsecured Credit Allowance for each Applicant and/or its Guarantor. As its source for calculating the Unsecured Credit Allowance, PJM will rely on the ratings from a Rating Agency, if any, on the Applicant's or Guarantor's senior unsecured debt or their issuer ratings or corporate ratings if senior unsecured debt ratings are not available. If there is a split rating between the Rating Agencies, the lower of the ratings shall apply. If no external credit rating is available PJM will utilize its Internal Credit Score in order to calculate the Unsecured Credit Allowance.

The model used to develop the Internal Credit Score will be quantitative, based on financial data found in the income statement, balance sheet, and cash flow statement, and it will be qualitative based on relevant factors that may be internal or external to a particular Applicant and/or its Guarantor.

PJM will employ a framework, as outlined in Tables 1-5 below, based on metrics internal to the Applicant and/or its Guarantor, including capital and leverage, cash flow coverage of fixed obligations, liquidity, profitability, and other qualitative factors. The particular metrics and scoring rules differ according to the Applicant's or Guarantor's line of business and the PJM Markets in which it anticipates participating, in order to account for varying sources and degrees of risk to the PJM Markets and PJM members.

The formulation of each metric will be consistently applied to all Applicants and Guarantors across industries with slight variations based on identifiable differences in entity type, anticipated market activity, and risks to the PJM Markets and PJM members. In instances where the external credit rating is used to calculate the unsecured credit allowance, PJM may also use the Internal Credit Score as an input into determining the overall risk profile of an Applicant and/or its Guarantor.

Table 1. Quantitative Metrics by Line of Business: Leverage and Capital Structure	Investor-Owned Utilities	Municipal Utilities	Co-Operative Utilities	Power Transmission	Merchant Power	Project Developers	Exploration & Production	Financial Institutions	Commodity Trading	Private Equity
Debt / Total Capitalization (%)										
FFO / Debt (%)										
Debt / EBITDA (x)										
Debt / Property, Plant & Equipment (%)										
Retained Earnings / Total Assets (%)										
Debt / Avg Daily Production or Kwh (\$)										
Tangible Net Worth (\$)										
Core Capital / Total Assets (%)										
Risk-Based Capital / RWA (%)										
Tier 1 Capital / RWA (%)										
Equity / Investments (%)										
Debt / Investments (%)										

primary metric **secondary metric**

FFO = Funds From Operations RWA = Risk-Weighted Assets

Table 2. Quantitative Metrics by Line of Business: Fixed Charge Coverage and Funding	Investor-Owned Utilities	Municipal Utilities	Co-Operative Utilities	Power Transmission	Merchant Power	Project Developers	Exploration & Production	Financial Institutions	Commodity Trading	Private Equity
EBIT / Interest Expense (x)										
EBITDA / Interest Expense (x)										
EBITDA / [Interest Exp + CPLTD] (x)										
[FFO + Interest Exp] / Interest Exp (x)										
Loans / Total Deposits (%)										
NPL / Gross Loans (%)										
NPL / [Net Worth + LLR] (%)										
Market Funding / Tangible Bank Assets (%)										

primary metric **secondary metric**

CPLTD = Current Portion of Long-Term Debt EBIT = Earnings Before Interest and Taxes EBITDA = Earnings Before Interest, Taxes, Depreciation and Amortization LLR = Loan Loss Reserves NPL = Non-Performing Loans

Table 3. Quantitative Metrics by Line of Business: Liquidity	Investor- Owned	Municipal Utilities	Co- Operative	Power Transmission Merchant Power	Project Developers	Exploration & Production	Financial Institutions	Commodity Trading	Private Equity
CFFO / Total Debt (x)									
Current Assets / Current Liabilities (x)									
Liquid Assets / Tangible Bank Assets (%)									
Sources / Uses of Funds (x)									
Weighted Avg Maturity of Debt (yrs)									
Floating Rate Debt / Total Debt (%)									

primary metric secondary metric

CFFO = Cash Flow From Operations

Table 4. Quantitative Metrics by Line of Business: Profitability	Investor- Owned	Municipal Utilities	Co- Operative	Power Transmission Merchant Power	Project Developers	Exploration & Production	Financial Institutions	Commodity Trading	Private Equity
Return on Assets (%)									
Return on Equity (%)									
Profit Volatility (%)									
Return on Revenue (%)									
Net Income / Tangible Assets (%)									
Net Profit (\$)									
Net Income / Dividends (x)									

primary metric secondary metric

Table 5. Qualitative Factors: Industry Level	Sample Referenc e Metrics	Investor-Owned Utilities	Municipal Utilities	Co-Operative Utilities	Power Transmission	Merchant Power	Project Developers	Exploration & Production	Financial Institutions	Commodity Trading	Private Equity

Need for PJM Markets to Achieve Business Goals	Rating Agency criteria or other industry analysis	High	High	High	High	Med	Low	Med	Low	Low	N/A
Ability to Grow/Enter Markets other than PJM	Rating Agency criteria or other industry analysis	Very Low	Very Low	Very Low	Very Low	High	High	Med	Med	High	N/A
Other Participants' Ability to Serve Customers	Rating Agency criteria or other industry analysis	Low	Low	Low	Low	Low	Med	Low	Low	High	N/A
Regulation of Participant's Business	RRA regulatory climate scores, S&P BICRA	PUCS	Govt	N/A	FERC PUCS	N/A	N/A	N/A	N/A	N/A	N/A
Primary Purpose of PJM Activity	Investment ("Inv.)/ Trading ("Trade")/ Hedging or Mitigating Commercial Risk of Operations ("CRH")	CRH	CRH	CRH	CRH/Trade	CRH/Trade	CRH/Trade	CRH/Trade	Inv./Trade	Inv./Trade	Inv./Trade

RRA = Regulatory Research Associates, a division of S&P Global, Inc. BICRA = Bank Industry Country Risk Assessment

The scores developed will range from 1-6, with the following mappings:

- 1 = Very Low Risk (S&P/Fitch: AAA to AA-; Moody's: Aaa to Aa3)
- 2 = Low Risk (S&P/Fitch: A+ to BBB+; Moody's: A1 to Baa1)
- 3 = Low to Medium Risk (S&P/Fitch: BBB; Moody's: Baa2)
- 4 = Medium Risk (S&P/Fitch: BBB-; Moody's: Baa3)
- 5 = Medium to High Risk (S&P/Fitch: BB+ to BB; Moody's Ba1 to Ba2)
- 6 = High Risk (S&P/Fitch: BB- and below; Moody's: Ba3 and below)

4. Trade References

If deemed necessary by PJM, whether because the Applicant is newly or recently formed or for any other reason, each Applicant and/or its Guarantor shall provide at least one (1) bank reference and three (3) Trade References to provide PJM with evidence of Applicant's understanding of the markets in which the Applicant is seeking to participate and the Applicant's experience and ability to manage risk. PJM may contact the bank references and Trade References provided by the Applicant to verify their business experience with the Applicant.

5. Litigation and Contingencies

Unless prohibited by law, each Applicant and Guarantor is also required to disclose and provide information as to the occurrence of, within the five (5) years prior to the submission of the information to PJM (i) any litigation, arbitration, investigation (formal inquiry initiated by a governmental or regulatory entity), or proceeding, pending or, to the knowledge of the involving, Applicant or its Guarantor or any of their Principals that would likely have a material adverse impact on its financial condition and/or would likely materially affect the risk of non-payment by the Applicant or Guarantor, or (ii) any finding of material defalcation, market manipulation or fraud by or involving the Applicant, Guarantor, or any of their Principals, predecessors, subsidiaries, or Credit Affiliates that participate in any United States power markets based upon a final adjudication of regulatory and/or legal proceedings, (iii) any bankruptcy declarations or petitions by or against an Applicant and/or Guarantor, or (iv) any violation by any of the foregoing of any federal or state regulations or laws regarding energy commodities, U.S. Commodity Futures Trading Commission ("CFTC") or FERC requirements, the rules of any exchange monitored by the National Futures Association, any self-regulatory organization or any other governing, regulatory, or standards body responsible for regulating activity in North American markets for electricity, natural gas or electricity-related commodity products. Each Applicant and Guarantor shall take reasonable measures to obtain permission to disclose information related to a non-public investigation. These disclosures shall be made by Applicant and Guarantor upon application, and within ten (10) Business Days of any material change with respect to any of the above matters.

6. History of Defaults in Energy Projects

Each Applicant and Guarantor shall disclose their current default status and default history for any energy related generation or transmission project (e.g. generation, solar, development), and within any wholesale or retail energy market, including but not limited to within PJM, any Independent System Operator or Regional Transmission Organization, and exchange that has not been cured within the past five (5) years. Defaults of a non-recourse project financed entity may not be included in the default history.

7. Other Disclosures and Additional Information

Each Applicant and Guarantor is required to disclose any Credit Affiliates that are currently Members of PJM, applying for membership with PJM, Transmission Customers, Participants, applying to become Market Participants, or that participate directly or indirectly in any PJM Markets or any other North American markets for electricity, natural gas or electricity-related commodity products. Each Applicant and Guarantor shall also provide a copy of its limited

liability company agreement or equivalent agreement, certification of formation, articles of incorporation or other similar organization document, offering memo or equivalent, the names of its five (5) most senior Principals, and information pertaining to any non-compliance with debt covenants and indentures.

Applicants shall provide PJM the credit application referenced in section III.A and any other information or documentation reasonably required for PJM to perform the initial risk evaluation of Applicant's or Guarantor's creditworthiness and ability to comply with the requirements contained in the Agreements related to settlements, billing, credit requirements, and other financial matters.

B. Supplemental Risk Evaluation Process

As described in section VI below, PJM will conduct a supplemental risk evaluation process for Applicants, Participants, and Guarantors applying to conduct virtual and export transactions or participate in any PJM Markets.

C. Unsecured Credit Allowance

A Market Participant may request that PJM consider it for an Unsecured Credit Allowance pursuant to the provisions herein. Notwithstanding the foregoing, an FTR Participant shall not be considered for an Unsecured Credit Allowance for participation in the FTR markets.

1. Unsecured Credit Allowance Evaluation

PJM will perform a credit evaluation on each Participant that has requested an Unsecured Credit Allowance, both initially and at least annually thereafter. PJM shall determine the amount of Unsecured Credit Allowance, if any, that can be provided to the Market Participant in accordance with the creditworthiness and other requirements set forth in this Attachment Q. In completing the credit evaluation, PJM will consider:

(a) Rating Agency Reports

PJM will review Rating Agency reports as for each Market Participant on the same basis as described in section II.A.1 above and section II.E.1 below.

(b) Financial Statements and Related Information

All financial statements and related information considered for an Unsecured Credit Allowance must satisfy all of the same requirements described in section II.A.2 above and section II.E.2 below.

2. Material Adverse Changes

Each Market Participant is responsible for informing PJM, in writing, of any Material Adverse Change in its financial condition (or the financial condition of its Guarantor) since the date of the Market Participant or Guarantor's most recent annual financial statements provided to PJM, pursuant to the requirements reflected in section II.A.2 above and section II.E.3 below.

In the event that PJM determines that a Material Adverse Change in the financial condition of a Market Participant warrants a requirement to provide Collateral, additional Collateral or Restricted Collateral, PJM shall comply with the process and requirements described in section II.A above and section II.E below.

3. Other Disclosures

Each Market Participant desiring an Unsecured Credit Allowance is required to make the disclosures and upon the same requirements reflected in section II.A.7 above and section II.E.7 below.

D. Determination of Unreasonable Credit Risk

Unreasonable credit risk shall be determined by the likelihood that an Applicant will default on a financial obligation arising from its participation in any PJM Markets. Indicators of potentially unreasonable credit risk include, but are not limited to, a history of market manipulation based upon a final adjudication of regulatory and/or legal proceedings, a history of financial defaults, a history of bankruptcy or insolvency within the past five (5) years, or a combination of current market and financial risk factors such as low capitalization, a reasonably likely future material financial liability, a low Internal Credit Score (derived pursuant to section II.A.3 above) and/or a low externally derived credit score. PJM's determination will be based on, but not limited to, information and material provided to PJM during its initial risk evaluation process, information and material provided to PJM in the Officer's Certification, and/or information gleaned by PJM from public and non-public sources.

If PJM determines that an Applicant poses an unreasonable credit risk to the PJM Markets, PJM may require Collateral, additional Collateral, or Restricted Collateral commensurate with the Applicant's risk of financial default, reject an application, and/or limit or deny Applicant's participation in the PJM Markets, to the extent and for the time period it determines is necessary to mitigate the unreasonable credit risk to the PJM Markets. PJM will reject an application if it determines that Collateral, additional Collateral, or Restricted Collateral cannot address the risk.

PJM will communicate its concerns regarding whether the Applicant presents an unreasonable credit risk, if any, in writing to the Applicant and attempt to better understand the circumstances surrounding that Applicant's financial and credit position before making its determination. In the event PJM determines that an Applicant presents an unreasonable credit risk that warrants a requirement to provide Collateral of any type, or some action to mitigate risk, PJM shall provide the Applicant with a written explanation of why such determination was made.

E. Ongoing Risk Evaluation

In addition to the initial risk evaluation set forth in sections II.A through II.D above and the annual certification requirements set forth in section III.A below, each Market Participant and/or its Guarantor has an ongoing obligation to provide PJM with the information required in section IV.A described in more detail below. PJM may also review public information regarding a

Market Participant and/or its Guarantor as part of its ongoing risk evaluation. If appropriate, PJM will revise the Market Participant's Unsecured Credit Allowance and/or change its determination of creditworthiness, credit support, Restricted Collateral, required Collateral or other assurances pursuant to PJM's ongoing risk evaluation process.

Each Market Participant and/or its Guarantor must provide the information set forth below on an ongoing basis in order to remain eligible to participate in any PJM Markets. The same quantitative and qualitative factors will be used to evaluate Market Participants whether or not they have rated debt.

1. Rating Agency Reports

PJM will review Rating Agency reports for each Market Participant and/or Guarantor on the same basis as described in section II.A.1 above.

2. Financial Statements and Related Information

On an ongoing basis, Market Participants and/or their Guarantors shall provide the information they are required to provide as described in section II.A.2 above, pursuant to the schedule reflected below, with one exception. With regard to the summary that is required to be provided by the Principal responsible for PJM Market activity, with respect to experience of the Participant or its Principals in managing risks in similar markets, the Principal only needs to provide that information for a new Principal that was not serving in the position when the prior summary was provided. PJM will review financial statements and related information for each Market Participant and/or Guarantor on the same basis as described in section II.A.2 above.

Each Market Participant and/or its Guarantor must submit, or cause to be submitted, annual audited financial statements, except as otherwise indicated below, prepared in accordance with US GAAP or any other format acceptable to PJM for the fiscal year most recently ended within ten (10) calendar days of the financial statements becoming available and no later than one hundred twenty (120) calendar days after its fiscal year end. Market Participants and/or their Guarantors must submit, or cause to be submitted, financial statements, which may be unaudited, for each completed fiscal quarter of the current fiscal year, promptly upon their issuance, but no later than sixty (60) calendar days after the end of each fiscal quarter. All audited financial statements provided by the Market Participant and/or its Guarantor must be audited by an Independent Auditor.

Notwithstanding the foregoing, PJM may upon request, grant a Market Participant or Guarantor an extension of time, if the financials are not available within the time frame stated above.

3. Material Adverse Changes

Each Market Participant and each Guarantor is responsible for informing PJM, in writing, of any Material Adverse Change in its or its Guarantor's financial condition within five (5) Business Days of any Principal becoming aware of the occurrence of a Material Adverse Change since the date of the Market Participant or Guarantor's most recent annual financial statements provided to

PJM. However, PJM may also independently establish from available information that a Participant and/or its Guarantor has experienced a Material Adverse Change in its financial condition without regard to whether such Market Participant or Guarantor has informed PJM of the same.

For the purposes of this Attachment Q, a Material Adverse Change in financial condition may include, but is not be limited to, any of the following:

- (a) a bankruptcy filing;
- (b) insolvency;
- (c) a significant decrease in market capitalization;
- (d) restatement of prior financial statements unless required due to regulatory changes;
- (e) the resignation or removal of a Principal unless there is a new Principal appointed or expected to be appointed, a transition plan in place pending the appointment of a new Principal, or a planned restructuring of such roles;
- (f) the filing of a lawsuit or initiation of an arbitration, investigation, or other proceeding that would likely have a material adverse effect on any current or future financial results or financial condition or increase the likelihood of non-payment;
- (g) a material financial default in any other organized energy, ancillary service, financial transmission rights and/or capacity markets including but not limited to those of another Regional Transmission Organization or Independent System Operator, or on any commodity exchange, futures exchange or clearing house, that has not been cured or remedied after any required notice has been given and any cure period has elapsed;
- (h) a revocation of a license or other authority by any Federal or State regulatory agency; where such license or authority is necessary or important to the Participant's continued business, for example, FERC market-based rate authority, or State license to serve retail load;
- (i) a significant change in credit default swap spreads, market capitalization, or other market-based risk measurement criteria, such as a recent increase in Moody's KMV Expected Default Frequency (EDFtm) that is materially greater than the increase in its peers' EDFtm rates, or a collateral default swap (CDS) premium normally associated with an entity rated lower than investment grade;
- (j) a confirmed, undisputed material financial default in a bilateral arrangement with another Participant or counterparty that has not been cured or remedied after any required notice has been given and any cure period has elapsed;
- (k) the sale by a Participant of all or substantially all of its bilateral position(s) in the PJM Markets;
- (l) any adverse changes in financial condition which, individually, or in the aggregate, are material; and,
- (m) any adverse changes, events or occurrences which, individually or in the aggregate, could affect the ability of the entity to pay its debts as they become due or could reasonably be expected to have a material adverse effect on any current or future financial results or financial condition.

Upon identification of a Material Adverse Change, PJM shall evaluate the financial strength and risk profile of the Market Participant and/or its Guarantor at that time and may do so on a more frequent basis going forward. If the result of such evaluation identifies unreasonable credit risk to any PJM Market as further described in section II.E.8 below, PJM will take steps to mitigate the financial exposure to the PJM Markets. These steps include, but are not limited to requiring the Market Participant and/or each Guarantor to provide Collateral, additional Collateral or additional Restricted Collateral that is commensurate with the amount of risk in which the Market Participant wants to engage, and/or limiting the Market Participant's ability to participate in any PJM Market to the extent, and for the time-period necessary to mitigate the unreasonable credit risk. In the event PJM determines that a Material Adverse Change in the financial condition or risk profile of a Market Participant and/or Guarantor, warrants a requirement to provide Collateral of any type, or some action to mitigate risk, PJM shall provide the Market Participant and/or Guarantor, a written explanation of why such determination was made. Conversely, in the event PJM determines there has been an improvement in the financial condition or risk profile of a Market Participant and/or Guarantor such that the amount of Collateral needed for that Market Participant and/or Guarantor can be reduced, PJM shall provide a written explanation why such determination was made, including the amount of the Collateral reduction and indicating when and how the reduction will be made.

4. Litigation and Contingencies

Each Market Participant and/or Guarantor is required to disclose and provide information regarding litigation and contingencies as outlined in section II.A.5 above.

5. History of Defaults in Energy Projects

Each Market Participant and/or Guarantor is required to disclose current default status and default history as outlined in section II.A.6 above.

6. Internal Credit Score

As part of its ongoing risk evaluation, PJM will use credit risk scoring methodologies as a tool in determining an Internal Credit Score for each Market Participant and/or Guarantor, utilizing the same model and framework outlined in section II.A.3 above.

7. Other Disclosures and Additional Information

Each Market Participant and/or Guarantor is required to make other disclosures and provide additional information outlined in section II.A.7 above.

PJM will monitor each Market Participant's use of services and associated financial obligations on a regular basis to determine their total potential financial exposure and for credit monitoring purposes, and may require the Market Participant and/or Guarantor to provide additional information, pursuant to the terms and provisions described herein.

Market Participants shall provide PJM, upon request, any information or documentation reasonably required for PJM to monitor and evaluate a Market Participant's creditworthiness and compliance with the Agreements related to settlements, billing, credit requirements, and other financial matters.

8. Unreasonable Credit Risk

If PJM has reasonable grounds to believe that a Market Participant and/or its Guarantor poses an unreasonable credit risk to any PJM Markets, PJM may immediately notify the Market Participant of such unreasonable credit risk and (1) issue a Collateral Call to demand Collateral, additional Collateral, or Restricted Collateral or other assurances commensurate with the Market Participant's and/or its Guarantor's risk of financial default or other risk posed by the Market Participant's or Guarantor's financial condition or risk profile to the PJM Markets and PJM members, or (2) limit or suspend the Market Participant's participation in any PJM Markets, to the extent and for such time period PJM determines is necessary to mitigate the unreasonable credit risk to any PJM Markets. PJM will only limit or suspend a Market Participant's market participation if Collateral, additional Collateral or Restricted Collateral cannot address the unreasonable credit risk.

PJM's determination will be based on, but not limited to, information and material provided to PJM during its ongoing risk evaluation process or in the Officer's Certification, and/or information gleaned by PJM from public and non-public sources. PJM will communicate its concerns, if any, in writing to the Market Participant and attempt to better understand the circumstances surrounding the Market Participant's financial and credit position before making its determination. At PJM's request or upon its own initiative, the Market Participant or its Guarantor may provide supplemental information to PJM that would allow PJM to consider reducing the additional Collateral requested or reducing the severity of limitations or other restrictions designed to mitigate the Market Participant's credit risk. Such information shall include, but not be limited to: (i) the Market Participant's estimated exposure, (ii) explanations for any recent change in the Market Participant's market activity, (iii) any relevant new load or unit outage information; or (iv) any default or supply contract expiration, termination or suspension.

The Market Participant shall have five (5) Business Days to respond to PJM's request for supplemental information. If the requested information is provided in full to PJM's satisfaction during said period, the additional Collateral requirement shall reflect the Market Participant's anticipated exposure based on the information provided. Notwithstanding the foregoing, any additional Collateral requested by PJM in a Collateral Call must be provided by the Market Participant within the applicable cure period.

In the event PJM determines that an Market Participant and/or its Guarantor presents an unreasonable credit risk, as described above, that warrants a requirement to provide Collateral of any type, or some action to mitigate risk, PJM shall provide the Market Participant with a written explanation of why such final determination was made.

PJM has the right at any time to modify any Unsecured Credit Allowance and/or require additional Collateral as may be deemed reasonably necessary to support current or anticipated market activity as set forth in Tariff, Attachment Q, sections II.A.2 and II.C.1.b. Failure to remit the required amount of additional Collateral within the applicable cure period shall constitute an Event of Default.

F. Collateral and Credit Restrictions

PJM may establish certain restrictions on available credit by requiring that some amounts of credit, i.e. Restricted Collateral, may not be available to satisfy credit requirements. Such designations shall be construed to be applicable to the calculation of credit requirements only, and shall not restrict PJM's ability to apply such designated credit to any obligation(s) in case of a default. Any such Restricted Collateral will be held by PJM, as applicable. Such Restricted Collateral will not be returned to the Participant until PJM has determined that the risk for which such Restricted Collateral is being held has subsided or been resolved.

PJM may post on PJM's web site, and may reference on OASIS, a supplementary document which contains additional business practices (such as algorithms for credit scoring) that are not included in this Attachment Q. Changes to the supplementary document will be subject to stakeholder review and comment prior to implementation. PJM may specify a required compliance date, not less than fifteen (15) calendar days from notification, by which time all Participants and their Guarantors must comply with provisions that have been revised in the supplementary document.

PJM will regularly post each Participant's and/or its Guarantor's credit requirements and credit provisions on the PJM web site in a secure, password-protected location. Each Participant and/or its Guarantor is responsible for monitoring such information, and maintaining sufficient credit to satisfy the credit requirements described herein. Failure to maintain credit sufficient to satisfy the credit requirements of the Attachment Q shall constitute a Credit Breach, and the Participant will be subject to the remedies established herein and in any of the Agreements.

G. Unsecured Credit Allowance Calculation

The external rating from a Rating Agency will be used as the source for calculating the Unsecured Credit Allowance, unless no external credit rating is available in which case PJM will utilize its Internal Credit Score for such purposes. If there is a split rating between the Rating Agencies, the lower of the ratings shall apply.

Where two or more entities, including Participants, are considered Credit Affiliates, Unsecured Credit Allowances will be established for each individual Participant, subject to an aggregate maximum amount for all Credit Affiliates as provided for in Attachment Q, section II.G.3.

In its credit evaluation of Municipalities and Cooperatives, PJM may request additional information as part of the ongoing risk evaluation process and will also consider qualitative factors in determining financial strength and creditworthiness.

1. Credit Rating and Internal Credit Score

As previously described in section II.A.3 above, PJM will determine the Internal Credit Score for an Applicant, Market Participant and/or its Guarantor using the credit risk scoring methodologies contained therein. Internal Credit Scores, ranging from 1-6, for each Applicant, Market Participant and/or its Guarantor, will be determined with the following mappings:

- 1 = Very Low Risk (S&P/Fitch: AAA to AA-; Moody's: Aaa to Aa3)
- 2 = Low Risk (S&P/Fitch: A+ to BBB+; Moody's: A1 to Baa1)
- 3 = Low to Medium Risk (S&P/Fitch: BBB; Moody's: Baa2)
- 4 = Medium Risk (S&P/Fitch: BBB-; Moody's: Baa3)
- 5 = Medium to High Risk (S&P/Fitch: BB+ to BB; Moody's Ba1 to Ba2)
- 6 = High Risk (S&P/Fitch: BB- and below; Moody's: Ba3 and below)

In instances where the external credit rating is used to calculate the unsecured credit allowance, PJM may also use the Internal Credit Score as an input into its determination of the overall risk profile of an Applicant and/or its Guarantor

2. Unsecured Credit Allowance

PJM will determine a Participant's Unsecured Credit Allowance based on its external rating or its Internal Credit Score, as applicable, and the parameters in the table below. The maximum Unsecured Credit Allowance is the lower of:

- (a) A percentage of the Participant's Tangible Net Worth, as stated in the table below, with the percentage based on the Participant's external rating or Internal Credit Score, as applicable; and
- (b) A dollar cap based on the external rating or Internal Credit Score, as applicable, as stated in the table below:

Internal Credit Score	Risk Ranking	Tangible Net Worth Factor	Maximum Unsecured Credit Allowance (\$ Million)
1.00 – 1.99	1 – Very Low (AAA to AA-)	Up to 10.00%	\$50
2.00 – 2.99	2 – Low (A+ to BBB+)	Up to 8.00%	\$42
3.00 – 3.49	3 – Low to Medium (BBB)	Up to 6.00%	\$33
3.50 – 4.49	4 – Medium (BBB-)	Up to 5.00%	\$7
4.50 – 5.49	5 – Medium to High (BB+ to BB)	0%	\$0
> 5.49	6 – High (BB- and below)	0%	\$0

If a Corporate Guaranty is utilized to establish an Unsecured Credit Allowance for a Participant, the value of a Corporate Guaranty will be the lesser of:

- (a) The limit imposed in the Corporate Guaranty;
- (b) The Unsecured Credit Allowance calculated for the Guarantor; and
- (c) A portion of the Unsecured Credit Allowance calculated for the Guarantor in the case of Credit Affiliates.

PJM has the right at any time to modify any Unsecured Credit Allowance and/or require additional Collateral as may be deemed reasonably necessary to support current market activity. Failure to remit the required amount of additional Collateral within the applicable cure period shall be deemed an Event of Default.

PJM will maintain a posting of each Participant's Unsecured Credit Allowance, along with certain other credit related parameters, on the PJM website in a secure, password-protected location. Each Participant will be responsible for monitoring such information and recognizing changes that may occur.

3. Unsecured Credit Limits For Credit Affiliates

If two or more Participants are Credit Affiliates and have requested an Unsecured Credit Allowance, PJM will consider the overall creditworthiness of the Credit Affiliates when determining the Unsecured Credit Allowances in order not to establish more Unsecured Credit for the Credit Affiliates collectively than the overall corporate family could support.

Example: Participants A and B each have a \$10.0 million Corporate Guaranty from their common parent, a holding company with an Unsecured Credit Allowance calculation of \$12.0 million. PJM may limit the Unsecured Credit Allowance for each Participant to \$6.0 million, so the total Unsecured Credit Allowance does not exceed the corporate family total of \$12.0 million.

PJM will work with the Credit Affiliates to allocate the total Unsecured Credit Allowance among the Credit Affiliates while assuring that no individual Participant, nor common guarantor, exceeds the Unsecured Credit Allowance appropriate for its credit strength. The aggregate Unsecured Credit for a Participant, including Unsecured Credit Allowance granted based on its own creditworthiness and risk profile, and any Unsecured Credit Allowance conveyed through a Guaranty shall not exceed \$50 million. The aggregate Unsecured Credit for a Credit Affiliates corporate family shall not exceed \$50 million. A Credit Affiliate corporate family subject to this cap shall request PJM to allocate the maximum Unsecured Credit amongst the corporate family, assuring that no individual Participant or common guarantor, shall exceed the Unsecured Credit level appropriate for its credit strength and activity.

H. Contesting an Unsecured Credit Evaluation

PJM will provide to a Participant, upon request, a written explanation for any determination of or change in Unsecured Credit or credit requirement within ten (10) Business Days of receiving such request.

If a Participant believes that either its level of Unsecured Credit or its credit requirement has been incorrectly determined, according to this Attachment Q, then the Participant may send a request for reconsideration in writing to PJM. Such a request should include:

- (1) A citation to the applicable section(s) of this Attachment Q along with an explanation of how the respective provisions of this Attachment Q were not carried out in the determination as made; and
- (2) A calculation of what the Participant believes should be the appropriate Unsecured Credit or Collateral requirement, according to terms of this Attachment Q.

PJM will provide a written response as promptly as practical, but no more than ten (10) Business Days after receipt of the request. If the Participant still feels that the determination is incorrect, then the Participant may contest that determination. Such contest should be in written form, addressed to PJM, and should contain:

- (1) A complete copy of the Participant's earlier request for reconsideration, including citations and calculations;
- (2) A copy of PJM's written response to its request for reconsideration; and
- (3) An explanation of why it believes that the determination still does not comply with this Attachment Q.

PJM will investigate and will respond to the Participant with a final determination on the matter as promptly as practical, but no more than twenty (20) Business Days after receipt of the request.

Neither requesting reconsideration nor contesting the determination following such request shall relieve or delay Participant's responsibility to comply with all provisions of this Attachment Q, including without limitation posting Collateral, additional Collateral or Restricted Collateral in response to a Collateral Call.

If a Corporate Guaranty is being utilized to establish credit for a Participant, the Guarantor will be evaluated and the Unsecured Credit Allowance granted, if any, based on the financial strength and creditworthiness, and risk profile of the Guarantor. Any utilization of a Corporate Guaranty will only be applicable to non-FTR credit requirements, and will not be applicable to cover FTR credit requirements.

PJM will identify any necessary Collateral requirements and establish a Working Credit Limit for each Participant. Any Unsecured Credit Allowance will only be applicable to non-FTR credit requirements, for positions in PJM Markets other than the FTR market, because all FTR credit requirements must be satisfied by posting Collateral.

III. MINIMUM PARTICIPATION REQUIREMENTS

A Participant seeking to participate in any PJM Markets shall submit to PJM any information or documentation reasonably required for PJM to evaluate its experience and resources. If PJM determines, based on its review of the relevant information and after consultation with the Participant, that the Participant's participation in any PJM Markets presents an unreasonable credit risk, PJM may reject the Participant's application to become a Market Participant, notwithstanding applicant's ability to meet other minimum participation criteria, registration requirements and creditworthiness requirements.

A. Annual Certification

Before they are eligible to transact in any PJM Market, all Applicants shall provide to PJM (i) an executed copy of a credit application and (ii) a copy of the annual certification set forth in Attachment Q, Appendix 1. As a condition to continued eligibility to transact in any PJM Market, Market Participants shall provide to PJM the annual certification set forth in Attachment Q, Appendix 1.

After the initial submission, the annual certification must be submitted each calendar year by all Market Participants between January 1 and April 30. PJM will accept such certifications as a matter of course and the Market Participants will not need further notice from PJM before commencing or maintaining their eligibility to participate in any PJM Markets.

A Market Participant that fails to provide its annual certification by April 30 shall be ineligible to transact in any PJM Markets and PJM will disable the Market Participant's access to any PJM Markets until such time as PJM receives the certification. In addition, failure to provide an executed annual certification in a form acceptable to PJM and by the specified deadlines may result in a default under the Tariff.

Market Participants acknowledge and understand that the annual certification constitutes a representation upon which PJM will rely. Such representation is additionally made under the Tariff, filed with and accepted by FERC, and any false, misleading or incomplete statement knowingly made by the Market Participant and that is material to the Market Participant's ability to perform may be considered a violation of the Tariff and subject the Market Participant to action by FERC. Failure to comply with any of the criteria or requirements listed herein or in the certification may result in suspension or limitation of a Market Participant's transaction rights in any PJM Markets.

Applicants and Market Participants shall submit to PJM, upon request, any information or documentation reasonably and/or legally required to confirm Applicant's or Market Participant's compliance with the Agreements and the annual certification.

B. PJM Market Participation Eligibility Requirements

PJM may conduct periodic verification to confirm that Applicants and Market Participants can demonstrate that they meet the definition of “appropriate person” to further ensure minimum criteria are in place. Such demonstration will consist of the submission of evidence and an executed Annual Officer Certification form as set forth in Attachment Q, Appendix 1 in a form acceptable to PJM. If an Applicant or Market Participant does not provide sufficient evidence for verification to PJM within five (5) Business Days of written request, then such Applicant or Market Participant may result in a default under this Tariff. Demonstration of “appropriate person” status and support of other certifications on the annual certification is one part of the Minimum Participation Requirements for any PJM Markets and does not obviate the need to meet the other Minimum Participation Requirements such as those for minimum capitalization and risk profile as set forth in this Attachment Q.

To be eligible to transact in any PJM Markets, an Applicant or Participant must demonstrate in accordance with the Risk Management and Verification processes set forth below that it qualifies in one of the following ways:

1. an “appropriate person,” as that term is defined under Commodity Exchange Act, section 4(c)(3), or successor provision, or;
2. an “eligible contract participant,” as that term is defined in Commodity Exchange Act, section 1a(18), or successor provision, or;
3. a business entity or person who is in the business of: (1) generating, transmitting, or distributing electric energy, or (2) providing electric energy services that are necessary to support the reliable operation of the transmission system, or;
4. an Applicant or Market Participant seeking eligibility as an “appropriate person” providing an unlimited Corporate Guaranty in a form acceptable to PJM as described in section V below from a Guarantor that has demonstrated it is an “appropriate person,” and has at least \$1 million of total net worth or \$5 million of total assets per Applicant and Market Participant for which the Guarantor has issued an unlimited Corporate Guaranty, or;
5. an Applicant or Market Participant providing a Letter of Credit of at least \$5 million to PJM in a form acceptable to PJM as described in section V below, that the Applicant or Market Participant acknowledges is separate from, and cannot be applied to meet, its credit requirements to PJM, or;
6. an Applicant or Market Participant providing a surety bond of at least \$5 million to PJM in a form acceptable to PJM as described in section V below, that the Applicant or Market Participant acknowledges is separate from, and cannot be applied to meet, its credit requirements to PJM.

If, at any time, a Market Participant cannot meet the eligibility requirements set forth above, it shall immediately notify PJM and immediately cease conducting transactions in any PJM Markets. PJM may terminate a Market Participant’s transaction rights in any PJM Markets if, at

any time, it becomes aware that the Market Participant does not meet the minimum eligibility requirements set forth above.

In the event that a Market Participant is no longer able to demonstrate it meets the minimum eligibility requirements set forth above, and possesses, obtains or has rights to possess or obtain, any open or forward positions in any PJM Markets, PJM may take any such action it deems necessary with respect to such open or forward positions, including, but not limited to, liquidation, transfer, assignment or sale; provided, however, that the Market Participant will, notwithstanding its ineligibility to participate in any PJM Markets, be entitled to any positive market value of those positions, net of any obligations due and owing to PJM.

C. Risk Management and Verification

All Market Participants must maintain current written risk management policies, procedures, or controls to address how market and credit risk is managed, and are required to submit to PJM (at the time they make their annual certification) a copy of their current governing risk control policies, procedures and controls applicable to their market activities. PJM will review such documentation to verify that it appears generally to conform to prudent risk management practices for entities participating in any PJM Markets.

All Market Participants subject to this provision shall make a one-time payment of \$1,500.00 to PJM to cover administrative costs. Thereafter, if such Participant's risk policies, procedures and controls applicable to its market activities change substantively, it shall submit such modified documentation, with applicable administrative charge determined by PJM, to PJM for review and verification at the time it makes its annual certification. All Market Participant's continued eligibility to participate in any PJM Markets is conditioned on PJM notifying a Participant that its annual certification, including the submission of its risk policies, procedures and controls, has been accepted by PJM. PJM may retain outside expertise to perform the review and verification function described in this section, however, in all circumstances, PJM and any third-party it may retain will treat as confidential the documentation provided by a Participant under this section, consistent with the applicable provisions of the Operating Agreement.

Participants must demonstrate that they have implemented prudent risk management policies and procedures in order to be eligible to participate in any PJM Markets. Participants must demonstrate on at least an annual basis that they have implemented and maintained prudent risk management policies and procedures in order to continue to participate in any PJM Markets. Upon written request, the Participant will have fourteen (14) calendar days to provide to PJM current governing risk management policies, procedures, or controls applicable to Participant's activities in any PJM Markets.

D. Capitalization

In advance of certification, Applicants shall meet the minimum capitalization requirements below. In addition to the annual certification requirements in Attachment Q, Appendix 1, a Market Participant shall satisfy the minimum capitalization requirements on an annual basis thereafter. A Participant must demonstrate that it meets the minimum financial requirements

appropriate for the PJM Markets in which it transacts by satisfying either the minimum capitalization or the provision of Collateral requirements listed below:

1. Minimum Capitalization

Minimum capitalization may be met by demonstrating minimum levels of Tangible Net Worth or tangible assets. FTR Participants must demonstrate a Tangible Net Worth in excess of \$1 million or tangible assets in excess of \$10 million. Other Market Participants must demonstrate a Tangible Net Worth in excess of \$500,000 or tangible assets in excess of \$5 million.

(a) Consideration of tangible assets and Tangible Net Worth shall exclude assets which PJM reasonably believes to be restricted, highly risky, or potentially unavailable to settle a claim in the event of default. Examples include, but are not limited to, restricted assets, derivative assets, goodwill, and other intangible assets.

(b) Demonstration of “tangible” assets and Tangible Net Worth may be satisfied through presentation of an acceptable Corporate Guaranty, provided that both:

- (i) the Guarantor is a Credit Affiliate company that satisfies the Tangible Net Worth or tangible assets requirements herein, and;
- (ii) the Corporate Guaranty is either unlimited or at least \$500,000.

If the Corporate Guaranty presented by the Participant to satisfy these capitalization requirements is limited in value, then the Participant’s resulting Unsecured Credit Allowance shall be the lesser of:

- (1) the applicable Unsecured Credit Allowance available to the Participant by the Corporate Guaranty pursuant to the creditworthiness provisions of this Attachment Q, or,
- (2) the face value of the Corporate Guaranty, reduced by \$500,000 and further reduced by 10%. (For example, a \$10.5 million Corporate Guaranty would be reduced first by \$500,000 to \$10 million and then further reduced 10% more to \$9 million. The resulting \$9 million would be the Participant’s Unsecured Credit Allowance available through the Corporate Guaranty).

In the event that a Participant provides Collateral in addition to a limited Corporate Guaranty to increase its available credit, the value of such Collateral shall be reduced by 10%. This reduced value shall be considered the amount available to satisfy requirements of this Attachment Q.

(c) Demonstrations of minimum capitalization (minimum Tangible Net Worth or tangible assets) must be presented in the form of audited financial statements for the Participant's most recent fiscal year during the initial risk evaluation process and ongoing risk evaluation process.

2. Provision of Collateral

If a Participant does not demonstrate compliance with its applicable minimum capitalization requirements above, it may still qualify to participate in any PJM Markets by posting Collateral, additional Collateral, and/or Restricted Collateral, subject to the terms and conditions set forth herein.

Any Collateral provided by a Participant unable to satisfy the minimum capitalization requirements above will also be restricted in the following manner:

- (a) Collateral provided by Market Participants that engage in FTR transactions shall be reduced by an amount of the current risk plus any future risk to any PJM Markets and PJM membership in general, and may coincide with limitations on market participation. The amount of this Restricted Collateral shall not be available to cover any credit requirements from market activity. The remaining value shall be considered the amount available to satisfy requirements of this Attachment Q.
- (b) Collateral provided by other Participants that engage in Virtual Transactions or Export Transactions shall be reduced by \$200,000 and then further reduced by 10%. The amount of this Restricted Collateral shall not be available to cover any credit requirements from market activity. The remaining value shall be considered the amount available to satisfy requirements of this Attachment Q.
- (c) Collateral provided by other Participants that do not engage in Virtual Transactions or Export Transactions shall be reduced by 10%. The amount of this Restricted Collateral shall not be available to cover any credit requirements from market activity. The remaining value shall be considered the amount available to satisfy requirements of this Attachment Q.

In the event a Participant that satisfies the minimum capital requirement through provision of Collateral also provides a Corporate Guaranty to increase its available credit, then the Participant's resulting Unsecured Credit Allowance conveyed through such Corporate Guaranty shall be the lesser of:

- (a) the applicable Unsecured Credit Allowance available to the Participant by the Corporate Guaranty pursuant to the creditworthiness provisions of this Attachment Q; or
- (b) the face value of the Corporate Guaranty, reduced commensurate with the amount of the current risk plus any anticipated future risk to any PJM Markets and PJM membership in general, and may coincide with limitations on market participation.

IV. ONGOING COVENANTS

A. Ongoing Obligation to Provide Information to PJM

So long as a Participant is eligible to participate, or participates or holds positions, in any PJM Markets, it shall deliver to PJM, in form and detail satisfactory to PJM:

- (1) All financial statements and other financial disclosures as required by section II.E.2 by the deadline set forth therein;
- (2) Notice, within five (5) Business Days, of any Principal becoming aware that the Participant does not meet the Minimum Participation Requirements set forth in section III;
- (3) Notice when any Principal becomes aware of any matter that has resulted or would reasonably be expected to result in a Material Adverse Change in the financial condition of the Participant or its Guarantor, if any, a description of such Material Adverse Change in detail reasonable to allow PJM to determine its potential effect on, or any change in, the Participant's risk profile as a participant in any PJM Markets, by the deadline set forth in section II.E.3 above;
- (4) Notice, within the deadline set forth therein, of any Principal becoming aware of a litigation or contingency event described in section II.E.4, or of a Material Adverse Change in any such litigation or contingency event previously disclosed to PJM, information in detail reasonable to allow PJM to determine its potential effect on, or any change in, the Market Participant's risk profile as a participant in any PJM Markets by the deadline set forth therein;
- (5) Notice, within two (2) Business Days after any Principal becomes aware of a Credit Breach, Financial Default, or Credit Support Default, that includes a description of such default or event and the Participant's proposals for addressing the default or event;
- (6) As soon as available but not later than April 30th of any calendar year, the annual Certification described in section III.A in a form set forth in Attachment Q, Appendix 1;
- (7) Concurrently with submission of the annual certification, demonstration that the Participant meets the minimum capitalization requirements set forth in section III.D;
- (8) Concurrently with submission of the annual certification and within the applicable deadline of any substantive change, or within the applicable deadline of a request from PJM, a copy of the Participant's written risk management policies, procedures or controls addressing how the Participant manages market and credit risk in the PJM Markets in which it participates, as well as a high level summary by the chief risk officer or other Principal regarding any material violations, breaches, or compliance or disciplinary actions related to the risk management policies, by the Participant under the policies, procedures or controls within the prior 12 months, as set forth in section VI.B below;
- (9) Within five (5) Business Days of request by PJM, evidence demonstrating the Participant meets the definition of "appropriate person" or "eligible contract participant," as those terms are defined in the Commodity Exchange Act and the CFTC regulations promulgated thereunder, or of any other certification in the annual Certification; or

- (10) Within a reasonable time after PJM requests, any other information or documentation reasonably and/or legally required by PJM to confirm Participant's compliance with the Tariff and its eligibility to participate in any PJM Markets.

Participants acknowledge and understand that the deliveries constitute representations upon which PJM will rely in allowing the Participant to continue to participate in its markets, with the Internal Credit Score and Unsecured Credit Allowance, if any, previously determined by PJM.

B. Risk Management Review

PJM shall also conduct a periodic compliance verification process to review and verify, as applicable, Participants' risk management policies, practices, and procedures pertaining to the Participant's activities in any PJM Markets. PJM shall review such documentation to verify that it appears generally to conform to prudent risk management practices for entities trading in any PJM Markets. Participant shall also provide a high level summary by the chief risk officer or other Principal regarding any material violations, breaches, or compliance or disciplinary actions in connection with such risk management policies, practices and procedures within the prior twelve (12) months.

If a third-party industry association publishes or modifies principles or best practices relating to risk management in North American markets for electricity, natural gas or electricity-related commodity products, PJM may, following stakeholder discussion and with no less than six (6) months prior notice to stakeholders, consider such principles or best practices in evaluating the Participant's risk controls.

PJM will prioritize the verification of risk management policies based on a number of criteria, including but not limited to how long the entity has been in business, the Participant's and its Principals' history of participation in any PJM Markets, and any other information obtained in determining the risk profile of the Participant.

Each Participant's continued eligibility to participate in any PJM Markets is conditioned upon PJM notifying the Participant of successful completion of PJM's verification of the Participant's risk management policies, practices and procedures, as discussed herein. However, if PJM notifies the Participant in writing that it could not successfully complete the verification process, PJM shall allow such Participant fourteen (14) calendar days to provide sufficient evidence for verification prior to declaring the Participant as ineligible to continue to participate in any PJM Markets, which declaration shall be in writing with an explanation of why PJM could not complete the verification. If the Participant does not provide sufficient evidence for verification to PJM within the required cure period, such Participant will be considered in default under this Tariff. PJM may retain outside expertise to perform the review and verification function described in this paragraph. PJM and any third party it may retain will treat as confidential the documentation provided by a Participant under this paragraph, consistent with the applicable provisions of the Agreements. If PJM retains such outside expertise, a Participant may direct in writing that PJM perform the risk management review and verification for such Participant instead of utilizing a third party, provided however, that employees and contract employees of PJM and PJM shall not be considered to be such outside expertise or third parties.

Participants are solely responsible for the positions they take and the obligations they assume in any PJM Markets. PJM hereby disclaims any and all responsibility to any Participant or PJM

Member associated with Participant's submitting or failure to submit its annual certification or PJM's review and verification of a Participant's risk policies, procedures and controls. Such review and verification is limited to demonstrating basic compliance by a Participant showing the existence of written policies, procedures and controls to limit its risk in any PJM Markets and does not constitute an endorsement of the efficacy of such policies, procedures or controls.

V. FORMS OF CREDIT SUPPORT

In order to satisfy their PJM credit requirements Participants may provide credit support in a PJM-approved form and amount pursuant to the guidelines herein, provided that, notwithstanding anything to the contrary in this section, a Market Participant in PJM's FTR markets shall meet its credit support requirements related to those FTR markets with either cash or Letters of Credit.

Unless otherwise restricted by PJM, credit support provided may be used by PJM to secure the payment of Participant's financial obligations under the Agreements.

Collateral which may no longer be required to be maintained under provisions of the Agreements, shall be returned at the request of a Participant, no later than two (2) Business Days following determination by PJM within a commercially reasonable period of time that such Collateral is not required.

Except when an Event of Default has occurred, a Participant may substitute an approved PJM form of Collateral for another PJM approved form of Collateral of equal value.

A. Cash Deposit

Cash provided by a Participant as Collateral will be held in a depository account by PJM. Interest shall accrue to the benefit of the Participant, provided that PJM may require Participants to provide appropriate tax and other information in order to accrue such interest credits.

PJM may establish an array of investment options among which a Participant may choose to invest its cash deposited as Collateral. The depository account shall be held in PJM's name in a banking or financial institution acceptable to PJM. Where practicable, PJM may establish a means for the Participant to communicate directly with the bank or financial institution to permit the Participant to direct certain activity in the PJM account in which its Collateral is held. PJM will establish and publish procedural rules, identifying the investment options and respective discounts in Collateral value that will be taken to reflect any liquidation, market and/or credit risk presented by such investments.

Cash Collateral may not be pledged or in any way encumbered or restricted from full and timely use by PJM in accordance with terms of the Agreements.

PJM has the right to liquidate all or a portion of the Collateral account balance at its discretion to satisfy a Participant's Total Net Obligation to PJM in the Event of Default under this Attachment Q or one or more of the Agreements.

B. Letter of Credit

An unconditional, irrevocable standby Letter of Credit can be utilized to meet the Collateral requirement. As stated below, the form, substance, and provider of the Letter of Credit must all be acceptable to PJM.

- (1) The Letter of Credit will only be accepted from U.S.-based financial institutions or U.S. branches of foreign financial institutions (“financial institutions”) that have a minimum corporate debt rating of “A” by Standard & Poor’s or Fitch Ratings, or “A2” from Moody’s Investors Service, or an equivalent short term rating from one of these agencies. PJM will consider the lowest applicable rating to be the rating of the financial institution. If the rating of a financial institution providing a Letter of Credit is lowered below A/A2 by any Rating Agency, then PJM may require the Participant to provide a Letter of Credit from another financial institution that is rated A/A2 or better, or to provide a cash deposit. If a Letter of Credit is provided from a U.S. branch of a foreign institution, the U.S. branch must itself comply with the terms of this Attachment Q, including having its own acceptable credit rating.
- (2) The Letter of Credit shall state that it shall renew automatically for successive one-year periods, until terminated upon at least ninety (90) calendar days prior written notice from the issuing financial institution. If PJM or PJM receives notice from the issuing financial institution that the current Letter of Credit is being cancelled or expiring, the Participant will be required to provide evidence, acceptable to PJM, that such Letter of Credit will be replaced with appropriate Collateral, effective as of the cancellation date of the Letter of Credit, no later than thirty (30) calendar days before the cancellation date of the Letter of Credit, and no later than ninety (90) calendar days after the notice of cancellation. Failure to do so will constitute a default under this Attachment Q and one or more of the Agreements.
- (3) PJM will post on its web site an acceptable standard form of a Letter of Credit that should be utilized by a Participant choosing to submit a Letter of Credit to establish credit at PJM. If the Letter of Credit varies in any way from the standard format, it must first be reviewed and approved by PJM. All costs associated with obtaining and maintaining a Letter of Credit and meeting the Attachment Q provisions are the responsibility of the Participant.
- (4) PJM may accept a Letter of Credit from a financial institution that does not meet the credit standards of this Attachment Q provided that the Letter of Credit has third-party support, in a form acceptable to PJM, from a financial institution that does meet the credit standards of this Attachment Q.

C. Corporate Guaranty

An irrevocable and unconditional Corporate Guaranty may be utilized to establish an Unsecured Credit Allowance for a Participant. Such credit will be considered a transfer of Unsecured Credit from the Guarantor to the Participant, and will not be considered a form of Collateral.

PJM will post on its web site an acceptable form that should be utilized by a Participant choosing to establish its credit with a Corporate Guaranty. If the Corporate Guaranty varies in any way from the PJM format, it must first be reviewed and approved by PJM before it may be applied to satisfy the Participant's credit requirements.

The Corporate Guaranty must be signed by an officer of the Guarantor, and must demonstrate that it is duly authorized in a manner acceptable to PJM. Such demonstration may include either a corporate seal on the Corporate Guaranty itself, or an accompanying executed and sealed secretary's certificate from the Guarantor's corporate secretary noting that the Guarantor was duly authorized to provide such Corporate Guaranty and that the person signing the Corporate Guaranty is duly authorized, or other manner acceptable to PJM.

PJM will evaluate the creditworthiness of a Guarantor and will establish any Unsecured Credit granted through a Corporate Guaranty using the methodology and requirements established for Participants requesting an Unsecured Credit Allowance as described herein. Foreign Guaranties and Canadian Guaranties shall be subject to additional requirements as established herein. If PJM determines at any time that a Material Adverse Change in the financial condition of the Guarantor has occurred, or if the Corporate Guaranty comes within thirty (30) calendar days of expiring without renewal, PJM may reduce or eliminate any Unsecured Credit afforded to the Participant through the guaranty. Such reduction or elimination may require the Participant to provide Collateral within the applicable cure period. If the Participant fails to provide the required Collateral, the Participant shall be in default under this Attachment Q.

All costs associated with obtaining and maintaining a Corporate Guaranty and meeting the Attachment Q provisions are the responsibility of the Participant.

1. Foreign Guaranties

A Foreign Guaranty is a Corporate Guaranty that is provided by a Credit Affiliate entity that is domiciled in a country other than the United States or Canada. The entity providing a Foreign Guaranty on behalf of a Participant is a Foreign Guarantor. A Participant may provide a Foreign Guaranty in satisfaction of part of its credit obligations or voluntary credit provision at PJM provided that all of the following conditions are met:

PJM reserves the right to deny, reject, or terminate acceptance of any Foreign Guaranty at any time, including for material adverse circumstances or occurrences.

- (a) A Foreign Guaranty:
 - (i) Must contain provisions equivalent to those contained in PJM's standard form of Foreign Guaranty with any modifications subject to review and approval by PJM counsel.
 - (ii) Must be denominated in US currency.
 - (iii) Must be written and executed solely in English, including any duplicate originals.
 - (iv) Will not be accepted towards a Participant's Unsecured Credit Allowance for more than the following limits, depending on the Foreign Guarantor's credit rating:

Rating of Foreign Guarantor	Maximum Accepted Guaranty if Country Rating is AAA	Maximum Accepted Guaranty if Country Rating is AA+
A- and above	USD50,000,000	USD30,000,000
BBB+	USD30,000,000	USD20,000,000
BBB	USD10,000,000	USD10,000,000
BBB- or below	USD 0	USD 0

- (v) May not exceed 50% of the Participant's total credit, if the Foreign Grantor is rated less than BBB+.
- (b) A Foreign Guarantor:
- (i) Must satisfy all provisions of this Attachment Q applicable to domestic Guarantors.
 - (ii) Must be a Credit Affiliate of the Participant.
 - (iii) Must maintain an agent for acceptance of service of process in the United States; such agent shall be situated in the Commonwealth of Pennsylvania, absent legal constraint.
 - (iv) Must be rated by at least one Rating Agency acceptable to PJM; the credit strength of a Foreign Guarantor may not be determined based on an evaluation of its audited financial statements without an actual credit rating as well.
 - (v) Must have a senior unsecured (or equivalent, in PJM's sole discretion) rating of BBB (one notch above BBB-) or greater by any and all agencies that provide rating coverage of the entity.
 - (vi) Must provide audited financial statements, in US GAAP format or any other format acceptable to PJM, with clear representation of net worth, intangible assets, and any other information PJM may require in order to determine the entity's Unsecured Credit Allowance.
 - (vii) Must provide a Secretary's Certificate from the Participant's corporate secretary certifying the adoption of Corporate Resolutions:
 1. Authorizing and approving the Guaranty; and
 2. Authorizing the Officers to execute and deliver the Guaranty on behalf of the Guarantor.
 - (viii) Must be domiciled in a country with a minimum long-term sovereign (or equivalent) rating of AA+/Aa1, with the following conditions:
 1. Sovereign ratings must be available from at least two rating agencies acceptable to PJM (e.g. S&P, Moody's, Fitch, DBRS).
 2. Each agency's sovereign rating for the domicile will be considered to be the lowest of: country ceiling, senior unsecured government debt, long-term foreign currency sovereign rating, long-term local currency sovereign rating, or other equivalent measures, at PJM's sole discretion.
 3. Whether ratings are available from two or three agencies, the lowest of the two or three will be used.
 - (ix) Must be domiciled in a country that recognizes and enforces judgments of US courts.

- (x) Must demonstrate financial commitment to activity in the United States as evidenced by one of the following:
 1. American Depository Receipts (ADR) are traded on the New York Stock Exchange, American Stock Exchange, or NASDAQ.
 2. Equity ownership worth over USD 100,000,000 in the wholly-owned or majority owned subsidiaries in the United States.
- (xi) Must satisfy all other applicable provisions of the PJM Tariff and/or Operating Agreement, including this Attachment Q.
- (xii) Must pay for all expenses incurred by PJM related to reviewing and accepting a foreign guaranty beyond nominal in-house credit and legal review.
- (xiii) Must, at its own cost, provide PJM with independent legal opinion from an attorney/solicitor of PJM's choosing and licensed to practice law in the United States and/or Guarantor's domicile, in form and substance acceptable to PJM in its sole discretion, confirming the enforceability of the Foreign Guaranty, the Guarantor's legal authorization to grant the Guaranty, the conformance of the Guaranty, Guarantor, and Guarantor's domicile to all of these requirements, and such other matters as PJM may require in its sole discretion.

2. Canadian Guaranties

The entity providing a Canadian Guaranty on behalf of a Participant is a Canadian Guarantor. A Participant may provide a Canadian Guaranty in satisfaction of part of its credit obligations or voluntary credit provision at PJM provided that all of the following conditions are met.

PJM reserves the right to deny, reject, or terminate acceptance of any Canadian Guaranty at any time for reasonable cause, including material adverse circumstances or occurrences.

- (a) A Canadian Guaranty:
 - (i) Must contain provisions equivalent to those contained in PJM's standard form of Foreign Guaranty with any modifications subject to review and approval by PJM counsel.
 - (ii) Must be denominated in US currency.
 - (iii) Must be written and executed solely in English, including any duplicate originals.
- (b) A Canadian Guarantor:
 - (i) Must be a Credit Affiliate of the Participant.
 - (ii) Must satisfy all provisions of this Attachment Q applicable to domestic Guarantors.
 - (iii) Must maintain an agent for acceptance of service of process in the United States; such agent shall be situated in the Commonwealth of Pennsylvania, absent legal constraint.
 - (iv) Must be rated by at least one Rating Agency acceptable to PJM; the credit strength of a Canadian Guarantor may not be determined based on an evaluation of its audited financial statements without an actual credit rating as well.
 - (v) Must provide audited financial statements, in US GAAP format or any other format acceptable to PJM with clear representation of net worth, intangible assets,

and any other information PJM may require in order to determine the entity's Unsecured Credit Allowance.

- (vi) Must satisfy all other applicable provisions of the PJM Tariff and/or Operating Agreement, including this Attachment Q.

D. Surety Bond

An unconditional, irrevocable surety bond can be utilized to meet the Collateral requirement for Participants. As stated below, the form, substance, and provider of the surety bond must all be acceptable to PJM.

- (i) An acceptable surety bond must be payable immediately upon demand without prior demonstration of the validity of the demand. The surety bond will only be accepted from a U.S. Treasury-listed approved surety that has either (i) a minimum corporate debt rating of “A” by Standard & Poor’s or Fitch Ratings, or “A2” from Moody’s Investors Service, or an equivalent short term rating from one of these agencies, or (ii) a minimum insurer rating of “A” by A.M. Best. PJMSettlement will consider the lowest applicable rating to be the rating of the surety. If the rating of a surety providing a surety bond is lowered below A/A2 by any rating agency, then PJMSettlement may require the Participant to provide a surety bond from another surety that is rated A/A2 or better, or to provide another form of Collateral.
- (ii) The surety bond shall have an initial period of at least one year, and shall state that it shall renew automatically for successive one-year periods, until terminated upon at least ninety (90) days prior written notice from the issuing surety. If PJM receives notice from the issuing surety that the current surety bond is being cancelled, the Participant will be required to provide evidence, acceptable to PJM, that such surety bond will be replaced with appropriate Collateral, effective as of the cancellation date of the surety bond, no later than thirty (30) days before the cancellation date of the surety bond, and no later than ninety (90) days after the notice of cancellation. Failure to do so will constitute a default under this Attachment Q and one of more of the Agreements enabling PJM to immediately demand payment of the full value of the surety bond.
- (iii) PJM will post on its web site an acceptable standard form of a surety bond that should be utilized by a Participant choosing to submit a surety bond to establish credit at PJM. The acceptable standard form of surety bond will include non-negotiable provisions, including but not be limited to, a payment on demand feature, requirement that the bond be construed pursuant to Pennsylvania law, making the surety’s obligation to pay out on the bond absolute and unconditional irrespective of the principal’s (Market Participant’s) bankruptcy, terms of any other agreements, investigation of the Market Participant by any entity or governmental authority, or PJM first attempting to collect payment from the Market Participant, and will require, among other things, that (a) the surety waive **all** rights that would be available to a principal or surety under the law, including

but not limited to any right to investigate or verify any matter related to a demand for payment, rights to set-off amounts due by PJM to the Market Participant, and all counterclaims, (b) the surety expressly waive **all** of its and the principal's defenses, including illegality, fraud in the inducement, reliance on statements or representations of PJM and every other typically available defense; (c) the language of the bond that is determinative of the surety's obligation, and not the underlying agreement or arrangement between the principal and the obligee; (d) the bond shall not be conditioned on PJM first resorting to any other means of security or collateral, or pursuing any other remedies it may have; and (e) the surety acknowledge the continuing nature of its obligations in the event of termination or nonrenewal of the surety bond to make clear the surety remains liable for any obligations that arose before the effective date of its notice of cancellation of the surety bond. If the surety bond varies in any way from the standard format, it must first be reviewed and approved by PJM. PJM shall not accept any surety bond that varies in any material way from the standard format.

- (iv) All costs associated with obtaining and maintaining a surety bond and meeting the Attachment Q provisions are the responsibility of the Participant.
- (v) PJM shall not accept surety bonds with an aggregate value greater than \$10 million dollars (\$10,000,000) issued by any individual surety on behalf of any individual Participant.
- (vi) PJM shall not accept surety bonds with an aggregate value greater than \$50 million dollars (\$50,000,000) issued by any individual surety.

E. PJM Administrative Charges

Collateral or credit support held by PJM shall also secure obligations to PJM for PJM administrative charges, and may be liquidated to satisfy all such obligations in an Event of Default.

F. Collateral and Credit Support Held by PJM

Collateral or credit support submitted by Participants and held by PJM shall be held by PJM for the benefit of PJM.

VI. SUPPLEMENTAL CREDIT REQUIREMENTS FOR SCREENED TRANSACTIONS

A. Virtual and Export Transaction Screening

1. Credit for Virtual and Export Transactions

Export Transactions and Virtual Transactions both utilize Credit Available for Virtual Transactions to support their credit requirements.

PJM does not require a Market Participant to establish separate or additional credit for submitting Virtual or Export Transactions; however, once transactions are submitted and accepted by PJM, PJM may require credit supporting those transactions to be held until the transactions are completed and their financial impact incorporated into the Market Participant's Obligations. If a Market Participant chooses to establish additional Collateral and/or Unsecured Credit Allowance in order to increase its Credit Available for Virtual Transactions, the Market Participant's Working Credit Limit for Virtual Transactions shall be increased in accordance with the definition thereof. The Collateral and/or Unsecured Credit Allowance available to increase a Market Participant's Credit Available for Virtual Transactions shall be the amount of Collateral and/or Unsecured Credit Allowance available after subtracting any credit required for Minimum Participation Requirements, FTR, RPM or other credit requirement determinants defined in this Attachment Q, as applicable.

If a Market Participant chooses to provide additional Collateral in order to increase its Credit Available for Virtual Transactions PJM may establish a reasonable timeframe, not to exceed three months, for which such Collateral must be maintained. PJM will not impose such restriction on a deposit unless a Market Participant is notified prior to making the deposit. Such restriction, if applied, shall be applied to all future deposits by all Market Participants engaging in Virtual Transactions.

A Market Participant may increase its Credit Available for Virtual Transactions by providing additional Collateral to PJM. PJM will make a good faith effort to make new Collateral available as Credit Available for Virtual Transactions as soon as practicable after confirmation of receipt. In any event, however, Collateral received and confirmed by noon on a Business Day will be applied (as provided under this Attachment Q) to Credit Available for Virtual Transactions no later than 10:00 am on the following Business Day. Receipt and acceptance of wired funds for cash deposit shall mean actual receipt by PJM's bank, deposit into PJM's customer deposit account, confirmation by PJM that such wire has been received and deposited, and entry into PJM's credit system. Receipt and acceptance of letters of credit or surety bonds shall mean receipt of the original Letter of Credit or surety bond, or amendment thereto, confirmation from PJM's credit and legal staffs that such Letter of Credit or surety bond, or amendment thereto conforms to PJM's requirements, which confirmation shall be made in a reasonable and practicable timeframe, and entry into PJM's credit system. To facilitate this process, bidders submitting additional Collateral for the purpose of increasing their Credit Available for Virtual Transactions are advised to submit such Collateral well in advance of the desired time, and to specifically notify PJM of such submission.

A Market Participant wishing to submit Virtual or Export Transactions must allocate within PJM's credit system the appropriate amount of Credit Available for Virtual Transactions to the virtual and export allocation sections within each customer account in which it wishes to submit such transactions.

2. Virtual Transaction Screening

All Virtual Transactions submitted to PJM shall be subject to a credit screen prior to acceptance in the Day-ahead Energy Market. The credit screen is applied separately for each of a Market Participant's customer accounts. The credit screen process will automatically reject Virtual Transactions submitted by the Market Participant in a customer account if the Market Participant's Credit Available for Virtual Transactions, allocated on a customer account basis, is exceeded by the Virtual Credit Exposure that is calculated based on the Market Participant's Virtual Transactions submitted, as described below.

A Market Participant's Virtual Credit Exposure will be calculated separately for each customer account on a daily basis for all Virtual Transactions submitted by the Market Participant for the next Operating Day using the following equation:

Virtual Credit Exposure = INC and DEC Exposure + Up-to Congestion Exposure
Where:

(a) INC and DEC Exposure for each customer account is calculated as:

(i) ((the total MWh bid or offered, whichever is greater, hourly at each node) x the Nodal Reference Price x 1 day) summed over all nodes and all hours; plus (ii) ((the difference between the total bid MWh cleared and total offered MWh cleared hourly at each node) x Nodal Reference Price) summed over all nodes and all hours for the previous cleared Day-ahead Energy Market.

(b) Up-to Congestion Exposure for each customer account is calculated as:

(i) Total MWh bid hourly for each Up-to Congestion Transaction x (price bid – Up-to Congestion Reference Price) summed over all Up-to Congestion Transactions and all hours; plus (ii) Total MWh cleared hourly for each Up-to Congestion Transaction x (cleared price – Up-to Congestion Reference Price) summed over all Up-to Congestion Transactions and all hours for the previous cleared Day-ahead Energy Market, provided that hours for which the calculation for an Up-to Congestion Transaction is negative, it shall be deemed to have a zero contribution to the sum.

3. Export Transaction Screening

Export Transactions in the Real-time Energy Market shall be subject to Export Transaction Screening. Export Transaction Screening may be performed either for the duration of the entire Export Transaction, or separately for each time interval comprising an Export Transaction. PJM will deny or curtail all or a portion (based on the relevant time interval) of an Export Transaction if that Export Transaction, or portion thereof, would otherwise cause the Market Participant's Export Credit Exposure to exceed its Credit Available for Export Transactions. Export Transaction Screening shall be applied separately for each Operating Day and shall also be applied to each Export Transaction one or more times prior to the market clearing process for each relevant time interval. Export Transaction Screening shall not apply to transactions established directly by and between PJM and a neighboring Balancing Authority for the purpose of maintaining reliability.

A Market Participant's credit exposure for an individual Export Transaction shall be the MWh volume of the Export Transaction for each relevant time interval multiplied by each relevant Export Transaction Price Factor and summed over all relevant time intervals of the Export Transaction.

B. RPM Auction and Price Responsive Demand Credit Requirements

Settlement during any Delivery Year of cleared positions resulting or expected to result from any RPM Auction shall be included as appropriate in Peak Market Activity, and the provisions of this Attachment Q shall apply to any such activity and obligations arising therefrom. In addition, the provisions of this section shall apply to any entity seeking to participate in any RPM Auction, to address credit risks unique to such auctions. The provisions of this section also shall apply under certain circumstances to PRD Providers that seek to commit Price Responsive Demand pursuant to the provisions of the Reliability Assurance Agreement.

Credit requirements described herein for RPM Auctions and RPM bilateral transactions are applied separately for each customer account of a Market Participant. Market Participants wishing to participate in an RPM Auction or enter into RPM bilateral transactions must designate the appropriate amount of credit to each account in which their offers are submitted.

1. Applicability

A Market Participant seeking to submit a Sell Offer in any RPM Auction based on any Capacity Resource for which there is a materially increased risk of nonperformance must satisfy the credit requirement specified herein before submitting such Sell Offer. A PRD Provider seeking to commit Price Responsive Demand for which there is a materially increased risk of non-performance must satisfy the credit requirement specified herein before it may commit the Price Responsive Demand. Credit must be maintained until such risk of non-performance is substantially eliminated, but may be reduced commensurate with the reduction in such risk, as set forth in section VI.B.3 below.

For purposes of this provision, a resource for which there is a materially increased risk of nonperformance shall mean: (i) a Planned Generation Capacity Resource; (ii) a Planned Demand Resource or an Energy Efficiency Resource; (iii) a Qualifying Transmission Upgrade; (iv) an existing or Planned Generation Capacity Resource located outside the PJM Region that at the time it is submitted in a Sell Offer has not secured firm transmission service to the border of the PJM Region sufficient to satisfy the deliverability requirements of the Reliability Assurance Agreement; or (v) Price Responsive Demand to the extent the responsible PRD Provider has not registered PRD-eligible load at a PRD Substation level to satisfy its Nominal PRD Value commitment, in accordance with Reliability Assurance Agreement, Schedule 6.1.

2. Reliability Pricing Model Auction and Price Responsive Demand Credit Requirement

Except as provided for Credit-Limited Offers below, for any resource specified in section VI.B.1 above, other than Price Responsive Demand, the credit requirement shall be the RPM Auction Credit Rate, as provided in section VI.B.4 below, times the megawatts to be offered for sale from such resource in an RPM Auction. For Qualified Transmission Upgrades, the credit requirements shall be based on the Locational Deliverability Area in which such upgrade was to increase the Capacity Emergency Transfer Limit. However, the credit requirement for Planned Financed Generation Capacity Resources and Planned External Financed Generation Capacity Resources shall be one half of the product of the RPM Auction Credit Rate, as provided in section VI.B.4 below, times the megawatts to be offered for sale from such resource in a Reliability Pricing Model Auction. The RPM Auction Credit Requirement for each Market Participant shall be determined on a customer account basis, separately for each customer account of a Market Participant, and shall be the sum of the credit requirements for all such resources to be offered by such Market Participant in the auction or, as applicable, cleared by such Market Participant in the relevant auctions. For Price Responsive Demand, the credit requirement shall be based on the Nominal PRD Value (stated in Unforced Capacity terms) times the Price Responsive Demand Credit Rate as set forth in section VI.B.5 below. Except for Credit-Limited Offers, the RPM Auction Credit requirement for a Market Participant will be reduced for any Delivery Year to the extent less than all of such Market Participant's offers clear in the Base Residual Auction or any Incremental Auction for such Delivery Year. Such reduction shall be proportional to the quantity, in megawatts, that failed to clear in such Delivery Year.

A Sell Offer based on a Planned Generation Capacity Resource, Planned Demand Resource, or Energy Efficiency Resource may be submitted as a Credit-Limited Offer. A Market Participant electing this option shall specify a maximum amount of Unforced Capacity, in megawatts, and a maximum credit requirement, in dollars, applicable to the Sell Offer. A Credit-Limited Offer shall clear the RPM Auction in which it is submitted (to the extent it otherwise would clear based on the other offer parameters and the system's need for the offered capacity) only to the extent of the lesser of: (i) the quantity of Unforced Capacity that is the quotient of the division of the specified maximum credit requirement by the Auction Credit Rate resulting from section VI.B.4.b. below; and (ii) the maximum amount of Unforced Capacity specified in the Sell Offer. For a Market Participant electing this alternative, the RPM Auction Credit requirement applicable prior to the posting of results of the auction shall be the maximum credit requirement specified in its Credit-Limited Offer, and the RPM Auction Credit requirement subsequent to posting of the results will be the Auction Credit Rate, as provided in section VI.B.4.b, c. or d. of this Attachment Q, as applicable, times the amount of Unforced Capacity from such Sell Offer that cleared in the auction. The availability and operational details of Credit-Limited Offers shall be as described in the PJM Manuals.

As set forth in section VI.B.4 below, a Market Participant's Auction Credit requirement shall be determined separately for each Delivery Year.

3. Reduction in Credit Requirement

As specified below, the RPM Auction Credit Rate may be reduced under certain circumstances after the auction has closed.

The Price Responsive Demand credit requirement shall be reduced as and to the extent the PRD Provider registers PRD-eligible load at a PRD Substation level to satisfy its Nominal PRD Value commitment, in accordance with Reliability Assurance Agreement, Schedule 6.1.

In addition, the RPM Auction Credit requirement for a Market Participant for any given Delivery Year shall be reduced periodically, after the Market Participant has provided PJM a written request for each reduction, accompanied by documentation sufficient for PJM to verify attainment of required milestones or satisfaction of other requirements, and PJM has verified that the Market Participant has successfully met progress milestones for its Capacity Resource that reduce the risk of non-performance, as follows:

(a) For Planned Demand Resources and Energy Efficiency Resources, the RPM Auction Credit requirement will be reduced in direct proportion to the megawatts of such Demand Resource that the Resource Provider qualifies as a Capacity Resource, in accordance with the procedures established under the Reliability Assurance Agreement.

(b) For Existing Generation Capacity Resources located outside the PJM Region that have not secured sufficient firm transmission to the border of the PJM Region prior to the auction in which such resource is first offered, the RPM Auction Credit requirement shall be reduced in direct proportion to the megawatts of firm transmission service secured by the Market Participant

that qualify such resource under the deliverability requirements of the Reliability Assurance Agreement.

(c) For Planned Generation Capacity Resources located in the PJM Region, the RPM Auction Credit requirement shall be reduced as the Capacity Resource attains the milestones stated in the following table and as further described in the PJM Manuals.

Milestones	Increment of reduction from initial RPM Auction Credit requirement
Effective Date of Interconnection Service Agreement	50%
Financial Close	15%
Full Notice to Proceed and Commencement of Construction (e.g., footers poured)	5%
Main Power Generating Equipment Delivered	5%
Commencement of Interconnection Service	25%

For externally financed projects, the Market Participant must submit with its request for reduction a sworn, notarized certification of a duly authorized independent engineer for the Financial Close, Full Notice to Proceed and Commencement of Construction, and Main Power Generating Equipment Delivered milestones.

For internally financed projects, the Market Participant must submit with its request for reduction a sworn, notarized certification of a duly authorized officer of the Market Participant for the Financial Close milestone and either a duly authorized independent engineer or Professional Engineer for the Full Notice to Proceed and Commencement of Construction and the Main Power Generating Equipment Delivered milestones.

The required certifications must be in a form acceptable to PJM, certifying that the engineer or officer, as applicable, has personal knowledge, or has engaged in a diligent inquiry to determine, that the milestone has been achieved and that, based on its review of the relevant project information, the engineer or officer, as applicable, is not aware of any information that could reasonably cause it to believe that the Capacity Resource will not be in-service by the beginning of the applicable Delivery Year. The Market Participant shall, if requested by PJM, supply to PJM on a confidential basis all records and documents relating to the engineer's and/or officer's certifications.

(d) For Planned External Generation Capacity Resources, the RPM Auction Credit requirement shall be reduced as the Capacity Resource attains the milestones stated in the following table and as further described in the PJM Manuals; provided, however, that the total percentage reduction in the RPM Auction Credit requirement shall be no greater than the quotient of (i) the MWs of firm transmission service that the Market Participant has secured for the complete transmission path divided by (ii) the MWs of firm transmission service required to

qualify such resource under the deliverability requirements of the Reliability Assurance Agreement.

Credit Reduction Milestones for Planned External Generation Capacity Resources	
Milestones	Increment of reduction from initial RPM Auction Credit requirement
Effective Date of the equivalent of an Interconnection Service Agreement	50%
Financial Close	15%
Full Notice to Proceed and Commencement of Construction (e.g., footers poured)	5%
Main Power Generating Equipment Delivered	5%
Commencement of Interconnection Service	25%

To obtain a reduction in its RPM Auction Credit requirement, the Market Participant must demonstrate satisfaction of the applicable milestone in the same manner as set forth for Planned Generation Capacity Resources in subsection (c) above.

(e) For Planned Financed Generation Capacity Resources located in the PJM Region, the RPM Auction Credit requirement shall be reduced as the Capacity Resource attains the milestones stated in the following table and as further described in the PJM Manuals.

Credit Reduction Milestones for Planned Financed Generation Capacity Resources	
Milestones	Increment of reduction from initial RPM Auction Credit requirement
Full Notice to Proceed	50%
Commencement of Construction (e.g., footers poured)	15%
Main Power Generating Equipment Delivered	10%
Commencement of Interconnection Service	25%

To obtain a reduction in its RPM Auction Credit requirement, the Market Participant must demonstrate satisfaction of the applicable milestone in the same manner as set forth for Planned Generation Capacity Resources in subsection (c) above.

(f) For Planned External Financed Generation Capacity Resources, the RPM Auction Credit Requirement shall be reduced as the Capacity Resource attains the milestones stated in the following table and as further described in the PJM Manuals; provided, however, that the total percentage reduction in the RPM Auction Credit requirement, including the initial 50% reduction for being a Planned External Financed Generation Capacity Resources, shall be no greater than the quotient of (i) the MWs of firm transmission service that the Market Participant has secured for the complete transmission path divided by (ii) the MWs of firm transmission service required

to qualify such resource under the deliverability requirements of the Reliability Assurance Agreement.

Credit Reduction Milestones for Planned External Financed Generation Capacity	
Milestones	Increment of reduction from initial RPM Auction Credit requirement
Full Notice to Proceed	50%
Commencement of Construction (e.g., footers poured)	15%
Main Power Generating Equipment Delivered	10%
Commencement of Interconnection Service	25%

To obtain a reduction in its RPM Auction Credit requirement, the Market Participant must demonstrate satisfaction of the applicable milestone in the same manner as set forth for Planned Generation Capacity Resources in subsection (c) above.

(g) For Qualifying Transmission Upgrades, the RPM Auction Credit requirement shall be reduced to 50% of the amount calculated under section VI.B.2 above beginning as of the effective date of the latest associated Interconnection Service Agreement (or, when a project will have no such agreement, an Upgrade Construction Service Agreement), and shall be reduced to zero on the date the Qualifying Transmission Upgrade is placed in service.

4. RPM Auction Credit Rate

As set forth in the PJM Manuals, a separate Auction Credit Rate shall be calculated for each Delivery Year prior to each RPM Auction for such Delivery Year, as follows:

- (a) Prior to the posting of the results of a Base Residual Auction for a Delivery Year, the Auction Credit Rate shall be:
- (i) For all Capacity Resources other than Capacity Performance Resources, (the greater of (A) 0.3 times the Net Cost of New Entry for the PJM Region for such Delivery Year, in MW-day or (B) \$20 per MW-day) times the number of calendar days in such Delivery Year; and
 - (ii) For Capacity Performance Resources, the greater of ((A) 0.5 times the Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in MW-day or (B) \$20 per MW-day) times the number of calendar days in such Delivery Year.
 - (iii) For Seasonal Capacity Performance Resources, the same as the Auction Credit Rate for Capacity Performance Resources, but reduced to be proportional to the number of calendar days in the relevant season.

(b) Subsequent to the posting of the results from a Base Residual Auction, the Auction Credit Rate used for ongoing credit requirements for supply committed in such auction shall be:

- (i) For all Capacity Resources other than Capacity Performance Resources, (the greater of (A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the resource is located) times the number of calendar days in such Delivery Year; and
- (ii) For Capacity Performance Resources, the (greater of [(A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the resource is located) or (C) the lesser of (1) 0.5 times the Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day or (2) 1.5 times the Net Cost of New Entry (stated on an installed capacity basis) for the PJM Region for such Delivery year or for the Relevant LDA, in \$/MW-day minus (the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the resource is located)] times the number of calendar days in such Delivery Year).
- (iii) For Seasonal Capacity Performance Resources, the same as the Auction Credit Rate for Capacity Performance Resources, but reduced to be proportional to the number of calendar days in the relevant season.

(c) For any resource not previously committed for a Delivery Year that seeks to participate in an Incremental Auction, the Auction Credit Rate shall be:

(i) For all Capacity Resources other than Capacity Performance Resources, (the greater of (A) 0.3 times the Net Cost of New Entry for the PJM Region for such Delivery Year, in MW-day or (B) 0.24 times the Capacity Resource Clearing Price in the Base Residual Auction for such Delivery Year for the Locational Deliverability Area within which the resource is located or (C) \$20 per MW-day) times the number of calendar days in such Delivery Year; and

(ii) For Capacity Performance Resources, the (greater of (A) 0.5 times Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA or (B) \$20/MW-day) times the number of calendar days in such Delivery Year.

(d) Subsequent to the posting of the results of an Incremental Auction, the Auction Credit Rate used for ongoing credit requirements for supply committed in such auction shall be:

- (i) For Base Capacity Resources: (the greater of (A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the resource is located) times the number of calendar days in such Delivery Year, but no greater than the Auction Credit Rate previously established for such resource's participation in such Incremental Auction pursuant to subsection (c) above) times the number of calendar days in such Delivery Year;

- (ii) For Capacity Performance Resources, the greater of [(A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the resource is located or (C) the lesser of (1) 0.5 times the Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day or (2) 1.5 times the Net Cost of New Entry (stated on an installed capacity basis) for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day minus (the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the resource is located)] times the number of calendar days in such Delivery Year); and
- (iii) For Seasonal Capacity Performance Resources, the same as the Auction Credit Rate for Capacity Performance Resources, but reduced to be proportional to the number of calendar days in the relevant season.

(e) For the purposes of this section VI.B.4 and section VI.B.5 below, “Relevant LDA” means the Locational Deliverability Area in which the Capacity Performance Resource is located if a separate Variable Resource Requirement Curve has been established for that Locational Deliverability Area for the Base Residual Auction for such Delivery Year.

5. Price Responsive Demand Credit Rate

- (a) For the 2018/2019 through 2022/2023 Delivery Years:
 - (i) Prior to the posting of the results of a Base Residual Auction for a Delivery Year, the Price Responsive Demand Credit Rate shall be (the greater of (A) 0.3 times the Net Cost of New Entry for the PJM Region for such Delivery Year, in MW-day or (B) \$20 per MW-day) times the number of calendar days in such Delivery Year;
 - (ii) Subsequent to the posting of the results from a Base Residual Auction, the Price Responsive Demand Credit Rate used for ongoing credit requirements for Price Responsive Demand committed in such auction shall be (the greater of (A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the Price Responsive Demand load is located, in \$/MW-day) times the number of calendar days in such Delivery Year times a final price uncertainty factor of 1.05;
 - (iii) For any additional Price Responsive Demand that seeks to commit in a Third Incremental Auction in response to a qualifying change in the final LDA load forecast, the Price Responsive Demand Credit Rate shall be the same as the rate for Price Responsive Demand that had cleared in the Base Residual Auction; and
 - (iv) Subsequent to the posting of the results of the Third Incremental Auction, the Price Responsive Demand Credit Rate used for ongoing credit requirements for

all Price Responsive Demand, shall be (the greater of (i) \$20/MW-day or (ii) 0.2 times the Final Zonal Capacity Price for the Locational Deliverability Area within which the Price Responsive Demand is located) times the number of calendar days in such Delivery Year, but no greater than the Price Responsive Demand Credit Rate previously established under subsections (a)(i), (a)(ii), or (a)(iii) of this section for such Delivery Year.

- (b) For the 2022/2023 Delivery Year and Subsequent Delivery Years:
- (i) Prior to the posting of the results of a Base Residual Auction for a Delivery Year, the Price Responsive Demand Credit Rate shall be (the greater of (A) 0.5 times the Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day or (B) \$20 per MW-day) times the number of calendar days in such Delivery Year;
 - (ii) Subsequent to the posting of the results from a Base Residual Auction, the Price Responsive Demand Credit Rate used for ongoing credit requirements for Price Responsive Demand committed in such auction shall be (the greater of [(A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the Price Responsive Demand is located, in \$/MW-day or (C) the lesser of (1) 0.5 times the Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day or (2) 1.5 times the Net Cost of New Entry (stated on an installed capacity basis) for the PJM Region for such Delivery year or for the Relevant LDA, in \$/MW-day minus (the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the Price Responsive Demand is located)] times the number of calendar days in such Delivery Year;
 - (iii) For any additional Price Responsive Demand that seeks to commit in a Third Incremental Auction in response to a qualifying change in the final LDA load forecast, the Price Responsive Demand Credit Rate shall be (the greater of (A) 0.5 times Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day or (B) \$20/MW-day) times the number of calendar days in such Delivery Year; and
 - (iv) Subsequent to the posting of the results of the Third Incremental Auction, the Price Responsive Demand Credit Rate used for ongoing credit requirements for all Price Responsive Demand committed in such auction shall be the greater of [(A) \$20/MW-day or (B) 0.2 times the Capacity Resource Clearing Price in such auction for the Locational Deliverability Area within which the Price Responsive Demand is located or (C) the lesser of (1) 0.5 times the Net Cost of New Entry for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day or (2) 1.5 times the Net Cost of New Entry (stated on an installed capacity basis) for the PJM Region for such Delivery Year or for the Relevant LDA, in \$/MW-day minus (the Capacity Performance Resource Clearing Price in such Incremental Auction for the Locational Deliverability Areas within which the Price

Responsive Demand is located)] times the number of calendar days in such Delivery Year.

6. RPM Seller Credit - Additional Form of Unsecured Credit for RPM

In addition to the forms of credit specified elsewhere in this Attachment Q, RPM Seller Credit shall be available to Market Participants, but solely for purposes of satisfying RPM Auction Credit requirements. If a supplier has a history of being a net seller into PJM Markets, on average, over the past 12 months, then PJM will count as available Unsecured Credit twice the average of that Market Participant's total net monthly PJM bills over the past 12 months. This RPM Seller Credit shall be subject to the cap on available Unsecured Credit as established in section II.G.3 above.

RPM Seller Credit is calculated as a single value for each Market Participant, not separately by account, and must be designated to specific customer accounts in order to be available to satisfy RPM Auction Credit requirements that are calculated in each such customer account.

7. Credit Responsibility for Traded Planned RPM Capacity Resources

PJM may require that credit and financial responsibility for planned Capacity Resources that are traded remain with the original party (which for these purposes, means the party bearing credit responsibility for the planned Capacity Resource immediately prior to trade) unless the receiving party independently establishes consistent with this Attachment Q, that it has sufficient credit with PJM and agrees by providing written notice to PJM that it will fully assume the credit responsibility associated with the traded planned Capacity Resource.

C. Financial Transmission Right Auctions

Credit requirements described herein for FTR activity are applied separately for each customer account of a Market Participant, unless specified otherwise in this section C. FTR Participants must designate the appropriate amount of credit to each separate customer account in which any activity occurs or will occur.

1. FTR Credit Limit.

Participants must maintain their FTR Credit Limit at a level equal to or greater than their FTR Credit Requirement for each applicable account. FTR Credit Limits will be established only by a Participant providing Collateral and designating the available credit to specific accounts.

2. FTR Credit Requirement.

For each Market Participant with FTR activity, PJM shall calculate an FTR Credit Requirement. The FTR Credit Requirement shall be calculated on a portfolio basis for each Market Participant based on (a) initial margin, (b) Auction Revenue Right Credits, (c) Mark-to-Auction Value, (d) application of a 10¢ per MWh minimum value adjustment, and (e) realized gains and/or losses, as set forth in subsections (a)-(e) of this subsection, employing the formula:

Max { Max (IM – ARR – MTA, Ten Cent per Mwh Minimum) – Realized Gains and/or Losses, 0}

Where IM is the initial margin, ARR is Auction Revenue Rights Credits and MTA is the Mark-to-Auction Value. The FTR Credit Requirement may be increased to reflect any change in the value of a Market Participant's portfolio requiring an increase in Collateral as further described below.

(a) Initial Margin

Initial margin shall be calculated in accordance with the following formula:

$$\text{IM} = \text{FTR Obligations IM} + \text{FTR Options IM}$$

The model will employ a confidence interval of 97 percent.

(i) FTR Obligations IM

Initial margin values for Financial Transmission Right Obligations shall be determined utilizing a historical simulation value-at-risk methodology that calculates the size and value at risk of the applicable FTR portfolio based on a defined confidence interval and subject to a weighted aggregation method that is represented by a straight sum for long term positions and a combination of straight sum (20%) and weighted root sum of squares (80%) for balance of planning period positions.

(ii) FTR Options IM

The initial margin for Financial Transmission Right Options shall be calculated as the FTR cost minus the FTR Historical Values. FTR Historical Values shall be calculated separately for weekend on-peak, weekday on-peak, off-peak, and 24-hour FTRs for each month of the year. FTR Historical Values shall be adjusted by plus or minus ten percent for cleared counter flow or prevailing flow FTRs, respectively, in order to mitigate exposure due to uncertainty and fluctuations in actual FTR value. Historical values used in the calculation of FTR Historical Values shall be adjusted when the network simulation model utilized in PJM's economic planning process indicates that transmission congestion will decrease due to certain transmission upgrades that are in effect or planned to go into effect for the following Planning Period. The transmission upgrades to be modeled for this purpose shall only include those upgrades that, individually, or together, have 10% or more impact on the transmission congestion on an individual constraint or constraints with congestion of \$5 million or more affecting a common congestion path. The adjustments to historical values shall be the dollar amount of the adjustment shown in the network simulation model.

(b) Auction Revenue Rights Credits

For a given month for which initial margin is calculated, the prorated value of any Auction Revenue Rights Credits held by a Market Participant with Financial Transmission Right Obligations shall be subtracted from the initial margin for that month. In accordance with subsection 3 below, PJM may recalculate Auction Revenue Rights Credits at any time, but shall do so no less frequently than subsequent to each annual FTR auction. If a reduction in such ARR credits at any time increases an FTR Participant's FTR Credit Requirements beyond its credit available for FTR activity, the FTR Participant must increase its Collateral or the FTR Credit Limit.

(c) Mark-to-Auction Value

A Mark-to-Auction Value shall be calculated for each Market Participant in accordance with subsection 7 below.

(d) Ten Cent (10¢) per MWh Minimum Value Adjustment

If the FTR Credit Requirement as calculated pursuant to subsections (a)-(c) above, results in a value that is less than ten cents (10¢) per MWh, the FTR Credit Requirement shall be increased to ten cents (10¢) per MWh. When calculating the portfolio MWh for this comparison, for cleared "Sell" FTRs, the MWh shall be subtracted from the portfolio total; prior to clearing, the MWh for "Sell" FTRs shall not be included in the portfolio total.

(e) Realized Gains and/or Losses

Any realized gains and/or losses resulting from the settlement of Financial Transmission Right Obligations that have not been paid out will be subtracted from the FTR Credit Requirement. A realized gain will decrease the FTR Credit Requirement (but not below \$0.00), whereas a realized loss will increase the FTR Credit Requirement.

3. Rejection of FTR Bids.

Bids submitted into an auction will be rejected if the Market Participant's FTR Credit Requirement including such submitted bids would exceed the Market Participant's FTR Credit Limit, or if the Market Participant fails to provide additional Collateral as required pursuant to provisions related to mark-to-auction.

4. FTR Credit Collateral Returns.

A Market Participant may request from PJM the return of any Collateral no longer required for the FTR markets. PJM is permitted to limit the frequency of such requested Collateral returns, provided that Collateral returns shall be made by PJM at least once per calendar quarter, if requested by a Market Participant.

5. Credit Responsibility for Bilateral Transfers of FTRs.

PJM may require that credit responsibility associated with an FTR bilaterally transferred to a new Market Participant remain with the original party (which for these purposes, means the party bearing credit responsibility for the FTR immediately prior to bilateral transfer) unless and until the receiving party independently establishes, consistent with this Attachment Q, sufficient credit with PJM and agrees through confirmation of the bilateral transfer in PJM's FTR reporting tool that it will meet in full the credit requirements associated with the transferred FTR.

6. FTR Administrative Charge Credit Requirement

In addition to any other credit requirements, PJM may apply a credit requirement to cover the maximum administrative fees that may be charged to a Market Participant for its bids and offers.

7. Mark-to-Auction

A Mark-to-Auction Value shall be calculated separately for each customer account of a Market Participant. For each such customer account, the Mark-to-Auction Value shall be a single number equal to the sum, over all months remaining in the applicable FTR period and for all cleared FTRs in the customer account, of the most recently available cleared auction price applicable to the FTR minus the original transaction price of the FTR, multiplied by the transacted quantity.

The FTR Credit Requirement, as otherwise described above, shall be increased when the Mark-to-Auction Value is negative and decreased when the Mark-to-Auction Value is positive. The increase shall equal the absolute value of the negative Mark-to-Auction Value less the value of ARR credits that are held in the customer account and have not been used to reduce the FTR Credit Requirement prior to application of the Mark-to-Auction Value. PJM shall recalculate ARR credits held by each Market Participant after each annual FTR auction and may also recalculate such ARR credits at any other additional time intervals it deems appropriate. Application of the Mark-to-Auction Value, including the effect from ARR application, shall not decrease the FTR Credit Requirement below the Ten Cent (10¢) per MWh Minimum.

For Market Participant customer accounts for which FTR bids have been submitted into the current FTR auction, if the Market Participant's FTR Credit Requirement exceeds its credit available for the Market Participant's portfolio of FTRs in the tentative cleared solution for an FTR auction (or auction round), PJM shall issue a Collateral Call to the Market Participant, and the Market Participant must fulfill such demand before 4:00 p.m. Eastern Prevailing Time on the following Business Day. If a Market Participant does not timely satisfy such Collateral Call,

PJM shall, in coordination with PJM, cause the removal of all of that Market Participant's bids in that FTR auction (or auction round), submitted from such Market Participant's customer account, and a new cleared solution shall be calculated for the FTR auction (or auction round).

If necessary, PJM shall repeat the auction clearing calculation. PJM shall repeat these mark-to-auction calculations subsequent to any secondary clearing calculation, and PJM shall require affected Market Participants to establish additional credit.

Subsequent to final clearing of an FTR auction or an annual FTR auction round, PJM shall recalculate the FTR Credit Requirement for all FTR portfolios, and, as applicable, issue to each Market Participant a request for Collateral for the total amount by which the FTR Credit Requirement exceeds the credit allocated in any of the Market Participant's accounts. The Market Participant must fulfill such demand by 4:00 p.m. Eastern Prevailing Time on the following Business Day.

If the request for Collateral is not satisfied within the applicable cure period referenced in Operating Agreement, section 15, then such Market Participant shall be restricted in all of its credit-screened transactions. Specifically, such Market Participant may not engage in any Virtual Transactions or Export Transactions, or participate in RPM Auctions or other RPM activity. Such Market Participant may engage only in the selling of open FTR positions, either in FTR auctions or bilaterally, provided such sales would reduce the Market Participant's FTR Credit Requirements. PJM shall not return any Collateral to such Market Participant, and no payment shall be due or payable to such Market Participant, until its credit shortfall is remedied. Market Participant shall allocate any excess or unallocated Collateral to any of its account in which there is a credit shortfall. Market Participants may remedy their credit shortfall at any time through provision of sufficient Collateral.

If a Market Participant fails to satisfy a request for Collateral for two consecutive auctions of overlapping periods, e.g. two balance of Planning Period auctions, an annual FTR auction and a balance of Planning Period auction, or two long term FTR auctions, (for this purpose the four rounds of an annual FTR auction shall be considered a single auction), the Market Participant shall be declared in default of this Attachment Q.

VII. PEAK MARKET ACTIVITY AND WORKING CREDIT LIMIT

A. Peak Market Activity Credit Requirement

PJM shall calculate a Peak Market Activity credit requirement for each Participant. Each Participant must maintain sufficient Unsecured Credit Allowance and/or Collateral, as applicable, and subject to the provisions herein, to satisfy its Peak Market Activity credit requirement.

Peak Market Activity for Participants will be determined semi-annually, utilizing an initial Peak Market Activity, as explained below, calculated after the first complete billing week in the months of April and October. Peak Market Activity shall be the greater of the initial Peak Market Activity, or the greatest amount invoiced for the Participant's transaction activity for all

PJM Markets and services in any rolling one, two, or three week period, ending within a respective semi-annual period. However, Peak Market Activity shall not exceed the greatest amount invoiced for the Participant's transaction activity for all PJM Markets and services in any rolling one, two or three week period in the prior 52 weeks.

Peak Market Activity shall exclude FTR Net Activity, Virtual Transactions Net Activity, and Export Transactions Net Activity.

When calculating Peak Market Activity, PJM may attribute credits for Regulation service to the days on which they were accrued, rather than including them in the month-end invoice.

The initial Peak Market Activity for Applicants will be determined by PJM based on a review of an estimate of their transactional activity for all PJM Markets and services over the next 52 weeks, which the Applicant shall provide to PJM.

The initial Peak Market Activity for Market Participants and Transmission Customers, calculated at the beginning of each semi-annual period, shall be the three-week average of all non-zero invoice totals over the previous 52 weeks. This calculation shall be performed and applied within three (3) Business Days following the day the invoice is issued for the first full billing week in the current semi-annual period.

Prepayments shall not affect Peak Market Activity unless otherwise agreed to in writing pursuant to this Attachment Q.

Peak Market Activity calculations shall take into account reductions of invoice values effectuated by early payments which are applied to reduce a Participant's Peak Market Activity as contemplated by other terms of this Attachment Q; provided that the initial Peak Market Activity shall not be less than the average value calculated using the weeks for which no early payment was made.

A Participant may reduce its Collateral requirement by agreeing in writing (in a form acceptable to PJM) to make additional payments, including prepayments, as and when necessary to ensure that such Participant's Total Net Obligation at no time exceeds such reduced Collateral requirement.

PJM may, at its discretion, adjust a Participant's Peak Market Activity requirement if PJM determines that the Peak Market Activity is not representative of such Participant's expected activity, as a consequence of known, measurable, and sustained changes. Such changes may include, but shall not be limited to when a Participant makes PJM aware of federal, state or local law that could affect the allocation of charges or credits from a Participant to another party, the loss (without replacement) of short-term load contracts, when such contracts had terms of three months or more and were acquired through state-sponsored retail load programs, but shall not include short-term buying and selling activities.

PJM may waive the credit requirements for a Participant that has no outstanding transactions and agrees in writing that it shall not, after the date of such agreement, incur obligations under any of

the Agreements. Such entity's access to all electronic transaction systems administered by PJM shall be terminated.

A Participant receiving unsecured credit may make early payments up to ten times in a rolling 52-week period in order to reduce its Peak Market Activity for credit requirement purposes. Imputed Peak Market Activity reductions for credit purposes will be applied to the billing period for which the payment was received. Payments used as the basis for such reductions must be received prior to issuance or posting of the invoice for the relevant billing period. The imputed Peak Market Activity reduction attributed to any payment may not exceed the amount of Unsecured Credit for which the Participant is eligible.

B. Working Credit Limit

PJM will establish a Working Credit Limit for each Participant against which its Total Net Obligation will be monitored.

If a Participant's Total Net Obligation approaches its Working Credit Limit, PJM may require the Participant to make an advance payment or increase its Collateral in order to maintain its Total Net Obligation below its Working Credit Limit. Except as explicitly provided herein, advance payments shall not serve to reduce the Participant's Peak Market Activity for the purpose of calculating credit requirements.

Example: After ten (10) calendar days, and with five (5) calendar days remaining before the bill is due to be paid, a Participant approaches its \$4.0 million Working Credit Limit. PJM may require a prepayment of \$2.0 million in order that the Total Net Obligation will not exceed the Working Credit Limit.

If a Participant exceeds its Working Credit Limit or is required to make advance payments more than ten times during a 52-week period, PJM may require Collateral in an amount as may be deemed reasonably necessary to support its Total Net Obligation.

When calculating Total Net Obligation, PJM may attribute credits for Regulation service to the days on which they were accrued, rather than including them in the month-end invoice.

VIII. SUSPENSION OR LIMITATION ON MARKET PARTICIPATION

If PJM determines that a Participant presents an unreasonable credit risk as determined pursuant to initial or ongoing risk evaluations, as described in section II above, or in the case of any other event which, after notice, lapse of time, or both, would result in an Event of Default, PJM will take steps to mitigate the exposure of any PJM Markets, which may include, but is not limited to, requiring Collateral, additional Collateral or Restricted Collateral or suspending or limiting the Market Participant's ability to participate in the PJM Markets commensurate to the risk to any PJM Markets.

If a Participant fails to reduce or eliminate any unreasonable credit risks to PJM's satisfaction within the applicable cure period including without limitation by posting Collateral, additional Collateral or Restricted Collateral, PJM may treat such failure as an Event of Default.

Notwithstanding the foregoing, a Participant that transacts in FTRs will be eligible to request that PJM exempt or exclude FTR transactions of such Participant from the effect of any such limitations on market activity established by PJM, and PJM may but shall not be required to so exempt or exclude, any FTR transactions that the Participant reasonably demonstrates to PJM it has entered into to “hedge or mitigate commercial risk” arising from its transactions in the PJM Interchange Energy Market that are intended to result in the actual flow of physical energy or ancillary services in the PJM Region, as the phrase “hedge or mitigate commercial risks” is defined under the CFTC’s regulations defining the end-user exception to clearing set forth in 17 C.F.R. §50.50(c).

IX. REMEDIES FOR CREDIT BREACH, FINANCIAL DEFAULT OR CREDIT SUPPORT DEFAULT; REMEDIES FOR EVENTS OF DEFAULT

If PJM determines that a Market Participant is in Credit Breach, or that a Financial Default or Credit Support Default exists, PJM may issue to the Market Participant a breach notice and/or a Collateral Call or demand for additional documentation or assurances. At such time, PJM may also suspend payments of any amounts due to the Participant and limit, restrict or rescind the Market Participant’s privileges to participate in any or all PJM Markets under the Agreements during any such cure period. Failure to remedy the Credit Breach, Financial Default or to satisfy a Collateral Call or demand for additional documentation or assurances within the applicable cure period described in Operating Agreement, section 15.1.5, shall constitute an Event of Default. If a Participant fails to meet the requirements of this Attachment Q, but then remedies the Credit Breach, Financial Default or Credit Support Default, or satisfies a Collateral Call or demand for additional documentation or assurances within the applicable cure period, then the Participant shall be deemed to again be in compliance with this Attachment Q, so long as no other Credit Breach, Financial Default, Credit Support Default or Collateral Call or demand for additional documentation or assurances has occurred and is continuing.

Only one cure period shall apply to a single event giving rise to a Credit Breach, Financial Default or Credit Support Default. Application of Collateral towards a Financial Default, Credit Breach or Credit Support Breach shall not be considered a cure of such Credit Breach, Financial Default or Credit Support Default unless the Participant is determined by PJM to be in full compliance with all requirements of this Attachment Q after such application.

When an Event of Default under this Attachment Q or one or more of the Agreements has occurred and is continuing, PJM may take such actions as may be required or permitted under the Agreements to protect the PJM Markets and the PJM Members, including but not limited to (a) suspension and/or termination of the Participant’s ongoing Transmission Service, (b) limitation, suspension and/or termination of participation in any PJM Markets, (c) close out and liquidation of the Market Participant’s market portfolio, exercising judgment in the manner in which this is achieved in any PJM Markets.

When an Event of Default under this Attachment Q or one or more of the Agreements has occurred and is continuing, PJM also has the immediate right to liquidate all or a portion of a Participant’s Collateral at its discretion to satisfy Total Net Obligations to PJM under this Attachment Q or one or more of the Agreements. No remedy for an Event of Default is or shall

be deemed to be exclusive of any other available remedy or remedies by contract or under applicable laws and regulations. Each such remedy shall be distinct, separate and cumulative, shall not be deemed inconsistent with or in exclusion of any other available remedy, and shall be in addition to and separate and distinct from every other remedy.

When an Event of Default under this Attachment Q or one or more of the Agreements has occurred and is continuing, PJM may continue to retain all payments due to a Participant as a cash security for all such Participant's obligations under the Agreements (regardless of any restrictions placed on such Participant's use of Collateral for any account, market activity or capitalization purpose); provided, however, that an Event of Default will not be deemed cured or no longer continuing because PJM is retaining amounts due the Participant, or because PJM has not yet applied Collateral or credit support to any amounts due PJM, unless PJM determines that the Participant has again satisfied all the Collateral requirements and application requirements as a new Applicant for participation in the PJM Markets, and consistent with the requirements and limitations of Operating Agreement, section 15.

In Event of Default by a Participant, PJM may exercise any remedy or action allowed or prescribed by this Attachment Q immediately or following investigation and determination of an orderly exercise of such remedy or action. Delay in exercising any allowed remedy or action shall not preclude PJM from exercising such remedy or action at a later time.

PJM may hold a defaulting Participant's Collateral for as long as such party's positions exist and consistent with this Attachment Q, in order to protect the PJM Markets and PJM's membership, and minimize or mitigate the impacts or potential impacts or risks associated with such Event of Default when an Event of Default under this Attachment Q or one or more of the Agreements has occurred and is continuing.

PJM may apply towards an ongoing Event of Default any amounts that are held or later become available or due to the defaulting Participant through PJM's markets and systems.

In order to cover the Participant's Obligations, PJM may hold a Participant's Collateral indefinitely and specifically through the end of the billing period which includes the 90th day following the last day a Participant had activity, open positions, or accruing obligations (other than reconciliations and true-ups), until such Participant has satisfactorily paid any obligations invoiced through such period and until PJM determines that the Participant's positions represent no risk exposure to the PJM Markets or the PJM Members. Obligations incurred or accrued through such period shall survive any withdrawal from PJM. When an Event of Default under this Attachment Q or one or more of the Agreements has occurred and is continuing, PJM may apply any Collateral to such Participant's Obligations, even if Participant had previously announced and effected its withdrawal from PJM.

X. FTRS UNDER THE COMMODITY EXCHANGE ACT AND THE BANKRUPTCY CODE

Under the terms of the Tariff, PJM Settlement is the counterparty to all transactions in PJM Markets, including but not limited to all FTR transactions, other than (i) any bilateral

transactions between Participants, or (ii) with respect to self-supplied or self-scheduled transactions reported to the Office of the Interconnection. Pursuant to the “Final Order in Response to a Petition From Certain Independent System Operators and Regional Transmission Organizations To Exempt Specified Transactions Authorized by a Tariff or Protocol Approved by the Federal Energy Regulatory Commission or the Public Utility Commission of Texas From Certain Provisions of the Commodity Exchange Act Pursuant to the Authority Provided in the Act” 78 Fed. Reg. 19880 (April 2, 2013) (the “CFTC RTO/ISO Order”), the Commodity Futures Trading Commission (the “CFTC”) exempts transactions offered or entered into in a market administered by PJM pursuant to the Tariff, including but not limited to FTR transactions, from the provisions of the Commodity Exchange Act and the CFTC’s rules applicable to “swaps,” with the exception of the CFTC’s general anti-fraud and anti-manipulation authority and scienter-based prohibitions.

Notwithstanding the CFTC RTO/ISO Order, for purposes of the United States Bankruptcy Code (“Bankruptcy Code”), all FTR transactions constitute “swap agreements” and/or “forward contracts,” and PJM and each FTR Participant is a “forward contract merchant” and/or a “swap participant” within the meaning of the Bankruptcy Code for purposes of FTR transactions.

Pursuant to this Attachment Q and other provisions of the Agreements, PJM already has, and shall continue to have, the following rights (among other rights) with respect to a Market Participant’s Event of Default: (a) the right to terminate and/or liquidate any FTR transaction held by that Market Participant; (b) the right to immediately proceed against any Collateral provided by the Market Participant; (c) the right to set-off any obligations due or owing to that Market Participant pursuant to any forward contract, swap agreement, or similar agreement against any amounts due and owing by that Market Participant pursuant to any forward contract, swap agreement, or similar agreement, such arrangement to constitute a “master netting agreement” within the meaning of the Bankruptcy Code; and (d) the right to suspend or limit that Market Participant from entering into further FTR transactions.

For the avoidance of doubt, upon the commencement of a voluntary or involuntary proceeding for a Participant under the Bankruptcy Code, and without limiting any other rights of PJM or obligations of any Participant under the Agreements, PJM may exercise any of its rights against such Participant, including, without limitation (1) the right to terminate and/or liquidate any FTR transaction held by that Participant, (2) the right to immediately proceed against any Collateral provided by that Participant, (3) the right to set off any obligations due and owing to that Participant pursuant to any forward contract, swap agreement and/or master netting agreement against any amounts due and owing by that Participant with respect to an FTR transaction including as a result of the actions taken by PJM pursuant to (a) above, and 4) the right to suspend or limit that Participant from entering into future FTR transactions.

For purposes of the Bankruptcy Code, all transactions, including but not limited to FTR transactions, between PJM, on the one hand, and a Market Participant, on the other hand, are intended to be part of a single integrated agreement, and together with the Agreements constitute a “master netting agreement.”

Attachment Q
Appendix 1

PJM MINIMUM PARTICIPATION CRITERIA
ANNUAL OFFICER CERTIFICATION FORM

Participant Name: _____ (**"Participant"**)

I, _____, a duly authorized officer of Participant, understanding that PJM Interconnection, L.L.C. and PJMSettlement, Inc. ("PJMSettlement") are relying on this certification as evidence that Participant meets the minimum requirements set forth in the PJM Open Access Transmission Tariff ("PJM Tariff"), Attachment Q hereby certify that I have full authority to represent on behalf of Participant and further represent as follows, as evidenced by my initialing each representation in the space provided below:

1. All employees or agents transacting in markets or services provided pursuant to the PJM Tariff or PJM Amended and Restated Operating Agreement ("PJM Operating Agreement") on behalf of the Participant have received appropriate training and are authorized to transact on behalf of Participant. As used in this representation, the term "appropriate" as used with respect to training means training that is (i) comparable to generally accepted practices in the energy trading industry, and (ii) commensurate and proportional in sophistication, scope and frequency to the volume of transactions and the nature and extent of the risk taken by the participant. _____
2. Participant has written risk management policies, procedures, and controls, approved by Participant's independent risk management function and applicable to transactions in any PJM Markets in which it participates and for which employees or agents transacting in markets or services provided pursuant to the PJM Tariff or PJM Operating Agreement have been trained, that provide an appropriate, comprehensive risk management framework that, at a minimum, clearly identifies and documents the range of risks to which Participant is exposed, including, but not limited to credit risks, liquidity risks and market risks. As used in this representation, a Participant's "independent risk management function" can include appropriate corporate persons or bodies that are independent of the Participant's trading functions, such as a risk management committee, a risk officer, a Participant's board or board committee, or a board or committee of the Participant's parent company.
 - a. Participant is providing to PJM or PJMSettlement, in accordance with Tariff, Attachment Q, section III, with this Annual Officer Certification Form, a copy of its current governing risk management policies, procedures and controls applicable to its activities in any PJM Markets pursuant to Attachment Q or because there have been substantive changes made to such policies, procedures and controls applicable to its market activities since they were last provided to PJM. _____
 - b. If the risk management policies, procedures and controls applicable to Participant's market activities submitted to PJM or PJMSettlement were submitted prior to the current certification, Participant certifies that no substantive changes have

been made to such policies, procedures and controls applicable to its market activities since such submission. _____

3. An FTR Participant must make either the following 3.a. or 3.b. additional representations, evidenced by the undersigned officer initialing either the one 3.a. representation or the four 3.b. representations in the spaces provided below:

- a. Participant transacts in PJM’s FTR markets with the sole intent to hedge congestion risk in connection with either obligations Participant has to serve load or rights Participant has to generate electricity in the PJM Region (“physical transactions”) and monitors all of the Participant’s FTR market activity to endeavor to ensure that its FTR positions, considering both the size and pathways of the positions, are either generally proportionate to or generally do not exceed the Participant’s physical transactions, and remain generally consistent with the Participant’s intention to hedge its physical transactions. _____

- b. On no less than a weekly basis, Participant values its FTR positions and engages in a probabilistic assessment of the hypothetical risk of such positions using analytically based methodologies, predicated on the use of industry accepted valuation methodologies. _____

Such valuation and risk assessment functions are performed either by persons within Participant’s organization independent from those trading in PJM’s FTR markets or by an outside firm qualified and with expertise in this area of risk management. _____

Having valued its FTR positions and quantified their hypothetical risks, Participant applies its written policies, procedures and controls to limit its risks using industry recognized practices, such as value-at-risk limitations, concentration limits, or other controls designed to prevent Participant from purposefully or unintentionally taking on risk that is not commensurate or proportional to Participant’s financial capability to manage such risk. _____

Exceptions to Participant’s written risk policies, procedures and controls applicable to Participant’s FTR positions are documented and explain a reasoned basis for the granting of any exception. _____

4. Participant has appropriate personnel resources, operating procedures and technical abilities to promptly and effectively respond to all PJM and PJMSettlement communications and directions. _____
5. Participant has demonstrated compliance with the Minimum Capitalization criteria set forth in Tariff, Attachment Q that are applicable to any PJM Markets in which Participant transacts, and is not aware of any change having occurred or being imminent that would invalidate such compliance. _____

6. All Participants must certify and initial in at least one of the five sections below:
- a. I certify that Participant qualifies as an “appropriate person” as that term is defined under section 4(c)(3), or successor provision, of the Commodity Exchange Act or an “eligible contract participant” as that term is defined under section 1a(18), or successor provision, of the Commodity Exchange Act. I certify that Participant will cease transacting in any PJM Markets and notify PJM and PJMSettlement immediately if Participant no longer qualifies as an “appropriate person” or “eligible contract participant.” _____

If providing audited financial statements, which shall be in US GAAP format or any other format acceptable to PJM, to support Participant’s certification of qualification as an “appropriate person:”

I certify, to the best of my knowledge and belief, that the audited financial statements provided to PJM and/or PJMSettlement present fairly, pursuant to such disclosures in such audited financial statements, the financial position of Participant as of the date of those audited financial statements. Further, I certify that Participant continues to maintain the minimum \$1 million total net worth and/or \$5 million total asset levels reflected in these audited financial statements as of the date of this certification. I acknowledge that both PJM and PJMSettlement are relying upon my certification to maintain compliance with federal regulatory requirements. _____

If not providing audited financial statements to support Participant’s certification of qualification as an “appropriate person,” Participant certifies that they qualify as an “appropriate person” under one of the entities defined in section 4(c)(3)(A)-(J) of the Commodities Exchange Act. _____

If providing audited financial statements, which shall be in US GAAP format or any other format acceptable to PJM, to support Participant’s certification of qualification as an “eligible contract participant:”

I certify, to the best of my knowledge and belief, that the audited financial statements provided to PJM and/or PJMSettlement present fairly, pursuant to such disclosures in such audited financial statements, the financial position of Participant as of the date of those audited financial statements. Further, I certify that Participant continues to maintain the minimum \$1 million total net worth and/or \$10 million total asset levels reflected in these audited financial statements as of the date of this certification. I acknowledge that both PJM and PJMSettlement are relying upon my certification to maintain compliance with federal regulatory requirements. _____

If not providing audited financial statements to support Participant’s certification of qualification as an “eligible contract participant,” Participant certifies that they

qualify as an “eligible contract participant” under one of the entities defined in section 1a(18)(A) of the Commodities Exchange Act. _____

- b. I certify that Participant has provided an unlimited Corporate Guaranty in a form acceptable to PJM as described in Tariff, Attachment Q, section III.D from an issuer that has at least \$1 million of total net worth or \$5 million of total assets per Participant for which the issuer has issued an unlimited Corporate Guaranty. I also certify, to the best of my knowledge and belief, that the audited financial statements provided to PJM and/or PJMSettlement present fairly, pursuant to such disclosures in such audited financial statements, the financial position of the issuer as of the date of those audited financial statements. Further, I certify that Participant will cease transacting PJM’s Markets and notify PJM and PJMSettlement immediately if issuer of the unlimited Corporate Guaranty for Participant no longer has at least \$1 million of total net worth or \$5 million of total assets per Participant for which the issuer has issued an unlimited Corporate Guaranty. _____

I certify that the issuer of the unlimited Corporate Guaranty to Participant continues to have at least \$1 million of total net worth or \$5 million of total assets per Participant for which the issuer has issued an unlimited Corporate Guaranty. I acknowledge that PJM and PJMSettlement are relying upon my certifications to maintain compliance with federal regulatory requirements. _____

- c. I certify that Participant fulfills the eligibility requirements of the Commodity Futures Trading Commission exemption order (78 F.R. 19880 – April 2, 2013) by being in the business of at least one of the following in the PJM Region as indicated below (initial those applicable):

1. Generating electric energy, including Participants that resell physical energy acquired from an entity generating electric energy: _____
2. Transmitting electric energy: _____
3. Distributing electric energy delivered under Point-to-Point or Network Integration Transmission Service, including scheduled import, export and wheel through transactions: _____
4. Other electric energy services that are necessary to support the reliable operation of the transmission system: _____

Description only if c(4) is initialed:

Further, I certify that Participant will cease transacting in any PJM Markets and notify PJM and PJMSettlement immediately if Participant no longer performs at least one of the functions noted above in the PJM Region. I acknowledge that PJM and

PJMSettlement are relying on my certification to maintain compliance with federal energy regulatory requirements. _____

- d. I certify that Participant has provided a Letter of Credit of \$5 million or more to PJM or PJMSettlement in a form acceptable to PJM and/or PJMSettlement as described in Tariff, Attachment Q, section V.B that the Participant acknowledges cannot be utilized to meet its credit requirements to PJM and PJMSettlement. I acknowledge that PJM and PJMSettlement are relying on the provision of this letter of credit and my certification to maintain compliance with federal regulatory requirements. _____
 - e. I certify that Participant has provided a surety bond of \$5 million or more to PJM or PJMSettlement in a form acceptable to PJM and/or PJMSettlement as described in Tariff, Attachment Q, section V.D. that the Participant acknowledges cannot be utilized to meet its credit requirements to PJM and PJMSettlement. I acknowledge that PJM and PJMSettlement are relying on the provision of this surety bond and my certification to maintain compliance with federal regulatory requirements. _____
7. I acknowledge that I have read and understood the provisions of Tariff, Attachment Q applicable to Participant's business in any PJM Markets, including those provisions describing PJM's Minimum Participation Requirements and the enforcement actions available to PJM and PJMSettlement of a Participant not satisfying those requirements. I acknowledge that the information provided herein is true and accurate to the best of my belief and knowledge after due investigation. In addition, by signing this certification, I acknowledge the potential consequences of making incomplete or false statements in this Certification. _____

Date: _____

Participant (Signature)

Print Name: _____

Title: _____

6.4 Market Seller Offer Caps

(a) The Market Seller Offer Cap, stated in dollars per MW/day of unforced capacity, applicable to price-quantity offers within the Base Offer Segment for an Existing Generation Capacity Resource shall be the Avoidable Cost Rate for such resource, less the Projected PJM Market Revenues for such resource, stated in dollars per MW/day of unforced capacity. A Capacity Market Seller offering above \$0/MW-day must support and obtain approval of a unit-specific Market Seller Offer Cap pursuant to the procedures and standards of subsection (b) of this section 6.4 or may, at its election, if available, utilize a Market Seller Offer Cap determined using the applicable default gross Avoidable Cost Rate for the applicable resource type shown in the table below, as adjusted for Delivery Years subsequent to the 2022/2023 or 2026/2027 Delivery Year, as applicable, to reflect changes in avoidable costs, net of Projected PJM Market Revenues equal to the resource's net energy and ancillary service revenues for the resource type, as determined in accordance with Tariff, Attachment DD, section 6.8(d).

Existing Resource Type	Through the 2025/2026 Delivery Years: Default Gross ACR (\$/MW-day) (Nameplate)	For the 2026/2027 Delivery Year and Subsequent Delivery Years: Default Gross ACR (\$/MW-day) (Nameplate)
Nuclear – single	\$697	\$591
Nuclear – dual	\$445	\$537
Coal	\$80	\$94
Combined Cycle	\$56	\$113
Combustion Turbine	\$50	\$52
Steam Oil & Gas	NA	\$64
Solar PV (fixed and tracking)	\$40	\$70
Wind Onshore	\$83	\$147

The Market Seller Offer Cap for an Existing Generation Capacity Resource shall be the Opportunity Cost for such resource, if applicable, as determined in accordance with Tariff, Attachment DD, section 6.7.

(b) For each Existing Generation Capacity Resource, a potential Capacity Market Seller must provide to the Market Monitoring Unit and the Office of the Interconnection data and documentation required under section 6.7 below to establish the level of the Market Seller Offer Cap applicable to each resource by no later than one hundred twenty (120) days prior to the commencement of the offer period for the applicable RPM Auction. The Capacity Market Seller must promptly address any concerns identified by the Market Monitoring Unit regarding the data and documentation provided, review the Market Seller Offer Cap proposed by the Market Monitoring Unit, and attempt to reach agreement with the Market Monitoring Unit on the level of the Market Seller Offer Cap by no later than ninety (90) days prior to the commencement of

the offer period for the applicable RPM Auction. The Capacity Market Seller shall notify the Market Monitoring Unit in writing, with a copy to the Office of the Interconnection, whether an agreement with the Market Monitoring Unit has been reached or, if no agreement has been reached, specifying the level of Market Seller Offer Cap to which it commits by no later than eighty (80) days prior to the commencement of the offer period for the applicable RPM Auction. The Office of the Interconnection shall review the data submitted by the Capacity Market Seller, make a determination whether to accept or reject the requested unit-specific Market Seller Offer Cap, and notify the Capacity Market Seller and the Market Monitoring Unit of its determination in writing, by no later than sixty-five (65) days prior to the commencement of the offer period for the applicable RPM Auction. In the event the Office of the Interconnection rejects the Capacity Market Seller's requested unit-specific Market Seller Offer Cap for a particular Capacity Resource, the Capacity Market Seller of such Capacity Resource may submit an offer up to (1) should one exist, the default gross Avoidable Cost Rate for the applicable resource type net of Projected PJM Market Revenues equal to the resource's net energy and ancillary service revenues for the resource type, or (2) the unit-specific Market Seller Offer Cap proposed by the Market Monitoring Unit upon PJM approval of such value. If the Market Monitoring Unit does not provide its determination to the Capacity Market Seller and the Office of the Interconnection by the specified deadline, by no later than sixty-five (65) days prior to the commencement of the offer period for the applicable RPM Auction the Office of the Interconnection will make the determination of the level of the Market Seller Offer Cap, which shall be deemed to be final. If the Capacity Market Seller does not notify the Market Monitoring Unit and the Office of the Interconnection of the Market Seller Offer Cap it desires to utilize by no later than eighty (80) days prior to the commencement of the offer period for the applicable RPM Auction, it shall be required to utilize a Market Seller Offer Cap determined using the applicable default Avoidable Cost Rate specified in section 6.4(a) above.

Notwithstanding the provisions of Tariff, Attachment M-Appendix, section II.E.2 and this Tariff, Attachment DD, section 6.4(b), no later than eighty (80) days prior to the commencement of the offer period for the auction, the Market Monitoring Unit and the relevant Capacity Market Seller may mutually agree on the value of such Market Seller Offer Cap. Nothing herein shall preclude the Market Monitoring Unit from modifying the Market Seller Offer Cap for a Generation Capacity Resource beyond the eighty-day (80-day) deadline prior to the commencement of the offer period for the auction, through the commencement of the offer period for the auction, so long as the Market Monitoring Unit and the relevant Capacity Market Seller mutually agree with the value of such Market Seller Offer Cap. The Capacity Market Seller shall notify the Market Monitoring Unit in writing, with a copy to the Office of the Interconnection, if such an agreement with the Market Monitoring Unit has been reached. The Office of the Interconnection shall review the Market Seller Offer Cap submitted by the Capacity Market Seller and make a determination whether the Market Seller Offer Cap complies with the tariff, and notify the Capacity Market Seller and the Market Monitoring Unit of its determination.

(c) Nothing in this section precludes the Capacity Market Seller from filing a petition with FERC seeking a determination of whether the Sell Offer complies with the requirements of the Tariff.

(d) For any Third Incremental Auction for the 2018/2019 Delivery Year or any subsequent Delivery Year, the Market Seller Offer Cap for an Existing Generation Capacity Resource offering as a Capacity Performance Resource shall be determined pursuant to subsection (a) of this Section 6.4, or if elected by the Capacity Market Seller, shall be equal to 1.1 times the Capacity Resource Clearing Price in the Base Residual Auction for the relevant LDA and Delivery Year.

6.5 Mitigation

The Office of the Interconnection shall apply market power mitigation measures in any Base Residual Auction or Incremental Auction for any LDA, Unconstrained LDA Group, or the PJM Region that fails the Market Structure Test.

(a) Mitigation for Generation Capacity Resources.

i) Existing Generation Capacity Resource

Mitigation will be applied on a unit-specific basis and only if the Sell Offer of Unforced Capacity from an Existing Generation Capacity Resource: (1) is greater than \$0/MW-day, except as described in Tariff, Attachment DD, section 6.4(a); and (2) would, absent mitigation, increase the Capacity Resource Clearing Price in the relevant auction. If such conditions are met, such Sell Offer shall be set equal to the Market Seller Offer Cap.

ii) Planned Generation Capacity Resources

(A) Sell Offers based on Planned Generation Capacity Resources (including External Planned Generation Capacity Resources) shall be presumed to be competitive and shall not be subject to market power mitigation in any Base Residual Auction or Incremental Auction for which such resource qualifies as a Planned Generation Capacity Resource, but any such Sell Offer shall be rejected if it meets the criteria set forth in subsection (C) below, unless the Capacity Market Seller obtains approval from FERC for use of such offer prior to the close of the offer period for the applicable RPM Auction.

(B) Sell Offers based on Planned Generation Capacity Resources (including Planned External Generation Capacity Resources) shall be deemed competitive and not be subject to mitigation if: (1) collectively all such Sell Offers provide Unforced Capacity in an amount equal to or greater than two times the incremental quantity of new entry required to meet the LDA Reliability Requirement; and (2) at least two unaffiliated suppliers have submitted Sell Offers for Planned Generation Capacity Resources in such LDA. Notwithstanding the foregoing, any Capacity Market Seller, together with affiliates, whose Sell Offers based on Planned Generation Capacity Resources in that modeled LDA are pivotal, shall be subject to mitigation.

(C) Where the two conditions stated in subsection (B) above are not met, or the Sell Offer is pivotal, the Sell Offer shall be rejected if it exceeds 140 percent of: 1) the average of location-adjusted Sell Offers for Planned Generation Capacity Resources from the same asset class as such Sell Offer, submitted (and not rejected) (Asset-Class New Plant Offers) for such Delivery Year; or 2) if there are no Asset-Class New Plant Offers

for such Delivery Year, the average of Asset-Class New Plant Offers for all prior Delivery Years; or 3) if there are no Asset-Class New Plant Offers for any prior Delivery Year, the Net CONE applicable for such Delivery Year in the LDA for which such Sell Offer was submitted. For purposes of this section, asset classes shall be as stated in section 6.7(c) below as effective for such Delivery Year, and Asset-Class New Plant Offers shall be location-adjusted by the ratio between the Net CONE effective for such Delivery Year for the LDA in which the Sell Offer subject to this section was submitted and the average, weighted by installed capacity, of the Net CONEs for all LDAs in which the units underlying such Asset Class New Plant Offers are located. Following the conduct of the applicable auction and before the final determination of clearing prices, in accordance with Section 6.2(b) above, each Capacity Market Seller whose Sell Offer is so rejected shall be notified in writing by the Office of the Interconnection by no later than one (1) Business Day after the close of the offer period for the applicable RPM Auction and allowed an opportunity to submit a revised Sell Offer that does not exceed such threshold within one (1) Business Day of the Office of the Interconnection's rejection of such Sell Offer. If such revised Sell Offer is accepted by the Office of the Interconnection, the Office of the Interconnection then shall clear the auction with such revised Sell Offer in place. Pursuant to Tariff, Attachment M-Appendix, Section II.F, the Market Monitoring Unit shall notify in writing each Capacity Market Seller whose Sell Offer has been determined to be non-competitive and subject to mitigation, with a copy to the Office of the Interconnection, by no later than one (1) Business Day after the close of the offer period for the applicable RPM Auction.

(b) Mitigation for Demand Resources

The Market Seller Offer Cap shall not be applied to Sell Offers of Demand Resources or Energy Efficiency Resources.

6.6 Offer Requirement for Capacity Resources

(a) To avoid application of subsection (h) below, all of the installed capacity of all Existing Generation Capacity Resources located in the PJM Region shall be offered by the Capacity Market Seller that owns or controls all or part of such resource (which may include submission as Self-Supply) in all RPM Auctions for each Delivery Year, less any amount determined by the Office of the Interconnection to be eligible for an exception to this RPM must-offer requirement, where installed capacity is determined as of the date on which bidding commences for each RPM Auction pursuant to Tariff, Attachment DD, section 5.6.6. The Unforced Capacity of such resources is determined using the EFORD value that is submitted by the Capacity Market Seller in its Sell Offer, which shall not exceed the maximum EFORD for that resource as defined in section 6.6(b). If a resource should be included on the list of Existing Generation Capacity Resources subject to the RPM must-offer requirement that is maintained by the Market Monitoring Unit pursuant to Tariff, Attachment M-Appendix, section II.C.1, but is omitted therefrom whether by mistake of the Market Monitoring Unit or failure of the Capacity Market Seller that owns or controls all or part of such resource to provide information about the resource to the Market Monitoring Unit, this shall not excuse such resource from the RPM must-offer requirement.

(b) For each Existing Generation Capacity Resource, a potential Capacity Market Seller must timely provide to the Market Monitoring Unit and the Office of the Interconnection all data and documentation required under this section 6.6 to establish the maximum EFORD applicable to each resource in accordance with standards and procedures specified in the PJM Manuals. The maximum EFORD that may be used in a Sell Offer for RPM Auctions held prior to the date on which the final EFORDs used for a Delivery Year are posted, is the greater of (i) the average EFORD for the five consecutive years ending on the September 30 that last precedes the Base Residual Auction, or (ii) the EFORD for the 12 months ending on the September 30 that last precedes the Base Residual Auction.

Notwithstanding the foregoing, a Capacity Market Seller may request an alternate maximum EFORD for Sell Offers submitted in such auctions if it has a documented, known reason that would result in an increase in its EFORD, by submitting a written request to the Market Monitoring Unit and Office of the Interconnection, along with data and documentation required to support the request for an alternate maximum EFORD, by no later one hundred twenty (120) days prior to the commencement of the offer period for the Base Residual Auction for the applicable Delivery Year. The Capacity Market Seller must address any concerns identified by the Market Monitoring Unit and/or the Office of the Interconnection regarding the data and documentation provided and attempt to reach agreement with the Market Monitoring Unit on the level of the alternate maximum EFORD by no later than ninety (90) days prior to the commencement of the offer period for the Base Residual Auction for the applicable Delivery Year. As further described in Tariff, Attachment M-Appendix, section II.C, the Market Monitoring Unit shall notify the Capacity Market Seller and the Office of the Interconnection in writing of its determination of the requested alternate maximum EFORD by no later than ninety (90) days prior to the commencement of the offer period for the Base Residual Auction for the applicable Delivery Year. By no later than eighty (80) days prior to the commencement of the offer period for the Base Residual Auction for the applicable Delivery Year, the Capacity Market

Seller shall notify the Office of the Interconnection and the Market Monitoring Unit in writing whether it agrees with the Market Monitoring Unit on the alternate maximum EFORD or, if no agreement has been reached, specifying the level of alternate maximum EFORD to which it commits. If a Capacity Market Seller fails to request an alternate maximum EFORD prior to the specified deadlines, the maximum EFORD for the applicable RPM Auction shall be deemed to be the default EFORD calculated pursuant to this section.

The maximum EFORD that may be used in a Sell Offer for Third Incremental Auction, and for Conditional Incremental Auctions held after the date on which the final EFORD used for a Delivery Year is posted, is the EFORD for the 12 months ending on the September 30 that last precedes the submission of such offers.

(c) [Reserved for Future Use]

(d) In the event that a Capacity Market Seller and the Market Monitoring Unit cannot agree on the maximum level of the alternate EFORD that may be used in a Sell Offer for RPM Auctions held prior to the date on which the final EFORDs used for a Delivery Year are posted, the Office of the Interconnection shall make its own determination of the maximum level of the alternate EFORD based on the requirements of the Tariff and the PJM Manuals, per Tariff, Attachment DD, section 5.8, by no later than sixty-five (65) days prior to the commencement of the offer period for the Base Residual for the applicable Delivery Year, and shall notify the Capacity Market Seller and the Market Monitoring Unit in writing of such determination.

(e) Nothing in this section precludes the Capacity Market Seller from filing a petition with FERC seeking a determination of whether the EFORD complies with the requirements of the Tariff.

(f) Notwithstanding the foregoing, a Capacity Market Seller may submit an EFORD that it chooses for an RPM Auction held prior to the date on which the final EFORD used for a Delivery Year is posted, provided that (i) it has participated in good faith with the process described in this section 6.6 and in Tariff, Attachment M-Appendix, section II.C, (ii) the offer is no higher than the level defined in any agreement reached by the Capacity Market Seller and the Market Monitoring Unit that resulted from the foregoing process, and (iii) the offer is accepted by the Office of the Interconnection subject to the criteria set forth in the Tariff and the PJM Manuals.

(g) A Capacity Market Seller that owns or controls an existing generation resource in the PJM Region that is capable of qualifying as an Existing Generation Capacity Resource as of the date on which bidding commences for an RPM Auction may not avoid the rule in subsection (a) or be removed from Capacity Resource status by failing to qualify as a Generation Capacity Resource, or by attempting to remove a unit previously qualified as a Generation Capacity Resource from classification as a Capacity Resource for that RPM Auction. However, generation resource may qualify for an exception to the RPM must-offer requirement, as shown by appropriate documentation, if the Capacity Market Seller that owns or controls such resource demonstrates that it: (i) is reasonably expected to be physically unable to participate in the relevant Delivery Year; (ii) has a financially and physically firm commitment to an external sale

of its capacity, or (iii) was interconnected to the Transmission System as an Energy Resource and not subsequently converted to a Capacity Resource.

In order to establish that a resource is reasonably expected to be physically unable to participate in the relevant auction as set forth in (i) above, the Capacity Market Seller must demonstrate that:

- A. It has a documented plan in place to retire the resource prior to or during the Delivery Year, and has submitted a notice of Deactivation to the Office of the Interconnection consistent with Tariff, Part V, section 113.1, without regard to whether the Office of the Interconnection has requested the Capacity Market Seller to continue to operate the resource beyond its desired deactivation date in accordance with Tariff, Part V, section 113.2 for the purpose of maintaining the reliability of the PJM Transmission System and the Capacity Market Seller has agreed to do so;
- B. Significant physical operational restrictions cause long term or permanent changes to the installed capacity value of the resource, or the resource is under major repair that will extend into the applicable Delivery Year, that will result in the imposition of RPM performance penalties pursuant to Tariff, Attachment DD;
- C. The Capacity Market Seller is involved in an ongoing regulatory proceeding (e.g. – regarding potential environmental restrictions) specific to the resource and has received an order, decision, final rule, opinion or other final directive from the regulatory authority that will result in the retirement of the resource; or
- D. A resource considered an Existing Generating Capacity Resource because it cleared an RPM Auction for a Delivery Year prior to the Delivery Year of the relevant auction, but which is not yet in service, is unable to achieve full commercial operation prior to the Delivery Year of the relevant auction. The Capacity Market Seller must submit to the Office of the Interconnection and the Market Monitoring Unit a written sworn, notarized statement of a corporate officer certifying that the resource will not be in full commercial operation prior to the referenced Delivery Year.

In order to establish that a resource has a financially and physically firm commitment to an external sale of its capacity as set forth in (ii) above, the Capacity Market Seller must demonstrate that it has entered into a unit-specific bilateral transaction for service to load located outside the PJM Region, by a demonstration that such resource is identified on a unit-specific basis as a network resource under the transmission tariff for the control area applicable to such external load, or by an equivalent demonstration of a financially and physically firm commitment to an external sale. The Capacity Market Seller additionally shall identify the megawatt amount, export zone, and time period (in days) of the export.

A Capacity Market Seller that seeks approval for an exception to the RPM must-offer requirement, for any reason other than the reason specified in Paragraph A above, shall first submit such request in writing, along with all supporting data and documentation, to the Market Monitoring Unit for evaluation, notifying the Office of the Interconnection by copy of the same,

by no later than one hundred twenty (120) days prior to the commencement of the offer period for the applicable RPM Auction.

In order to obtain an exception to the RPM must-offer requirement for the reason specified in Paragraph A above, a Capacity Market Seller shall first submit a preliminary exception request in writing, along with supporting data and documentation indicating the reasons and conditions upon which the Capacity Market Seller is relying in its analysis of whether to retire such resource, to the Market Monitoring Unit for evaluation, notifying the Office of the Interconnection by copy of the same, by no later than (a) November 1, 2013 for the Base Residual Auction for the 2017/2018 Delivery Year, (b) the September 1 that last precedes the Base Residual Auction for the 2018/2019 and subsequent Delivery Years, and (c) two hundred forty (240) days prior to the commencement of the offer period for the applicable Incremental Auction. By no later than five (5) Business Days after the notification deadline for any such preliminary exception requests, the Office of the Interconnection will post on its website a summary of the number of megawatts of Generation Capacity Resources for which it has received notification of preliminary exception requests, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.

Thereafter, as applicable, such Capacity Market Seller shall by no later than (a) the December 1 that last precedes the Base Residual Auction for the applicable Delivery Year, or (b) one hundred twenty (120) days prior to the commencement of the offer period for the applicable Incremental Auction, either (a) notify the Office of the Interconnection and the Market Monitoring Unit in writing that it is withdrawing its preliminary exception request and explaining the changes to its analysis of whether to retire such resource that support its decision to withdraw, or (b) demonstrate that it has met the requirements specified under Paragraph A above. By no later than five (5) Business Days after the notification deadline for such notification, the Office of the Interconnection will post on its website a revised summary of the number of megawatts of Generation Capacity Resources for which it has received requests for exceptions to the RPM must-offer requirement for the reason specified in Paragraph A above, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.

A Capacity Market Seller that seeks to remove a Generation Capacity Resource from Capacity Resource status shall first submit a preliminary request in writing, along with supporting data and documentation indicating the reasons and conditions upon which the Capacity Market Seller is relying in its analysis of whether to remove the Capacity Resource status of such resource to the Market Monitoring Unit for evaluation, notifying the Office of the Interconnection by copy of the same, by no later than (a) the September 1 that last precedes the Base Residual Auction, and (b) two hundred forty (240) days prior to the commencement of the offer period for the applicable Incremental Auction. For the Base Residual Auction for the 2023/2024 Delivery Year, a Capacity Market Seller that seeks to remove a Generation Capacity Resource from Capacity Resource status shall first submit such preliminary request by no later than November 1, 2019. By no later than five (5) Business Days after the notification deadline for any such preliminary requests, the Office of the Interconnection will post on its website a summary of the number of megawatts of Generation Capacity Resources for which it has

received notification of preliminary requests, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.

Thereafter, as applicable, such Capacity Market Seller shall, by no later than (a) the December 1 that last precedes the Base Residual Auction for the applicable Delivery Year, or (b) one hundred twenty (120) days prior to the commencement of the offer period for the applicable Incremental Auction, notify the Office of the Interconnection and the Market Monitoring Unit in writing that it is either (a) withdrawing its preliminary request and explaining the changes to its analysis that support its decision to withdraw, or (b) confirming its preliminary decision to remove the Generation Capacity Resource from Capacity Resource status. By no later than five (5) Business Days after the notification deadline for such notification, the Office of the Interconnection will post on its website a revised summary of the number of megawatts of Generation Capacity Resources for which it has received requests to remove its Capacity Resource status, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.

The Market Monitoring Unit shall analyze the effects of the proposed removal of a Generation Capacity Resource from Capacity Resource status with regard to potential market power issues and shall notify the Capacity Market Seller and the Office of the Interconnection in writing of its determination of the request to remove the Generation Capacity Resource from Capacity Resource status, and whether a market power issue has been identified, by no later than ninety (90) days prior to the commencement of the offer period for the applicable RPM Auction. Such notice shall include the specific market power impact resulting from the proposed removal of the Generation Capacity Resource from Capacity Resource status, as well as an initial assessment of any steps that could be taken to mitigate the market power impact.

A Capacity Market Seller may only remove the Generation Capacity Resource from Capacity Resource status if (i) the Market Monitoring Unit has determined that the Generation Capacity Resource meets the applicable criteria set forth in Tariff, Attachment DD, sections 5.6.6 and this section 6.6 and the Office of the Interconnection agrees with this determination, or (ii) the Commission has issued an order terminating the Capacity Resource status of the resource, or (iii) it is required as set forth in Tariff, Attachment DD, section 6.6A(c). Nothing herein shall require a Market Seller to offer its resource into an RPM Auction prior to seeking to remove a resource from Capacity Resource status, subject to satisfaction of this section 6.6. A Generation Capacity Resource that is removed from Capacity Resource status shall no longer qualify as an Existing Generation Capacity Resource, and the Capacity Interconnection Rights associated with such facility shall be subject to termination in accordance with the rules described in Tariff, Part VI, section 230.3.3. The Office of the Interconnection shall amend the applicable Interconnection Service Agreement or wholesale market participation agreement to reflect any such removal of the Capacity Interconnection Rights, and shall report the amended agreement to the Commission in the same manner as the original (e.g., FERC filing or Electronic Quarterly Reports). The Office of the Interconnection shall file the amended agreement unexecuted if the Interconnection Customer or wholesale market participant does not sign the amended Interconnection Service Agreement or wholesale market participation agreement.

If the Capacity Market Seller disagrees with the Market Monitoring Unit's determination of its request to remove a resource from Capacity Resource status or its request for an exception

to the RPM must-offer requirement, it must notify the Market Monitoring Unit in writing, with a copy to the Office of the Interconnection, of the same by no later than eighty (80) days prior to the commencement of the offer period for the applicable RPM Auction. After the Market Monitoring Unit has made its determination of whether a resource may be removed from Capacity Resource status, or whether the resource meets one of the exceptions thereto, and has notified the Capacity Market Seller and the Office of the Interconnection of the same pursuant to Tariff, Attachment M-Appendix, section II.C.4, the Office of the Interconnection shall approve or deny the request. The request shall be deemed to be approved by the Office of the Interconnection, consistent with the determination of the Market Monitoring Unit, unless the Office of the Interconnection notifies the Capacity Market Seller and Market Monitoring Unit, by no later than sixty-five (65) days prior to the date on which the offer period for the applicable RPM Auction commences, that the request is denied.

If the Market Monitoring Unit does not timely notify the Capacity Market Seller and the Office of the Interconnection of its determination of the request to remove a Generation Capacity Resource from Capacity Resource status or for an exception to the RPM must-offer requirement, the Office of the Interconnection shall make the determination whether the request shall be approved or denied, and will notify the Capacity Market Seller of its determination in writing, with a copy to the Market Monitoring Unit, by no later than sixty-five (65) days prior to the date on which the offer period for the applicable RPM Auction commences.

After the Market Monitoring Unit and the Office of the Interconnection have made their determinations of whether a resource meets the criteria to qualify for an exception to the RPM must-offer requirement, the Capacity Market Seller must notify the Market Monitoring Unit and the Office of the Interconnection whether it intends to exclude from its Sell Offer some or all of the subject capacity on the basis of an identified exception by no later than sixty-five (65) days prior to the date on which the offer period for the applicable RPM Auction commences. PJM does not make determinations of whether withholding of capacity constitutes market power. A Generation Capacity Resource that does not qualify for submission into an RPM Auction because it is not owned or controlled by the Capacity Market Seller for a full Delivery Year is not subject to the offer requirement hereunder; provided, however, that a Capacity Market Seller planning to transfer ownership or control of a Generation Capacity Resource during a Delivery Year pursuant to a sale or transfer agreement entered into after March 26, 2009 shall be required to satisfy the offer requirement hereunder for the entirety of such Delivery Year and may satisfy such requirement by providing for the assumption of this requirement by the transferee of ownership or control under such agreement.

If a Capacity Market Seller doesn't timely seek to remove a Generation Capacity Resource from Capacity Resource status or timely submit a request for an exception to the RPM must-offer requirement, the Generation Capacity Resource shall only be removed from Capacity Resource status, and may only be approved for an exception to the RPM must-offer requirement, upon the Capacity Market Seller requesting and receiving an order from FERC, prior to the close of the offer period for the applicable RPM Auction, directing the Office of the Interconnection to remove the resource from Capacity Resource status and/or granting an exception to the RPM must-offer requirement or a waiver of the RPM must-offer requirement as to such resource.

(h) Any existing generation resource located in the PJM Region that satisfies the criteria in the definition of Existing Generation Capacity Resource as of the date on which bidding commences for the Base Residual Auction for a Delivery Year, that is not offered into such Base Residual Auction, and that does not meet any of the exceptions stated in the prior subsection (g): (i) may not participate in any subsequent Incremental Auctions conducted for such Delivery Year; (ii) shall not receive any payments under Tariff, Attachment DD, section 5.14 for such Delivery Year for the capacity of such Generation Capacity Resources; and (iii) shall not be permitted to satisfy any LSE's Unforced Capacity Obligation, or any entity's obligation to obtain the commitment of Capacity Resources, for such Delivery Year.

All generation resources located in the PJM Region that satisfy the criteria in the definition of Existing Generation Capacity Resource as of the date on which bidding commences for an Incremental Auction for a particular Delivery Year, but that did not satisfy such criteria as of the date that on which bidding commenced in the Base Residual Auction for that Delivery Year, that is not offered into that Incremental Auction, and that does not meet any of the exceptions stated in the prior subsection (g): (i) may not participate in any subsequent Incremental Auctions conducted for such Delivery Year; (ii) shall not receive any payments under Tariff, Attachment DD, section 5.14 for such Delivery Year for the capacity of such Generation Capacity Resources; and (iii) shall not be permitted to satisfy any LSE's Unforced Capacity Obligation, or any entity's obligation to obtain the commitment of Capacity Resources, for such Delivery Year.

All Existing Generation Capacity Resources that are offered into a Base Residual Auction or Incremental Auction for a particular Delivery Year but do not clear in such auction, that are not offered into each subsequent Incremental Auction, and that do not meet any of the exceptions stated in the prior subsection (g): (i) may not participate in any Incremental Auctions conducted for such Delivery Year subsequent to such failure to offer; (ii) shall not receive any payments under Tariff, Attachment DD, section 5.14 for such Delivery Year for the capacity of such Generation Capacity Resources; and (iii) shall not be permitted to satisfy any LSE's Unforced Capacity Obligation, or any entity's obligation to obtain the commitment of Capacity Resources, for such Delivery Year.

Any such Existing Generation Capacity Resources may also be subject to further action by the Market Monitoring Unit under the terms of Tariff, Attachment M and Tariff, Attachment M – Appendix.

(i) In addition to the remedies set forth in subsections (g) and (h) above, if the Market Monitoring Unit determines that one or more Capacity Market Sellers' failure to offer part or all of one or more existing generation resources, for which the Office of the Interconnection has not approved an exception to the RPM must-offer requirement, into an RPM Auction as required by this Section 6.6 would result in an increase of greater than five percent in any Zonal Capacity Price determined through such auction, and the Office of the Interconnection agrees with that determination, the Office of the Interconnection shall apply to FERC for an order, on an expedited basis, directing such Capacity Market Seller to participate in the relevant RPM Auction, or for other appropriate relief, and PJM will postpone clearing the auction pending FERC's decision on the matter. If the Office of the Interconnection disagrees with the

Market Monitoring Unit's determination and does not apply to FERC for an order directing the Capacity Market Seller to participate in the auction or for other appropriate relief, the Market Monitoring Unit may exercise its powers to inform Commission staff of its concerns and to seek appropriate relief.

Definitions C - D

Capacity Resource:

“Capacity Resource” shall have the meaning provided in the Reliability Assurance Agreement.

Capacity Storage Resource:

“Capacity Storage Resource” shall mean any Energy Storage Resource that participates in the Reliability Pricing Model or is otherwise treated as capacity in PJM’s markets such as through a Fixed Resource Requirement Capacity Plan.

Catastrophic Force Majeure:

“Catastrophic Force Majeure” shall not include any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, or curtailment, order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, unless as a consequence of any such action, event, or combination of events, either (i) all, or substantially all, of the Transmission System is unavailable, or (ii) all, or substantially all, of the interstate natural gas pipeline network, interstate rail, interstate highway or federal waterway transportation network serving the PJM Region is unavailable. The Office of the Interconnection shall determine whether an event of Catastrophic Force Majeure has occurred for purposes of this Agreement, the PJM Tariff, and the Reliability Assurance Agreement, based on an examination of available evidence. The Office of the Interconnection’s determination is subject to review by the Commission.

Charge Economic Maximum Megawatts:

“Charge Economic Maximum Megawatts” shall mean the greatest magnitude of megawatt power consumption available for charging in economic dispatch by an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource in Continuous Mode or in Charge Mode. Charge Economic Maximum Megawatts shall be the Economic Minimum for an Energy Storage Resource or solar-storage Open-Loop Hybrid Resource in Charge Mode or in Continuous Mode.

Charge Economic Minimum Megawatts:

“Charge Economic Minimum Megawatts” shall mean the smallest magnitude of megawatt power consumption available for charging in economic dispatch by an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource in Charge Mode. Charge Economic Minimum Megawatts shall be the Economic Maximum for an Energy Storage Resource or solar-storage Open-Loop Hybrid Resource in Charge Mode.

Charge Mode:

“Charge Mode” shall mean the mode of operation of an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource that only includes negative megawatt quantities (i.e., the Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource is only withdrawing megawatts from the grid).

Charge Ramp Rate:

“Charge Ramp Rate” shall mean the Ramping Capability of an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource in Charge Mode.

Closed-Loop Hybrid Resource:

“Closed-Loop Hybrid Resource” shall mean a Hybrid Resource that is physically or contractually incapable of charging from the grid.

Cold/Warm/Hot Notification Time:

“Cold/Warm/Hot Notification Time” shall mean the time interval between PJM notification and the beginning of the start sequence for a generating unit that is currently in its cold/warm/hot temperature state. The start sequence may include steps such as any valve operation, starting feed water pumps, startup of auxiliary equipment, etc.

Cold/Warm/Hot Start-up Time:

For all generating units that are not combined cycle units, “Cold/Warm/Hot Start-up Time” shall mean the time interval, measured in hours, from the beginning of the start sequence to the point after generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero for a generating unit in its cold/warm/hot temperature state. For combined cycle units, “Cold/Warm/Hot Start-up Time” shall mean the time interval from the beginning of the start sequence to the point after first combustion turbine generator breaker closure in its cold/warm/hot temperature state, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero. For all generating units, the start sequence may include steps such as any valve operation, starting feed water pumps, startup of auxiliary equipment, etc. Other more detailed actions that could signal the beginning of the start sequence could include, but are not limited to, the operation of pumps, condensers, fans, water chemistry evaluations, checklists, valves, fuel systems, combustion turbines, starting engines or systems, maintaining stable fuel/air ratios, and other auxiliary equipment necessary for startup.

Cold Weather Alert:

“Cold Weather Alert” shall mean the notice that PJM provides to PJM Members, Transmission Owners, resource owners and operators, customers, and regulators to prepare personnel and facilities for expected extreme cold weather conditions.

Co-Located Resource:

“Co-Located Resource” shall mean a component of a Mixed Technology Facility that operates in the capacity, energy, and/or ancillary services market(s) as a separate resource from the other components of such facility.

Committed Offer:

The “Committed Offer shall mean 1) for pool-scheduled resources, an offer on which a resource was scheduled by the Office of the Interconnection for a particular clock hour for an Operating Day, and 2) for self-scheduled resources, either the offer on which the Market Seller has elected to schedule the resource or the applicable offer for the resource determined pursuant to Operating Agreement, Schedule 1, section 6.4, and the parallel provisions of Tariff, Attachment K-Appendix, section 6.4, or Operating Agreement, Schedule 1, section 6.6, and the parallel provisions of Tariff, Attachment K-Appendix, section 6.6, for a particular clock hour for an Operating Day.

Compliance Monitoring and Enforcement Program:

“Compliance Monitoring and Enforcement Program” shall mean the program to be used by the NERC and the Regional Entities to monitor, assess and enforce compliance with the NERC Reliability Standards. As part of a Compliance Monitoring and Enforcement Program, NERC and the Regional Entities may, among other things, conduct investigations, determine fault and assess monetary penalties.

Composite Energy Offer:

“Composite Energy Offer” for generation resources shall mean the sum (in \$/MWh) of the Incremental Energy Offer and amortized Start-Up Costs and amortized No-load Costs, and for Economic Load Response Participant resources the sum (in \$/MWh) of the Incremental Energy Offer and amortized shutdown costs, as determined in accordance with Operating Agreement, Schedule 1, section 2.4 and Operating Agreement, Schedule 1, section 2.4A and the PJM Manuals.

Congestion Price:

“Congestion Price” shall mean the congestion component of the Locational Marginal Price, which is the effect on transmission congestion costs (whether positive or negative) associated with increasing the output of a generation resource or decreasing the consumption by a Demand Resource, based on the effect of increased generation from or consumption by the resource on transmission line loadings, calculated as specified in Operating Agreement, Schedule 1, section 2, and the parallel provisions of Tariff, Attachment K-Appendix, section 2.

Consolidated Transmission Owners Agreement, PJM Transmission Owners Agreement or Transmission Owners Agreement:

“Consolidated Transmission Owners Agreement,” “PJM Transmission Owners Agreement” or “Transmission Owners Agreement” shall mean that certain Consolidated Transmission Owners Agreement, dated as of December 15, 2005, by and among the Transmission Owners and by and between the Transmission Owners and PJM Interconnection, L.L.C. on file with the Commission, as amended from time to time.

Continuous Mode:

“Continuous Mode” shall mean the mode of operation of an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource that includes both negative and positive megawatt quantities (i.e., the Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource is capable of continually and immediately transitioning from withdrawing megawatt quantities from the grid to injecting megawatt quantities onto the grid or injecting megawatts to withdrawing megawatts). Energy Storage Resource Model Participants or solar-storage Open-Loop Hybrid Resource operating in Continuous Mode are considered to have an unlimited ramp rate. Continuous Mode requires Discharge Economic Maximum Megawatts to be zero or correspond to an injection, and Charge Economic Maximum Megawatts to be zero or correspond to a withdrawal.

Control Area:

“Control Area” shall mean an electric power system or combination of electric power systems bounded by interconnection metering and telemetry to which a common automatic generation control scheme is applied in order to:

- (a) match the power output of the generators within the electric power system(s) and energy purchased from entities outside the electric power system(s), with the load within the electric power system(s);
- (b) maintain scheduled interchange with other Control Areas, within the limits of Good Utility Practice;
- (c) maintain the frequency of the electric power system(s) within reasonable limits in accordance with Good Utility Practice and the criteria of NERC and each Applicable Regional Entity;
- (d) maintain power flows on transmission facilities within appropriate limits to preserve reliability; and
- (e) provide sufficient generating capacity to maintain operating reserves in accordance with Good Utility Practice.

Control Zone:

“Control Zone” shall mean one Zone or multiple contiguous Zones, as designated in the PJM Manuals.

Coordinated External Transaction:

“Coordinated External Transaction” shall mean a transaction to simultaneously purchase and sell energy on either side of a CTS Enabled Interface in accordance with the procedures of Operating Agreement, Schedule 1, section 1.13 and the parallel provisions of Tariff, Attachment K-Appendix, section 1.13.

Coordinated Transaction Scheduling:

“Coordinated Transaction Scheduling” or “CTS” shall mean the scheduling of Coordinated External Transactions at a CTS Enabled Interface in accordance with the procedures of Operating Agreement, Schedule 1, section 1.13, and the parallel provisions of Tariff, Attachment K-Appendix, section 1.13.

Counterparty:

“Counterparty” shall mean PJMSettlement as the contracting party, in its name and own right and not as an agent, to an agreement or transaction with a Market Participant or other entities, including the agreements and transactions with customers regarding transmission service and other transactions under the PJM Tariff and this Operating Agreement. PJMSettlement shall not be a counterparty to (i) any bilateral transactions between Members, or (ii) any Member’s self-supply of energy to serve its load, or (iii) any Member’s self-schedule of energy reported to the extent that energy serves that Member’s own load.

Credit Breach:

“Credit Breach” shall mean (a) the failure of a Participant to perform, observe, meet or comply with any requirements of Tariff, Attachment Q or other provisions of the Agreements, other than a Financial Default, or (b) a determination by PJM and notice to the Participant that a Participant represents an unreasonable credit risk to the PJM Markets; that, in either event, has not been cured or remedied after any required notice has been given and any cure period has elapsed.

CTS Enabled Interface:

“CTS Enabled Interface” shall mean an interface between the PJM Control Area and an adjacent Control Area at which the Office of the Interconnection has authorized the use of Coordinated Transaction Scheduling (“CTS”). The CTS Enabled Interfaces between the PJM Control Area and the New York Independent System Operator, Inc. Control Area shall be designated in Joint Operating Agreement Among and Between New York Independent System Operator Inc. and PJM Interconnection, L.L.C. (PJM Rate Schedule FERC No. 45) Schedule A. The CTS Enabled Interfaces between the PJM Control Area and the Midcontinent Independent System Operator, Inc. shall be designated consistent with Joint Operating Agreement between Midcontinent Independent System Operator, Inc. and PJM Interconnection, L.L.C, Attachment 3, section 2.

CTS Interface Bid:

“CTS Interface Bid” shall mean a unified real-time bid to simultaneously purchase and sell energy on either side of a CTS Enabled Interface in accordance with the procedures of Operating Agreement, Schedule 1, section 1.13, and the parallel provisions of Tariff, Attachment K-Appendix, section 1.13.

Curtailment Service Provider:

“Curtailment Service Provider” or “CSP” shall mean a Member or a Special Member, which action on behalf of itself or one or more other Members or non-Members, participates in the PJM Interchange Energy Market, Ancillary Services markets, and/or Reliability Pricing Model by causing a reduction in demand.

Day-ahead Congestion Price:

“Day-ahead Congestion Price” shall mean the Congestion Price resulting from the Day-ahead Energy Market.

Day-ahead Energy Market:

“Day-ahead Energy Market” shall mean the schedule of commitments for the purchase or sale of energy and payment of Transmission Congestion Charges developed by the Office of the Interconnection as a result of the offers and specifications submitted in accordance with Operating Agreement, Schedule 1, section 1.10, and the parallel provisions of Tariff, Attachment K-Appendix, section 1.10.

Day-ahead Energy Market Injection Congestion Credits:

“Day-ahead Energy Market Injection Congestion Credits” shall mean those congestion credits paid to Market Participants for supply transactions in the Day-ahead Energy Market including generation schedules, Increment Offers, Up-to Congestion Transactions, import transactions, and Day-ahead Pseudo-Tie Transactions.

Day-ahead Energy Market Transmission Congestion Charges:

“Day-ahead Energy Market Transmission Congestion Charges” shall be equal to the sum of Day-ahead Energy Market Withdrawal Congestion Charges minus [the sum of Day-ahead Energy Market Injection Congestion Credits plus any congestion charges calculated pursuant to the Joint Operating Agreement between the Midcontinent Independent Transmission System Operator, Inc. and PJM Interconnection, L.L.C. (PJM Rate Schedule FERC No. 38), plus any congestion charges calculated pursuant to the Joint Operating Agreement Among and Between New York Independent System Operator Inc. and PJM Interconnection, L.L.C. (PJM Rate Schedule FERC No. 45), plus any congestion charges calculated pursuant to agreements between the Office of the Interconnection and other entities, as applicable].

Day-ahead Energy Market Withdrawal Congestion Charges:

“Day-ahead Energy Market Withdrawal Congestion Charges” shall mean those congestion charges collected from Market Participants for withdrawal transactions in the Day-ahead Energy Market from transactions including Demand Bids, Decrement Bids, Up-to Congestion Transactions, Export Transactions, and Day-ahead Pseudo-Tie Transactions.

Day-ahead Loss Price:

“Day-ahead Loss Price” shall mean the Loss Price resulting from the Day-ahead Energy Market.

Day-ahead Prices:

“Day-ahead Prices” shall mean the Locational Marginal Prices resulting from the Day-ahead Energy Market.

Day-Ahead Pseudo-Tie Transaction:

“Day-Ahead Pseudo-Tie Transaction” shall mean a transaction scheduled in the Day-ahead Energy Market to the PJM-MISO interface from a generator within the PJM balancing authority area that Pseudo-Ties into the MISO balancing authority area.

Day-ahead Settlement Interval:

“Day-ahead Settlement Interval” shall mean the interval used by settlements, which shall be every one clock hour.

Day-ahead System Energy Price:

“Day-ahead System Energy Price” shall mean the System Energy Price resulting from the Day-ahead Energy Market.

Decrement Bid:

“Decrement Bid” shall mean a type of Virtual Transaction that is a bid to purchase energy at a specified location in the Day-ahead Energy Market. A cleared Decrement Bid results in scheduled load at the specified location in the Day-ahead Energy Market.

Default Allocation Assessment:

“Default Allocation Assessment” shall mean the assessment determined pursuant to Operating Agreement, section 15.2.2.

Demand Bid:

“Demand Bid” shall mean a bid, submitted by a Load Serving Entity in the Day-ahead Energy Market, to purchase energy at its contracted load location, for a specified timeframe and megawatt quantity, that if cleared will result in energy being scheduled at the specified location

in the Day-ahead Energy Market and in the physical transfer of energy during the relevant Operating Day.

Demand Bid Limit:

“Demand Bid Limit” shall mean the largest MW volume of Demand Bids that may be submitted by a Load Serving Entity for any hour of an Operating Day, as determined pursuant to Operating Agreement, Schedule 1, section 1.10.1B, and the parallel provisions of Tariff, Attachment K-Appendix, section 1.10.1B.

Demand Bid Screening:

“Demand Bid Screening” shall mean the process by which Demand Bids are reviewed against the applicable Demand Bid Limit, and rejected if they would exceed that limit, as determined pursuant to Operating Agreement, Schedule 1, section 1.10.1B, and the parallel provisions of Tariff, Attachment K-Appendix, section 1.10.1B.

Demand Resource:

“Demand Resource” shall have the meaning provided in the Reliability Assurance Agreement.

Designated Entity:

“Designated Entity” shall mean an entity, including an existing Transmission Owner or Nonincumbent Developer, designated by the Office of the Interconnection with the responsibility to construct, own, operate, maintain, and finance Immediate-need Reliability Projects, Short-term Projects, Long-lead Projects, or Economic-based Enhancements or Expansions pursuant to Operating Agreement, Schedule 6, section 1.5.8.

Direct Charging Energy:

“Direct Charging Energy” shall mean the energy that an Energy Storage Resource or Open-Loop Hybrid Resource purchases from the PJM Interchange Energy Market and (i) later resells to the PJM Interchange Energy Market; or (ii) is lost to conversion inefficiencies, provided that such inefficiencies are an unavoidable component of the conversion, storage, and discharge process that is used to resell energy back to the PJM Interchange Energy Market.

Direct Load Control:

“Direct Load Control” shall mean load reduction that is controlled directly by the Curtailment Service Provider’s market operations center or its agent, in response to PJM instructions.

Discharge Economic Maximum Megawatts:

“Discharge Economic Maximum Megawatts” shall mean the maximum megawatt power output available for discharge in economic dispatch by an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource in Continuous Mode or in Discharge Mode.

Discharge Economic Maximum Megawatts shall be the Economic Maximum for an Energy Storage Resource or solar-storage Open-Loop Hybrid Resource in Discharge Mode or in Continuous Mode.

Discharge Economic Minimum Megawatts:

“Discharge Economic Minimum Megawatts” shall mean the minimum megawatt power output available for discharge in economic dispatch by an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource in Discharge Mode. Discharge Economic Minimum Megawatts shall be the Economic Minimum for an Energy Storage Resource or solar-storage Open-Loop Hybrid Resource in Discharge Mode.

Discharge Mode:

“Discharge Mode” shall mean the mode of operation of an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource that only includes positive megawatt quantities (i.e., the Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource is only injecting megawatts onto the grid).

Discharge Ramp Rate:

“Discharge Ramp Rate” shall mean the Ramping Capability of an Energy Storage Resource Model Participant or solar-storage Open-Loop Hybrid Resource in Discharge Mode.

Dispatch Rate:

“Dispatch Rate” shall mean the control signal, expressed in dollars per megawatt-hour, calculated and transmitted continuously and dynamically to direct the output level of all generation resources dispatched by the Office of the Interconnection in accordance with the Offer Data.

Dispatched Charging Energy:

“Dispatched Charging Energy” shall mean Direct Charging Energy that an Energy Storage Resource Model Participant or Open-Loop Hybrid Resource receives from the electric grid pursuant to PJM dispatch while providing one of the following services in the PJM markets: Energy Imbalance Service pursuant to Tariff, Schedule 4; Regulation; Tier 2 Synchronized Reserves; or Reactive Service. Energy Storage Resource Model Participants and Open-Loop Hybrid Resource shall be considered to be providing Energy Imbalance Service when they are dispatchable by PJM in real-time.

Dynamic Schedule:

“Dynamic Schedule” shall have the same meaning set forth in the NERC Glossary of Terms Used in NERC Reliability Standards.

Dynamic Transfer:

“Dynamic Transfer” shall mean a Pseudo-Tie or Dynamic Schedule.

14B.2 Payments:

(a) **Monthly Bills.** Net amounts due to PJMSettlement, in its own name or as agent for the LLC, as applicable, pursuant to a monthly bill shall be due and payable by the Member or other entity no later than noon Eastern Prevailing Time on the due date of the first weekly bill issued for activity in the month that the monthly bill is issued. It is possible, due to the timing of holidays, that the billing and payment cycle for monthly bills stated here would call for payment of a monthly bill on a Friday that occurs less than three Business Days after the issuance of the bill by PJM. Where this occurs, the payment period of the monthly bill will be extended such that payment will be due when payment for the second weekly bill is due.

(b) **Weekly Bills.** Net amounts due to PJMSettlement, in its own name or as agent for the LLC, as applicable, pursuant to a weekly bill shall be due and payable by the Member or other entity no later than noon Eastern Prevailing Time on the third Business Day following the issuance of the weekly bill. Weekly bills issued after 5:00 p.m. Eastern Prevailing Time shall be considered to be issued the following Business Day.

(i) Municipal Electric Systems.

Recognizing that municipal electric systems may, at times, face unique circumstances that could temporarily prevent their ability to make payments on a weekly bill issued pursuant to Section 14B.1 when due, the LLC may allow a municipal electric system to make arrangements with PJM whereby PJM would extend trade credit to the municipal electric system sufficient to enable it to make payment on a weekly bill provided that the following conditions are met:

- (a) the LLC determines, in its sole discretion, that it has sufficient excess working capital available to complete financial settlement with other market participants;
- (b) the municipal electric system reimburses PJM for the actual cost of such working capital;
- (c) the municipal electric system provides PJM with a binding representation that it has all legal right and authority to enter into the arrangement with PJM;
- (d) PJMSettlement will continue to issue weekly bills to the municipal electric system in accordance with Section 14B.1 above and the municipal electric system will make payment as due under the weekly bills using the proceeds it obtains under its arrangement with PJM. Reimbursement of these amounts, including PJM's actual costs of working capital, shall be due from the municipal electric system at the time payment is due for the invoice issued under Section 14B.2(a);
- (e) the aggregate of all financed amounts and accrued obligations shall not exceed the Working Credit Limit available to the municipal electric system;

(f) the municipal electric system provides the LLC with at least one week of notice (though PJM may waive this provision), and;

(g) the accumulated duration of such postponed payments shall not exceed three months in a rolling twelve-month period.

PJM may terminate this payment option at any time it determines its excess working capital is no longer sufficient to allow further or continued extension financing. In such cases, PJM shall attempt to give five Business Days, but not less than three Business Days notice to the affected municipal electric system, and may call for immediate reimbursement of any outstanding amounts owed by the municipal electric system.

(c) Form of Payments. All payments tendered in satisfaction of a Member's or other entity's obligations to PJMSettlement or the LLC shall be made in the form of immediately available funds payable to PJMSettlement, or by wire transfer to a bank named by PJMSettlement.

(d) Payments by PJMSettlement. Unless delayed by unforeseen events, payments made by PJMSettlement, in its own name or as agent for the LLC, for amounts due to Members and other entities shall be paid no later than 5:00 p.m. Eastern Prevailing Time on the Business Day following the payment due date for net amounts owed to PJMSettlement, in its own name or as agent for the LLC, as specified above.

(e) Payment Calendar. A comprehensive billing and settlement calendar will be posted on the LLC's website prior to March 31 for the upcoming June – May annual period to communicate the schedule of holidays for settlement and billing purposes.

(f) Late Payments. In the event that a Member, or other entity, is delinquent in paying the amount set forth in its weekly or monthly bill two or more times within any rolling twelve (12) month period, PJMSettlement, in its own name or as agent for the LLC, may assess, in addition to the interest on each late payment as provided for in Section 7.2 of this Tariff, a late payment charge for a second and any subsequent failure to pay on time during such twelve (12) month period (a "Late Payment Charge"). The applicable Late Payment Charge will be assessed in an amount equal to the greater of: (i) two percent (2%) of the total amount set forth in the monthly or weekly bill that the Transmission Customer or other entity has been late in paying, or (ii) \$1,000; up to a maximum of \$100,000 per late bill payment. For the sole purpose of application of this Section 7.1A(f), weekly and monthly bills that are due on the same date shall be considered to be one bill; moreover, the term "on time" shall mean payment received on the date due; and "delinquent" shall mean any payment received on a day subsequent to the date due.

Late Payment Charges that are collected pursuant to this Section 7.1A(f) shall be credited to PJMSettlement administrative costs contemplated under Schedule 9 of this Tariff.

1.10 Scheduling.

1.10.1 General.

(a) The Office of the Interconnection shall administer scheduling processes to implement a Day-ahead Energy Market and a Real-time Energy Market. PJMSettlement shall be the Counterparty to the purchases and sales of energy that clear the Day-ahead Energy Market and the Real-time Energy Market; provided that PJMSettlement shall not be a contracting party to bilateral transactions between Market Participants or with respect to a Generating Market Buyer's self-schedule or self-supply of its generation resources up to that Generating Market Buyer's Equivalent Load.

(b) The Day-ahead Energy Market shall enable Market Participants to purchase and sell energy through the PJM Interchange Energy Market at Day-ahead Prices and enable Transmission Customers to reserve transmission service with Transmission Congestion Charges and Transmission Loss Charges based on locational differences in Day-ahead Prices. Up-to Congestion Transactions submitted in the Day-ahead Energy Market shall not require transmission service and Transmission Customers shall not reserve transmission service for such Up-to Congestion Transactions. Market Participants whose purchases and sales, and Transmission Customers whose transmission uses are scheduled in the Day-ahead Energy Market, shall be obligated to purchase or sell energy, or pay Transmission Congestion Charges and Transmission Loss Charges, at the applicable Day-ahead Prices for the amounts scheduled.

(c) (i) In the Real-time Energy Market, Market Participants that deviate from the amounts of energy purchases or sales scheduled in the Day-ahead Energy Market shall be obligated to purchase or sell energy for the amount of the deviations at the applicable Real-time Prices or price differences, unless otherwise specified by this Schedule.

(ii) In the Real-time Energy Market, Transmission Customers that deviate from the transmission uses, scheduled in the Day-ahead Energy Market shall be obligated to pay Transmission Congestion Charges and Transmission Loss Charges for the amount of the deviations at the applicable Real-time Prices or price differences, unless otherwise specified by this Schedule.

(iii) Market Participants that deviate in real-time from the amounts of Secondary Reserve, Non-Synchronized Reserve, or Synchronized Reserve sales, scheduled day-ahead shall be obligated to purchase Secondary Reserve, Non-Synchronized Reserve, or Synchronized Reserve for the amount of the deviations at the applicable Real-time Prices or price differences, unless otherwise specified by this Schedule.

(d) The following scheduling procedures and principles shall govern the commitment of resources to the Day-ahead Energy Market and the Real-time Energy Market over a period extending from one week to one hour prior to the real-time dispatch. Scheduling encompasses the day-ahead and hourly scheduling process, through which the Office of the Interconnection determines the Day-ahead Energy Market and determines, based on changing forecasts of conditions and actions by Market Participants and system constraints, a plan to serve the hourly

energy and reserve requirements of the Internal Market Buyers and the purchase requests of the External Market Buyers in the least costly manner, subject to maintaining the reliability of the PJM Region. Scheduling does not encompass Coordinated External Transactions, which are subject to the procedures of Operating Agreement, Schedule 1, section 1.13. Scheduling shall be conducted as specified in section 1.10.1A below, subject to the following condition. If the Office of the Interconnection's forecast for the next seven days projects a likelihood of Emergency conditions, the Office of the Interconnection may commit, for all or part of such seven day period, to the use of generation resources with notification or start-up times greater than one day as necessary in order to alleviate or mitigate such Emergency, in accordance with the Market Sellers' offers for such units for such periods and the specifications in the PJM Manuals. Such resources committed by the Office of the Interconnection to alleviate or mitigate an Emergency will not receive Operating Reserve Credits nor otherwise be made whole for its hours of operation for the duration of any portion of such commitment that exceeds the maximum start-up and notification times for such resources during Hot Weather Alerts and Cold Weather Alerts, consistent with Operating Agreement, Schedule 1, section 3.2.3 and Operating Agreement, Schedule 1, section 6.6.

1.10.1A Day-ahead and Real-time Energy Market Scheduling.

The following actions shall occur not later than 11:00 a.m. on the day before the Operating Day for which transactions are being scheduled, or such other deadline as may be specified by the Office of the Interconnection in order to comply with the practical requirements and the economic and efficiency objectives of the scheduling process specified in this Schedule.

(a) Each Market Participant may submit to the Office of the Interconnection specifications of the amount and location of its customer loads and/or energy purchases to be included in the Day-ahead Energy Market for each hour of the next Operating Day, such specifications to comply with the requirements set forth in the PJM Manuals. Each Market Buyer shall inform the Office of the Interconnection of the prices, if any, at which it desires not to include its load in the Day-ahead Energy Market rather than pay the Day-ahead Price. PRD Providers that have committed Price Responsive Demand in accordance with the Reliability Assurance Agreement shall submit to the Office of the Interconnection, in accordance with procedures specified in the PJM Manuals, any desired updates to their previously submitted PRD Curves, provided that such updates are consistent with their Price Responsive Demand commitments, and provided further that PRD Providers that are not Load Serving Entities for the Price Responsive Demand at issue may only submit PRD Curves for the Real-time Energy Market. Price Responsive Demand that has been committed in accordance with the Reliability Assurance Agreement shall be presumed available for the next Operating Day in accordance with the most recently submitted PRD Curve unless the PRD Curve is updated to indicate otherwise. PRD Providers may also submit PRD Curves for any Price Responsive Demand that is not committed in accordance with the Reliability Assurance Agreement; provided that PRD Providers that are not Load Serving Entities for the Price Responsive Demand at issue may only submit PRD Curves for the Real-time Energy Market. All PRD Curves shall be on a PRD Substation basis, and shall specify the maximum time period required to implement load reductions.

(b) Each Generating Market Buyer shall submit to the Office of the Interconnection:
(i) hourly schedules for resource increments, including hydropower units, self-scheduled by the Market Buyer to meet its Equivalent Load; and (ii) the Dispatch Rate at which each such self-scheduled resource will disconnect or reduce output, or confirmation of the Market Buyer's intent not to reduce output.

(c) All Market Participants shall submit to the Office of the Interconnection schedules for any energy exports, energy imports, and wheel through transactions involving use of generation or Transmission Facilities as specified below, and shall inform the Office of the Interconnection if the transaction is to be scheduled in the Day-ahead Energy Market. Any Market Participant that elects to schedule an export, import or wheel through transaction in the Day-ahead Energy Market may specify the price (such price not to exceed \$2,000/MWh), if any, at which the export, import or wheel through transaction will be wholly or partially curtailed. The foregoing price specification shall apply to the applicable interface pricing point. Any Market Participant that elects not to schedule its export, import or wheel through transaction in the Day-ahead Energy Market shall inform the Office of the Interconnection if the parties to the transaction are not willing to incur Transmission Congestion and Loss Charges in the Real-time Energy Market in order to complete any such scheduled transaction. Such transactions in the Real-time Energy Market, other than Coordinated Transaction Schedules and emergency energy sales and purchases, may specify a price up to \$2,000/MWh. Scheduling of such transactions shall be conducted in accordance with the specifications in the PJM Manuals and the following requirements:

- i) Market Participants shall submit schedules for all energy purchases for delivery within the PJM Region, whether from resources inside or outside the PJM Region;
- ii) Market Participants shall submit schedules for exports for delivery outside the PJM Region from resources within the PJM Region that are not Dynamic Transfers to such entities pursuant to Operating Agreement, Schedule 1, section 1.12; and
- iii) In addition to the foregoing schedules for exports, imports and wheel through transactions, Market Participants shall submit confirmations of each scheduled transaction from each other party to the transaction in addition to the party submitting the schedule, or the adjacent Control Area.

(c-1) A Market Participant may elect to submit in the Day-ahead Energy Market a form of Virtual Transaction that combines an offer to sell energy at a source, with a bid to buy the same megawatt quantity of energy at a sink where such transaction specifies the maximum difference between the Locational Marginal Prices at the source and sink. The Office of Interconnection will schedule these transactions only to the extent this difference in Locational Marginal Prices is within the maximum amount specified by the Market Participant. A Virtual Transaction of this type is referred to as an "Up-to Congestion Transaction." Such Up-to Congestion Transactions may be wholly or partially scheduled depending on the price difference between the source and sink locations in the Day-ahead Energy Market. The maximum difference between the source

and sink prices that a participant may specify shall be limited to +/- \$50/MWh. The foregoing price specification shall apply to the price difference between the specified source and sink in the day-ahead scheduling process only. An accepted Up-to Congestion Transaction results in scheduled injection at a specified source and scheduled withdrawal of the same megawatt quantity at a specified sink in the Day-ahead Energy Market.

(c-2) A Market Participant may elect to submit an Increment Offer and/or Decrement Bid form of Virtual Transaction in the Day-ahead Energy Market and shall specify the price for such transaction which shall be limited to \$2,000/megawatt-hour.

(c-3) Up-to Congestion Transactions may only be submitted at hubs, Residual Metered Load and interfaces not described in Tariff, Attachment K-Appendix, section 2.6A(b). Increment Offers and Decrement Bids may be only submitted at hubs, nodes at which physical generation or load is settled, Residual Metered Load and interfaces not described in Tariff, Attachment K-Appendix, section 2.6A(b).

(d) Market Sellers in the Day-ahead Energy Market shall submit offers for the supply of energy, demand reductions, or other services for the following Operating Day for each clock hour for which the Market Seller desires or is required to make its resource available to the Office of the Interconnection. Offers for the supply of energy may be cost-based, market-based, or both, and may vary hourly. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A(d), section 1.10.9B below, Operating Agreement, Schedule 2, and the PJM Manuals, as applicable. Market Sellers owning or controlling the output of a Generation Capacity Resource that is committed as a Capacity Resource under Tariff, Attachment DD or RAA, Schedule 8.1, and that has not been rendered unavailable by a Generator Planned Outage, a Generator Maintenance Outage, or a Generator Forced Outage shall submit offers for the available capacity of such Generation Capacity Resource, including any portion that is self-scheduled by the Generating Market Buyer. Such offers shall be based on the ICAP equivalent of the Market Seller's cleared UCAP capacity commitment, provided, however, where the underlying resource is a Capacity Storage Resource or an Intermittent Resource, the Market Seller shall satisfy the must offer requirement by either self-scheduling or offering the unit as a dispatchable resource, in accordance with the PJM Manuals, where the hourly day-ahead self-scheduled values for such Capacity Storage Resources and Intermittent Resources may vary hour to hour from the capacity commitment. Any offer not designated as a Maximum Emergency offer shall be considered available for scheduling and dispatch under both Emergency and non-Emergency conditions. Offers may only be designated as Maximum Emergency offers to the extent that the Generation Capacity Resource falls into at least one of the following categories:

- i) Environmental limits. If the resource has a limit on its run hours imposed by a federal, state, or other governmental agency that will significantly limit its availability, on either a temporary or long-term basis. This includes a resource that is limited to operating only during declared PJM capacity emergencies by a governmental authority.

- ii) Fuel limits. If physical events beyond the control of the resource owner result in the temporary interruption of fuel supply and there is limited on-site fuel storage. A fuel supplier's exercise of a contractual right to interrupt supply or delivery under an interruptible service agreement shall not qualify as an event beyond the control of the resource owner.
- iii) Temporary emergency conditions at the unit. If temporary emergency physical conditions at the resource significantly limit its availability.
- iv) Temporary megawatt additions. If a resource can provide additional megawatts on a temporary basis by oil topping, boiler over-pressure, or similar techniques, and such megawatts are not ordinarily otherwise available.

The submission of offers for resource increments that are not committed as a Capacity Resource under Tariff, Attachment DD or RAA, Schedule 8.1 shall be optional, but any such offers must contain the information specified in the Office of the Interconnection's Offer Data specification, Operating Agreement, Schedule 1, sections 1.10.1A(d) and 1.10.9B, Operating Agreement, Schedule 2, and the PJM Manuals, as applicable. Energy offered from generation resources that are not committed as a Capacity Resource under Tariff, Attachment DD or RAA, Schedule 8.1 shall not be supplied from resources that are included in or otherwise committed to supply the Operating Reserves of a Control Area outside the PJM Region.

The foregoing offers:

- i) Shall specify the Generation Capacity Resource or Economic Load Response Participant resource and energy or demand reduction amount, respectively, for each clock hour in the offer period;
- ii) Shall specify the amounts and prices for each clock hour during the entire Operating Day for each resource component offered by the Market Seller to the Office of the Interconnection;
- iii) May specify for generation resources offer parameters for each clock hour during the entire Operating Day, as applicable and in accordance with section 1.10.9B below, including: (1) Minimum Run Time; (2) maximum run time; (3) Start-up Costs; (4) No-load Costs; (5) Incremental Energy Offer; (6) notification time; (7) availability; (8) ramp rate; (9) Economic Minimum; (10) Economic Maximum; (11) emergency minimum MW; (12) emergency maximum MW; (13) Synchronized Reserve maximum MW; (14) Secondary Reserve maximum MW; and (15) condense to generation time constraints, and may specify offer parameters for Economic Load Response Participant resources for each clock hour during the entire Operating Day, as applicable and in accordance with section 1.10.9B below, including: (1) minimum down time; (2) shutdown costs;

(3) Incremental Energy Offer; (4) notification time; (5) Economic Minimum; and (6) Economic Maximum;

- iv) Shall set forth any special conditions upon which the Market Seller proposes to supply a resource increment, including any curtailment rate specified in a bilateral contract for the output of the resource, or any cancellation fees;
- v) May include a schedule of offers for prices and operating data contingent on acceptance by the deadline specified in this Schedule, with additional schedules applicable if accepted after the foregoing deadline;
- vi) Shall constitute an offer to submit the resource increment to the Office of the Interconnection for scheduling and dispatch in accordance with the terms of the offer for the clock hour, which offer shall remain open through the Operating Day, for which the offer is submitted, unless the Market Seller a) submits a Real-time Offer for the applicable clock hour, or b) updates the availability of its offer for that hour, as further described in the PJM Manuals;
- vii) Shall be final as to the price or prices at which the Market Seller proposes to supply energy or other services to the PJM Interchange Energy Market, such price or prices being guaranteed by the Market Seller for the period extending through the end of the following Operating Day, unless modified after the close of the Day-ahead Energy Market as permitted pursuant to sections 1.10.9A or 1.10.9B below;
- viii) Shall not exceed an energy offer price of \$1,000/megawatt-hour for all generation resources, except (1) when a Market Seller's cost-based offer is above \$1,000/megawatt-hour and less than or equal to \$2,000/megawatt-hour, then its market-based offer must be less than or equal to the cost-based offer; and (2) when a Market Seller's cost-based offer is greater than \$2,000/megawatt-hour, then its market-based offer must be less than or equal to \$2,000/megawatt-hour;
- ix) Shall not exceed a demand reduction offer price of \$1,000/megawatt-hour, except when an Economic Load Response Participant submits a cost-based offer that includes an incremental cost component that is above \$1,000/megawatt-hour, then its market-based offer must be less than or equal to the cost-based offer but in no event greater than \$2,000/megawatt-hour;
- x) Shall not exceed an offer price as follows for Emergency Load Response and Pre-Emergency Load Response participants with:
 - a) a 30 minute lead time, pursuant to Tariff, Attachment DD-1,

section A.2 and the parallel provision of RAA, Schedule 6, \$1,000/megawatt-hour, plus the applicable Reserve Penalty Factor for the Primary Reserve Requirement, minus \$1.00;

- b) an approved 60 minute lead time, pursuant to Tariff, Attachment DD-1, section A.2 and the parallel provision of RAA, Schedule 6, \$1,000/megawatt-hour, plus [the applicable Reserve Penalty Factor for the Primary Reserve Requirement divided by 2]; and
- c) an approved 120 minute lead time, pursuant to Tariff, Attachment DD-1, section A.2 and the parallel provisions of RAA, Schedule 6, \$1,100/megawatt-hour; and

- xi) Shall not exceed an energy offer price of \$0.00/MWh for pumped storage hydropower units scheduled by the Office of the Interconnection pursuant to the hydro optimization tool in the Day-ahead Energy Market.

(e) A Market Seller that wishes to make a resource available to sell Regulation service shall submit an offer for Regulation for each clock hour for which the Market Seller desires to make its resource available to the Office of the Interconnection to provide Regulation that shall specify the megawatts of Regulation being offered, which must equal or exceed 0.1 megawatts, the Regulation Zone for which such Regulation is offered, the price of the capability offer in dollars per MW, the price of the performance offer in Dollars per change in MW, and such other information specified by the Office of the Interconnection as may be necessary to evaluate the offer and the resource's opportunity costs. Such offers may vary hourly, and may be updated each hour, up to 65 minutes before the applicable clock hour during the Operating Day. The total of the performance offer multiplied by the historical average mileage used in the market clearing plus the capability offer shall not exceed \$100/megawatt-hour in the case of Regulation offered for all Regulation Zones. In addition to any market-based offer for Regulation, the Market Seller also shall submit a cost-based offer. A cost-based offer must be in the form specified in the PJM Manuals and consist of the following components as well as any other components specified in the PJM Manuals:

- i. The costs (in \$/MW) of the fuel cost increase due to the steady-state heat rate increase resulting from operating the unit at lower megawatt output incurred from the provision of Regulation shall apply to the capability offer;
- ii. The cost increase (in \$/ΔMW) in costs associated with movement of the regulation resource incurred from the provision of Regulation shall apply to the performance offer; and
- iii. An adder of up to \$12.00 per megawatt of Regulation provided applied to the capability offer.

Qualified Regulation capability must satisfy the measurement and verification tests specified in the PJM Manuals.

(f) Each Market Seller owning or controlling the output of a Generation Capacity Resource committed to service of PJM loads under the Reliability Pricing Model or Fixed Resource Requirement Alternative shall submit a forecast of the availability of each such Generation Capacity Resource for the next seven days. A Market Seller (i) may submit a non-binding forecast of the price at which it expects to offer a generation resource increment to the Office of the Interconnection over the next seven days, and (ii) shall submit a binding offer for energy, along with Start-up Costs and No-load Costs, if any, for the next seven days or part thereof, for any generation resource with minimum notification or start-up requirement greater than 24 hours. Such resources committed by the Office of the Interconnection will not receive Operating Reserve Credits nor otherwise be made whole for its hours of operation for the duration of any portion of such commitment that exceeds the maximum start-up and notification times for such resources during Hot Weather Alerts and Cold Weather Alerts, consistent with Operating Agreement, Schedule 1, section 3.2.3 and Operating Agreement, Schedule 1, section 6.6.

(g) Each component of an offer by a Market Seller of a Generation Capacity Resource that is constant for the entire Operating Day and does not vary hour to hour shall remain in effect for subsequent Operating Days until superseded or canceled.

(h) The Office of the Interconnection shall post the total hourly loads scheduled in the Day-ahead Energy Market, as well as, its estimate of the combined hourly load of the Market Buyers for the next four days, and peak load forecasts for an additional three days.

(i) Except for Economic Load Response Participants, all Market Participants may submit Virtual Transactions that apply to the Day-ahead Energy Market only. Such Virtual Transactions must comply with the requirements set forth in the PJM Manuals and must specify amount, location and price, if any, at which the Market Participant desires to purchase or sell energy in the Day-ahead Energy Market. The Office of the Interconnection may require that a market participant shall not submit in excess of a defined number of bid/offer segments in the Day-ahead Energy Market, as specified in the PJM Manuals, when the Office of the Interconnection determines that such limit is required to avoid or mitigate significant system performance problems related to bid/offer volume. Notice of the need to impose such limit shall be provided prior to 10:00 a.m. EPT on the day that the Day-ahead Energy Market will clear. For purposes of this provision, a bid/offer segment is each pairing of price and megawatt quantity submitted as part of an Increment Offer or Decrement Bid. For purposes of applying this provision to an Up-to Congestion Transaction, a bid/offer segment shall refer to the pairing of a source and sink designation, as well as price and megawatt quantity, that comprise each Up-to Congestion Transaction.

(j) (i) Offers to Supply Synchronized and Non-Synchronized Reserves By Generation Resources in the Day-ahead and Real-time Reserve Markets

(1) Market Sellers owning or controlling the output of a Generation Capacity Resource that was committed in an FRR Capacity Plan, self-supplied, offered and

cleared in a Base Residual Auction or Incremental Auction, or designated as replacement capacity, as specified in Tariff, Attachment DD, is capable of providing Synchronized Reserve or Non-Synchronized Reserve as specified in section 1.7.19A(a), in section 1.7.19A.01(a) and in the PJM Manuals, and has not been rendered unavailable by a Generator Planned Outage, a Generator Maintenance Outage, or a Generator Forced Outage, shall submit offers or otherwise make their 10-minute reserve capability available to supply Synchronized Reserve or, as applicable, Non-Synchronized Reserve, including any portion that is self-scheduled by the Generating Market Buyer, in an amount equal to the available 10-minute reserve capability of such Generation Capacity Resource. Market Sellers of Generation Capacity Resources subject to this must-offer requirement that do not make the reserve capability of such resources available when such resource is able to operate with a dispatchable range (e.g. through offering a fixed output) will be in violation of this provision.

(2) Market Sellers of all other generation resources that (A) are capable of providing Synchronized Reserve or Non-Synchronized Reserve, as specified in section 1.7.19A(a), in section 1.7.19A.01(a) and in the PJM Manuals, (B) are located within the metered boundaries of the PJM Region, and (C) have submitted offers for the supply of energy into the Day-ahead Energy Market and/or Real-time Energy Market shall be deemed to have made their reserve capability available to provide Synchronized Reserve or Non-Synchronized Reserve in the Day-ahead Energy Market and/or Real-time Energy Market for each clock hour for which the Market Seller submits an available offer to supply energy; provided, however that hydroelectric generation resources and Energy Storage Resources are not automatically deemed available to provide reserves based on the submission of an available energy offer but may submit offers to supply Synchronized Reserve and Non-Synchronized Reserve, as applicable.

(3) Offers for the supply of Synchronized Reserve by all generation resources must be cost-based. Consistent with the resource's offer to supply energy, such offers may vary hourly and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A, section 1.10.9B below, and the PJM Manuals, as applicable. For offers to supply Synchronized Reserve, the offer price shall not exceed the expected value of the penalty for failing to provide Synchronized Reserve, where such expected value shall be recalculated annually, in accordance with the PJM Manuals, and posted on PJM's website. The expected value of the penalty is calculated as the product of: (A) the average penalty, expressed in \$/MWh, multiplied by (B) the average rate of non-performance during Synchronized Reserve events multiplied by (C) the probability a Synchronized Reserve event that will qualify for non-performance assessments will occur.

The expected value of the penalty shall be determined by an annual review of the twelve-month period ending October 31 of the calendar year in which the review is performed. The Office of the Interconnection shall post the results of its annual review by no later than December 15, and the revised offer price cap shall be effective as of the following January 1; provided, however, that at the time of implementation of this rule the expected value of the penalty shall be \$0.02/MWh, and for the period from the second month after implementation through the second December 31 following such date of implementation, the expected value of the penalty shall be recalculated on a monthly basis using data from the implementation date of this rule through the 15th day of the current month, and the revised value shall be effective the 1st day of the following month.

(4) All Non-Synchronized Reserve offers shall be for \$0.00/MWh. Consistent with the resource's offer to supply energy, such offers may vary hourly and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this subsection (d) of this section 1.10.1A(d), section 1.10.9B below, and the PJM Manuals, as applicable.

(ii) Determination of Available Synchronized Reserve Capability of Generation Resources

(1) For each offer to supply reserves by a synchronized resource, the Office of the Interconnection shall determine the MW of available Synchronized Reserve capability offered in the Day-ahead Energy Market and Real-time Energy Market, in accordance with the PJM Manuals; except, however, that the Office of the Interconnection will not make such determination for hydroelectric generation resources or Energy Storage Resources. Hydroelectric generation resources and Energy Storage Resources may submit offers for their available Synchronized Reserve capability as part of their offer into the Synchronized Reserve market, provided that such offer equals or exceeds 0.1 MW; however, any such resource which is subject to the must offer requirements in section 1.10.1A(j)(i) above must submit a Synchronized Reserve offer which specifies the MW of available Synchronized Reserve capability in order to remain compliant with such requirements.

(2) An on-line generation resource's available Synchronized Reserve capability, except for generation resources capable of synchronous condensing, shall be determined in accordance with the PJM Manuals and based on the resource's current performance and initial energy output and the following offer parameters submitted as part of the resource's energy offer: (A) ramp rate; (B) Economic Minimum; and (C) the lesser of Economic Maximum and Synchronized Reserve maximum MW, where Synchronized Reserve maximum MW may be lower than the Economic Maximum only where the Market Seller

has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Synchronized Reserves above the Synchronized Reserve maximum MW.

For generation resources capable of synchronous condensing, the resource's available Synchronized Reserve capability shall be based on the following offer parameters submitted as part of the resource's energy offer: (D) ramp rate; (E) condense to generation time constraints; (F) Economic Minimum; and (G) the lesser of Economic Maximum and Synchronized Reserve maximum MW, where Synchronized Reserve maximum MW may be lower than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Synchronized Reserves above the Synchronized Reserve maximum MW.

(3) Any Market Seller that believes its generating unit has operating modes, limits, or conditions where the unit would not be capable of providing Synchronized Reserves in real time, can submit to the Office of the Interconnection with a copy to the Market Monitoring Unit a request for an exception from being assigned Synchronized Reserves in the Real-time Synchronized Reserve Market during time periods in which the generating unit is in those operating modes, limits, or conditions. As part of the request, the Market Seller shall supply, for each generating unit, technical information about the operational modes, limits, or conditions to support the requested exception, as further detailed in the PJM Manuals. The Office of the Interconnection shall consult with the Market Monitoring Unit, and consider any input received from the Market Monitoring Unit, in its determination of a request for such an exception. Within 60 days of the submission of the request, the Office of the Interconnection shall notify the Market Seller in writing, with a copy to the Market Monitoring Unit, whether the request is approved or denied. The effective date of any approved request will be provided in the written notification. If a Market Seller has an approved exception, the Market Seller must communicate to the Office of the Interconnection when the unit cannot provide reserves, and the Office of the Interconnection will provide a mechanism for Market Sellers with an approved exception to provide such communication to the Office of the Interconnection in real time, as further detailed in the PJM Manuals. An approved exception will remain applicable to the unit until such time as the Office of the Interconnection determines that a change is needed or the Market Seller notifies the Office of the Interconnection, with a copy to the Market Monitoring Unit, that a change is needed based on changed operational capabilities of the unit. Market Sellers must notify the Office of the Interconnection, with a copy to the Market Monitoring Unit, within 30 days of any changed operational capabilities that necessitate a change in an approved exception.

(iii) Determination of Available Non-Synchronized Reserve Capability of Generation Resources

(1) For each offer to supply reserves by an off-line generation resource, the Office of the Interconnection shall determine the MW of available Non-Synchronized Reserve capability offered in the Day-ahead Energy Market and Real-time Energy Market in accordance with the PJM Manuals; except, however, that the Office of the Interconnection will not make such determination for hydroelectric generation resources or Energy Storage Resources. Such hydroelectric generation resources or Energy Storage Resources may submit offers for their available Non-Synchronized Reserve capability as part of their offer into the Non-Synchronized Reserve market, provided that such offer equals or exceeds 0.1 MW; however, any such resource which is subject to the must offer requirements in section 1.10.1A(j)(i) above must submit a Non-Synchronized Reserve offer which specifies the MW of available Non-Synchronized Reserve capability in order to remain compliant with such requirements.

(2) An off-line generation resource's available Non-Synchronized Reserve capability shall be determined in accordance with the PJM Manuals and based on the following offer parameters submitted as part of the resource's energy offer: (A) startup time; (B) notification time; (C) ramp rate; (D) Economic Minimum; and (E) the lesser of Economic Maximum and Synchronized Reserve maximum MW, where Synchronized Reserve maximum MW may be lower than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Non-Synchronized Reserves above its Synchronized Reserve maximum MW.

(iv) Offers to Supply Synchronized Reserves by Economic Load Response Participant Resources in the Day-ahead and Real-time Reserve Markets

(1) Economic Load Response Participants that submit offers to reduce demand into the Day-ahead Energy Market and Real-time Energy Market and wish to make their resources available to supply Synchronized Reserve may submit offers to supply Synchronized Reserve from such resources, where such offers shall specify the megawatts of Synchronized Reserve being offered, which must equal or exceed 0.1 megawatts and such other information specified by the Office of the Interconnection as may be necessary to evaluate the offer. Such offers may vary hourly, and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day.

(2) All offers to supply Synchronized Reserve offers from Economic Load Response Participant resources shall not exceed the expected value of the penalty for failing to provide Synchronized Reserve, as determined in accordance with

section 1.10.1A(j)(i)(3) above. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A(d), section 1.10.9B below, and the PJM Manuals, as applicable.

(k) An Economic Load Response Participant that wishes to participate in the Day-ahead Energy Market by reducing demand shall submit an offer to reduce demand to the Office of the Interconnection for each clock hour for which the Economic Load Response Participant desires to make its resource available to the Office of the Interconnection to reduce demand. The offer must equal or exceed 0.1 megawatts, may vary hourly, and shall specify: (i) the amount of the offered curtailment in minimum increments of .1 megawatts; (ii) the Day-ahead Locational Marginal Price above which the end-use customer will reduce load, subject to section 1.10.1A(d)(ix); and (iii) at the Economic Load Response Participant's option, shutdown costs associated with reducing load, including direct labor and equipment costs, opportunity costs, and/or a minimum of number of contiguous hours for which the load reduction must be committed. Such offers may be updated each hour, up to 65 minutes before the applicable clock hour during the Operating Day. Economic Load Response Participants submitting offers to reduce demand in the Day-ahead Energy Market may establish an incremental offer curve, provided that such offer curve shall be limited to ten price pairs (in MWs) per hour.

(l) Market Sellers owning or controlling the output of an Economic Load Response Participant resource that was committed in an FRR Capacity Plan, or that was self-supplied or that offered and cleared in a Base Residual Auction or Incremental Auction, may submit demand reduction bids for the available load reduction capability of the Economic Load Response Participant resource. The submission of demand reduction bids for Economic Load Response Participant resource increments that were not committed in an FRR Capacity Plan, or that have not cleared in a Base Residual Auction or Incremental Auction, shall be optional, but any such bids must contain the information required to be included in such bids, as specified in the PJM Economic Load Response Program. An Economic Load Response Participant resource that was committed in an FRR Capacity Plan, or that was self-supplied or offered and cleared in a Base Residual Auction or Incremental Auction, may submit a demand reduction bid in the Day-ahead Energy Market as specified in the Economic Load Response Program; provided, however, that in the event of an Emergency PJM shall require Economic Load Response Participant resources to reduce load, notwithstanding that the Zonal LMP at the time such Emergency is declared is below the price identified in the demand reduction bid.

(m) (i) Offers to Supply Secondary Reserve By Generation Resources

(1) Market Sellers owning or controlling the output of a Generation Capacity Resource that was committed in an FRR Capacity Plan, self-supplied, offered and cleared in a Base Residual Auction or Incremental Auction, or designated as replacement capacity, as specified in Tariff, Attachment DD, that is available for energy, is capable of providing Secondary Reserve, as specified in section 1.7.19A.02(a) and in the PJM Manuals, and has not been rendered unavailable by a Generator Planned Outage, a Generator Maintenance Outage, or a Generator

Forced Outage shall submit offers to supply Secondary Reserve, or otherwise make their Secondary Reserve capability available. Such offers shall be for an amount equal to the resource's available energy output achievable within thirty minutes (less its energy output achievable within ten minutes) from a request of the Office of the Interconnection. Market Sellers of Generation Capacity Resources subject to this must-offer requirement that do not make the reserve capability of such resources available when such resource is able to operate with a dispatchable range (e.g. through offering a fixed output) will be in violation of this provision.

(2) Market Sellers of all other generation resources located within the metered boundaries of the PJM Region that submit offers for the supply of energy into the Day-ahead Energy Market and/or Real-time Energy Market and are capable of providing Secondary Reserve, as specified in the PJM Manuals, shall be deemed to have made their reserve capability available to provide Secondary Reserve in the Day-ahead Energy Market and/or Real-time Energy Market for each clock hour for which the Market Seller submits an available offer to supply energy; provided, however that hydroelectric generation resources and Energy Storage Resources are not automatically deemed available to provide reserves based on the submission of an available energy offer but may submit offers to supply Secondary Reserve, as applicable.

(3) Offers for the supply of Secondary Reserve shall be for \$0.00/MWh. Consistent with the resource's offer to supply energy, such offers may vary hourly and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this subsection (d) above, section 1.10.9B below, and the PJM Manuals, as applicable.

(ii) Determination of Available Secondary Reserve Capability of Generation Resources

(1) For each offer to supply Secondary Reserve by a generation resource, the Office of the Interconnection shall determine the MW of available Secondary Reserve capability offered in the Day-ahead Energy Market and Real-time Energy Market in accordance with the PJM Manuals; except, however, that the Office of the Interconnection will not make such determination for hydroelectric generation resources or Energy Storage Resources. Hydroelectric generation resources or Energy Storage Resources may submit their available Secondary Reserve capability as part of their offer into the Secondary Reserve market, provided that such offer equals or exceeds 0.1 MW; however, any such resource which is subject to the must offer requirements in section 1.10.1A(m)(i) above must submit a Secondary Reserve offer which specifies the MW of available Secondary Reserve capability in order to remain compliant with such requirements.

(2) (A) An on-line generation resource's available Secondary Reserve capability, except for generation resources capable of synchronous condensing, shall be based on the resource's current performance and initial energy output, the resource's available Synchronized Reserve capability; and the following offer parameters submitted as part of the energy offer: (i) ramp rate; (ii) Economic Minimum; and (iii) the lesser of Economic Maximum and Secondary Reserve maximum MW, where a resource's Secondary Reserve maximum MW may be less than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Secondary Reserves above its Secondary Reserve maximum MW.

(B) For generation resources capable of synchronous condensing, the resource's available Secondary Reserve capability shall be based on the following offer parameters submitted as part of the energy offer: (i) ramp rate; (ii) condense to generation time constraints; (iii) Economic Minimum; and (iv) the lesser of Economic Maximum and Secondary Reserve maximum MW, where a resource's Secondary Reserve maximum MW may be less than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Secondary Reserves above its Secondary Reserve maximum MW.

(C) An off-line generation resource's available Secondary Reserve capability, shall be based on the resource's available Secondary Reserve capability and the following offer parameters submitted as part of the resource's energy offer: (i) startup time; (ii) notification time; (iii) ramp rate; (iv) Economic Minimum; and (v) the lesser of Economic Maximum and Secondary Reserve maximum MW, where a resource's Secondary Reserve maximum MW may be less than the Economic Maximum only where the Market Seller has, in accordance with the procedures set forth in the PJM Manuals, submitted justification to the Office of the Interconnection that the resource has an operating configuration that prevents it from reliably providing Secondary Reserves above its Secondary Reserve maximum MW.

(3) Any Market Seller that believes its generating unit has operating modes, limits, or conditions where the unit would not be capable of providing Secondary Reserves in real time, can submit to the Office of the Interconnection with a copy to the Market Monitoring Unit a request for an exception from being assigned Secondary Reserves in the Real-time

Secondary Reserve Market during time periods in which the generating unit is in those operating modes, limits, or conditions. As part of the request, the Market Seller shall supply, for each generating unit, technical information about the operational modes, limits, or conditions to support the requested exception, as further detailed in the PJM Manuals. The Office of the Interconnection shall consult with the Market Monitoring Unit, and consider any input received from the Market Monitoring Unit, in its determination of a request for such an exception. Within 60 days of the submission of the request, the Office of the Interconnection shall notify the Market Seller in writing, with a copy to the Market Monitoring Unit, whether the request is approved or denied. The effective date of any approved request will be provided in the written notification. If a Market Seller has an approved exception, the Market Seller must communicate to the Office of the Interconnection when the unit cannot provide reserves, and the Office of the Interconnection will provide a mechanism for Market Sellers with an approved exception to provide such communication to the Office of the Interconnection in real time, as further detailed in the PJM Manuals. An approved exception will remain applicable to the unit until such time as the Office of the Interconnection determines that a change is needed or the Market Seller notifies the Office of the Interconnection, with a copy to the Market Monitoring Unit, that a change is needed based on changed operational capabilities of the unit. Market Sellers must notify the Office of the Interconnection, with a copy to the Market Monitoring Unit, within 30 days of any changed operational capabilities that necessitate a change in an approved exception.

(iii) Offers to Supply Secondary Reserves by Economic Load Response Participant resources

(1) Each Economic Load Response Participant that submits offers to reduce demand into the Day-ahead Energy Market and Real-time Energy Market and wishes to make their resources available to supply Secondary Reserve shall submit offers to supply Secondary Reserve from such resources, where such offers shall specify the megawatts of Secondary Reserve being offered, which must equal or exceed 0.1 megawatts and include such other information specified by the Office of the Interconnection as may be necessary to evaluate the offer. Such offers may vary hourly, and may be updated each hour up to 65 minutes before the applicable clock hour during the Operating Day.

(2) All Secondary Reserve offers by Economic Load Response Participant resources shall be for \$0.00/MWh. Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection and shall contain the information specified in the Office of the Interconnection's Offer Data specification, this section 1.10.1A(d), section 1.10.9B below, and the PJM Manuals, as applicable.

(n) A Market Participant may submit a Day-Ahead Pseudo-Tie Transaction for a Market Participant's generator within the PJM balancing authority area that is a Pseudo-Tie into the MISO balancing authority area. Day-Ahead Pseudo-Tie Transactions combine an offer to sell energy at a source with a bid to buy the same megawatt quantity of energy at a sink where such transaction specifies the maximum difference between the Locational Marginal Prices at the source and sink.

Each Day-Ahead Pseudo-Tie Transaction shall: (1) source at a Market Participant's generator within the PJM balancing authority area that Pseudo-Ties into MISO; and (2) sink at the PJM-MISO interface. A Market Participant must reserve transmission service in accordance with the PJM Tariff for each Day-Ahead Pseudo-Tie Transaction. Megawatt quantities for Day-Ahead Pseudo-Tie Transactions shall be greater than zero and less than or equal to the transmission service reserved for the Day-Ahead Pseudo-Tie Transaction. An accepted Day-Ahead Pseudo-Tie Transaction results in scheduled injection at a specified source and scheduled withdrawal of the same megawatt quantity at a specified sink in the Day-Ahead Energy Market.

1.10.1B Demand Bid Scheduling and Screening

(a) The Office of the Interconnection shall apply Demand Bid Screening to all Demand Bids submitted in the Day-ahead Energy Market for each Load Serving Entity, separately by Zone. Using Demand Bid Screening, the Office of the Interconnection will automatically reject a Load Serving Entity's Demand Bids in any future Operating Day for which the Load Serving Entity submits bids if the total megawatt volume of such bids would exceed the Load Serving Entity's Demand Bid Limit for any hour in such Operating Day, unless the Office of the Interconnection permits an exception pursuant to subsection (d) below.

(b) On a daily basis, PJM will update and post each Load Serving Entity's Demand Bid Limit in each applicable Zone. Such Demand Bid Limit will apply to all Demand Bids submitted by that Load Serving Entity for each future Operating Day for which it submits bids. The Demand Bid Limit is calculated using the following equation:

Demand Bid Limit = greater of (Zonal Peak Demand Reference Point * 1.3), or (Zonal Peak Demand Reference Point + 10MW)

Where:

1. Zonal Peak Demand Reference Point = for each Zone: the product of (a) LSE Recent Load Share, multiplied by (b) Peak Daily Load Forecast.
2. LSE Recent Load Share is the Load Serving Entity's highest share of Network Load in each Zone for any hour over the most recently available seven Operating Days for which PJM has data.
3. Peak Daily Load Forecast is PJM's highest available peak load forecast for each applicable Zone that is calculated on a daily basis.

(c) A Load Serving Entity whose Demand Bids are rejected as a result of Demand Bid Screening may change its Demand Bids to reduce its total megawatt volume to a level that does

not exceed its Demand Bid Limit, and may resubmit them subject to the applicable rules related to bid submission outlined in Tariff, Operating Agreement and PJM Manuals.

(d) PJM may allow a Load Serving Entity to submit bids in excess of its Demand Bid Limit when circumstances exist that will cause, or are reasonably expected to cause, a Load Serving Entity's actual load to exceed its Demand Bid Limit on a given Operating Day. Examples of such circumstances include, but are not limited to, changes in load commitments due to state sponsored auctions, mergers and acquisitions between PJM Members, and sales and divestitures between PJM Members. A Load Serving Entity may submit a written exception request to the Office of Interconnection for a higher Demand Bid Limit for an affected Operating Day. Such request must include a detailed explanation of the circumstances at issue and supporting documentation that justify the Load Serving Entity's expectation that its actual load will exceed its Demand Bid Limit.

1.10.2 Pool-scheduled Resources.

Pool-scheduled resources are those resources for which Market Participants submitted offers to sell energy in the Day-ahead Energy Market and offers to reduce demand in the Day-ahead Energy Market, which the Office of the Interconnection scheduled in the Day-ahead Energy Market as well as generators committed by the Office of the Interconnection subsequent to the Day-ahead Energy Market. Such resources shall be committed to provide energy in the real-time dispatch unless the schedules for such units are revised pursuant to section 1.10.9 below or Operating Agreement, Schedule 1, section 1.11. Pool-scheduled resources shall be governed by the following principles and procedures.

(a) Pool-scheduled resources shall be selected by the Office of the Interconnection on the basis of the prices offered for energy and demand reductions and related services, whether the resource is expected to be needed to maintain system reliability during the Operating Day, Start-up Costs, No-load Costs, and cancellation fees, and the specified operating characteristics, offered by Market Sellers to the Office of the Interconnection by the offer deadline specified in section 1.10.1A above. Hydropower units can only be pool-scheduled if they are pumped storage units and scheduled by the Office of the Interconnection pursuant to the hydro optimization tool in the Day-ahead Energy Market.

(b) A resource that is scheduled by a Market Participant to support a bilateral sale, or that is self-scheduled by a Generating Market Buyer, shall not be selected by the Office of the Interconnection as a pool-scheduled resource except in an Emergency.

(c) Market Sellers offering energy from hydropower or other facilities with fuel or environmental limitations may submit data to the Office of the Interconnection that is sufficient to enable the Office of the Interconnection to determine the available operating hours of such facilities.

(d) The Market Seller of a resource selected as a pool-scheduled resource shall receive payments or credits for energy, demand reductions or related services, or for Start-up Costs and

No-load Costs, from the Office of the Interconnection on behalf of the Market Buyers in accordance with Operating Agreement, Schedule 1, section 3. Alternatively, the Market Seller shall receive, in lieu of Start-up Costs and No-load Costs, its actual costs incurred, if any, up to a cap of the resource's Start-up Costs, if the Office of the Interconnection cancels its selection of the resource as a pool-scheduled resource and so notifies the Market Seller before the resource is synchronized.

(e) Market Participants shall make available their pool-scheduled resources to the Office of the Interconnection for coordinated operation to supply the Operating Reserves needs of the applicable Control Zone.

(f) Economic Load Response Participants offering to reduce demand shall specify: (i) the amount of the offered curtailment, which must equal or exceed 0.1 megawatts, in minimum increments of 0.1 megawatts; (ii) the real-time Locational Marginal Price above which the end-use customer will reduce load; and (iii) at the Economic Load Response Participant's option, shut-down costs associated with reducing load, including direct labor and equipment costs, opportunity costs, and/or a minimum number of contiguous hours for which the load reduction must be committed. Economic Load Response Participants submitting offers to reduce demand in the Day-ahead Energy Market and/or the Real-time Energy Market may establish an incremental offer curve, provided that such offer curve shall be limited to ten price pairs (in MWs). Economic Load Response Participants offering to reduce demand shall also indicate the hours that the demand reduction is not available.

1.10.3 Self-scheduled Resources.

Self-scheduled resources shall be governed by the following principles and procedures.

(a) Each Generating Market Buyer shall use all reasonable efforts, consistent with Good Utility Practice, not to self-schedule resources in excess of its Equivalent Load.

(b) The offered prices of resources that are self-scheduled and not dispatchable by the Office of the Interconnection shall not be considered by the Office of the Interconnection in determining Locational Marginal Prices.

(c) Market Participants shall make available their self-scheduled resources to the Office of the Interconnection for coordinated operation to supply the Operating Reserves needs of the applicable Control Zone, by submitting an offer as to such resources.

(d) A Market Participant self-scheduling a resource in the Day-ahead Energy Market that does not deliver the energy in the Real-time Energy Market, shall replace the energy not delivered with energy from the Real-time Energy Market and shall pay for such energy at the applicable Real-time Price.

(e) A Market Participant self-scheduling a resource to supply Synchronized Reserve in the Day-ahead Synchronized Reserve Market that does not deliver the scheduled megawatt quantity in the applicable real-time reserve market, shall replace the Synchronized Reserve not delivered

and shall pay for such Synchronized Reserve at the applicable Real-time Synchronized Reserve Market Clearing Price. Market Participants shall not self-schedule a resource to provide Secondary Reserve or Non-Synchronized Reserve.

(f) For energy, hydropower units, excluding pumped storage units, may only be self-scheduled.

(g) A resource that has been self-scheduled shall not receive payments or credits for Start-up Costs or No-load Costs.

1.10.4 Capacity Resources.

(a) A Generation Capacity Resource committed to service of PJM loads under the Reliability Pricing Model or Fixed Resource Requirement Alternative that is selected as a pool-scheduled resource shall be made available for scheduling and dispatch at the direction of the Office of the Interconnection. Such a Generation Capacity Resource that does not deliver energy as scheduled shall be deemed to have experienced a Generator Forced Outage to the extent of such energy not delivered. A Market Participant offering such Generation Capacity Resource in the Day-ahead Energy Market shall replace the energy not delivered with energy from the Real-time Energy Market and shall pay for such energy at the applicable Real-time Price.

(b) Energy from a Generation Capacity Resource committed to service of PJM loads under the Reliability Pricing Model or Fixed Resource Requirement Alternative that has not been scheduled in the Day-ahead Energy Market may be sold on a bilateral basis by the Market Seller, may be self-scheduled, or may be offered for dispatch during the Operating Day in accordance with the procedures specified in this Schedule. Such a Generation Capacity Resource that has not been scheduled in the Day-ahead Energy Market and that has been sold on a bilateral basis must be made available upon request to the Office of the Interconnection for scheduling and dispatch during the Operating Day if the Office of the Interconnection declares a Maximum Generation Emergency. Any such resource so scheduled and dispatched shall receive the applicable Real-time Price for energy delivered.

1.10.5 External Resources.

(a) External Resources may submit offers to the PJM Interchange Energy Market, in accordance with the day-ahead and real-time scheduling processes specified above. An External Resource selected as a pool-scheduled resource shall be made available for scheduling and dispatch at the direction of the Office of the Interconnection, and except as specified below shall be compensated on the same basis as other pool-scheduled resources. External Resources that are not capable of Dynamic Transfer shall, if selected by the Office of the Interconnection on the basis of the Market Seller's Offer Data, be block loaded on an hourly scheduled basis. Market Sellers shall offer External Resources to the PJM Interchange Energy Market on either a resource-specific or an aggregated resource basis. A Market Participant whose pool-scheduled resource does not deliver the energy scheduled in the Day-ahead Energy Market shall replace

such energy not delivered as scheduled in the Day-ahead Energy Market with energy from the PJM Real-time Energy Market and shall pay for such energy at the applicable Real-time Price.

(b) Offers for External Resources from an aggregation of two or more generating units shall so indicate, and shall specify, in accordance with the Offer Data requirements specified by the Office of the Interconnection: (i) energy prices; (ii) hours of energy availability; (iii) a minimum dispatch level; (iv) a maximum dispatch level; and (v) unless such information has previously been made available to the Office of the Interconnection, sufficient information, as specified in the PJM Manuals, to enable the Office of the Interconnection to model the flow into the PJM Region of any energy from the External Resources scheduled in accordance with the Offer Data.

(c) Offers for External Resources on a resource-specific basis shall specify the resource being offered, along with the information specified in the Offer Data as applicable.

1.10.6 External Market Buyers.

(a) Deliveries to an External Market Buyer not subject to Dynamic Transfer by the Office of the Interconnection shall be delivered on a block loaded basis to the bus or buses at the electrical boundaries of the PJM Region, or in such area with respect to an External Market Buyer's load within such area not served by Network Service, at which the energy is delivered to or for the External Market Buyer. External Market Buyers shall be charged (which charge may be positive or negative) at either the Day-ahead Prices or Real-time Prices, whichever is applicable, for energy at the foregoing bus or buses.

(b) An External Market Buyer's hourly schedules for energy purchased from the PJM Interchange Energy Market shall conform to the ramping and other applicable requirements of the interconnection agreement between the PJM Region and the Control Area to which, whether as an intermediate or final point of delivery, the purchased energy will initially be delivered.

(c) The Office of the Interconnection shall curtail deliveries to an External Market Buyer if necessary to maintain appropriate reserve levels for a Control Zone as defined in the PJM Manuals, or to avoid shedding load in such Control Zone.

1.10.7 Bilateral Transactions.

Bilateral transactions as to which the parties have notified the Office of the Interconnection by the deadline specified in section 1.10.1A above that they elect not to be included in the Day-ahead Energy Market and that they are not willing to incur Transmission Congestion Charges in the Real-time Energy Market shall be curtailed by the Office of the Interconnection as necessary to reduce or alleviate transmission congestion. Bilateral transactions that were not included in the Day-ahead Energy Market and that are willing to incur congestion charges and bilateral transactions that were accepted in the Day-ahead Energy Market shall continue to be implemented during periods of congestion, except as may be necessary to respond to Emergencies.

1.10.8 Office of the Interconnection Responsibilities.

(a) The Office of the Interconnection shall use its best efforts to determine (i) the least-cost means of satisfying the projected hourly requirements for energy, Operating Reserves, and other ancillary services of the Market Buyers, including the reliability requirements of the PJM Region, of the Day-ahead Energy Market, and (ii) the least-cost means of satisfying the Operating Reserve and other ancillary service requirements for any portion of the load forecast of the Office of the Interconnection for the Operating Day in excess of that scheduled in the Day-ahead Energy Market. In making these determinations, the Office of the Interconnection shall take into account: (i) the Office of the Interconnection's forecasts of PJM Interchange Energy Market and PJM Region energy requirements, giving due consideration to the energy requirement forecasts and purchase requests submitted by Market Buyers and PRD Curves properly submitted by PRD Providers; (ii) the offers submitted by Market Sellers; (iii) the availability of limited energy resources; (iv) the capacity, location, and other relevant characteristics of self-scheduled resources; (v) the objectives of each Control Zone for Operating Reserves, as specified in the PJM Manuals; (vi) the requirements of each Regulation Zone for Regulation and other ancillary services, as specified in the PJM Manuals; (vii) the benefits of avoiding or minimizing transmission constraint control operations, as specified in the PJM Manuals; and (viii) such other factors as the Office of the Interconnection reasonably concludes are relevant to the foregoing determination, including, without limitation, transmission constraints on external coordinated flowgates to the extent provided by Operating Agreement, Schedule 1, section 1.7.6. The Office of the Interconnection shall develop a Day-ahead Energy Market based on the foregoing determination, and shall determine the Day-ahead Prices resulting from such schedule. The Office of the Interconnection shall report the planned schedule for a hydropower resource to the operator of that resource as necessary for plant safety and security, and legal limitations on pond elevations.

(b) By 1:30 p.m., or as soon as practicable thereafter, of the day before each Operating Day, or such other deadline as may be specified by the Office of the Interconnection in the PJM Manuals, the Office of the Interconnection shall: (i) post the aggregate Day-ahead Energy Market results; (ii) post the Day-ahead Prices; and (iii) inform the Market Sellers, Market Buyers, and Economic Load Response Participants of their scheduled injections, withdrawals, and demand reductions respectively. The foregoing notwithstanding, the deadlines set forth in this subsection shall not apply if the Office of the Interconnection is unable to obtain Market Participant bid/offer data due to extraordinary circumstances. For purposes of this subsection, extraordinary circumstances shall mean a technical malfunction that limits, prohibits or otherwise interferes with the ability of the Office of the Interconnection to obtain Market Participant bid/offer data prior to 11:59 p.m. on the day before the affected Operating Day. Extraordinary circumstances do not include a Market Participant's inability to submit bid/offer data to the Office of the Interconnection. If the Office of the Interconnection is unable to clear the Day-ahead Energy Market prior to 11:59 p.m. on the day before the affected Operating Day as a result of such extraordinary circumstances, the Office of the Interconnection shall notify Members as soon as practicable.

(c) Following posting of the information specified in section 1.10.8(b), and absent extraordinary circumstances preventing the clearing of the Day-ahead Energy Market, the Office of the Interconnection shall revise its schedule of generation resources to reflect updated

projections of load, conditions affecting electric system operations in the PJM Region, the availability of and constraints on limited energy and other resources, transmission constraints, and other relevant factors.

(d) Market Buyers shall pay PJMSettlement and Market Sellers shall be paid by PJMSettlement for the quantities of energy scheduled in the Day-ahead Energy Market at the Day-ahead Prices when the Day-ahead Price is positive. Market Buyers shall be paid by PJMSettlement and Market Sellers shall pay PJMSettlement for the quantities of energy scheduled in the Day-ahead Energy Market at the Day-ahead Prices when the Day-ahead Price is negative. Economic Load Response Participants shall be paid for scheduled demand reductions pursuant to Operating Agreement, Schedule 1, section 3.3A. Notwithstanding the foregoing, if the Office of the Interconnection is unable to clear the Day-ahead Energy Market prior to 11:59 p.m. on the day before the affected Operating Day due to extraordinary circumstances as described in subsection (b) above, it will be declared a Market Suspension, and Day-ahead Prices shall be determined pursuant to Operating Agreement, Schedule 1, section 2.6.1. If the Office of the Interconnection declares a Market Suspension, it shall notify Market Participants of the Market Suspension as soon as practicable.

(e) If the Office of the Interconnection discovers a *potential* error in prices and/or cleared quantities in the Day-ahead Energy Market or Day-ahead Ancillary Services Markets, or the Real-time Energy Market or Real-time Ancillary Services Markets after it has posted the results for these markets on its Web site, the Office of the Interconnection shall notify Market Participants as soon as possible after it is found, but in no event later than 12:00 p.m. of the second Business Day following the Operating Day for the Real-time Energy Market and Real-time Ancillary Services Markets, and no later than 5:00 p.m. of the second Business Day following the initial publication of the results for the Day-ahead Energy Market and Day-ahead Ancillary Services Markets. After this initial notification, if the Office of the Interconnection determines it is necessary to post modified results, it shall provide notification of its intent to do so, *along with a description detailing the cause and scope of the error*, by no later than 5:00 p.m. of the fifth Business Day following the Operating Day for the Real-time Energy Market and Real-time Ancillary Services Markets, and no later than 5:00 p.m. of the fifth Business Day following the initial publication of the results in the Day-ahead Energy Market and Day-ahead Ancillary Services Markets. *The provided description will not contain information that is market sensitive or confidential.* Thereafter, the Office of the Interconnection must post on its Web site the corrected results by no later than 5:00 p.m. of the tenth calendar day following the Operating Day for the Day-ahead Energy Market, Real-time Energy Market, and Day-ahead Ancillary Services Markets, and Real-time Ancillary Service Markets. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced market results are under publicly noticed review by the FERC.

(f) Consistent with Operating Agreement, section 18.17.1, and notwithstanding anything to the contrary in the Operating Agreement or in the PJM Tariff, to allow the tracking of Market Participants' non-aggregated bids and offers over time as required by FERC Order No. 719, the Office of the Interconnection shall post on its Web site the non-aggregated bid data and Offer

Data submitted by Market Participants (for participation in the PJM Interchange Energy Market) approximately four months after the bid or offer was submitted to the Office of the Interconnection.

1.10.9 Hourly Scheduling.

(a) Following the initial posting by the Office of the Interconnection of the Locational Marginal Prices resulting from the Day-ahead Energy Market, and subject to the right of the Office of the Interconnection to schedule and dispatch pool-scheduled resources and to direct that schedules be changed in an Emergency, and absent extraordinary circumstances preventing the clearing of the Day-ahead Energy Market, a generation rebidding period shall exist. Typically the rebidding period shall be from the time the Office of the Interconnection posts the results of the Day-ahead Energy Market until 2:15 p.m. on the day before each Operating Day. However, should the clearing of the Day-ahead Energy Market be significantly delayed, the Office of the Interconnection may establish a revised rebidding period. During the rebidding period, Market Participants may submit revisions to generation Offer Data for the next Operating Day. Adjustments to the Day-ahead Energy Market shall be settled at the applicable Real-time Prices, and shall not affect the obligation to pay or receive payment for the quantities of energy scheduled in the Day-ahead Energy Market at the applicable Day-ahead Prices.

(b) A Market Participant may adjust the schedule of a resource under its dispatch control on an hour-to-hour basis beginning at 6:30 p.m. of the day before each Operating Day, provided that the Office of the Interconnection is notified not later than 65 minutes prior to the hour in which the adjustment is to take effect, as follows and as specified in section 1.10.9A below:

- i) A Generating Market Buyer may self-schedule any of its resource increments, including hydropower resources, not previously designated as self-scheduled and not selected as a pool-scheduled resource in the Day-ahead Energy Market;
- ii) A Market Participant may request the scheduling of a non-firm bilateral transaction; or
- iii) A Market Participant may request the scheduling of deliveries or receipts of Spot Market Energy; or
- iv) A Generating Market Buyer may remove from service a resource increment, including a hydropower resource, that it had previously designated as self-scheduled, provided that the Office of the Interconnection shall have the option to schedule energy from any such resource increment that is a Capacity Resource at the price offered in the scheduling process, with no obligation to pay any Start-Up Costs.

(c) An External Market Buyer may refuse delivery of some or all of the energy it requested to purchase in the Day-ahead Energy Market by notifying the Office of the Interconnection of the adjustment in deliveries not later than 65 minutes prior to the hour in which the adjustment is

to take effect, but any such adjustment shall not affect the obligation of the External Market Buyer to pay for energy scheduled on its behalf in the Day-ahead Energy Market at the applicable Day-ahead Prices.

(d) The Office of the Interconnection shall provide External Market Buyers and External Market Sellers and parties to bilateral transactions with any revisions to their schedules resulting from the rebidding period by 6:30 p.m. on the day before each Operating Day. The Office of the Interconnection may also commit additional resources after such time as system conditions require. For each hour in the Operating Day, as soon as practicable after the deadlines specified in the foregoing subsection of this section 1.10, the Office of the Interconnection shall provide External Market Buyers and External Market Sellers and parties to bilateral transactions with any revisions to their schedules for the hour.

1.10.9A Updating Offers in Real-time

(a) Each Market Seller may submit Real-time Offers for a resource up to 65 minutes before the applicable clock hour, and such Real-time Offers shall supersede any previous offer for that resource for the clock hour, as further described in the PJM Manuals and subject to the following conditions:

(i) A market-based Real-time Offer shall not exceed the applicable energy offer caps specified in this Schedule. Once a Market Seller's resource is committed for an applicable clock hour, the Market Seller may not increase its Incremental Energy Offer and may only submit a market-based Real-time Offer that is higher than its market-based offer that was in effect at the time of commitment to reflect increases in the resource's cost-based Start-up Costs and cost-based No-load Costs. The Market Seller may elect not to have its market-based offer considered for dispatch and to have only its lowest cost-based offer considered for the remainder of the Operating Day.

(ii) Cost-based Real-time Offers shall be submitted to the Office of the Interconnection in the form specified by the Office of the Interconnection's Offer Data specification, Operating Agreement, Schedule 1, sections 1.10.1A(d) and 1.10.9B, Operating Agreement, Schedule 2 and the PJM Manuals, as applicable. If a Market Seller submits a market-based Real-time Offer for a particular clock hour in accordance with subsection (c) below, or if updates to a cost-based offer are required by the Market Seller's approved Fuel Cost Policy, the Market Seller shall update its previously submitted cost-based Real-time Offer.

(iii) If a Market Seller's available cost-based offer is not compliant with Operating Agreement, Schedule 2 and the PJM Manuals at the time a Market Seller submits a market-based Real-time Offer for an applicable clock hour during the Operating Day, the Market Seller must submit an updated cost-based Real-time Offer consisting of an Incremental Energy Offer, Start-up Cost, and No-load Cost for that clock hour that is compliant with Operating Agreement, Schedule 2 and the PJM Manuals.

(b) Each Market Seller may submit Real-time Offers for a resource during and through the end of the applicable clock hour to update only the following offer parameters, as further described in the PJM Manuals: (1) Economic Minimum; (2) Economic Maximum; (3) emergency minimum MW; (4) emergency maximum MW; (5) unit availability status; (6) fixed output indicator; (7) Synchronized Reserve maximum MW; and (8) Secondary Reserve maximum MW. Such Real-time Offers shall supersede any previous offer for that resource for the clock hour.

1.10.9B Offer Parameter Flexibility

(a) Market Sellers may, in accordance with sections 1.10.1A and 1.10.9A above, this section 1.10.9B, and the PJM Manuals, update offer parameters at any time up to 65 minutes before the applicable clock hour, including prior to the close of the Day-ahead Energy Market and prior to the close of the rebidding period specified in section 1.10.9, except that Market Sellers may not update their offers for the supply of energy, Secondary Reserve, Synchronized Reserve, Non-Synchronized Reserve, or demand reduction: (1) during the period after the close the Day-ahead Energy Market and prior to the posting of the Day-ahead Energy Market results pursuant to section 1.10.8(b); or (2) during the period after close of the rebidding period and prior to PJM announcing the results of the rebidding period pursuant to section 1.10.9(d).

(b) For generation resource offers, Market Sellers may vary for each clock hour during the entire Operating Day the following offer parameters: (1) cost-based Start-up Costs; (2) cost-based No-load Costs; (3) Incremental Energy Offer; (4) Economic Minimum and Economic Maximum; (5) emergency minimum MW and emergency maximum MW; (6) ramp rate; (7) Synchronized Reserve maximum MW; (8) Secondary Reserve maximum MW; and (9) for Real-time Offers only, (i) notification time and (ii) for uncommitted hours only, Minimum Run Time.

(c) For Economic Load Response Participant resource offers, Market Sellers may vary for each clock hour during the entire Operating Day the following offer parameters: (1) shutdown costs, (2) Incremental Energy Offer; (3) Economic Minimum; (4) Economic Maximum; and (5) for Real-time Offers only, (i) notification time and (ii) for uncommitted hours only, minimum down time.

(d) After the announcement of the results of the rebidding period pursuant to section 1.10.9(d), a Market Seller may submit a Real-time Offer where offer parameters may differ from the offer originally submitted in the Day-ahead Energy Market, except that a Market Seller may not submit a Real-time Offer that changes, of the offer parameters listed in section 1.10.1A(d), the MW amounts specified in the Incremental Energy Offer, MW amounts specified in the ramp rate, maximum run time, and availability; provided, however, Market Sellers of dual-fueled resources may submit Real-time Offers for such resources that change the availability of a submitted cost-based offer.

3.2 Market Settlements.

If a dollar-per-MW-hour value is applied in a calculation under this section 3.2 where the interval of the value produced in that calculation is less than an hour, then for purposes of that calculation the dollar-per-MW hour value is divided by the number of Real-time Settlement Intervals in the hour.

3.2.1 Spot Market Energy.

(a) The Office of the Interconnection shall calculate System Energy Prices in the form of Day-ahead System Energy Prices and Real-time System Energy Prices for the PJM Region, in accordance with Operating Agreement, Schedule 1, section 2.

(b) Each Market Participant shall be charged for all of its Market Participant Energy Withdrawals scheduled in the Day-ahead Energy Market at the Day-ahead System Energy Price to be served in the PJM Interchange Energy Market.

(c) Each Market Participant shall be paid for all of its Market Participant Energy Injections scheduled in the Day-ahead Energy Market at the Day-ahead System Energy Price to be delivered to the PJM Interchange Energy Market.

(d) For each Day-ahead Settlement Interval during an Operating Day, the Office of the Interconnection shall calculate Spot Market Energy charges for each Market Participant as the difference between the sum of its Market Participant Energy Withdrawals scheduled times the Day-ahead System Energy Price and the sum of its Market Participant Energy Injections scheduled times the Day-ahead System Energy Price.

(e) For each Real-time Settlement Interval during an Operating Day, the Office of the Interconnection shall calculate Spot Market Energy charges for each Market Participant as the difference between the sum of its real-time Market Participant Energy Withdrawals less its scheduled Market Participant Energy Withdrawals times the Real-time System Energy Price and the sum of its real-time Market Participant Energy Injections less scheduled Market Participant Energy Injections times the Real-time System Energy Price. The Revenue Data for Settlements determined for each Real-time Settlement Interval in accordance with Operating Agreement, Schedule 1, section 3.1A shall be used in determining the real-time Market Participant Energy Withdrawals and Market Participant Energy Injections used to calculate Spot Market Energy charges under this subsection (e).

(f) For pool External Resources, the Office of the Interconnection shall model, based on an appropriate flow analysis, the megawatts of real-time energy injections to be delivered from each such resource to the corresponding Interface Pricing Point between adjacent Control Areas and the PJM Region.

3.2.2 Regulation.

(a) Each Market Participant that is a Load Serving Entity in a Regulation Zone shall have an hourly Regulation objective equal to its pro rata share of the Regulation requirements of such Regulation Zone for the hour, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Regulation Zone for the hour ("Regulation Obligation"). A Market Participant with an hourly Regulation Obligation shall be charged the pro rata share of the sum of the Regulation market performance clearing price credits and Regulation market capability clearing price credits for the Real-time Settlement Intervals in an hour.

$\text{Regulation Charge} = \text{Hourly Regulation Obligation Share} * (\text{sum of the Real-time Settlement Interval Regulation credits in an hour})$

(b) Each Market Participant supplying Regulation in a Regulation Zone at the direction of the Office of the Interconnection shall be credited for each of its resources such that the calculated credit for each increment of Regulation provided by each resource shall be the higher of: (i) the Regulation market-clearing price; or (ii) the sum of the applicable Regulation offers for a resource determined pursuant to section 3.2.2A.1 below, the unit-specific shoulder hour opportunity costs described in subsection (e) of this section, the unit-specific inter-temporal opportunity costs, and the unit-specific opportunity costs discussed in subsection (d) of this section.

(c) The total Regulation market-clearing price in each Regulation Zone shall be determined in the Real-time Price software program, which is known as the pricing run, for each Real-time Settlement Interval. The total Regulation market-clearing price shall include: (i) the performance Regulation market-clearing price in a Regulation Zone that shall be calculated in accordance with subsection (g) of this section; (ii) the capability Regulation market-clearing price that shall be calculated in accordance with subsection (h) of this section; and (iii) a Regulation resource's unit-specific opportunity costs during the 5-minute period, determined as described in subsection (d) below, divided by the unit-specific benefits factor described in subsection (j) of this section and divided by the historic accuracy score of the resource from among the resources selected to provide Regulation. A resource's Regulation offer by any Market Seller that fails the three-pivotal supplier test set forth in section 3.2.2A.1 below shall not exceed the cost of providing Regulation from such resource, plus twelve dollars, as determined pursuant to the formula in Operating Agreement, Schedule 1, section 1.10.1A(e).

(d) In determining the Regulation 5-minute clearing price for each Regulation Zone, the estimated unit-specific opportunity costs of a generation resource offering to sell Regulation in each regulating hour, except for hydroelectric resources, shall be equal to the product of (i) the deviation of the set point of the generation resource that is expected to be required in order to provide Regulation from the generation resource's expected output level if it had been dispatched in economic merit order times, (ii) the absolute value of the difference between the expected Locational Marginal Price at the generation bus for the generation resource and the lesser of the available market-based or highest available cost-based energy offer from the

generation resource (at the megawatt level of the Regulation set point for the resource) in the PJM Interchange Energy Market.

For hydroelectric resources offering to sell Regulation in a regulating hour, the estimated unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the full value of the Locational Marginal Price at that generation bus for each megawatt of Regulation capability.

The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead megawatt commitment greater than zero shall be equal to the product of (i) the deviation of the set point of the hydroelectric resource that is expected to be required in order to provide Regulation from the hydroelectric resource's expected output level if it had been dispatched in economic merit order times (ii) the difference between the expected Locational Marginal Price at the generation bus for the hydroelectric resource and the average of the Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating. Estimated opportunity costs shall be zero for hydroelectric resources for which the average Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period, excluding those Real-time Settlement Intervals during which all available units at the hydroelectric resource were operating is higher than the actual Locational Marginal Price at the generator bus for the Real-time Settlement Interval.

The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead megawatt commitment greater than zero shall be equal to the product of (i) the deviation of the set point of the hydroelectric resource that is expected to be required in order to provide Regulation from the hydroelectric resource's expected output level if it had been dispatched in economic merit order times (ii) the difference between the average of the Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating and the expected Locational Marginal Price at the generation bus for the hydroelectric resource. Estimated opportunity costs shall be zero for hydroelectric resources for which the actual Locational Marginal Price at the generator bus for the Real-time Settlement Interval is higher than the average Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period, excluding those Real-time Settlement Intervals during which all available units at the hydroelectric resource were operating.

For the purpose of committing resources and setting Regulation market clearing prices, the Office of the Interconnection shall utilize day-ahead Locational Marginal Prices to calculate opportunity costs for hydroelectric resources. For the purposes of settlements, the Office of the Interconnection shall utilize the real-time Locational Marginal Prices to calculate opportunity costs for hydroelectric resources.

Estimated opportunity costs for Economic Load Response Participant resources to provide Regulation are zero.

(e) In determining the credit under subsection (b) to a Market Participant selected to provide Regulation in a Regulation Zone and that actively follows the Office of the Interconnection's Regulation signals and instructions, the unit-specific opportunity cost of a generation resource shall be determined for (1) each Real-time Settlement Interval that the Office of the Interconnection requires a generation resource to provide Regulation, and (2) the last three Real-time Settlement Intervals of the preceding shoulder hour and the first three Real-time Settlement Intervals of the following shoulder hour in accordance with the PJM Manuals and below.

The unit-specific opportunity cost incurred during the Real-time Settlement Interval in which the Regulation obligation is fulfilled shall be equal to the product of (i) the deviation of the generation resource's output necessary to follow the Office of the Interconnection's Regulation signals from the generation resource's expected output level if it had been dispatched in economic merit order times (ii) the absolute value of the difference between the Locational Marginal Price at the generation bus for the generation resource and the lesser of the available market-based or highest available cost-based energy offer from the generation resource (at the actual megawatt level of the resource when the actual megawatt level is within the tolerance defined in the PJM Manuals for the Regulation set point, or at the Regulation set point for the resource when it is not within the corresponding tolerance) in the PJM Interchange Energy Market. Opportunity costs for Economic Load Response Participant resources to provide Regulation are zero.

The unit-specific opportunity costs associated with uneconomic operation during each of the preceding three Real-time Settlement Intervals of the shoulder hour shall be equal to the product of (i) the deviation between the set point of the generation resource that is expected to be required in the initial regulating Real-time Settlement Interval in order to provide Regulation and the resource's expected output in each of the preceding three Real-time Settlement Intervals of the shoulder hour times (ii) the absolute value of the difference between the Locational Marginal Price at the generation bus for the generation resource in each of the preceding three Real-time Settlement Intervals of the shoulder hour and the lesser of the available market-based or highest available cost-based energy offer from the generation resource (at the megawatt level of the Regulation set point for the resource in the initial regulating Real-time Settlement Interval) in the PJM Interchange Energy Market, all as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals.

The unit-specific opportunity costs associated with uneconomic operation during each of the following three Real-time Settlement Intervals of the shoulder hour shall be equal to the product of (i) the deviation between the set point of the generation resource that is expected to be required in the final regulating Real-time Settlement Interval in order to provide Regulation and the resource's expected output in each of the following three Real-time Settlement Intervals of the shoulder hour times (ii) the absolute value of the difference between the Locational Marginal Price at the generation bus for the generation resource in each of the following three Real-time Settlement Intervals of the shoulder hour and the lesser of the available market-based or highest available cost-based energy offer from the generation resource (at the megawatt level of the Regulation set point for the resource in final regulating hour) in the PJM Interchange Energy

Market all as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals.

(f) Any amounts credited for Regulation in an hour in excess of the Regulation market-clearing price in that hour shall be allocated and charged to each Market Participant in a Regulation Zone that does not meet its hourly Regulation obligation in proportion to its purchases of Regulation in such Regulation Zone in megawatt-hours during that hour.

(g) To determine the Regulation market performance-clearing price for each Regulation Zone, the Office of the Interconnection shall adjust the submitted performance offer for each resource in accordance with the historical performance of that resource, the amount of Regulation that resource will be dispatched based on the ratio of control signals calculated by the Office of the Interconnection, and the unit-specific benefits factor described in subsection (j) of this section for which that resource is qualified. The maximum adjusted performance offer of all cleared resources will set the Regulation market performance-clearing price.

The owner of each Regulation resource that actively follows the Office of the Interconnection's Regulation signals and instructions, will be credited for Regulation performance by multiplying the assigned MW(s) by the Regulation market performance-clearing price, by the ratio between the requested mileage for the Regulation dispatch signal assigned to the Regulation resource and the Regulation dispatch signal assigned to traditional resources, and by the Regulation resource's accuracy score calculated in accordance with subsection (k) of this section.

(h) The Office of the Interconnection shall divide each Regulation resource's capability offer by the unit-specific benefits factor described in subsection (j) of this section and divided by the historic accuracy score for the resource for the purposes of committing resources and setting the market clearing prices.

The Office of the Interconnection shall calculate the Regulation market capability-clearing price for each Regulation Zone by subtracting the Regulation market performance-clearing price described in subsection (g) from the total Regulation market clearing price described in subsection (c). This residual sets the Regulation market capability-clearing price for that market Real-time Settlement Interval.

The owner of each Regulation resource that actively follows the Office of the Interconnection's Regulation signals and instructions will be credited for Regulation capability based on the assigned MW and the capability Regulation market-clearing price multiplied by the Regulation resource's accuracy score calculated in accordance with subsection (k) of this section.

(i) In accordance with the processes described in the PJM Manuals, the Office of the Interconnection shall: (i) calculate inter-temporal opportunity costs for each applicable resource; (ii) include such inter-temporal opportunity costs in each applicable resource's offer to sell frequency Regulation service; and (iii) account for such inter-temporal opportunity costs in the Regulation market-clearing price.

(j) The Office of the Interconnection shall calculate a unit-specific benefits factor for each of the dynamic Regulation signal and traditional Regulation signal in accordance with the PJM Manuals. Each resource shall be assigned a unit-specific benefits factor based on their order in the merit order stack for the applicable Regulation signal. The unit-specific benefits factor is the point on the benefits factor curve that aligns with the last megawatt, adjusted by historical performance, that resource will add to the dynamic resource stack. Resources following the dynamic Regulation signal which have a unit-specific benefits factor less than 0.1 will not be considered for the purposes of committing resources. The unit-specific benefits factor for the traditional Regulation signal shall be equal to one.

(k) The Office of the Interconnection shall calculate each Regulation resource's accuracy score. The accuracy score shall be the average of a delay score, correlation score, and energy score for each ten second interval. For purposes of setting the interval to be used for the correlation score and delay scores, PJM will use the maximum of the correlation score plus the delay score for each interval.

The Office of the Interconnection shall calculate the correlation score using the following statistical correlation function (r) that measures the delay in response between the Regulation signal and the resource change in output:

$$\text{Correlation Score} = r_{\text{Signal,Response}(\delta, \delta+5 \text{ Min})};$$

$\delta=0 \text{ to } 5 \text{ Min}$

where δ is delay.

The Office of the Interconnection shall calculate the delay score using the following equation:

$$\text{Delay Score} = \text{Abs} ((\delta - 5 \text{ Minutes}) / (5 \text{ Minutes})).$$

The Office of the Interconnection shall calculate an energy score as a function of the difference in the energy provided versus the energy requested by the Regulation signal while scaling for the number of samples. The energy score is the absolute error (ϵ) as a function of the resource's Regulation capacity using the following equations:

$$\text{Energy Score} = 1 - 1/n \sum \text{Abs} (\text{Error});$$

$$\text{Error} = \text{Average of Abs} ((\text{Response} - \text{Regulation Signal}) / (\text{Hourly Average Regulation Signal})); \text{ and}$$

n = the number of samples in the hour and the energy.

The Office of the Interconnection shall calculate an accuracy score for each Regulation resource that is the average of the delay score, correlation score, and energy score for a five-minute period using the following equation where the energy score, the delay score, and the correlation score are each weighted equally:

$$\text{Accuracy Score} = \max ((\text{Delay Score}) + (\text{Correlation Score})) + (\text{Energy Score}).$$

The historic accuracy score will be based on a rolling average of the Real-time Settlement Interval accuracy scores, with consideration of the qualification score, as defined in the PJM Manuals.

(1) During a Market Suspension where the suspension is less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Regulation, the resources providing Regulation at the direction of the Office of the Interconnection will be compensated based on a calculated Regulation market-clearing price. Regulation market-clearing prices for each Real-time Settlement Interval associated with such Market Suspension shall be the average of the Regulation market-clearing prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

During a Market Suspension where the suspension is greater than twenty-four (24) consecutive hours, if the Office of the Interconnection is assigning Regulation, resources providing Regulation at the direction of the Office of the Interconnection will be compensated based on a calculated Regulation clearing price. The Regulation clearing price for each Real-time Settlement Interval will be determined by calculating a Regulation clearing cost for the online resources providing Regulation during the Market Suspension. The resource's Regulation clearing cost is determined by the summation of their Regulation offer and opportunity cost. The opportunity cost will be based on the resource's cost-based offer and will be determined as follows:

For online resources providing Regulation on a cost-based offer at the time of the Market Suspension, that cost-based offer will be used.

For online resources providing Regulation on a price-based offer at the time of the Market Suspension, the Office of the Interconnection shall use the cheapest available cost-based offer based on the dispatch cost formula as defined in Operating Agreement, Schedule 1, section 6.4.1(g) using the available cost-based offers in the Office of the Interconnection system at the time of the Market Suspension.

The highest cost resource, based on this Regulation clearing cost, will set the Regulation market-clearing price for each hour of the Market Suspension.

During a Market Suspension, if the Office of the Interconnection is not assigning Regulation resources, then the Regulation market-clearing price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period and no resource-specific opportunity cost will be calculated.

During a Market Suspension, the following Regulation components for all Real-time Settlement Intervals in the Market Suspension period will be determined as follows:

- (i) If the regulation accuracy score cannot be calculated during a Market Suspension, the 100-hour rolling average accuracy score will be used for the Market Suspension period.
- (ii) If the regulation mileage ratio cannot be calculated during a Market Suspension, the mileage ratio will be set to one (1) for the Market Suspension period.
- (iii) If the unit-specific benefits factor cannot be calculated during a Market Suspension, the unit-specific benefits factor would be based on the historical average unit-specific benefits factor over past hours that shared the same penetration of Regulation D resources that exist for the given Market Suspension hour.

3.2.2A Offer Price Caps.

3.2.2A.1 Applicability.

(a) Each hour, the Office of the Interconnection shall conduct a three-pivotal supplier test as described in this section. Regulation offers from Market Sellers that fail the three-pivotal supplier test shall be capped in the hour in which they failed the test at their cost based offers as determined pursuant to Operating Agreement, Schedule 1, section 1.10.1A(e). A Regulation supplier fails the three-pivotal supplier test in any hour in which such Regulation supplier and the two largest other Regulation suppliers are jointly pivotal.

(b) For the purposes of conducting the three-pivotal supplier test pursuant to this section, the following applies:

(i) The three-pivotal supplier test will include in the definition of available supply all offers from resources capable of satisfying the Regulation requirement of the PJM Region multiplied by the historic accuracy score of the resource and multiplied by the unit-specific benefits factor for which the capability cost-based offer plus the performance cost-based offer plus any eligible opportunity costs is no greater than 150 percent of the clearing price that would be calculated if all offers were limited to cost (plus eligible opportunity costs).

(ii) The three-pivotal supplier test will apply on a Regulation supplier basis (i.e. not a resource by resource basis) and only the Regulation suppliers that fail the three-pivotal supplier test will have their Regulation offers capped. A Regulation supplier for the purposes of this section includes corporate affiliates. Regulation from resources controlled by a Regulation supplier or its affiliates, whether by contract with unaffiliated third parties or otherwise, will be included as Regulation of that Regulation supplier. Regulation provided by resources owned by a Regulation supplier but controlled by an unaffiliated third party, whether by contract or otherwise, will be included as Regulation of that third party.

(iii) Each supplier shall be ranked from the largest to the smallest offered megawatt of eligible Regulation supply adjusted by the historic performance of each resource and the unit-specific benefits factor. Suppliers are then tested in order, starting with the three largest suppliers. For each iteration of the test, the two largest suppliers are combined with a third supplier, and the combined supply is subtracted from total effective supply. The resulting net amount of eligible supply is divided by the Regulation requirement for the hour to determine the residual supply index. Where the residual supply index for three pivotal suppliers is less than or equal to 1.0, then the three suppliers are jointly pivotal and the suppliers being tested fail the three pivotal supplier test. Iterations of the test continue until the combination of the two largest suppliers and a third supplier result in a residual supply index greater than 1.0, at which point the remaining suppliers pass the test. Any resource owner that fails the three-pivotal supplier test will be offer-capped.

3.2.3 Operating Reserves.

(a) A Market Seller's pool-scheduled resources capable of providing Operating Reserves shall be credited as specified below based on the applicable offer for the operation of such resource, provided that the resource was available for the entire time specified in the Offer Data for such resource. To the extent that sections 3.2.3A, 3.2.3A.001, and 3.2.3A.01 below do not meet the Synchronized Reserve Requirements, the Primary Reserve Requirements, and the 30-minute Reserve Requirements, the Office of the Interconnection shall schedule additional Operating Reserves pursuant to Section 1.7.17 and 1.10 of Schedule 1 of this Agreement. In addition the Office of the Interconnection shall schedule Operating Reserves pursuant to those sections to satisfy any unforeseen Operating Reserve requirements that are not reflected in the day-ahead market. PJMSettlement shall be the Counterparty to the purchases and sales of Operating Reserve in the PJM Interchange Energy Market.

(b) The following determination shall be made for each pool-scheduled resource that is scheduled in the Day-ahead Energy Market: the total offered price for Start-up Costs and No-load Costs and energy, determined on the basis of the resource's scheduled output, shall be compared to the total value of that resource's energy – as determined by the Day-ahead Energy Market and the Day-ahead Prices applicable to the relevant generation bus in the Day-ahead Energy Market. PJM shall also (i) determine whether any resources were scheduled in the Day-ahead Energy Market to provide Black Start service, Reactive Services or transfer interface control during the Operating Day because they are known or expected to be needed to maintain system reliability in a Zone during the Operating Day in order to minimize the total cost of Operating Reserves associated with the provision of such services and reflect the most accurate possible expectation of real-time operating conditions in the day-ahead model, which resources would not have otherwise been committed in the day-ahead security-constrained dispatch and (ii) report on the day following the Operating Day the megawatt quantities scheduled in the Day-ahead Energy Market for the above-enumerated purposes for the entire RTO.

Except as provided in section 3.2.3(n) below, if the total offered price for Start-up Costs (shutdown costs for Economic Load Response Participant resources) and No-load Costs and energy summed over all Day-ahead Settlement Intervals exceeds the total value summed over all

Day-ahead Settlement Intervals, the difference shall be credited to the Market Seller as a day-ahead Operating Reserve credit.

However, for the Day-ahead Settlement Intervals in which the resource is scheduled to provide energy in the Operating Day and the resource actually provides energy in at least one Real-time Settlement Interval in an hour that corresponds to such scheduled Day-ahead Settlement Intervals, a resource's day-ahead Operating Reserve credit shall be reduced by the greater of zero or the difference of the resource's Day-ahead Operating Reserve Target and the Balancing Operating Reserve Target, as determined below.

A resource's Day-ahead Operating Reserve Target shall be determined in accordance with the following equation:

$$(A + B) - C$$

Where:

A = Start-up Costs

B = the sum of day-ahead No-load Costs and energy over the applicable Real-time Settlement Intervals that correspond with Day-ahead Settlement Intervals in which the resource is scheduled. The day-ahead No-load Costs and energy are divided by twelve to determine the cost for each Real-time Settlement Interval.

C = the sum of the day-ahead revenues calculated for each Real-time Settlement Interval that corresponds with a Day-ahead Settlement Interval in which the resource is scheduled, where the day-ahead revenue for each such Real-time Settlement Interval equals the product of the megawatt amount of energy scheduled in the Day-ahead Energy Market and the Day-ahead Price at the applicable pricing point for the resource divided by twelve.

A resource's Balancing Operating Reserve Target shall be determined in accordance with the following equation:

$$D - (E + F)$$

Where:

D = the sum of Start-up Costs and No-load Costs and the incremental cost of energy summed over all Real-time Settlement Intervals that correspond to the Day-ahead Settlement Intervals in which the resource was scheduled;

E = [(the megawatt amount of energy provided in the Real-time Energy Market minus the megawatt amount of energy scheduled in the Day-ahead Energy Market) multiplied by the Real-time Price at the applicable pricing point for the resource] plus the sum of the day-ahead revenues as determined in part C of the above formula for determining the

Day-ahead Operating Reserve Target, summed over the applicable Real-time Settlement Intervals; and

F = the sum of all revenues earned for providing Secondary Reserves, Synchronized Reserves, Non-Synchronized Reserves, and Reactive Services over the applicable Real-time Settlement Intervals.

The Office of the Interconnection shall apply any balancing Operating Reserve credits allocated pursuant to this section 3.2.3(b) to real-time deviations or real-time load share plus exports, pursuant to Operating Agreement, Schedule 1, section 3.2.3(p), depending on whether the balancing Operating Reserve credits are related to resources scheduled during the reliability analysis for an Operating Day, or during the actual Operating Day.

(i) For resources scheduled by the Office of the Interconnection during the reliability analysis for an Operating Day, the associated balancing Operating Reserve credits shall be allocated based on the reason the resource was scheduled according to the following provisions:

(A) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to operate in real-time to augment the physical resources committed in the Day-ahead Energy Market to meet the forecasted real-time load plus the Operating Reserve requirement, the associated balancing Operating Reserve credits, identified as RA Credits for Deviations, shall be allocated to real-time deviations.

(B) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to maintain system reliability, the associated balancing Operating Reserve credits, identified as RA Credits for Reliability, shall be allocated according to ratio share of real time load plus export transactions.

(C) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource with a day-ahead schedule is required to deviate from that schedule to provide balancing Operating Reserves, the associated balancing Operating Reserve credits shall be segmented and separately allocated pursuant to subsections 3.2.3(b)(i)(A) or 3.2.3(b)(i)(B) hereof. Balancing Operating Reserve credits for such resources will be identified in the same manner as units committed during the reliability analysis pursuant to subsections 3.2.3(b)(i)(A) and 3.2.3(b)(i)(B) hereof.

(ii) For resources scheduled during an Operating Day, the associated balancing Operating Reserve credits shall be allocated according to the following provisions:

(A) If the Office of the Interconnection directs a resource to operate during an Operating Day to provide balancing Operating Reserves, the associated

balancing Operating Reserve credits, identified as RT Credits for Reliability, shall be allocated according to ratio share of load plus exports. The foregoing notwithstanding, credits will be applied pursuant to this section only if the LMP at the resource's bus does not meet or exceed the applicable offer of the resource for at least four 5-minute intervals during one or more discrete clock hours during each period the resource operated and produced MWs during the relevant Operating Day. If a resource operated and produced MWs for less than four 5-minute intervals during one or more discrete clock hours during the relevant Operating Day, the credits for that resource during the hour it was operated less than four 5-minute intervals will be identified as being in the same category (RT Credits for Reliability or RT Credits for Deviations) as identified for the Operating Reserves for the other discrete clock hours.

(B) If the Office of the Interconnection directs a resource not covered by section 3.2.3(b)(ii)(A) hereof to operate in real-time during an Operating Day, the associated balancing Operating Reserve credits, identified as RT Credits for Deviations, shall be allocated according to real-time deviations from day-ahead schedules.

(iii) PJM shall post on its Web site the aggregate amount of MWs committed that meet the criteria referenced in subsections (b)(i) and (b)(ii) hereof.

(c) The sum of the foregoing credits calculated in accordance with section 3.2.3(b) plus any unallocated charges from section 3.2.3(h) and Operating Agreement, Schedule 1, section 5.1.7, and any shortfalls paid pursuant to the Market Settlement provision of the Day-ahead Economic Load Response Program, shall be the cost of Operating Reserves in the Day-ahead Energy Market.

(d) The cost of Operating Reserves in the Day-ahead Energy Market shall be allocated and charged to each Market Participant in proportion to the sum of its (i) scheduled load (net of Behind The Meter Generation expected to be operating, but not to be less than zero), accepted Decrement Bids in the Day-ahead Energy Market in megawatt-hours for that Operating Day and accepted Up-to Congestion Transactions in the Day-ahead Energy Market in megawatt-hours for the Operating Day at the sink of the transaction; and (ii) scheduled energy sales in the Day-ahead Energy Market from within the PJM Region to load outside such region in megawatt-hours for that Operating Day, but not including its bilateral transactions that are Dynamic Transfers to load outside such area pursuant to Operating Agreement, Schedule 1, section 1.12, except to the extent PJM scheduled resources to provide Black Start service, Reactive Services or transfer interface control. The cost of Operating Reserves in the Day-ahead Energy Market for resources scheduled to provide Black Start service for the Operating Day which resources would not have otherwise been committed in the day-ahead security constrained dispatch shall be allocated by ratio share of the monthly transmission use of each Network Customer or Transmission Customer serving Zone Load or Non-Zone Load, as determined in accordance with the formulas contained in Tariff, Schedule 6A. The cost of Operating Reserves in the Day-ahead Energy Market for resources scheduled to provide Reactive Services or transfer interface control because they are known or expected to be needed to maintain system reliability in a Zone during

the Operating Day and would not have otherwise been committed in the day-ahead security constrained dispatch shall be allocated and charged to each Market Participant in proportion to the sum of its real-time deliveries of energy to load (net of operating Behind The Meter Generation) in such Zone, served under Network Transmission Service, in megawatt-hours during that Operating Day, as compared to all such deliveries for all Market Participants in such Zone.

(e) At the end of each Operating Day, the following determination shall be made for each synchronized pool-scheduled resource of each Market Seller that operates as requested by the Office of the Interconnection. For each calendar day, pool-scheduled resources in the Real-time Energy Market shall be made whole for each of the following Segments: 1) the greater of their day-ahead schedules and minimum run time specified at the time of commitment (minimum down time specified at the time of commitment for Economic Load Response Participant resources); and 2) any block of Real-time Settlement Intervals the resource operates at PJM's direction in excess of the greater of its day-ahead schedule and minimum run time specified at the time of commitment (minimum down time specified at the time of commitment for Economic Load Response Participant resources). For each calendar day, and for each synchronized start of a generation resource or PJM-dispatched economic load reduction, there will be a maximum of two Segments for each resource. Segment 1 will be the greater of the day-ahead schedule and minimum run time specified at the time of commitment (minimum down time specified at the time of commitment for Demand Resources) and Segment 2 will include the remainder of the contiguous Real-time Settlement Intervals when the resource is operating at the direction of the Office of the Interconnection, provided that a segment is limited to the Operating Day in which it commenced and cannot include any part of the following Operating Day.

A Generation Capacity Resource that operates outside of its unit-specific parameters will not receive Operating Reserve Credits nor be made whole for such operation when not dispatched by the Office of the Interconnection, unless the Market Seller of the Generation Capacity Resource can justify to the Office of the Interconnection that operation outside of such unit-specific parameters was the result of an actual constraint. Such Market Seller shall provide to the Market Monitoring Unit and the Office of the Interconnection its request to receive Operating Reserve Credits and/or to be made whole for such operation, along with documentation explaining in detail the reasons for operating its resource outside of its unit-specific parameters, within thirty calendar days following the issuance of billing statement for the Operating Day. The Market Seller shall also respond to additional requests for information from the Market Monitoring Unit and the Office of the Interconnection. The Market Monitoring Unit shall evaluate such request for compensation and provide its determination of whether there was an exercise of market power to the Office of the Interconnection by no later than twenty-five calendar days after receiving the Market Seller's request for compensation. The Office of the Interconnection shall make its determination whether the Market Seller justified that it is entitled to receive Operating Reserve Credits and/or be made whole for such operation of its resource for the day(s) in question, by no later than thirty calendar days after receiving the Market Seller's request for compensation.

Nuclear generation resources shall not be eligible for Operating Reserve payments unless: 1) the Office of the Interconnection directs such resources to reduce output, in which case, such units

shall be compensated in accordance with Tariff, Attachment K-Appendix, section 3.2.3(f) and the parallel provision of Operating Agreement, Schedule 1, section 3.2.3(f); or 2) the resource submits a request for a risk premium to the Market Monitoring Unit under the procedures specified in Tariff, Attachment M – Appendix, section II.B. A nuclear generation resource (i) must submit a risk premium consistent with its agreement under such process, or, (ii) if it has not agreed with the Market Monitoring Unit on an appropriate risk premium, may submit its own determination of an appropriate risk premium to the Office of the Interconnection, subject to acceptance by the Office of the Interconnection, with or without prior approval from the Commission.

Credits received pursuant to this section shall be equal to the positive difference between a resource's Total Operating Reserve Offer, and the total value of the resource's energy in the Day-ahead Energy Market plus any credit or change for quantity deviations, at PJM dispatch direction (excluding quantity deviations caused by an increase in the Market Seller's Real-time Offer), from the Day-ahead Energy Market during the Operating Day at the real-time LMP(s) applicable to the relevant generation bus in the Real-time Energy Market. The foregoing notwithstanding, credits for Segment 2 shall exclude start up (shutdown costs for Economic Load Response Participant resources) costs for generation resources.

Except as provided in section 3.2.3(m), if the total offered price exceeds the total value, the difference less any credit as determined pursuant to section 3.2.3(b), and less the absolute value of any negative Synchronized Reserve lost opportunity cost credit, as determined in section 3.2.3A(f)(iv) below, and less the absolute value of any negative Non-Synchronized Reserve lost opportunity cost credit determined in section 3.2.3.A.001(d)(iii) below, and less any amounts credited for providing Reactive Services as specified in section 3.2.3B, and the absolute value of any negative Secondary Reserve lost opportunity cost credit, as determined in section 3.2.3A.01(f)(iv) below, and plus the sum of the Market Revenue Neutrality Offsets for Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve, shall be credited to the Market Seller.

Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve credits applied against Operating Reserve credits pursuant to this section shall be netted against the Operating Reserve credits earned in the corresponding Real-time Settlement Interval(s) in which the Synchronized Reserve, Non-Synchronized Reserve, and Secondary Reserve credits accrued, provided that for condensing combustion turbines, Synchronized Reserve credits will be netted against the total Operating Reserve credits accrued during each Real-time Settlement Interval the unit operates in condensing and generation mode.

(f) A Market Seller of a unit not defined in subsection (f-1), (f-2), or (f-4) hereof (or self-scheduled, if operating according to Operating Agreement, Schedule 1, section 1.10.3(c) hereof), the output of which is reduced or suspended at the request of the Office of the Interconnection due to a transmission constraint or other reliability issue, and for which the real-time LMP at the unit's bus is higher than the unit's offer corresponding to the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override), shall be credited for each Real-time Settlement Interval in an

amount equal to the product of (A) the LOC Deviation times (B) the Locational Marginal Price at the generation bus for the generating unit, minus (C) the Total Lost Opportunity Cost Offer, provided that the resulting outcome is greater than \$0.00. This equation is represented as $(A*B) - C$. If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.11.6, where the suspension is greater than twenty-four (24) consecutive hours, resources will not be compensated for lost opportunity costs.

(f-1) With the exception of Market Sellers of Flexible Resources that submit a Real-time Offer greater than their resource's Committed Offer in the Day-ahead Energy Market, a Market Seller of a Flexible Resource shall be compensated for lost opportunity cost, and shall be limited to the lesser of the unit's Economic Maximum or the unit's Generation Resource Maximum Output, if either of the following conditions occur:

- (i) if the unit output is reduced at the direction of the Office of the Interconnection and the real time LMP at the unit's bus is higher than the unit's offer corresponding to the level of output requested by the Office of the Interconnection (as directed by the PJM dispatcher), then the Market Seller shall be credited in a manner consistent with that described in section 3.2.3(f).
- (ii) If the unit is scheduled to produce energy in the Day-ahead Energy Market for a Day-ahead Settlement Interval, but the unit is not called on by the Office of the Interconnection and does not operate in the corresponding Real-time Settlement Interval(s), then the Market Seller shall be credited in an amount equal to the higher of:
 - 1) the product of (A) the amount of megawatts committed in the Day-ahead Energy Market for the generating unit, and (B) the Real-time Price at the generation bus for the generating unit, minus the sum of (C) the Total Lost Opportunity Cost Offer plus No-load Costs, plus (D) the Start-up Cost, divided by the Real-time Settlement Intervals committed for each set of contiguous hours for which the unit was scheduled in Day-ahead Energy Market. This equation is represented as $(A*B) - (C+D)$. The startup cost, (D), shall be excluded from this calculation if the unit operates in real time following the Office of the Interconnection's direction during any portion of the set of contiguous hours for which the unit was scheduled in Day-ahead Energy Market, or
 - 2) the Real-time Price at the unit's bus minus the Day-ahead Price at the unit's bus, multiplied by the number of megawatts committed in the Day-ahead Energy Market for the generating unit.

(f-2) A Market Seller of a hydroelectric resource that is pool-scheduled (or self-scheduled, if operating according to Operating Agreement, Schedule 1, section 1.10.3(c) hereof),

the output of which is altered at the request of the Office of the Interconnection from the schedule submitted by the owner, due to a transmission constraint or other reliability issue, shall be compensated for lost opportunity cost in the same manner as provided in sections 3.2.2(d) and 3.2.3A(f) and further detailed in the PJM Manuals.

(f-3) If a Market Seller believes that, due to specific pre-existing binding commitments to which it is a party, and that properly should be recognized for purposes of this section, the above calculations do not accurately compensate the Market Seller for opportunity cost associated with following PJM dispatch instructions and reducing or suspending a unit's output due to a transmission constraint or other reliability issue, then the Office of the Interconnection, the Market Monitoring Unit and the individual Market Seller will discuss a mutually acceptable, modified amount of opportunity cost compensation, taking into account the specific circumstances binding on the Market Seller. Following such discussion, if the Office of the Interconnection accepts a modified amount of opportunity cost compensation, the Office of the Interconnection shall invoice the Market Seller accordingly. If the Market Monitoring Unit disagrees with the modified amount of opportunity cost compensation, as accepted by the Office of the Interconnection, it will exercise its powers to inform the Commission staff of its concerns.

(f-4) A Market Seller of a wind generating unit that is pool-scheduled or self-scheduled, has SCADA capability to transmit and receive instructions from the Office of the Interconnection, has provided data and established processes to follow PJM basepoints pursuant to the requirements for wind generating units as further detailed in this Agreement, the Tariff and the PJM Manuals, and which is operating as requested by the Office of the Interconnection, the output of which is reduced or suspended at the request of the Office of the Interconnection due to a transmission constraint or other reliability issue, and for which the , real-time LMP at the unit's bus is higher than the unit's offer corresponding to the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override), shall be credited for each Real-time Settlement Interval in an amount equal to the product of (A) the LOC Deviation times (B) the Real-time Price at the generation bus for the generating unit, minus (C) the Total Lost Opportunity Cost Offer, provided that the resulting outcome is greater than \$0.00. This equation is represented as $(A*B) - C$.

(f-5) (i) A Market Seller of a pool-scheduled resource or a dispatchable self-scheduled resource shall receive Dispatch Differential Lost Opportunity Cost credits as calculated under subsection (iv) below if the resource is dispatched to provide energy in the Real-time Energy Market, provided such resource is not committed to provide real-time ancillary services (Regulation, reserves, reactive service) or instructed to reduce or suspend output due to a transmission constraint or other reliability issue pursuant to Operating Agreement, Schedule 1, section 3.2.3(f-1) through Operating Agreement, Schedule 1, section (f-4).

(ii) PJM will calculate the revenue above cost for the pricing run for each Real-time Settlement Interval in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = the resource's expected output level based on its resource parameters at the Real-time Price at the applicable pricing point;

B = the Real-time Price at the applicable pricing point; and

C = the sum of the resource's Real-time Energy Market offer integrated under the Final Offer for the resource's expected output level based on its resource parameters at the Real-time Price at the applicable pricing point.

(iii) PJM will calculate the revenue above cost for the dispatch run for each Real-time Settlement Interval in accordance with the following equation:

$$(\text{greater of A and B}) - (\text{lesser of C and D})$$

Where:

A = the product of the amount of megawatts of energy dispatched in the Real-time Energy Market dispatch run for the resource in that Real-time Settlement Interval and the Real-time Price at the applicable pricing point;

B = the product of the amount of megawatts of energy the resource actually provided in that Real-time Settlement Interval and the Real-time Price at the applicable pricing point;

C = the resource's Real-time Energy Market offer integrated under the Final Offer for the amount of megawatts dispatched in the Real-time Energy Market dispatch run;

D = the resource's Real-time Energy Market offer integrated under the Final Offer for the amount of megawatts the resource actually provided in that Real-time Settlement Interval.

(iv) The Dispatch Differential Lost Opportunity Cost credit shall equal the greater of (A) the difference between the revenue above cost based on the pricing run determined in subsection (f-5)(ii) and the revenue above cost based on the dispatch run determined in subsection (f-5)(iii) or (B) zero.

(v) For each hour in an Operating Day, the total cost of the Dispatch Differential Lost Opportunity Cost credits shall be allocated and charged to each Market Participant in proportion to the sum of its (i) deliveries of energy to load ((a) net of operating Behind The Meter Generation, but not to be less than zero; and (b) excluding Direct Charging Energy) in the PJM Region, served under Network Transmission Service, in megawatt-hours; and (ii) deliveries of energy sales from within the PJM Region to load outside such region in megawatt-hours but not including its bilateral transactions that are Dynamic Transfers to load

outside the PJM Region pursuant to Operating Agreement, Schedule 1, section 1.12, as compared to the sum of all such deliveries for all Market Participants.

(g) The sum of the foregoing credits in Operating Agreement, Schedule 1, section 3.2.3(f-1) through Operating Agreement, Schedule 1, section 3.2.3(f-4), plus any cancellation fees paid in accordance with Operating Agreement, Schedule 1, section 1.10.2(d), such cancellation fees to be applied to the Operating Day for which the unit was scheduled, plus any shortfalls paid pursuant to the Market Settlement provision of the real-time Economic Load Response Program, less any payments received from another Control Area for Operating Reserves shall be the cost of Operating Reserves for the Real-time Energy Market in each Operating Day.

(h) The cost of Operating Reserves for the Real-time Energy Market for each Operating Day, except those associated with the scheduling of units for Black Start service or testing of Black Start Units as provided in Tariff, Schedule 6A, shall be allocated and charged to each Market Participant based on their daily total of hourly deviations determined in accordance with the following equation:

$$\sum_h (A + B + C)$$

Where:

h = the hours in the applicable Operating Day;

A = For each Real-time Settlement Interval in an hour, the sum of the absolute value of the withdrawal deviations (in MW) between the quantities scheduled in the Day-ahead Energy Market and the Market Participant's energy withdrawals (net of operating Behind The Meter Generation) in the Real-time Energy Market, except as noted in subsection (h)(ii) below and in the PJM Manuals divided by the number of Real-time Settlement Intervals for that hour. The summation of each Real-time Settlement Interval's withdrawal deviation in an hour will be the Market Participant's total hourly withdrawal deviations. Market Participant bilateral transactions that are Dynamic Transfers to load outside the PJM Region pursuant to Operating Agreement, Schedule 1, section 1.12 are not included in the determination of withdrawal deviations;

B = For each Real-time Settlement Interval in an hour, the sum of the absolute value of generation deviations (in MW and not including deviations in Behind The Meter Generation) as determined in subsection (o) divided by the number of Real-time Settlement Intervals for that hour;

C = For each Real-time Settlement Interval in an hour, the sum of the absolute value of the injection deviations (in MW) between the quantities scheduled in the Day-ahead Energy Market and the Market Participant's energy injections in the Real-time Energy Market divided by the number of Real-time Settlement Intervals for that hour. The summation of the injection deviations for each Real-time Settlement Interval in an hour

will be the Market Participant's total hourly injection deviations. The determination of injection deviations does not include generation resources.

The Revenue Data for Settlements determined for each Real-time Settlement Interval in accordance with Operating Agreement, Schedule 1, section 3.1A shall be used in determining the real-time withdrawal deviations, generation deviations and injection deviations used to calculate Operating Reserve under this subsection (e).

The costs associated with scheduling of units for Black Start service or testing of Black Start Units shall be allocated by ratio share of the monthly transmission use of each Network Customer or Transmission Customer serving Zone Load or Non-Zone Load, as determined in accordance with the formulas contained in Tariff, Schedule 6A.

Notwithstanding section (h)(1) above, as more fully set forth in the PJM Manuals, load deviations from the Day-ahead Energy Market shall not be assessed Operating Reserves charges to the extent attributable to reductions in the load of Price Responsive Demand that is in response to an increase in Locational Marginal Price from the Day-ahead Energy Market to the Real-time Energy Market and that is in accordance with a properly submitted PRD Curve.

Deviations that occur within a single Zone shall be associated with the Eastern or Western Region, as defined in section 3.2.3(q) below, and shall be subject to the regional balancing Operating Reserve rate determined in accordance with Section 3.2.3(q). Deviations at a hub shall be associated with the Eastern or Western Region if all the buses that define the hub are located in the region. Deviations at an Interface Pricing Point shall be associated with whichever region, the Eastern or Western Region, with which the majority of the buses that define that Interface Pricing Point are most closely electrically associated. If deviations at interfaces and hubs are associated with the Eastern or Western region, they shall be subject to the regional balancing Operating Reserve rate. Demand and supply deviations shall be based on total activity in a Zone, including all aggregates and hubs defined by buses that are wholly contained within the same Zone.

The foregoing notwithstanding, netting deviations shall be allowed for each Real-time Settlement Interval in accordance with the following provisions:

(i) Generation resources with multiple units located at a single bus shall be able to offset deviations in accordance with the PJM Manuals to determine the net deviation MW at the relevant bus.

(ii) Demand deviations will be assessed by comparing all day-ahead demand transactions, which include the components referenced in section 3.2.3(d) regarding the cost of Operating Reserves in the Day-ahead Energy Market, at a single transmission zone, hub, or interface against the real-time demand transactions at that same transmission zone, hub, or interface; except that the positive values of demand deviations, as set forth in the PJM Manuals, will not be assessed Operating Reserve charges in the event of a Primary Reserve or Synchronized Reserve shortage in real-time or where PJM initiates the request for emergency load reductions in real-time in order to avoid a Primary Reserve or Synchronized Reserve shortage.

(iii) Supply deviations will be assessed by comparing all day-ahead transactions at a single transmission zone, hub, or interface against the real-time transactions at that same transmission zone, hub, or interface.

(iv) Bilateral transactions inside the PJM Region, as defined in Operating Agreement, Schedule 1, section 1.7.10, will not be included in the determination of Supply or Demand deviations.

(i) At the end of each Operating Day, Market Sellers shall be credited on the basis of their offered prices for synchronous condensing for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, as well as the credits calculated as specified in Section 3.2.3(b) for those generators committed solely for the purpose of providing synchronous condensing for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, at the request of the Office of the Interconnection.

(j) The sum of the foregoing credits as specified in section 3.2.3(i) shall be the cost of Operating Reserves for synchronous condensing for the PJM Region for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, or in association with post-contingency operation for the Operating Day and shall be separately determined for the PJM Region.

(k) The cost of Operating Reserves for synchronous condensing for purposes other than providing Synchronized Reserve, Secondary Reserve, or Reactive Services, or in association with post-contingency operation for each Operating Day shall be allocated and charged to each Market Participant in proportion to the sum of its (i) deliveries of energy to load (net of operating Behind The Meter Generation, but not to be less than zero) in the PJM Region, served under Network Transmission Service, in megawatt-hours during that Operating Day; and (ii) deliveries of energy sales from within the PJM Region to load outside such region in megawatt-hours during that Operating Day, but not including its bilateral transactions that are Dynamic Transfers to load outside the PJM Region pursuant to Operating Agreement, Schedule 1, section 1.12, as compared to the sum of all such deliveries for all Market Participants.

(l) For any Operating Day in either, as applicable, the Day-ahead Energy Market or the Real-time Energy Market for which, for all or any part of such Operating Day, the Office of the Interconnection: (i) declares a Maximum Generation Emergency; (ii) issues an alert that a Maximum Generation Emergency may be declared (“Maximum Generation Emergency Alert”); or (iii) schedules units based on the anticipation of a Maximum Generation Emergency or a Maximum Generation Emergency Alert, the Operating Reserves credit otherwise provided by section 3.2.3.(b) or section 3.2.3.(e) in connection with market-based offers shall be limited as provided in subsections (n) or (m), respectively. The Office of the Interconnection shall provide timely notice on its internet site of the commencement and termination of any of the actions described in subsection (i), (ii), or (iii) of this subsection (l) (collectively referred to as “MaxGen Conditions”). Following the posting of notice of the commencement of a MaxGen Condition, a Market Seller may elect to submit a cost-based offer in accordance with Operating Agreement, Schedule 2, in which case subsections (m) and (n) shall not apply to such offer; provided,

however, that such offer must be submitted in accordance with the deadlines in Operating Agreement, Schedule 1, section 1.10 for the submission of offers in the Day-ahead Energy Market or Real-time Energy Market, as applicable. Submission of a cost-based offer under such conditions shall not be precluded by Operating Agreement, Schedule 1, section 1.9.7(b); provided, however, that the Market Seller must return to compliance with Operating Agreement, Schedule 1, section 1.9.7(b) when it submits its bid for the first Operating Day after termination of the MaxGen Condition.

(m) For the Real-time Energy Market, if the Effective Offer Price (as defined below) for a market-based offer is greater than \$1,000/MWh and greater than the Market Seller's lowest available and applicable cost-based offer, the Market Seller shall not receive any credit for Operating Reserves. For purposes of this subsection (m), the Effective Offer Price shall be the amount that, absent subsections (l) and (m), would have been credited for Operating Reserves for such Operating Day pursuant to section 3.2.3(e) plus the Real-time Energy Market revenues for the Real-time Settlement Intervals that the offer is economic divided by the megawatt hours of energy provided during the Real-time Settlement Intervals that the offer is economic. The Real-time Settlement Intervals that the offer is economic shall be: (i) the Real-time Settlement Intervals that the offer price for energy is less than or equal to the Real-time Price for the relevant generation bus, (ii) the Real-time Settlement Intervals in which the offer for energy is greater than Locational Marginal Price and the unit is operated at the direction of the Office of the Interconnection that are in addition to any Real-time Settlement Intervals required due to the minimum run time or other operating constraint of the unit, and (iii) for any unit with a minimum run time of one hour or less and with more than one start available per day, any hours the unit operated at the direction of the Office of the Interconnection.

(n) For the Day-ahead Energy Market, if notice of a MaxGen Condition is provided prior to 11:00 a.m. on the day before the Operating Day for which transactions are being scheduled and the Effective Offer Price for a market-based offer is greater than \$1,000/MWh and greater than the Market Seller's lowest available and applicable cost-based offer, the Market Seller shall not receive any credit for Operating Reserves. If notice of a MaxGen Condition is provided after 11:00 a.m. on the day before the Operating Day for which transactions are being scheduled and the Effective Offer Price is greater than \$1,000/MWh, the Market Seller shall receive credit for Operating Reserves determined in accordance with section 3.2.3(b), subject to the limit on total compensation stated below. If the Effective Offer Price is less than or equal to \$1,000/MWh, regardless of when notice of a MaxGen Condition is provided, the Market Seller shall receive credit for Operating Reserves determined in accordance with section 3.2.3(b), subject to the limit on total compensation stated below. For purposes of this subsection (n), the Effective Offer Price shall be the amount that, absent subsections (l) and (n), would have been credited for Operating Reserves for such Operating Day divided by the megawatt hours of energy offered during the Specified Hours, plus the offer for energy during such hours. The Specified Hours shall be the lesser of: (1) the minimum run hours stated by the Market Seller in its Offer Data; and (2) either (i) for steam-electric generating units and for combined-cycle units when such units are operating in combined-cycle mode, the six consecutive hours of highest Day-ahead Price during such Operating Day when such units are running or (ii) for combustion turbine units and for combined-cycle units when such units are operating in combustion turbine mode, the two consecutive hours of highest Day-ahead Price during such Operating Day when

such units are running. Notwithstanding any other provision in this subsection, the total compensation to a Market Seller on any Operating Day that includes a MaxGen Condition shall not exceed \$1,000/MWh during the Specified Hours, where such total compensation in each such hour is defined as the amount that, absent subsections (l) and (n), would have been credited for Operating Reserves for such Operating Day pursuant to section 3.2.3(b) divided by the Specified Hours, plus the Day-ahead Price for such hour, and no Operating Reserves payments shall be made for any other hour of such Operating Day. If a unit operates in real time at the direction of the Office of the Interconnection consistently with its day-ahead clearing, then subsection (m) does not apply.

(o) Dispatchable pool-scheduled generation resources and dispatchable self-scheduled generation resources that follow dispatch shall not be assessed balancing Operating Reserve deviations. Pool-scheduled generation resources and dispatchable self-scheduled generation resources that do not follow dispatch shall be assessed balancing Operating Reserve deviations in accordance with the calculations described below and in the PJM Manuals.

The Office of the Interconnection shall calculate a ramp-limited desired MW value for generation resources where the economic minimum and economic maximum are at least as far apart in real-time as they are in day-ahead according to the following parameters:

(i) real-time economic minimum \leq 105% of day-ahead economic minimum or day-ahead economic minimum plus 5 MW, whichever is greater.

(ii) real-time economic maximum \geq 95% day-ahead economic maximum or day-ahead economic maximum minus 5 MW, whichever is lower.

The ramp-limited desired MW value for a generation resource shall be equal to:

$$Ramp_Request_t = \frac{(Dispatchtarget_{t-1} - AOutput_{t-1})}{(LAtime_{t-1})}$$

$$RL_Desired_t = AOutput_{t-1} + (Ramp_Request_t * Case_Eff_time_{t-1})$$

where:

1. Dispatchtarget = Dispatch Signal for the previous approved Dispatch case
2. AOutput = Unit's achievable target MW at case solution time as defined in the PJM Manuals
3. LAtime = Dispatch look ahead time
4. Case_Eff_time = Time between signal changes
5. RL_Desired = Ramp-limited desired MW

To determine if a generation resource is following dispatch the Office of the Interconnection shall determine the unit's MW off dispatch and % off dispatch by using the lesser of the difference between the actual output and the dispatch signal or the actual output and ramp-limited desired MW value for each Real-time Settlement Interval. If the dispatch signal and the ramp-limited desired MW for the resource are unavailable, the Office of the Interconnection will determine the unit's MW off dispatch and % off dispatch by calculating the lesser of the difference between the actual output and the dispatch LMP Desired MW for each Real-time Settlement Interval.

A pool-scheduled or dispatchable self-scheduled resource is considered to be following dispatch if its actual output is between its ramp-limited desired MW value and dispatch signal, or if its % off dispatch is ≤ 10 , or its Real-time Settlement Interval MWh is within 5% of the Real-time Settlement Interval ramp-limited desired MW. A self-scheduled generator must also be dispatched above economic minimum. The degree of deviations for resources that are not following dispatch shall be determined for each Real-time Settlement Interval in accordance with the following provisions:

- A dispatchable self-scheduled resource that is not dispatched above economic minimum shall be assessed balancing Operating Reserve deviations according to the following formula: Real-time Settlement Interval MWh – Day-Ahead MWh.
- A resource that is dispatchable day-ahead but is Fixed Gen in real-time shall be assessed balancing Operating Reserve deviations according to the following formula: Real-time Settlement Interval MWh – dispatch LMP Desired MW.
- Pool-scheduled generators that are not following dispatch shall be assessed balancing Operating Reserve deviations according to the following formula: Real-time Settlement Interval MWh – Ramp-Limited Desired MW.
- If a resource's real-time economic minimum is greater than its day-ahead economic minimum by 5% or 5 MW, whichever is greater, or its real-time economic maximum is less than its Day Ahead economic maximum by 5% or 5 MW, whichever is lower, and dispatch LMP Desired MWh for the Real-time Settlement Interval is either below the real time economic minimum or above the real time economic maximum, then balancing Operating Reserve deviations for the resource shall be assessed according to the following formula: Real time Settlement Interval MWh – dispatch LMP Desired MWh.
- If a resource is not following dispatch and its % Off Dispatch is $\leq 20\%$, balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh – Ramp-Limited Desired MW. If deviation value is within 5% of Ramp-Limited Desired MW, balancing Operating Reserve deviations shall not be assessed.

- If a resource is not following dispatch and its % off Dispatch is > 20%, balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh – dispatch LMP Desired MWh.
- If a resource is not following dispatch, and the resource has tripped, for the Real-time Settlement Interval the resource tripped and the Real-time Settlement Intervals it remains offline throughout its day-ahead schedule balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh – Day-Ahead MWh.
- For resources that are not dispatchable in both the Day-Ahead and Real-time Energy Markets balancing Operating Reserve deviations shall be assessed according to the following formula: Real-time Settlement Interval MWh - Day-ahead MWh.

If a resource has a sum of the absolute value of generator deviations for an hour that is less than 5 MWh, then the resource shall not be assessed balancing Operating Reserve deviations for that hour.

(o-1) Dispatchable economic load reduction resources that follow dispatch shall not be assessed balancing Operating Reserve deviations. Economic Load Response Participant resources that do not follow dispatch shall be assessed balancing Operating Reserve deviations as described in this subsection and as further specified in the PJM Manuals.

The Desired MW quantity for such resources for each hour shall be the hourly integrated MW quantity to which the load reduction resource was dispatched for each hour (where the hourly integrated value is the average of the dispatched values as determined by the Office of the Interconnection for the resource for each hour).

If the actual reduction quantity for the load reduction resource for a given hour deviates by no more than 20% above or below the Desired MW quantity, then no balancing Operating Reserve deviation will accrue for that hour. If the actual reduction quantity for the load reduction resource for a given hour is outside the 20% bandwidth, the balancing Operating Reserve deviations will accrue for that hour in the amount of the absolute value of (Desired MW – actual reduction quantity). For those hours where the actual reduction quantity is within the 20% bandwidth specified above, the load reduction resource will be eligible to be made whole for the total value of its offer as defined in Operating Agreement, Schedule 1, section 3.3A. Hours for which the actual reduction quantity is outside the 20% bandwidth will not be eligible for the make-whole payment. If at least one hour is not eligible for make-whole payment based on the 20% criteria, then the resource will also not be made whole for its shutdown cost.

(p) The Office of the Interconnection shall allocate the charges assessed pursuant to Operating Agreement, Schedule 1, section 3.2.3(h) except those associated with the scheduling of units for Black Start service or testing of Black Start Units as provided in Tariff, Schedule 6A, to real-time deviations from day-ahead schedules or real-time load share plus exports depending on whether the underlying balancing Operating Reserve credits are related to resources scheduled during the reliability analysis for an Operating Day, or during the actual Operating

Day. If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, section 1.11.6, the Office of the Interconnection shall allocate the charges to the ratio share of real-time load plus export transactions.

(i) For resources scheduled by the Office of the Interconnection during the reliability analysis for an Operating Day, the associated balancing Operating Reserve charges shall be allocated based on the reason the resource was scheduled according to the following provisions:

(A) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to operate in real-time to augment the physical resources committed in the Day-ahead Energy Market to meet the forecasted real-time load plus the Operating Reserve requirement, the associated balancing Operating Reserve charges shall be allocated to real-time deviations from day-ahead schedules.

(B) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource was committed to maintain system reliability, the associated balancing Operating Reserve charges shall be allocated according to ratio share of real time load plus export transactions.

(C) If the Office of the Interconnection determines during the reliability analysis for an Operating Day that a resource with a day-ahead schedule is required to deviate from that schedule to provide balancing Operating Reserves, the associated balancing Operating Reserve charges shall be allocated pursuant to (A) or (B) above.

(ii) For resources scheduled during an Operating Day, the associated balancing Operating Reserve charges shall be allocated according to the following provisions:

(A) If the Office of the Interconnection directs a resource to operate during an Operating Day to provide balancing Operating Reserves, the associated balancing Operating Reserve charges shall be allocated according to ratio share of load plus exports. The foregoing notwithstanding, charges will be assessed pursuant to this section only if the LMP at the resource's bus does not meet or exceeds the applicable offer of the resource for at least four-5-minute intervals during one or more discrete clock hours during each period the resource operated and produced MWs during the relevant Operating Day. If a resource operated and produced MWs for less than four 5-minute intervals during one or more discrete clock hours during the relevant Operating Day, the charges for that resource during the hour it was operated less than four 5-minute intervals will be identified as being in the same category as identified for the Operating Reserves for the other discrete clock hours.

(B) If the Office of the Interconnection directs a resource not covered by Operating Agreement, Schedule 1, section 3.2.3(h)(ii)(A) to operate in real-time during an Operating Day, the associated balancing Operating Reserve charges shall be allocated according to real-time deviations from day-ahead schedules.

(q) The Office of the Interconnection shall determine regional balancing Operating Reserve rates for the Western and Eastern Regions of the PJM Region. For the purposes of this section, the Western Region shall be the AEP, APS, ComEd, Duquesne, Dayton, ATSI, DEOK, EKPC, OVEC transmission Zones, and the Eastern Region shall be the AEC, BGE, Dominion, PENELEC, PEPCO, ME, PPL, JCPL, PECO, DPL, PSEG, RE transmission Zones. The regional balancing Operating Reserve rates shall be determined in accordance with the following provisions:

(i) The Office of the Interconnection shall calculate regional adder rates for the Eastern and Western Regions. Regional adder rates shall be equal to the total balancing Operating Reserve credits paid to generators for transmission constraints that occur on transmission system capacity equal to or less than 345kv. The regional adder rates shall be separated into reliability and deviation charges, which shall be allocated to real-time load or real-time deviations, respectively. Whether the underlying credits are designated as reliability or deviation charges shall be determined in accordance with section 3.2.3(p).

(ii) The Office of the Interconnection shall calculate RTO balancing Operating Reserve rates. RTO balancing Operating Reserve rates shall be equal to balancing Operating Reserve credits except those associated with the scheduling of units for Black Start service or testing of Black Start Units as provided in Tariff, Schedule 6A, in excess of the regional adder rates calculated pursuant to Operating Agreement, Schedule 1, section 3.2.3(q)(i) of Schedule 1 of this Agreement. The RTO balancing Operating Reserve rates shall be separated into reliability and deviation charges, which shall be allocated to real-time load or real-time deviations, respectively. Whether the underlying credits are allocated as reliability or deviation charges shall be determined in accordance with section 3.2.3(p).

(iii) Reliability and deviation regional balancing Operating Reserve rates shall be determined by summing the relevant RTO balancing Operating Reserve rates and regional adder rates.

(iv) If the Eastern and/or Western Regions do not have regional adder rates, the relevant regional balancing Operating Reserve rate shall be the reliability and/or deviation RTO balancing Operating Reserve rate.

(r) Market Sellers that incur incremental operating costs for a generation resource that are either greater than \$1,000/MWh as determined in accordance with the Market Seller's PJM-approved Fuel Cost Policy, Operating Agreement, Schedule 2 and PJM Manual 15, but are not verified at the time of dispatch of the resource under section 6.4.3 of this Schedule, or greater

than \$2,000/MWh as determined in accordance with the Market Seller’s PJM-approved Fuel Cost Policy, Operating Agreement, Schedule 2, and PJM Manual 15, will be eligible to receive credit for Operating Reserves upon review of the Market Monitoring Unit and the Office of the Interconnection, and approval of the Office of the Interconnection. Market Sellers must submit to the Office of the Interconnection and the Market Monitoring Unit all relevant documentation demonstrating the calculation of costs greater than \$2,000/MWh, and costs greater than \$1,000/MWh which were not verified at the time of dispatch of the resource under Operating Agreement, Schedule 1, section 6.4.3. The Office of the Interconnection must approve any Operating Reserve credits paid to a Market Seller under this subsection (r).

3.2.3A Synchronized Reserve.

(a) Each Market Participant that is a Load Serving Entity that is not part of an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have an obligation for hourly Synchronized Reserve equal to its pro rata share of Synchronized Reserve requirements for the hour for each Reserve Zone and Reserve Sub-zone of the PJM Region, based on the Market Participant’s total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Reserve Zone or Reserve Sub-zone for the hour (“Synchronized Reserve Obligation”), less any amount obtained from condensers associated with provision of Reactive Services as described in section 3.2.3B(i) and any amount obtained from condensers associated with post-contingency operations, as described in section 3.2.3C(b). Those entities that participate in an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have their reserve obligations determined based on the stipulations in such agreement. A Market Participant’s hourly Synchronized Reserve Obligation shall be adjusted by any Synchronized Reserve provided on the Market Participant’s behalf through a bilateral agreement. A Market Participant with an hourly Synchronized Reserve Obligation shall be charged the pro rata share of the sum of day-ahead and real-time credits for Synchronized Reserve as defined in sections 3.2.3A(b)(i) and (ii) below.

(b) A resource supplying Synchronized Reserve at the direction of the Office of the Interconnection shall be credited as follows:

i) Credits for Synchronized Reserve provided by generation and Economic Load Response Participant resources assigned to provide Synchronized Reserve by the Office of the Interconnection or self-scheduled in the Day-ahead Synchronized Reserve Market shall be equal to the product of the Day-ahead Synchronized Reserve Market Clearing Price multiplied by the megawatt amount of Synchronized Reserve such resource is assigned to provide..

ii) Credits for Synchronized Reserve provided by generation resources and Economic Load Response Participant resources assigned to provide Synchronized Reserve by the Office of the Interconnection or self-scheduled in the Real-time Synchronized Reserve Market shall be determined for each operating hour based on the sum of their hourly total of Real-time Settlement Interval deviations determined in accordance with the following equation:

$$\sum_i ((A - B) * C)$$

Where:

i = the Real-time Settlement Intervals in the applicable operating hour;

A = For each Real-time Settlement Interval, the megawatts of Synchronized Reserve from that resource assigned by the Office of the Interconnection or self-scheduled in the Real-time Synchronized Reserve Market. The megawatt value is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements of the resource for each Real-time Settlement Interval where there is not a Synchronized Reserve event;

B = For each Real-time Settlement Interval, the megawatts of Synchronized Reserve from that resource assigned by the Office of the Interconnection or self-scheduled in the Day-ahead Synchronized Reserve Market; and

C = For each Real-time Settlement Interval, the Real-time Synchronized Reserve Market Clearing Price.

If a Synchronized Reserve Event is initiated by the Office of the Interconnection and the Economic Load Response Participant resource reduced its load in response to the event, the resource shall be eligible to receive a credit for the fixed costs associated with achieving the load reduction, as specified in the PJM Manuals.

iii) Pool-scheduled resources shall be credited a Synchronized Reserve lost opportunity cost credit, where positive, as described in subsection (f)(iv) below.

(c) [Reserved for future use]

(d) Synchronized Reserve Market Clearing Prices

(i) For the Day-ahead Synchronized Reserve Market, the Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection for each hour of the Operating Day. The Day-ahead Synchronized Reserve Market Clearing Price shall be calculated as the price of serving the next increment of demand for Synchronized Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Synchronized Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Synchronized Reserve established in accordance with Operating Agreement, Schedule 1, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Synchronized Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute and (B) the price of serving the next increment of demand for Primary Reserve and 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute, provided that the Synchronized Reserve Market Clearing Price shall be

less than or equal to the sum of no more than two of the Reserve Penalty Factors for the Synchronized Reserve Requirement, the Primary Reserve Requirement, and the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.10.8(d), Day-ahead Synchronized Reserve Market Clearing Prices shall be set to zero dollars per megawatt-hour and for purposes of settlements for such Operating Day, the Office of the Interconnection shall utilize a scheduled megawatt quantity and Day-ahead Synchronized Reserve Market Clearing Price of zero dollars per megawatt-hour and all settlements will be based on the Real-time Synchronized Reserve market quantities and prices as determined pursuant to subsection (d)(ii) hereof.

(ii) For the Real-time Synchronized Reserve Market, the Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection in the Real-time Price software program, which is known as the pricing run, for each Real-time Settlement Interval of the Operating Day. Each 5-minute clearing price shall be calculated as the price of serving the next increment of demand for Synchronized Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Synchronized Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Synchronized Reserve established in accordance with Operating Agreement, Schedule 1, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Synchronized Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute and (B) the price of serving the next increment of demand for Primary Reserve and 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute, provided that the Synchronized Reserve Market Clearing Price shall be less than or equal to the sum of no more than two of the Reserve Penalty Factors for the Synchronized Reserve Requirement, the Primary Reserve Requirement, and the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, and the Office of the Interconnection is not assigning Synchronized Reserves, then the Synchronized Reserve Market Clearing Price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, where the real-time Market Suspension is less than or equal to six (6) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Synchronized Reserves, then the Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the

average of the Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than six (6) consecutive hours but less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are cleared Day-ahead Synchronized Reserve Market Clearing Prices for the affected Operating Day, then the Real-time Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the Day-ahead Synchronized Reserve Market Clearing Prices for each corresponding hour. If no such Day-ahead Synchronized Reserve Market Clearing Prices exist, then the Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than twenty-four (24) consecutive hours, and the Office of the Interconnection is assigning Synchronized Reserves, the Office of the Interconnection will set the Synchronized Reserve Market Clearing Price to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period. Resources will be compensated for lost opportunity cost per subsection (f) hereof using the energy price as determined in Operating Agreement, Schedule 1, section 2.5.2.iii. The opportunity cost shall be zero for all resources self-scheduled to provide Synchronized Reserve, synchronous condensers and Economic Load Response Participant resources.

If the Office of the Interconnection has initiated in a Reserve Zone or Reserve Sub-zone either a Voltage Reduction Action as described in the PJM Manuals or a Manual Load Dump Action as described in the PJM Manuals, the Real-time Synchronized Reserve Market Clearing Price shall be the sum of the Reserve Penalty Factors for the Primary Reserve Requirement, and the Synchronized Reserve Requirement for that Reserve Zone or Reserve Sub-zone.

(iii) The Reserve Penalty Factor for the Synchronized Reserve Requirement shall be \$850/MWh.

The Reserve Penalty Factor for the Extended Synchronized Reserve Requirement shall be \$300/MWh.

(iv) By no later than April 30 of each year, the Office of the Interconnection will analyze Market Participants' response to prices exceeding \$1,000/MWh on an annual basis and will provide its analysis to PJM stakeholders. The Office of the Interconnection will also review this analysis to determine whether any changes to the Synchronized Reserve Penalty Factors are warranted for subsequent Delivery Year(s).

(e) (i) For determining the Synchronized Reserve Market Clearing Price in each hour of the Day-ahead Synchronized Reserve Market, the estimated resource-specific opportunity cost for a generation resource or Economic Load Response Participant resource shall be the difference between the Locational Marginal Price at the generation or Economic Load Response Participant resource bus and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) or offer price to reduce energy from the Economic Load Response Participant resource in the PJM Interchange Energy Market when the Locational Marginal Price at the generation or Economic Load Participant resource bus is greater than the offer price for energy from the generation resource or the offer price to reduce energy from the Economic Load Response Participant resource.

However, the opportunity costs shall be zero for resources self-scheduled to provide Synchronized Reserve and for synchronous condensers and for Economic Load Response Participant resources that do not receive a day-ahead commitment to provide energy in the same operating hour in which such resource is committed to provide Synchronized Reserve.

(ii) For determining the Synchronized Reserve Market Clearing Price for each Real-time Settlement Interval in the Real-time Synchronized Reserve Market, the estimated unit-specific opportunity cost for a generation resource that is not a hydroelectric resource shall be the difference between the Locational Marginal Price at the generation bus for the generation resource and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) in the PJM Interchange Energy Market when the Locational Marginal Price at the generation bus is greater than the offer price for energy from the generation resource.

For hydroelectric resources, the estimated unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the expected real-time Locational Marginal Price at that generation bus. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions, as defined in the PJM Manuals, and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the expected real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average day-ahead Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

The opportunity costs shall be zero for all resources self-scheduled to provide Synchronized Reserve, synchronous condensers and Economic Load Response Participant resources.

(f) (i) In determining the credit under subsection (b) to a generation resource, except a generation resource that is operating as a synchronous condenser, selected to provide Synchronized Reserve in the Day-ahead Synchronized Reserve Market, or an Economic Load Response Participant resource that is selected to provide Synchronized Reserve in the Day-ahead Synchronized Reserve Market for the same operating hour in which such resource receives a day-ahead commitment to provide energy, the opportunity cost of a resource shall be determined for each operating hour that the Office of the Interconnection requires a resource to provide Synchronized Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Day-ahead Locational Marginal Price at the generation bus of the generation resource or the applicable pricing point for the Economic Load Response Participant resource;

B = The deviation of the resource's energy output or load reduction necessary to supply a Day-ahead Synchronized Reserve assignment from the resource's energy expected output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load; and

C = The Day-ahead Energy market offer integrated under the applicable energy offer curve for the resource's energy output or load reduction necessary to provide a Day-ahead Synchronized Reserve Market assignment from the resource's expected energy output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load.

For a generation resource that is operating as a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: [energy use for providing synchronous condensing multiplied by A] plus [the applicable condense start-up cost divided by the number of hours the resource is assigned Synchronized Reserve].

(ii) In determining the credit under subsection (b) to a generation resource, except a generation resource that is operating as a synchronous condenser, selected to provide Synchronized Reserve in the Real-time Synchronized Reserve Market in excess of the resource's Day-ahead Synchronized Reserve Market assignment and that actively follows the Office of the Interconnection's signals and instructions, the unit-specific opportunity cost of that generation resource shall be determined for each Real-time Settlement Interval that the Office of the Interconnection requires that generation resource to provide Synchronized Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Real-time Locational Marginal Price at the generation bus of the generation resource;

B = The deviation of the generation resource's output necessary to supply Synchronized Reserve in real-time, reduced by the amount of Synchronized Reserve the resource failed to respond during a Synchronized Reserve Event during the Operating Day, in excess of its Day-ahead Synchronized Reserve Market assignment and follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy; and

C = The energy offer integrated under the applicable energy offer curve for the generation resource's output necessary to supply Synchronized Reserve in real-time from the lesser of the generation resource's output necessary to provide a Day-ahead Synchronized Reserve Market assignment or follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy.

For a generation resource that is a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: [additional energy use in excess of day-ahead energy use for providing synchronous condensing in real-time multiplied by A] plus [any applicable condense start-up costs due to additional condense start-ups in real-time in excess of day-ahead condense start-ups allocated to each Real-time Settlement Interval as described in PJM Manuals].

For hydroelectric resources, the unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the real-time Locational Marginal Price at that generation bus multiplied by the additional megawatts assigned to supply Synchronized Reserve in real-time in excess of its Day-ahead Synchronized Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average real-time Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating multiplied by the additional megawatts assigned to supply the hourly Synchronized Reserve in real-time in excess of its Day-ahead Synchronized Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

(iii) For each Real-time Settlement Interval, a Market Revenue Neutrality Offset is calculated for each resource, if eligible. If there is a decrease in the resource's real-time reserve MW from a day-ahead market assignment in more than one market for that Real-time Settlement Interval, the total Market Revenue Neutrality Offset is allocated to the Synchronized Reserve market based on the ratio of the opportunity cost owed due to a reduction in assignment in real-time within the Synchronized Reserve market and the total opportunity cost owed due to a reduction in assignment in real-time from all reserve markets, not to exceed the resource's opportunity cost owed in the Synchronized Reserve market.

A resource is not eligible for Market Revenue Neutrality Offset for Synchronized Reserve in a Real-time Settlement Interval for any of the following conditions:

(A) A resource's real-time Synchronized Reserve assignment decreases due to the resource being self-scheduled to provide energy or Regulation;

(B) A resource reduces its flexibility in real-time such that the resource no longer qualifies to provide Synchronized Reserve in real-time;

(C) A resource's Final Offer is less than its Committed Offer;

(D) A resource trips offline or otherwise becomes unavailable in real-time;

(E) A resource does not follow dispatch as described in section 3.2.3(o) above and section 3.2.3(o-1) above; or

(F) A resource increases its Synchronized Reserve offer price in the Real-time Synchronized Reserve Market from its offer price in the Day-ahead Synchronized Reserve Market.

(iv) A Synchronized Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:

$$(A + B + C + D) - (E + F + G + H)$$

Where:

A = day-ahead Synchronized Reserve offer price times the Synchronized Reserve MW assignment;

B = real-time Synchronized Reserve offer price times the Synchronized Reserve MW assigned in real-time in excess of the Synchronized Reserve MW assigned day-ahead, where the Synchronized Reserve MW assigned is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus

the Revenue Data for Settlements of the resource for each Real-time Settlement Interval where there is not a Synchronized Reserve event;

C = day-ahead opportunity cost as determined in subsection (f)(i) above;

D = real-time opportunity cost as determined in subsection (f)(ii) above;

E = day-ahead clearing price credits as determined in subsection (b)(i) above;

F = real-time clearing price credits as determined in subsection (b)(ii) above less any applicable charges for failure to respond to a Synchronized Reserve Event as determined in subsection (j) below;

G = the applicable Market Revenue Neutrality Offset as determined in subsection (f)(iii) above; and

H = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A(f)(iii) above if not eligible for Market Revenue Neutrality Offset.

(v) The opportunity costs for an Economic Load Response Participant resource assigned Synchronized Reserve in real-time or any resource self-scheduled for Synchronized Reserves shall be zero.

(g) [Reserved for future use]

(h) For each operating hour, the sum of the Synchronized Reserve lost opportunity cost credits credited in accordance with subsection (b)(iii) above shall be allocated and charged to each Market Participant that does not meet its hourly Synchronized Reserve Obligation in proportion to its real-time purchases of Synchronized Reserve in megawatt-hours during that hour.

(i) [Reserved for future use]

(j) In the event a generation resource or Economic Load Response Participant Resource that either has been assigned by the Office of the Interconnection or self-scheduled to provide Synchronized Reserve in real-time fails to provide the assigned or self-scheduled amount of Synchronized Reserve in response to a Synchronized Reserve Event, the resource will be charged at the Real-time Synchronized Reserve Market Clearing Price for the real-time Synchronized Reserve assignment, in excess of amount that actually responded for all Real-time Settlement Intervals the resource was assigned or self-scheduled Synchronized Reserve real-time, which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements for the resource on the Operating Day during which the event occurred. The determination of the amount of Synchronized Reserve credited to a resource shall be on an individual resource basis, not on an aggregate basis.

The resource shall refund payments received for Synchronized Reserve it failed to provide. For purposes of determining the amount of the payments to be refunded by a Market Participant, the Office of the Interconnection shall calculate the shortfall of Synchronized Reserve on an individual resource basis unless the Market Participant had multiple resources that were assigned or self-scheduled to provide Synchronized Reserve, in which case the shortfall will be determined on an aggregate basis. For performance determined on an aggregate basis, the response of any resource that provided more Synchronized Reserve than it was assigned or self-scheduled to provide will be used to offset the performance of other resources that provided less Synchronized Reserve than they were assigned or self-scheduled to provide during a Synchronized Reserve Event, as calculated in the PJM Manuals. The determination of a Market Participant's aggregate response shall not be taken into consideration in the determination of the amount of Synchronized Reserve credited to each individual resource.

The amount refunded shall be determined by multiplying the retroactive penalty megawatts by the Real-time Synchronized Reserve Market Clearing Price for all intervals the resource was assigned or self-scheduled to provide Synchronized Reserve for a period of time immediately preceding the Synchronized Reserve Event equal to the lesser of the average number of days between Synchronized Reserve Events, or the number of days since the resource last failed to provide the amount of Synchronized Reserve it was assigned or self-scheduled to provide in response to a Synchronized Reserve Event. The retroactive penalty megawatts for each interval shall be the lesser of the amount of the shortfall of Synchronized Reserve, measured in megawatts, and the real-time Synchronized Reserve assignment for each interval, which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements for the resource. The average number of days between Synchronized Reserve Events for purposes of this calculation shall be determined by an annual review of the twenty-four month period ending October 31 of the calendar year in which the review is performed, and shall be rounded down to a whole day value. The Office of the Interconnection shall report the results of its annual review to stakeholders by no later than December 31, and the average number of days between Synchronized Reserve Events shall be effective as of the following January 1. The refunded charges shall be allocated as credits to Market Participants based on its pro rata share of the Synchronized Reserve Obligation megawatts in the hour(s) of the Synchronized Reserve Event for the Reserve Sub-zone or Reserve Zone, except that Market Participants that incur a refund obligation and also have an applicable Synchronized Reserve Obligation during the hour(s) of the Synchronized Reserve Event shall not be included in the allocation of such refund credits. If the event spans multiple hours, the refund credits will be prorated hourly based on the duration of the event within each clock hour.

(k) The magnitude of response to a Synchronized Reserve Event by a generation resource or an Economic Load Response Participant resource, except for Batch Load Economic Load Response Participant resources covered by section 3.2.3A(1), is the difference between the generation resource's output or the Economic Load Response Participant resource's consumption at the start of the event and its output or consumption 10 minutes after the start of the event. In order to allow for small fluctuations and possible telemetry delays, generation resource output or Economic Load Response Participant resource consumption at the start of the event is defined as the lowest telemetered generator resource output or greatest Economic Load Response

Participant resource consumption between one minute prior to and one minute following the start of the event. Similarly, a generation resource's output or an Economic Load Response Participant resource's consumption 10 minutes after the event is defined as the greatest generator resource output or lowest Economic Load Response Participant resource consumption achieved between 9 and 11 minutes after the start of the event. The response actually credited to a generation resource will be reduced by the amount the megawatt output of the generation resource falls below the level achieved after 10 minutes by either the end of the event or after 30 minutes from the start of the event, whichever is shorter. The response actually credited to an Economic Load Response Participant resource will be reduced by the amount the megawatt consumption of the Economic Load Response Participant resource exceeds the level achieved after 10 minutes by either the end of the event or after 30 minutes from the start of the event, whichever is shorter.

(l) The magnitude of response by a Batch Load Economic Load Response Participant resource that is at the stage in its production cycle when its energy consumption is less than the level of megawatts in its offer at the start of a Synchronized Reserve Event shall be the difference between (i) the Batch Load Economic Load Response Participant resource's consumption at the end of the Synchronized Reserve Event and (ii) the Batch Load Economic Load Response Participant resource's consumption during the minute within the ten minutes after the end of the Synchronized Reserve Event in which the Batch Load Economic Load Response Participant resource's consumption was highest and for which its consumption in all subsequent minutes within the ten minutes was not less than fifty percent of the consumption in such minute; provided that, the magnitude of the response shall be zero if, when the Synchronized Reserve Event commences, the scheduled off-cycle stage of the production cycle is greater than ten minutes. .

3.2.3A.001 Non-Synchronized Reserve.

(a) Each Market Participant that is a Load Serving Entity that is not part of an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have an obligation for hourly Non-Synchronized Reserve equal to its pro rata share of Non-Synchronized Reserve assigned for the hour for each Reserve Zone and Reserve Sub-zone of the PJM Region, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Reserve Zone and Reserve Sub-zone for the hour ("Non-Synchronized Reserve Obligation"). Those entities that participate in an agreement to share reserves with external entities subject to the requirements in BAL-002 shall have their reserve obligations determined based on the stipulations in such agreement. A Market Participant's hourly Non-Synchronized Reserve Obligation shall be adjusted by any Non-Synchronized Reserve provided on the Market Participant's behalf through a bilateral agreement. A Market Participant with an hourly Non-Synchronized Reserve Obligation shall be charged the pro rata share of the sum day-ahead and real-time credits for Non-Synchronized Reserve as defined in sections 3.2.3A.001(b)(i) and (ii) below.

(b) Resources assigned to provide Non-Synchronized Reserve at the direction of the Office of the Interconnection shall be credited as follows:

(i) Credits for Non-Synchronized Reserve provided by generation resources assigned to provide Non-Synchronized Reserve by the Office of the Interconnection in the Day-ahead Non-Synchronized Reserve Market shall be equal to the product of the Day-ahead Non-Synchronized Market Clearing Price multiplied by the megawatt amount of Non-Synchronized Reserve such resource is assigned to provide.

(ii) Credits for Non-Synchronized Reserve provided by generation resources assigned to provide Non-Synchronized Reserve by the Office of the Interconnection in the Real-time Non-Synchronized Reserve Market shall be determined for each operating hour based on the sum on their hourly total of Real-time Settlement Interval deviations determined in accordance with the following equation:

$$\sum_i ((A - B) * C)$$

Where:

i = the Real-time Settlement Intervals in the applicable operating hour;

A = For each Real-time Settlement Interval, the megawatts of Non-Synchronized Reserve from that resource assigned by the Office of the Interconnection in the Real-time Non-Synchronized Reserve Market;

B = For each Real-time Settlement Interval, the megawatts of Non-Synchronized Reserve from that resource assigned by the Office of the Interconnection in the Day-ahead Non-Synchronized Reserve Market; and

C = For each Real-time Settlement Interval, the Real-time Non-Synchronized Reserve Market Clearing Price.

(iii) Pool-scheduled generation resources assigned to provide Non-Synchronized Reserve in the Day-ahead Non-Synchronized Reserve Market shall be credited a Non-Synchronized Reserve lost opportunity cost credit, where positive, as determined in accordance with subsection (d)(iii) below, to recover any net monetary loss to the Market Seller of such resource associated with the purchase of Non-Synchronized Reserve in the Real-time Non-Synchronized Reserve Market as a result of following the dispatch direction of the Office of the Interconnection.

(c) Non-Synchronized Reserve Market Clearing Prices

(i) For the Day-ahead Non-Synchronized Reserve Market, the Non-Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection for each hour of the Operating Day. The Day-ahead Non-Synchronized Reserve Market Clearing Price shall be calculated as the price of serving the next increment of demand for Primary Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Non-Synchronized Reserve offer prices and the applicable Operating

Reserve Demand Curve for Non-Synchronized Reserve established in accordance with Operating Agreement, Schedule 1, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Primary Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for Primary Reserve can contribute and (B) the price of serving the next increment of demand for 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Primary Reserve can contribute, provided that the Non-Synchronized Reserve Market Clearing Price shall be less than or equal to the product of 1.5 multiplied by the Reserve Penalty Factor for the Primary Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Non-Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.10.8(d), Day-ahead Non-Synchronized Reserve Market Clearing Prices shall be set to zero dollars per megawatt-hour and for purposes of settlements for such Operating Day, the Office of the Interconnection shall utilize a scheduled megawatt quantity and Day-ahead Non-Synchronized Reserve Market Clearing Price of zero dollars per megawatt-hour and all settlements will be based on the Real-time Non-Synchronized Reserve market quantities and prices as determined pursuant to subsection (c)(ii) hereof.

(ii) For the Real-time Non-Synchronized Reserve Market, the Non-Synchronized Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection in the Real-time Price software program, which is known as the pricing run, for each Real-time Settlement Interval of the Operating Day. Each 5-minute clearing price shall be calculated as the price of serving the next increment of demand for Primary Reserve in a Reserve Zone or Reserve Sub-zone determined by the interaction between a supply curve formed using Non-Synchronized Reserve offer prices and the applicable Operating Reserve Demand Curve for Non-Synchronized Reserve established in accordance with Operating Agreement, Schedule 1, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus (A) the price of serving the next increment of demand for Primary Reserve for any other Reserve Zone or Reserve Subzone to which the next increment of demand for Primary Reserve can contribute and (B) the price of serving the next increment of demand for 30-minute Reserve for each Reserve Zone or Reserve Sub-zone to which the next increment of demand for Primary Reserve can contribute, provided that the Non-Synchronized Reserve Market Clearing Price shall be less than or equal to the product of 1.5 multiplied by the Reserve Penalty Factor for the Primary Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for Non-Synchronized Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, and the Office of the Interconnection is not assigning Non-Synchronized Reserves, then the Non-Synchronized Reserve Clearing Price will be set to zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, where the real-time Market Suspension is less than or equal to six (6) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Non-Synchronized Reserves, then the Non-Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Non-Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than six (6) consecutive hours but less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are cleared Day-ahead Non-Synchronized Reserve Market Clearing Prices for the affected Operating Day, then the Real-time Non-Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the Day-ahead Non-Synchronized Reserve Market Clearing Prices for each corresponding hour. If no such Day-ahead Non-Synchronized Reserve Market Clearing Prices exist, then the Non-Synchronized Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Non-Synchronized Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than twenty-four (24) consecutive hours, the Non-Synchronized Reserve Market Clearing Price will be set to zero dollars per megawatt-hour regardless of whether the Office of the Interconnection is assigning Non-Synchronized Reserves.

If the Office of the Interconnection has initiated in a Reserve Zone or Reserve Sub-zone either a Voltage Reduction Action as described in the PJM Manuals or a Manual Load Dump Action as described in the PJM Manuals, the Real-time Non-Synchronized Reserve Market Clearing Price shall be the product of 1.5 multiplied by the Reserve Penalty Factor for the Primary Reserve Requirement for that Reserve Zone or Reserve Sub-zone.

(iii) The Reserve Penalty Factor for the Primary Reserve Requirement shall be \$850/MWh.

The Reserve Penalty Factor for the Extended Primary Reserve Requirement shall be \$300/MWh.

(iv) By no later than April 30 of each year, the Office of the Interconnection will analyze Market Participants' response to prices exceeding \$1,000/MWh on an annual basis and will provide its analysis to PJM stakeholders. The Office of the Interconnection will also review this analysis to determine whether any changes to the Primary Reserve Penalty Factors are warranted for subsequent Delivery Year(s).

(d) (i) For determining the Non-Synchronized Reserve clearing price for each hour in the Day-ahead Non-Synchronized Reserve Market and for each Real-time Settlement Interval in the Real-time Non-Synchronized Reserve Market, including during a declaration of a Market Suspension, the unit-specific opportunity cost for a generation resource that is not providing energy because they are providing Non-Synchronized Reserves will be zero.

(ii) For each Real-time Settlement Interval, a total Market Revenue Neutrality Offset is calculated for each resource, if eligible. If there is a decrease in real-time reserve MW from a day-ahead market assignment in more than one market for that Real-time Settlement Interval, the total Market Revenue Neutrality Offset is allocated to the Non-Synchronized Reserve market based on the ratio of the opportunity cost owed due to a reduction in assignment in real-time within the Non-Synchronized Reserve market and the total opportunity cost owed due to a reduction in assignment in real-time from all reserve markets, not to exceed the resource's opportunity cost owed in the Non-Synchronized Reserve market.

A resource is not eligible for Market Revenue Neutrality Offset for Non-Synchronized Reserve in a Real-time Settlement Interval for any of the following conditions:

(A) A resource's real-time Non-Synchronized Reserve assignment decreases due to the resource being self-scheduled to provide energy, Synchronized Reserve, or Regulation;

(B) A resource reduces flexibility in real-time such that the resource no longer qualifies to provide Non-Synchronized Reserve in real-time;

(C) A resource's Final Offer is less than its Committed Offer;

(D) A resource trips offline or otherwise becomes unavailable in real-time; or

(E) A resource does not follow dispatch as described in section 3.2.3(o) above and section 3.2.3(o-1) above.

(iii) A Non-Synchronized Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:

$$(\text{zero}) - (A + B + C + D)$$

Where:

A = day-ahead clearing price credits as determined in subsection (b)(i) above;

B = real-time clearing price credits as determined in subsection (b)(ii) above;

C = the applicable Market Revenue Neutrality Offset as determined in subsection (d)(ii) above; and

D = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A.001(d)(ii) above if not eligible for Market Revenue Neutrality Offset.

(e) [Reserved for future use]

(f) For each operating hour, the sum of the Non-Synchronized Reserve lost opportunity cost credits credited in subsection (b)(iii) above shall be allocated and charged to each Market Participant that does not meet its hourly Non-Synchronized Reserve Obligation in proportion to its real-time purchases of Non-Synchronized Reserve in megawatt-hours during that hour.

(g) The magnitude of response to a Non-Synchronized Reserve Event by a generation resource is the difference between the generation resource's output at the start of the event and its output 10 minutes after the start of the event. In order to allow for small fluctuations and possible telemetry delays, generation resource output at the start of the event is defined as the lowest telemetered generator resource output between one minute prior to and one minute following the start of the event. Similarly, a generation resource's output 10 minutes after the start of the event is defined as the greatest generator resource output achieved between 9 and 11 minutes after the start of the event. The response actually credited to a generation resource will be reduced by the amount the megawatt output of the generation resource falls below the level achieved after 10 minutes by either the end of the event or after 30 minutes from the start of the event, whichever is shorter.

(h) In the event a generation resource that has been assigned by the Office of the Interconnection to provide Non-Synchronized Reserve fails to provide the assigned amount of Non-Synchronized Reserve in response to a Non-Synchronized Reserve Event, the resource will be credited for Non-Synchronized Reserve capacity in the amount that actually responded for the contiguous Real-time Settlement Interval the resource was assigned Non-Synchronized Reserve during which the event occurred.

3.2.3A.01 Secondary Reserve.

(a) Each Market Participant that is a Load Serving Entity shall have an obligation for hourly Secondary Reserve equal to its pro rata share of Secondary Reserve assigned for the hour for each Reserve Zone and Reserve Sub-zone of the PJM Region, based on the Market Participant's total load (net of operating Behind The Meter Generation, but not to be less than zero) in such Reserve Zone and Reserve Sub-zone for the hour ("Secondary Reserve Obligation"). A Market Participant's hourly Secondary Reserve Obligation shall be adjusted by any Secondary Reserve provided on the Market Participant's behalf through a bilateral

agreement. A Market Participant with an hourly Secondary Reserve Obligation shall be charged the pro rata share of the sum of day-ahead and real-time credits for Secondary Reserve as defined in sections 3.2.3A.01(b)(i) and (ii) below.

(b) Resources assigned to provide Secondary Reserve at the direction of the Office of the Interconnection shall be credited as follows:

(i) Credits for Secondary Reserve provided by generation resources and Economic Load Response Participant resources assigned to provide Secondary Reserve by the Office of the Interconnection in the Day-ahead Secondary Reserve Market shall be equal to the product of the Day-ahead Secondary Reserve Market Clearing Price multiplied by the megawatt amount of Secondary Reserve such resource is scheduled to provide.

(ii) Credits for Secondary Reserve provided by generation resources and Economic Load Response Participant resources scheduled to provide Secondary Reserve by the Office of the Interconnection in the Real-time Secondary Reserve Market shall be determined for each operating hour based on the sum of their hourly total of Real-time Settlement Interval deviations determined in accordance with the following equation:

$$\sum_i ((A - B) * C)$$

Where:

i = the Real-time Settlement Intervals in the applicable operating hour;

A = For each Real-time Settlement Interval, the megawatts of Secondary Reserve from that resource assigned by the Office of the Interconnection in the Real-time Secondary Reserve Market. The megawatt value is capped at the lesser of the Economic Maximum or Secondary Reserve maximum MW minus the Revenue Data for Settlements of the resource for each Real-time Settlement Interval minus the Real-time Synchronized Reserve assignment;

B = For each Real-time Settlement Interval, the megawatts of Secondary Reserve from that resource scheduled by the Office of the Interconnection in the Day-ahead Secondary Reserve Market; and

C = For each Real-time Settlement Interval, the Real-time Secondary Reserve Market Clearing Price.

(iii) Pool-scheduled resources and Economic Load Response Participant resources shall be credited a Secondary Reserve lost opportunity cost credit, where positive, as described in subsection (f)(iv) below.

(c) [Reserved for future use]

(d) Secondary Reserve Market Clearing Prices

(i) For the Day-ahead Secondary Reserve Market, the Secondary Reserve Market Clearing Price shall be determined for each Reserve Zone and, as applicable, Reserve Sub-zone by the Office of the Interconnection for each hour of the Operating Day. The Day-ahead Secondary Reserve Market Clearing Price shall be calculated as the price of serving the next increment of demand for 30-minute Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Secondary Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Secondary Reserve established in accordance with Operating Agreement, Schedule 1, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus the price of serving the next increment of demand for 30-minute Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute, but the Secondary Reserve Market Clearing Price shall not exceed the Reserve Penalty Factor for the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, per Operating Agreement, Schedule 1, section 1.10.8(d), Day-ahead Secondary Reserve Market Clearing Prices shall be set to zero dollars per megawatt-hour and for purposes of settlements for such Operating Day, the Office of the Interconnection shall utilize a scheduled megawatt quantity and Day-ahead Secondary Reserve Market Clearing Price of zero dollars per megawatt-hour and all settlements will be based on the Real-time Secondary Reserve market quantities and prices as determined pursuant to subsection (d)(ii) hereof.

(ii) For the Real-time Secondary Reserve Market, the Secondary Reserve Market Clearing Price shall be determined for each Reserve Zone and Reserve Sub-zone by the Office of the Interconnection for each Real-time Settlement Interval of the Operating Day. Each 5-minute clearing price shall be calculated as the price of serving the next increment of demand for 30-minute Reserve in a Reserve Zone or Reserve Sub-zone, determined by the interaction between a supply curve formed using Secondary Reserve offer prices and opportunity costs and the applicable Operating Reserve Demand Curve for Secondary Reserve established in accordance with Operating Agreement, Schedule 1, section 3.2.3A.02 for that Reserve Zone or Reserve Sub-zone, plus the price of serving the next increment of demand for 30-minute Reserve for any other Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute but the Secondary Reserve Market Clearing Price shall not exceed the Reserve Penalty Factor for the 30-minute Reserve Requirement for the Reserve Zone or Reserve Sub-zone to which the next increment of demand for 30-minute Reserve can contribute.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, and the Office of the Interconnection is not assigning Secondary Reserves, then the Secondary Reserve Clearing Price will be set to

zero dollars per megawatt-hour for all Real-time Settlement Intervals in the Market Suspension period.

If the Office of the Interconnection declares a Market Suspension, as per Operating Agreement, Schedule 1, section 2.5.2, where the real-time Market Suspension is less than or equal to six (6) consecutive hours, which may span up to two Operating Days, and the Office of the Interconnection is assigning Secondary Reserves, then the Secondary Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Secondary Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than six (6) consecutive hours but less than or equal to twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are cleared Day-ahead Secondary Reserve Market Clearing Prices for the affected Operating Day, then the Real-time Secondary Reserve Market Clearing Prices associated with such Market Suspension shall be the Day-ahead Secondary Reserve Market Clearing Prices for each corresponding hour. If no such Day-ahead Secondary Reserve Market Clearing Prices exist, then the Secondary Reserve Market Clearing Prices associated with such Market Suspension shall be the average of the Secondary Reserve Market Clearing Prices for all Real-time Settlement Intervals of the preceding and subsequent clock hours (from XX:00 to XX:59) adjacent to such Market Suspension.

If the real-time Market Suspension is greater than twenty-four (24) consecutive hours, and the Office of the Interconnection is assigning Secondary Reserves, the Secondary Reserve Market Clearing Price will be set to zero dollars per megawatt-hour. Resources will be compensated for lost opportunity cost per subsection (f) hereof using the energy price as determined in Operating Agreement, Schedule 1, section 2.5.2.iii.

If the Office of the Interconnection has initiated in a Reserve Zone or Reserve Sub-zone either a Voltage Reduction Action or a Manual Load Dump Action as described in the PJM Manuals, the Real-time Secondary Reserve Market Clearing Price for a given Reserve Zone or Sub-zone shall be the Reserve Penalty Factor for the 30-minute Reserve Requirements for that Reserve Zone or Reserve Sub-zone

(iii) The Reserve Penalty Factor for the 30-minute Reserve Requirement shall be \$850/MWh.

The Reserve Penalty Factor for the Extended 30-minute Reserve Requirement shall be \$300/MWh.

(iv) By no later than April 30 of each year, the Office of the Interconnection will analyze Market Participants' response to prices exceeding \$1,000/MWh on an annual basis and will provide its analysis to PJM stakeholders. The Office of the Interconnection will also review this analysis to determine whether any changes to the Reserve Penalty Factor for 30-minute Reserve are warranted for subsequent Delivery Year(s).

(e) (i) For determining the Secondary Reserve Market Clearing Price for each hour in the Day-ahead Secondary Reserve Market, the estimated resource-specific opportunity cost for a generation resource or Economic Load Response Participant resources shall be the difference between the Locational Marginal Price at the generation or Economic Load Response Participant resource bus and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) or offer price to reduce energy from the Economic Load Response Participant resource in the PJM Interchange Energy Market when the Locational Marginal Price at the Economic Load Response Participant resource bus is greater than the offer price for energy from the generation resource or the offer price to reduce energy from the Economic Load Response Participant resource.

However, opportunity costs shall be zero for resources self-scheduled to provide Synchronized Reserve, and for synchronous condensers and for Economic Load Response Participant resources that do not receive a day-ahead commitment to provide energy in the same operating hour in which such resource is committed to provide Secondary Reserve.

(ii) For determining the Secondary Reserve Market Clearing Price for each Real-time Settlement Interval in the Real-time Secondary Reserve Market, the estimated unit-specific opportunity cost for a generation resource that is not a hydroelectric resource shall be the difference between the Locational Marginal Price at the generation bus for the generation resource and the offer price for energy from the generation resource (at the megawatt level of the energy dispatch point for the resource) in the PJM Interchange Energy Market when the Locational Marginal Price at the generation bus is greater than the offer price for energy from the generation resource.

For hydroelectric resources, the estimated unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the expected real-time Locational Marginal Price at that generation bus. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the expected real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average day-ahead Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating. The estimated unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

However, the opportunity costs shall be zero for resources self-scheduled to provide Synchronized Reserve, and for synchronous condensers and Economic Load Response Participant resources.

(f) (i) In determining the credit under subsection (b) to a generation resource, except a generation resource that is a synchronous condenser, selected to provide Secondary Reserve in the Day-ahead Secondary Reserve Market or an Economic Load Response Participant resource that is selected to provide Secondary Reserve in the Day-ahead Secondary Reserve Market in the same operating hour in which such resource receives a day-ahead commitment to provide energy, the opportunity cost of a resource shall be determined for each operating hour that the Office of the Interconnection requires a resource to provide Secondary Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Day-ahead Locational Marginal Price at the generation bus of the generation resource or the applicable pricing point for the Economic Load Response Participant resource;

B= The deviation of the resource's energy output or load reduction necessary to supply a Day-ahead Secondary Reserve assignment from the resource's expected energy output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load less any Day-ahead Synchronized Reserve Market assignment; and

C = The Day-ahead Energy Market offer integrated under the applicable energy offer curve for the resource's energy output or load reduction necessary to provide a Day-ahead Secondary Reserve Market assignment from the resource's expected energy output or load reduction level if it had been assigned in economic merit order to provide energy or reduce load less any Day-ahead Synchronized Reserve Market assignment.

For a generation resource that is a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: [energy use for providing synchronous condensing multiplied by A] plus [the applicable condense start-up cost divided by the number of hours the resource is assigned Secondary Reserve].

(ii) In determining the credit under subsection (b) to a generation resource, except a generation that is a synchronous condenser, selected to provide Secondary Reserve in the Real-time Secondary Reserve Market in excess of the resource's Day-ahead Secondary Reserve Market assignment and that actively follows the Office of the Interconnection's signals and instructions, the unit-specific opportunity cost of that generation resource shall be determined for each Real-time Settlement Interval that the Office of the Interconnection requires that generation resource to provide Secondary Reserve and shall be in accordance with the following equation:

$$(A \times B) - C$$

Where:

A = The Real-time Locational Marginal Price at the generation bus of the generation resource;

B= The deviation of the generation resource's output necessary to supply Secondary Reserve in real-time in excess of its Day-ahead Secondary Reserve Market assignment and follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy less any Real-time Synchronized Reserve Market assignment; and

C = The energy offer integrated under the applicable energy offer curve for the generation resource's output necessary to supply Secondary Reserve in real-time from the lesser of the generation resource's output necessary to provide a Day-ahead Secondary Reserve Market assignment or follow the Office of the Interconnection's signals and instructions from the generation resource's expected output level if it had been dispatched in economic merit order to provide energy less any Real-time Synchronized Reserve Market assignment.

For hydroelectric resources, the unit-specific opportunity costs for each hydroelectric resource in spill conditions as defined in the PJM Manuals will be the real-time Locational Marginal Price at that generation bus multiplied by the additional megawatts assigned to supply Synchronized Reserve in real-time in excess of its Day-ahead Secondary Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and has a day-ahead energy commitment greater than zero shall be the greater of zero and the difference between the real-time Locational Marginal Price at the generation bus for the hydroelectric resource and the average real-time Locational Marginal Price at the generation bus for the appropriate on-peak or off-peak period as defined in the PJM Manuals, excluding those hours during which all available units at the hydroelectric resource were operating multiplied by the additional megawatts assigned to supply Secondary Reserve in real-time in excess of its Day-ahead Secondary Reserve Market assignment.

The unit-specific opportunity costs for each hydroelectric resource that is not in spill conditions as defined in the PJM Manuals and does not have a day-ahead energy commitment greater than zero shall be zero.

For a generation resource that is a synchronous condenser, the resource's unit-specific opportunity cost shall be determined as follows: additional energy use in excess of day-ahead energy use for providing synchronous condensing in real-time multiplied by A plus [any applicable condense start-up costs due to additional condense start-ups in real-time in excess of day-ahead condense start-ups allocated to each Real-time

Settlement Interval as described in PJM Manuals]. If the generation resource is operating as a synchronous condenser and also has a Real-time Synchronized Reserve assignment, resource's unit-specific opportunity cost in the Secondary Reserve Market shall be zero,

(iii) For each Real-time Settlement Interval, a total Market Revenue Neutrality Offset is calculated for each resource, if eligible. If there is a decrease in real-time reserve MW from a day-ahead market assignment in more than one market for that real-time settlement interval, the total Market Revenue Neutrality Offset is allocated to the Secondary Reserve market based on the ratio of the opportunity cost owed due to a reduction in assignment in real-time within the Secondary Reserve market and the total opportunity cost owed due to a reduction in assignment in real-time from all reserve markets, not to exceed the resource's opportunity cost owed in the Secondary Reserve market.

A resource is not eligible for Market Revenue Neutrality Offset for Secondary Reserve in a Real-time Settlement Interval for any of the following conditions:

(A) A resource's real-time Secondary Reserve assignment decreases due to the resource being self-scheduled to provide energy, Synchronized Reserve, or Regulation;

(B) A resource reduces flexibility in real-time such that the resource no longer qualifies to provide Secondary Reserve in real-time;

(C) A resource's Final Offer is less than its Committed Offer;

(D) A resource trips offline or otherwise becomes unavailable in real-time;

(E) A resource does not follow dispatch as described in section 3.2.3(o) above and section 3.2.3(o-1) above; or

(F) A resource that fails to come online and reach Economic Minimum output within 30 minutes as described in section 3.2.3A.01(h)(i) below.

(iv) A Secondary Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:

$$(A + B) - (C + D + E + F)$$

Where:

A = day-ahead opportunity cost as determined in subsection (f)(i) above;

B = real-time opportunity cost as determined in subsection (f)(ii) above;

C = day-ahead clearing price credits as determined in subsection (b)(i) above;

D = real-time clearing price credits as determined subsection (b)(ii) above;

E = the applicable Market Revenue Neutrality Offset as determined in subsection (f)(iii) above; and

F = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A.01(f)(iii) above if not eligible for Market Revenue Neutrality Offset.

(v) The opportunity costs for Economic Load Response Participant resources and generation resources not synchronized to the grid shall be zero, except that Economic Load Response Participant resources may have a day-ahead opportunity cost, as determined in subsection (f)(i) above.

(g) For each operating hour, the sum of the Secondary Reserve lost opportunity cost credits credited in accordance with subsection (b)(iii) above shall be allocated and charged to each Market Participant that does not meet its hourly Secondary Reserve Obligation in proportion to its real-time purchases of Secondary Reserve in megawatt-hours during that hour.

(h) (i) In the event an offline generation resource has been assigned by the Office of the Interconnection to provide Secondary Reserve in real-time and is subsequently dispatched by the Office of the Interconnection to supply energy during that Operating Day and the resource qualifies as a Secondary Reserve resource at the time it is dispatched to provide energy, the Office of the Interconnection will assess the resource's performance as follows:

For each generation resource that fails to come online and reach Economic Minimum output within 30 minutes as instructed by the Office of the Interconnection, the resource's Real-time Secondary Reserve assignment will be set to zero megawatts for that interval and for all prior intervals in which the resource was assigned to provide Secondary Reserve in the Real-time Secondary Reserve Market starting at the later of (A) the last interval the resource was online or (B) the beginning of that Operating Day and continuing up to the interval the resource failed to come online. This results in the resource buying back the day-ahead assignment at the Real-time Secondary Reserve Market Clearing Price, or if solely assigned in real-time not being paid for the assigned MW.

(ii) In the event an Economic Load Response Participant resource has been assigned by the Office of the Interconnection to provide Secondary Reserve in real-time and is subsequently dispatched to supply the Secondary Reserve assignment as a load reduction, the Office of the Interconnection will assess the resource's performance as follows:

For the purposes of this subsection, a resource's starting MW usage shall be the greatest telemetered consumption between one minute prior to and one minute following the issuance of a dispatch instruction from the Office of the Interconnection, and a resource's ending MW usage shall be the lowest consumption between 29 and 31 minutes after the issuance of a dispatch instruction from the Office of the Interconnection.

For each Economic Load Response Participant resource that fails to reduce load by at least the Economic Minimum, where the measured response is the difference between the resource's starting MW usage and the resource's ending MW usage as described above, within 30 minutes as instructed by the Office of the Interconnection, the resource's Real-time Secondary Reserve assignment will be set to zero megawatts for that interval, and for all prior intervals in which the resource was assigned to provide Secondary Reserve in the Real-time Secondary Reserve Market between such non-performance event starting at the later of (A) the last interval the resource reduced load at the instruction of the Office of the Interconnection or (B) the beginning of that Operating Day, and for all subsequent intervals through the earlier of (C) the next interval in which the resource is dispatched to reduce load or (D) the end of the Operating Day. This results in the resource buying back the day-ahead assignment at the Real-time Secondary Reserve Market Clearing Price, or if solely assigned in real-time, refunding all payments due for Secondary Reserve during such period.

(iii) For Batch Load Economic Load Response Participant Resources, a second method of verification will be used for instances where a Secondary Reserve assignment dispatched as an energy load reduction is initiated and the resource is operating at the minimum consumption level of its duty cycle. In this case, the magnitude of the response will be measured as the difference between (A) the minimum of the resource's consumption between the minute before and the minute after the end of the last settlement interval the resource reduced load at the instruction of the Office of the Interconnection and (B) the maximum consumption within a ten (10) minute period following the end of the last settlement interval the resource reduced load provided that all subsequent minutes following that minute are no less than 50% of the consumption in that minute.

For each Batch Load Economic Load Response Participant Resource that fails to reduce load by at least the Economic Minimum, where the measured response is the difference between the resource's starting MW usage and the resource's ending MW usage as described in section (ii) above or the difference between (A) and (B) as described in section (iii) above, within 30 minutes as instructed by the Office of the Interconnection, the resource's Real-time Secondary Reserve assignment will be set to zero megawatts for that interval, and for all prior intervals in which the resource was assigned to provide Secondary Reserve in either the Day-ahead or Real-time Secondary Reserve Markets between such non-performance event starting at the later of (A) the last interval the resource reduced load at the instruction of the Office of the Interconnection or (B) the beginning of that Operating Day, and for all subsequent intervals through the earlier of (C) the next interval in which the resource is dispatched to reduce load or (D) the end of the Operating Day. This results in the resource buying back the day-ahead assignment at the Real-

time Secondary Reserve Market Clearing Price, or if solely assigned in real-time, refunding all payments due for Secondary Reserve during such period.

3.2.3A.02 Operating Reserve Demand Curves

The Office of the Interconnection shall establish Operating Reserve Demand Curves for clearing 30-minute Reserve, Primary Reserve, and Synchronized Reserve, for, as applicable, each Reserve Zone or Reserve Sub-zone to procure sufficient reserves to meet, as applicable, (a) 30-minute Reserve Requirement and Extended 30-minute Reserve Requirement; (b) Primary Reserve Requirement and Extended Primary Reserve Requirement; and (c) Synchronized Reserve Requirement and Extended Synchronized Reserve Requirement. The Operating Reserve Demand Curves established for each reserve type shall be used to commit such reserves in both the day-ahead and real-time reserve markets. The Operating Reserve Demand Curves shall be determined in accordance with the applicable Reserve Penalty Factors and PJM Manuals.

3.2.3B Reactive Services.

(a) A Market Seller providing Reactive Services at the direction of the Office of the Interconnection shall be credited as specified below for the operation of its resource. These provisions are intended to provide payments to generating units when the LMP dispatch algorithms would not result in the dispatch needed for the required reactive service. LMP will be used to compensate generators that are subject to redispatch for reactive transfer limits.

(b) At the end of each Operating Day, where the active energy output of a Market Seller's resource is reduced or suspended at the request of the Office of the Interconnection for the purpose of maintaining reactive reliability within the PJM Region, the Market Seller shall be credited according to sections 3.2.3B(c) & 3.2.3B(d).

(c) A Market Seller providing Reactive Services from either a steam-electric generating unit or combined cycle unit operating in combined cycle mode, where such unit is pool-scheduled (or self-scheduled, if operating according to Operating Agreement, Schedule 1, section 1.10.3 (c) hereof), and where the real time LMP at the unit's bus is higher than the price offered by the Market Seller for energy from the unit at the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override) shall be compensated for lost opportunity cost by receiving a credit for each Real-time Settlement Interval in an amount equal to the product of (A) the deviation of the generating unit's output necessary to follow the Office of the Interconnection's signals and the generating unit's expected output level if it had been dispatched in economic merit order, times (B) the Real-time Price at the generation bus for the generating unit, minus (C) the Total Lost Opportunity Cost Offer, provided that the resulting outcome is greater than \$0.00. This equation is represented as $(A*B) - C$.

(d) A Market Seller providing Reactive Services from either a combustion turbine unit or combined cycle unit operating in simple cycle mode that is pool scheduled (or self-scheduled, if operating according to Operating Agreement, Schedule 1, section 1.10.3 (c)

hereof), operated as requested by the Office of the Interconnection, shall be compensated for lost opportunity cost for each Real-time Settlement Interval, limited to the lesser of the unit's Economic Maximum or the unit's Generation Resource Maximum Output, if the unit output is reduced at the direction of the Office of the Interconnection and the real time LMP at the unit's bus is higher than the price offered by the Market Seller for energy from the unit at the level of output requested by the Office of the Interconnection as directed by the PJM dispatcher, then the Market Seller shall be credited in a manner consistent with that described above in section 3.2.3B(c) for a steam unit or a combined cycle unit operating in combined cycle mode.

(e) At the end of each Operating Day, where the active energy output of a Market Seller's unit is increased at the request of the Office of the Interconnection for the purpose of maintaining reactive reliability within the PJM Region and the offered price of the energy is above the real-time LMP at the unit's bus, the Market Seller shall be credited according to section 3.2.3B(f).

(f) A Market Seller providing Reactive Services from either a steam-electric generating unit, combined cycle unit or combustion turbine unit, where such unit is pool scheduled (or self-scheduled, if operating according to Operating Agreement, Schedule 1, section 1.10.3 (c) hereof), and where the real time LMP at the unit's bus is lower than the price offered by the Market Seller for energy from the unit at the level of output requested by the Office of the Interconnection (as indicated either by the desired MWs of output from the unit determined by PJM's unit dispatch system or as directed by the PJM dispatcher through a manual override), shall receive a credit in an amount equal to $\{(AG - LMP_{DMW}) \times (UB - URTLMP)\}$ where:

AG equals the actual output of the unit;

LMP_{DMW} equals the level of output for the unit determined according to the point on the scheduled offer curve on which the unit was operating corresponding to the real time LMP at the unit's bus and adjusted for any Regulation or Tier 2 Synchronized Reserve assignments;

UB equals the unit offer for that unit for which output is increased, determined according to the lesser of the Final Offer or Committed Offer;

URTLMP equals the real time LMP at the unit's bus; and

where $UB - URTLMP$ shall not be negative.

(g) A Market Seller providing Reactive Services from a hydroelectric resource where such resource is pool scheduled (or self-scheduled, if operating according to Operating Agreement, Schedule 1, section 1.10.3 (c) hereof), and where the output of such resource is altered from the schedule submitted by the Market Seller for the purpose of maintaining reactive reliability at the request of the Office of the Interconnection, shall be compensated for lost opportunity cost in the same manner as provided in sections 3.2.2(d) and 3.2.3A(f) and further detailed in the PJM Manuals.

(h) If a Market Seller believes that, due to specific pre-existing binding commitments to which it is a party, and that properly should be recognized for purposes of this section, the above calculations do not accurately compensate the Market Seller for lost opportunity cost associated with following the Office of the Interconnection's dispatch instructions to reduce or suspend a unit's output for the purpose of maintaining reactive reliability, then the Office of the Interconnection, the Market Monitoring Unit and the individual Market Seller will discuss a mutually acceptable, modified amount of such alternate lost opportunity cost compensation, taking into account the specific circumstances binding on the Market Seller. Following such discussion, if the Office of the Interconnection accepts a modified amount of alternate lost opportunity cost compensation, the Office of the Interconnection shall invoice the Market Participant accordingly. If the Market Monitoring Unit disagrees with the modified amount of alternate lost opportunity cost compensation, as accepted by the Office of the Interconnection, it will exercise its powers to inform the Commission staff of its concerns.

(i) The amount of Synchronized Reserve provided by generating units maintaining reactive reliability shall be counted as Synchronized Reserve satisfying the overall PJM Synchronized Reserve requirements. Operators of these generating units shall be notified of such provision, and to the extent a generating unit's operator indicates that the generating unit is capable of providing Synchronized Reserve, shall be subject to the same requirements contained in section 3.2.3A regarding provision of Synchronized Reserve. At the end of each Operating Day, to the extent a condenser operated to provide Reactive Services also provided Synchronized Reserve, a Market Seller shall be credited for providing synchronous condensing for the purpose of maintaining reactive reliability at the request of the Office of the Interconnection, in an amount equal to the higher of (i) the Synchronized Reserve Market Clearing Price for each Real-time Settlement Interval a generating unit provided synchronous condensing multiplied by the amount of Synchronized reserve provided by the synchronous condenser or (ii) the sum of (A) the generating unit's cost to provide synchronous condensing, calculated in accordance with the PJM Manuals, (B) the product of MW energy usage for providing synchronous condensing multiplied by the real time LMP at the generating unit's bus, (C) the generating unit's startup-cost of providing synchronous condensing, and (D) the unit-specific lost opportunity cost of the generating resource supplying the increment of Synchronized Reserve as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals. To the extent a condenser operated to provide Reactive Services was not also providing Synchronized Reserve, the Market Seller shall be credited only for the generating unit's cost to condense, as described in (ii) above. The total Synchronized Reserve Obligations of all Load Serving Entities under section 3.2.3A(a) in the zone where these condensers are located shall be reduced by the amount counted as satisfying the PJM Synchronized Reserve requirements. The Synchronized Reserve Obligation of each Load Serving Entity in the zone under section 3.2.3A(a) shall be reduced to the same extent that the costs of such condensers counted as Synchronized Reserve are allocated to such Load Serving Entity pursuant to subsection (l) below.

(j) A Market Seller's pool scheduled steam-electric generating unit or combined cycle unit operating in combined cycle mode, that is not committed to operate in the Day-ahead Market, but that is directed by the Office of the Interconnection to operate solely for the purpose of maintaining reactive reliability, at the request of the Office of the Interconnection, shall be

credited in the amount of the unit's offered price for start-up and no-load fees. The unit also shall receive, if applicable, compensation in accordance with Sections 3.2.3B(e)-(f).

(k) The sum of the foregoing credits as specified in Sections 3.2.3B(b)-(j) shall be the cost of Reactive Services for the purpose of maintaining reactive reliability for the Operating Day and shall be separately determined for each transmission zone in the PJM Region based on whether the resource was dispatched for the purpose of maintaining reactive reliability in such transmission zone.

(l) The cost of Reactive Services for the purpose of maintaining reactive reliability in a transmission zone in the PJM Region for each Operating Day shall be allocated and charged to each Market Participant in proportion to its deliveries of energy to load (net of operating Behind The Meter Generation) in such transmission zone, served under Network Transmission Service, in megawatt-hours during that Operating Day, as compared to all such deliveries for all Market Participants in such transmission zone.

(m) Generating units receiving dispatch instructions from the Office of the Interconnection under the expectation of increased actual or reserve reactive shall inform the Office of the Interconnection dispatcher if the requested reactive capability is not achievable. Should the operator of a unit receiving such instructions realize at any time during which said instruction is effective that the unit is not, or likely would not be able to, provide the requested amount of reactive support, the operator shall as soon as practicable inform the Office of the Interconnection dispatcher of the unit's inability, or expected inability, to provide the required reactive support, so that the associated dispatch instruction may be cancelled. PJM Performance Compliance personnel will audit operations after-the-fact to determine whether a unit that has altered its active power output at the request of the Office of the Interconnection has provided the actual reactive support or the reactive reserve capability requested by the Office of the Interconnection. PJM shall utilize data including, but not limited to, historical reactive performance and stated reactive capability curves in order to make this determination, and may withhold such compensation as described above if reactive support as requested by the Office of the Interconnection was not or could not have been provided.

3.2.3C Synchronous Condensing for Post-Contingency Operation.

(a) Under normal circumstances, PJM operates generation out of merit order to control contingency overloads when the flow on the monitored element for loss of the contingent element ("contingency flow") exceeds the long-term emergency rating for that facility, typically a 4-hour or 2-hour rating. At times however, and under certain, specific system conditions, PJM does not operate generation out of merit order for certain contingency overloads until the contingency flow on the monitored element exceeds the 30-minute rating for that facility ("post-contingency operation"). In conjunction with such operation, when the contingency flow on such element exceeds the long-term emergency rating, PJM operates synchronous condensers in the areas affected by such constraints, to the extent they are available, to provide greater certainty that such resources will be capable of producing energy in sufficient time to reduce the flow on the monitored element below the normal rating should such contingency occur.

(b) The amount of Synchronized Reserve provided by synchronous condensers associated with post-contingency operation shall be counted as Synchronized Reserve satisfying the applicable Synchronized Reserve Requirements. Operators of these generation units shall be notified of such provision, and to the extent a generation unit's operator indicates that the generation unit is capable of providing Synchronized Reserve, shall be subject to the same requirements contained in section 3.2.3A regarding provision of Synchronized Reserve. At the end of each Operating Day, to the extent a condenser operated in conjunction with post-contingency operation also provided Synchronized Reserve, a Market Seller shall be credited for providing synchronous condensing in conjunction with post-contingency operation at the request of the Office of the Interconnection, in an amount equal to the higher of (i) the Real-time Synchronized Reserve Market Clearing Price for each applicable interval a generation resource provided synchronous condensing multiplied by the amount of Synchronized Reserve provided by the synchronous condenser or (ii) the sum of (A) the generation resource's applicable interval cost to provide synchronous condensing, calculated in accordance with the PJM Manuals, (B) the applicable interval product of the megawatts of energy used to provide synchronous condensing multiplied by the real-time LMP at the generation bus of the generation resource, (C) the generation resource's start-up cost of providing synchronous condensing, and (D) the unit-specific lost opportunity cost of the generation resource supplying the increment of Synchronized Reserve as determined by the Office of the Interconnection in accordance with procedures specified in the PJM Manuals. To the extent a condenser operated in association with post-contingency constraint control was not also providing Synchronized Reserve, the Market Seller shall be credited only for the generation unit's cost to condense, as described in (ii) above. The total Synchronized Reserve Obligations of all Load Serving Entities under section 3.2.3A(a) in the zone where these condensers are located shall be reduced by the amount counted as satisfying the PJM Synchronized Reserve requirements. The Synchronized Reserve Obligation of each Load Serving Entity in the zone under section 3.2.3A(a) shall be reduced to the same extent that the costs of such condensers counted as Synchronized Reserve are allocated to such Load Serving Entity pursuant to subsection (d) below.

(c) The sum of the foregoing credits as specified in section 3.2.3C(b) shall be the cost of synchronous condensers associated with post-contingency operations for the Operating Day and shall be separately determined for each transmission zone in the PJM Region based on whether the resource was dispatched in association with post-contingency operation in such transmission zone.

(d) The cost of synchronous condensers associated with post-contingency operations in a transmission zone in the PJM Region for each Operating Day shall be allocated and charged to each Market Participant in proportion to its deliveries of energy to load (net of operating Behind The Meter Generation) in such transmission zone, served under Network Transmission Service, in megawatt-hours during that Operating Day, as compared to all such deliveries for all Market Participants in such transmission zone.

3.2.4 Transmission Congestion Charges.

Each Market Buyer shall be assessed Transmission Congestion Charges as specified in Operating Agreement, Schedule 1, section 5.

3.2.5 Transmission Loss Charges.

Each Market Buyer shall be assessed Transmission Loss Charges as specified in Operating Agreement, Schedule 1, section 5.

3.2.6 Emergency Energy.

(a) When the Office of the Interconnection has implemented Emergency procedures, resources offering Emergency energy are eligible to set real-time Locational Marginal Prices, capped at the energy offer cap plus the sum of the applicable Reserve Penalty Factors for the Synchronized Reserve Requirement and Primary Reserve Requirement, provided that the Emergency energy is needed to meet demand in the PJM Region.

(b) Market Participants shall be allocated a proportionate share of the net cost of Emergency energy purchased by the Office of the Interconnection. Such allocated share during each applicable interval of such Emergency energy purchase shall be in proportion to the amount of each Market Participant's real-time deviation from its net withdrawals and injections in the Day-ahead Energy Market, whenever that deviation increases the Market Participant's spot market purchases or decreases its spot market sales. This deviation shall not include any reduction or suspension of output of pool scheduled resources requested by PJM to manage an Emergency within the PJM Region.

(c) Net revenues in excess of Real-time Prices attributable to sales of energy in connection with Emergencies to other Control Areas shall be credited to Market Participants during each applicable interval of such Emergency energy sale in proportion to the sum of (i) each Market Participant's real-time deviation from its net withdrawals and injections in the Day-ahead Energy Market, whenever that deviation increases the Market Participant's spot market purchases or decreases its spot market sales, and (ii) each Market Participant's energy sales from within the PJM Region to entities outside the PJM Region that have been curtailed by PJM.

(d) The net costs or net revenues associated with sales or purchases of energy in connection with a Minimum Generation Emergency in the PJM Region, or in another Control Area, shall be allocated during each applicable interval of such Emergency sale or purchase to each Market Participant in proportion to the amount of each Market Participant's real-time deviation from its net withdrawals and injections in the Day-ahead Market, whenever that deviation increases the Market Participant's spot market sales or decreases its spot market purchases.

3.2.7 Billing.

(a) PJM Settlement shall prepare a billing statement each billing cycle for each Market Participant in accordance with the charges and credits specified in Operating Agreement, Schedule 1, sections 3.2.1 through 3.2.6, and showing the net amount to be paid or received by the Market Participant. Billing statements shall provide sufficient detail, as specified in the PJM Manuals, to allow verification of the billing amounts and completion of the Market Participant's internal accounting.

(b) If deliveries to a Market Participant that has PJM Interchange meters in accordance with Operating Agreement, section 14 include amounts delivered for a Market Participant that does not have PJM Interchange meters separate from those of the metered Market Participant, PJMSettlement shall prepare a separate billing statement for the unmetered Market Participant based on the allocation of deliveries agreed upon between the Market Participant and the unmetered Market Participant specified by them to the Office of the Interconnection.

7.1 Auctions of Financial Transmission Rights.

Annual, periodic and long-term auctions to allow Market Participants to acquire or sell Financial Transmission Rights shall be conducted by the Office of the Interconnection in accordance with the provisions of this Section. PJMSettlement shall be the Counterparty to the purchases and sales of Financial Transmission Rights arising from such auctions; provided however, that PJMSettlement shall not be a contracting party to any subsequent bilateral transfer of Financial Transmission Rights between Market Participants. The conversion of an Auction Revenue Right to a Financial Transmission Right pursuant to this section 7 shall not constitute a purchase or sale transaction to which PJMSettlement is a contracting party.

7.1.1 Auction Period and Scope of Auctions.

(a) The periods covered by auctions shall be: (1) the one-year period beginning the month after the final round of an annual auction; and (2) any single calendar month period remaining in the Planning Period. With the exception of FTRs allocated pursuant to Operating Agreement, Schedule 1, section 5.2.2 (e) and the Financial Transmission Rights awarded as a result of the exercise of the conversion option pursuant to Operating Agreement, Schedule 1, section 7.1.1(b), in the annual auction, the Office of the Interconnection, on behalf of PJMSettlement, shall offer for sale the entire Financial Transmission Rights capability for the year in four rounds with 25 percent of the capability offered in each round. In the monthly auction, the Office of the Interconnection, on behalf of PJMSettlement, shall offer for sale in the auction any remaining Financial Transmission Rights capability for the months remaining in the Planning Period after taking into account all of the Financial Transmission Rights already outstanding at the time of the auction. In addition, any holder of a Financial Transmission Right for the period covered by an auction may offer such Financial Transmission Right for sale in such auction. Weekend on-peak, weekday on-peak, off-peak and 24-hour Financial Transmission Rights, as those products are described in Operating Agreement, Schedule 1, section 7.3.4, will be offered in the annual and monthly auctions. FTRs will be offered as Financial Transmission Right Obligations and Financial Transmission Right Options, provided that such Financial Transmission Right Obligations and Financial Transmission Right Options shall be awarded based only on the residual system capability that remains after the allocation of Financial Transmission Rights pursuant to Operating Agreement, Schedule 1, section 5.2.2(e) and the award of Financial Transmission Rights pursuant to Operating Agreement, Schedule 1, section 7.1.1(b). Market Participants may bid for and acquire any number of Financial Transmission Rights, provided that all Financial Transmission Rights awarded are simultaneously feasible with each other and with all Financial Transmission Rights outstanding at the time of the auction and not sold into the auction. An ARR holder may self-schedule an FTR on the same path in the Annual FTR auction according to the rules described in the PJM Manuals.

(b) An Auction Revenue Rights holder may convert Auction Revenue Rights to Financial Transmission Rights, and such conversion shall not be considered a purchase or sale of Financial Transmission Rights in the auction. Such Financial Transmission Rights must (i) have the same source and sink points as the Auction Revenue Rights; and (ii) be Financial Transmission Right Obligations. The Auction Revenue Rights holder must inform the Office of the Interconnection

in accordance with the procedures established by the Office of the Interconnection that it intends to exercise the conversion option prior to close of round one of the annual Financial Transmission Rights auction. Once the conversion option is exercised, it will remain in effect for the entire Financial Transmission Rights auction. The Office of the Interconnection will designate twenty-five percent of the megawatt amount of the Auction Revenue Rights to be converted as price-taker bids in each of the four rounds of the Financial Transmission Rights auction. An Auction Revenue Rights holder that converts its Auction Revenue Rights may not designate a price bid for its converted Financial Transmission Rights and will receive a price equal to the clearing price set by other bids in the annual Financial Transmission Right auction. To the extent a market participant seeks to obtain FTRs in the annual auction through such conversion, the FTRs sought will not be included in the calculation of such market participant's credit requirement for such annual FTR auction.

7.1.2 Frequency and Time of Auctions.

Subject to Operating Agreement, Schedule 1, section 7.1.1, annual Financial Transmission Rights auctions shall offer the entire FTR capability of the PJM system in four rounds with 25 percent of the capability offered in each round. All four rounds of the annual Financial Transmission Rights auction shall occur within the two-month period (April – May) preceding the start of the PJM Planning Period. Each round shall occur over five Business Days and shall be conducted sequentially. Each round shall begin with the bidding period. The bidding period for annual Financial Transmission Rights auctions shall be open for three consecutive Business Days, opening the first day at 12:00 midnight (Eastern Prevailing Time) and closing the third day at 5:00 p.m. (Eastern Prevailing Time), subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e). Monthly Financial Transmission Rights auctions shall be held each month. The bidding period for monthly Financial Transmission Rights auctions shall be open for three consecutive Business Days in the month preceding the first month for which Financial Transmission Rights are being auctioned, opening the first day at 12:00 midnight (Eastern Prevailing Time) and closing the third day at 5:00 p.m. (Eastern Prevailing Time), subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e).

7.1.3 Duration of Financial Transmission Rights.

Each Financial Transmission Right acquired in a Financial Transmission Rights auction shall entitle the holder to credits of Day-ahead Energy Market Transmission Congestion Charges for the period that was specified in the corresponding auction.

7.1A Long-Term Financial Transmission Rights Auctions.

7.1A.1 Auctions.

(i) Subsequent to each annual Financial Transmission Rights auction conducted pursuant to Operating Agreement, Schedule 1, section 7.1, the Office of the Interconnection shall conduct a long-term Financial Transmission Rights auction for the three consecutive Planning Periods immediately subsequent to the Planning Period during which the long-term Financial Transmission Rights auction is conducted. PJMSettlement shall be the Counterparty to the purchases and sales of Financial Transmission Rights arising from such long-term Financial Transmission Rights auctions, provided however, that PJMSettlement shall not be a contracting party to any subsequent bilateral transfers of Financial Transmission Rights between Market Participants. The conversion of an Auction Revenue Right to a Financial Transmission Right pursuant to this section 7 shall not constitute a purchase or sale transaction to which PJMSettlement is a contracting party.

(ii) The capacity offered for sale in long-term Financial Transmission Rights auctions shall be the residual system capability after the annual Auction Revenue Rights allocations and the annual Financial Transmission Rights auction. In determining the residual capability the Office of the Interconnection shall assume that all Auction Revenue Rights allocated in the immediately prior annual Auction Revenue Rights allocation process, including Auction Revenue Rights made available in which transmission facilities which were modeled out of service in the annual Auction Revenue Rights allocations return to service, are self-scheduled into Financial Transmission Rights, which shall be modeled as fixed injections and withdrawals in the long-term Financial Transmission Rights auction. Additionally, residual annual Auction Revenue Rights that become available through incremental capability created by future transmission upgrades as further described in the PJM Manuals shall be modeled as fixed injections and withdrawals in the long-term Financial Transmission Rights auction. The long-term Financial Transmission Rights auction model shall include all upgrades planned to be placed into service on or before June 30th of the first Planning Period within the three year period covered by the auction. The transmission upgrades to be modeled for this purpose shall only include those upgrades that, individually, or together, have 10% or more impact on the transmission congestion on an individual constraint or constraints with congestion of \$5 million or more affecting a common congestion path. Transmission upgrades modeled for this purpose also will be modeled in the subsequent long-term Financial Transmission Rights auction, as further detailed in the PJM Manuals. Residual Auction Revenue Rights created by an increase in transmission capability due to future transmission upgrades, as specified above, are determined only for modeling purposes and will not be allocated to Market Participants.

7.1A.2 Frequency and Timing.

The long-term Financial Transmission Rights auction process shall consist of five rounds. The first round shall be conducted by the Office of the Interconnection approximately 11 months prior to the start of the three Planning Period term covered by the relevant long-term Financial Transmission Rights auction. The second round shall be conducted approximately 2 months

after the first round. The third round shall be conducted approximately 2 months after the second round. The fourth round shall be conducted approximately 2 months after the third round, and the fifth round shall be conducted approximately 3 months after the fourth round. In each round 20 percent of total capacity available in the long-term Financial Transmission Rights auction shall be offered for sale. Eligible entities may submit bids to purchase and offers to sell Financial Transmission Rights at the start of the bidding period in each round. The bidding period shall be three Business Days ending at 5:00 p.m. on the last day, subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e). PJM performs the Financial Transmission Rights auction clearing analysis for each round and posts the auction results on the market user interface within five Business Days after the close of the bidding period for each round unless circumstances beyond PJM's control prevent PJM from meeting the applicable deadline. Under such circumstances, PJM will post the auction results at the earliest possible opportunity. If the Office of the Interconnection discovers a potential error in the results posted for a long-term Financial Transmission Rights auction, the Office of the Interconnection shall notify Market Participants as soon as possible after it is found, but in no event later than 5:00 p.m. of the Business Day immediately following the initial publication of the results for that auction. After this initial notification, if the Office of the Interconnection determines it is necessary to post modified auction results, it shall provide notification of its intent to do so, along with a description detailing the cause and scope of the error, by no later than 5:00 p.m. of the second Business Day following the initial publication of prices for that auction. The provided description will not contain information that is market sensitive or confidential. Thereafter, the Office of the Interconnection must post the corrected prices by no later than 5:00 p.m. of the fourth calendar day following the initial publication of prices in the auction. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced auction results are under publicly noticed review by the FERC.

7.1A.3 Products.

- (i) The periods covered by long-term Financial Transmission Rights auctions shall be any single Planning Period within the three Planning Period term covered by the relevant auction.
- (ii) Weekend on-peak, weekday on-peak, off-peak and 24-hour Financial Transmission Rights, as those products are described in Operating Agreement, Schedule 1, section 7.3.4, shall be offered in long-term Financial Transmission Rights auctions; Financial Transmission Rights options shall not be offered.

7.1A.4 Participation Eligibility.

- (i) To participate in long-term Financial Transmission Rights auctions an entity shall be a PJM Member or a PJM Transmission Customer. Eligible entities may submit bids or offers in long-term Financial Transmission Rights auctions, provided they own Financial Transmission Rights offered for sale.

7.1A.5 Specified Receipt and Delivery Points.

The Office of the Interconnection will post a list of available receipt and delivery points for each long-term Financial Transmission Rights auction. Eligible receipt and delivery points in long-term Financial Transmission Rights auctions shall be limited to the posted available hubs, Zones, aggregates, generators, and Interface Pricing Points.

7.3 Auction Procedures.

7.3.1 Role of the Office of the Interconnection.

Financial Transmission Rights auctions shall be conducted by the Office of the Interconnection in accordance with standards and procedures set forth in the PJM Manuals, such standards and procedures to be consistent with the requirements of this Schedule. PJMSettlement shall be the Counterparty to the purchases and sales of Financial Transmission Rights arising from such auctions, provided however, that PJMSettlement shall not be a contracting party to any subsequent bilateral transfers of Financial Transmission Rights between Market Participants. The conversion of an Auction Revenue Right to a Financial Transmission Right pursuant to this section 7 shall not constitute a purchase or sale transaction to which PJMSettlement is a contracting party. Any Financial Transmission Rights auctions conducted to liquidate a defaulting Member's Financial Transmission Rights portfolio shall be conducted by the Office of the Interconnection in accordance with the procedures set forth in section 7.3.9 below, and as may be further described in the PJM Manuals.

7.3.2 Notice of Offer.

A holder of a Financial Transmission Right wishing to offer the Financial Transmission Right for sale shall notify the Office of the Interconnection of any Financial Transmission Rights to be offered. Each Financial Transmission Right sold in an auction shall, at the end of the period for which the Financial Transmission Rights were auctioned, revert to the offering holder or the entity to which the offering holder has transferred such Financial Transmission Right, subject to the term of the Financial Transmission Right itself and to the right of such holder or transferee to offer the Financial Transmission Right in the next or any subsequent auction during the term of the Financial Transmission Right.

7.3.3 Pending Applications for Firm Service.

(a) [Reserved.]

(b) Financial Transmission Rights may be assigned to entities requesting Network Transmission Service or Firm Point-to-Point Transmission Service pursuant to Operating Agreement, Schedule 1, section 5.2.2 (e), and the parallel provisions of Tariff, Attachment K-Appendix, section 5.2.2(e), only if such Financial Transmission Rights are simultaneously feasible with all outstanding Financial Transmission Rights, including Financial Transmission Rights effective for the then-current auction period. If an assignment of Financial Transmission Rights pursuant to a pending application for Network Transmission Service or Firm Point-to-Point Transmission Service cannot be completed prior to an auction, Financial Transmission Rights attributable to such transmission service shall not be assigned for the then-current auction period. If a Financial Transmission Right cannot be assigned for this reason, the applicant may withdraw its application, or request that the Financial Transmission Right be assigned effective with the start of the next auction period.

7.3.4 Weekend On-Peak, Weekday On-Peak, Off-Peak and 24-Hour Periods.

Weekend on-peak, weekday on-peak, off-peak and 24-hour Financial Transmission Rights will be offered in the annual , long-term, and monthly auctions. Weekend on-peak Financial Transmission Rights shall cover the periods from 7:00 a.m. up to the hour ending 11:00 p.m. on Saturdays, Sundays, and holidays as defined in the PJM Manuals. Weekday on-peak Financial Transmission Rights shall cover the periods from 7:00 a.m. up to the hour ending at 11:00 p.m. on Mondays through Fridays, except holidays as defined in the PJM Manuals. Off-Peak Financial Transmission Rights shall cover the periods from 11:00 p.m. up to the hour ending 7:00 a.m. on all days. The 24-hour period shall cover the period from hour ending 1:00 a.m. to the hour ending 12:00 midnight on all days. Each bid shall specify whether it is for a weekend on-peak, weekday on-peak, off-peak, or 24-hour period.

7.3.5 Offers and Bids.

(a) Offers to sell and bids to purchase Financial Transmission Rights shall be submitted during the period set forth in Operating Agreement, Schedule 1, section 7.1.2, and the parallel provisions of Tariff, Attachment K-Appendix, section 7.1.2, and shall be in the form specified by the Office of the Interconnection in accordance with the requirements set forth below.

(b) Offers to sell shall identify the specific Financial Transmission Right, by term, megawatt quantity and receipt and delivery points, offered for sale. An offer to sell a specified megawatt quantity of Financial Transmission Rights shall constitute an offer to sell a quantity of Financial Transmission Rights equal to or less than the specified quantity. An offer to sell may not specify a minimum quantity being offered. Each offer may specify a reservation price, below which the offeror does not wish to sell the Financial Transmission Right. Offers submitted by entities holding rights to Financial Transmission Rights shall be subject to such reasonable standards for the verification of the rights of the offeror as may be established by the Office of the Interconnection. Offers shall be subject to such reasonable standards for the creditworthiness of the offeror or for the posting of security for performance as the Office of the Interconnection shall establish.

(c) Bids to purchase shall specify the term, megawatt quantity, price per megawatt, and receipt and delivery points of the Financial Transmission Right that the bidder wishes to purchase. A bid to purchase a specified megawatt quantity of Financial Transmission Rights shall constitute a bid to purchase a quantity of Financial Transmission Rights equal to or less than the specified quantity. A bid to purchase may not specify a minimum quantity that the bidder wishes to purchase. A bid may specify receipt and delivery points in accordance with Operating Agreement, Schedule 1, section 7.2.2, and the parallel provisions of Tariff, Attachment K-Appendix, section 7.2.2, and may include Financial Transmission Rights for which the associated Transmission Congestion Credits may have negative values. Bids shall be subject to such reasonable standards for the creditworthiness of the bidder or for the posting of security for performance as the Office of the Interconnection shall establish.

(d) Bids and offers shall be specified to the nearest tenth of a megawatt and shall be greater than zero. The Office of the Interconnection may require that a market participant shall

not submit in excess of 5000 bids and offers for any single monthly auction, or for any single round of the annual auction, when the Office of the Interconnection determines that such limit is required to avoid or mitigate significant system performance problems related to bid/offer volume. Notice of the need to impose such limit shall be provided prior to the start of the bidding period if possible. Where such notice is provided after the start of the bidding period, market participants shall be required within one day to reduce their bids and offers for such auction below 5000, and the bidding period in such cases shall be extended by one day.

(e) In the event of extraordinary circumstances affecting the submission of bids within the bidding period in which the Office of the Interconnection determines it necessary to extend the bidding period, the Office of the Interconnection shall notify Market Participants as soon as possible of the new bidding period ending day and time.

7.3.6 Determination of Winning Bids and Clearing Price.

(a) At the close of each bidding period, the Office of the Interconnection will create a base Financial Transmission Rights power flow model that includes all outstanding Financial Transmission Rights that have been approved and confirmed for any portion of the month for which the auction was conducted and that were not offered for sale in the auction. The base Financial Transmission Rights model also will include estimated uncompensated parallel flows into each interface point of the PJM Region and estimated scheduled transmission outages.

(b) In accordance with the requirements of Operating Agreement, Schedule 1, section 7.5, and the parallel provisions of Tariff, Attachment K-Appendix, section 7.5, and subject to all applicable transmission constraints and reliability requirements, the Office of the Interconnection shall determine the simultaneous feasibility of all outstanding Financial Transmission Rights not offered for sale in the auction and of all Financial Transmission Rights that could be awarded in the auction for which bids were submitted. The winning bids shall be determined from an appropriate linear programming model that, while respecting transmission constraints and the maximum MW quantities of the bids and offers, selects the set of simultaneously feasible Financial Transmission Rights with the highest net total auction value as determined by the bids of buyers and taking into account the reservation prices of the sellers. In the event that there are two or more identical bids for the selected Financial Transmission Rights and there are insufficient Financial Transmission Rights to accommodate all of the identical bids, then each such bidder will receive a pro rata share of the Financial Transmission Rights that can be awarded.

(c) Financial Transmission Rights shall be sold at the market-clearing price for Financial Transmission Rights between specified pairs of receipt and delivery points, as determined by the bid value of the marginal Financial Transmission Right that could not be awarded because it would not be simultaneously feasible. The linear programming model shall determine the clearing prices of all Financial Transmission Rights paths based on the bid value of the marginal Financial Transmission Rights, which are those Financial Transmission Rights with the highest bid values that could not be awarded fully because they were not simultaneously feasible, and based on the flow sensitivities of each Financial Transmission Rights path relative to the marginal Financial Transmission Rights paths flow sensitivities on the binding

transmission constraints. Financial Transmission Rights with a zero clearing price will only be awarded if there is a minimum of one binding constraint in the auction period for which the Financial Transmission Rights path sensitivity is non-zero. Financial Transmission Right Options with a market-clearing price less than one dollar will not be awarded.

7.3.7 Announcement of Winners and Prices.

Within two (2) Business Days after the close of the bidding period for an annual Financial Transmission Rights auction round, and within five (5) Business Days after the close of the bidding period for a monthly Financial Transmission Rights auction, the Office of the Interconnection shall post the winning bidders, the megawatt quantity, the term and the receipt and delivery points for each Financial Transmission Right awarded in the auction and the price at which each Financial Transmission Right was awarded unless circumstances beyond PJM's control prevent PJM from meeting the applicable deadline. Under such circumstances, PJM will post the auction results at the earliest possible opportunity. The Office of the Interconnection shall not disclose the price specified in any bid to purchase or the reservation price specified in any offer to sell. If the Office of the Interconnection discovers an error in the results posted for a Financial Transmission Rights auction (or a given round of the annual Financial Transmission Rights auction), the Office of the Interconnection shall notify Market Participants of the error as soon as possible after it is found, but in no event later than 5:00 p.m. of the Business Day following the initial publication of the results of the auction or round of the annual auction. After this initial notification, if the Office of the Interconnection determines that it is necessary to post modified results, it shall provide notification of its intent to do so, together with all available supporting documentation, by no later than 5:00 p.m. of the second Business Day following the initial publication of the results of that auction or round of the annual auction. Thereafter, the Office of the Interconnection must post any corrected results by no later than 5:00 p.m. of the fourth calendar day following the initial publication of the results of the auction or round of the annual auction. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced auction results are under publicly noticed review by the FERC.

7.3.8 Auction Settlements.

All buyers and sellers of Financial Transmission Rights between the same points of receipt and delivery shall pay PJM Settlement or be paid by PJM Settlement the market-clearing price, as determined in the auction, for such Financial Transmission Rights.

For a Market Suspension where the suspension is greater than twenty-four (24) consecutive hours, which may span up to two Operating Days, and there are no Day-Ahead Prices available for the affected Operating Day, the Financial Transmission Right auction costs would be zero in proportion to the number of hours of the Market Suspension in the Operating Day.

7.3.9 Addressing Defaulting Member's Financial Transmission Rights.

In the event a Member fails to meet creditworthiness requirements or make timely payments when due pursuant to the Operating Agreement or Tariff, the Office of the Interconnection shall, as soon as practicable after declaring the Member to be in default as provided in Operating Agreement, section 15.1.5, use reasonable efforts to initiate within two applicable auctions the following procedures to settle, liquidate or otherwise resolve each Financial Transmission Rights position held by the defaulting Member:

a) The Office of the Interconnection shall unilaterally terminate all of the defaulting Member's rights with respect to forward Financial Transmission Rights positions as of the date of the Member's default.

b) As to each Financial Transmission Rights position held by the defaulting Member immediately prior to the termination of the defaulting Member's rights under subsection (a) above, the Office of the Interconnection shall determine and execute an appropriate course of action for addressing such Financial Transmission Rights position, based on the specific circumstances of the default as determined by the Office of the Interconnection in exercise of its reasonable judgment, such as (1) liquidating the position by offering it for sale in an upcoming applicable Financial Transmission Rights auction, (2) liquidating the position by offering it for sale in an auction called and scheduled for the specific purpose of liquidating one or more positions held by the defaulting Member ("Special Auction"), (3) allowing the position to go to settlement, or (4) another course of action the Office of the Interconnection determines to be appropriate under the circumstances that is designed to minimize potential losses to PJM Members. The Office of the Interconnection will provide reasonable advance notice to PJM Members of the approach or course of action it has determined to be appropriate prior to implementing that approach or course of action. The Office of the Interconnection is not required to apply a single approach to the defaulting Member's entire Financial Transmission Rights portfolio, and may determine that the appropriate course of action for addressing a defaulting Member's portfolio includes a combination of the above approaches as applied to different positions within the defaulting Member's overall Financial Transmission Rights portfolio.

c) The Office of the Interconnection will seek to minimize the losses to PJM Members associated with settling, liquidating or otherwise resolving the defaulting Member's Financial Transmission Rights portfolio and may base its determination in subsection (b) above on several factors, including but not limited to, the following:

- 1) the Office of the Interconnection's assessment of which approach will provide the greatest degree of protection to the financial integrity of the PJM Markets;
- 2) the size of the defaulting Member's Financial Transmission Rights portfolio, both in absolute terms and relative to overall market volume;
- 3) the term of the Financial Transmission Rights positions held by the defaulting Member as considered for a single position or on a portfolio basis;

- 4) whether liquidation is feasible or not, and on what timeline, due to the cessation or curtailment of trading at PJM for all Financial Transmission Rights or a subset of Financial Transmission Rights positions;
- 5) prevailing market conditions, such as but not limited to market liquidity and volatility; and
- 6) timing of the default and the actions taken to address the default.

d) Special Auctions. The Office of the Interconnection shall administer each Special Auction provided for in subsection (b)(2) above according to the procedures set forth in the Tariff and PJM Manuals for FTR auctions to the extent appropriate in the Office of the Interconnection's sole discretion, and may adopt special rules for each Special Auction to accommodate the unique circumstances underlying the particular default and particular Financial Transmission Rights positions being liquidated, with the terms and conditions of such auction being determined with the goal of facilitating a successful auction in light of the particular positions to be auctioned, the prevailing market conditions for such open positions (including the depth, scope, and nature of participation in such markets), and such other factors as the Office of the Interconnection determines appropriate, including those factors enumerated in subsection (c) above. The Office of the Interconnection shall provide reasonable advance notice to FTR Participants of a Special Auction and the terms and conditions under which it will be conducted.

e) All liquidations made pursuant to subsection (b) above shall be for the account of the defaulting Member (and all amounts owed PJM in respect thereof shall be included in amounts owed by the defaulting Member as part of its default).

f) Notwithstanding subsections 7.3.9(a) and (b) above, the actual net charges or credits resulting from the defaulting Member's Financial Transmission Rights positions for which PJM Settlement acted as counterparty as calculated through the normal settlement processes shall be included in calculating the Default Allocation Assessment charges as described in Operating Agreement, section 15.2.2.

D. FRR Capacity Plans

1. Each FRR Entity shall submit its initial FRR Capacity Plan as required by subsection C.1 of this Schedule, and shall annually extend and update such plan by no later than one month prior to the Base Residual Auction for each succeeding Delivery Year in such plan. Each FRR Capacity Plan shall indicate the nature and current status of each resource, including the status of each Planned Generation Capacity Resource or Planned Demand Resource, the planned deactivation or retirement of any Generation Capacity Resource or Demand Resource, and the status of commitments for each sale or purchase of capacity included in such plan.

1.1 Beginning with the 2020/2021 Delivery Year and for all subsequent Delivery Years, the FRR Capacity Plan shall comprise only Capacity Performance Resources and Seasonal Capacity Performance Resources.

2. The FRR Capacity Plan of each FRR Entity that commits that it will not sell surplus Capacity Resources as a Capacity Market Seller in any auction conducted under Attachment DD of the PJM Tariff, or to any direct or indirect purchaser that uses such resource as the basis of any Sell Offer in such auction, shall designate Capacity Resources in a megawatt quantity no less than the Forecast Pool Requirement for each applicable Delivery Year times the FRR Entity's allocated share of the Preliminary Zonal Peak Load Forecast for such Delivery Year, as determined in accordance with procedures set forth in the PJM Manuals. For the 2016/2017 Delivery Year and prior Delivery Years, the set of Capacity Resources designated in the FRR Capacity Plan must meet the Minimum Annual Resource Requirement and the Minimum Extended Summer Resource Requirement associated with the FRR Entity's capacity obligation. For the 2017/2018 and 2018/2019 Delivery Years, the set of Capacity Resources designated in the FRR Capacity Plan must satisfy the Limited Resource Constraints and the Sub-Annual Resource Constraints applicable to the FRR Entity's capacity obligation. For the 2019/2020 Delivery Year, the set of Capacity Resources designated in the FRR Capacity Plan must satisfy the Base Capacity Resource Constraints and Base Capacity Demand Resource Constraints applicable to the FRR Entity's capacity obligation. If the FRR Entity is not responsible for all load within a Zone, the Preliminary Forecast Peak Load for such entity shall be the FRR Entity's Obligation Peak Load last determined prior to the Base Residual Auction for such Delivery Year, times the Base Zonal FRR Scaling Factor. The FRR Capacity Plan of each FRR Entity that does not commit that it will not sell surplus Capacity Resources as set forth above shall designate Capacity Resources at least equal to the Threshold Quantity. To the extent the FRR Entity's allocated share of the Final Zonal Peak Load Forecast exceeds the FRR Entity's allocated share of the Preliminary Zonal Peak Load Forecast, such FRR Entity's FRR Capacity Plan shall be updated to designate additional Capacity Resources in an amount no less than the Forecast Pool Requirement times such increase; provided, however, any excess megawatts of Capacity Resources included in such FRR Entity's previously designated Threshold Quantity, if any, may be used to satisfy the capacity obligation for such increased load. To the extent the FRR Entity's allocated share of the Final Zonal Peak Load Forecast is less than the FRR Entity's allocated share of the Preliminary Zonal Peak Load Forecast, such FRR Entity's FRR Capacity Plan may be updated to release previously designated Capacity Resources in an amount no greater than the Forecast Pool Requirement times such decrease. Peak load values referenced in this section shall be adjusted as necessary to take into account any applicable Nominal PRD Values approved

pursuant to Schedule 6.1 of this Agreement. Any FRR Entity seeking an adjustment to peak load for Price Responsive Demand must submit a separate PRD Plan in compliance with Section 6.1 (provided that the FRR Entity shall not specify any PRD Reservation Price), and shall register all PRD-eligible load needed to satisfy its PRD commitment and be subject to compliance charges as set forth in that Schedule under the circumstances specified therein; provided that for non-compliance by an FRR Entity, the compliance charge rate shall be equal to 1.20 times the Capacity Resource Clearing Price resulting from all RPM Auctions for such Delivery Year for the LDA encompassing the FRR Entity's Zone, weight-averaged for the Delivery Year based on the prices established and quantities cleared in the RPM auctions for such Delivery Year; and provided further that an alternative PRD Provider may provide PRD in an FRR Service Area by agreement with the FRR Entity responsible for the load in such FRR Service Area, subject to the same terms and conditions as if the FRR Entity had provided the PRD.

3. As to any FRR Entity, the Base Zonal FRR Scaling Factor for each Zone in which it serves load for a Delivery Year shall equal $ZPLDY/ZWNSP$, where:

$ZPLDY$ = Preliminary Zonal Peak Load Forecast for such Zone for such Delivery Year; and

$ZWNSP$ = Zonal Weather-Normalized Summer Peak Load for such Zone for the summer concluding four years prior to the commencement of such Delivery Year.

4. Capacity Resources identified and committed in an FRR Capacity Plan shall meet all requirements under this Agreement, the PJM Tariff, and the PJM Operating Agreement applicable to Capacity Resources, including, as applicable, requirements and milestones for Planned Generation Capacity Resources and Planned Demand Resources. A Capacity Resource submitted in an FRR Capacity Plan must be on a unit-specific basis, and may not include "slice of system" or similar agreements that are not unit specific. An FRR Capacity Plan may include bilateral transactions that commit capacity for less than a full Delivery Year only if the resources included in such plan in the aggregate satisfy all obligations for all Delivery Years. All demand response, load management, energy efficiency, or similar programs on which such FRR Entity intends to rely for a Delivery Year must be included in the FRR Capacity Plan, subject to applicable demand resource constraints for the relevant Delivery Year, submitted three years in advance of such Delivery Year and must satisfy all requirements applicable to Demand Resources or Energy Efficiency Resources, as applicable, including, without limitation, those set forth in Schedule 6 to this Agreement and the PJM Manuals; provided, however, that previously uncommitted Unforced Capacity from such programs may be used to satisfy any increased capacity obligation for such FRR Entity resulting from a Final Zonal Peak Load Forecast applicable to such FRR Entity. Without limiting the generality of the foregoing, the FRR Entity must submit a Demand Resource Sell Offer Plan 15 business days before the deadline for submitting an FRR Capacity Plan as to any Demand Resources it intends to include in such FRR Capacity Plan and may only include in such FRR Capacity Plan Demand Resources that are approved by PJM following review of such Demand Resource Sell Offer Plan. The requirements, standards, and procedures for a Demand Resource Sell Offer Plan shall be as set forth in Schedule 6 of this Agreement, provided that all references (including deadlines) in Schedule 6, section A-1 to submission or clearing of a Demand Resource offer in an RPM Auction shall be understood for purposes of FRR Entities as referring to inclusion of a Demand

Resource in an FRR Capacity Plan, and a distinct Demand Resource Officer Certification Form shall be applicable to FRR Entities, as shown in the PJM Manuals and provided on the PJM website.

5. For each LDA for which the Office of the Interconnection is required to establish a separate Variable Resource Requirement Curve for any Delivery Year addressed by such FRR Capacity Plan, the plan must include a Percentage Internal Resources Required, subject to subsections D.1.1 and D.2 of this Schedule. The Percentage Internal Resources Required will be calculated as the LDA Reliability Requirement less the CETL for the Delivery Year, as determined by the RTEP process as set forth in the PJM Manuals. Such requirement shall be expressed as a percentage of the Unforced Capacity Obligation based on the Preliminary Zonal Peak Load Forecast multiplied by the Forecast Pool Requirement. Notwithstanding the provisions of Sections C.1 and C.2 of this Schedule 8.1, an FRR Entity may terminate its election of the FRR Alternative prior to meeting its minimum five year commitment without penalty for any Delivery Year after the first Delivery Year of its minimum five year FRR commitment for which the Office of the Interconnection will be required to establish a separate Variable Resource Requirement Curve by giving written notice two months prior to the Base Residual Auction for the Delivery Year. The Office of the Interconnection shall be deemed to be required to establish a separate Variable Resource Requirement Curve for an LDA if the LDA is the Eastern Mid-Atlantic Region (“EMAR”), Southwest Mid-Atlantic Region (“SWMAR”), or Mid-Atlantic Region (“MAR”), or for other LDAs if the separate modeling is required by Section 5.10(a)(ii)(A) or (B) of Attachment DD of the Tariff.

6. An FRR Entity may reduce the Percentage Internal Resources Required as to any LDA to the extent the FRR Entity commits to a transmission upgrade that increases the CETL for such LDA. Any such transmission upgrade shall adhere to all requirements for a Qualified Transmission Upgrade as set forth in Attachment DD to the PJM Tariff. The increase in CETL used in the FRR Capacity Plan shall be that approved by PJM prior to inclusion of any such upgrade in an FRR Capacity Plan. The FRR Entity shall designate specific additional Capacity Resources located in the LDA from which the CETL was increased, to the extent of such increase.

7. The Office of the Interconnection will review the adequacy of all submittals hereunder both as to timing and content. A Party that seeks to elect the FRR Alternative that submits an FRR Capacity Plan which, upon review by the Office of the Interconnection, is determined not to satisfy such Party’s capacity obligations hereunder, shall not be permitted to elect the FRR Alternative. If a previously approved FRR Entity submits an FRR Capacity Plan that, upon review by the Office of the Interconnection, is determined not to satisfy such Party’s capacity obligations hereunder, the Office of the Interconnection shall notify the FRR Entity, in writing, of the insufficiency within five (5) business days after the submittal deadline of the FRR Capacity Plan. If the FRR Entity does not cure such insufficiency within five (5) business days after receiving such notice of insufficiency, then such FRR Entity shall be assessed an FRR Commitment Insufficiency Charge, in an amount equal to two times the Cost of New Entry for the relevant location, in \$/MW-day, times the shortfall of Capacity Resources below the FRR

Entity's capacity obligation (including any Threshold Quantity requirement) in such FRR Capacity Plan, for the remaining term of such plan.

8. In a state regulatory jurisdiction that has implemented retail choice, the FRR Entity must include in its FRR Capacity Plan all load, including expected load growth, in the FRR Service Area, notwithstanding the loss of any such load to or among alternative retail LSEs. In the case of load reflected in the FRR Capacity Plan that switches to an alternative retail LSE, where the state regulatory jurisdiction requires switching customers or the LSE to compensate the FRR Entity for its FRR capacity obligations, such state compensation mechanism will prevail. In the absence of a state compensation mechanism, the applicable alternative retail LSE shall compensate the FRR Entity at the capacity price in the unconstrained portions of the PJM Region, as determined in accordance with Attachment DD to the PJM Tariff, provided that the FRR Entity may, at any time, make a filing with FERC under Sections 205 of the Federal Power Act proposing to change the basis for compensation to a method based on the FRR Entity's cost or such other basis shown to be just and reasonable, and a retail LSE may at any time exercise its rights under Section 206 of the FPA.

9. Notwithstanding the foregoing, in lieu of providing the compensation described above, such alternative retail LSE may, for any Delivery Year subsequent to those addressed in the FRR Entity's then-current FRR Capacity Plan, provide to the FRR Entity Capacity Resources sufficient to meet the capacity obligation described in paragraph D.2 for the switched load. Such Capacity Resources shall meet all requirements applicable to Capacity Resources pursuant to this Agreement, the PJM Tariff, and the PJM Operating Agreement, all requirements applicable to resources committed to an FRR Capacity Plan under this Agreement, and shall be committed to service to the switched load under the FRR Capacity Plan of such FRR Entity. The alternative retail LSE shall provide the FRR Entity all information needed to fulfill these requirements and permit the resource to be included in the FRR Capacity Plan. The alternative retail LSE, rather than the FRR Entity, shall be responsible for any performance charges or compliance penalties related to the performance of the resources committed by such LSE to the switched load. For any Delivery Year, or portion thereof, the foregoing obligations apply to the alternative retail LSE serving the load during such time period. PJM shall manage the transfer accounting associated with such compensation and shall administer the collection and payment of amounts pursuant to the compensation mechanism.

Such load shall remain under the FRR Capacity Plan until the effective date of any termination of the FRR Alternative and, for such period, shall not be subject to Locational Reliability Charges under Section 7.2 of this Agreement.

E. Conditions on Purchases and Sales of Capacity Resources by FRR Entities

1. An FRR Entity may not include in its FRR Capacity Plan for any Delivery Year any Capacity Resource MWs that are committed to RPM for such Delivery Year. Nothing herein shall preclude an FRR Entity from including in its FRR Capacity Plan any uncommitted Capacity Resource MWs for such Delivery Year. Furthermore, nothing herein shall preclude an FRR Entity from including in its FRR Capacity Plan a Capacity Resource obtained from a different FRR Entity, provided, however, that each FRR Entity shall be individually responsible for meeting its capacity obligations hereunder, and provided further that the same megawatts of Unforced Capacity shall not be committed to more than one FRR Capacity Plan for any given Delivery Year.

2. An FRR Entity that designates Capacity Resources in its FRR Capacity Plan(s) for a Delivery Year based on the Threshold Quantity may offer to sell Capacity Resources in excess of that needed for the Threshold Quantity in any auction conducted under Tariff, Attachment DD for such Delivery Year, but may not offer to sell Capacity Resources in the auctions for any such Delivery Year in excess of an amount equal to the lesser of (a) 25% times the Unforced Capacity equivalent of the Installed Reserve Margin for such Delivery Year multiplied by the Preliminary Forecast Peak Load for which such FRR Entity is responsible under its FRR Capacity Plan(s) for such Delivery Year, or (b) 1300 MW.

3. An FRR Entity that designates Capacity Resources in its FRR Capacity Plan(s) for a Delivery Year based on the Threshold Quantity may not offer to sell such resources in any Reliability Pricing Model auction, but may use such resources to meet any increased capacity obligation resulting from unanticipated growth of the loads in its FRR Capacity Plan(s), subject to the limitations described in RAA, Schedule 8.1, section D, subsection D.2, or may sell such resources to serve loads located outside the PJM Region, or to another FRR Entity, subject to subsection E.1 above.

4. A Party that has selected the FRR Alternative for only part of its load in the PJM Region pursuant to RAA, Schedule 8.1, section B, subsection B.2 that designates Capacity Resources as Self-Supply in a Reliability Pricing Model Auction to meet such Party's expected Daily Unforced Capacity Obligation under RAA, Schedule 8 shall not be required, solely as a result of such designation, to identify Capacity Resources in its FRR Capacity Plan(s) based on the Threshold Quantity; provided, however, that such Party may not so designate Capacity Resources in an amount in excess of the lesser of (a) 25% times such Party's total expected Unforced Capacity obligation (under both RAA, Schedule 8 and RAA, Schedule 8.1), or (b) 200 MW. A Party that wishes to avoid the foregoing limitation must identify Capacity Resources in its FRR Capacity Plan(s) based on the Threshold Quantity.

Attachment C

GDECS – Chart of Proposed Clean-Ups, Clarifications and Corrections to the PJM Open Access Transmission Tariff, PJM Operating Agreement and PJM Reliability Assurance Agreement

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
1.	Tariff, definition L-M-N	<p>Minimum Run Time</p> <p>For all generating units that are not combined cycle units, “Minimum Run Time” shall mean the minimum number of hours a unit must run, in real-time operations, from the time after generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero, to the time of generator breaker opening, as measured by PJM's State Estimator. For combined cycle units, “Minimum Run Time” shall mean the time period after the first combustion turbine generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero, and the last generator breaker opening as measured by PJM’s State Estimator.</p>	<p>Minimum Run Time</p> <p>For all generating units that are not combined cycle units, “Minimum Run Time” shall mean the minimum number of hours a unit must run, in real-time operations, from the time after generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero, to the time of generator breaker opening, as measured by PJM's State Estimator. For combined cycle units, “Minimum Run Time” shall mean the time period between the first combustion turbine generator breaker closure, which is typically indicated by telemetered or aggregated State Estimator megawatts greater than zero, and to the time of the last generator breaker opening as measured by PJM’s State Estimator.</p>	<p>A literal read of the definition as described for combined cycles would mean Minimum Run Time begins after the last generator breaker opens, which is after the unit stops generating for PJM. As a result, PJM proposes to clarify that for a combined cycle resource, the min run time is measured as the minimum number of hours a unit must run, which is measured between the first generator breaker closure to the time of the last breaker opening.</p>
2.	Tariff, Attachment K – Appendix, section 1.10.1A(j)(i)(3) Operating Agreement, Schedule 1, section 1.10.1A(j)(i)(3)	<p>The expected value of the penalty shall be determined by an annual review of the twelve-month period ending October 31 of the calendar year in which the review is performed. The Office of the Interconnection shall post the results of its annual review by no later than December 15, and the revised offer price cap shall be effective as of the following January 1; provided, however, that at the time of implementation of this rule the expected value of the penalty shall be \$0.02/MWh, and for the period from the second month after implementation through the second January 1 following such date of implementation, the expected value of the penalty shall be recalculated on a monthly basis using data from the implementation date of this rule through the 15th day of the current month, and the revised value shall be effective the 1st day of the following month.</p>	<p>The expected value of the penalty shall be determined by an annual review of the twelve-month period ending October 31 of the calendar year in which the review is performed. The Office of the Interconnection shall post the results of its annual review by no later than December 15, and the revised offer price cap shall be effective as of the following January 1; provided, however, that at the time of implementation of this rule the expected value of the penalty shall be \$0.02/MWh, and for the period from the second month after implementation through the second January 1 December 31 following such date of implementation, the expected value of the penalty shall be recalculated on a monthly basis using data from the implementation date of this rule through the 15th day of the current month, and the</p>	<p>There is a conflict in the existing language that specifies the monthly calculation will be used through January 1, but the yearly calculation should start January 1. This correction would end the monthly calculation on December 31 and allow the yearly calculation to begin January 1, as intended.</p> <p>Because the offer cap penalty was implemented with Reserve Price Formation on 10/01/22, the second December 31 would be 12/31/23.</p>

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
			revised value shall be effective the 1st day of the following month.	
3.	Tariff, Attachment K – Appendix, section 3.2.3A(f)((ii) and Operating Agreement, Schedule 1, section 3.2.3A(f)((ii)	(ii) In determining the credit under subsection (b) to a generation resource, except a generation resource that is operating as a synchronous condenser, selected to provide Synchronized Reserve in the Real-time Synchronized Reserve Market in excess of the resource’s Day-ahead Synchronized Reserve Market assignment and that actively follows the Office of the Interconnection’s signals and instructions, the unit-specific opportunity cost of that generation resource shall be determined for each Real-time Settlement Interval that the Office of the Interconnection requires that generation resource to provide Synchronized Reserve and shall be in accordance with the following equation: (A x B) - C Where: A = The Real-time Locational Marginal Price at the generation bus of the generation resource; B = The deviation of the generation resource’s output necessary to supply Synchronized Reserve in real-time, capped at the amount of Synchronized Reserve the resource responded during a Synchronized Reserve Event during the Operating Day, in excess of its Day-ahead Synchronized Reserve Market assignment and follow the Office of the Interconnection’s signals and instructions from the generation resource’s expected output level if it had been dispatched in economic merit order to provide energy; and	(ii) In determining the credit under subsection (b) to a generation resource, except a generation resource that is operating as a synchronous condenser, selected to provide Synchronized Reserve in the Real-time Synchronized Reserve Market in excess of the resource’s Day-ahead Synchronized Reserve Market assignment and that actively follows the Office of the Interconnection’s signals and instructions, the unit-specific opportunity cost of that generation resource shall be determined for each Real-time Settlement Interval that the Office of the Interconnection requires that generation resource to provide Synchronized Reserve and shall be in accordance with the following equation: (A x B) - C Where: A = The Real-time Locational Marginal Price at the generation bus of the generation resource; B = The deviation of the generation resource’s output necessary to supply Synchronized Reserve in real-time, eapped at reduced by the amount of Synchronized Reserve the resource failed to responded during a Synchronized Reserve Event during the Operating Day, in excess of its Day-ahead Synchronized Reserve Market assignment and follow the Office of the Interconnection’s signals and instructions from the generation resource’s expected output level if it had been dispatched in	Section 3.2.3 (f)(ii) describes the real-time sync reserves opportunity cost calculations. Consistent with the day-of-penalty charge where resources forfeit real-time clearing price revenues for the penalty MW, the under response or penalty MW also reduce the applicable MW when determining real-time opportunity costs during all intervals of the Operating Day. PJM’s Real-time Opportunity Cost language also inadvertently used the capping terminology in the approved Tariff language.

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
		<p>C = The energy offer integrated under the applicable energy offer curve for the generation resource’s output necessary to supply Synchronized Reserve in real-time from the lesser of the generation resource’s output necessary to provide a Day-ahead Synchronized Reserve Market assignment or follow the Office of the Interconnection’s signals and instructions from the generation resource’s expected output level if it had been dispatched in economic merit order to provide energy.</p>	<p>economic merit order to provide energy; and</p> <p>C = The energy offer integrated under the applicable energy offer curve for the generation resource’s output necessary to supply Synchronized Reserve in real-time from the lesser of the generation resource’s output necessary to provide a Day-ahead Synchronized Reserve Market assignment or follow the Office of the Interconnection’s signals and instructions from the generation resource’s expected output level if it had been dispatched in economic merit order to provide energy.</p>	
4.	<p>Tariff, Attachment K – Appendix, section 3.2.3A (f)(iv)</p> <p>Operating Agreement, Schedule 1, section 3.2.3A (f)(iv)</p>	<p>(iv) A Synchronized Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:</p> $(A + B + C + D) - (E + F + G + H)$ <p>Where:</p> <p>A = day-ahead Synchronized Reserve offer price times the Synchronized Reserve MW assignment; B = real-time Synchronized Reserve offer price times the Synchronized Reserve MW assigned in real-time in excess of the Synchronized Reserve MW assigned day-ahead, where the Synchronized Reserve MW assigned is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements of the resource for each Real-time</p>	<p>(iv) A Synchronized Reserve lost opportunity cost credit is determined for each resource for each Real-time Settlement Interval in accordance with the following equation:</p> $(A + B + C + D) - (E + F + G + H)$ <p>Where:</p> <p>A = day-ahead Synchronized Reserve offer price times the Synchronized Reserve MW assignment; B = real-time Synchronized Reserve offer price times the Synchronized Reserve MW assigned in real-time in excess of the Synchronized Reserve MW assigned day-ahead, where the Synchronized Reserve MW assigned is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements of the resource for each</p>	<p>Section 3.2.3 (f)(iv) describes the Lost Opportunity Cost credits paid to resources that follow PJM’s direction to provide reserves and as a result forgo revenues in the energy market. The Lost Opportunity Cost Credit pays a resource for any forgone opportunity costs above any revenues that they received through the reserve market. The Reserve Pricing filing included a change to the Day-of Synchronized Reserve Event Penalty settlements implementation. The change was intended to separately identify the Day-of Penalty as a charge rather than the previous billing practice of reducing the credits paid to a resource. As a</p>

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
		<p>Settlement Interval where there is not a Synchronized Reserve event; C = day-ahead opportunity cost as determined in subsection (f)(i) above; D = real-time opportunity cost as determined in subsection (f)(ii) above; E = day-ahead clearing price credits as determined in subsection (b)(i) above; F = real-time clearing price credits as determined in subsection (b)(ii) above; G = the applicable Market Revenue Neutrality Offset as determined in subsection (f)(iii) above; and H = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A(f)(iii) above if not eligible for Market Revenue Neutrality Offset.</p>	<p>Real-time Settlement Interval where there is not a Synchronized Reserve event; C = day-ahead opportunity cost as determined in subsection (f)(i) above; D = real-time opportunity cost as determined in subsection (f)(ii) above; E = day-ahead clearing price credits as determined in subsection (b)(i) above; F = real-time clearing price credits as determined in subsection (b)(ii) above less any applicable charges for failure to respond to a Synchronized Reserve Event as determined in subsection (j) below; G = the applicable Market Revenue Neutrality Offset as determined in subsection (f)(iii) above; and H = the opportunity cost credit owed due to a reduction in assignment in real-time as described in section 3.2.3A(f)(iii) above if not eligible for Market Revenue Neutrality Offset.</p>	<p>result, a reference to subsection (j) was inadvertently missed in the equation for Lost Opportunity Cost Credits. Item F referencing the real-time clearing price credits should include any offsetting Day-of Penalty charges for failure to respond to a Synchronized Reserve Event during the Operating Day.</p>
5.	Tariff, Attachment K – Appendix, section 3.2.3A(j); Operating Agreement, Schedule 1, section 3.2.3A(j)	(j) In the event a generation resource or Economic Load Response Participant Resource that either has been assigned by the Office of the Interconnection or self-scheduled to provide Synchronized Reserve in real-time fails to provide the assigned or self-scheduled amount of Synchronized Reserve in response to a Synchronized Reserve Event, the resource will be charged at the Real-time Synchronized Reserve Market Clearing Price for the real-time Synchronized Reserve assignment, which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue	(j) In the event a generation resource or Economic Load Response Participant Resource that either has been assigned by the Office of the Interconnection or self-scheduled to provide Synchronized Reserve in real-time fails to provide the assigned or self-scheduled amount of Synchronized Reserve in response to a Synchronized Reserve Event, the resource will be charged at the Real-time Synchronized Reserve Market Clearing Price for the real-time Synchronized Reserve assignment, which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the	Section 3.2.3A(j) describes the day-of penalty charge that is assessed to all intervals in the day where the resource had a sync reserve assignment. The Reserve Pricing Formation changes in Docket ER19-1486 included changes to pay resources for capped real-time assignments. This capping provision limits payments to the lesser of the reserve assignment or the amount of reserves available based on actual real-

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
		Data for Settlements for the resource, in excess of amount that actually responded for all Real-time Settlement Intervals the resource was assigned or self-scheduled Synchronized Reserve real-time on the Operating Day during which the event occurred. The determination of the amount of Synchronized Reserve credited to a resource shall be on an individual resource basis, not on an aggregate basis.	Revenue Data for Settlements for the resource , in excess of amount that actually responded for all Real-time Settlement Intervals the resource was assigned or self-scheduled Synchronized Reserve real-time, which is capped at the lesser of the Economic Maximum and the Synchronized Reserve maximum MW minus the Revenue Data for Settlements for the resource on the Operating Day during which the event occurred. The determination of the amount of Synchronized Reserve credited to a resource shall be on an individual resource basis, not on an aggregate basis.	time MW. The capping language was inadvertently included in the wrong location in paragraph j. As filed, the Tariff language can be interpreted as calculating the shortfall MW by comparing the capped assignment to the response MW. The assignment is not capped when determining the under response or penalty MWs that is assessed to the resource. The assignment should not be capped when determining the under response or Penalty MW that is assessed to the resource. The intent was to charge the resource the RT SRMCP for the under response/penalty MW which can be further limited by the capped assignments in all other intervals of the Operating Day. Transmittal letters for past filings support the intention for the retroactive penalty megawatt and day-of penalty MW calculations to be parallel.
6.	Tariff, Attachment K, Appendix,7.1.2	Subject to Operating Agreement, Schedule 1, section 7.1.1, annual Financial Transmission Rights auctions shall offer the entire FTR capability of the PJM system in four rounds with 25 percent of the capability offered in each round. All four rounds of the annual Financial Transmission Rights	Subject to Operating Agreement, Schedule 1, section 7.1.1, annual Financial Transmission Rights auctions shall offer the entire FTR capability of the PJM system in four rounds with 25 percent of the capability offered in each round. All four rounds of the annual Financial	Correspond to tariff/OA changes regarding extension of the FTR bidding period.

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
	Operating Agreement, Schedule 1, 7.1.2	<p>auction shall occur within the two-month period (April – May) preceding the start of the PJM Planning Period. Each round shall occur over five Business Days and shall be conducted sequentially. Each round shall begin with the bid and offer period. The bid and offer period for annual Financial Transmission Rights auctions shall be open for three consecutive Business Days, opening the first day at 12:00 midnight (Eastern Prevailing Time) and closing the third day at 5:00 p.m. (Eastern Prevailing Time). Monthly Financial Transmission Rights auctions shall be held each month. The bid and offer period for monthly Financial Transmission Rights auctions shall be open for three consecutive Business Days in the month preceding the first month for which Financial Transmission Rights are being auctioned, opening the first day at 12:00 midnight (Eastern Prevailing Time) and closing the third day at 5:00 p.m. (Eastern Prevailing Time).</p>	<p>Transmission Rights auction shall occur within the two-month period (April – May) preceding the start of the PJM Planning Period. Each round shall occur over five Business Days and shall be conducted sequentially. Each round shall begin with the bidding and offer bidding and offer period. The bidding-and-offer bidding and offer period for annual Financial Transmission Rights auctions shall be open for three consecutive Business Days, opening the first day at 12:00 midnight (Eastern Prevailing Time) and closing the third day at 5:00 p.m. (Eastern Prevailing Time), subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e). Monthly Financial Transmission Rights auctions shall be held each month. The bidding and offer bidding and offer period for monthly Financial Transmission Rights auctions shall be open for three consecutive Business Days in the month preceding the first month for which Financial Transmission Rights are being auctioned, opening the first day at 12:00 midnight (Eastern Prevailing Time) and closing the third day at 5:00 p.m. (Eastern Prevailing Time), subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e).</p>	
7.	Tariff, Attachment K, Appendix, 7.1A.2 Operating Agreement, Schedule 1,	<p>The long-term Financial Transmission Rights auction process shall consist of five rounds. The first round shall be conducted by the Office of the Interconnection approximately 11 months prior to the start of the three Planning Period term covered by the relevant long-term Financial Transmission Rights auction. The second round shall be conducted</p>	<p>The long-term Financial Transmission Rights auction process shall consist of five rounds. The first round shall be conducted by the Office of the Interconnection approximately 11 months prior to the start of the three Planning Period term covered by the relevant long-term Financial Transmission Rights auction. The second</p>	<p>Correspond to tariff/OA changes regarding extension of the FTR bidding period.</p>

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
	7.1A.2	<p>approximately 2 months after the first round. The third round shall be conducted approximately 2 months after the second round. The fourth round shall be conducted approximately 2 months after the third round, and the fifth round shall be conducted approximately 3 months after the fourth round. In each round 20 percent of total capacity available in the long-term Financial Transmission Rights auction shall be offered for sale. Eligible entities may submit bids to purchase and offers to sell Financial Transmission Rights at the start of the bidding period in each round. The bidding period shall be three Business Days ending at 5:00 p.m. on the last day. PJM performs the Financial Transmission Rights auction clearing analysis for each round and posts the auction results on the market user interface within five Business Days after the close of the bidding period for each round unless circumstances beyond PJM's control prevent PJM from meeting the applicable deadline. Under such circumstances, PJM will post the auction results at the earliest possible opportunity. If the Office of the Interconnection discovers a potential error in the results posted for a long-term Financial Transmission Rights auction, the Office of the Interconnection shall notify Market Participants as soon as possible after it is found, but in no event later than 5:00 p.m. of the Business Day immediately following the initial publication of the results for that auction. After this initial notification, if the Office of the Interconnection</p>	<p>round shall be conducted approximately 2 months after the first round. The third round shall be conducted approximately 2 months after the second round. The fourth round shall be conducted approximately 2 months after the third round, and the fifth round shall be conducted approximately 3 months after the fourth round. In each round 20 percent of total capacity available in the long-term Financial Transmission Rights auction shall be offered for sale. Eligible entities may submit bids to purchase and offers to sell Financial Transmission Rights at the start of the bidding period in each round. The bidding period shall be three Business Days ending at 5:00 p.m. on the last day, subject to extension of the bidding period in accordance with Tariff, Attachment K-Appendix, section 7.3.5(e). PJM performs the Financial Transmission Rights auction clearing analysis for each round and posts the auction results on the market user interface within five Business Days after the close of the bidding period for each round unless circumstances beyond PJM's control prevent PJM from meeting the applicable deadline. Under such circumstances, PJM will post the auction results at the earliest possible opportunity. If the Office of the Interconnection discovers a potential error in the results posted for a long-term Financial</p>	

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
		<p>determines it is necessary to post modified auction results, it shall provide notification of its intent to do so, along with a description detailing the cause and scope of the error, by no later than 5:00 p.m. of the second Business Day following the initial publication of prices for that auction. The provided description will not contain information that is market sensitive or confidential. Thereafter, the Office of the Interconnection must post the corrected prices by no later than 5:00 p.m. of the fourth calendar day following the initial publication of prices in the auction. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced auction results are under publicly noticed review by the FERC.</p>	<p>later than 5:00 p.m. of the Business Day immediately following the initial publication of the results for that auction. After this initial notification, if the Office of the Interconnection determines it is necessary to post modified auction results, it shall provide notification of its intent to do so, along with a description detailing the cause and scope of the error, by no later than 5:00 p.m. of the second Business Day following the initial publication of prices for that auction. The provided description will not contain information that is market sensitive or confidential. Thereafter, the Office of the Interconnection must post the corrected prices by no later than 5:00 p.m. of the fourth calendar day following the initial publication of prices in the auction. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced auction results are under publicly noticed review by the FERC.</p>	
8.	Tariff, Attachment K, Appendix 7.3.5 Operating Agreement,	(d) Bids and offers shall be specified to the nearest tenth of a megawatt and shall be greater than zero. The Office of the Interconnection may require that a market participant shall not submit in excess of 5000 bids and offers for any single monthly auction, or for any single round of the annual auction, when the Office of the Interconnection determines	(d) Bids and offers shall be specified to the nearest tenth of a megawatt and shall be greater than zero. The Office of the Interconnection may require that a market participant shall not submit in excess of 5000 bids and offers for any single monthly auction, or for any single round of the annual auction, when the Office of the	Addition of language to provide for notice to Members in the event the bidding period is extended for an unforeseen circumstance such as a software malfunction. This language permits the submission of bids to

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
	Schedule 1, Section 7.3.5	that such limit is required to avoid or mitigate significant system performance problems related to bid/offer volume. Notice of the need to impose such limit shall be provided prior to the start of the bidding period if possible. Where such notice is provided after the start of the bidding period, market participants shall be required within one day to reduce their bids and offers for such auction below 5000, and the bidding period in such cases shall be extended by one day.	<p>Interconnection determines that such limit is required to avoid or mitigate significant system performance problems related to bid/offer volume. Notice of the need to impose such limit shall be provided prior to the start of the bidding period if possible. Where such notice is provided after the start of the bidding period, market participants shall be required within one day to reduce their bids and offers for such auction below 5000, and the bidding period in such cases shall be extended by one day.</p> <p>(e) In the event of extraordinary circumstances affecting the submission of bids within the bidding period in which the Office of the Interconnection determines it necessary to extend the bidding period, the Office of the Interconnection shall notify Market Participants as soon as possible of the new bidding period ending day and time.</p>	continue with notice to Members to accommodate an orderly bidding process.
9.	Tariff, Attachment K, Appendix 7.3.7 Operating Agreement, Schedule 1, Section 7.3.7	Within two (2) Business Days after the close of the bid and offer period for an annual Financial Transmission Rights auction round, and within five (5) Business Days after the close of the bid and offer period for a monthly Financial Transmission Rights auction, the Office of the Interconnection shall post the winning bidders, the megawatt quantity, the term and the receipt and delivery points for each Financial Transmission Right awarded in the auction and the price at which each Financial Transmission Right was awarded unless circumstances beyond PJM's control prevent PJM from meeting the applicable deadline. Under such circumstances, PJM will post the	Within two (2) Business Days after the close of the bidding-and-offer period for an annual Financial Transmission Rights auction round, and within five (5) Business Days after the close of the bidding-and-offer period for a monthly Financial Transmission Rights auction, the Office of the Interconnection shall post the winning bidders, the megawatt quantity, the term and the receipt and delivery points for each Financial Transmission Right awarded in the auction and the price at which each Financial Transmission Right was awarded unless circumstances beyond PJM's control prevent PJM from meeting the applicable deadline. Under such	Correspond to tariff/OA changes regarding extension of the FTR bidding period.

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
		<p>auction results at the earliest possible opportunity. The Office of the Interconnection shall not disclose the price specified in any bid to purchase or the reservation price specified in any offer to sell. If the Office of the Interconnection discovers an error in the results posted for a Financial Transmission Rights auction (or a given round of the annual Financial Transmission Rights auction), the Office of the Interconnection shall notify Market Participants of the error as soon as possible after it is found, but in no event later than 5:00 p.m. of the Business Day following the initial publication of the results of the auction or round of the annual auction. After this initial notification, if the Office of the Interconnection determines that it is necessary to post modified results, it shall provide notification of its intent to do so, together with all available supporting documentation, by no later than 5:00 p.m. of the second Business Day following the initial publication of the results of that auction or round of the annual auction. Thereafter, the Office of the Interconnection must post any corrected results by no later than 5:00 p.m. of the fourth calendar day following the initial publication of the results of the auction or round of the annual auction. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced auction results are under publicly noticed review by the FERC.</p>	<p>circumstances, PJM will post the auction results at the earliest possible opportunity. The Office of the Interconnection shall not disclose the price specified in any bid to purchase or the reservation price specified in any offer to sell. If the Office of the Interconnection discovers an error in the results posted for a Financial Transmission Rights auction (or a given round of the annual Financial Transmission Rights auction), the Office of the Interconnection shall notify Market Participants of the error as soon as possible after it is found, but in no event later than 5:00 p.m. of the Business Day following the initial publication of the results of the auction or round of the annual auction. After this initial notification, if the Office of the Interconnection determines that it is necessary to post modified results, it shall provide notification of its intent to do so, together with all available supporting documentation, by no later than 5:00 p.m. of the second Business Day following the initial publication of the results of that auction or round of the annual auction. Thereafter, the Office of the Interconnection must post any corrected results by no later than 5:00 p.m. of the fourth calendar day following the initial publication of the results of the auction or round of the annual auction. Should any of the above deadlines pass without the associated action on the part of the Office of the Interconnection, the originally posted results will be considered final. Notwithstanding the foregoing, the deadlines set forth above shall not apply if the referenced auction results are under publicly noticed review by the FERC.</p>	

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
10.	Tariff, Attachment Q, section VI.C.2.	(e) Realized Gains and/or Losses Any realized gains and/or losses resulting from the sale of Financial Transmission Right Obligations will be subtracted from the FTR Credit Requirement. A realized gain will decrease the FTR Credit Requirement (but not below \$0.00), whereas a realized loss will increase the FTR Credit Requirement.	(e) Realized Gains and/or Losses Any realized gains and/or losses resulting from the sale settlement of Financial Transmission Right Obligations that have not been paid out will be subtracted from the FTR Credit Requirement. A realized gain will decrease the FTR Credit Requirement (but not below \$0.00), whereas a realized loss will increase the FTR Credit Requirement.	In Docket ER22-2029-000 FERC approved PJM’s Revised FTR Credit Requirement. This change clarifies the FTR Credit Requirement to reflect that activity resulting from settled FTR activity will be included as part of realized gains and losses.
11.	Tariff, Attachment DD, section 6.4	(a)The Market Seller Offer Cap, stated in dollars per MW/day of unforced capacity, applicable to price-quantity offers within the Base Offer Segment for an Existing Generation Capacity Resource shall be the Avoidable Cost Rate for such resource, less the Projected PJM Market Revenues for such resource, stated in dollars per MW/day of unforced capacity. A Capacity Market Seller offering above \$0/MW-day must support and obtain approval of a unit-specific Market Seller Offer Cap pursuant to the procedures and standards of subsection (b) of this section 6.4 or may, at its election, if available, utilize a Market Seller Offer Cap determined using the applicable default gross Avoidable Cost Rate for the applicable resource type shown in the table below, as adjusted for Delivery Years subsequent to the 2022/2023 Delivery Year to reflect changes in avoidable costs, net of projected PJM market revenues equal to the resource’s net energy and ancillary service revenues for the resource type, as determined in accordance with Tariff, Attachment DD, section 6.8(d-1).	(a)The Market Seller Offer Cap, stated in dollars per MW/day of unforced capacity, applicable to price-quantity offers within the Base Offer Segment for an Existing Generation Capacity Resource shall be the Avoidable Cost Rate for such resource, less the Projected PJM Market Revenues for such resource, stated in dollars per MW/day of unforced capacity. A Capacity Market Seller offering above \$0/MW-day must support and obtain approval of a unit-specific Market Seller Offer Cap pursuant to the procedures and standards of subsection (b) of this section 6.4 or may, at its election, if available, utilize a Market Seller Offer Cap determined using the applicable default gross Avoidable Cost Rate for the applicable resource type shown in the table below, as adjusted for Delivery Years subsequent to the 2022/2023 Delivery Year to reflect changes in avoidable costs, net of P rojected PJM M arket R evenues equal to the resource’s net energy and ancillary service revenues for the resource type, as determined in accordance with Tariff, Attachment DD, section 6.8(d- 1).	Correct reference to 6.8(d), which applies to EAS methodology for the 23/24 DY and subsequent DYs. Current reference to 6.8(d-1) only applies to the 22/23 DY. Capitalize defined term for “Projected PJM Market Revenue”

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
		<p>(b)For each Existing Generation Capacity Resource, a potential Capacity Market Seller must provide to the Market Monitoring Unit and the Office of the Interconnection data and documentation required under section 6.7 below to establish the level of the Market Seller Offer Cap applicable to each resource by no later than one hundred twenty (120) days prior to the commencement of the offer period for the applicable RPM Auction. The Capacity Market Seller must promptly address any concerns identified by the Market Monitoring Unit regarding the data and documentation provided, review the Market Seller Offer Cap proposed by the Market Monitoring Unit, and attempt to reach agreement with the Market Monitoring Unit on the level of the Market Seller Offer Cap by no later than ninety (90) days prior to the commencement of the offer period for the applicable RPM Auction. The Capacity Market Seller shall notify the Market Monitoring Unit in writing, with a copy to the Office of the Interconnection, whether an agreement with the Market Monitoring Unit has been reached or, if no agreement has been reached, specifying the level of Market Seller Offer Cap to which it commits by no later than eighty (80) days prior to the commencement of the offer period for the applicable RPM Auction. The Office of the Interconnection shall review the data submitted by the Capacity Market Seller, make a determination whether to accept or reject the requested unit-specific Market Seller Offer Cap, and notify the Capacity Market Seller and the Market Monitoring Unit of its determination in writing, by no later than sixty-five (65) days prior to the</p>	<p>...</p> <p>(b)For each Existing Generation Capacity Resource, a potential Capacity Market Seller must provide to the Market Monitoring Unit and the Office of the Interconnection data and documentation required under section 6.7 below to establish the level of the Market Seller Offer Cap applicable to each resource by no later than one hundred twenty (120) days prior to the commencement of the offer period for the applicable RPM Auction. The Capacity Market Seller must promptly address any concerns identified by the Market Monitoring Unit regarding the data and documentation provided, review the Market Seller Offer Cap proposed by the Market Monitoring Unit, and attempt to reach agreement with the Market Monitoring Unit on the level of the Market Seller Offer Cap by no later than ninety (90) days prior to the commencement of the offer period for the applicable RPM Auction. The Capacity Market Seller shall notify the Market Monitoring Unit in writing, with a copy to the Office of the Interconnection, whether an agreement with the Market Monitoring Unit has been reached or, if no agreement has been reached, specifying the level of Market Seller Offer Cap to which it commits by no later than eighty (80) days prior to the commencement of the offer period for the applicable RPM Auction. The Office of the Interconnection shall review the data submitted by the Capacity Market Seller, make a determination whether to accept or reject the</p>	

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
		<p>commencement of the offer period for the applicable RPM Auction. In the event the Office of the Interconnection rejects the Capacity Market Seller's requested unit-specific Market Seller Offer Cap for a particular Capacity Resource, the Capacity Market Seller of such Capacity Resource may submit an offer up to (1) should one exist, the default gross Avoidable Cost Rate for the applicable resource type net of projected PJM market revenues equal to the resource's net energy and ancillary service revenues for the resource type, or (2) the unit-specific Market Seller Offer Cap proposed by the Market Monitoring Unit upon PJM approval of such value. If the Market Monitoring Unit does not provide its determination to the Capacity Market Seller and the Office of the Interconnection by the specified deadline, by no later than sixty-five (65) days prior to the commencement of the offer period for the applicable RPM Auction the Office of the Interconnection will make the determination of the level of the Market Seller Offer Cap, which shall be deemed to be final. If the Capacity Market Seller does not notify the Market Monitoring Unit and the Office of the Interconnection of the Market Seller Offer Cap it desires to utilize by no later than eighty (80) days prior to the commencement of the offer period for the applicable RPM Auction, it shall be required to utilize a Market Seller Offer Cap determined using the applicable default Avoidable Cost Rate specified in section 6.4(a) above.</p>	<p>requested unit-specific Market Seller Offer Cap, and notify the Capacity Market Seller and the Market Monitoring Unit of its determination in writing, by no later than sixty-five (65) days prior to the commencement of the offer period for the applicable RPM Auction. In the event the Office of the Interconnection rejects the Capacity Market Seller's requested unit-specific Market Seller Offer Cap for a particular Capacity Resource, the Capacity Market Seller of such Capacity Resource may submit an offer up to (1) should one exist, the default gross Avoidable Cost Rate for the applicable resource type net of Pprojected PJM Mmarket Revenues equal to the resource's net energy and ancillary service revenues for the resource type, or (2) the unit-specific Market Seller Offer Cap proposed by the Market Monitoring Unit upon PJM approval of such value. If the Market Monitoring Unit does not provide its determination to the Capacity Market Seller and the Office of the Interconnection by the specified deadline, by no later than sixty-five (65) days prior to the commencement of the offer period for the applicable RPM Auction the Office of the Interconnection will make the determination of the level of the Market Seller Offer Cap, which shall be deemed to be final. If the Capacity Market Seller does not notify the Market Monitoring Unit and the Office of the Interconnection of the Market Seller Offer Cap it desires to utilize by no later than eighty (80) days prior to the commencement of the offer period for the applicable RPM Auction, it shall be required to utilize a Market Seller Offer Cap determined using the applicable</p>	

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
			default Avoidable Cost Rate specified in section 6.4(a) above.	
12.	Tariff, Attachment DD, section 6.5(a)	Notwithstanding the foregoing, any Capacity Market Seller, together with Affiliates, whose Sell Offers based on Planned Generation Capacity Resources in that modeled LDA are pivotal, shall be subject to mitigation.	Notwithstanding the foregoing, any Capacity Market Seller, together with A affiliates, whose Sell Offers based on Planned Generation Capacity Resources in that modeled LDA are pivotal, shall be subject to mitigation.	The use of the defined “Affiliate” term may be inconsistent with affiliate tests used for other market mitigation purposes. For instance, the Three Pivotal Supplier Test used for regulation market uses the lower case “affiliate” term. See OA, Schedule 1, Section 3.2.2A(ii). Likewise, for energy market offer capping, the term “affiliate” is used for purposes of the three pivotal supplier test.
13.	Tariff, Attachment DD, section 6.6(g)	In order to obtain an exception to the RPM must-offer requirement for the reason specified in Paragraph A above, a Capacity Market Seller shall first submit a preliminary exception request in writing, along with supporting data and documentation indicating the reasons and conditions upon which the Capacity Market Seller is relying in its analysis of whether to retire such resource, to the Market Monitoring Unit for evaluation, notifying the Office of the Interconnection by copy of the same, by no later than (a) November 1, 2013 for the Base Residual Auction for the 2017/2018 Delivery Year, (b) the September 1 that last precedes the Base Residual Auction for the 2018/2019 and subsequent Delivery Years, and (c) two hundred forty (240) days prior to the commencement of the offer period for the applicable Incremental Auction. By no later than five (5) Business Days after receipt of any such preliminary	In order to obtain an exception to the RPM must-offer requirement for the reason specified in Paragraph A above, a Capacity Market Seller shall first submit a preliminary exception request in writing, along with supporting data and documentation indicating the reasons and conditions upon which the Capacity Market Seller is relying in its analysis of whether to retire such resource, to the Market Monitoring Unit for evaluation, notifying the Office of the Interconnection by copy of the same, by no later than (a) November 1, 2013 for the Base Residual Auction for the 2017/2018 Delivery Year, (b) the September 1 that last precedes the Base Residual Auction for the 2018/2019 and subsequent Delivery Years, and (c) two hundred forty (240) days prior to the commencement of the offer period for the applicable Incremental Auction. By no later than five (5) Business Days after the	This revision updates the deadline from 5 days after the seller notification of exception request or removal of Capacity Resource status to 5 days after the notification deadline. This update is appropriate given that a Seller can rescind their notification prior to the deadline and therefore PJM does not know until the actual deadline what to post. Further, it is confusing to constantly update posting after each notification is received instead of simply posting all together at one point in time.

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
		<p>exception requests, the Office of the Interconnection will post on its website a summary of the number of megawatts of Generation Capacity Resources for which it has received notification of preliminary exception requests, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.</p> <p>Thereafter, as applicable, such Capacity Market Seller shall by no later than (a) the December 1 that last precedes the Base Residual Auction for the applicable Delivery Year, or (b) one hundred twenty (120) days prior to the commencement of the offer period for the applicable Incremental Auction, either (a) notify the Office of the Interconnection and the Market Monitoring Unit in writing that it is withdrawing its preliminary exception request and explaining the changes to its analysis of whether to retire such resource that support its decision to withdraw, or (b) demonstrate that it has met the requirements specified under Paragraph A above. By no later than five (5) Business Days after receipt of such notification, the Office of the Interconnection will post on its website a revised summary of the number of megawatts of Generation Capacity Resources for which it has received requests for exceptions to the RPM must-offer requirement for the reason specified in Paragraph A above, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.</p>	<p>notification deadline receipt of for any such preliminary exception requests, the Office of the Interconnection will post on its website a summary of the number of megawatts of Generation Capacity Resources for which it has received notification of preliminary exception requests, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.</p> <p>Thereafter, as applicable, such Capacity Market Seller shall by no later than (a) the December 1 that last precedes the Base Residual Auction for the applicable Delivery Year, or (b) one hundred twenty (120) days prior to the commencement of the offer period for the applicable Incremental Auction, either (a) notify the Office of the Interconnection and the Market Monitoring Unit in writing that it is withdrawing its preliminary exception request and explaining the changes to its analysis of whether to retire such resource that support its decision to withdraw, or (b) demonstrate that it has met the requirements specified under Paragraph A above. By no later than five (5) Business Days after receipt <u>the notification deadline for</u> such notification, the Office of the Interconnection will post on its website a revised summary of the number of megawatts of Generation Capacity Resources for which it has received requests for exceptions to the RPM must-offer requirement for the reason specified in Paragraph A above, on an aggregate basis by Zone and Locational</p>	

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
		<p>A Capacity Market Seller that seeks to remove a Generation Capacity Resource from Capacity Resource status shall first submit a preliminary request in writing, along with supporting data and documentation indicating the reasons and conditions upon which the Capacity Market Seller is relying in its analysis of whether to remove the Capacity Resource status of such resource to the Market Monitoring Unit for evaluation, notifying the Office of the Interconnection by copy of the same, by no later than (a) the September 1 that last precedes the Base Residual Auction, and (b) two hundred forty (240) days prior to the commencement of the offer period for the applicable Incremental Auction. For the Base Residual Auction for the 2023/2024 Delivery Year, a Capacity Market Seller that seeks to remove a Generation Capacity Resource from Capacity Resource status shall first submit such preliminary request by no later than November 1, 2019. By no later than five (5) Business Days after receipt of any such preliminary requests, the Office of the Interconnection will post on its website a summary of the number of megawatts of Generation Capacity Resources for which it has received notification of preliminary requests, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.</p> <p>Thereafter, as applicable, such Capacity Market Seller shall, by no later than (a) the December 1 that last precedes the Base Residual Auction for the</p>	<p>Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals.</p> <p>A Capacity Market Seller that seeks to remove a Generation Capacity Resource from Capacity Resource status shall first submit a preliminary request in writing, along with supporting data and documentation indicating the reasons and conditions upon which the Capacity Market Seller is relying in its analysis of whether to remove the Capacity Resource status of such resource to the Market Monitoring Unit for evaluation, notifying the Office of the Interconnection by copy of the same, by no later than (a) the September 1 that last precedes the Base Residual Auction, and (b) two hundred forty (240) days prior to the commencement of the offer period for the applicable Incremental Auction. For the Base Residual Auction for the 2023/2024 Delivery Year, a Capacity Market Seller that seeks to remove a Generation Capacity Resource from Capacity Resource status shall first submit such preliminary request by no later than November 1, 2019. By no later than five (5) Business Days after receipt <u>the notification deadline</u> for of any such preliminary requests, the Office of the Interconnection will post on its website a summary of the number of megawatts of Generation Capacity Resources for which it has received notification of preliminary requests, on an aggregate basis by Zone and Locational Deliverability Area that</p>	

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
		<p>applicable Delivery Year, or (b) one hundred twenty (120) days prior to the commencement of the offer period for the applicable Incremental Auction, notify the Office of the Interconnection and the Market Monitoring Unit in writing that it is either (a) withdrawing its preliminary request and explaining the changes to its analysis that support its decision to withdraw, or (b) confirming its preliminary decision to remove the Generation Capacity Resource from Capacity Resource status. By no later than five (5) Business Days after receipt of such notification, the Office of the Interconnection will post on its website a revised summary of the number of megawatts of Generation Capacity Resources for which it has received requests to remove its Capacity Resource status, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals</p>	<p>comprises a subset of a Zone, as specified in the PJM Manuals.</p> <p>Thereafter, as applicable, such Capacity Market Seller shall, by no later than (a) the December 1 that last precedes the Base Residual Auction for the applicable Delivery Year, or (b) one hundred twenty (120) days prior to the commencement of the offer period for the applicable Incremental Auction, notify the Office of the Interconnection and the Market Monitoring Unit in writing that it is either (a) withdrawing its preliminary request and explaining the changes to its analysis that support its decision to withdraw, or (b) confirming its preliminary decision to remove the Generation Capacity Resource from Capacity Resource status. By no later than five (5) Business Days after receipt <u>the notification deadline for</u> such notification, the Office of the Interconnection will post on its website a revised summary of the number of megawatts of Generation Capacity Resources for which it has received requests to remove its Capacity Resource status, on an aggregate basis by Zone and Locational Deliverability Area that comprises a subset of a Zone, as specified in the PJM Manuals</p>	
14.	OA, definitions C-D.	<p>“Catastrophic Force Majeure” shall not include any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, or Curtailment, order, regulation or restriction imposed by</p>	<p>“Catastrophic Force Majeure” shall not include any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, or Curtailment, order, regulation or restriction imposed by</p>	<p>As used here, the term “curtailment” refers to actions imposed by governmental, military or lawfully established civilian authorities. The use</p>

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
		governmental, military or lawfully established civilian authorities, unless as a consequence of any such action, event, or combination of events, either (i) all, or substantially all, of the Transmission System is unavailable, or (ii) all, or substantially all, of the interstate natural gas pipeline network, interstate rail, interstate highway or federal waterway transportation network serving the PJM Region is unavailable. The Office of the Interconnection shall determine whether an event of Catastrophic Force Majeure has occurred for purposes of this Agreement, the PJM Tariff, and the Reliability Assurance Agreement, based on an examination of available evidence. The Office of the Interconnection’s determination is subject to review by the Commission.	governmental, military or lawfully established civilian authorities, unless as a consequence of any such action, event, or combination of events, either (i) all, or substantially all, of the Transmission System is unavailable, or (ii) all, or substantially all, of the interstate natural gas pipeline network, interstate rail, interstate highway or federal waterway transportation network serving the PJM Region is unavailable. The Office of the Interconnection shall determine whether an event of Catastrophic Force Majeure has occurred for purposes of this Agreement, the PJM Tariff, and the Reliability Assurance Agreement, based on an examination of available evidence. The Office of the Interconnection’s determination is subject to review by the Commission	of a defined term “Curtailment” is inappropriate as such action is limited to “reduction in firm or non-firm transmission service in response to a transfer capability shortage as a result of system reliability conditions.”
15.	Operating Agreement Section 14B.2.	Late Payment Charges that are collected pursuant to this Section 7.1A(f) shall be credited to PJMSettlement administrative costs and will be included in any applicable stated rate refund calculations as contemplated under Schedule 9 of this Tariff	Late Payment Charges that are collected pursuant to this Section 7.1A(f) shall be credited to PJMSettlement administrative costs and will be included in any applicable stated rate refund calculations as contemplated under Schedule 9 of this Tariff	FERC accepted PJM compliance filing in its administrative rate case in Docket ER22-26-003. PJM has changed from stated rate to formula rate
16.	RAA, Schedule 8.1.D	7. The Office of the Interconnection will review the adequacy of all submittals hereunder both as to timing and content. A Party that seeks to elect the FRR Alternative that submits an FRR Capacity Plan which, upon review by the Office of the Interconnection, is determined not to satisfy such Party's capacity obligations hereunder, shall not be permitted to elect the FRR Alternative. If a previously approved FRR Entity submits an FRR Capacity Plan that, upon review by the Office of the Interconnection, is determined not to satisfy such Party's capacity obligations	7. The Office of the Interconnection will review the adequacy of all submittals hereunder both as to timing and content. A Party that seeks to elect the FRR Alternative that submits an FRR Capacity Plan which, upon review by the Office of the Interconnection, is determined not to satisfy such Party's capacity obligations hereunder, shall not be permitted to elect the FRR Alternative. If a previously approved FRR Entity submits an FRR Capacity Plan that, upon review by the Office of the Interconnection, is determined not to satisfy such	Because FRR entities can adjust and resend a new plan up until the deadline, it is not practical for PJM to provide its determination within 5 days after the plan is submitted. Instead, this should be within 5 business days after the FRR Capacity Plan deadline, which is 30 days before the BRA. Market Sellers continue to have 5 business days to cure any insufficiency after

	Governing Document, Agreement, Attachment, Section, Title	Current Language	Proposed Revisions	Rationale/Notes
		<p>hereunder, the Office of the Interconnection shall notify the FRR Entity, in writing, of the insufficiency within five (5) business days of the submittal of the FRR Capacity Plan. If the FRR Entity does not cure such insufficiency within five (5) business days after receiving such notice of insufficiency, then such FRR Entity shall be assessed an FRR Commitment Insufficiency Charge, in an amount equal to two times the Cost of New Entry for the relevant location, in \$/MW-day, times the shortfall of Capacity Resources below the FRR Entity's capacity obligation (including any Threshold Quantity requirement) in such FRR Capacity Plan, for the remaining term of such plan.</p>	<p>Party's capacity obligations hereunder, the Office of the Interconnection shall notify the FRR Entity, in writing, of the insufficiency within five (5) business days after of the submittal deadline of the FRR Capacity Plan. If the FRR Entity does not cure such insufficiency within five (5) business days after receiving such notice of insufficiency, then such FRR Entity shall be assessed an FRR Commitment Insufficiency Charge, in an amount equal to two times the Cost of New Entry for the relevant location, in \$/MW-day, times the shortfall of Capacity Resources below the FRR Entity's capacity obligation (including any Threshold Quantity requirement) in such FRR Capacity Plan, for the remaining term of such plan.</p>	<p>receiving notice.</p>
17.	RAA, Schedule 8.1.E	<p>1. An FRR Entity may not include in its FRR Capacity Plan for any Delivery Year any Capacity Resource that has a capacity commitment cleared in any auction under Tariff, Attachment DD for such Delivery Year. Nothing herein shall preclude an FRR Entity from including in its FRR Capacity Plan any Capacity Resource that has not cleared such an auction for such Delivery Year. Furthermore, nothing herein shall preclude an FRR Entity from including in its FRR Capacity Plan a Capacity Resource obtained from a different FRR Entity, provided, however, that each FRR Entity shall be individually responsible for meeting its capacity obligations hereunder, and provided further that the same megawatts of Unforced Capacity shall not be committed to more than one FRR Capacity Plan for any given Delivery Year.</p>	<p>1. An FRR Entity may not include in its FRR Capacity Plan for any Delivery Year any Capacity Resource MWs that are committed to RPM has a capacity commitment cleared in any auction under Tariff, Attachment DD for such Delivery Year. Nothing herein shall preclude an FRR Entity from including in its FRR Capacity Plan any uncommitted Capacity Resource MWs that has not cleared such an auction for such Delivery Year. Furthermore, nothing herein shall preclude an FRR Entity from including in its FRR Capacity Plan a Capacity Resource obtained from a different FRR Entity, provided, however, that each FRR Entity shall be individually responsible for meeting its capacity obligations hereunder, and provided further that the same megawatts of Unforced Capacity shall not be committed to more than one FRR Capacity Plan for any given Delivery Year.</p>	<p>Clarifies that only RPM committed MW cannot be included in the capacity plan. If a MW cleared, but then is later available (through replacement etc), it can still be used in a capacity plan</p>