



VIA DocuSign

September 1, 2017

**Daniel Wang
sPower Development Company, LLC
201 Mission St., Suite 540
San Francisco, CA 94133**

Dear Daniel:

Re: AC2-031 – Hillsboro 138 kV - Feasibility Study Report

Attached is a report documenting the results of the **AC2-031** Feasibility Study. The intent of the Feasibility Study is to determine a plan, with preliminary cost estimates to connect the subject project to the PJM network at a location specified by the Interconnection Customer. The results of this Feasibility Study are predicated on a year **2020** transmission system based upon PJM's best assumptions at the present time for load growth and connection of proposed new generation additions. The project was evaluated for system normal conditions and single contingency outage conditions.

Feasibility Studies are performed to provide an Interconnection Customer with preliminarily estimated reinforcement costs and information concerning both direct connection facilities and potential transmission network upgrades. Since the analysis inherently has to include assumptions for future system conditions, the results should be used in this context. More comprehensive estimates will be developed upon execution of a System Impact Study Agreement in accordance with Part VI of the PJM Tariff.

As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Attachment Facilities, which are new facilities and/or facilities upgrades needed to connect the project to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. In some instances a project may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g., another interconnection project, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the System Impact Study is performed.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. Note that Tariff §212.5 milestones require that you have all site permits, water and fuel agreements and associated right of way, and a memorandum of understanding for major equipment at the time you return your executed Interconnection Service Agreement (ISA). It is your responsibility to ensure these requirements are met and if they cannot be met at the time of the return of the

ISA, you must demonstrate your due diligence and propose dates when those milestones will be met.

In addition, the Feasibility Study estimates do not include any the costs associated with engineering and constructing the equipment and facilities on the developer's side of the point of interconnection. These costs are the responsibility of the project developer.

Pursuant to Section 204.3 of the PJM Tariff, enclosed is a copy of a System Impact Study Agreement for your consideration. The necessary deposit and executed agreement must be in the possession of PJM within thirty days (**by close of business on October 2, 2017**) to maintain the project's position in the queue. In addition, your project's electrical data sheet must be completed and submitted electronically by the above date for the Impact Study Agreement to be considered complete. The data sheet is located here: <http://www.pjm.com/planning/rtep-development/expansion-plan-process/form-impact-study-data.aspx>. Failure to submit this data by the due date will result in the withdrawal of your project. Required with the signed agreement, per Section 3 of the enclosed System Impact Study Agreement is **\$50,000 (\$45,000 refundable and \$5,000 non-refundable)**. Please execute the System Impact Study Agreement (SISA) agreement through DocuSign and send the check to:

Jeannette Mittan
PJM Interconnection, LLC
2750 Monroe Blvd.
Audubon, PA 19403

The following information is provided for wire transfers: **Bank:** PNC Bank, NA, New Jersey; **ABA Number:** 031-207-607; **Account Number:** 8013589826. Please e-mail Jeannette Mittan at Jeannette.Mittan@pjm.com with the project name, queue number, date and amount of wire.

In addition to the executed System Impact Study Agreement and deposit, you are responsible to ensure that all queue requests that you may have in the PJM queue are in good financial standing and that you meet the requirements of Tariff §204.3. Failure to meet the requirements of Tariff §204.3 or have your accounts in good standing will result in your project to be withdrawn from the queue. It is your responsibility to meet these requirements.

Please be advised that the System Impact Study deposit may be used to satisfy any outstanding Feasibility Study costs. The costs associated with the Feasibility Study are being tabulated and you will receive a final statement/invoice electronically from PJM detailing your balance and the System Impact Study deposit applied to that balance.

If you wish to discuss the results of the Feasibility Study with me, please let me know. My office telephone number is 610-666-4265 and my email address is joseph.hay@pjm.com.

Sincerely,



Joseph S. Hay
Sr. Engineer
PJM Interconnection Projects

jsh\jm CERA# 55589694
Attachments

PJM (w/attachments):

Noorgul Dada - AEP
Jon Riley - AEP
File

***Generation Interconnection
Feasibility Study Report***

For

***PJM Generation Interconnection Request
Queue Position AC2-031***

Hillsboro 138 kV

August 2017

Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

General

sPower Development Company, LLC proposes to install PJM Project #AC2-031, a 100.0 MW (67.0 MW Capacity) solar generating facility in Hillsboro, Ohio (see Figure 2). The point of interconnection will be a direct connection to AEP's Hillsboro 138 kV substation (see Figure 1).

The requested in service date is October 1, 2019.

Attachment Facilities

Point of Interconnection (Hillsboro 138 kV Substation)

To accommodate the interconnection at the Hillsboro 138 kV substation, the substation will have to be expanded requiring the installation of two (2) 138 kV circuit breakers, extending the two 138 kV buses, and starting a new string (see Figure 1). Installation of associated protection and control equipment, 138 kV line risers, SCADA, and 138 kV revenue metering will also be required.

Note: Two 138 kV circuit breakers are recommended for this interconnection to allow for breaker maintenance and inspections.

Station Work:

- Expand the Hillsboro 138 kV substation, start a new string, extend the two 138 kV buses and install two (2) 138 kV circuit breakers (see Figure 1). Installation of associated protection and control equipment, 138 kV line risers, SCADA, and 138 kV revenue metering will also be required.
- **Estimated Station Cost: \$3,000,000**

Non-Direct Connection Cost Estimate

The total preliminary cost estimate for Non-Direct Connection work is given in the following tables below:

For AEP building Direct Connection cost estimates:

Description	Estimated Cost
138 kV Revenue Metering	\$250,000
Upgrade line protection and control settings at the Millbrook Park 138 kV substation to coordinate with the expanded Hillsboro 138 kV substation.	\$25,000
Upgrade line protection and control settings at the Highland 138 kV substation to coordinate with the expanded Hillsboro 138 kV substation.	\$25,000
Upgrade line protection and control settings at the Clinton County 138 kV substation to coordinate with the expanded Hillsboro 138 kV	\$25,000

Description	Estimated Cost
substation.	
Upgrade line protection and control settings at the Wildcat 138 kV substation to coordinate with the expanded Hillsboro 138 kV substation.	\$25,000
Upgrade line protection and control settings at the O.H. Hutchings (DP&L) 138 kV substation to coordinate with the expanded Hillsboro 138 kV substation.	DP&L to provide scope and cost
Total	\$350,000

Table 1

It is understood that sPower Development Company is responsible for all costs associated with this interconnection. The costs above are reimbursable to AEP. The cost of sPower Development Company’s generating plant and the costs for the line connecting the generating plant to the Hillsboro 138 kV substation are not included in this report; these are assumed to be sPower Development Company’s responsibility.

The Generation Interconnection Agreement does not in or by itself establish a requirement for American Electric Power to provide power for consumption at the developer's facilities. A separate agreement may be reached with the local utility that provides service in the area to ensure that infrastructure is in place to meet this demand and proper metering equipment is installed. It is the responsibility of the developer to contact the local service provider to determine if a local service agreement is required.

Interconnection Customer Requirements

Requirement from the PJM Open Access Transmission Tariff:

1. An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.
2. The Interconnection Customer may be required to install and/or pay for metering as necessary to properly track real time output of the facility as well as installing metering which shall be used for billing purposes. See Section 8 of Appendix 2 to the Interconnection Service Agreement as well as Section 4 of PJM Manual 14D for additional information.

Revenue Metering and SCADA Requirements

PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC’s generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

AEP Requirements

The Interconnection Customer will be required to comply with all AEP Revenue Metering Requirements for Generation Interconnection Customers. The Revenue Metering Requirements may be found within the “Requirements for Connection of New Facilities or Changes to Existing Facilities Connected to the AEP Transmission System” document located at the following link:

<http://www.pjm.com/~media/planning/plan-standards/private-aep/aep-interconnection-requirements.ashx>

Network Impacts

The Queue Project AC2-031 was evaluated as a 100.0 MW (Capacity 67.0 MW) injection at the Hillsboro 138 kV substation in the AEP area. Project AC2-031 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AC2-031 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Base Case Used

Summer Peak Analysis – 2020 Case

Contingency Descriptions

The following contingencies resulted in overloads:

Contingency Name	Description
462_B3_05MILLBR 138-5_WOMOAB	CONTINGENCY '462_B3_05MILLBR 138-5_WOMOAB' OPEN BRANCH FROM BUS 242988 TO BUS 243042 CKT 1 / 242988 05DOGWOO 138 243042 05MILLBR 138 1 OPEN BRANCH FROM BUS 243069 TO BUS 243042 CKT 1 / 243069 05FIREBR 138 243042 05MILLBR 138 1 OPEN BRANCH FROM BUS 243042 TO BUS 243047 CKT 1 / 243042 05MILLBR 138 243047 05N PORT 138 1 OPEN BRANCH FROM BUS 243042 TO BUS 243173 CKT 1 / 243042 05MILLBR 138 243173 05MILLBRK 69.0 1 END
5891_B2_TOR607	CONTINGENCY '5891_B2_TOR607' OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB 138 253111 09MIDDLE 138 1 OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111 09MIDDLE 138 253057 09OHH 138 1 END
7342_B2_TOR7202268	CONTINGENCY '7342_B2_TOR7202268' OPEN BRANCH FROM BUS 246911 TO BUS 243019 CKT 1 / 246911 05HIGHLA 138 243019 05HILLSB 138 1 END

Contingency Name	Description
7351_C2_05HILLSB 138-_A	CONTINGENCY '7351_C2_05HILLSB 138-_A' OPEN BRANCH FROM BUS 246911 TO BUS 243019 CKT 1 / 246911 05HIGHLA 138 243019 05HILLSB 138 1 OPEN BRANCH FROM BUS 243019 TO BUS 926100 CKT 1 / 243019 05HILLSB 138 926100 AC1-089 TAP 138 1 END
7353_B2_TOR12737	CONTINGENCY '7353_B2_TOR12737' OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 243019 05HILLSB 138 249995 08CLINCO 138 1 OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995 08CLINCO 138 250122 08WARRN1 138 1 END
7954_C1_05MILLBR 138-2_A	CONTINGENCY '7954_C1_05MILLBR 138-2_A' OPEN BRANCH FROM BUS 243042 TO BUS 243088 CKT 1 / 243042 05MILLBR 138 243088 05S POIN 138 1 OPEN BRANCH FROM BUS 243042 TO BUS 931350 CKT 1 / 243042 05MILLBR 138 931350 AC2-049 TAP 138 1 END
7965_C2_05MILLBR 138-N	CONTINGENCY '7965_C2_05MILLBR 138-N' OPEN BRANCH FROM BUS 242988 TO BUS 243042 CKT 1 / 242988 05DOGWOO 138 243042 05MILLBR 138 1 OPEN BRANCH FROM BUS 243069 TO BUS 243042 CKT 1 / 243069 05FIREBR 138 243042 05MILLBR 138 1 OPEN BRANCH FROM BUS 243042 TO BUS 243047 CKT 1 / 243042 05MILLBR 138 243047 05N PORT 138 1 OPEN BRANCH FROM BUS 243042 TO BUS 243173 CKT 1 / 243042 05MILLBR 138 243173 05MILLBRK 69.0 1 OPEN BRANCH FROM BUS 243047 TO BUS 243819 CKT 1 / 243047 05N PORT 138 243819 05N PORTSM 69.0 1 OPEN BRANCH FROM BUS 243819 TO BUS 243826 CKT 1 / 243819 05N PORTSM 69.0 243826 05ORTELCRN 69.0 1 OPEN BRANCH FROM BUS 243819 TO BUS 243822 CKT 1 / 243819 05N PORTSM 69.0 243822 05ROSEMOUN 69.0 1 END

Contingency Name	Description
7970_C2_05MILLBR 138-G	CONTINGENCY '7970_C2_05MILLBR 138-G' OPEN BRANCH FROM BUS 242988 TO BUS 243042 CKT 1 / 242988 05DOGWOO 138 243042 05MILLBR 138 1 OPEN BRANCH FROM BUS 243069 TO BUS 243042 CKT 1 / 243069 05FIREBR 138 243042 05MILLBR 138 1 OPEN BRANCH FROM BUS 243688 TO BUS 243042 CKT 1 / 243688 05FULLER 138 243042 05MILLBR 138 1 OPEN BRANCH FROM BUS 243688 TO BUS 342538 CKT 1 / 243688 05FULLER 138 342538 4ARGENTUM 138 1 OPEN BRANCH FROM BUS 243042 TO BUS 243047 CKT 1 / 243042 05MILLBR 138 243047 05N PORT 138 1 OPEN BRANCH FROM BUS 243042 TO BUS 243173 CKT 1 / 243042 05MILLBR 138 243173 MILLBRK 69.0 1 OPEN BRANCH FROM BUS 243688 TO BUS 244686 CKT 1 / 243688 05FULLER 138 244686 VANCEBRG 12.0 1 END
7981_A	CONTINGENCY '7981_A' OPEN BRANCH FROM BUS 243019 TO BUS 931430 CKT 1 / 243019 05HILLSB 138 931430 AC2-061 TAP 138 1 OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB 138 253111 09MIDDLE 138 1 OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995 08CLINCO 138 250122 08WARRN1 138 1 OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111 09MIDDLE 138 253057 09OHH 138 1 END
7981_B	CONTINGENCY '7981_B' OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061 TAP 138 249995 08CLINCO 138 1 OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB 138 253111 09MIDDLE 138 1 OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995 08CLINCO 138 250122 08WARRN1 138 1 OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111 09MIDDLE 138 253057 09OHH 138 1 END

Contingency Name	Description
8107_C2_05HILLSB 138-C_A	CONTINGENCY '8107_C2_05HILLSB 138-C_A' OPEN BRANCH FROM BUS 246911 TO BUS 243019 CKT 1 / 246911 05HIGHLA 138 243019 05HILLSB 138 1 OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB 138 253111 09MIDDLE 138 1 END
8107_C2_05HILLSB 138-C_B	CONTINGENCY '8107_C2_05HILLSB 138-C_B' OPEN BRANCH FROM BUS 246911 TO BUS 243019 CKT 1 / 246911 05HIGHLA 138 243019 05HILLSB 138 1 OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB 138 253111 09MIDDLE 138 1 OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111 09MIDDLE 138 253057 09OHH 138 1 END
8108_C2_05HILLSB 138-D_A	CONTINGENCY '8108_C2_05HILLSB 138-D_A' OPEN BRANCH FROM BUS 243019 TO BUS 931430 CKT 1 / 243019 05HILLSB 138 931430 AC2-061 TAP 138 1 OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB 138 253111 09MIDDLE 138 1 OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995 08CLINCO 138 250122 08WARRN1 138 1 OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111 09MIDDLE 138 253057 09OHH 138 1 END
8109_C2_05HILLSB 138-A_A	CONTINGENCY '8109_C2_05HILLSB 138-A_A' OPEN BRANCH FROM BUS 243019 TO BUS 243102 CKT 1 / 243019 05HILLSB 138 243102 05SINKG8 138 1 OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB 138 253111 09MIDDLE 138 1 OPEN BRANCH FROM BUS 931350 TO BUS 243102 CKT 1 / 931350 AC2-049 TAP 138 243102 05SINKG8 138 1 OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111 09MIDDLE 138 253057 09OHH 138 1 END
8111_C2_05HILLSB 138-A	CONTINGENCY '8111_C2_05HILLSB 138-A' OPEN BRANCH FROM BUS 243019 TO BUS 926100 CKT 1 / 243019 05HILLSB 138 926100 AC1-089 TAP 138 1 OPEN BRANCH FROM BUS 243019 TO BUS 931430 CKT 1 / 243019 05HILLSB 138 931430

Contingency Name	Description
	AC2-060 TAP 138 1 END
P1-#..B2 WARREN-CLINTONCO-HILLSBORO 2381	CONTINGENCY 'P1-#..B2 WARREN-CLINTONCO-HILLSBORO 2381' OPEN BUS 249995 END
P2-1..LOE BRKR OPEN AT HILLSBORO AEP 2381	CONTINGENCY 'P2-1..LOE BRKR OPEN AT HILLSBORO AEP 2381' OPEN BRANCH FROM BUS 249995 TO BUS 931430 CKT 1 END
P2-2..C1 CLINTON COUNTY_A	CONTINGENCY 'P2-2..C1 CLINTON COUNTY_A' OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061 138 249995 08CLINCO 138 1 OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 OPEN BUS 251803 END

Table 2

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

AC2-031 Generator Deliverability													
#	Contingency Type	Contingency Name	Affected Area	Facility Description	Bus			Loading		Rating		MW Con.	FG App.
					From	To	Cir.	Initial	Final	Type	MVA		
1	N-1	P2-1..LOE BRKR OPEN AT HILLSBORO AEP 2381	AEP - DAY	05HILLSB-09MIDDLE 138 kV line	243019	253111	1	60.2	67.28	ER	185	13.09	
2	N-1	7353_B2_TOR1 2737	AEP - DAY	05HILLSB-09MIDDLE 138 kV line	243019	253111	1	60.09	67.17	ER	185	13.09	
3	N-1	5891_B2_TOR6 07	AEP - DEO&K	05HILLSB-AC2-061 TAP 138 kV line	243019	931430	1	57.8	67.49	ER	184	17.83	
4	N-1	7342_B2_TOR7 202268	AEP - DEO&K	05HILLSB-AC2-061 TAP 138 kV line	243019	931430	1	57.62	68.21	ER	184	19.49	
5	Non	Non	AEP - DEO&K	05HILLSB-AC2-061 TAP 138 kV line	243019	931430	1	49.26	58.73	NR	159	15.06	
6	N-1	P2-1..LOE BRKR OPEN AT HILLSBORO AEP 2381	AEP - AEP	05HIGHLA 138/69 kV transformer	246911	243606	3	76.27	82.78	ER	122	7.94	

AC2-031 Generator Deliverability													
#	Contingency		Affected Area	Facility Description	Bus			Loading		Rating		MW Con.	FG App.
	Type	Name			From	To	Cir.	Initial	Final	Type	MVA		
7	N-1	7353_B2_TOR1 2737	AEP - AEP	05HIGHLA 138/69 kV transformer	246911	243606	3	76.19	82.7	ER	122	7.94	
8	N-1	7342_B2_TOR7 202268	DEO&K - DEO&K	08CLINCO- 08WARRN1 138 kV line	249995	250122	1	39.16	49	ER	198	19.49	
9	N-1	5891_B2_TOR6 07	DEO&K - DEO&K	08CLINCO- 08WARRN1 138 kV line	249995	250122	1	39.37	48.37	ER	198	17.83	
10	N-1	P2-1..LOE BRKR OPEN AT HILLSBORO AEP 2381	DAY - DAY	09MIDDLE- 09OHH 138 kV line	253111	253057	1	57.93	65.01	ER	185	13.09	
11	N-1	7353_B2_TOR1 2737	DAY - DAY	09MIDDLE- 09OHH 138 kV line	253111	253057	1	57.82	64.9	ER	185	13.09	
12	N-1	7353_B2_TOR1 2737	AEP - AEP	AC2-049 TAP- 05MILLBR 138 kV line	931350	243042	1	28.6	39.17	ER	179	18.92	
13	N-1	P1-#..B2 WARREN- CLINTONCO- HILLSBORO 2381	AEP - AEP	AC2-049 TAP- 05MILLBR 138 kV line	931350	243042	1	28.54	39.11	ER	179	18.92	
14	N-1	7342_B2_TOR7 202268	DEO&K - DEO&K	AC2-061 TAP- 08CLINCO 138 kV line	931430	249995	1	57.62	68.21	ER	184	19.49	
15	N-1	5891_B2_TOR6 07	DEO&K - DEO&K	AC2-061 TAP- 08CLINCO 138 kV line	931430	249995	1	57.8	67.49	ER	184	17.83	
16	Non	Non	DEO&K - DEO&K	AC2-061 TAP- 08CLINCO 138 kV line	931430	249995	1	49.19	58.67	NR	159	15.06	

Table 3

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

AC2-031 Multiple Facility Contingency													
#	Contingency		Affected Area	Facility Description	Bus			Loading		Rating		MW Con.	FG App.
	Type	Name			From	To	Cir.	Initial	Final	Type	MVA		
1	DCTL	7981_B	AEP - AEP	05HILLSB- 05HIGHLA 138 kV line	243019	246911	1	78.02	86.93	ER	413	36.77	1
2	LFFB	8108_C2_05HI LLSB 138-D_A	AEP - AEP	05HILLSB- 05HIGHLA 138 kV line	243019	246911	1	78.02	86.93	ER	413	36.77	

AC2-031 Multiple Facility Contingency													
#	Contingency		Affected Area	Facility Description	Bus			Loading		Rating		MW Con.	FG App.
	Type	Name			From	To	Cir.	Initial	Final	Type	MVA		
3	DCTL	7981_A	AEP - AEP	05HILLSB-05HIGHLA 138 kV line	243019	246911	1	78.02	86.93	ER	413	36.77	
4	BUS	7954_C1_05MI LLBR 138-2_A	AEP - AEP	05HILLSB-05HIGHLA 138 kV line	243019	246911	1	59.27	66.44	ER	413	29.63	
5	LFFB	7351_C2_05HILL SB 138-_A	AEP - DAY	05HILLSB-09MIDDLE 138 kV line	243019	253111	1	91.89	105.52	ER	185	25.21	2
6	LFFB	8111_C2_05HILL SB 138-_A	AEP - DAY	05HILLSB-09MIDDLE 138 kV line	243019	253111	1	94.68	108.39	ER	185	25.36	
7	BUS	7954_C1_05MI LLBR 138-2_A	AEP - DAY	05HILLSB-09MIDDLE 138 kV line	243019	253111	1	95.75	106.1	ER	185	19.15	
8	DCTL	7981_B	AEP - AEP	05HILLSB-AC1-089 TAP 138 kV line	243019	926100	1	51.49	66.81	ER	185	28.34	3
9	LFFB	8107_C2_05HILL SB 138-C_B	AEP - AEP	05HILLSB-AC1-089 TAP 138 kV line	243019	926100	1	48.24	63.48	ER	185	28.2	
10	LFFB	8107_C2_05HILL SB 138-C_A	AEP - AEP	05HILLSB-AC1-089 TAP 138 kV line	243019	926100	1	48.24	63.48	ER	185	28.2	
11	DCTL	7981_A	AEP - AEP	05HILLSB-AC1-089 TAP 138 kV line	243019	926100	1	51.49	66.81	ER	185	28.34	
12	LFFB	8107_C2_05HILL SB 138-C_A	AEP - AEP	05MILLBR-05N PORT 138 kV line	243042	243047	1	66.99	73.61	ER	185	12.24	4
13	LFFB	8107_C2_05HILL SB 138-C_B	AEP - AEP	05MILLBR-05N PORT 138 kV line	243042	243047	1	66.99	73.61	ER	185	12.24	
14	DCTL	7981_B	AEP - AEP	05MILLBR-05N PORT 138 kV line	243042	243047	1	56.12	62.03	ER	185	10.94	
15	DCTL	7981_A	AEP - AEP	05MILLBR-05N PORT 138 kV line	243042	243047	1	56.12	62.03	ER	185	10.94	
16	LFFB	7970_C2_05MI LLBR 138-G	AEP - AEP	05MILLBR-05S POIN 138 kV line	243042	243088	1	57.13	65.51	ER	167	14	5
17	LFFB	7965_C2_05MI LLBR 138-N	AEP - AEP	05MILLBR-05S POIN 138 kV line	243042	243088	1	46.91	53.76	ER	167	11.44	
18	LFFB	8109_C2_05HILL SB 138-A_A	AEP - AEP	05ADAMS-05WARERD 138 kV line	243464	246942	1	99.75	111.22	ER	150	17.21	
19	BUS	7954_C1_05MI LLBR 138-2_A	AEP - AEP	05ADAMS-05WARERD 138 kV line	243464	246942	1	79.52	88.9	ER	150	14.06	
20	DCTL	7981_B	AEP - AEP	05SEAMAN-05ADAMS 138 kV line	243571	243464	1	89.76	100.73	ER	150	16.45	6

AC2-031 Multiple Facility Contingency													
#	Contingency		Affected Area	Facility Description	Bus			Loading		Rating		MW Con.	FG App.
	Type	Name			From	To	Cir.	Initial	Final	Type	MVA		
21	LFFB	8109_C2_05HI LLSB 138-A_A	AEP - AEP	05SEAMAN- 05ADAMS 138 kV line	243571	243464	1	86.62	97.83	ER	150	16.81	
22	LFFB	8108_C2_05HI LLSB 138-D_A	AEP - AEP	05SEAMAN- 05ADAMS 138 kV line	243571	243464	1	89.76	100.73	ER	150	16.45	
23	DCTL	7981_A	AEP - AEP	05SEAMAN- 05ADAMS 138 kV line	243571	243464	1	89.76	100.73	ER	150	16.45	
24	BUS	7954_C1_05MI LLBR 138-2_A	AEP - AEP	05SEAMAN- 05ADAMS 138 kV line	243571	243464	1	67.49	76.63	ER	150	13.72	
25	DCTL	7981_B	AEP - DAY	05HIGHLA- 09MRTNSV 69 kV line	243606	253043	1	83.32	88.66	ER	71	8.41	7
26	LFFB	8108_C2_05HI LLSB 138-D_A	AEP - DAY	05HIGHLA- 09MRTNSV 69 kV line	243606	253043	1	83.32	88.66	ER	71	8.41	
27	DCTL	7981_A	AEP - DAY	05HIGHLA- 09MRTNSV 69 kV line	243606	253043	1	83.32	88.66	ER	71	8.41	
28	DCTL	7981_B	AEP - AEP	05HIGHLA- 05NMARSS 138 kV line	246911	247035	1	54.42	61.46	ER	310	21.83	8
29	DCTL	7981_B	AEP - AEP	05WARERD- 05WAVERL 138 kV line	246942	243585	1	92.23	103.37	ER	150	16.71	9
30	LFFB	8109_C2_05HI LLSB 138-A_A	AEP - AEP	05WARERD- 05WAVERL 138 kV line	246942	243585	1	89.55	101.02	ER	150	17.21	
31	LFFB	8108_C2_05HI LLSB 138-D_A	AEP - AEP	05WARERD- 05WAVERL 138 kV line	246942	243585	1	92.23	103.37	ER	150	16.71	
32	DCTL	7981_A	AEP - AEP	05WARERD- 05WAVERL 138 kV line	246942	243585	1	92.23	103.37	ER	150	16.71	
33	BUS	7954_C1_05MI LLBR 138-2_A	AEP - AEP	05WARERD- 05WAVERL 138 kV line	246942	243585	1	69.32	78.7	ER	150	14.06	
34	DCTL	7981_B	AEP - AEP	05WLDCAT- 05EMERSS 138 kV line	246946	247034	1	79.11	94.43	ER	185	28.34	10
35	LFFB	8107_C2_05HI LLSB 138-C_B	AEP - AEP	05WLDCAT- 05EMERSS 138 kV line	246946	247034	1	75.77	91.01	ER	185	28.2	
36	LFFB	8107_C2_05HI LLSB 138-C_A	AEP - AEP	05WLDCAT- 05EMERSS 138 kV line	246946	247034	1	75.77	91.01	ER	185	28.2	
37	DCTL	7981_A	AEP - AEP	05WLDCAT- 05EMERSS 138 kV line	246946	247034	1	79.11	94.43	ER	185	28.34	
38	DCTL	7981_B	AEP - AEP	05EMERSS- AC2-062 TAP 138 kV line	247034	931440	1	77.11	92.43	ER	185	28.34	11

AC2-031 Multiple Facility Contingency

#	Contingency		Affected Area	Facility Description	Bus			Loading		Rating		MW Con.	FG App.
	Type	Name			From	To	Cir.	Initial	Final	Type	MVA		
39	LFFB	8107_C2_05HI LLSB 138-C_A	AEP - AEP	05EMERSS- AC2-062 TAP 138 kV line	247034	931440	1	73.72	88.96	ER	185	28.2	
40	LFFB	8107_C2_05HI LLSB 138-C_B	AEP - AEP	05EMERSS- AC2-062 TAP 138 kV line	247034	931440	1	73.72	88.96	ER	185	28.2	
41	DCTL	7981_A	AEP - AEP	05EMERSS- AC2-062 TAP 138 kV line	247034	931440	1	77.11	92.43	ER	185	28.34	
42	DCTL	7981_B	AEP - AEP	05NMARSS- 05SEAMAN 138 kV line	247035	243571	1	51.03	58.07	ER	310	21.83	12
43	LFFB	7351_C2_05HI LLSB 138-A	DEO&K - DEO&K	08CLINCO- 08WARRN1 138 kV line	249995	250122	1	82.63	101.72	ER	198	37.8	
44	BUS	7954_C1_05MI LLBR 138-2_A	DEO&K - DEO&K	08CLINCO- 08WARRN1 138 kV line	249995	250122	1	89.87	104.38	ER	198	28.73	
45	LFFB	7351_C2_05HI LLSB 138-A	DAY - DAY	09MIDDLE- 09OHH 138 kV line	253111	253057	1	89.62	103.25	ER	185	25.21	13
46	LFFB	8111_C2_05HI LLSB 138-A	DAY - DAY	09MIDDLE- 09OHH 138 kV line	253111	253057	1	92.41	106.12	ER	185	25.36	
47	BUS	7954_C1_05MI LLBR 138-2_A	DAY - DAY	09MIDDLE- 09OHH 138 kV line	253111	253057	1	93.48	103.83	ER	185	19.15	
48	DCTL	7981_B	AEP - AEP	AC1-089 TAP- 05WLDCAT 138 kV line	926100	246946	1	80.19	95.51	ER	185	28.34	14
49	LFFB	8107_C2_05HI LLSB 138-C_B	AEP - AEP	AC1-089 TAP- 05WLDCAT 138 kV line	926100	246946	1	76.85	92.1	ER	185	28.2	
50	LFFB	8107_C2_05HI LLSB 138-C_A	AEP - AEP	AC1-089 TAP- 05WLDCAT 138 kV line	926100	246946	1	76.85	92.1	ER	185	28.2	
51	DCTL	7981_A	AEP - AEP	AC1-089 TAP- 05WLDCAT 138 kV line	926100	246946	1	80.19	95.51	ER	185	28.34	
52	BUS	P2-2..C1 CLINTON COUNTY_A	AEP - AEP	AC2-055 TAP- 05BCKSKI 69 kV line	931380	243598	1	76.95	81.68	ER	50	5.25	
53	DCTL	7981_B	AEP - LGEE	AC2-062 TAP- 4KENTON 138 kV line	931440	324267	1	76.41	91.73	ER	185	28.34	15
54	LFFB	8107_C2_05HI LLSB 138-C_B	AEP - LGEE	AC2-062 TAP- 4KENTON 138 kV line	931440	324267	1	73.07	88.31	ER	185	28.2	
55	LFFB	8107_C2_05HI LLSB 138-C_A	AEP - LGEE	AC2-062 TAP- 4KENTON 138 kV line	931440	324267	1	73.07	88.31	ER	185	28.2	
56	DCTL	7981_A	AEP - LGEE	AC2-062 TAP- 4KENTON 138 kV line	931440	324267	1	76.41	91.73	ER	185	28.34	

Table 4

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

Note: Please see Appendices for projects providing impacts to flowgate violations. The values in the Reference column correspond to the proper table in the Appendix.

AC2-031 Contribution to Previously Identified Overloads													
#	Contingency Type	Contingency Name	Affected Area	Facility Description	Bus			Loading		Rating		MW Con.	FG App.
					From	To	Cir.	Initial	Final	Type	MVA		
1	DCTL	7981_B	AEP - AEP	05HILLSB-05SINKG8 138 kV line	243019	243102	1	126.23	145.09	ER	185	34.89	16
2	LFFB	8107_C2_05HILLSB 138-C_B	AEP - AEP	05HILLSB-05SINKG8 138 kV line	243019	243102	1	125.52	144.68	ER	185	35.43	
3	LFFB	8107_C2_05HILLSB 138-C_A	AEP - AEP	05HILLSB-05SINKG8 138 kV line	243019	243102	1	125.47	144.62	ER	185	35.43	
4	DCTL	7981_A	AEP - AEP	05HILLSB-05SINKG8 138 kV line	243019	243102	1	126.29	145.14	ER	185	34.89	
5	LFFB	8107_C2_05HILLSB 138-C_A	AEP - DEO&K	05HILLSB-AC2-061 TAP 138 kV line	243019	931430	1	154.64	174.41	ER	184	36.37	17
6	LFFB	8107_C2_05HILLSB 138-C_B	AEP - DEO&K	05HILLSB-AC2-061 TAP 138 kV line	243019	931430	1	154.59	174.36	ER	184	36.37	
7	LFFB	8109_C2_05HILLSB 138-A_A	AEP - DEO&K	05HILLSB-AC2-061 TAP 138 kV line	243019	931430	1	147.28	166.67	ER	184	35.66	
8	BUS	7954_C1_05MILLBR 138-2_A	AEP - DEO&K	05HILLSB-AC2-061 TAP 138 kV line	243019	931430	1	111.56	127.18	ER	184	28.73	
9	DCTL	7981_B	AEP - AEP	05SINKG8-AC2-049 TAP 138 kV line	243102	931350	1	128.51	148	ER	179	34.89	18
10	LFFB	8107_C2_05HILLSB 138-C_B	AEP - AEP	05SINKG8-AC2-049 TAP 138 kV line	243102	931350	1	127.72	147.51	ER	179	35.43	
11	LFFB	8107_C2_05HILLSB 138-C_A	AEP - AEP	05SINKG8-AC2-049 TAP 138 kV line	243102	931350	1	127.72	147.51	ER	179	35.43	
12	DCTL	7981_A	AEP - AEP	05SINKG8-AC2-049 TAP 138 kV line	243102	931350	1	128.51	148	ER	179	34.89	
13	DCTL	7981_B	AEP - AEP	05ADAMS-05WARERD 138 kV line	243464	246942	1	102.43	113.57	ER	150	16.71	19
14	LFFB	8108_C2_05HILLSB 138-D_A	AEP - AEP	05ADAMS-05WARERD 138 kV line	243464	246942	1	102.43	113.57	ER	150	16.71	
15	DCTL	7981_A	AEP - AEP	05ADAMS-05WARERD	243464	246942	1	102.43	113.57	ER	150	16.71	

AC2-031 Contribution to Previously Identified Overloads

#	Contingency		Affected Area	Facility Description	Bus			Loading		Rating		MW Con.	FG App.
	Type	Name			From	To	Cir.	Initial	Final	Type	MVA		
				138 kV line									
16	DCTL	7981_B	AEP - AEP	05HIGHLA-05PETERSB8 69 kV line	243606	243612	1	137.52	143.4	ER	50	6.53	20
17	LFFB	8108_C2_05HI LLSB 138-D_A	AEP - AEP	05HIGHLA-05PETERSB8 69 kV line	243606	243612	1	137.52	143.4	ER	50	6.53	
18	DCTL	7981_A	AEP - AEP	05HIGHLA-05PETERSB8 69 kV line	243606	243612	1	137.52	143.4	ER	50	6.53	
19	DCTL	7981_B	AEP - AEP	05PETERSB8-AC2-055 TAP 69 kV line	243612	931380	1	113.92	119.8	ER	50	6.53	21
20	LFFB	8108_C2_05HI LLSB 138-D_A	AEP - AEP	05PETERSB8-AC2-055 TAP 69 kV line	243612	931380	1	113.92	119.8	ER	50	6.53	
21	DCTL	7981_A	AEP - AEP	05PETERSB8-AC2-055 TAP 69 kV line	243612	931380	1	113.92	119.8	ER	50	6.53	
22	DCTL	7981_B	AEP - AEP	05HIGHLA 138/69 kV transformer	246911	243606	3	143.15	155.4	ER	122	14.94	22
23	LFFB	8108_C2_05HI LLSB 138-D_A	AEP - AEP	05HIGHLA 138/69 kV transformer	246911	243606	3	143.15	155.4	ER	122	14.94	
24	DCTL	7981_A	AEP - AEP	05HIGHLA 138/69 kV transformer	246911	243606	3	143.15	155.4	ER	122	14.94	
25	LFFB	8107_C2_05HI LLSB 138-C_A	DEO&K - DEO&K	08CLINCO-08WARRN1 138 kV line	249995	250122	1	130.16	148.52	ER	198	36.37	23
26	LFFB	8107_C2_05HI LLSB 138-C_B	DEO&K - DEO&K	08CLINCO-08WARRN1 138 kV line	249995	250122	1	130.11	148.47	ER	198	36.37	
27	LFFB	8109_C2_05HI LLSB 138-A_A	DEO&K - DEO&K	08CLINCO-08WARRN1 138 kV line	249995	250122	1	123.35	141.36	ER	198	35.66	
28	DCTL	7981_B	AEP - AEP	AC2-049 TAP-05MILLBR 138 kV line	931350	243042	1	128.4	147.89	ER	179	34.89	24
29	LFFB	8107_C2_05HI LLSB 138-C_B	AEP - AEP	AC2-049 TAP-05MILLBR 138 kV line	931350	243042	1	127.61	147.4	ER	179	35.43	
30	LFFB	8107_C2_05HI LLSB 138-C_A	AEP - AEP	AC2-049 TAP-05MILLBR 138 kV line	931350	243042	1	127.61	147.4	ER	179	35.43	
31	DCTL	7981_A	AEP - AEP	AC2-049 TAP-05MILLBR 138 kV line	931350	243042	1	128.4	147.89	ER	179	34.89	
32	DCTL	7981_B	AEP - AEP	AC2-055 TAP-05BCKSKI 69 kV line	931380	243598	1	113.72	119.6	ER	50	6.53	25

AC2-031 Contribution to Previously Identified Overloads

#	Contingency		Affected Area	Facility Description	Bus			Loading		Rating		MW Con.	FG App.
	Type	Name			From	To	Cir.	Initial	Final	Type	MVA		
33	DCTL	7981_A	AEP - AEP	AC2-055 TAP-05BCKSKI 69 kV line	931380	243598	1	113.72	119.6	ER	50	6.53	
34	LFFB	8107_C2_05HI LLSB 138-C_B	DEO&K - DEO&K	AC2-061 TAP-08CLINCO 138 kV line	931430	249995	1	154.59	174.36	ER	184	36.37	26
35	LFFB	8107_C2_05HI LLSB 138-C_A	DEO&K - DEO&K	AC2-061 TAP-08CLINCO 138 kV line	931430	249995	1	154.59	174.36	ER	184	36.37	
36	LFFB	8109_C2_05HI LLSB 138-A_A	DEO&K - DEO&K	AC2-061 TAP-08CLINCO 138 kV line	931430	249995	1	147.28	166.67	ER	184	35.66	
37	LFFB	7351_C2_05HI LLSB 138-_A	DEO&K - DEO&K	AC2-061 TAP-08CLINCO 138 kV line	931430	249995	1	103.39	123.94	ER	184	37.8	
38	BUS	7954_C1_05MI LLBR 138-2_A	DEO&K - DEO&K	AC2-061 TAP-08CLINCO 138 kV line	931430	249995	1	111.56	127.18	ER	184	28.73	

Table 5

Steady-State Voltage Requirements

None

Short Circuit

(Summary of impacted circuit breakers)

New circuit breakers found to be over-duty:

None

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

AC2-031 Delivery of Energy Portion of Interconnection Request													
#	Contingency		Affected Area	Facility Description	Bus			Loading		Rating		MW Con.	FG App.
	Type	Name			From	To	Cir.	Initial	Final	Type	MVA		
1	N-1	7353_B2_TOR1 2737	AEP - AEP	05HILLSB- 05SINKG8 138 kV line	243019	243102	1	91.26	106.52	ER	185	28.24	
2	Non	Non	AEP - AEP	05HILLSB- 05HIGHLA 138 kV line	243019	246911	1	71.98	79.7	NR	296	22.85	
3	N-1	P2-1..LOE BRKR OPEN AT HILLSBORO AEP 2381	AEP - AEP	05HILLSB- 05HIGHLA 138 kV line	243019	246911	1	62.2	69.33	ER	413	29.47	
4	N-1	P2-1..LOE BRKR OPEN AT HILLSBORO AEP 2381	AEP - DAY	05HILLSB- 09MIDDLE 138 kV line	243019	253111	1	102.42	112.99	ER	185	19.54	
5	N-1	7353_B2_TOR1 2737	AEP - AEP	05HILLSB- AC1-089 TAP 138 kV line	243019	926100	1	25.72	38.02	ER	185	22.75	
6	N-1	7342_B2_TOR7 202268	AEP - DEO&K	05HILLSB- AC2-061 TAP 138 kV line	243019	931430	1	116.95	132.75	ER	184	29.08	
7	Non	Non	AEP - DEO&K	05HILLSB- AC2-061 TAP 138 kV line	243019	931430	1	107.78	121.92	NR	159	22.48	
8	N-1	462_B3_05MIL LBR 138- 5_WOMOAB	AEP - AEP	05MILLBR-05S POIN 138 kV line	243042	243088	1	46.94	53.78	ER	167	11.42	
9	N-1	P1-#..B2 WARREN- CLINTONCO- HILLSBORO 2381	AEP - AEP	05SINKG8- AC2-049 TAP 138 kV line	243102	931350	1	92.3	108.08	ER	179	28.24	
10	N-1	7353_B2_TOR1 2737	AEP - AEP	05ADAMS- 05WARERD 138 kV line	243464	246942	1	81.34	90.36	ER	150	13.53	
11	N-1	7353_B2_TOR1 2737	AEP - AEP	05SEAMAN- 05ADAMS 138 kV line	243571	243464	1	69.72	78.59	ER	150	13.3	

AC2-031 Delivery of Energy Portion of Interconnection Request

#	Contingency		Affected Area	Facility Description	Bus			Loading		Rating		MW Con.	FG App.
	Type	Name			From	To	Cir.	Initial	Final	Type	MVA		
12	N-1	P1-#.B2 WARREN-CLINTONCO-HILLSBORO 2381	AEP - AEP	05HIGHLA-05PETERSB8 69 kV line	243606	243612	1	100.55	105.28	ER	50	5.25	
13	N-1	7353_B2_TOR1 2737	AEP - DAY	05HIGHLA-09MRTNSV 69 kV line	243606	253043	1	61.34	65.53	ER	71	6.61	
14	N-1	P2-1..LOE BRKR OPEN AT HILLSBORO AEP 2381	AEP - AEP	05PETERSB8-AC2-055 TAP 69 kV line	243612	931380	1	76.95	81.68	ER	50	5.25	
15	N-1	P2-1..LOE BRKR OPEN AT HILLSBORO AEP 2381	AEP - AEP	05HIGHLA 138/69 kV transformer	246911	243606	3	117.77	127.49	ER	122	11.86	
16	N-1	7353_B2_TOR1 2737	AEP - AEP	05WARERD-05WAVERL 138 kV line	246942	243585	1	71.14	80.16	ER	150	13.53	
17	N-1	P2-1..LOE BRKR OPEN AT HILLSBORO AEP 2381	AEP - AEP	05WLDCAT-05EMERSS 138 kV line	246946	247034	1	49.72	62.02	ER	185	22.75	
18	N-1	7353_B2_TOR1 2737	AEP - AEP	05EMERSS-AC2-062 TAP 138 kV line	247034	931440	1	47.72	60.02	ER	185	22.75	
19	N-1	7342_B2_TOR7 202268	DEO&K - DEO&K	08CLINCO-08WARRN1 138 kV line	249995	250122	1	94.88	109.57	ER	198	29.08	
20	N-1	P2-1..LOE BRKR OPEN AT HILLSBORO AEP 2381	DAY - DAY	09MIDDLE-09OHH 138 kV line	253111	253057	1	100.15	110.72	ER	185	19.54	
21	N-1	P2-1..LOE BRKR OPEN AT HILLSBORO AEP 2381	AEP - AEP	AC1-089 TAP-05WLDCAT 138 kV line	926100	246946	1	51.04	63.34	ER	185	22.75	
22	N-1	7353_B2_TOR1 2737	AEP - AEP	AC2-049 TAP-05MILLBR 138 kV line	931350	243042	1	92.25	108.02	ER	179	28.24	
23	N-1	7342_B2_TOR7 202268	DEO&K - DEO&K	AC2-061 TAP-08CLINCO 138 kV line	931430	249995	1	116.95	132.75	ER	184	29.08	
24	Non	Non	DEO&K - DEO&K	AC2-061 TAP-08CLINCO 138 kV line	931430	249995	1	107.72	121.86	NR	159	22.48	
25	N-1	7353_B2_TOR1 2737	AEP - LGEE	AC2-062 TAP-4KENTON 138	931440	324267	1	46.63	58.93	ER	185	22.75	

AC2-031 Delivery of Energy Portion of Interconnection Request

#	Contingency Type	Affected Area	Facility Description	Bus		Loading		Rating		MW Con.	FG App.
				From	To	Cir.	Initial	Final	Type		
			kV line								

Table 6

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

#	Overloaded Facility	Upgrade Description	Schedule	Estimated Cost
#1	05HILLSB-05HIGHLA 138 kV line	<p>4.24 miles of the ACSR 1033.5 54/7 conductor section 2 will need to be rebuilt/reconducted.</p> <p>3.15 miles of ACSR 1033.5 54/7 conductor section 1 will need to be rebuilt/reconducted.</p> <p>Replace the Highland Wavetrap (2000A)</p> <p>Replace the Hillsboro Wavetrap (2000A)</p> <p>This facility is not overloaded by the AC2-031 project as is shown in table 4 above but the AC2 Queue overloads this facility and the AC2-031 project contributes to the overload.</p>	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$11,190,000
#2	05HILLSB-09MIDDLE 138 kV line	<p>22.3 miles of the ACSR 477 26/7 conductor section 1 will need to be rebuilt/reconducted.</p> <p>An engineering study will need to be conducted to determine if the Relay Compliance Trip limits settings at Hillsboro can be adjusted to mitigate the overload.</p>	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$33,450,000
#3	05HILLSB-AC1-089 Tap 138 kV line	A Sag Study will be required on the 8.5 mile ACSR 477 26/7 conductor section 1 to mitigate the overload.	An approximate time for the sag study is 6 to 12 months after signing an interconnection agreement.	\$34,000
#4	05MILLBR-N PORT 138 kV line	<p>A Sag Study will be required on the 3.44 mile ACSR 477 26/7 conductor section 1 to mitigate the overload.</p> <p>This facility is not overloaded by the AC2-031 project as is shown in table 4 above but the AC2 Queue overloads this facility and the AC2-031 project contributes to the overload.</p>	An approximate time for the sag study is 6 to 12 months after signing an interconnection agreement.	\$15,000
	05MILLBR-05S POIN 138 kV line	A Sag Study will be required on the 8.5 mile ACSR 397.5 30/7 conductor section 1 to mitigate the overload.	An approximate time for the sag study is 6 to 12 months after signing an	\$463,000

#	Overloaded Facility	Upgrade Description	Schedule	Estimated Cost
#5		<p>Replace the South Point risers</p> <p>Replace the Millbrook Park risers</p> <p>An engineering study will need to be conducted to determine if the Relay Thermal limits settings can be adjusted at South Point to mitigate the overload.</p> <p>Replace the Millbrook Park Wavetrap (800A)</p> <p>Replace the Millbrook Park line risers</p> <p>This facility is not overloaded by the AC2-031 project as is shown in table 4 above but the AC2 Queue overloads this facility and the AC2-031 project contributes to the overload.</p>	<p>interconnection agreement.</p> <p>An approximate construction time would be 12 to 24 months after signing an interconnection agreement</p>	
#6	05ADAMS-05SEAMAN 138 kV line	8.0 miles of ACSR 336.4 30/7 conductor section 1 will need to be rebuilt/reconducted.	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$12,000,000
#7	05HIGHLA-05NMARSS 138 kV line	<p>1.0 mile of ACSR 636 26/7 conductor section 2 will need to be rebuilt/reconducted.</p> <p>This facility is not overloaded by the AC2-031 project as is shown in table 4 above but the AC2 Queue overloads this facility and the AC2-031 project contributes to the overload.</p>	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$1,500,000
#8	05WARERD-05WAVERL 138 kV line	<p>3.12 miles of ACSR 336.4 30/7 conductor section 1 will need to be rebuilt/reconducted.</p> <p>4.37 miles of ACSR 336.4 30/7 conductor section 2 will need to be rebuilt/reconducted.</p>	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$11,240,000
#9	05WLDCAT-05EMERSS 138 kV line	<p>1.3 miles of the ACSR 477 26/7 conductor section 1 will need to be rebuilt/reconducted.</p> <p>Replace the Emerald jumpers</p> <p>An engineering study will need to be conducted to determine if the Relay Compliance Trip limits settings at Wildcat can be adjusted to mitigate the overload.</p> <p>This facility is not overloaded by the AC2-031 project as is shown in table 4 above but the AC2 Queue overloads this facility and the AC2-031 project contributes to the overload.</p>	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$2,025,000

#	Overloaded Facility	Upgrade Description	Schedule	Estimated Cost
#10	05EMERSS-AC2-062 Tap 138 kV line	6.4 miles of the ACSR 477 26/7 conductor section 1 will need to be rebuilt/reconducted. This facility is not overloaded by the AC2-031 project as is shown in table 4 above but the AC2 Queue overloads this facility and the AC2-031 project contributes to the overload.	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$9,600,000
#11	05NMARSS-05SEAMAN 138 kV line	13.2 mile of ACSR 636 26/7 conductor section 2 will need to be rebuilt/reconducted. This facility is not overloaded by the AC2-031 project as is shown in table 4 above but the AC2 Queue overloads this facility and the AC2-031 project contributes to the overload.	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$19,800,000
#12	05WLDCAT-AC1-089 Tap 138 kV line	1.7 mile of ACSR 477 26/7 conductor section 2 will need to be rebuilt/reconducted. This facility is not overloaded by the AC2-031 project as is shown in table 4 above but the AC2 Queue overloads this facility and the AC2-031 project contributes to the overload.	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$2,500,000
#13	AC2-062 Tap-4KENTON 138 kV line	18.0 miles of the ACSR 477 26/7 conductor section 1 will need to be rebuilt/reconducted. Replace the Emerald Jumpers This is an AEP-LGEE tie line therefore; PJM is going to have to coordinate this upgrade with LGEE as well to make sure that their equipment will not set a limit lower than what is required. This facility is not overloaded by the AC2-031 project as is shown in table 4 above but the AC2 Queue overloads this facility and the AC2-031 project contributes to the overload.	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$27,050,000
			Total Network Upgrades	\$130,867,000

Table 7

The System Reinforcements listed below is not part of the Bulk Electric System (BES), but was identified by AEP and will be required for the interconnection of AC2-031.

#	Overloaded Facility	Upgrade Description	Schedule	Estimated Cost
	05HIGHLA-09MRTNSV 69 kV line	An engineering study will need to be conducted to determine if the CT Thermal limit settings can be adjusted at Highland to	An approximate engineering study time would be 6 to 12 months	\$50,000

#	Overloaded Facility	Upgrade Description	Schedule	Estimated Cost
#1		mitigate the overload. An engineering study will need to be conducted to determine if the Relay Thermal limits settings can be adjusted at Highland to mitigate the overload.	after signing an interconnection agreement	
			Total Network Upgrades	\$50,000

Table 8

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

(Summary form of Cost allocation for transmission lines and transformers will be inserted here if any)

#	Overloaded Facility	Upgrade Description	Schedule	Estimated Cost
#1	05HILLSB-05SINKG8 138 kV line	Rebuild/Reconductor 4.36 miles of ACSR 477 26/7 conductor section 1. An engineering study will need to be conducted to determine if the Relay Compliance Trip limits settings can be adjusted to mitigate the overload. Replace the Sinking Springs jumpers. Replace the Sinking Spring Switch (1200A) Rebuild/Reconductor 8.93 miles of ACSR 477 26/7 conductor section 2.	An approximate construction time would be 24 to 36 months after signing an interconnection agreement.	\$20,500,000
#2	05HILLSB-AC2-061 Tap 138 kV line	5.0 miles of the ACSR 477 26/7 conductor section 1 will need to be rebuilt/reconducted. An engineering study will need to be conducted to determine if the Relay Compliance Trip limits settings at Hillsboro can be adjusted to mitigate the overload This is an AEP-Dayton Power & Light tie line therefore; PJM is going to have to coordinate this upgrade with Dayton Power & Light as well to make sure that their equipment will not set a limit lower than what is required	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$7,500,000
	05SINKG8-AC2-049 Tap 138 kV line	An engineering study will need to be conducted to determine if the Relay Compliance Trip limit settings can be adjusted at Millbrook Park to mitigate the overload.	An approximate time for the sag study is 6 to 12 months after signing an interconnection agreement.	\$1,170,500

#	Overloaded Facility	Upgrade Description	Schedule	Estimated Cost
#3		<p>Replace the Millbrook Park line risers</p> <p>Replace the Millbrook Park bus and risers</p> <p>Replace the Millbrook Park trap riser</p> <p>Replace the Sinking Spring switch (1200A)</p> <p>A Sag Study will be required on the 20.37 mile ACSR 477 26/7 conductor section 2 to mitigate the overload.</p> <p>A Sag Study will be required on the 9.76 mile ACSR 477 26/7 conductor section 2 to mitigate the overload.</p> <p>An engineering study will need to be conducted to determine if the Relay Thermal limits settings can be adjusted at Millbrook Park to mitigate the overload.</p>	An approximate construction time would be 12 to 24 months after signing an interconnection agreement	
#4	05ADAMS-05WARERD 138 kV line	20.52 miles of ACSR 336.4 30/7 conductor section 1 will need to be rebuilt/reconducted.	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$30,780,000
#7	05AC2-049 Tap- 05MILLBR 138 kV line	<p>An engineering study will need to be conducted to determine if the Relay Compliance Trip limit settings can be adjusted at Millbrook Park to mitigate the overload.</p> <p>8.50 miles of ACSR 477 26/7 conductor section 3 will need to be rebuilt/reconducted.</p> <p>Replace the Millbrook Park line risers</p> <p>Replace the Millbrook Park bus and risers</p> <p>Replace the Millbrook Park trap riser</p> <p>Replace the Sinking Spring switch (1200A)</p> <p>20.4 miles of ACSR 477 26/7 conductor section 2 will need to be rebuilt/reconducted.</p> <p>9.8 miles of ACSR 477 26/7 conductor section 1 will need to be rebuilt/reconducted.</p> <p>An engineering study will need to be conducted to determine if the Relay Thermal limits settings can be adjusted at Millbrook Park to mitigate the overload.</p> <p>Replace the Hillsboro Wavetrap (2000A)</p>	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$59,100,000

#	Overloaded Facility	Upgrade Description	Schedule	Estimated Cost
#8	0AC2-055 Tap-05BCKSKI 69 kV line	2.75 miles of ACSR 211.6.4 6/1 conductor section 1 will need to be rebuilt/reconductored. Replace the Petersburg Switch (600A)	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$4,500,000
			Total Network Upgrades	\$123,550,500

Table 9

The System Reinforcements listed below is not part of the Bulk Electric System (BES), but was identified by AEP and will be required for the interconnection of AC2-031.

#	Overloaded Facility	Upgrade Description	Schedule	Estimated Cost
#1	05HIGHLA-05PETERSB8 69 kV line	10.0 miles of ACSR 336.4 30/7 conductor section 1 will need to be rebuilt/reconductored.	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$12,000,000
#2	05PETERSB8-AC2-055 69 kV line	16.4 miles of ACSR 211.6.4 6/1 conductor section 1 will need to be rebuilt/reconductored.	An approximate construction time would be 24 to 36 months after signing an interconnection agreement	\$7,680,000
#3	05HIGHLA 138/69 kV transformer	Replace the 138/69 kV Transformer #3 at Highland	An approximate construction time will be 12 months after signing of an interconnection agreement.	\$1,500,000
			Total Network Upgrades	\$21,180,000

Table 10

Schedule

It is anticipated that the time between receipt of executed agreements and Commercial Operation may range from 12 to 18 months if no line work is required. If line work is required, construction time would be between 24 to 36 months after signing an interconnection agreement.

Note: The time provided between anticipated normal completion of System Impact, Facilities Studies, subsequent execution of ISA and ICSA documents, and the proposed Backfeed Date is shorter than usual and may be difficult to achieve.

Conclusion

Based upon the results of this Feasibility Study, the construction of the 100.0 MW (67.0 MW Capacity) solar generating facility of SPower Development Company (PJM Project #AC2-031) will require the following additional interconnection charges. This plan of service will interconnect the proposed solar generating facility in a manner that will provide operational reliability and flexibility to both the AEP system and the SPower Development Company generating facility.

Cost Breakdown for Point of Interconnection (Hillsboro 138 kV Substation)		
Attachment Cost	Expand Hillsboro 138 kV Substation	\$3,000,000
Non-Direct Connection Cost Estimate	138 kV Revenue Metering	\$250,000
	Upgrade line protection and control settings at the Millbrook Park 138 kV substation to coordinate with the expanded Hillsboro 138 kV substation.	\$25,000
	Upgrade line protection and control settings at the Highland 138 kV substation to coordinate with the expanded Hillsboro 138 kV substation.	\$25,000
	Upgrade line protection and control settings at the Clinton County 138 kV substation to coordinate with the expanded Hillsboro 138 kV substation.	\$25,000
	Upgrade line protection and control settings at the Wildcat 138 kV substation to coordinate with the expanded Hillsboro 138 kV substation.	\$25,000
	Upgrade line protection and control settings at the O.H. Hutchings (DP&L) 138 kV substation to coordinate with the expanded Hillsboro 138 kV substation.	DP&L to provide scope and cost
	New System Reinforcements-Not part of the BES	\$50,000
	New System Reinforcements	\$130,867,000
	Contribution to Previously Identified System Reinforcements-Not part of the BES	\$21,180,000
	Contribution to Previously Identified System Reinforcements	\$123,550,500
Total Estimated Cost for Project AC2-031		\$278,997,500

Table 11

The estimates are preliminary in nature, as they were determined without the benefit of detailed engineering studies. The cost of remediation for sag limited conductors is not included in this estimate. Final estimates will require an on-site review and coordination to determine final construction requirements.

Figure 1: Point of Interconnection (Hillsboro 138 kV Substation)
Single-Line Diagram

AC2-031 Point of Interconnection





Figure 2: Point of Interconnection (Hillsboro 138 kV Substation)



Appendices

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact.

It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Appendix 1

(AEP - AEP) The 05HILLSB-05HIGHLA 138 kV line (from bus 243019 to bus 246911 ckt 1) loads from 78.02% to 86.93% (**DC power flow**) of its emergency rating (413 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 36.77 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
 TAP 138 249995 08CLINCO 138 1
 OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
 138 253111 09MIDDLE 138 1
 OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
 08CLINCO 138 250122 08WARRN1 138 1
 OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
 09MIDDLE 138 253057 09OHH 138 1
 END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	2.92
931132	AC2-020 E OP	2.77
931221	AC2-031 C	24.64
931222	AC2-031 E	12.14
931281	AC2-042 C	77.01
931282	AC2-042 E	51.34
931351	AC2-049 C	5.14
931352	AC2-049 E	3.43
931431	AC2-061 C	21.37
931432	AC2-061 E	21.66
931441	AC2-062 C OP	6.83
931442	AC2-062 E OP	3.05
931451	AC2-064 C	12.07
931452	AC2-064 E	8.05
926061	AC1-085 C	55.9
926062	AC1-085 E	91.2
926101	AC1-089 C	18.8
926102	AC1-089 E	30.67
926631	AC1-144 C	24.75
926632	AC1-144 E	12.03

Appendix 2

(AEP - DAY) The 05HILLSB-09MIDDLE 138 kV line (from bus 243019 to bus 253111 ckt 1) loads from 91.89% to 105.52% (**DC power flow**) of its emergency rating (185 MVA) for the line fault with failed breaker contingency outage of '7351_C2_05HILLSB 138-_A'. This project contributes approximately 25.21 MW to the thermal violation.

CONTINGENCY '7351_C2_05HILLSB 138-_A'

OPEN BRANCH FROM BUS 246911 TO BUS 243019 CKT 1 / 246911
05HIGHLA 138 243019 05HILLSB 138 1

OPEN BRANCH FROM BUS 243019 TO BUS 926100 CKT 1 / 243019 05HILLSB
138 926100 AC1-089 TAP 138 1

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931221	AC2-031 C	16.89
931222	AC2-031 E	8.32
931281	AC2-042 C	52.79
931282	AC2-042 E	35.2
931351	AC2-049 C	3.62
931352	AC2-049 E	2.42
931431	AC2-061 C	11.38
931432	AC2-061 E	11.53
931451	AC2-064 C	8.5
931452	AC2-064 E	5.67
916272	Z1-080 E	0.84
926061	AC1-085 C	38.32
926062	AC1-085 E	62.53
926631	AC1-144 C	16.97
926632	AC1-144 E	8.24

Appendix 3

(AEP - AEP) The 05HILLSB-AC1-089 TAP 138 kV line (from bus 243019 to bus 926100 ckt 1) loads from 51.49% to 66.81% (**DC power flow**) of its emergency rating (185 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 28.34 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931121	AC2-019 C	0.61
931122	AC2-019 E	1.
931131	AC2-020 C OP	0.46
931132	AC2-020 E OP	1.22
931192	AC2-027 E	1.62
931221	AC2-031 C	18.99
931222	AC2-031 E	9.35
931281	AC2-042 C	59.34
931282	AC2-042 E	39.56
931351	AC2-049 C	4.11
931352	AC2-049 E	2.74
931381	AC2-055 C OP	1.49
931382	AC2-055 E OP	2.42
931421	AC2-060 C	4.27
931422	AC2-060 E	2.4
931431	AC2-061 C	16.47
931432	AC2-061 E	16.69
931451	AC2-064 C	9.64
931452	AC2-064 E	6.43
931651	AC2-087 C OP	3.16
931652	AC2-087 E OP	2.51
247592	W4-036	0.8
924371	AB2-085 C OP	7.03
924372	AB2-085 E OP	3.31
924541	AB2-103 C OP	4.25
924542	AB2-103 E OP	2.
926061	AC1-085 C	43.08

<i>926062</i>	<i>ACI-085 E</i>	<i>70.28</i>
<i>926631</i>	<i>ACI-144 C</i>	<i>19.07</i>
<i>926632</i>	<i>ACI-144 E</i>	<i>9.27</i>

Appendix 4

(AEP - AEP) The 05MILLBR-05N PORT 138 kV line (from bus 243042 to bus 243047 ckt 1) loads from 66.99% to 73.61% (**DC power flow**) of its emergency rating (185 MVA) for the line fault with failed breaker contingency outage of '8107_C2_05HILLSB 138-C_A'. This project contributes approximately 12.24 MW to the thermal violation.

CONTINGENCY '8107_C2_05HILLSB 138-C_A'

OPEN BRANCH FROM BUS 246911 TO BUS 243019 CKT 1 / 246911
05HIGHLA 138 243019 05HILLSB 138 1

OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
342948	ILOVE HYDRO	2.67
931022	AC2-008 E	0.97
931221	AC2-031 C	8.2
931222	AC2-031 E	4.04
931281	AC2-042 C	25.63
931282	AC2-042 E	17.09
931351	AC2-049 C	7.12
931352	AC2-049 E	4.74
931431	AC2-061 C	5.52
931432	AC2-061 E	5.6
931441	AC2-062 C OP	2.25
931442	AC2-062 E OP	1.01
931451	AC2-064 C	16.7
931452	AC2-064 E	11.14
247613	X4-025	4.37
916272	Z1-080 E	0.41
926061	AC1-085 C	18.6
926062	AC1-085 E	30.36
926101	AC1-089 C	6.25
926102	AC1-089 E	10.2
926631	AC1-144 C	8.24
926632	AC1-144 E	4.

Appendix 5

(AEP - AEP) The 05MILLBR-05S POIN 138 kV line (from bus 243042 to bus 243088 ckt 1) loads from 57.13% to 65.51% (**DC power flow**) of its emergency rating (167 MVA) for the line fault with failed breaker contingency outage of '7970_C2_05MILLBR 138-G'. This project contributes approximately 14.0 MW to the thermal violation.

CONTINGENCY '7970_C2_05MILLBR 138-G'
 OPEN BRANCH FROM BUS 242988 TO BUS 243042 CKT 1 / 242988
 05DOGWO0 138 243042 05MILLBR 138 1
 OPEN BRANCH FROM BUS 243069 TO BUS 243042 CKT 1 / 243069 05FIREBR
 138 243042 05MILLBR 138 1
 OPEN BRANCH FROM BUS 243688 TO BUS 243042 CKT 1 / 243688
 05FULLER 138 243042 05MILLBR 138 1
 OPEN BRANCH FROM BUS 243688 TO BUS 342538 CKT 1 / 243688
 05FULLER 138 342538 4ARGENTUM 138 1
 OPEN BRANCH FROM BUS 243042 TO BUS 243047 CKT 1 / 243042
 05MILLBR 138 243047 05N PORT 138 1
 OPEN BRANCH FROM BUS 243042 TO BUS 243173 CKT 1 / 243042
 05MILLBR 138 243173 MILLBRK 69.0 1
 OPEN BRANCH FROM BUS 243688 TO BUS 244686 CKT 1 / 243688
 05FULLER 138 244686 VANCEBRG 12.0 1
 END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	1.13
931121	AC2-019 C	0.32
931122	AC2-019 E	0.52
931192	AC2-027 E	0.83
931221	AC2-031 C	9.38
931222	AC2-031 E	4.62
931281	AC2-042 C	29.32
931282	AC2-042 E	19.55
931351	AC2-049 C	11.43
931352	AC2-049 E	7.62
931431	AC2-061 C	6.47
931432	AC2-061 E	6.56
931441	AC2-062 C OP	2.73
931442	AC2-062 E OP	1.22
931451	AC2-064 C	26.82
931452	AC2-064 E	17.88
247613	X4-025	7.47
916272	Z1-080 E	0.5
924371	AB2-085 C OP	3.48
924372	AB2-085 E OP	1.64
924541	AB2-103 C OP	2.12

<i>924542</i>	<i>AB2-103 E OP</i>	<i>1.</i>
<i>926061</i>	<i>AC1-085 C</i>	<i>21.28</i>
<i>926062</i>	<i>AC1-085 E</i>	<i>34.73</i>
<i>926101</i>	<i>AC1-089 C</i>	<i>7.2</i>
<i>926102</i>	<i>AC1-089 E</i>	<i>11.74</i>
<i>926631</i>	<i>AC1-144 C</i>	<i>9.42</i>
<i>926632</i>	<i>AC1-144 E</i>	<i>4.58</i>

Appendix 6

(AEP - AEP) The 05SEAMAN-05ADAMS 138 kV line (from bus 243571 to bus 243464 ckt 1) loads from 89.76% to 100.73% (**DC power flow**) of its emergency rating (150 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 16.45 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	1.31
931121	AC2-019 C	0.58
931122	AC2-019 E	0.95
931131	AC2-020 C OP	0.4
931132	AC2-020 E OP	1.06
931192	AC2-027 E	1.53
931221	AC2-031 C	11.02
931222	AC2-031 E	5.43
931281	AC2-042 C	34.44
931282	AC2-042 E	22.96
931351	AC2-049 C	2.17
931352	AC2-049 E	1.45
931381	AC2-055 C OP	1.32
931382	AC2-055 E OP	2.15
931421	AC2-060 C	3.67
931422	AC2-060 E	2.07
931431	AC2-061 C	9.56
931432	AC2-061 E	9.69
931441	AC2-062 C OP	3.13
931442	AC2-062 E OP	1.4
931451	AC2-064 C	5.1
931452	AC2-064 E	3.4
931651	AC2-087 C OP	2.72
931652	AC2-087 E OP	2.16
247592	W4-036	0.69
924541	AB2-103 C OP	10.77
924542	AB2-103 E OP	5.07

<i>926061</i>	<i>ACI-085 C</i>	<i>25.</i>
<i>926062</i>	<i>ACI-085 E</i>	<i>40.79</i>
<i>926101</i>	<i>ACI-089 C</i>	<i>8.43</i>
<i>926102</i>	<i>ACI-089 E</i>	<i>13.75</i>
<i>926631</i>	<i>ACI-144 C</i>	<i>11.07</i>
<i>926632</i>	<i>ACI-144 E</i>	<i>5.38</i>

Appendix 7

(AEP - AEP) The 05HIGHLA-05NMARSS 138 kV line (from bus 246911 to bus 247035 ckt 1) loads from 54.42% to 61.46% (**DC power flow**) of its emergency rating (310 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 21.83 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	1.73
931121	AC2-019 C	0.77
931122	AC2-019 E	1.25
931131	AC2-020 C OP	0.54
931132	AC2-020 E OP	1.42
931192	AC2-027 E	2.02
931221	AC2-031 C	14.63
931222	AC2-031 E	7.2
931281	AC2-042 C	45.72
931282	AC2-042 E	30.48
931351	AC2-049 C	2.96
931352	AC2-049 E	1.97
931381	AC2-055 C OP	1.77
931382	AC2-055 E OP	2.88
931421	AC2-060 C	4.94
931422	AC2-060 E	2.78
931431	AC2-061 C	12.68
931432	AC2-061 E	12.86
931441	AC2-062 C OP	4.07
931442	AC2-062 E OP	1.82
931451	AC2-064 C	6.95
931452	AC2-064 E	4.63
931651	AC2-087 C OP	3.66
931652	AC2-087 E OP	2.9
247592	W4-036	0.93
926061	AC1-085 C	33.18
926062	AC1-085 E	54.14

<i>926101</i>	<i>ACI-089 C</i>	<i>11.16</i>
<i>926102</i>	<i>ACI-089 E</i>	<i>18.22</i>
<i>926631</i>	<i>ACI-144 C</i>	<i>14.69</i>
<i>926632</i>	<i>ACI-144 E</i>	<i>7.14</i>

Appendix 8

(AEP - AEP) The 05WARERD-05WAVERL 138 kV line (from bus 246942 to bus 243585 ckt 1) loads from 92.23% to 103.37% (**DC power flow**) of its emergency rating (150 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 16.71 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	1.34
931121	AC2-019 C	0.59
931122	AC2-019 E	0.96
931131	AC2-020 C OP	0.41
931132	AC2-020 E OP	1.07
931192	AC2-027 E	1.55
931221	AC2-031 C	11.2
931222	AC2-031 E	5.51
931281	AC2-042 C	34.99
931282	AC2-042 E	23.33
931351	AC2-049 C	2.18
931352	AC2-049 E	1.45
931381	AC2-055 C OP	1.33
931382	AC2-055 E OP	2.18
931421	AC2-060 C	3.7
931422	AC2-060 E	2.08
931431	AC2-061 C	9.71
931432	AC2-061 E	9.84
931441	AC2-062 C OP	3.21
931442	AC2-062 E OP	1.44
931451	AC2-064 C	5.11
931452	AC2-064 E	3.41
931651	AC2-087 C OP	2.74
931652	AC2-087 E OP	2.18
247592	W4-036	0.69
924371	AB2-085 C OP	27.11
924372	AB2-085 E OP	12.76

<i>924541</i>	<i>AB2-103 C OP</i>	<i>10.95</i>
<i>924542</i>	<i>AB2-103 E OP</i>	<i>5.15</i>
<i>926061</i>	<i>ACI-085 C</i>	<i>25.4</i>
<i>926062</i>	<i>ACI-085 E</i>	<i>41.44</i>
<i>926101</i>	<i>ACI-089 C</i>	<i>8.57</i>
<i>926102</i>	<i>ACI-089 E</i>	<i>13.99</i>
<i>926631</i>	<i>ACI-144 C</i>	<i>11.25</i>
<i>926632</i>	<i>ACI-144 E</i>	<i>5.46</i>

Appendix 9

(AEP - AEP) The 05WLDCAT-05EMERSS 138 kV line (from bus 246946 to bus 247034 ckt 1) loads from 79.11% to 94.43% (**DC power flow**) of its emergency rating (185 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 28.34 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	4.3
931121	AC2-019 C	0.61
931122	AC2-019 E	1.
931131	AC2-020 C OP	0.46
931132	AC2-020 E OP	1.22
931192	AC2-027 E	1.62
931221	AC2-031 C	18.99
931222	AC2-031 E	9.35
931281	AC2-042 C	59.34
931282	AC2-042 E	39.56
931351	AC2-049 C	4.11
931352	AC2-049 E	2.74
931381	AC2-055 C OP	1.49
931382	AC2-055 E OP	2.42
931421	AC2-060 C	4.27
931422	AC2-060 E	2.4
931431	AC2-061 C	16.47
931432	AC2-061 E	16.69
931451	AC2-064 C	9.64
931452	AC2-064 E	6.43
931651	AC2-087 C OP	3.16
931652	AC2-087 E OP	2.51
247592	W4-036	0.8
924371	AB2-085 C OP	7.03
924372	AB2-085 E OP	3.31
924541	AB2-103 C OP	4.25
924542	AB2-103 E OP	2.

<i>926061</i>	<i>ACI-085 C</i>	<i>43.08</i>
<i>926062</i>	<i>ACI-085 E</i>	<i>70.28</i>
<i>926101</i>	<i>ACI-089 C</i>	<i>20.33</i>
<i>926102</i>	<i>ACI-089 E</i>	<i>33.17</i>
<i>926631</i>	<i>ACI-144 C</i>	<i>19.07</i>
<i>926632</i>	<i>ACI-144 E</i>	<i>9.27</i>

Appendix 10

(AEP - AEP) The 05EMERSS-AC2-062 TAP 138 kV line (from bus 247034 to bus 931440 ckt 1) loads from 77.11% to 92.43% (**DC power flow**) of its emergency rating (185 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 28.34 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	4.3
931121	AC2-019 C	0.61
931122	AC2-019 E	1.
931131	AC2-020 C OP	0.46
931132	AC2-020 E OP	1.22
931192	AC2-027 E	1.62
931221	AC2-031 C	18.99
931222	AC2-031 E	9.35
931281	AC2-042 C	59.34
931282	AC2-042 E	39.56
931351	AC2-049 C	4.11
931352	AC2-049 E	2.74
931381	AC2-055 C OP	1.49
931382	AC2-055 E OP	2.42
931421	AC2-060 C	4.27
931422	AC2-060 E	2.4
931431	AC2-061 C	16.47
931432	AC2-061 E	16.69
931451	AC2-064 C	9.64
931452	AC2-064 E	6.43
931651	AC2-087 C OP	3.16
931652	AC2-087 E OP	2.51
247592	W4-036	0.8
924371	AB2-085 C OP	7.03
924372	AB2-085 E OP	3.31
924541	AB2-103 C OP	4.25
924542	AB2-103 E OP	2.

<i>926061</i>	<i>ACI-085 C</i>	<i>43.08</i>
<i>926062</i>	<i>ACI-085 E</i>	<i>70.28</i>
<i>926101</i>	<i>ACI-089 C</i>	<i>20.33</i>
<i>926102</i>	<i>ACI-089 E</i>	<i>33.17</i>
<i>926631</i>	<i>ACI-144 C</i>	<i>19.07</i>
<i>926632</i>	<i>ACI-144 E</i>	<i>9.27</i>

Appendix 11

(AEP - AEP) The 05NMARSS-05SEAMAN 138 kV line (from bus 247035 to bus 243571 ckt 1) loads from 51.03% to 58.07% (**DC power flow**) of its emergency rating (310 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 21.83 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	1.73
931121	AC2-019 C	0.77
931122	AC2-019 E	1.25
931131	AC2-020 C OP	0.54
931132	AC2-020 E OP	1.42
931192	AC2-027 E	2.02
931221	AC2-031 C	14.63
931222	AC2-031 E	7.2
931281	AC2-042 C	45.72
931282	AC2-042 E	30.48
931351	AC2-049 C	2.96
931352	AC2-049 E	1.97
931381	AC2-055 C OP	1.77
931382	AC2-055 E OP	2.88
931421	AC2-060 C	4.94
931422	AC2-060 E	2.78
931431	AC2-061 C	12.68
931432	AC2-061 E	12.86
931441	AC2-062 C OP	4.07
931442	AC2-062 E OP	1.82
931451	AC2-064 C	6.95
931452	AC2-064 E	4.63
931651	AC2-087 C OP	3.66
931652	AC2-087 E OP	2.9
247592	W4-036	0.93
926061	AC1-085 C	33.18
926062	AC1-085 E	54.14

<i>926101</i>	<i>ACI-089 C</i>	<i>11.16</i>
<i>926102</i>	<i>ACI-089 E</i>	<i>18.22</i>
<i>926631</i>	<i>ACI-144 C</i>	<i>14.69</i>
<i>926632</i>	<i>ACI-144 E</i>	<i>7.14</i>

Appendix 12

(DAY - DAY) The 09MIDDLE-09OHH 138 kV line (from bus 253111 to bus 253057 ckt 1) loads from 89.62% to 103.25% (**DC power flow**) of its emergency rating (185 MVA) for the line fault with failed breaker contingency outage of '7351_C2_05HILLSB 138-_A'. This project contributes approximately 25.21 MW to the thermal violation.

CONTINGENCY '7351_C2_05HILLSB 138-_A'

OPEN BRANCH FROM BUS 246911 TO BUS 243019 CKT 1 / 246911
05HIGHLA 138 243019 05HILLSB 138 1

OPEN BRANCH FROM BUS 243019 TO BUS 926100 CKT 1 / 243019 05HILLSB
138 926100 AC1-089 TAP 138 1

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931221	AC2-031 C	16.89
931222	AC2-031 E	8.32
931281	AC2-042 C	52.79
931282	AC2-042 E	35.2
931351	AC2-049 C	3.62
931352	AC2-049 E	2.42
931431	AC2-061 C	11.38
931432	AC2-061 E	11.53
931451	AC2-064 C	8.5
931452	AC2-064 E	5.67
916272	Z1-080 E	0.84
926061	AC1-085 C	38.32
926062	AC1-085 E	62.53
926631	AC1-144 C	16.97
926632	AC1-144 E	8.24

Appendix 13

(AEP - AEP) The AC1-089 TAP-05WLDCAT 138 kV line (from bus 926100 to bus 246946 ckt 1) loads from 80.19% to 95.51% (**DC power flow**) of its emergency rating (185 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 28.34 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931121	AC2-019 C	0.61
931122	AC2-019 E	1.
931131	AC2-020 C OP	0.46
931132	AC2-020 E OP	1.22
931192	AC2-027 E	1.62
931221	AC2-031 C	18.99
931222	AC2-031 E	9.35
931281	AC2-042 C	59.34
931282	AC2-042 E	39.56
931351	AC2-049 C	4.11
931352	AC2-049 E	2.74
931381	AC2-055 C OP	1.49
931382	AC2-055 E OP	2.42
931421	AC2-060 C	4.27
931422	AC2-060 E	2.4
931431	AC2-061 C	16.47
931432	AC2-061 E	16.69
931451	AC2-064 C	9.64
931452	AC2-064 E	6.43
931651	AC2-087 C OP	3.16
931652	AC2-087 E OP	2.51
247592	W4-036	0.8
924371	AB2-085 C OP	7.03
924372	AB2-085 E OP	3.31
924541	AB2-103 C OP	4.25
924542	AB2-103 E OP	2.
926061	AC1-085 C	43.08

<i>926062</i>	<i>ACI-085 E</i>	<i>70.28</i>
<i>926101</i>	<i>ACI-089 C</i>	<i>20.33</i>
<i>926102</i>	<i>ACI-089 E</i>	<i>33.17</i>
<i>926631</i>	<i>ACI-144 C</i>	<i>19.07</i>
<i>926632</i>	<i>ACI-144 E</i>	<i>9.27</i>

Appendix 14

(AEP - LGEE) The AC2-062 TAP-4KENTON 138 kV line (from bus 931440 to bus 324267 ckt 1) loads from 76.41% to 91.73% (**DC power flow**) of its emergency rating (185 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 28.34 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	4.3
931121	AC2-019 C	0.61
931122	AC2-019 E	1.
931131	AC2-020 C OP	0.46
931132	AC2-020 E OP	1.22
931192	AC2-027 E	1.62
931221	AC2-031 C	18.99
931222	AC2-031 E	9.35
931281	AC2-042 C	59.34
931282	AC2-042 E	39.56
931351	AC2-049 C	4.11
931352	AC2-049 E	2.74
931381	AC2-055 C OP	1.49
931382	AC2-055 E OP	2.42
931421	AC2-060 C	4.27
931422	AC2-060 E	2.4
931431	AC2-061 C	16.47
931432	AC2-061 E	16.69
931441	AC2-062 C OP	24.55
931442	AC2-062 E OP	10.98
931451	AC2-064 C	9.64
931452	AC2-064 E	6.43
931651	AC2-087 C OP	3.16
931652	AC2-087 E OP	2.51
247592	W4-036	0.8
924371	AB2-085 C OP	7.03
924372	AB2-085 E OP	3.31

924541	AB2-103 C OP	4.25
924542	AB2-103 E OP	2.
926061	AC1-085 C	43.08
926062	AC1-085 E	70.28
926101	AC1-089 C	20.33
926102	AC1-089 E	33.17
926631	AC1-144 C	19.07
926632	AC1-144 E	9.27

Appendix 15

(AEP - AEP) The 05HILLSB-05SINKG8 138 kV line (from bus 243019 to bus 243102 ckt 1) loads from 126.23% to 145.09% (**DC power flow**) of its emergency rating (185 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 34.89 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	2.78
931121	AC2-019 C	0.76
931122	AC2-019 E	1.25
931131	AC2-020 C OP	0.59
931132	AC2-020 E OP	1.55
931192	AC2-027 E	2.01
931221	AC2-031 C	23.37
931222	AC2-031 E	11.51
931281	AC2-042 C	73.05
931282	AC2-042 E	48.7
931381	AC2-055 C OP	1.86
931382	AC2-055 E OP	3.04
931421	AC2-060 C	5.36
931422	AC2-060 E	3.02
931431	AC2-061 C	20.27
931432	AC2-061 E	20.55
931441	AC2-062 C OP	6.62
931442	AC2-062 E OP	2.96
931651	AC2-087 C OP	3.97
931652	AC2-087 E OP	3.15
247592	W4-036	1.01
924371	AB2-085 C OP	8.23
924372	AB2-085 E OP	3.87
924541	AB2-103 C OP	5.1
924542	AB2-103 E OP	2.4
926061	AC1-085 C	53.03
926062	AC1-085 E	86.52

<i>926101</i>	<i>ACI-089 C</i>	<i>17.87</i>
<i>926102</i>	<i>ACI-089 E</i>	<i>29.16</i>
<i>926631</i>	<i>ACI-144 C</i>	<i>23.48</i>
<i>926632</i>	<i>ACI-144 E</i>	<i>11.41</i>

Appendix 16

(AEP - DEO&K) The 05HILLSB-AC2-061 TAP 138 kV line (from bus 243019 to bus 931430 ckt 1) loads from 154.64% to 174.41% (**DC power flow**) of its emergency rating (184 MVA) for the line fault with failed breaker contingency outage of '8107_C2_05HILLSB 138-C_A'. This project contributes approximately 36.37 MW to the thermal violation.

CONTINGENCY '8107_C2_05HILLSB 138-C_A'

OPEN BRANCH FROM BUS 246911 TO BUS 243019 CKT 1 / 246911

05HIGHLA 138 243019 05HILLSB 138 1

OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB

138 253111 09MIDDLE 138 1

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	2.88
931221	AC2-031 C	24.37
931222	AC2-031 E	12.
931281	AC2-042 C	76.15
931282	AC2-042 E	50.77
931351	AC2-049 C	5.23
931352	AC2-049 E	3.49
931441	AC2-062 C OP	6.68
931442	AC2-062 E OP	2.99
931451	AC2-064 C	12.27
931452	AC2-064 E	8.18
916272	Z1-080 E	2.17
926061	AC1-085 C	55.28
926062	AC1-085 E	90.19
926101	AC1-089 C	18.57
926102	AC1-089 E	30.29
926631	AC1-144 C	24.48
926632	AC1-144 E	11.89

Appendix 17

(AEP - AEP) The 05SINKG8-AC2-049 TAP 138 kV line (from bus 243102 to bus 931350 ckt 1) loads from 128.51% to 148.0% (**DC power flow**) of its emergency rating (179 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 34.89 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	2.78
931121	AC2-019 C	0.76
931122	AC2-019 E	1.25
931131	AC2-020 C OP	0.59
931132	AC2-020 E OP	1.55
931192	AC2-027 E	2.01
931221	AC2-031 C	23.37
931222	AC2-031 E	11.51
931281	AC2-042 C	73.05
931282	AC2-042 E	48.7
931381	AC2-055 C OP	1.86
931382	AC2-055 E OP	3.04
931421	AC2-060 C	5.36
931422	AC2-060 E	3.02
931431	AC2-061 C	20.27
931432	AC2-061 E	20.55
931441	AC2-062 C OP	6.62
931442	AC2-062 E OP	2.96
931651	AC2-087 C OP	3.97
931652	AC2-087 E OP	3.15
247592	W4-036	1.01
924371	AB2-085 C OP	8.23
924372	AB2-085 E OP	3.87
924541	AB2-103 C OP	5.1
924542	AB2-103 E OP	2.4
926061	AC1-085 C	53.03
926062	AC1-085 E	86.52

<i>926101</i>	<i>ACI-089 C</i>	<i>17.87</i>
<i>926102</i>	<i>ACI-089 E</i>	<i>29.16</i>
<i>926631</i>	<i>ACI-144 C</i>	<i>23.48</i>
<i>926632</i>	<i>ACI-144 E</i>	<i>11.41</i>

Appendix 18

(AEP - AEP) The 05ADAMS-05WARERD 138 kV line (from bus 243464 to bus 246942 ckt 1) loads from 102.43% to 113.57% (**DC power flow**) of its emergency rating (150 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 16.71 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	1.34
931121	AC2-019 C	0.59
931122	AC2-019 E	0.96
931131	AC2-020 C OP	0.41
931132	AC2-020 E OP	1.07
931192	AC2-027 E	1.55
931221	AC2-031 C	11.2
931222	AC2-031 E	5.51
931281	AC2-042 C	34.99
931282	AC2-042 E	23.33
931351	AC2-049 C	2.18
931352	AC2-049 E	1.45
931381	AC2-055 C OP	1.33
931382	AC2-055 E OP	2.18
931421	AC2-060 C	3.7
931422	AC2-060 E	2.08
931431	AC2-061 C	9.71
931432	AC2-061 E	9.84
931441	AC2-062 C OP	3.21
931442	AC2-062 E OP	1.44
931451	AC2-064 C	5.11
931452	AC2-064 E	3.41
931651	AC2-087 C OP	2.74
931652	AC2-087 E OP	2.18
247592	W4-036	0.69
924371	AB2-085 C OP	27.11
924372	AB2-085 E OP	12.76

<i>924541</i>	<i>AB2-103 C OP</i>	<i>10.95</i>
<i>924542</i>	<i>AB2-103 E OP</i>	<i>5.15</i>
<i>926061</i>	<i>ACI-085 C</i>	<i>25.4</i>
<i>926062</i>	<i>ACI-085 E</i>	<i>41.44</i>
<i>926101</i>	<i>ACI-089 C</i>	<i>8.57</i>
<i>926102</i>	<i>ACI-089 E</i>	<i>13.99</i>
<i>926631</i>	<i>ACI-144 C</i>	<i>11.25</i>
<i>926632</i>	<i>ACI-144 E</i>	<i>5.46</i>

Appendix 19

(AEP - AEP) The 05HIGHLA 138/69 kV transformer (from bus 246911 to bus 243606 ckt 3) loads from 143.15% to 155.4% (**DC power flow**) of its emergency rating (122 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 14.94 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	1.18
931132	AC2-020 E OP	4.19
931221	AC2-031 C	10.01
931222	AC2-031 E	4.93
931281	AC2-042 C	31.29
931282	AC2-042 E	20.86
931351	AC2-049 C	2.18
931352	AC2-049 E	1.45
931431	AC2-061 C	8.68
931432	AC2-061 E	8.8
931441	AC2-062 C OP	2.76
931442	AC2-062 E OP	1.23
931451	AC2-064 C	5.12
931452	AC2-064 E	3.41
924371	AB2-085 C OP	5.85
924372	AB2-085 E OP	2.75
924541	AB2-103 C OP	3.58
924542	AB2-103 E OP	1.68
926061	AC1-085 C	22.71
926062	AC1-085 E	37.06
926101	AC1-089 C	7.63
926102	AC1-089 E	12.45
926631	AC1-144 C	10.06
926632	AC1-144 E	4.89

Appendix 20

(DEO&K - DEO&K) The 08CLINCO-08WARRN1 138 kV line (from bus 249995 to bus 250122 ckt 1) loads from 130.16% to 148.52% (**DC power flow**) of its emergency rating (198 MVA) for the line fault with failed breaker contingency outage of '8107_C2_05HILLSB 138-C_A'. This project contributes approximately 36.37 MW to the thermal violation.

CONTINGENCY '8107_C2_05HILLSB 138-C_A'

OPEN BRANCH FROM BUS 246911 TO BUS 243019 CKT 1 / 246911
05HIGHLA 138 243019 05HILLSB 138 1

OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	2.88
931221	AC2-031 C	24.37
931222	AC2-031 E	12.
931281	AC2-042 C	76.15
931282	AC2-042 E	50.77
931351	AC2-049 C	5.23
931352	AC2-049 E	3.49
931431	AC2-061 C	29.12
931432	AC2-061 E	29.52
931441	AC2-062 C OP	6.68
931442	AC2-062 E OP	2.99
931451	AC2-064 C	12.27
931452	AC2-064 E	8.18
916272	Z1-080 E	3.83
926061	AC1-085 C	55.28
926062	AC1-085 E	90.19
926101	AC1-089 C	18.57
926102	AC1-089 E	30.29
926631	AC1-144 C	24.48
926632	AC1-144 E	11.89

Appendix 21

(AEP - AEP) The AC2-049 TAP-05MILLBR 138 kV line (from bus 931350 to bus 243042 ckt 1) loads from 128.4% to 147.89% (**DC power flow**) of its emergency rating (179 MVA) for the tower line contingency outage of '7981_B'. This project contributes approximately 34.89 MW to the thermal violation.

CONTINGENCY '7981_B'

OPEN BRANCH FROM BUS 931430 TO BUS 249995 CKT 1 / 931430 AC2-061
TAP 138 249995 08CLINCO 138 1
OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1
OPEN BRANCH FROM BUS 249995 TO BUS 250122 CKT 1 / 249995
08CLINCO 138 250122 08WARRN1 138 1
OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	2.78
931121	AC2-019 C	0.76
931122	AC2-019 E	1.25
931131	AC2-020 C OP	0.59
931132	AC2-020 E OP	1.55
931192	AC2-027 E	2.01
931221	AC2-031 C	23.37
931222	AC2-031 E	11.51
931281	AC2-042 C	73.05
931282	AC2-042 E	48.7
931351	AC2-049 C	20.15
931352	AC2-049 E	13.43
931381	AC2-055 C OP	1.86
931382	AC2-055 E OP	3.04
931421	AC2-060 C	5.36
931422	AC2-060 E	3.02
931431	AC2-061 C	20.27
931432	AC2-061 E	20.55
931441	AC2-062 C OP	6.62
931442	AC2-062 E OP	2.96
931451	AC2-064 C	47.29
931452	AC2-064 E	31.53
931651	AC2-087 C OP	3.97
931652	AC2-087 E OP	3.15
247592	W4-036	1.01
924371	AB2-085 C OP	8.23
924372	AB2-085 E OP	3.87

<i>924541</i>	<i>AB2-103 C OP</i>	<i>5.1</i>
<i>924542</i>	<i>AB2-103 E OP</i>	<i>2.4</i>
<i>926061</i>	<i>ACI-085 C</i>	<i>53.03</i>
<i>926062</i>	<i>ACI-085 E</i>	<i>86.52</i>
<i>926101</i>	<i>ACI-089 C</i>	<i>17.87</i>
<i>926102</i>	<i>ACI-089 E</i>	<i>29.16</i>
<i>926631</i>	<i>ACI-144 C</i>	<i>23.48</i>
<i>926632</i>	<i>ACI-144 E</i>	<i>11.41</i>

Appendix 22

(DEO&K - DEO&K) The AC2-061 TAP-08CLINCO 138 kV line (from bus 931430 to bus 249995 ckt 1) loads from 154.59% to 174.36% (**DC power flow**) of its emergency rating (184 MVA) for the line fault with failed breaker contingency outage of '8107_C2_05HILLSB 138-C_B'. This project contributes approximately 36.37 MW to the thermal violation.

CONTINGENCY '8107_C2_05HILLSB 138-C_B'

OPEN BRANCH FROM BUS 246911 TO BUS 243019 CKT 1 / 246911
05HIGHLA 138 243019 05HILLSB 138 1

OPEN BRANCH FROM BUS 243019 TO BUS 253111 CKT 1 / 243019 05HILLSB
138 253111 09MIDDLE 138 1

OPEN BRANCH FROM BUS 253111 TO BUS 253057 CKT 1 / 253111
09MIDDLE 138 253057 09OHH 138 1

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931022	AC2-008 E	2.88
931221	AC2-031 C	24.37
931222	AC2-031 E	12.
931281	AC2-042 C	76.15
931282	AC2-042 E	50.77
931351	AC2-049 C	5.23
931352	AC2-049 E	3.49
931431	AC2-061 C	29.12
931432	AC2-061 E	29.52
931441	AC2-062 C OP	6.68
931442	AC2-062 E OP	2.99
931451	AC2-064 C	12.27
931452	AC2-064 E	8.18
916272	Z1-080 E	2.17
926061	AC1-085 C	55.28
926062	AC1-085 E	90.19
926101	AC1-089 C	18.57
926102	AC1-089 E	30.29
926631	AC1-144 C	24.48
926632	AC1-144 E	11.89