

Generation Interconnection  
Feasibility Study Report

For

PJM Generation Interconnection Request Queue Position AB1-170

LaSalle—Braidwood

July 2016

**Network Impacts**

The Queue Project AB1-170 was evaluated as a 250.0 MW (Capacity 35.5 MW) injection tapping the LaSalle-Braidwood 345kV line in the COMED area. Project AB1-170 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AB1-170 was studied with a commercial probability of 53%. Potential network impacts were as follows:

**Summer Peak Analysis - 2019**

**Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

None

**Multiple Facility Contingency**

*(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)*

None

**Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

1. (AEP - AEP) The 05OLIVE-X2-052 TAP 345 kV line (from bus 243229 to bus 909144 ckt 2) loads from 102.95% to 103.61% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 21.04 MW to the thermal violation.

CONTINGENCY '2978\_C2\_05DUMONT 765-B\_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END

2. (MISO NIPS - AEP) The 17HIPLE-05COLNGW 345 kV line (from bus 255105 to bus 243214 ckt 1) loads from 104.44% to 104.5% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '7444\_C2\_05DUMONT 765-A2'. This project contributes approximately 19.0 MW to the thermal violation.

CONTINGENCY '7444\_C2\_05DUMONT 765-A2'  
OPEN BRANCH FROM BUS 243206 TO BUS 246999 CKT 1 / 243206 05DUMONT 765 246999 05SORENS 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 243219 CKT 2 / 243206 05DUMONT 765 243219 05DUMONT 345 2  
OPEN BRANCH FROM BUS 243219 TO BUS 909144 CKT 2 / 243219 05DUMONT 345 909144 X2-052 TAP 345 2  
END

3. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 112.27% to 114.72% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 26.74 MW to the thermal violation.

CONTINGENCY '2978\_C2\_05DUMONT 765-B\_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END

4. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 111.62% to 114.09% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 26.97 MW to the thermal violation.

CONTINGENCY '112-65-BT4-5\_\_'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END

5. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 111.58% to 114.05% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 26.96 MW to the thermal violation.

```
CONTINGENCY '112-65-BT3-4__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END
```

6. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 145.47% to 146.74% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 39.83 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

7. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 135.85% to 137.16% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '023-65-BT2-3\_\_'. This project contributes approximately 40.95 MW to the thermal violation.

```
CONTINGENCY '023-65-BT2-3__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765  
END
```

8. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 135.77% to 137.08% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '023-65-BT4-5\_\_'. This project contributes approximately 41.04 MW to the thermal violation.

```
CONTINGENCY '023-65-BT4-5__'  
TRIP BRANCH FROM BUS 275168 TO BUS 270607 CKT 1 / COLLI;2M 345 COLLI; 765  
TRIP BRANCH FROM BUS 275168 TO BUS 270697 CKT 1 / COLLI;2M 345 COLLI; R 345  
TRIP BRANCH FROM BUS 275168 TO BUS 275268 CKT 1 / COLLI;2M 345 COLLI;2C 33  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
END
```

9. (CE - AEP) The WILTON ; -05DUMONT 765 kV line (from bus 270644 to bus 243206 ckt 1) loads from 125.76% to 126.63% (**DC power flow**) of its emergency rating (4444 MVA) for the tower line contingency outage of '345-L94507\_B-S+\_345-L97008\_R-S'. This project contributes approximately 85.86 MW to the thermal violation.

```
CONTINGENCY '345-L94507_B-S+_345-L97008_R-S'  
TRIP BRANCH FROM BUS 274750 TO BUS 255112 CKT 1 / CRETE;BP 345 17STJOHN 345  
TRIP BRANCH FROM BUS 274804 TO BUS 243229 CKT 1 / UPNOR;RP 345 05OLIVE 345  
END
```

10. (CE - AEP) The WILTON ; -05DUMONT 765 kV line (from bus 270644 to bus 243206 ckt 1) loads from 124.27% to 125.14% (**DC power flow**) of its emergency rating (4444 MVA) for the tower line contingency outage of '345-L6607\_\_B-S+\_345-L97008\_R-S'. This project contributes approximately 85.96 MW to the thermal violation.

```
CONTINGENCY '345-L6607__B-S+_345-L97008_R-S'  
TRIP BRANCH FROM BUS 270728 TO BUS 274750 CKT 1 / E FRA; B 345 CRETE;BP 345  
TRIP BRANCH FROM BUS 274804 TO BUS 243229 CKT 1 / UPNOR;RP 345 05OLIVE 345  
END
```

11. (CE - MISO NIPS) The BURNHAM ; B-17SHEFFIELD 345 kV line (from bus 270674 to bus 255111 ckt 1) loads from 132.7% to 133.79% (**DC power flow**) of its emergency rating (1069 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 25.92 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

12. (CE - MISO NIPS) The BURNHAM ; B-17SHEFFIELD 345 kV line (from bus 270674 to bus 255111 ckt 1) loads from 132.49% to 133.58% (**DC power flow**) of its emergency rating (1069 MVA) for the line fault with failed breaker contingency outage of '023-65-BT2-3\_\_'. This project contributes approximately 25.93 MW to the thermal violation.

```
CONTINGENCY '023-65-BT2-3__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765
```

END

13. (CE - MISO NIPS) The BURNHAM ; B-17SHEFFIELD 345 kV line (from bus 270674 to bus 255111 ckt 1) loads from 132.15% to 133.25% (**DC power flow**) of its emergency rating (1069 MVA) for the line fault with failed breaker contingency outage of '023-65-BT4-5\_\_'. This project contributes approximately 26.19 MW to the thermal violation.

CONTINGENCY '023-65-BT4-5\_\_'  
TRIP BRANCH FROM BUS 275168 TO BUS 270607 CKT 1 / COLLI;2M 345 COLLI; 765  
TRIP BRANCH FROM BUS 275168 TO BUS 270697 CKT 1 / COLLI;2M 345 COLLI; R 345  
TRIP BRANCH FROM BUS 275168 TO BUS 275268 CKT 1 / COLLI;2M 345 COLLI;2C 33  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
END

14. (CE - MISO NIPS) The BURNHAM ;0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 122.82% to 124.04% (**DC power flow**) of its emergency rating (1195 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 32.4 MW to the thermal violation.

CONTINGENCY '2978\_C2\_05DUMONT 765-B\_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END

15. (CE - MISO NIPS) The BURNHAM ;0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 122.78% to 124.0% (**DC power flow**) of its emergency rating (1195 MVA) for the line fault with failed breaker contingency outage of '023-65-BT2-3\_\_'. This project contributes approximately 32.38 MW to the thermal violation.

CONTINGENCY '023-65-BT2-3\_\_'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765  
END

16. (CE - MISO NIPS) The BURNHAM ;0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 122.3% to 123.53% (**DC power flow**) of its emergency rating (1195 MVA) for the line fault with failed breaker contingency outage of '023-65-BT4-5\_\_'. This project contributes approximately 32.69 MW to the thermal violation.

CONTINGENCY '023-65-BT4-5\_\_'

TRIP BRANCH FROM BUS 275168 TO BUS 270607 CKT 1 / COLLI;2M 345 COLLI; 765  
 TRIP BRANCH FROM BUS 275168 TO BUS 270697 CKT 1 / COLLI;2M 345 COLLI; R 345  
 TRIP BRANCH FROM BUS 275168 TO BUS 275268 CKT 1 / COLLI;2M 345 COLLI;2C 33  
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
 END

17. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 110.77% to 111.86% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 23.47 MW to the thermal violation.

CONTINGENCY '2978\_C2\_05DUMONT 765-B\_A'  
 OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
 OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
 END

18. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 103.69% to 104.8% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 23.77 MW to the thermal violation.

CONTINGENCY '112-65-BT4-5\_\_'  
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
 END

19. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 103.69% to 104.8% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 23.77 MW to the thermal violation.

CONTINGENCY '112-65-BT3-4\_\_'  
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
 END

20. (CE - MISO NIPS) The ST JOHN ; T-17GREEN\_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 112.27% to 114.72% (**DC power flow**) of its emergency rating

(1091 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 26.74 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

21. (CE - MISO NIPS) The ST JOHN ; T-17GREEN\_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 111.62% to 114.09% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 26.97 MW to the thermal violation.

```
CONTINGENCY '112-65-BT4-5__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END
```

22. (CE - MISO NIPS) The ST JOHN ; T-17GREEN\_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 111.58% to 114.05% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 26.96 MW to the thermal violation.

```
CONTINGENCY '112-65-BT3-4__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END
```

23. (CE - CE) The WILTON ; B-WILTON ;3M 345 kV line (from bus 270926 to bus 275232 ckt 1) loads from 138.03% to 139.06% (**DC power flow**) of its emergency rating (1601 MVA) for the line fault with failed breaker contingency outage of '112-65-BT5-6\_\_'. This project contributes approximately 36.59 MW to the thermal violation.

```
CONTINGENCY '112-65-BT5-6__'  
TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END
```

24. (CE - CE) The WILTON ; R-WILTON ;4M 345 kV line (from bus 270927 to bus 275233 ckt 1) loads from 141.7% to 142.75% (**DC power flow**) of its emergency rating (1601 MVA) for the line fault with failed breaker contingency outage of '112-65-BT2-3\_\_'. This project contributes approximately 37.37 MW to the thermal violation.

```
CONTINGENCY '112-65-BT2-3__'
TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1      / WILTO; 765 COLLI; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1      / WILTO;3M 345 WILTO; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1      / WILTO;3M 345 WILTO; B 345
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1      / WILTO;3M 345 WILTO;3C 33
END
```

25. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 143.19% to 145.95% (**DC power flow**) of its emergency rating (1390 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 38.36 MW to the thermal violation.

```
CONTINGENCY '112-65-BT4-5__'
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1      / WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1      / WILTO;4M 345 WILTO; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1      / WILTO;4M 345 WILTO; R 345
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1      / WILTO;4M 345 WILTO;4C 33
END
```

26. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 143.16% to 145.9% (**DC power flow**) of its emergency rating (1390 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 38.11 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1      / 243206 05DUMONT 765 907040 X1-020 TAP 765 1
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1      / 243206 05DUMONT 765 270644 WILTON ; 765 1
END
```

27. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 143.12% to 145.88% (**DC power flow**) of its emergency rating (1390

MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 38.36 MW to the thermal violation.

```
CONTINGENCY '112-65-BT3-4__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END
```

28. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 138.8% to 140.15% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 29.05 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

29. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 137.6% to 138.96% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 29.32 MW to the thermal violation.

```
CONTINGENCY '112-65-BT4-5__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END
```

30. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 137.56% to 138.92% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 29.32 MW to the thermal violation.

```
CONTINGENCY '112-65-BT3-4__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END
```

31. (CE - CE) The WILTON ; 765/345 kV transformer (from bus 275232 to bus 270644 ckt 1) loads from 127.61% to 128.64% (**DC power flow**) of its emergency rating (1601 MVA) for the line fault with failed breaker contingency outage of '112-65-BT5-6\_\_'. This project contributes approximately 36.59 MW to the thermal violation.

```
CONTINGENCY '112-65-BT5-6__'
TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1      / WILTO; 765 COLLI; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1      / WILTO;4M 345 WILTO; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1      / WILTO;4M 345 WILTO; R 345
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1      / WILTO;4M 345 WILTO;4C 33
END
```

32. (CE - CE) The WILTON ; 765/345 kV transformer (from bus 275233 to bus 270644 ckt 1) loads from 130.25% to 131.31% (**DC power flow**) of its emergency rating (1601 MVA) for the line fault with failed breaker contingency outage of '112-65-BT2-3\_\_'. This project contributes approximately 37.37 MW to the thermal violation.

```
CONTINGENCY '112-65-BT2-3__'
TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1      / WILTO; 765 COLLI; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1      / WILTO;3M 345 WILTO; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1      / WILTO;3M 345 WILTO; B 345
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1      / WILTO;3M 345 WILTO;3C 33
END
```

33. (AEP - AEP) The X2-052 TAP-05DUMONT 345 kV line (from bus 909144 to bus 243219 ckt 2) loads from 126.56% to 127.23% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 21.04 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1      / 243206 05DUMONT 765 907040 X1-020 TAP 765 1
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1      / 243206 05DUMONT 765 270644 WILTON ; 765 1
END
```

34. (AEP - AEP) The X2-052 TAP-05DUMONT 345 kV line (from bus 909144 to bus 243219 ckt 2) loads from 116.91% to 117.65% (**DC power flow**) of its emergency rating (1409 MVA)

for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 22.93 MW to the thermal violation.

```
CONTINGENCY '112-65-BT4-5__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END
```

35. (AEP - AEP) The X2-052 TAP-05DUMONT 345 kV line (from bus 909144 to bus 243219 ckt 2) loads from 116.9% to 117.64% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 22.93 MW to the thermal violation.

```
CONTINGENCY '112-65-BT3-4__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END
```

### **Steady-State Voltage Requirements**

*(Results of the steady-state voltage studies should be inserted here)*

To be determined

### **Short Circuit**

*(Summary of impacted circuit breakers)*

To be determined

### **Affected System Analysis & Mitigation**

#### **External PJM Impacts:**

External PJM Impacts with MISO to be determined during later study phases.

### **Delivery of Energy Portion of Interconnection Request**

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under

study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

1. (AEP - AEP) The 05DUMONT-05SORENS 765 kV line (from bus 243206 to bus 246999 ckt 1) loads from 101.82% to 101.88% (**DC power flow**) of its normal rating (4257 MVA) for the single line contingency outage of '709\_B2\_TOR546'. This project contributes approximately 59.49 MW to the thermal violation.

```
CONTINGENCY '709_B2_TOR546'  
OPEN BRANCH FROM BUS 242924 TO BUS 243208 CKT 1 / 242924 05HANG R 765 243208 05JEFRSO 765 1  
END
```

2. (MISO NIPS - AEP) The 17HIPLE-05COLNGW 345 kV line (from bus 255105 to bus 243214 ckt 1) loads from 103.15% to 103.21% (**DC power flow**) of its normal rating (1409 MVA) for the single line contingency outage of '7442\_B2\_TOR200545'. This project contributes approximately 18.82 MW to the thermal violation.

```
CONTINGENCY '7442_B2_TOR200545'  
OPEN BRANCH FROM BUS 243206 TO BUS 246999 CKT 1 / 243206 05DUMONT 765 246999 05SORENS 765 1  
END
```

3. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 111.12% to 113.59% (**DC power flow**) of its emergency rating (1091 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 26.92 MW to the thermal violation.

```
CONTINGENCY '695_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END
```

4. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 135.54% to 136.85% (**DC power flow**) of its normal rating (1409 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 41.02 MW to the thermal violation.

```
CONTINGENCY '695_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
```

END

5. (CE - CE) The COLLINS ; -WILTON ; 765 kV line (from bus 270607 to bus 270644 ckt 1) loads from 107.81% to 108.39% (**DC power flow**) of its normal rating (4142 MVA) for non-contingency condition. This project contributes approximately 53.44 MW to the thermal violation.

6. (CE - CE) The COLLINS ; -WILTON ; 765 kV line (from bus 270607 to bus 270644 ckt 1) loads from 105.01% to 106.32% (**DC power flow**) of its emergency rating (4460 MVA) for the single line contingency outage of '345-L16703\_R-S'. This project contributes approximately 58.24 MW to the thermal violation.

CONTINGENCY '345-L16703\_R-S'  
TRIP BRANCH FROM BUS 270846 TO BUS 270847 CKT 1 / PLANO ; B 345 PLANO ; R 345  
TRIP BRANCH FROM BUS 270847 TO BUS 270733 CKT 1 / PLANO ; R 345 ELEC JUNC;3R 345  
END

7. (CE - AEP) The WILTON ; -05DUMONT 765 kV line (from bus 270644 to bus 243206 ckt 1) loads from 128.71% to 129.58% (**DC power flow**) of its normal rating (4047 MVA) for the single line contingency outage of '238\_B3'. This project contributes approximately 78.81 MW to the thermal violation.

CONTINGENCY '238\_B3'  
OPEN BRANCH FROM BUS 243219 TO BUS 255113 CKT 1 / 243219 05DUMONT 345 255113 17STILLWELL 345 1  
OPEN BRANCH FROM BUS 255100 TO BUS 255113 CKT 1 / 255100 17BABCOCK 345 255113 17STILLWELL 345 1  
OPEN BRANCH FROM BUS 255113 TO BUS 255180 CKT 1 / 255113 17STILLWELL 345 255180 17STILLWELL 138 1  
END

8. (CE - MISO NIPS) The BURNHAM ; B-17SHEFFIELD 345 kV line (from bus 270674 to bus 255111 ckt 1) loads from 131.34% to 132.44% (**DC power flow**) of its emergency rating (1069 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 26.13 MW to the thermal violation.

CONTINGENCY '695\_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

9. (CE - MISO NIPS) The BURNHAM ; 0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 121.46% to 122.69% (**DC power flow**) of its emergency rating (1195

MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 32.63 MW to the thermal violation.

CONTINGENCY '695\_B2'

OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

10. (CE - CE) The DAVIS CRK; B 345/138 kV transformer (from bus 270710 to bus 275174 ckt 1) loads from 122.26% to 124.01% (**DC power flow**) of its emergency rating (480 MVA) for the single line contingency outage of '345-L2004\_\_R-S'. This project contributes approximately 18.63 MW to the thermal violation.

CONTINGENCY '345-L2004\_\_R-S'

TRIP BRANCH FROM BUS 270671 TO BUS 270670 CKT 1 / BRAID; R 345 BRAID; B 345  
TRIP BRANCH FROM BUS 270671 TO BUS 270711 CKT 1 / BRAID; R 345 DAVIS; R 345  
END

11. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 123.09% to 125.76% (**DC power flow**) of its emergency rating (1399 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 38.67 MW to the thermal violation.

CONTINGENCY '695\_B2'

OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

12. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 103.63% to 104.73% (**DC power flow**) of its normal rating (971 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 23.76 MW to the thermal violation.

CONTINGENCY '695\_B2'

OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

13. (CE - CE) The PLANO ; B-ELECT JCT; B 345 kV line (from bus 270846 to bus 270730 ckt 1) loads from 102.8% to 104.86% (**DC power flow**) of its emergency rating (1341 MVA) for the single line contingency outage of '765-L11216\_\_-S'. This project contributes approximately 27.54 MW to the thermal violation.

CONTINGENCY '765-L11216\_\_-S'

TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765  
END

14. (CE - MISO NIPS) The ST JOHN ; T-17GREEN\_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 111.12% to 113.59% (**DC power flow**) of its emergency rating (1091 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 26.92 MW to the thermal violation.

CONTINGENCY '695\_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

15. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 142.33% to 145.08% (**DC power flow**) of its emergency rating (1390 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 38.27 MW to the thermal violation.

CONTINGENCY '695\_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

16. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 137.09% to 138.45% (**DC power flow**) of its normal rating (971 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 29.28 MW to the thermal violation.

CONTINGENCY '695\_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

17. (CE - CE) The DAVIS CRK;3M-DAVIS CRK; B 138 kV line (from bus 275174 to bus 271294 ckt 1) loads from 122.24% to 123.99% (**DC power flow**) of its emergency rating (480 MVA) for the single line contingency outage of '345-L2004\_\_R-S'. This project contributes approximately 18.63 MW to the thermal violation.

CONTINGENCY '345-L2004\_\_R-S'  
TRIP BRANCH FROM BUS 270671 TO BUS 270670 CKT 1 / BRAID; R 345 BRAID; B 345  
TRIP BRANCH FROM BUS 270671 TO BUS 270711 CKT 1 / BRAID; R 345 DAVIS; R 345  
END

18. (AEP - AEP) The X2-052 TAP-05DUMONT 345 kV line (from bus 909144 to bus 243219 ckt 2) loads from 116.75% to 117.48% (**DC power flow**) of its normal rating (1409 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 22.91 MW to the thermal violation.

CONTINGENCY '695\_B2'

OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

## **Light Load Analysis - 2019**

Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).

## **System Reinforcements**

### **Short Circuit**

*(Summary form of Cost allocation for breakers will be inserted here if any)*

None.

### **Stability and Reactive Power Requirement**

*(Results of the dynamic studies should be inserted here)*

To be determined

## **Summer Peak Load Flow Analysis Reinforcements**

### **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None

### **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

*(Summary form of Cost allocation for transmission lines and transformers will be inserted here if any)*

1. (AEP - AEP) The 05OLIVE-X2-052 TAP 345 kV line (from bus 243229 to bus 909144 ckt 2) loads from 102.95% to 103.61% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 21.04 MW to the thermal violation.

Reinforcement: A sag check will be required for the ACSR ~ 954 ~ 45/7 ~ RAIL Conductor Section 1 to determine if the line section can be operated above its emergency rating of 1409 MVA. The result could prove that no additional upgrades are necessary, that some upgrades on the circuit are necessary, or that the entire 14 mile section of line would need to be rebuilt. If deemed necessary to rebuild section of line

Cost: \$56,000-Sag study. \$28,000,000-Line rebuild

Time: 6 to 12 months-sag study. 24 to 36 months-sag study

2. (MISO NIPS - AEP) The 17HIPLE-05COLNGW 345 kV line (from bus 255105 to bus 243214 ckt 1) loads from 104.44% to 104.5% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '7444\_C2\_05DUMONT 765-A2'. This project contributes approximately 19.0 MW to the thermal violation.

AEP

Reinforcement: A Sag Study will be required on the 33.46 mile section of line to mitigate the overload on the Collingwood - Hiple 345 kV line.

Cost: Depending on the sag study results, cost for this upgrade is expected to be between \$133,840 (no remediations required just sag study) and \$67 million (complete line rebuild required).

Time: 6 to 12 months-sag study. 24 to 36 months-line rebuild

NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

3. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 112.27% to 114.72% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 26.74 MW to the thermal violation.

ComEd

ComEd 345kV L6617 SLD rating is 1237 MVA. No upgrade required.

NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

4. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 111.62% to 114.09% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 26.97 MW to the thermal violation.

Comed

ComEd 345kV L6617 SLD rating is 1237 MVA. No upgrade required.

NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

5. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 111.58% to 114.05% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 26.96 MW to the thermal violation.

Comed

ComEd 345kV L6617 SLD rating is 1237 MVA. No upgrade required.

NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

6. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 145.47% to 146.74% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 39.83 MW to the thermal violation.

AEP

Reinforcement: A sag check will be required for the ACSR ~ 954 ~ 45/7 ~ RAIL Conductor Section 1 to determine if the line section can be operated above its emergency rating of 1409 MVA. The result could prove that no additional upgrades are necessary, that some upgrades on the circuit are necessary, or that the entire 9 mile section of line would need to be rebuilt.

Replace the Dumont Wavetrap (2500 A)

Cost: \$40,000-sag study. \$18,000,000-line rebuild. \$300,000-Dumont Wave trap replacement

Time: 6 to 12 months-sag study. 24 to 36 months-line rebuild.

NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

7. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 135.85% to 137.16% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '023-65-BT2-3\_\_'. This project contributes approximately 40.95 MW to the thermal violation.

Same as Contribution to Previously Identified Overloads #6  
NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

8. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 135.77% to 137.08% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '023-65-BT4-5\_\_'. This project contributes approximately 41.04 MW to the thermal violation.

Same as Contribution to Previously Identified Overloads #6  
NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

9. (CE - AEP) The WILTON ;-05DUMONT 765 kV line (from bus 270644 to bus 243206 ckt 1) loads from 125.76% to 126.63% (**DC power flow**) of its emergency rating (4444 MVA) for the tower line contingency outage of '345-L94507\_B-S+\_345-L97008\_R-S'. This project contributes approximately 85.86 MW to the thermal violation.

Comed

Reinforcement: ComEd 765kV L11215. SLD is 4802 MVA. The relay thermal for this line is 5466 MVA. Based on the contingency above, the overload exceeds the relay thermal rating therefore the upgrade will be a new 765kV line. Contingent upon procurement of a right of way assuming the current right of way containing L11215 does not have land.

Cost: \$300M

Time: 36 months

AEP

Reinforcement: AEP rating of Dumont - Wilton Center 765 kV tie is S/N: 3555 MVA and S/E: 4105 MVA. The Dumont Wavetrap (2500A) will have to be replaced;

Cost: \$500,000.

Time: 12-24 months

10. (CE - AEP) The WILTON ;-05DUMONT 765 kV line (from bus 270644 to bus 243206 ckt 1) loads from 124.27% to 125.14% (**DC power flow**) of its emergency rating (4444 MVA) for

the tower line contingency outage of '345-L6607\_\_B-S+\_345-L97008\_R-S'. This project contributes approximately 85.96 MW to the thermal violation.

Same as Contribution to Previously Identified Overloads #9

11. (CE - MISO NIPS) The BURNHAM ; B-17SHEFFIELD 345 kV line (from bus 270674 to bus 255111 ckt 1) loads from 132.7% to 133.79% (**DC power flow**) of its emergency rating (1069 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 25.92 MW to the thermal violation.

ComEd

ComEd 345kV L17705 SLD rating is 1768 MVA. No upgrade required.

NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

12. (CE - MISO NIPS) The BURNHAM ; B-17SHEFFIELD 345 kV line (from bus 270674 to bus 255111 ckt 1) loads from 132.49% to 133.58% (**DC power flow**) of its emergency rating (1069 MVA) for the line fault with failed breaker contingency outage of '023-65-BT2-3\_\_'. This project contributes approximately 25.93 MW to the thermal violation.

Same as Contribution to Previously Identified Overload #11

13. (CE - MISO NIPS) The BURNHAM ; B-17SHEFFIELD 345 kV line (from bus 270674 to bus 255111 ckt 1) loads from 132.15% to 133.25% (**DC power flow**) of its emergency rating (1069 MVA) for the line fault with failed breaker contingency outage of '023-65-BT4-5\_\_'. This project contributes approximately 26.19 MW to the thermal violation.

Same as Contribution to Previously Identified Overload #11

14. (CE - MISO NIPS) The BURNHAM ;0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 122.82% to 124.04% (**DC power flow**) of its emergency rating (1195 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT

ComEd

ComEd 345kV L17703 SLD rating is 1768 MVA. No upgrade required.

NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

15. (CE - MISO NIPS) The BURNHAM ;0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 122.78% to 124.0% (**DC power flow**) of its emergency rating (1195 MVA) for the line fault with failed breaker contingency outage of '023-65-BT2-3\_\_'. This project contributes approximately 32.38 MW to the thermal violation.

Same as Contribution to Previously Identified Overload #14

16. (CE - MISO NIPS) The BURNHAM ;0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 122.3% to 123.53% (**DC power flow**) of its emergency rating (1195 MVA) for the line fault with failed breaker contingency outage of '023-65-BT4-5\_\_'. This project contributes approximately 32.69 MW to the thermal violation.

Same as Contribution to Previously Identified Overload #14

17. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 110.77% to 111.86% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 23.47 MW to the thermal violation.

ComEd

The ComEd facility is 345kV L6615. The ComEd SLD rating of 1237 MVA (ALDR is 1423 MVA). No ComEd upgrade required.

AEP

Reinforcement: Olive - Green Acres 345 kV line is a sag derated tie line and thus a sag check will be required for the entire 40.64 miles of ACSR/PE ~ 1414 ~ 62/19 Conductor section 1 to determine if the line can be operated above its emergency rating 971 MVA. If deemed necessary to rebuild the entire 40.64 miles of the section of the line.

Cost: \$162,560-sag study. \$81,280,000 line rebuild.

Time: 6-12months-sag study. 24-36 months line rebuild.

18. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 103.69% to 104.8% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 23.77 MW to the thermal violation.

Same as Contribution to Previously Identified Overloads #17

19. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 103.69% to 104.8% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 23.77 MW to the thermal violation.

Same as Contribution to Previously Identified Overloads #17

20. (CE - MISO NIPS) The ST JOHN ; T-17GREEN\_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 112.27% to 114.72% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 26.74 MW to the thermal violation.

Comed

The ComEd facility is 345kV L6617. The SLD rating of 1237 MVA (ALDR is 1423 MVA). No upgrade required.

NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

21. (CE - MISO NIPS) The ST JOHN ; T-17GREEN\_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 111.62% to 114.09% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 26.97 MW to the thermal violation.

Same as Contribution to Previously Identified Overloads #20

22. (CE - MISO NIPS) The ST JOHN ; T-17GREEN\_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 111.58% to 114.05% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 26.96 MW to the thermal violation.

Same as Contribution to Previously Identified Overloads #20

23. (CE - CE) The WILTON ; B-WILTON ;3M 345 kV line (from bus 270926 to bus 275232 ckt 1) loads from 138.03% to 139.06% (**DC power flow**) of its emergency rating (1601 MVA) for the line fault with failed breaker contingency outage of '112-65-BT5-6\_\_'. This project contributes approximately 36.59 MW to the thermal violation.

Reinforcement: The limit is Tr. 93 @ TSS 112 Wilton Center. The SLD is 1601 MVA (ALDR is 1841 MVA). Upgrade required at TSS 112 Wilton Center. Relocate 765kV L11216 from Bus 6 to Bus 8. Build out the 765kV bus and install 2 new 765kV Bus Tie CB's (BT 6-8 & 8-2), upgrade Tr. 93 station conductor and upgrade Tr. 93 forward relay trip setting. Upon completion the new ratings will be 1248/1479/1982 MVA, SN/SE/SLD (ALDR of 2279 MVA).

Cost: \$13M

Time: 24-30 months

24. (CE - CE) The WILTON ; R-WILTON ;4M 345 kV line (from bus 270927 to bus 275233 ckt 1) loads from 141.7% to 142.75% (**DC power flow**) of its emergency rating (1601 MVA) for the line fault with failed breaker contingency outage of '112-65-BT2-3\_\_'. This project contributes approximately 37.37 MW to the thermal violation.

Reinforcement: The limit is Tr. 94 @ TSS 112 Wilton Center.

The SLD is 1601 MVA (ALDR is 1841 MVA). Upgrade required at TSS 112 Wilton Center. Relocate 765kV L11216 from Bus 6 to Bus 8. Build out the 765kV bus and install 2 new 765kV Bus Tie CB's (BT 6-8 & 8-2) and upgrade Tr. 93 station conductor at TSS 112, Tr. 94 CT upgrades and Forward Relay Trip reviewed and upgraded. The new ratings would be 1248/1479/2221 MVA SN/SE/SLD (ALDR of 2390 MVA).

Cost: \$13M

Time: 24-30 months.

25. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 143.19% to 145.95% (**DC power flow**) of its emergency rating (1390 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 38.36 MW to the thermal violation.

ComEd

Reinforcement: The limiting element is 345kV L94507. ComEd SLD is 1674 MVA (ALDR for L94507 is 1925 MVA). Upgrade L94507 1414 kcmil paper expanded conductor to 2156 kcmil. Upon field completion, the ratings will be 1091/1399/2084 MVA SN/SE/SLD.

Cost: \$17.2M

Time: 24-30 months.

NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

26. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 143.16% to 145.9% (**DC power flow**) of its emergency rating (1390 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 38.11 MW to the thermal violation.

Comed

Reinforcement: The limiting element is 345kV L94507. ComEd SLD is 1674 MVA (ALDR for L94507 is 1925 MVA). Upgrade L94507 1414 kcmil paper expanded conductor to 2156 kcmil. Upon field completion, the ratings will be 1091/1399/2084 MVA SN/SE/SLD.

Cost: \$17.2M

Time: 24-30 months.

NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

27. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 143.12% to 145.88% (**DC power flow**) of its emergency rating (1390 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 38.36 MW to the thermal violation.

Comed

Reinforcement: The limiting element is 345kV L94507. ComEd SLD is 1674 MVA (ALDR for L94507 is 1925 MVA). Upgrade L94507 1414 kcmil paper expanded conductor to 2156 kcmil. Upon field completion, the ratings will be 1091/1399/2084 MVA SN/SE/SLD.

Cost: \$17.2M

Time: 24-30 months.

NIPSCO (MISO) will have to evaluate this violation during the SIS phase.

28. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 138.8% to 140.15% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 29.05 MW to the thermal violation.

Comed

The limiting element is 345kV L97008. ComEd SLD rating for L97008 is 1237 MVA (ALDR is 1423 MVA). The post contingency flow is below the line ALDR therefore no upgrade is required.

## AEP

Reinforcement: A sag check will be required for the AEP owned section of the Olive - University Park (CE) 345 kV line to determine if the line section can be operated above its emergency rating of 971 MVA. The result could prove that no additional upgrades are necessary, that some upgrades on the circuit are necessary, or that the entire 40.61 mile section of line would need to be rebuilt. The Olive switches to Line Riser will have to be replaced. For Olive RCTL, an engineering study will need to be conducted to determine if the Relay Compliance Trip limits settings can be adjusted to mitigate the overload. New relay packages will be required if the settings cannot be adjusted

Cost: \$162,440-sag study. \$81,220,000- reconductor/rebuild AEP section of line. \$1,400,000-Olive switches. :\$600,000-Relays

Time: 6-12 months sag study. 24-36 months-line rebuild.

29. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 137.6% to 138.96% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 29.32 MW to the thermal violation.

Same as Contribution to Previously Identified Overloads #28

30. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 137.56% to 138.92% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 29.32 MW to the thermal violation.

Same as Contribution to Previously Identified Overloads #28

31. (CE - CE) The WILTON ; 765/345 kV transformer (from bus 275232 to bus 270644 ckt 1) loads from 127.61% to 128.64% (**DC power flow**) of its emergency rating (1601 MVA) for the line fault with failed breaker contingency outage of '112-65-BT5-6\_\_'. This project contributes approximately 36.59 MW to the thermal violation.

## Comed

Reinforcement: The limit is Tr. 93 @ TSS 112 Wilton Center.

The SLD is 1601 MVA (ALDR is 1841 MVA). Upgrade required at TSS 112 Wilton Center. Relocate 765kV L11216 from Bus 6 to Bus 8. Build out the 765kV bus and install 2 new 765kV Bus Tie CB's (BT 6-8 & 8-2) and upgrade Tr. 93 station conductor. Upon completion the new ratings will be 1248/1479/1867 MVA, SN/SE/SLD (ALDR of 2147 MVA).

Cost: \$12M  
Time: 24-30 months.

32. (CE - CE) The WILTON ; 765/345 kV transformer (from bus 275233 to bus 270644 ckt 1) loads from 130.25% to 131.31% (**DC power flow**) of its emergency rating (1601 MVA) for the line fault with failed breaker contingency outage of '112-65-BT2-3\_\_'. This project contributes approximately 37.37 MW to the thermal violation.

Comed

Reinforcement: The limit is Tr. 94 @ TSS 112 Wilton Center.

The SLD is 1601 MVA (ALDR is 1841 MVA). Upgrade required at TSS 112 Wilton Center.

Relocate 765kV L11216 from Bus 6 to Bus 8. Build out the 765kV bus and install 2 new 765kV Bus Tie CB's (BT 6-8 & 8-2) and upgrade Tr. 93 station conductor at TSS 112. The new ratings would be 1248/1479/1867 MVA SN/SE/SLD (ALDR of 2147 MVA).

Cost: \$12M

Time: 24-30 months.

33. (AEP - AEP) The X2-052 TAP-05DUMONT 345 kV line (from bus 909144 to bus 243219 ckt 2) loads from 126.56% to 127.23% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 21.04 MW to the thermal violation.

AEP

Reinforcement: A sag check will be required for the ACSR ~ 954 ~ 45/7 ~ RAIL Conductor Section 1 to determine if the line section can be operated above its emergency rating of 1409 MVA. The result could prove that no additional upgrades are necessary, that some upgrades on the circuit are necessary, or that the entire 14 mile section of line would need to be rebuilt.. If deemed necessary to rebuild section of line,

Cost: \$56,000 Sag Study. \$28,000,000. Line rebuild

Time: 6-12 months sag study. 24-36 months for line rebuild

34. (AEP - AEP) The X2-052 TAP-05DUMONT 345 kV line (from bus 909144 to bus 243219 ckt 2) loads from 116.91% to 117.65% (**DC power flow**) of its emergency rating (1409 MVA)

for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 22.93 MW to the thermal violation.

Same as Contribution to Previously Identified Overloads #33

35. (AEP - AEP) The X2-052 TAP-05DUMONT 345 kV line (from bus 909144 to bus 243219 ckt 2) loads from 116.9% to 117.64% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 22.93 MW to the thermal violation.

Same as Contribution to Previously Identified Overloads #33

## Network Impacts for Secondary POI

The Queue Project AB1-170 was evaluated as a 250.0 MW (Capacity 35.5 MW) injection LaSalle 345kV substation in the COMED area. Project AB1-170 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AB1-170 was studied with a commercial probability of 53%. Potential network impacts were as follows:

## Summer Peak Analysis - 2019

### Generator Deliverability

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

None

### Multiple Facility Contingency

*(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)*

None

### Contribution to Previously Identified Overloads

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

1. (AEP - AEP) The 05OLIVE-X2-052 TAP 345 kV line (from bus 243229 to bus 909144 ckt 2) loads from 103.08% to 103.73% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 20.76 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

2. (MISO NIPS - AEP) The 17HIPLE-05COLNGW 345 kV line (from bus 255105 to bus 243214 ckt 1) loads from 104.55% to 104.61% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '7444\_C2\_05DUMONT 765-A2'. This project contributes approximately 18.8 MW to the thermal violation.

```
CONTINGENCY '7444_C2_05DUMONT 765-A2'  
OPEN BRANCH FROM BUS 243206 TO BUS 246999 CKT 1 / 243206 05DUMONT 765 246999 05SORENS 765 1
```

OPEN BRANCH FROM BUS 243206 TO BUS 243219 CKT 2 / 243206 05DUMONT 765 243219 05DUMONT 345 2  
OPEN BRANCH FROM BUS 243219 TO BUS 909144 CKT 2 / 243219 05DUMONT 345 909144 X2-052 TAP 345 2  
END

3. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 112.41% to 114.81% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 26.1 MW to the thermal violation.

CONTINGENCY '2978\_C2\_05DUMONT 765-B\_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END

4. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 111.77% to 114.18% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 26.34 MW to the thermal violation.

CONTINGENCY '112-65-BT4-5\_\_'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END

5. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 111.73% to 114.14% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 26.33 MW to the thermal violation.

CONTINGENCY '112-65-BT3-4\_\_'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END

6. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 145.76% to 147.02% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 39.48 MW to the thermal violation.

CONTINGENCY '2978\_C2\_05DUMONT 765-B\_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END

7. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 136.03% to 137.33% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '023-65-BT4-5\_\_'. This project contributes approximately 40.64 MW to the thermal violation.

```
CONTINGENCY '023-65-BT4-5__'  
TRIP BRANCH FROM BUS 275168 TO BUS 270607 CKT 1 / COLLI;2M 345 COLLI; 765  
TRIP BRANCH FROM BUS 275168 TO BUS 270697 CKT 1 / COLLI;2M 345 COLLI; R 345  
TRIP BRANCH FROM BUS 275168 TO BUS 275268 CKT 1 / COLLI;2M 345 COLLI;2C 33  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
END
```

8. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 135.86% to 137.15% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '023-65-BT2-3\_\_'. This project contributes approximately 40.52 MW to the thermal violation.

```
CONTINGENCY '023-65-BT2-3__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765  
END
```

9. (CE - AEP) The WILTON ; -05DUMONT 765 kV line (from bus 270644 to bus 243206 ckt 1) loads from 125.96% to 126.85% (**DC power flow**) of its emergency rating (4444 MVA) for the tower line contingency outage of '345-L94507\_B-S+\_345-L97008\_R-S'. This project contributes approximately 88.51 MW to the thermal violation.

```
CONTINGENCY '345-L94507_B-S+_345-L97008_R-S'  
TRIP BRANCH FROM BUS 274750 TO BUS 255112 CKT 1 / CRETE;BP 345 17STJOHN 345  
TRIP BRANCH FROM BUS 274804 TO BUS 243229 CKT 1 / UPNOR;RP 345 05OLIVE 345  
END
```

10. (CE - AEP) The WILTON ; -05DUMONT 765 kV line (from bus 270644 to bus 243206 ckt 1) loads from 124.46% to 125.36% (**DC power flow**) of its emergency rating (4444 MVA) for the tower line contingency outage of '345-L6607\_\_B-S+\_345-L97008\_R-S'. This project contributes approximately 88.61 MW to the thermal violation.

```
CONTINGENCY '345-L6607__B-S+_345-L97008_R-S'  
TRIP BRANCH FROM BUS 270728 TO BUS 274750 CKT 1 / E FRA; B 345 CRETE;BP 345  
TRIP BRANCH FROM BUS 274804 TO BUS 243229 CKT 1 / UPNOR;RP 345 05OLIVE 345  
END
```

11. (CE - MISO NIPS) The BURNHAM ; B-17SHEFFIELD 345 kV line (from bus 270674 to bus 255111 ckt 1) loads from 127.63% to 128.71% (**DC power flow**) of its emergency rating

(1069 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 25.79 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1      / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1      / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

12. (CE - MISO NIPS) The BURNHAM ; B-17SHEFFIELD 345 kV line (from bus 270674 to bus 255111 ckt 1) loads from 127.4% to 128.48% (**DC power flow**) of its emergency rating (1069 MVA) for the line fault with failed breaker contingency outage of '023-65-BT2-3\_\_'. This project contributes approximately 25.72 MW to the thermal violation.

```
CONTINGENCY '023-65-BT2-3__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1      / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1      / COLLI; 765 PLANO; 765  
END
```

13. (CE - MISO NIPS) The BURNHAM ; B-17SHEFFIELD 345 kV line (from bus 270674 to bus 255111 ckt 1) loads from 127.03% to 128.12% (**DC power flow**) of its emergency rating (1069 MVA) for the line fault with failed breaker contingency outage of '023-65-BT4-5\_\_'. This project contributes approximately 26.07 MW to the thermal violation.

```
CONTINGENCY '023-65-BT4-5__'  
TRIP BRANCH FROM BUS 275168 TO BUS 270607 CKT 1      / COLLI;2M 345 COLLI; 765  
TRIP BRANCH FROM BUS 275168 TO BUS 270697 CKT 1      / COLLI;2M 345 COLLI; R 345  
TRIP BRANCH FROM BUS 275168 TO BUS 275268 CKT 1      / COLLI;2M 345 COLLI;2C 33  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1      / WILTO; 765 05DUMONT 765  
END
```

14. (CE - MISO NIPS) The BURNHAM ;0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 128.39% to 129.6% (**DC power flow**) of its emergency rating (1195 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 32.27 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1      / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1      / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

15. (CE - MISO NIPS) The BURNHAM ;0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 128.37% to 129.57% (**DC power flow**) of its emergency rating (1195 MVA) for the line fault with failed breaker contingency outage of '023-65-BT2-3\_\_'. This project contributes approximately 32.15 MW to the thermal violation.

```
CONTINGENCY '023-65-BT2-3__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1      / WILTO; 765 05DUMONT 765
```

TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765  
END

16. (CE - MISO NIPS) The BURNHAM ;0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 127.89% to 129.11% (**DC power flow**) of its emergency rating (1195 MVA) for the line fault with failed breaker contingency outage of '023-65-BT4-5\_\_'. This project contributes approximately 32.58 MW to the thermal violation.

CONTINGENCY '023-65-BT4-5\_\_'  
TRIP BRANCH FROM BUS 275168 TO BUS 270607 CKT 1 / COLLI;2M 345 COLLI; 765  
TRIP BRANCH FROM BUS 275168 TO BUS 270697 CKT 1 / COLLI;2M 345 COLLI; R 345  
TRIP BRANCH FROM BUS 275168 TO BUS 275268 CKT 1 / COLLI;2M 345 COLLI;2C 33  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
END

17. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 103.65% to 105.83% (**DC power flow**) of its emergency rating (1674 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 37.69 MW to the thermal violation.

CONTINGENCY '112-65-BT4-5\_\_'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END

18. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 103.62% to 105.78% (**DC power flow**) of its emergency rating (1674 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 37.41 MW to the thermal violation.

CONTINGENCY '2978\_C2\_05DUMONT 765-B\_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END

19. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 103.59% to 105.77% (**DC power flow**) of its emergency rating (1674 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 37.68 MW to the thermal violation.

CONTINGENCY '112-65-BT3-4\_\_'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END

20. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 111.0% to 112.07% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 23.11 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

21. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 103.92% to 105.01% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 23.4 MW to the thermal violation.

```
CONTINGENCY '112-65-BT4-5__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END
```

22. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 103.92% to 105.01% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 23.4 MW to the thermal violation.

```
CONTINGENCY '112-65-BT3-4__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END
```

23. (CE - MISO NIPS) The ST JOHN ; T-17GREEN\_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 112.41% to 114.81% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 26.1 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

24. (CE - MISO NIPS) The ST JOHN ; T-17GREEN\_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 111.77% to 114.18% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 26.34 MW to the thermal violation.

CONTINGENCY '112-65-BT4-5\_\_'  
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
 END

25. (CE - MISO NIPS) The ST JOHN ; T-17GREEN\_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 111.73% to 114.14% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 26.33 MW to the thermal violation.

CONTINGENCY '112-65-BT3-4\_\_'  
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
 END

26. (CE - CE) The WILTON ; B-WILTON ;3M 345 kV line (from bus 270926 to bus 275232 ckt 1) loads from 138.31% to 139.35% (**DC power flow**) of its emergency rating (1601 MVA) for the line fault with failed breaker contingency outage of '112-65-BT5-6\_\_'. This project contributes approximately 36.78 MW to the thermal violation.

CONTINGENCY '112-65-BT5-6\_\_'  
 TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765  
 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
 END

27. (CE - CE) The WILTON ; R-WILTON ;4M 345 kV line (from bus 270927 to bus 275233 ckt 1) loads from 142.0% to 143.06% (**DC power flow**) of its emergency rating (1601 MVA) for the line fault with failed breaker contingency outage of '112-65-BT2-3\_\_'. This project contributes approximately 37.57 MW to the thermal violation.

CONTINGENCY '112-65-BT2-3\_\_'  
 TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765  
 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
 END

28. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 143.28% to 145.96% (**DC power flow**) of its emergency rating (1390 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 37.29 MW to the thermal violation.

```
CONTINGENCY '112-65-BT4-5__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END
```

29. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 143.24% to 145.91% (**DC power flow**) of its emergency rating (1390 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 37.01 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

30. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 143.2% to 145.88% (**DC power flow**) of its emergency rating (1390 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 37.28 MW to the thermal violation.

```
CONTINGENCY '112-65-BT3-4__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END
```

31. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 139.09% to 140.41% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 28.46 MW to the thermal violation.

```
CONTINGENCY '2978_C2_05DUMONT 765-B_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

32. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 137.88% to 139.21% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 28.74 MW to the thermal violation.

CONTINGENCY '112-65-BT4-5\_\_'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END

33. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 137.86% to 139.19% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 28.74 MW to the thermal violation.

CONTINGENCY '112-65-BT3-4\_\_'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END

34. (CE - CE) The WILTON ; 765/345 kV transformer (from bus 275232 to bus 270644 ckt 1) loads from 127.89% to 128.93% (**DC power flow**) of its emergency rating (1601 MVA) for the line fault with failed breaker contingency outage of '112-65-BT5-6\_\_'. This project contributes approximately 36.78 MW to the thermal violation.

CONTINGENCY '112-65-BT5-6\_\_'  
TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END

35. (CE - CE) The WILTON ; 765/345 kV transformer (from bus 275233 to bus 270644 ckt 1) loads from 130.55% to 131.61% (**DC power flow**) of its emergency rating (1601 MVA) for the line fault with failed breaker contingency outage of '112-65-BT2-3\_\_'. This project contributes approximately 37.57 MW to the thermal violation.

CONTINGENCY '112-65-BT2-3\_\_'  
TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END

36. (AEP - AEP) The X2-052 TAP-05DUMONT 345 kV line (from bus 909144 to bus 243219 ckt 2) loads from 126.69% to 127.35% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '2978\_C2\_05DUMONT 765-B\_A'. This project contributes approximately 20.76 MW to the thermal violation.

CONTINGENCY '2978\_C2\_05DUMONT 765-B\_A'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 907040 X1-020 TAP 765 1  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END

37. (AEP - AEP) The X2-052 TAP-05DUMONT 345 kV line (from bus 909144 to bus 243219 ckt 2) loads from 117.02% to 117.75% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5\_\_'. This project contributes approximately 22.59 MW to the thermal violation.

CONTINGENCY '112-65-BT4-5\_\_'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END

38. (AEP - AEP) The X2-052 TAP-05DUMONT 345 kV line (from bus 909144 to bus 243219 ckt 2) loads from 117.01% to 117.73% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4\_\_'. This project contributes approximately 22.59 MW to the thermal violation.

CONTINGENCY '112-65-BT3-4\_\_'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END

### **Steady-State Voltage Requirements**

*(Results of the steady-state voltage studies should be inserted here)*

To be determined

### **Short Circuit**

*(Summary of impacted circuit breakers)*

To be determined

### **Affected System Analysis & Mitigation**

## Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

1. (AEP - AEP) The 05DUMONT-05SORENS 765 kV line (from bus 243206 to bus 246999 ckt 1) loads from 101.86% to 101.92% (**DC power flow**) of its normal rating (4257 MVA) for the single line contingency outage of '709\_B2\_TOR546'. This project contributes approximately 59.79 MW to the thermal violation.

```
CONTINGENCY '709_B2_TOR546'  
OPEN BRANCH FROM BUS 242924 TO BUS 243208 CKT 1          / 242924 05HANG R 765 243208 05JEFRSO 765 1  
END
```

2. (MISO NIPS - AEP) The 17HIPLE-05COLNGW 345 kV line (from bus 255105 to bus 243214 ckt 1) loads from 103.26% to 103.31% (**DC power flow**) of its normal rating (1409 MVA) for the single line contingency outage of '7442\_B2\_TOR200545'. This project contributes approximately 18.63 MW to the thermal violation.

```
CONTINGENCY '7442_B2_TOR200545'  
OPEN BRANCH FROM BUS 243206 TO BUS 246999 CKT 1          / 243206 05DUMONT 765 246999 05SORENS 765 1  
END
```

3. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 111.26% to 113.66% (**DC power flow**) of its emergency rating (1091 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 26.28 MW to the thermal violation.

```
CONTINGENCY '695_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1          / 243206 05DUMONT 765 270644 WILTO; 765 1  
END
```

4. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 135.82% to 137.11% (**DC power flow**) of its normal rating (1409 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 40.61 MW to the thermal violation.

```
CONTINGENCY '695_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1          / 243206 05DUMONT 765 270644 WILTO; 765 1  
END
```

5. (CE - CE) The COLLINS ; -WILTON ; 765 kV line (from bus 270607 to bus 270644 ckt 1) loads from 110.41% to 111.86% (**DC power flow**) of its normal rating (4142 MVA) for non-contingency condition. This project contributes approximately 60.59 MW to the thermal violation.

6. (CE - CE) The COLLINS ; -WILTON ; 765 kV line (from bus 270607 to bus 270644 ckt 1) loads from 106.15% to 107.64% (**DC power flow**) of its emergency rating (4460 MVA) for the single line contingency outage of '345-L16703\_R-S'. This project contributes approximately 67.31 MW to the thermal violation.

```
CONTINGENCY '345-L16703_R-S'  
TRIP BRANCH FROM BUS 270846 TO BUS 270847 CKT 1 / PLANO ; B 345 PLANO ; R 345  
TRIP BRANCH FROM BUS 270847 TO BUS 270733 CKT 1 / PLANO ; R 345 ELEC JUNC;3R 345  
END
```

7. (CE - AEP) The WILTON ; -05DUMONT 765 kV line (from bus 270644 to bus 243206 ckt 1) loads from 128.8% to 129.64% (**DC power flow**) of its normal rating (4047 MVA) for the single line contingency outage of '363\_B2\_TOR1682'. This project contributes approximately 75.77 MW to the thermal violation.

```
CONTINGENCY '363_B2_TOR1682'  
OPEN BRANCH FROM BUS 243208 TO BUS 243209 CKT 1 / 243208 05JEFRSO 765 243209 05ROCKPT 765 1  
END
```

8. (CE - MISO NIPS) The BURNHAM ; B-17SHEFFIELD 345 kV line (from bus 270674 to bus 255111 ckt 1) loads from 126.23% to 127.32% (**DC power flow**) of its emergency rating (1069 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 25.99 MW to the thermal violation.

```
CONTINGENCY '695_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206  
05DUMONT 765 270644 WILTO; 765 1  
END
```

9. (CE - MISO NIPS) The BURNHAM ; 0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 127.06% to 128.28% (**DC power flow**) of its emergency rating (1195 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 32.49 MW to the thermal violation.

```
CONTINGENCY '695_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END
```

10. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 123.17% to 125.77% (**DC power flow**) of its emergency rating (1399 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 37.57 MW to the thermal violation.

CONTINGENCY '695\_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

11. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 103.85% to 104.94% (**DC power flow**) of its normal rating (971 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 23.39 MW to the thermal violation.

CONTINGENCY '695\_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

12. (CE - CE) The PLANO ; B-ELECT JCT; B 345 kV line (from bus 270846 to bus 270730 ckt 1) loads from 102.73% to 105.39% (**DC power flow**) of its emergency rating (1341 MVA) for the single line contingency outage of '765-L11216\_\_-S'. This project contributes approximately 35.68 MW to the thermal violation.

CONTINGENCY '765-L11216\_\_-S'  
TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765  
END

13. (CE - MISO NIPS) The ST JOHN ; T-17GREEN\_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 111.26% to 113.66% (**DC power flow**) of its emergency rating (1091 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 26.28 MW to the thermal violation.

CONTINGENCY '695\_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

14. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 142.41% to 145.09% (**DC power flow**) of its emergency rating (1390 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 37.17 MW to the thermal violation.

CONTINGENCY '695\_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

15. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 137.37% to 138.7% (**DC power flow**) of its normal rating (971 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 28.69 MW to the thermal violation.

CONTINGENCY '695\_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

16. (CE - CE) The COLLINS ;2M-COLLINS ; R 345 kV line (from bus 275168 to bus 270697 ckt 1) loads from 136.58% to 137.18% (**DC power flow**) of its emergency rating (1379 MVA) for the single line contingency outage of '765-L11216\_\_-S'. This project contributes approximately 18.08 MW to the thermal violation.

CONTINGENCY '765-L11216\_\_-S'  
TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765  
END

17. (AEP - AEP) The X2-052 TAP-05DUMONT 345 kV line (from bus 909144 to bus 243219 ckt 2) loads from 116.86% to 117.58% (**DC power flow**) of its normal rating (1409 MVA) for the single line contingency outage of '695\_B2'. This project contributes approximately 22.56 MW to the thermal violation.

CONTINGENCY '695\_B2'  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1  
END

## **Light Load Analysis - 2019**

Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).