

Generation Interconnection Feasibility Study Report Queue Position AB2-164

The Interconnection Customer (IC) has proposed a 20 MW (7.6 MW Capacity) solar generating facility to be located in Accomack County, Virginia. PJM studied the AB2-164 project at both a Primary and Secondary Point of Interconnection. The study results are provided below. The planned in-service date, as requested by the IC during the project kick-off call, is January 1, 2018. This date is not attainable due to additional required studies and construction schedules.

Point(s) of Interconnection

The Interconnection Customer requested a Primary and Secondary Point of Interconnection (POI) be evaluated for the AB2-164 project.

Primary Point of Interconnection

PJM studied the AB2-164 project into the Old Dominion Electric Cooperative (ODEC) system as a tap of the Tasley-Oak Hall 69 kV (east) circuit and evaluated it for compliance with reliability criteria for summer peak conditions in 2020.

Transmission Owner Scope of Attachment Facilities Work

The AB2-164 project will connect with the ODEC transmission system at a new 69 kV substation to be constructed adjacent to the Oak Hall-Tasley 69 kV circuit #6703 (east). The total estimated cost of Direct Connection Facilities needed to connect Queue AB2-164 to the ODEC 69 kV system are **\$2,390,000** without a statcom, and **3,880,000** if a statcom is required. Both estimates exclude any applicable state or federal taxes.

A further breakdown of the direct connection cost are as follows:

\$150,000.00	Grading and Site Preparation
\$450,000.00	Substation Package (steel, switches, buswork)
\$150,000.00	69 kV Circuit Breakers
\$200,000.00	Relaying and SCADA
\$120,000.00	Project Management
\$800,000.00	Substation Construction Labor and Contractor Supplied Materials
\$200,000.00	Engineering
\$60,000.00	Control Building
\$100,000.00	69 kV Structures
\$150,000.00	Communications to Oak Hall Substation
\$10,000.00	Power Quality Metering
<hr/>	<hr/>
\$2,390,000.00	Total Estimated Direct Connection Cost

\$160,000.00	Grading and Site Preparation
--------------	------------------------------

\$600,000.00	Substation Package (steel, switches, buswork)
\$200,000.00	69 kV Circuit Breakers
\$250,000.00	Relaying and SCADA
\$130,000.00	Project Management
\$1,000,000.00	Substation Construction Labor and Contractor Supplied Materials
\$220,000.00	Engineering
\$60,000.00	Control Building
\$100,000.00	69 kV Structures
\$150,000.00	Communications to Oak Hall Substation
\$10,000.00	Power Quality Metering
\$300,000.00	Transformer(s) for Statcom
\$700,000.00	4 MVA Statcom
\$3,880,000.00	Total Estimated Direct Connection Cost

The total estimated construction time for the Direct Connection facilities is **24 months**.

These transmission costs exclude any applicable state or federal taxes. If at a future date Federal CIAC taxes are deemed necessary by the IRS for this project, PJM, ANEC, and ODEC shall be reimbursed by the Interconnection Customer for such taxes.

Costs for extraordinary Threatened and Endangered Species, Archaeological, Cultural, or other as yet unidentified mitigation strategies are not estimated nor included in the above estimate. No environmental, real estate, or permitting issues were reviewed for this AB2-164 Feasibility Study.

Transmission Owner Interconnection Requirements

AB2-164 Inverter and GSU modeling

The AB2-164 Interconnection Customer must provide ODEC and PJM with the transformer test reports and a model of the inverters once they are available in order to perform more detailed analyses.

AB2-164 Generator Harmonic Requirements @ Point of Interconnection

Harmonic Voltage Requirements:

On the 69 kV system, the total harmonic distortion to the fundamental voltage wave from a single customer is limited to 1.5% of nominal. In addition, no individual harmonic component can exceed 1.0% of the fundamental system voltage.

Maximum Allowable Harmonic Voltage Distortion Table (Tariff Rule 32)		
Voltage Level	Distortion Factor (% System Voltage)	Individual Harmonic (% System Voltage)
69 kV through 138 kV	1.5	1

Harmonic current limits must comply with IEEE standard 519 (see table 10.2 and 10.3 limits for power generation). Harmonic filtering sufficient to limit harmonic current to the limits proscribed by these tables may need to be installed. AB2-164 will be responsible for installing such filtering and may be disconnected until remedies are taken if these standards are violated.

Current Distortion Limits in % of 60~ Current (from IEEE 519 tables 10.2 and 10.3)						
Voltage Level	<11	11<h<17	17<h<23	23<h<35	35<h	TDD
69 kV	2.0	1.0	0.75	0.3	0.15	2.5
25 kV	4.0	2.0	1.5	0.6	0.3	5.0

AB2-164 Inverter Regulation or Reactive Support Requirements

As specified in Interconnection Service Agreement, Appendix 2, Section 4.7.1.1 of the PJM OATT (Open Access Transmission Tariff), the AB2-164 generator may need to design its Facility to meet the following power factor requirement, depending on the outcome of the system impact study:

“For all new wind-powered and other non-synchronous generation facilities, if determined in the system impact study to be required for the safety or reliability of the Transmission System, the Generation Interconnection Customer shall design its Customer Facility with the ability to maintain a composite power delivery at continuous rated power output at a power factor of at least 0.95 leading to 0.95 lagging.”

Preliminary Schedule and Notes / Assumptions

ODEC will begin the project only after the PJM 3-party Interconnection Service Agreement (ISA) and Interconnection Construction Service Agreement (ICSA) are fully executed and ODEC receives a written authorization by PJM to commence activities. The estimated time to complete the direct connection work is approximately **24 months** after the execution of an ICSA. The schedule for the 69 kV transmission and substation work to accommodate AB2-164 would depend on the project start date. The work to accommodate AB2-164 will require transmission line outages. ODEC’s outage windows for construction are typically available in the spring and fall of the year. Missing an outage window could result in project delays.

Notes / Assumptions:

During construction, if extreme weather conditions or other system safety concerns arise, field construction may need to be rescheduled, which could possibly impact the schedule plan.

Excepting any operational, governmental and/or environmental regulatory delays, the use of additional resources, such as overtime, premiums for expedited material, and/or contractor labor, may enable ODEC to decrease this construction period. It is also assumed that all right-of-way and easements are secured without impact on anticipated construction start dates.

Interconnection Customer Scope of Work

Queue AB2-164 Interconnection Customer will be responsible for the construction of all generating station facilities on the AB2-164 side of the Point of Interconnection (POI). AB2-164 Interconnection Customer is required to design, construct, and own the 69 kV line from the POI to the Customer Facility. This line must be built in accordance RUS standards or an accepted national standard, be

effectively grounded, and appropriately shielded from lightning. (Refer to RUS bulletins 1728f-810 and 1724E-200.)

Protection equipment

The Interconnection Customer is responsible for the design and implementation of all protection equipment on the AB2-164 side of the POI (Point of Interconnection) as shown on the one line diagram of the previous page and will do so in accordance with good utility practice.

ODEC will provide relaying, a circuit breaker, and a transfer trip signal to the point of interconnection for all 69 kV faults on the line from Tasley to Kellam. AB2-164 will provide a 69 kV interrupting device at the POI beyond which ODEC protection will no longer be a primary means of interrupting fault current. The device **shall not** reclose after tripping. AB2-164 is required to provide ODEC with any information necessary to set ODEC line relaying and coordinate with their protective device, and to trip the device upon receipt of the transfer trip signal.

Statcom

AB2-164 will need to operate absorbing VARS from the system, so that when real power output decrease due to intermittent cloud cover, the resulting decrease in VAR withdrawal will maintain system voltage. To put it another way, the VARS needed for the step transformer will need to come from the system side of the interconnection. Also, due to the close proximity to the 80 MW of solar generation at Oak Hall, intermittent sunshine may cause voltage flicker, as there will be no diversity in the amount of solar energy supplied to these panels. Dynamic VAR support may be required to alleviate this problem. Further studies in during the Impact Study phase will be needed to make the final determine on the Statcom necessity and size.

Metering Equipment --

Installation of revenue grade Metering Equipment will be required at the Queue AB2-164 Point of Interconnection (POI). At the customer's discretion, ODEC will design and supply the required metering equipment but all the installation cost would be borne by the customer. ODEC requires that power quality metering be installed to monitor compliance with industry standards for harmonics and other power quality requirements.

The Interconnection Customer is also required to provide revenue metering and real-time telemetry data to PJM in compliance with the requirements listed in PJM Manuals M-01 and M-14. At the customer's discretion, ODEC will design and supply the required telemetering equipment but all the installation cost and on-going costs will be borne by AB2-164. In the event that that AB2-164 provides the metering, AB2-164 will provide ODEC read only access to its PJM metering account for this site for verification of billing for ODEC.

Distribution Service Requirements

The Interconnection Customer must submit a request for electric service through ANEC if back up electric service or station service power at less than 69 kV is desired.

Summer Peak Analysis - 2020

Transmission Network Impacts

Potential transmission network impacts are as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

1. (DP&L - DP&L) The TOWNSEND-MIDLTNTP 138 kV line (from bus 232107 to bus 232106 ckt 1) loads from 82.49% to 83.0% (DC power flow) of its emergency rating (348 MVA) for the tower line contingency outage of 'DBL_4NC'. This project contributes approximately 3.94 MW to the thermal violation.

CONTINGENCY 'DBL_4NC' /* RED LION-CEDAR CREEK
230;RED LION-CARTANZA 230
OPEN LINE FROM BUS 231004 TO BUS 232002 CKT 1
OPEN LINE FROM BUS 231004 TO BUS 232003 CKT 1
END

Please refer to Appendix 1 for a table containing the generators having contribution to this flowgate.

2. (DP&L - DP&L) The LORETTO 138/69 kV transformer (from bus 232127 to bus 232275 ckt 1) loads from 97.9% to 99.06% (DC power flow) of its emergency rating (71 MVA) for the line fault with failed breaker contingency outage of 'DP56'. This project contributes approximately 1.83 MW to the thermal violation.

CONTINGENCY 'DP56' /*LORETTO BUS BREAKER
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232117 CKT 1 /*LORETTO
VIENNA 138 1380
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232128 CKT 1 /*LORETTO
PINEY GROVE 138 138
END

Please refer to Appendix 2 for a table containing the generators having contribution to this flowgate.

3. (DP&L - DP&L) The PRESTON-TANYARD 69 kV line (from bus 232233 to bus 232821 ckt 1) loads from 71.63% to 72.74% (DC power flow) of its emergency rating (93 MVA) for the line fault with failed breaker contingency outage of 'DP11'. This project contributes approximately 2.29 MW to the thermal violation.

CONTINGENCY 'DP11' /*STEELE BUS BREAKER TO
MILFORD
DISCONNECT BRANCH FROM BUS 232004 TO BUS 232000 CKT 1 /*MILFORD
STEELE 230 230
DISCONNECT BRANCH FROM BUS 232000 TO BUS 232005 CKT 1 /*STEELE
VIENNA 230 230
END

Please refer to Appendix 3 for a table containing the generators having contribution to this flowgate.

4. (DP&L - DP&L) The TODD-PRESTON 69 kV line (from bus 232234 to bus 232233 ckt 1) loads from 77.65% to 78.76% (DC power flow) of its emergency rating (93 MVA) for the line fault with failed breaker contingency outage of 'DP11'. This project contributes approximately 2.29 MW to the thermal violation.

CONTINGENCY 'DP11' /*STEELE BUS BREAKER TO
MILFORD
DISCONNECT BRANCH FROM BUS 232004 TO BUS 232000 CKT 1 /*MILFORD
STEELE 230 230
DISCONNECT BRANCH FROM BUS 232000 TO BUS 232005 CKT 1 /*STEELE
VIENNA 230 230
END

Please refer to Appendix 4 for a table containing the generators having contribution to this flowgate.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

1. (DP&L - DP&L) The MILF_230-STEELE 230 kV line (from bus 232004 to bus 232000 ckt 1) loads from 147.01% to 147.81% (DC power flow) of its emergency rating (551 MVA) for the tower line contingency outage of 'DBL_4NC'. This project contributes approximately 9.82 MW to the thermal violation.

CONTINGENCY 'DBL_4NC' /* RED LION-CEDAR CREEK
230;RED LION-CARTANZA 230
OPEN LINE FROM BUS 231004 TO BUS 232002 CKT 1
OPEN LINE FROM BUS 231004 TO BUS 232003 CKT 1
END

Please refer to Appendix 5 for a table containing the generators having contribution to this flowgate.

2. (DP&L - DP&L) The PINEY_69-M HERMON 69 kV line (from bus 232274 to bus 232272 ckt 1) loads from 127.43% to 130.8% (DC power flow) of its emergency rating (143 MVA) for the line fault with failed breaker contingency outage of 'DP15'. This project contributes approximately 4.83 MW to the thermal violation.

```

CONTINGENCY 'DP15'                                /*INDIAN RIVER BUS BREAKER TO
PINEY GROVE
DISCONNECT BRANCH FROM BUS 232007 TO BUS 232006 CKT 1    /*PINEY GR
INDRIV 4 230 230
DISCONNECT BRANCH FROM BUS 232007 TO BUS 232128 CKT 1    /*PINEY GR
PINEY GR 230 138
DISCONNECT BRANCH FROM BUS 232006 TO BUS 232004 CKT 1    /*MILFORD
INDIAN RIVER 230 230
END

```

Please refer to Appendix 6 for a table containing the generators having contribution to this flowgate.

3. (DP&L - DP&L) The LORET_69-FRUITLND 69 kV line (from bus 232275 to bus 232288 ckt 1) loads from 105.26% to 107.79% (DC power flow) of its emergency rating (137 MVA) for the line fault with failed breaker contingency outage of 'DP56'. This project contributes approximately 3.47 MW to the thermal violation.

```

CONTINGENCY 'DP56'                                /*LORETTO BUS BREAKER
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232117 CKT 1    /*LORETTO
VIENNA 138 1380
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232128 CKT 1    /*LORETTO
PINEY GROVE 138 138
END

```

Please refer to Appendix 7 for a table containing the generators having contribution to this flowgate.

4. (DP&L - DP&L) The FRUITLND-PEMBERTN 69 kV line (from bus 232288 to bus 232273 ckt 1) loads from 112.98% to 116.79% (DC power flow) of its emergency rating (91 MVA) for the line fault with failed breaker contingency outage of 'DP56'. This project contributes approximately 3.47 MW to the thermal violation.

```

CONTINGENCY 'DP56'                                /*LORETTO BUS BREAKER
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232117 CKT 1    /*LORETTO
VIENNA 138 1380
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232128 CKT 1    /*LORETTO
PINEY GROVE 138 138
END

```

Please refer to Appendix 8 for a table containing the generators having contribution to this flowgate.

Summer Peak Load Flow Analysis Reinforcements

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

1. To mitigate the (DP&L) TOWNSEND-MIDLTNTP 138 kV line (from bus 232107 to bus 232106 ckt 1) overload will require reinforcements to increase the emergency rating of the Townsend to Middletown Tap 138 kV line. Those reinforcements include rebuilding a small section of the circuit and installing new poles and the re-mounting of 138 kV disconnect switches. The estimated cost to perform this work is **\$800,000** and will take **18 months** to complete.
2. To mitigate the (DP&L) LORETTO 138/69 kV transformer (from bus 232127 to bus 232275 ckt 1) overload will require replacement of the Loretto AT1 autotransformer, which requires the reconfiguration of the 138 kV and 69 kV buses at Loretto Substation. The estimate to perform this work is **\$4,377,000** and will take approximately **2 years** to complete.
3. To mitigate the (DP&L) PRESTON-TANYARD 69 kV line (from bus 232233 to bus 232821 ckt 1) overload will require the replacement of a disconnect switch at Preston Substation. The estimate to perform this work is **\$36,000** and will take approximately **1 year** to complete.
4. To mitigate the (DP&L) TODD-PRESTON 69 kV line (from bus 232234 to bus 232233 ckt 1) overload will require substation reinforcements at Preston Substation and Todd Substation. The estimate to perform this work is **\$67,000** and will take approximately **1 year** to complete.

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

(Summary form of Cost allocation for transmission lines and transformers will be inserted here if any)

1. To mitigate the (DP&L) MILF_230-STEELE 230 kV line (from bus 232004 to bus 232000 ckt 1) overload will require rebuilding of the circuit including the replacement of poles to increase the emergency rating. The estimate to perform this work is **\$43,965,000** and will take **4 years** to complete.
2. To mitigate the (DP&L) The PINEY_69-M HERMON 69 kV line (from bus 232274 to bus 232272 ckt 1) overload will require rebuilding of the Piney Grove – Mount Hermon 69 kV transmission line and substation reinforcements at Piney Grove Substation and Mount Hermon Substation. The estimate to perform this work is **\$9,688,000** and will take approximately **3 years** to complete.

3. To mitigate the (DP&L) LORET_69-FRUITLND 69 kV line (from bus 232275 to bus 232288 ckt 1) overload will require rebuilding of the Loretto – Fruitland 69 kV transmission line and substation reinforcements at Loretto Substation and Fruitland Substation. The estimate to perform this work is **\$7,196,000** and will take approximately **3 years** to complete.
4. To mitigate the (DP&L) FRUITLND-PEMBERTN 69 kV line (from bus 232288 to bus 232273 ckt 1) overload will require completion of PJM Supplemental Project s0820. Current estimated completion date is December 31, 2016.

Note: Queue project AB2-084 is not expected to have cost responsibility for this network upgrade due to cost allocation rules.

Steady-State Voltage Requirements

(Results of the steady-state voltage studies should be inserted here)

To be performed during later study phases.

Short Circuit

No issues identified.

Stability and Reactive Power Requirement

To be performed during later study phases.

Light Load Analysis - 2020

Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

1. (DP&L - DP&L) The PINEY138-LORETTO 138 kV line (from bus 232128 to bus 232127 ckt 1) loads from 114.19% to 118.11% (DC power flow) of its emergency rating (159 MVA) for the single line contingency outage of 'CKT 13713'. This project contributes approximately 6.23 MW to the thermal violation.

CONTINGENCY 'CKT 13713'

OPEN LINE FROM BUS 232129 TO BUS 232127 CIRCUIT 1 /KINGS CREEK -
LORETTO 138
END

2. (DP&L - DP&L) The POCOMOKE-T-144 TAP 138 kV line (from bus 232130 to bus 886230 ckt 1) loads from 88.09% to 91.93% (DC power flow) of its emergency rating (247 MVA) for the single line contingency outage of 'CKT 13764_B'. This project contributes approximately 9.48 MW to the thermal violation.

CONTINGENCY 'CKT 13764_B'
OPEN LINE FROM BUS 924680 TO BUS 232128 CIRCUIT 1 /AB2-120 TAP -
PINEY GROVE 138
END

3. (DP&L - DP&L) The N_CHURCH-AB2-120 TAP 138 kV line (from bus 232131 to bus 924680 ckt 1) loads from 109.8% to 114.11% (DC power flow) of its emergency rating (226 MVA) for the single line contingency outage of 'CKT 13713'. This project contributes approximately 9.73 MW to the thermal violation.

CONTINGENCY 'CKT 13713'
OPEN LINE FROM BUS 232129 TO BUS 232127 CIRCUIT 1 /KINGS CREEK -
LORETTO 138
END

4. (DP&L - DP&L) The PINEY_69-M HERMON 69 kV line (from bus 232274 to bus 232272 ckt 1) loads from 127.0% to 130.4% (DC power flow) of its emergency rating (143 MVA) for the single line contingency outage of 'CKT 23002'. This project contributes approximately 4.85 MW to the thermal violation.

CONTINGENCY 'CKT 23002'
DISCONNECT BUS 232007 /INDIAN RIVER - PINEY GROVE 230
& PNY GRV AT-20 XFMR
END

5. (DP&L - DP&L) The OAKHL_69-WATTSVIL 69 kV line (from bus 232280 to bus 232281 ckt 1) loads from 118.99% to 126.57% (DC power flow) of its emergency rating (89 MVA) for the single line contingency outage of 'CKT 13789'. This project contributes approximately 6.74 MW to the thermal violation.

CONTINGENCY 'CKT 13789'
OPEN LINE FROM BUS 232132 TO BUS 232133 CIRCUIT 1 /OAK HALL -
WATTSVILLE 138
END

6. (DP&L - DP&L) The SHORT 1-LAUREL 69 kV line (from bus 232828 to bus 232249 ckt 1) loads from 90.72% to 94.29% (DC power flow) of its emergency rating (57 MVA) for the single

line contingency outage of 'CKT 23002'. This project contributes approximately 2.04 MW to the thermal violation.

CONTINGENCY 'CKT 23002'
DISCONNECT BUS 232007 /INDIAN RIVER - PINEY GROVE 230
& PNY GRV AT-20 XFMR
END

7. (DP&L - DP&L) The T-144 TAP-COSTEN 138 kV line (from bus 886230 to bus 232807 ckt 1) loads from 88.09% to 91.93% (DC power flow) of its emergency rating (247 MVA) for the single line contingency outage of 'CKT 13764_B'. This project contributes approximately 9.48 MW to the thermal violation.

CONTINGENCY 'CKT 13764_B'
OPEN LINE FROM BUS 924680 TO BUS 232128 CIRCUIT 1 /AB2-120 TAP -
PINEY GROVE 138
END

8. (DP&L - DP&L) The AB2-120 TAP-PINEY138 138 kV line (from bus 924680 to bus 232128 ckt 1) loads from 137.68% to 141.99% (DC power flow) of its emergency rating (226 MVA) for the single line contingency outage of 'CKT 13713'. This project contributes approximately 9.73 MW to the thermal violation.

CONTINGENCY 'CKT 13713'
OPEN LINE FROM BUS 232129 TO BUS 232127 CIRCUIT 1 /KINGS CREEK -
LORETTO 138
END

9. (DP&L - DP&L) The AB2-120 TAP-PINEY138 138 kV line (from bus 924680 to bus 232128 ckt 1) loads from 111.62% to 115.27% (DC power flow) of its normal rating (172 MVA) for **non-contingency** condition. This project contributes approximately 6.28 MW to the thermal violation.

Secondary Point of Interconnection

PJM studied the AB2-164 project into the Delmarva Power and Light (DPL) system as a direct connection into the Oak Hall 138 kV Substation and evaluated it for compliance with reliability criteria for summer peak conditions in 2020.

Summer Peak Analysis - 2020

Transmission Network Impacts

Potential transmission network impacts are as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

DISCONNECT BRANCH FROM BUS 232007 TO BUS 232128 CKT 1 /*PINEY
GROVE PINEY GROVE 230 138
END

Please refer to Appendix 6 for a table containing the generators having contribution to this flowgate.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

1. (DP&L - DP&L) The MILF_230-STEELE 230 kV line (from bus 232004 to bus 232000 ckt 1) loads from 147.03% to 147.83% (DC power flow) of its emergency rating (551 MVA) for the tower line contingency outage of 'DBL_4NC'. This project contributes approximately 9.8 MW to the thermal violation.

CONTINGENCY 'DBL_4NC' /* RED LION-CEDAR CREEK
230;RED LION-CARTANZA 230
OPEN LINE FROM BUS 231004 TO BUS 232002 CKT 1
OPEN LINE FROM BUS 231004 TO BUS 232003 CKT 1
END

Please refer to Appendix 7 for a table containing the generators having contribution to this flowgate.

2. (DP&L - DP&L) The PINEY_69-M HERMON 69 kV line (from bus 232274 to bus 232272 ckt 1) loads from 127.65% to 130.95% (DC power flow) of its emergency rating (143 MVA) for the line fault with failed breaker contingency outage of 'DP15'. This project contributes approximately 4.73 MW to the thermal violation.

CONTINGENCY 'DP15' /*INDIAN RIVER BUS BREAKER TO
PINEY GROVE
DISCONNECT BRANCH FROM BUS 232007 TO BUS 232006 CKT 1 /*PINEY GR
INDRIV 4 230 230
DISCONNECT BRANCH FROM BUS 232007 TO BUS 232128 CKT 1 /*PINEY GR
PINEY GR 230 138
DISCONNECT BRANCH FROM BUS 232006 TO BUS 232004 CKT 1 /*MILFORD
INDIAN RIVER 230 230
END

Please refer to Appendix 8 for a table containing the generators having contribution to this flowgate.

3. (DP&L - DP&L) The LORET_69-FRUITLND 69 kV line (from bus 232275 to bus 232288 ckt 1) loads from 104.78% to 107.41% (DC power flow) of its emergency rating (137 MVA) for the line

fault with failed breaker contingency outage of 'DP56'. This project contributes approximately 3.6 MW to the thermal violation.

CONTINGENCY 'DP56' /*LORETTO BUS BREAKER
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232117 CKT 1 /*LORETTO
VIENNA 138 1380
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232128 CKT 1 /*LORETTO
PINEY GROVE 138 138
END

Please refer to Appendix 9 for a table containing the generators having contribution to this flowgate.

4. (DP&L - DP&L) The FRUITLND-PEMBERTN 69 kV line (from bus 232288 to bus 232273 ckt 1) loads from 112.26% to 116.22% (DC power flow) of its emergency rating (91 MVA) for the line fault with failed breaker contingency outage of 'DP56'. This project contributes approximately 3.6 MW to the thermal violation.

CONTINGENCY 'DP56' /*LORETTO BUS BREAKER
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232117 CKT 1 /*LORETTO
VIENNA 138 1380
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232128 CKT 1 /*LORETTO
PINEY GROVE 138 138
END

Please refer to Appendix 10 for a table containing the generators having contribution to this flowgate.

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

1. (DP&L - DP&L) The PINEY138-LORETTO 138 kV line (from bus 232128 to bus 232127 ckt 1) loads from 114.16% to 118.1% (DC power flow) of its emergency rating (159 MVA) for the single line contingency outage of 'CKT 13713'. This project contributes approximately 6.27 MW to the thermal violation.

CONTINGENCY 'CKT 13713'

OPEN LINE FROM BUS 232129 TO BUS 232127 CIRCUIT 1 /KINGS CREEK -
LORETTO 138
END

2. (DP&L - DP&L) The N_CHURCH-PINEY138 138 kV line (from bus 232131 to bus 232128 ckt 1) loads from 125.2% to 129.77% (DC power flow) of its emergency rating (226 MVA) for the single line contingency outage of 'CKT 13713'. This project contributes approximately 10.32 MW to the thermal violation.

CONTINGENCY 'CKT 13713'
OPEN LINE FROM BUS 232129 TO BUS 232127 CIRCUIT 1 /KINGS CREEK -
LORETTO 138
END

3. (DP&L - DP&L) The PINEY_69-M HERMON 69 kV line (from bus 232274 to bus 232272 ckt 1) loads from 127.22% to 130.54% (DC power flow) of its emergency rating (143 MVA) for the single line contingency outage of 'CKT 23002'. This project contributes approximately 4.75 MW to the thermal violation.

CONTINGENCY 'CKT 23002'
DISCONNECT BUS 232007 /INDIAN RIVER - PINEY GROVE 230
& PNY GRV AT-20 XFMR
END

4. (DP&L - DP&L) The OAKHL_69-WATTSVIL 69 kV line (from bus 232280 to bus 232281 ckt 1) loads from 103.24% to 107.52% (DC power flow) of its emergency rating (89 MVA) for the single line contingency outage of 'CKT 13789'. This project contributes approximately 3.81 MW to the thermal violation.

CONTINGENCY 'CKT 13789'
OPEN LINE FROM BUS 232132 TO BUS 232133 CIRCUIT 1 /OAK HALL -
WATTSVILLE 138
END

5. (DP&L - DP&L) The SHORT 1-LAUREL 69 kV line (from bus 232828 to bus 232249 ckt 1) loads from 90.77% to 94.33% (DC power flow) of its emergency rating (57 MVA) for the single line contingency outage of 'CKT 23002'. This project contributes approximately 2.03 MW to the thermal violation.

CONTINGENCY 'CKT 23002'
DISCONNECT BUS 232007 /INDIAN RIVER - PINEY GROVE 230
& PNY GRV AT-20 XFMR
END

Appendices

(Primary Point of Interconnection)

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gauge other generators impact.

It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Appendix 1

(DP&L - DP&L) The TOWNSEND-MIDLTNTP 138 kV line (from bus 232107 to bus 232106 ckt 1) loads from 82.49% to 83.0% (DC power flow) of its emergency rating (348 MVA) for the tower line contingency outage of 'DBL_4NC'. This project contributes approximately 3.94 MW to the thermal violation.

CONTINGENCY 'DBL_4NC'

/* RED LION-CEDAR CREEK

230;RED LION-CARTANZA 230

OPEN LINE FROM BUS 231004 TO BUS 232002 CKT 1

OPEN LINE FROM BUS 231004 TO BUS 232003 CKT 1

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232900	DEMECSMY	2.15
232851	DUP-SFR1	0.41
232902	EASTMUNI	3.4
232923	MR1	3.36
232924	MR2	3.36
232910	NRG_G1	2.43
232911	NRG_G2	2.43
292089	T-011	0.17
297076	V2-028 C	0.09
297077	V2-028 E	0.75
904212	V4-022E	0.61
232813	VAUGHN	0.15
232919	VN10	0.57
901004	W1-003 E	0.89
901014	W1-004 E	0.89
901024	W1-005 E	0.89
901034	W1-006 E	0.89
901411	W1-062	2.28

907052	X1-032 E	0.79
907324	X1-096 E	18.27
910571	X3-008 C	0.32
910572	X3-008 E	2.68
910591	X3-015 C	0.3
910592	X3-015 E	2.51
910821	X3-066 C	0.17
910822	X3-066 E	1.41
913361	Y1-079 C	0.24
913362	Y1-079 E	1.96
913411	Y1-080 C	0.05
913412	Y1-080 E	0.43
915751	Y3-033	1.46
915752	Y3-033	9.76
920543	Y3-054 E	2.48
915541	Y3-058 C	0.22
915542	Y3-058 E	1.86
920582	Z1-076 C	1.05
920583	Z1-076 E	1.71
920592	Z1-077 C	0.75
920593	Z1-077 E	1.22
916281	Z1-081 C	0.2
916282	Z1-081 E	1.65
917082	Z2-012 E	2.44
920763	Z2-076 E	0.4
920773	Z2-077 E	0.4
920812	Z2-097 C	1.57
920813	Z2-097 E	0.65
921122	AA1-059 C	0.84
921123	AA1-059 E	0.33
921142	AA1-061 C	2.87
921143	AA1-061 E	1.41
921442	AA1-110 C	1.78
921443	AA1-110 E	0.89
921592	AA1-140 C	1.51
921593	AA1-140 E	2.47
921602	AA1-141 C	1.13
921603	AA1-141 E	1.84
921872	AA2-069	104.81
922213	AA2-129 E	3.94
922222	AA2-130	0.39
922752	AB1-056 C OP	12.79
922753	AB1-056 E OP	36.43
922762	AB1-057 C	12.99
922763	AB1-057 E	37.03

923282	<i>ABI-137 C</i>	2.79
923283	<i>ABI-137 E</i>	1.2
923322	<i>ABI-141 C OP</i>	5.3
923323	<i>ABI-141 E OP</i>	2.47
923332	<i>ABI-142 C OP</i>	5.3
923333	<i>ABI-142 E OP</i>	2.47
923452	<i>ABI-162 C OP</i>	2.4
923453	<i>ABI-162 E OP</i>	3.92
923602	<i>ABI-176 C</i>	1.29
923603	<i>ABI-176 E</i>	2.12
923902	<i>AB2-030 E</i>	0.79
923921	<i>AB2-032 C</i>	5.34
923922	<i>AB2-032 E</i>	2.51
923931	<i>AB2-033 C</i>	1.41
923932	<i>AB2-033 E</i>	0.56
923951	<i>AB2-036 C</i>	13.81
923952	<i>AB2-036 E</i>	22.54
923961	<i>AB2-037 C</i>	14.99
923962	<i>AB2-037 E</i>	24.45
924191	<i>AB2-063 C</i>	2.87
924192	<i>AB2-063 E</i>	4.69
924361	<i>AB2-084 C</i>	0.75
924362	<i>AB2-084 E</i>	1.22
924461	<i>AB2-095 C</i>	2.27
924462	<i>AB2-095 E</i>	3.7
924681	<i>AB2-120 C OP</i>	7.49
924682	<i>AB2-120 E OP</i>	12.21
924781	<i>AB2-130 C OP</i>	7.73
924782	<i>AB2-130 E OP</i>	12.62
924801	<i>AB2-133 C OP</i>	14.2
924802	<i>AB2-133 E OP</i>	19.08
924821	<i>AB2-135 C</i>	12.06
924822	<i>AB2-135 E</i>	18.18
924831	<i>AB2-136 C OP</i>	5.19
924832	<i>AB2-136 E OP</i>	7.37
924881	<i>AB2-142 C</i>	1.14
924882	<i>AB2-142 E</i>	1.85
924891	<i>AB2-143 C OP</i>	3.37
924892	<i>AB2-143 E OP</i>	5.5
924971	<i>AB2-153 C</i>	2.98
924972	<i>AB2-153 E</i>	4.87
925071	<i>AB2-164 C OP</i>	1.5
925072	<i>AB2-164 E OP</i>	2.44
925081	<i>AB2-165 C OP</i>	1.5
925082	<i>AB2-165 E OP</i>	2.44

925091	AB2-166 C	0.4
925092	AB2-166 E	0.7
925101	AB2-167 C	1.05
925102	AB2-167 E	1.72
925151	AB2-172 C OP	4.11
925152	AB2-172 E OP	6.7
925231	AB2-177 C	0.49
925232	AB2-177 E	0.81
925251	AB2-179 C OP	26.29
925252	AB2-179 E OP	8.67
925261	AB2-180 C	2.8
925262	AB2-180 E	1.2
925271	AB2-185 C OP	4.42
925272	AB2-185 E OP	1.89
925311	AB2-192 C OP	1.5
925312	AB2-192 E OP	2.44

Appendix 2

(DP&L - DP&L) The LORETTO 138/69 kV transformer (from bus 232127 to bus 232275 ckt 1) loads from 97.9% to 99.06% (DC power flow) of its emergency rating (71 MVA) for the line fault with failed breaker contingency outage of 'DP56'. This project contributes approximately 1.83 MW to the thermal violation.

```
CONTINGENCY 'DP56'                               /*LORETTO BUS BREAKER
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232117 CKT 1 /*LORETTO
VIENNA 138 1380
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232128 CKT 1 /*LORETTO
PINEY GROVE 138 138
END
```

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232926	CRISFLD1	0.34
904212	V4-022E	0.28
901004	W1-003 E	0.43
901014	W1-004 E	0.43
901024	W1-005 E	0.43
901034	W1-006 E	0.43
907052	X1-032 E	0.58
907323	X1-096 C	0.66
907324	X1-096 E	16.04
920582	Z1-076 C	0.35
920583	Z1-076 E	0.57
920592	Z1-077 C	0.25
920593	Z1-077 E	0.41

917082	Z2-012 E	1.14
921122	AA1-059 C	0.74
921123	AA1-059 E	0.29
918831	AA1-102	1.27
922213	AA2-129 E	1.83
922222	AA2-130	0.35
923902	AB2-030 E	0.37
923931	AB2-033 C	0.66
923932	AB2-033 E	0.26
924361	AB2-084 C	0.55
924362	AB2-084 E	0.9
924681	AB2-120 C OP	3.12
924682	AB2-120 E OP	5.1
925071	AB2-164 C OP	0.7
925072	AB2-164 E OP	1.14
925081	AB2-165 C OP	0.7
925082	AB2-165 E OP	1.14
925101	AB2-167 C	0.35
925102	AB2-167 E	0.58
925311	AB2-192 C OP	0.7
925312	AB2-192 E OP	1.14

Appendix 3

(DP&L - DP&L) The PRESTON-TANYARD 69 kV line (from bus 232233 to bus 232821 ckt 1) loads from 71.63% to 72.74% (DC power flow) of its emergency rating (93 MVA) for the line fault with failed breaker contingency outage of 'DP11'. This project contributes approximately 2.29 MW to the thermal violation.

CONTINGENCY 'DP11' /*STEELE BUS BREAKER TO MILFORD
DISCONNECT BRANCH FROM BUS 232004 TO BUS 232000 CKT 1 /*MILFORD
STEELE 230 230
DISCONNECT BRANCH FROM BUS 232000 TO BUS 232005 CKT 1 /*STEELE
VIENNA 230 230
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232926	CRISFLD1	0.24
293670	O-025 C	0.16
297076	V2-028 C	0.1
297077	V2-028 E	0.81
904212	V4-022E	0.36
232919	VN10	0.61
232907	VN8	4.45
901003	W1-003 C	0.07
901004	W1-003 E	0.52

901013	W1-004 C	0.07
901014	W1-004 E	0.52
901023	W1-005 C	0.07
901024	W1-005 E	0.52
901033	W1-006 C	< 0.01
901034	W1-006 E	0.52
907052	X1-032 E	0.47
907323	X1-096 C	0.46
907324	X1-096 E	11.19
910571	X3-008 C	0.57
910572	X3-008 E	4.78
910591	X3-015 C	0.41
910592	X3-015 E	3.43
913411	Y1-080 C	0.07
913412	Y1-080 E	0.56
915541	Y3-058 C	0.17
915542	Y3-058 E	1.43
920582	Z1-076 C	0.61
920583	Z1-076 E	1.
920592	Z1-077 C	0.44
920593	Z1-077 E	0.71
916441	Z1-100	0.09
916451	Z1-101	0.09
916461	Z1-102	0.09
920602	Z1-103	0.09
917082	Z2-012 E	1.42
920763	Z2-076 E	0.18
920773	Z2-077 E	0.18
920952	AA1-025	0.08
920962	AA1-026	0.08
920972	AA1-027	0.08
920982	AA1-028	0.08
921122	AA1-059 C	0.52
921123	AA1-059 E	0.2
921142	AA1-061 C	4.87
921143	AA1-061 E	2.4
918831	AA1-102	0.88
921592	AA1-140 C	0.67
921593	AA1-140 E	1.1
921602	AA1-141 C	0.65
921603	AA1-141 E	1.07
922213	AA2-129 E	2.29
922222	AA2-130	0.24
922752	AB1-056 C OP	4.91
922753	AB1-056 E OP	14.

922762	<i>AB1-057 C</i>	<i>4.99</i>
922763	<i>AB1-057 E</i>	<i>14.23</i>
923282	<i>AB1-137 C</i>	<i>1.14</i>
923283	<i>AB1-137 E</i>	<i>0.49</i>
923902	<i>AB2-030 E</i>	<i>0.46</i>
923931	<i>AB2-033 C</i>	<i>0.82</i>
923932	<i>AB2-033 E</i>	<i>0.33</i>
924361	<i>AB2-084 C</i>	<i>0.45</i>
924362	<i>AB2-084 E</i>	<i>0.73</i>
924461	<i>AB2-095 C</i>	<i>1.16</i>
924462	<i>AB2-095 E</i>	<i>1.89</i>
924681	<i>AB2-120 C OP</i>	<i>4.32</i>
924682	<i>AB2-120 E OP</i>	<i>7.04</i>
924781	<i>AB2-130 C OP</i>	<i>4.57</i>
924782	<i>AB2-130 E OP</i>	<i>7.46</i>
924831	<i>AB2-136 C OP</i>	<i>7.47</i>
924832	<i>AB2-136 E OP</i>	<i>10.6</i>
925071	<i>AB2-164 C OP</i>	<i>0.87</i>
925072	<i>AB2-164 E OP</i>	<i>1.42</i>
925081	<i>AB2-165 C OP</i>	<i>0.87</i>
925082	<i>AB2-165 E OP</i>	<i>1.42</i>
925091	<i>AB2-166 C</i>	<i>0.26</i>
925092	<i>AB2-166 E</i>	<i>0.45</i>
925101	<i>AB2-167 C</i>	<i>0.61</i>
925102	<i>AB2-167 E</i>	<i>1.</i>
925151	<i>AB2-172 C OP</i>	<i>7.33</i>
925152	<i>AB2-172 E OP</i>	<i>11.96</i>
925231	<i>AB2-177 C</i>	<i>0.29</i>
925232	<i>AB2-177 E</i>	<i>0.47</i>
925261	<i>AB2-180 C</i>	<i>2.15</i>
925262	<i>AB2-180 E</i>	<i>0.92</i>
925311	<i>AB2-192 C OP</i>	<i>0.87</i>
925312	<i>AB2-192 E OP</i>	<i>1.42</i>

Appendix 4

(DP&L - DP&L) The TODD-PRESTON 69 kV line (from bus 232234 to bus 232233 ckt 1) loads from 77.65% to 78.76% (DC power flow) of its emergency rating (93 MVA) for the line fault with failed breaker contingency outage of 'DP11'. This project contributes approximately 2.29 MW to the thermal violation.

CONTINGENCY 'DP11'

/*STEELE BUS BREAKER TO MILFORD

DISCONNECT BRANCH FROM BUS 232004 TO BUS 232000 CKT 1

/*MILFORD

STEELE 230 230

DISCONNECT BRANCH FROM BUS 232000 TO BUS 232005 CKT 1
 VIENNA 230 230
 END

/*STEELE

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232926	CRISFLD1	0.24
293670	O-025 C	0.16
297076	V2-028 C	0.1
297077	V2-028 E	0.81
904212	V4-022E	0.36
232919	VN10	0.61
232907	VN8	4.45
901003	W1-003 C	0.07
901004	W1-003 E	0.52
901013	W1-004 C	0.07
901014	W1-004 E	0.52
901023	W1-005 C	0.07
901024	W1-005 E	0.52
901033	W1-006 C	< 0.01
901034	W1-006 E	0.52
907052	X1-032 E	0.47
907323	X1-096 C	0.46
907324	X1-096 E	11.19
910571	X3-008 C	0.57
910572	X3-008 E	4.78
910591	X3-015 C	0.41
910592	X3-015 E	3.43
913411	Y1-080 C	0.07
913412	Y1-080 E	0.56
915541	Y3-058 C	0.17
915542	Y3-058 E	1.43
920582	Z1-076 C	0.61
920583	Z1-076 E	1.
920592	Z1-077 C	0.44
920593	Z1-077 E	0.71
916441	Z1-100	0.09
916451	Z1-101	0.09
916461	Z1-102	0.09
920602	Z1-103	0.09
917082	Z2-012 E	1.42
920763	Z2-076 E	0.18
920773	Z2-077 E	0.18
920952	AA1-025	0.08
920962	AA1-026	0.08
920972	AA1-027	0.08
920982	AA1-028	0.08

921122	AA1-059 C	0.52
921123	AA1-059 E	0.2
921142	AA1-061 C	4.87
921143	AA1-061 E	2.4
918831	AA1-102	0.88
921592	AA1-140 C	0.67
921593	AA1-140 E	1.1
921602	AA1-141 C	0.65
921603	AA1-141 E	1.07
922213	AA2-129 E	2.29
922222	AA2-130	0.24
922752	AB1-056 C OP	4.91
922753	AB1-056 E OP	14.
922762	AB1-057 C	4.99
922763	AB1-057 E	14.23
923282	AB1-137 C	1.14
923283	AB1-137 E	0.49
923902	AB2-030 E	0.46
923931	AB2-033 C	0.82
923932	AB2-033 E	0.33
924361	AB2-084 C	0.45
924362	AB2-084 E	0.73
924461	AB2-095 C	1.16
924462	AB2-095 E	1.89
924681	AB2-120 C OP	4.32
924682	AB2-120 E OP	7.04
924781	AB2-130 C OP	4.57
924782	AB2-130 E OP	7.46
924831	AB2-136 C OP	7.47
924832	AB2-136 E OP	10.6
925071	AB2-164 C OP	0.87
925072	AB2-164 E OP	1.42
925081	AB2-165 C OP	0.87
925082	AB2-165 E OP	1.42
925091	AB2-166 C	0.26
925092	AB2-166 E	0.45
925101	AB2-167 C	0.61
925102	AB2-167 E	1.
925151	AB2-172 C OP	7.33
925152	AB2-172 E OP	11.96
925231	AB2-177 C	0.29
925232	AB2-177 E	0.47
925261	AB2-180 C	2.15
925262	AB2-180 E	0.92
925311	AB2-192 C OP	0.87

925312	AB2-192 E OP	1.42
--------	--------------	------

Appendix 5

(DP&L - DP&L) The MILF_230-STEELE 230 kV line (from bus 232004 to bus 232000 ckt 1) loads from 147.01% to 147.81% (DC power flow) of its emergency rating (551 MVA) for the tower line contingency outage of 'DBL_4NC'. This project contributes approximately 9.82 MW to the thermal violation.

CONTINGENCY 'DBL_4NC'

/* RED LION-CEDAR CREEK

230;RED LION-CARTANZA 230

OPEN LINE FROM BUS 231004 TO BUS 232002 CKT 1

OPEN LINE FROM BUS 231004 TO BUS 232003 CKT 1

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232900	DEMECSMY	5.99
232616	GEN FOOD	2.19
232904	IR4	52.79
232923	MR1	12.53
232924	MR2	12.53
232922	MR3	14.73
232901	NORTHST	6.5
297077	V2-028 E	1.28
904212	V4-022E	1.52
901004	W1-003 E	2.22
901014	W1-004 E	2.22
901024	W1-005 E	2.22
901034	W1-006 E	2.22
901411	W1-062	6.37
903511	W3-032A	44.61
907052	X1-032 E	1.89
907324	X1-096 E	42.96
910572	X3-008 E	3.32
910592	X3-015 E	3.81
913412	Y1-080 E	0.68
920543	Y3-054 E	8.3
915542	Y3-058 E	4.1
920582	Z1-076 C	2.64
920583	Z1-076 E	4.3
920592	Z1-077 C	1.88
920593	Z1-077 E	3.07
917082	Z2-012 E	6.09
920763	Z2-076 E	1.22
920773	Z2-077 E	1.22
921122	AA1-059 C	1.99

921123	AA1-059 E	0.79
921142	AA1-061 C	3.72
921143	AA1-061 E	1.83
921592	AA1-140 C	4.6
921593	AA1-140 E	7.51
921602	AA1-141 C	2.84
921603	AA1-141 E	4.63
921872	AA2-069	390.51
922213	AA2-129 E	9.83
922222	AA2-130	0.92
922752	AB1-056 C OP	41.89
922753	AB1-056 E OP	119.3
922762	AB1-057 C	42.54
922763	AB1-057 E	121.26
923282	AB1-137 C	8.78
923283	AB1-137 E	3.76
923902	AB2-030 E	1.96
923931	AB2-033 C	3.52
923932	AB2-033 E	1.39
924361	AB2-084 C	1.79
924362	AB2-084 E	2.93
924461	AB2-095 C	6.46
924462	AB2-095 E	10.53
924681	AB2-120 C OP	18.81
924682	AB2-120 E OP	30.7
924781	AB2-130 C OP	19.74
924782	AB2-130 E OP	32.21
924831	AB2-136 C OP	7.6
924832	AB2-136 E OP	10.79
925071	AB2-164 C OP	3.73
925072	AB2-164 E OP	6.09
925081	AB2-165 C OP	3.73
925082	AB2-165 E OP	6.09
925091	AB2-166 C	0.95
925092	AB2-166 E	1.66
925101	AB2-167 C	2.63
925102	AB2-167 E	4.31
925151	AB2-172 C OP	5.08
925152	AB2-172 E OP	8.29
925231	AB2-177 C	1.25
925232	AB2-177 E	2.04
925261	AB2-180 C	6.18
925262	AB2-180 E	2.65
925311	AB2-192 C OP	3.73
925312	AB2-192 E OP	6.09

Appendix 6

(DP&L - DP&L) The PINEY_69-M HERMON 69 kV line (from bus 232274 to bus 232272 ckt 1) loads from 127.43% to 130.8% (DC power flow) of its emergency rating (143 MVA) for the line fault with failed breaker contingency outage of 'DP15'. This project contributes approximately 4.83 MW to the thermal violation.

CONTINGENCY 'DP15' /*INDIAN RIVER BUS BREAKER TO
 PINEY GROVE
 DISCONNECT BRANCH FROM BUS 232007 TO BUS 232006 CKT 1 /*PINEY GR
 INDRIV 4 230 230
 DISCONNECT BRANCH FROM BUS 232007 TO BUS 232128 CKT 1 /*PINEY GR
 PINEY GR 230 138
 DISCONNECT BRANCH FROM BUS 232006 TO BUS 232004 CKT 1 /*MILFORD
 INDIAN RIVER 230 230
 END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232905	BAYVIEW1	0.59
232926	CRISFLD1	0.36
232912	OH NUG1	2.1
232913	OH NUG2	2.07
232914	OH NUG3	2.1
232915	OH NUG4	2.1
232916	OH NUG5	2.1
232917	OH NUG6	2.09
232918	OH NUG7	2.09
232921	TASLEY2G	1.46
904210	V4-022C	0.09
904212	V4-022E	0.75
901003	W1-003 C	0.15
901004	W1-003 E	1.07
901013	W1-004 C	0.15
901014	W1-004 E	1.07
901023	W1-005 C	0.15
901024	W1-005 E	1.07
901033	W1-006 C	< 0.01
901034	W1-006 E	1.07
907052	X1-032 E	0.82
907323	X1-096 C	0.71
907324	X1-096 E	17.31
920582	Z1-076 C	1.54
920583	Z1-076 E	2.52
920592	Z1-077 C	1.1
920593	Z1-077 E	1.8

916441	Z1-100	0.19
916451	Z1-101	0.19
916461	Z1-102	0.19
920602	Z1-103	0.19
917081	Z2-012 C	0.36
917082	Z2-012 E	2.99
920952	AA1-025	0.17
920962	AA1-026	0.17
920972	AA1-027	0.17
920982	AA1-028	0.17
921122	AA1-059 C	0.8
921123	AA1-059 E	0.32
918831	AA1-102	1.37
921602	AA1-141 C	1.86
921603	AA1-141 E	3.04
922213	AA2-129 E	4.76
922222	AA2-130	0.37
923902	AB2-030 E	0.97
923931	AB2-033 C	1.73
923932	AB2-033 E	0.68
924361	AB2-084 C	0.78
924362	AB2-084 E	1.27
924681	AB2-120 C OP	9.21
924682	AB2-120 E OP	15.02
925071	AB2-164 C OP	1.83
925072	AB2-164 E OP	2.99
925081	AB2-165 C OP	1.83
925082	AB2-165 E OP	2.99
925101	AB2-167 C	1.54
925102	AB2-167 E	2.53
925231	AB2-177 C	0.82
925232	AB2-177 E	1.34
925311	AB2-192 C OP	1.83
925312	AB2-192 E OP	2.99

Appendix 7

(DP&L - DP&L) The LORET_69-FRUITLND 69 kV line (from bus 232275 to bus 232288 ckt 1) loads from 105.26% to 107.79% (DC power flow) of its emergency rating (137 MVA) for the line fault with failed breaker contingency outage of 'DP56'. This project contributes approximately 3.47 MW to the thermal violation.

CONTINGENCY 'DP56'

/*LORETTO BUS BREAKER

DISCONNECT BRANCH FROM BUS 232127 TO BUS 232117 CKT 1
 VIENNA 138 1380
 DISCONNECT BRANCH FROM BUS 232127 TO BUS 232128 CKT 1
 PINEY GROVE 138 138
 END

/*LORETTO

/*LORETTO

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232905	BAYVIEW1	0.42
232926	CRISFLD1	0.64
232912	OH NUG1	1.52
232913	OH NUG2	1.5
232914	OH NUG3	1.52
232915	OH NUG4	1.52
232916	OH NUG5	1.52
232917	OH NUG6	1.52
232918	OH NUG7	1.51
232921	TASLEY2G	1.05
904210	V4-022C	0.06
904212	V4-022E	0.54
901003	W1-003 C	0.12
901004	W1-003 E	0.82
901013	W1-004 C	0.12
901014	W1-004 E	0.82
901023	W1-005 C	0.12
901024	W1-005 E	0.82
901033	W1-006 C	< 0.01
901034	W1-006 E	0.82
907052	X1-032 E	1.1
907323	X1-096 C	1.25
907324	X1-096 E	30.34
920582	Z1-076 C	0.67
920583	Z1-076 E	1.09
920592	Z1-077 C	0.48
920593	Z1-077 E	0.78
916441	Z1-100	0.15
916451	Z1-101	0.15
916461	Z1-102	0.15
920602	Z1-103	0.15
917081	Z2-012 C	0.26
917082	Z2-012 E	2.15
920952	AA1-025	0.13
920962	AA1-026	0.13
920972	AA1-027	0.13
920982	AA1-028	0.13
921122	AA1-059 C	1.4
921123	AA1-059 E	0.55

918831	AA1-102	2.4
921602	AA1-141 C	0.52
921603	AA1-141 E	0.85
922213	AA2-129 E	3.46
922222	AA2-130	0.65
923902	AB2-030 E	0.69
923931	AB2-033 C	1.24
923932	AB2-033 E	0.49
924361	AB2-084 C	1.04
924362	AB2-084 E	1.7
924681	AB2-120 C OP	5.91
924682	AB2-120 E OP	9.64
925071	AB2-164 C OP	1.32
925072	AB2-164 E OP	2.15
925081	AB2-165 C OP	1.32
925082	AB2-165 E OP	2.15
925101	AB2-167 C	0.66
925102	AB2-167 E	1.09
925231	AB2-177 C	0.23
925232	AB2-177 E	0.38
925311	AB2-192 C OP	1.32
925312	AB2-192 E OP	2.15

Appendix 8

(DP&L - DP&L) The FRUITLND-PEMBERTN 69 kV line (from bus 232288 to bus 232273 ckt 1) loads from 112.98% to 116.79% (DC power flow) of its emergency rating (91 MVA) for the line fault with failed breaker contingency outage of 'DP56'. This project contributes approximately 3.47 MW to the thermal violation.

CONTINGENCY 'DP56' /*LORETTO BUS BREAKER
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232117 CKT 1 /*LORETTO
VIENNA 138 1380
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232128 CKT 1 /*LORETTO
PINEY GROVE 138 138
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232905	BAYVIEW1	0.42
232926	CRISFLD1	0.64
232912	OH NUG1	1.52
232913	OH NUG2	1.5
232914	OH NUG3	1.52
232915	OH NUG4	1.52
232916	OH NUG5	1.52

232917	<i>OH NUG6</i>	1.52
232918	<i>OH NUG7</i>	1.51
232921	<i>TASLEY2G</i>	1.05
904210	<i>V4-022C</i>	0.06
904212	<i>V4-022E</i>	0.54
901003	<i>W1-003 C</i>	0.12
901004	<i>W1-003 E</i>	0.82
901013	<i>W1-004 C</i>	0.12
901014	<i>W1-004 E</i>	0.82
901023	<i>W1-005 C</i>	0.12
901024	<i>W1-005 E</i>	0.82
901033	<i>W1-006 C</i>	< 0.01
901034	<i>W1-006 E</i>	0.82
907052	<i>X1-032 E</i>	1.1
907323	<i>X1-096 C</i>	1.25
907324	<i>X1-096 E</i>	30.34
920582	<i>Z1-076 C</i>	0.67
920583	<i>Z1-076 E</i>	1.09
920592	<i>Z1-077 C</i>	0.48
920593	<i>Z1-077 E</i>	0.78
916441	<i>Z1-100</i>	0.15
916451	<i>Z1-101</i>	0.15
916461	<i>Z1-102</i>	0.15
920602	<i>Z1-103</i>	0.15
917081	<i>Z2-012 C</i>	0.26
917082	<i>Z2-012 E</i>	2.15
920952	<i>AA1-025</i>	0.13
920962	<i>AA1-026</i>	0.13
920972	<i>AA1-027</i>	0.13
920982	<i>AA1-028</i>	0.13
921122	<i>AA1-059 C</i>	1.4
921123	<i>AA1-059 E</i>	0.55
918831	<i>AA1-102</i>	2.4
921602	<i>AA1-141 C</i>	0.52
921603	<i>AA1-141 E</i>	0.85
922213	<i>AA2-129 E</i>	3.46
922222	<i>AA2-130</i>	0.65
923902	<i>AB2-030 E</i>	0.69
923931	<i>AB2-033 C</i>	1.24
923932	<i>AB2-033 E</i>	0.49
924361	<i>AB2-084 C</i>	1.04
924362	<i>AB2-084 E</i>	1.7
924681	<i>AB2-120 C OP</i>	5.91
924682	<i>AB2-120 E OP</i>	9.64
925071	<i>AB2-164 C OP</i>	1.32

925072	AB2-164 E OP	2.15
925081	AB2-165 C OP	1.32
925082	AB2-165 E OP	2.15
925101	AB2-167 C	0.66
925102	AB2-167 E	1.09
925231	AB2-177 C	0.23
925232	AB2-177 E	0.38
925311	AB2-192 C OP	1.32
925312	AB2-192 E OP	2.15

Appendices (Secondary Point of Interconnection)

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact.

It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Appendix 1

(DP&L - DP&L) The LORETTO 138/69 kV transformer (from bus 232127 to bus 232275 ckt 1) loads from 97.68% to 98.89% (DC power flow) of its emergency rating (71 MVA) for the line fault with failed breaker contingency outage of 'DP56'. This project contributes approximately 1.91 MW to the thermal violation.

```
CONTINGENCY 'DP56'                               /*LORETTO BUS BREAKER
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232117 CKT 1 /*LORETTO
VIENNA 138 1380
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232128 CKT 1 /*LORETTO
PINEY GROVE 138 138
END
```

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232926	CRISFLD1	0.34
904212	V4-022E	0.28
901004	W1-003 E	0.43
901014	W1-004 E	0.43
901024	W1-005 E	0.43
901034	W1-006 E	0.43

907052	XI-032 E	0.58
907323	XI-096 C	0.66
907324	XI-096 E	16.04
920582	ZI-076 C	0.35
920583	ZI-076 E	0.57
920592	ZI-077 C	0.25
920593	ZI-077 E	0.41
917082	Z2-012 E	1.14
921122	AA1-059 C	0.74
921123	AA1-059 E	0.29
918831	AA1-102	1.27
922213	AA2-129 E	1.83
922222	AA2-130	0.35
923902	AB2-030 E	0.37
923931	AB2-033 C	0.66
923932	AB2-033 E	0.26
924361	AB2-084 C	0.55
924362	AB2-084 E	0.9
924681	AB2-120 C OP	2.99
924682	AB2-120 E OP	4.88
925071	AB2-164 C OP	0.72
925072	AB2-164 E OP	1.18
925081	AB2-165 C OP	0.7
925082	AB2-165 E OP	1.14
925101	AB2-167 C	0.35
925102	AB2-167 E	0.58
925311	AB2-192 C OP	0.72
925312	AB2-192 E OP	1.18

Appendix 2

(DP&L - DP&L) The KINGS CK-LORETTO 138 kV line (from bus 232129 to bus 232127 ckt 1) loads from 91.89% to 95.03% (DC power flow) of its emergency rating (351 MVA) for the line fault with failed breaker contingency outage of 'DP59'. This project contributes approximately 11.02 MW to the thermal violation.

CONTINGENCY 'DP59' /*PINEY GROVE BUS BREAKER
DISCONNECT BRANCH FROM BUS 232131 TO BUS 232128 CKT 1 /*PINEY GROVE
NEW CHURCH 138 138
DISCONNECT BRANCH FROM BUS 232007 TO BUS 232128 CKT 1 /*PINEY GROVE
PINEY GROVE 230 138
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232905	BAYVIEW1	1.29

232926	<i>CRISFLD1</i>	1.66
232912	<i>OH NUG1</i>	4.86
232913	<i>OH NUG2</i>	4.79
232914	<i>OH NUG3</i>	4.86
232915	<i>OH NUG4</i>	4.86
232916	<i>OH NUG5</i>	4.86
232917	<i>OH NUG6</i>	4.84
232918	<i>OH NUG7</i>	4.82
232921	<i>TASLEY2G</i>	3.17
904210	<i>V4-022C</i>	0.2
904212	<i>V4-022E</i>	1.63
901003	<i>W1-003 C</i>	0.35
901004	<i>W1-003 E</i>	2.5
901013	<i>W1-004 C</i>	0.35
901014	<i>W1-004 E</i>	2.5
901023	<i>W1-005 C</i>	0.35
901024	<i>W1-005 E</i>	2.5
901033	<i>W1-006 C</i>	< 0.01
901034	<i>W1-006 E</i>	2.5
907052	<i>X1-032 E</i>	2.96
907323	<i>X1-096 C</i>	3.24
907324	<i>X1-096 E</i>	78.81
920582	<i>Z1-076 C</i>	1.95
920583	<i>Z1-076 E</i>	3.18
920592	<i>Z1-077 C</i>	1.39
920593	<i>Z1-077 E</i>	2.27
916441	<i>Z1-100</i>	0.45
916451	<i>Z1-101</i>	0.45
916461	<i>Z1-102</i>	0.45
920602	<i>Z1-103</i>	0.45
917081	<i>Z2-012 C</i>	0.78
917082	<i>Z2-012 E</i>	6.51
920952	<i>AA1-025</i>	0.4
920962	<i>AA1-026</i>	0.4
920972	<i>AA1-027</i>	0.4
920982	<i>AA1-028</i>	0.4
921122	<i>AA1-059 C</i>	3.64
921123	<i>AA1-059 E</i>	1.44
918831	<i>AA1-102</i>	6.23
921602	<i>AA1-141 C</i>	1.48
921603	<i>AA1-141 E</i>	2.42
922213	<i>AA2-129 E</i>	11.02
922222	<i>AA2-130</i>	1.69
923902	<i>AB2-030 E</i>	2.1
923931	<i>AB2-033 C</i>	3.76

923932	AB2-033 E	1.49
924361	AB2-084 C	2.82
924362	AB2-084 E	4.59
924681	AB2-120 C OP	15.83
924682	AB2-120 E OP	25.83
925071	AB2-164 C OP	4.19
925072	AB2-164 E OP	6.83
925081	AB2-165 C OP	3.99
925082	AB2-165 E OP	6.51
925101	AB2-167 C	1.94
925102	AB2-167 E	3.19
925231	AB2-177 C	0.65
925232	AB2-177 E	1.07
925311	AB2-192 C OP	4.19
925312	AB2-192 E OP	6.83

Appendix 3

(DP&L - DP&L) The POCOMOKE-T-144 TAP 138 kV line (from bus 232130 to bus 886230 ckt 1) loads from 88.12% to 92.58% (DC power flow) of its emergency rating (247 MVA) for the line fault with failed breaker contingency outage of 'DP59'. This project contributes approximately 11.02 MW to the thermal violation.

CONTINGENCY 'DP59' /*PINEY GROVE BUS BREAKER
DISCONNECT BRANCH FROM BUS 232131 TO BUS 232128 CKT 1 /*PINEY GROVE
NEW CHURCH 138 138
DISCONNECT BRANCH FROM BUS 232007 TO BUS 232128 CKT 1 /*PINEY GROVE
PINEY GROVE 230 138
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232905	BAYVIEW1	1.29
232912	OH NUG1	4.86
232913	OH NUG2	4.8
232914	OH NUG3	4.86
232915	OH NUG4	4.86
232916	OH NUG5	4.86
232917	OH NUG6	4.84
232918	OH NUG7	4.83
232921	TASLEY2G	3.17
904210	V4-022C	0.2
904212	V4-022E	1.63
901003	W1-003 C	0.35
901004	W1-003 E	2.5
901013	W1-004 C	0.35

901014	W1-004 E	2.5
901023	W1-005 C	0.35
901024	W1-005 E	2.5
901033	W1-006 C	< 0.01
901034	W1-006 E	2.5
920582	Z1-076 C	1.95
920583	Z1-076 E	3.19
920592	Z1-077 C	1.4
920593	Z1-077 E	2.28
916441	Z1-100	0.45
916451	Z1-101	0.45
916461	Z1-102	0.45
920602	Z1-103	0.45
917081	Z2-012 C	0.78
917082	Z2-012 E	6.52
920952	AA1-025	0.4
920962	AA1-026	0.4
920972	AA1-027	0.4
920982	AA1-028	0.4
921602	AA1-141 C	1.48
921603	AA1-141 E	2.42
922213	AA2-129 E	11.02
923902	AB2-030 E	2.1
923931	AB2-033 C	3.76
923932	AB2-033 E	1.49
924681	AB2-120 C OP	15.85
924682	AB2-120 E OP	25.86
925071	AB2-164 C OP	4.19
925072	AB2-164 E OP	6.84
925081	AB2-165 C OP	3.99
925082	AB2-165 E OP	6.52
925101	AB2-167 C	1.95
925102	AB2-167 E	3.19
925231	AB2-177 C	0.65
925232	AB2-177 E	1.07
925311	AB2-192 C OP	4.19
925312	AB2-192 E OP	6.84

Appendix 4

(DP&L - DP&L) The PRESTON-TANYARD 69 kV line (from bus 232233 to bus 232821 ckt 1) loads from 71.73% to 74.2% (DC power flow) of its emergency rating (93 MVA) for the line fault with failed breaker contingency outage of 'DP11'. This project contributes approximately 2.29 MW to the thermal violation.

CONTINGENCY 'DP11'

/*STEELE BUS BREAKER TO MILFORD

DISCONNECT BRANCH FROM BUS 232004 TO BUS 232000 CKT 1

/*MILFORD

STEELE 230 230

DISCONNECT BRANCH FROM BUS 232000 TO BUS 232005 CKT 1

/*STEELE

VIENNA 230 230

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232926	CRISFLD1	0.24
293670	O-025 C	0.16
297076	V2-028 C	0.1
297077	V2-028 E	0.81
904212	V4-022E	0.36
232919	VN10	0.61
232907	VN8	4.45
901003	W1-003 C	0.07
901004	W1-003 E	0.52
901013	W1-004 C	0.07
901014	W1-004 E	0.52
901023	W1-005 C	0.07
901024	W1-005 E	0.52
901033	W1-006 C	< 0.01
901034	W1-006 E	0.52
907052	X1-032 E	0.47
907323	X1-096 C	0.46
907324	X1-096 E	11.19
910571	X3-008 C	0.57
910572	X3-008 E	4.78
910591	X3-015 C	0.41
910592	X3-015 E	3.43
913411	Y1-080 C	0.07
913412	Y1-080 E	0.56
915541	Y3-058 C	0.17
915542	Y3-058 E	1.43
920582	Z1-076 C	0.61
920583	Z1-076 E	1.
920592	Z1-077 C	0.44
920593	Z1-077 E	0.71
916441	Z1-100	0.09
916451	Z1-101	0.09
916461	Z1-102	0.09
920602	Z1-103	0.09
917082	Z2-012 E	1.42
920763	Z2-076 E	0.18
920773	Z2-077 E	0.18

920952	AAI-025	0.08
920962	AAI-026	0.08
920972	AAI-027	0.08
920982	AAI-028	0.08
921122	AAI-059 C	0.52
921123	AAI-059 E	0.2
921142	AAI-061 C	4.87
921143	AAI-061 E	2.4
918831	AAI-102	0.88
921592	AAI-140 C	0.67
921593	AAI-140 E	1.1
921602	AAI-141 C	0.65
921603	AAI-141 E	1.07
922213	AA2-129 E	2.29
922222	AA2-130	0.24
922752	ABI-056 C OP	4.91
922753	ABI-056 E OP	14.
922762	ABI-057 C	4.99
922763	ABI-057 E	14.23
923282	ABI-137 C	1.14
923283	ABI-137 E	0.49
923902	AB2-030 E	0.46
923931	AB2-033 C	0.82
923932	AB2-033 E	0.33
924361	AB2-084 C	0.45
924362	AB2-084 E	0.73
924461	AB2-095 C	1.16
924462	AB2-095 E	1.89
924681	AB2-120 C OP	4.31
924682	AB2-120 E OP	7.03
924781	AB2-130 C OP	4.54
924782	AB2-130 E OP	7.4
924831	AB2-136 C OP	7.55
924832	AB2-136 E OP	10.72
925071	AB2-164 C OP	0.87
925072	AB2-164 E OP	1.42
925081	AB2-165 C OP	0.87
925082	AB2-165 E OP	1.42
925091	AB2-166 C	0.26
925092	AB2-166 E	0.45
925101	AB2-167 C	0.61
925102	AB2-167 E	1.
925151	AB2-172 C OP	7.23
925152	AB2-172 E OP	11.8
925231	AB2-177 C	0.29

925232	AB2-177 E	0.47
925261	AB2-180 C	2.15
925262	AB2-180 E	0.92
925311	AB2-192 C OP	0.87
925312	AB2-192 E OP	1.42

Appendix 5

(DP&L - DP&L) The TODD-PRESTON 69 kV line (from bus 232234 to bus 232233 ckt 1) loads from 77.75% to 80.22% (DC power flow) of its emergency rating (93 MVA) for the line fault with failed breaker contingency outage of 'DP11'. This project contributes approximately 2.29 MW to the thermal violation.

CONTINGENCY 'DP11' /*STEELE BUS BREAKER TO MILFORD
DISCONNECT BRANCH FROM BUS 232004 TO BUS 232000 CKT 1 /*MILFORD
STEELE 230 230
DISCONNECT BRANCH FROM BUS 232000 TO BUS 232005 CKT 1 /*STEELE
VIENNA 230 230
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232926	CRISFLD1	0.24
293670	O-025 C	0.16
297076	V2-028 C	0.1
297077	V2-028 E	0.81
904212	V4-022E	0.36
232919	VN10	0.61
232907	VN8	4.45
901003	W1-003 C	0.07
901004	W1-003 E	0.52
901013	W1-004 C	0.07
901014	W1-004 E	0.52
901023	W1-005 C	0.07
901024	W1-005 E	0.52
901033	W1-006 C	< 0.01
901034	W1-006 E	0.52
907052	X1-032 E	0.47
907323	X1-096 C	0.46
907324	X1-096 E	11.19
910571	X3-008 C	0.57
910572	X3-008 E	4.78
910591	X3-015 C	0.41
910592	X3-015 E	3.43
913411	Y1-080 C	0.07
913412	Y1-080 E	0.56

915541	Y3-058 C	0.17
915542	Y3-058 E	1.43
920582	Z1-076 C	0.61
920583	Z1-076 E	1.
920592	Z1-077 C	0.44
920593	Z1-077 E	0.71
916441	Z1-100	0.09
916451	Z1-101	0.09
916461	Z1-102	0.09
920602	Z1-103	0.09
917082	Z2-012 E	1.42
920763	Z2-076 E	0.18
920773	Z2-077 E	0.18
920952	AA1-025	0.08
920962	AA1-026	0.08
920972	AA1-027	0.08
920982	AA1-028	0.08
921122	AA1-059 C	0.52
921123	AA1-059 E	0.2
921142	AA1-061 C	4.87
921143	AA1-061 E	2.4
918831	AA1-102	0.88
921592	AA1-140 C	0.67
921593	AA1-140 E	1.1
921602	AA1-141 C	0.65
921603	AA1-141 E	1.07
922213	AA2-129 E	2.29
922222	AA2-130	0.24
922752	AB1-056 C OP	4.91
922753	AB1-056 E OP	14.
922762	AB1-057 C	4.99
922763	AB1-057 E	14.23
923282	AB1-137 C	1.14
923283	AB1-137 E	0.49
923902	AB2-030 E	0.46
923931	AB2-033 C	0.82
923932	AB2-033 E	0.33
924361	AB2-084 C	0.45
924362	AB2-084 E	0.73
924461	AB2-095 C	1.16
924462	AB2-095 E	1.89
924681	AB2-120 C OP	4.31
924682	AB2-120 E OP	7.03
924781	AB2-130 C OP	4.54
924782	AB2-130 E OP	7.4

924831	AB2-136 C OP	7.55
924832	AB2-136 E OP	10.72
925071	AB2-164 C OP	0.87
925072	AB2-164 E OP	1.42
925081	AB2-165 C OP	0.87
925082	AB2-165 E OP	1.42
925091	AB2-166 C	0.26
925092	AB2-166 E	0.45
925101	AB2-167 C	0.61
925102	AB2-167 E	1.
925151	AB2-172 C OP	7.23
925152	AB2-172 E OP	11.8
925231	AB2-177 C	0.29
925232	AB2-177 E	0.47
925261	AB2-180 C	2.15
925262	AB2-180 E	0.92
925311	AB2-192 C OP	0.87
925312	AB2-192 E OP	1.42

Appendix 6

(DP&L - DP&L) The T-144 TAP-COSTEN 138 kV line (from bus 886230 to bus 232807 ckt 1) loads from 88.12% to 92.58% (DC power flow) of its emergency rating (247 MVA) for the line fault with failed breaker contingency outage of 'DP59'. This project contributes approximately 11.02 MW to the thermal violation.

CONTINGENCY 'DP59' /*PINEY GROVE BUS BREAKER
DISCONNECT BRANCH FROM BUS 232131 TO BUS 232128 CKT 1 /*PINEY GROVE
NEW CHURCH 138 138
DISCONNECT BRANCH FROM BUS 232007 TO BUS 232128 CKT 1 /*PINEY GROVE
PINEY GROVE 230 138
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232905	BAYVIEW1	1.29
232912	OH NUG1	4.86
232913	OH NUG2	4.8
232914	OH NUG3	4.86
232915	OH NUG4	4.86
232916	OH NUG5	4.86
232917	OH NUG6	4.84
232918	OH NUG7	4.83
232921	TASLEY2G	3.17
904210	V4-022C	0.2
904212	V4-022E	1.63

901003	W1-003 C	0.35
901004	W1-003 E	2.5
901013	W1-004 C	0.35
901014	W1-004 E	2.5
901023	W1-005 C	0.35
901024	W1-005 E	2.5
901033	W1-006 C	< 0.01
901034	W1-006 E	2.5
920582	Z1-076 C	1.95
920583	Z1-076 E	3.19
920592	Z1-077 C	1.4
920593	Z1-077 E	2.28
916441	Z1-100	0.45
916451	Z1-101	0.45
916461	Z1-102	0.45
920602	Z1-103	0.45
917081	Z2-012 C	0.78
917082	Z2-012 E	6.52
920952	AA1-025	0.4
920962	AA1-026	0.4
920972	AA1-027	0.4
920982	AA1-028	0.4
921602	AA1-141 C	1.48
921603	AA1-141 E	2.42
922213	AA2-129 E	11.02
923902	AB2-030 E	2.1
923931	AB2-033 C	3.76
923932	AB2-033 E	1.49
924681	AB2-120 C OP	15.85
924682	AB2-120 E OP	25.86
925071	AB2-164 C OP	4.19
925072	AB2-164 E OP	6.84
925081	AB2-165 C OP	3.99
925082	AB2-165 E OP	6.52
925101	AB2-167 C	1.95
925102	AB2-167 E	3.19
925231	AB2-177 C	0.65
925232	AB2-177 E	1.07
925311	AB2-192 C OP	4.19
925312	AB2-192 E OP	6.84

Appendix 7

(DP&L - DP&L) The MILF_230-STEELE 230 kV line (from bus 232004 to bus 232000 ckt 1) loads from 147.03% to 147.83% (DC power flow) of its emergency rating (551 MVA) for the tower line contingency outage of 'DBL_4NC'. This project contributes approximately 9.8 MW to the thermal violation.

CONTINGENCY 'DBL_4NC'

/* RED LION-CEDAR CREEK

230;RED LION-CARTANZA 230

OPEN LINE FROM BUS 231004 TO BUS 232002 CKT 1

OPEN LINE FROM BUS 231004 TO BUS 232003 CKT 1

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232900	DEMECSMY	5.99
232616	GEN FOOD	2.19
232904	IR4	52.79
232923	MR1	12.53
232924	MR2	12.53
232922	MR3	14.73
232901	NORTHST	6.5
297077	V2-028 E	1.28
904212	V4-022E	1.52
901004	W1-003 E	2.22
901014	W1-004 E	2.22
901024	W1-005 E	2.22
901034	W1-006 E	2.22
901411	W1-062	6.37
903511	W3-032A	44.61
907052	X1-032 E	1.89
907324	X1-096 E	42.96
910572	X3-008 E	3.32
910592	X3-015 E	3.81
913412	Y1-080 E	0.68
920543	Y3-054 E	8.3
915542	Y3-058 E	4.1
920582	Z1-076 C	2.64
920583	Z1-076 E	4.3
920592	Z1-077 C	1.88
920593	Z1-077 E	3.07
917082	Z2-012 E	6.09
920763	Z2-076 E	1.22
920773	Z2-077 E	1.22
921122	AA1-059 C	1.99
921123	AA1-059 E	0.79
921142	AA1-061 C	3.72

921143	AA1-061 E	1.83
921592	AA1-140 C	4.6
921593	AA1-140 E	7.51
921602	AA1-141 C	2.84
921603	AA1-141 E	4.63
921872	AA2-069	390.51
922213	AA2-129 E	9.83
922222	AA2-130	0.92
922752	AB1-056 C OP	41.89
922753	AB1-056 E OP	119.3
922762	AB1-057 C	42.54
922763	AB1-057 E	121.26
923282	AB1-137 C	8.78
923283	AB1-137 E	3.76
923902	AB2-030 E	1.96
923931	AB2-033 C	3.52
923932	AB2-033 E	1.39
924361	AB2-084 C	1.79
924362	AB2-084 E	2.93
924461	AB2-095 C	6.46
924462	AB2-095 E	10.53
924681	AB2-120 C OP	18.86
924682	AB2-120 E OP	30.77
924781	AB2-130 C OP	19.84
924782	AB2-130 E OP	32.38
924831	AB2-136 C OP	7.57
924832	AB2-136 E OP	10.74
925071	AB2-164 C OP	3.72
925072	AB2-164 E OP	6.08
925081	AB2-165 C OP	3.73
925082	AB2-165 E OP	6.09
925091	AB2-166 C	0.95
925092	AB2-166 E	1.66
925101	AB2-167 C	2.63
925102	AB2-167 E	4.31
925151	AB2-172 C OP	5.12
925152	AB2-172 E OP	8.36
925231	AB2-177 C	1.25
925232	AB2-177 E	2.04
925261	AB2-180 C	6.18
925262	AB2-180 E	2.65
925311	AB2-192 C OP	3.72
925312	AB2-192 E OP	6.08

Appendix 8

(DP&L - DP&L) The PINEY_69-M HERMON 69 kV line (from bus 232274 to bus 232272 ckt 1) loads from 127.65% to 130.95% (DC power flow) of its emergency rating (143 MVA) for the line fault with failed breaker contingency outage of 'DP15'. This project contributes approximately 4.73 MW to the thermal violation.

CONTINGENCY 'DP15' /*INDIAN RIVER BUS BREAKER TO
 PINEY GROVE
 DISCONNECT BRANCH FROM BUS 232007 TO BUS 232006 CKT 1 /*PINEY GR
 INDRIV 4 230 230
 DISCONNECT BRANCH FROM BUS 232007 TO BUS 232128 CKT 1 /*PINEY GR
 PINEY GR 230 138
 DISCONNECT BRANCH FROM BUS 232006 TO BUS 232004 CKT 1 /*MILFORD
 INDIAN RIVER 230 230
 END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232905	BAYVIEW1	0.59
232926	CRISFLD1	0.36
232912	OH NUG1	2.1
232913	OH NUG2	2.07
232914	OH NUG3	2.1
232915	OH NUG4	2.1
232916	OH NUG5	2.1
232917	OH NUG6	2.09
232918	OH NUG7	2.09
232921	TASLEY2G	1.46
904210	V4-022C	0.09
904212	V4-022E	0.75
901003	W1-003 C	0.15
901004	W1-003 E	1.07
901013	W1-004 C	0.15
901014	W1-004 E	1.07
901023	W1-005 C	0.15
901024	W1-005 E	1.07
901033	W1-006 C	< 0.01
901034	W1-006 E	1.07
907052	X1-032 E	0.82
907323	X1-096 C	0.71
907324	X1-096 E	17.31
920582	Z1-076 C	1.54
920583	Z1-076 E	2.52
920592	Z1-077 C	1.1
920593	Z1-077 E	1.8

916441	Z1-100	0.19
916451	Z1-101	0.19
916461	Z1-102	0.19
920602	Z1-103	0.19
917081	Z2-012 C	0.36
917082	Z2-012 E	2.99
920952	AA1-025	0.17
920962	AA1-026	0.17
920972	AA1-027	0.17
920982	AA1-028	0.17
921122	AA1-059 C	0.8
921123	AA1-059 E	0.32
918831	AA1-102	1.37
921602	AA1-141 C	1.86
921603	AA1-141 E	3.04
922213	AA2-129 E	4.76
922222	AA2-130	0.37
923902	AB2-030 E	0.97
923931	AB2-033 C	1.73
923932	AB2-033 E	0.68
924361	AB2-084 C	0.78
924362	AB2-084 E	1.27
924681	AB2-120 C OP	9.32
924682	AB2-120 E OP	15.21
925071	AB2-164 C OP	1.8
925072	AB2-164 E OP	2.93
925081	AB2-165 C OP	1.83
925082	AB2-165 E OP	2.99
925101	AB2-167 C	1.54
925102	AB2-167 E	2.53
925231	AB2-177 C	0.82
925232	AB2-177 E	1.34
925311	AB2-192 C OP	1.8
925312	AB2-192 E OP	2.93

Appendix 9

(DP&L - DP&L) The LORET_69-FRUITLND 69 kV line (from bus 232275 to bus 232288 ckt 1) loads from 104.78% to 107.41% (DC power flow) of its emergency rating (137 MVA) for the line fault with failed breaker contingency outage of 'DP56'. This project contributes approximately 3.6 MW to the thermal violation.

CONTINGENCY 'DP56'

/*LORETTO BUS BREAKER

DISCONNECT BRANCH FROM BUS 232127 TO BUS 232117 CKT 1
 VIENNA 138 1380
 DISCONNECT BRANCH FROM BUS 232127 TO BUS 232128 CKT 1
 PINEY GROVE 138 138
 END

/*LORETTO

/*LORETTO

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232905	BAYVIEW1	0.42
232926	CRISFLD1	0.64
232912	OH NUG1	1.52
232913	OH NUG2	1.5
232914	OH NUG3	1.52
232915	OH NUG4	1.52
232916	OH NUG5	1.52
232917	OH NUG6	1.52
232918	OH NUG7	1.51
232921	TASLEY2G	1.05
904210	V4-022C	0.06
904212	V4-022E	0.54
901003	W1-003 C	0.12
901004	W1-003 E	0.82
901013	W1-004 C	0.12
901014	W1-004 E	0.82
901023	W1-005 C	0.12
901024	W1-005 E	0.82
901033	W1-006 C	< 0.01
901034	W1-006 E	0.82
907052	X1-032 E	1.1
907323	X1-096 C	1.25
907324	X1-096 E	30.34
920582	Z1-076 C	0.67
920583	Z1-076 E	1.09
920592	Z1-077 C	0.48
920593	Z1-077 E	0.78
916441	Z1-100	0.15
916451	Z1-101	0.15
916461	Z1-102	0.15
920602	Z1-103	0.15
917081	Z2-012 C	0.26
917082	Z2-012 E	2.15
920952	AA1-025	0.13
920962	AA1-026	0.13
920972	AA1-027	0.13
920982	AA1-028	0.13
921122	AA1-059 C	1.4
921123	AA1-059 E	0.55

918831	AA1-102	2.4
921602	AA1-141 C	0.52
921603	AA1-141 E	0.85
922213	AA2-129 E	3.46
922222	AA2-130	0.65
923902	AB2-030 E	0.69
923931	AB2-033 C	1.24
923932	AB2-033 E	0.49
924361	AB2-084 C	1.04
924362	AB2-084 E	1.7
924681	AB2-120 C OP	5.66
924682	AB2-120 E OP	9.23
925071	AB2-164 C OP	1.37
925072	AB2-164 E OP	2.23
925081	AB2-165 C OP	1.32
925082	AB2-165 E OP	2.15
925101	AB2-167 C	0.66
925102	AB2-167 E	1.09
925231	AB2-177 C	0.23
925232	AB2-177 E	0.38
925311	AB2-192 C OP	1.37
925312	AB2-192 E OP	2.23

Appendix 10

(DP&L - DP&L) The FRUITLND-PEMBERTN 69 kV line (from bus 232288 to bus 232273 ckt 1) loads from 112.26% to 116.22% (DC power flow) of its emergency rating (91 MVA) for the line fault with failed breaker contingency outage of 'DP56'. This project contributes approximately 3.6 MW to the thermal violation.

CONTINGENCY 'DP56' /*LORETTO BUS BREAKER
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232117 CKT 1 /*LORETTO
VIENNA 138 1380
DISCONNECT BRANCH FROM BUS 232127 TO BUS 232128 CKT 1 /*LORETTO
PINEY GROVE 138 138
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232905	BAYVIEW1	0.42
232926	CRISFLD1	0.64
232912	OH NUG1	1.52
232913	OH NUG2	1.5
232914	OH NUG3	1.52
232915	OH NUG4	1.52
232916	OH NUG5	1.52

232917	<i>OH NUG6</i>	1.52
232918	<i>OH NUG7</i>	1.51
232921	<i>TASLEY2G</i>	1.05
904210	<i>V4-022C</i>	0.06
904212	<i>V4-022E</i>	0.54
901003	<i>W1-003 C</i>	0.12
901004	<i>W1-003 E</i>	0.82
901013	<i>W1-004 C</i>	0.12
901014	<i>W1-004 E</i>	0.82
901023	<i>W1-005 C</i>	0.12
901024	<i>W1-005 E</i>	0.82
901033	<i>W1-006 C</i>	< 0.01
901034	<i>W1-006 E</i>	0.82
907052	<i>X1-032 E</i>	1.1
907323	<i>X1-096 C</i>	1.25
907324	<i>X1-096 E</i>	30.34
920582	<i>Z1-076 C</i>	0.67
920583	<i>Z1-076 E</i>	1.09
920592	<i>Z1-077 C</i>	0.48
920593	<i>Z1-077 E</i>	0.78
916441	<i>Z1-100</i>	0.15
916451	<i>Z1-101</i>	0.15
916461	<i>Z1-102</i>	0.15
920602	<i>Z1-103</i>	0.15
917081	<i>Z2-012 C</i>	0.26
917082	<i>Z2-012 E</i>	2.15
920952	<i>AA1-025</i>	0.13
920962	<i>AA1-026</i>	0.13
920972	<i>AA1-027</i>	0.13
920982	<i>AA1-028</i>	0.13
921122	<i>AA1-059 C</i>	1.4
921123	<i>AA1-059 E</i>	0.55
918831	<i>AA1-102</i>	2.4
921602	<i>AA1-141 C</i>	0.52
921603	<i>AA1-141 E</i>	0.85
922213	<i>AA2-129 E</i>	3.46
922222	<i>AA2-130</i>	0.65
923902	<i>AB2-030 E</i>	0.69
923931	<i>AB2-033 C</i>	1.24
923932	<i>AB2-033 E</i>	0.49
924361	<i>AB2-084 C</i>	1.04
924362	<i>AB2-084 E</i>	1.7
924681	<i>AB2-120 C OP</i>	5.66
924682	<i>AB2-120 E OP</i>	9.23
925071	<i>AB2-164 C OP</i>	1.37

<i>925072</i>	<i>AB2-164 E OP</i>	<i>2.23</i>
<i>925081</i>	<i>AB2-165 C OP</i>	<i>1.32</i>
<i>925082</i>	<i>AB2-165 E OP</i>	<i>2.15</i>
<i>925101</i>	<i>AB2-167 C</i>	<i>0.66</i>
<i>925102</i>	<i>AB2-167 E</i>	<i>1.09</i>
<i>925231</i>	<i>AB2-177 C</i>	<i>0.23</i>
<i>925232</i>	<i>AB2-177 E</i>	<i>0.38</i>
<i>925311</i>	<i>AB2-192 C OP</i>	<i>1.37</i>
<i>925312</i>	<i>AB2-192 E OP</i>	<i>2.23</i>