

***Generation Interconnection
Feasibility Study Report***

For

***PJM Generation Interconnection Request
Queue Position AC1-158***

***Spotsylvania 500kV
347.5 MW Capacity / 500 MW Energy***

Revised May / 2017

Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Virginia Electric and Power Company (VEPCO).

Preface

The intent of the Feasibility Study is to determine a plan, with high level estimated cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the IC. The IC may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the IC may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the Impact Study is performed.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The IC is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by ITO, the costs may be included in the study.

General

The IC has proposed a solar generating facility located in Spotsylvania County, VA. The installed facilities will have a total capability of 347.5 MW with 500 MW of this output being recognized by PJM as capacity. The proposed in-service date for this project is 10/01/2019.

This study does not imply an ITO commitment to this in-service date.

Point of Interconnection

AC1-158 will interconnect with the ITO transmission system at Spotsylvania 500kV.

Cost Summary

The AC1-158 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$2,200,000
Direct Connection Network Upgrades	\$0
Non Direct Connection Network Upgrades	\$3,500,000
Total Costs	\$5,700,000

In addition, the AC1-158 project may be responsible for a contribution to the following costs:

Description	Total Cost
New System Upgrades	\$0
Previously Identified Upgrades	\$123,500,000
Total Costs	\$123,500,000

Cost allocations for these upgrades will be provided in the System Impact Study Report.

Note: PJM Open Access Transmission Tariff (OATT) section 217.3A outline cost allocation rules. The rules are further clarified in PJM Manual 14A Attachment B. For New System Upgrades, the cost allocation rule differ depending on whether the minimum amount of upgrades to resolve a single reliability criteria violation will cost less than \$5,000,000. For upgrades estimated to cost less than \$5,000,000 the allocation of costs will not occur outside of the Queue in which the need for the Network Upgrade was identified. Cost allocation within the Queue will be contingent each Queue projects Distribution Factor on the overloaded facility. For upgrades estimated to cost \$5,000,000 or greater the allocation of costs will start with the first Queue project to cause the need for the upgrade. Later queue projects will receive cost allocation contingent on their contribution to the violation and are allocated to the queues that have not closed less than 5 years following the execution of the first Interconnection Service Agreement which identifies the need for this upgrade.

Attachment Facilities

Generation Substation: Install metering and associated protection equipment. Estimated Cost \$700,000.

Transmission: Build approximately 0.5 miles of 500 kV Line. Estimated Cost \$1,500,000

The estimated total cost of the Attachment Facilities is \$2,200,000. It is estimated to take 10-12 months to complete this work. These preliminary cost estimates are based on typical engineering costs. A more detailed engineering cost estimates are normally done when the IC provides an exact site plan location for the generation substation during the Facility Study phase. These costs do not include CIAC Tax Gross-up. The single line is shown below in Attachment 1.

Non-Direct Connection Cost Estimate

Substation: Add one 500 kV Breaker to convert the station from a three breaker ring bus to a four breaker ring bus. Estimated Cost \$1,500,000. It is estimated to take 14-20 months to complete this work.

Transmission: Re-arrange existing lines to accommodate new 500 kV Line. Estimated Cost \$2,000,000.

Remote Terminal Work: During the Facilities Study, ITO's System Protection Engineering Department will review transmission line protection as well as anti-islanding required to accommodate the new generation and interconnection substation. System Protection Engineering will determine the minimal acceptable protection requirements to reliably interconnect the proposed generating facility with the transmission system. The review is based on maintaining system reliability by reviewing ITO's protection requirements with the known transmission system configuration which includes generating facilities in the area. This review may determine that transmission line protection and communication upgrades are required at remote substations.

Contribution to Previously Identified System Reinforcements

Reinforcement: Brister - Chance 500kV: Wreck and rebuild the line since overload exceeds conductor rating of 2913 MVA by 3.1% to new line rating of 4300 MVA. It is estimated to cost \$73,000,000 and it is estimate to take 36-48 months to engineer, permit and construct.

Reinforcement: Ladysmith – Chancellor 500kV line #581: Wreck and rebuild the existing line since overload exceeds conductor rating of 2913 MVA by 3.1% new line rating 4300 MVA. A Virginia CPCN is required. It is estimated to cost \$50,000,000 and it is estimate to take 36-48 months to engineer, permit and construct.

Reinforcement: Ladysmith – Possum Pt 500 kV line #568: replace wave trap at both Ladysmith and Possum Point Substations. This will increase line rating by 12% to 2913 MVA. Estimated cost \$500,000 and it is estimated to 14-16 months to engineer and construct.

Interconnection Customer Requirements

ITO's Facility Connection Requirements as posted on PJM's website

<http://www.pjm.com/~media/planning/plan-standards/private-dominion/facility-connection-requirements1.ashx>

An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

Voltage Ride Through Requirements - The Customer Facility shall be designed to remain in service (not trip) for voltages and times as specified for the Eastern Interconnection in Attachment 1 of NERC Reliability Standard PRC-024-1, and successor Reliability Standards, for both high and low voltage conditions, irrespective of generator size, subject to the permissive trip exceptions established in PRC-024-1 (and successor Reliability Standards).

Frequency Ride Through Requirements - The Customer Facility shall be designed to remain in service (not trip) for frequencies and times as specified in Attachment 2 of NERC Reliability Standard PRC-024-1, and successor Reliability Standards, for both high and low frequency condition, irrespective of generator size, subject to the permissive trip exceptions established in PRC-024-1 (and successor Reliability Standards).

Reactive Power - The Generation Interconnection Customer shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading to 0.95 lagging measured at the generator's terminals.

Revenue Metering and SCADA Requirements

PJM Requirements

The IC will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

Network Impacts

The Queue Project AC1-158 was evaluated as a 500.0 MW (Capacity 347.5 MW) injection at the Spotsylvania 500kV substation in the ITO area. Project AC1-158 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AC1-158 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Contingency Descriptions

The following contingencies resulted in overloads:

Contingency Name	Description
LN 594	CONTINGENCY 'LN 594' OPEN BRANCH FROM BUS 314916 TO BUS 314934 CKT 1 /* 8MORRSVL 500.00 - 8SPOTSYL 500.00 END

Summer Peak Analysis - 2020

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

Short Circuit

(Summary of impacted circuit breakers)

New circuit breakers found to be over-duty:

None

Contributions to previously identified circuit breakers found to be over-duty:

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

#	Contingency		Affected Area	Facility Description	Bus			Power Flow	Loading %		Rating		MW Contribution	Ref
	Type	Name			From	To	Cir.		Initial	Final	Type	MVA		
1	N-1	LN 594	DVP - DVP	8CHANCE-8BRISTER 500 kV line	314905	314900	1	DC	111.02	114.53	ER	2442	88.41	1

#	Contingency		Affected Area	Facility Description	Bus			Power Flow	Loading %		Rating		MW Contribution	Ref
	Type	Name			From	To	Cir.		Initial	Final	Type	MVA		
2	N-1	LN 594	DVP - DVP	8LDYSMTH-8CHANCE 500 kV line	314911	314905	1	DC	100.21	103.03	ER	2738	78.78	2
3	N-1	LN 594	DVP - DVP	8LDYSMTH-8POSSUM 500 kV line	314911	314922	1	DC	102.75	105.79	ER	2442	74.59	3

Steady-State Voltage Requirements

(Summary of the VAR requirements based upon the results of the steady-state voltage studies)

To be determined during Impact Study

Stability and Reactive Power Requirement for Low Voltage Ride Through

(Summary of the VAR requirements based upon the results of the dynamic studies)

To be determined during Impact Study

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

None

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

Violation #	Overloaded Facility	Upgrade Description	Network Upgrade Number	Upgrade Cost
# 1	8CHANCE-8BRISTER 500 kV line	Rebuild the existing line since overload exceeds conductor rating of 2913 MVA by 3.1% new line rating 4300 MVA. (VA CPCN is required). Estimated time: 36 – 48 months.	Pending	\$73,000,000

Violation #	Overloaded Facility	Upgrade Description	Network Upgrade Number	Upgrade Cost
# 2	8LDYSMTH-8CHANCE 500 kV line	Wreck and rebuild the existing line since overload exceeds conductor rating of 2913 MVA by 3.1% new line rating 4300 MVA. (VA CPCN is required). Estimated time: 36 – 48 months.	Pending	\$50,000,000
# 3	8LDYSMTH-8POSSUM 500 kV line	Replace wave trap at both Ladysmith and Possum Point Substations. This will increase line rating by 12% to 2913 MVA. Estimated time: 14 – 16 months.	Pending	\$500,000
Total New Network Upgrades				\$123,500,000

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The IC can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

#	Contingency		Affected Area	Facility Description	Bus		Circuit	Power Flow	Loading %		Rating		MW Contribution
	Type	Name			From	To			Initial	Final	Type	MVA	
4	N-1	LN 594	DVP - DVP	8CHANCE-8BRISTER 500 kV line	314905	314900	1	DC	123.39	128.6	ER	2442	127.2
5	N-1	LN 594	DVP - DVP	8LDYSMTH-8CHANCE 500 kV line	314911	314905	1	DC	110.17	114.31	ER	2738	113.35
6	N-1	LN 594	DVP - DVP	8LDYSMTH-8POSSUM 500 kV line	314911	314922	1	DC	110.98	115.38	ER	2442	107.32
7	N-1	LN 594	DVP - DVP	8NO ANNA-8LDYSMTH 500 kV line	314918	314911	1	DC	90.61	100.69	ER	3219	324.47

Light Load Analysis

Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).

ITO Analysis

ITO assessed the impact of the proposed Queue Project #AC1-158 interconnection of a 500 MW Energy (347.5 MW Capacity) injection into the ITO's Transmission System at Spotsylvania Substation 500 kV bus, for compliance with NERC Reliability Criteria on ITO's Transmission System. The system was assessed using the summer 2020 RTEP case provided to ITO by PJM. When performing a generation analysis, ITO's main analysis will be load flow study results under single contingency (both normal and stressed system conditions). ITO Criteria considers a transmission facility overloaded if it exceeds 94% of its emergency rating under normal and stressed system conditions. A full listing of ITO's Planning Criteria and interconnection requirements can be found in the ITO's Facility Connection Requirements which are publicly available at: <http://www.dom.com>. The results of these studies evaluate the system under a limited set of operating conditions and do not guarantee the full delivery of the capacity and associated energy of this proposed generation facility under all operating conditions. NERC Planning and Operating Reliability Criteria allow for the re-dispatch of generating units to resolve projected and actual deficiencies in real time and planning studies. Specifically NERC Category C Contingency Conditions (Bus Fault, Tower Line, N-1-1, and Stuck Breaker scenarios) allow for re-dispatch of generating units to resolve potential reliability deficiencies. For ITO's Planning Criteria the re-dispatch of generating units for these contingency conditions is allowed as long as the projected loading does not exceed 100% of a facility Load Dump Rating.

As part of its generation impact analysis, the ITO routinely evaluates the impact that a proposed new generation resource will have under maximum generation conditions, stress system conditions and import/export system conditions (greater than 20 MW). The results of these studies are discussed in more detail below.

Category B Analysis (Single Contingency):

System Normal – No deficiencies identified

Critical System Condition (No Surry 230 kV Unit) – No deficiencies identified

Category C Analysis: (Multiple Facility Analysis)

Bus Fault - No deficiencies identified

Line Stuck Breaker - No deficiencies identified

Tower Line – No deficiencies identified

The import and export conditions into and out of the ITO System are evaluated with any new interconnection greater than 20 MW, any new facility that is interconnected with the ITO System should not significantly decrement FCITC between utilities. These studies will be performed during the System Impact Study.

Affected System Analysis & Mitigation

Duke, Progress & TVA Impacts:

Duke Carolina, Progress, & TVA Impacts to be determined during later study phases (as applicable).

Flowgate Appendices

Appendices

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gauge other generators impact. When a flowgate is identified in multiple analysis the appendix is presented for only the analysis with the greatest overload.

It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Appendix 1

(DVP - DVP) The 8CHANCE-8BRISTER 500 kV line (from bus 314905 to bus 314900 ckt 1) loads from 111.02% to 114.53% (**DC power flow**) of its emergency rating (2442 MVA) for the single line contingency outage of 'LN 594'. This project contributes approximately 88.41 MW to the thermal violation.

CONTINGENCY 'LN 594'

OPEN BRANCH FROM BUS 314916 TO BUS 314934 CKT 1

/* 8MORRSVL

500.00 - 8SPOTSYL 500.00

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315053	1BELMED1	3.51
315054	1BELMED2	3.51
315055	1BELMED3	2.91
315067	1DARBY 1	3.2
315068	1DARBY 2	3.2
315069	1DARBY 3	3.24
315070	1DARBY 4	3.24
315043	1FRIVERA	4.31
315044	1FRIVERB	3.33
315045	1FRIVERC	4.31
315046	1FRIVERD	3.33
315047	1FRIVERE	3.33
315048	1FRIVERF	4.31
315225	1N ANNA1	48.51
315226	1N ANNA2	47.76
315083	1SPRUNCA	2.15
315084	1SPRUNCB	2.15
315085	1SPRUNCC	1.59
315086	1SPRUNCD	1.59
315091	1YORKTN2	31.52
314309	6IRON208	0.48
314236	6NRTHEST	0.23
314251	6S PUMP	1.07
297087	V2-040	0.15
LTF	Z2-067	16.76
921092	AA1-049 C	2.52
LTF	AA1-058	0.75

921162	AA1-063AC	8.24
921172	AA1-064 C	8.21
921292	AA1-083	4.
921532	AA1-132 C	7.78
921542	AA1-133 C	10.41
921552	AA1-134 C	10.17
921562	AA1-135 C	8.81
921572	AA1-138 C	9.98
921582	AA1-139 C	15.61
921622	AA1-145	68.05
921752	AA2-053 C	8.35
921772	AA2-059 C	2.41
921862	AA2-068 C	2.08
LTF	AA2-074	4.98
921982	AA2-088 C	6.4
922512	AA2-174 C	0.38
922522	AA2-177 C	10.72
922532	AA2-178 C	9.63
922602	ABI-013 C	2.91
922672	ABI-026 C	2.11
922682	ABI-027 C	2.79
922722	ABI-053 C	1.01
922732	ABI-054 C	6.75
923262	ABI-132 C OP	13.47
923272	ABI-135 C OP	2.75
923572	ABI-173 C OP	2.17
923582	ABI-173AC OP	2.17
923801	AB2-015 C OP	8.68
923831	AB2-022 C	2.38
923841	AB2-024 C	2.64
923851	AB2-025 C	2.47
923861	AB2-026 C	2.33
923911	AB2-031 C OP	2.16
923981	AB2-039 C OP	8.76
923991	AB2-040 C OP	7.09
924061	AB2-050	4.
924071	AB2-051 C OP	143.84
924241	AB2-068 OP	215.98
924381	AB2-087 C	0.55

924501	AB2-099 C	0.57
924511	AB2-100 C	11.07
924761	AB2-128 C	9.48
924811	AB2-134 C OP	13.74
924931	AB2-147 C	2.47
924941	AB2-149 C OP	3.52
924951	AB2-150 C OP	2.47
924961	AB2-152	2.89
925051	AB2-160 C OP	5.81
925061	AB2-161 C OP	3.54
925121	AB2-169 C OP	6.27
925141	AB2-171 C OP	4.89
925171	AB2-174 C OP	6.8
925281	AB2-186 C	0.63
925291	AB2-188 C OP	2.37
925331	AB2-190 C	24.5
925361	AC1-007 C OP	0.72
925521	AC1-027 C	2.1
925691	AC1-045 C	1.81
925701	AC1-046 C	1.81
925711	AC1-047 C	2.41
925811	AC1-060	2.66
925821	AC1-061	0.04
925841	AC1-063	0.41
925861	AC1-065 C	3.57
926001	AC1-076 C	4.68
926071	AC1-086 C	19.84
926201	AC1-098 C	5.78
926211	AC1-099 C	1.94
926291	AC1-107 OP	326.
926411	AC1-112 C	2.17
926441	AC1-115 C	1.12
926471	AC1-118 C	1.99
926551	AC1-134	10.01
926591	AC1-142 C	9.92
926661	AC1-147 C	2.37
926731	AC1-158 C	88.41
926741	AC1-159 C	142.73
926751	AC1-161 C OP	31.97

<i>926771</i>	<i>ACI-163 C</i>	<i>2.06</i>
<i>926781</i>	<i>ACI-164 C OP</i>	<i>44.99</i>
<i>927041</i>	<i>ACI-191 C</i>	<i>10.79</i>
<i>927051</i>	<i>ACI-193 C</i>	<i>3.59</i>
<i>927221</i>	<i>ACI-216 C OP</i>	<i>10.49</i>

Appendix 2

(DVP - DVP) The 8LDYSMTH-8CHANCE 500 kV line (from bus 314911 to bus 314905 ckt 1) loads from 100.21% to 103.03% (**DC power flow**) of its emergency rating (2738 MVA) for the single line contingency outage of 'LN 594'. This project contributes approximately 78.78 MW to the thermal violation.

CONTINGENCY 'LN 594'

OPEN BRANCH FROM BUS 314916 TO BUS 314934 CKT 1

/* 8MORRSVL

500.00 - 8SPOTSYL 500.00

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315053	1BELMED1	3.45
315054	1BELMED2	3.45
315055	1BELMED3	2.86
315067	1DARBY 1	3.15
315068	1DARBY 2	3.15
315069	1DARBY 3	3.19
315070	1DARBY 4	3.19
315043	1FRIVERA	4.27
315044	1FRIVERB	3.3
315045	1FRIVERC	4.27
315046	1FRIVERD	3.3
315047	1FRIVERE	3.3
315048	1FRIVERF	4.27
315037	1LDYSMT1	5.56
315038	1LDYSMT2	5.55
315039	1LDYSMT3	5.88
315040	1LDYSMT4	5.89
315041	1LDYSMT5	5.91
315225	1N ANNA1	46.02
315226	1N ANNA2	45.3
315091	1YORKTN2	30.94
314309	6IRON208	0.48
314236	6NRTHEST	0.23
314251	6S PUMP	1.05
297087	V2-040	0.15
921092	AA1-049 C	2.46
LTF	AA1-058	0.73

921162	AA1-063AC	8.04
921172	AA1-064 C	7.98
921182	AA1-067 C	1.54
921292	AA1-083	3.97
921532	AA1-132 C	7.61
921542	AA1-133 C	10.18
921552	AA1-134 C	9.94
921562	AA1-135 C	8.6
921572	AA1-138 C	9.75
921582	AA1-139 C	15.27
921622	AA1-145	67.49
921752	AA2-053 C	8.14
921772	AA2-059 C	2.35
921862	AA2-068 C	2.02
LTF	AA2-074	4.84
921982	AA2-088 C	6.24
922512	AA2-174 C	0.37
922522	AA2-177 C	10.51
922532	AA2-178 C	9.41
922602	AB1-013 C	2.84
922672	AB1-026 C	2.1
922682	AB1-027 C	2.75
922722	AB1-053 C	0.99
922732	AB1-054 C	6.59
923262	AB1-132 C OP	13.14
923272	AB1-135 C OP	2.71
923572	AB1-173 C OP	2.12
923582	AB1-173AC OP	2.12
923801	AB2-015 C OP	8.48
923831	AB2-022 C	2.33
923841	AB2-024 C	2.6
923851	AB2-025 C	2.41
923861	AB2-026 C	2.25
923911	AB2-031 C OP	2.1
923981	AB2-039 C OP	8.58
923991	AB2-040 C OP	6.91
924061	AB2-050	3.97
924071	AB2-051 C OP	140.73
924241	AB2-068 OP	213.47

924381	AB2-087 C	0.54
924491	AB2-098 C	0.51
924501	AB2-099 C	0.56
924511	AB2-100 C	10.8
924761	AB2-128 C	9.25
924811	AB2-134 C OP	13.48
924931	AB2-147 C	2.41
924941	AB2-149 C OP	3.45
924951	AB2-150 C OP	2.41
924961	AB2-152	2.84
925051	AB2-160 C OP	5.69
925061	AB2-161 C OP	3.47
925121	AB2-169 C OP	6.12
925141	AB2-171 C OP	4.78
925171	AB2-174 C OP	6.63
925281	AB2-186 C	0.61
925291	AB2-188 C OP	2.32
925331	AB2-190 C	24.03
925361	AC1-007 C OP	0.7
925521	AC1-027 C	2.05
925691	AC1-045 C	1.77
925701	AC1-046 C	1.78
925711	AC1-047 C	2.36
925811	AC1-060	2.62
925821	AC1-061	0.04
925841	AC1-063	0.41
925861	AC1-065 C	3.52
926071	AC1-086 C	19.35
926201	AC1-098 C	5.64
926211	AC1-099 C	1.89
926291	AC1-107 OP	322.22
926411	AC1-112 C	2.14
926441	AC1-115 C	1.12
926471	AC1-118 C	1.98
926551	AC1-134	9.93
926591	AC1-142 C	9.8
926661	AC1-147 C	2.32
926731	AC1-158 C	78.78
926741	AC1-159 C	139.64

<i>926751</i>	<i>AC1-161 C OP</i>	<i>31.28</i>
<i>926771</i>	<i>AC1-163 C</i>	<i>2.02</i>
<i>926781</i>	<i>AC1-164 C OP</i>	<i>44.47</i>
<i>927041</i>	<i>AC1-191 C</i>	<i>10.67</i>
<i>927051</i>	<i>AC1-193 C</i>	<i>3.5</i>
<i>927141</i>	<i>AC1-208 C</i>	<i>8.11</i>
<i>927221</i>	<i>AC1-216 C OP</i>	<i>10.29</i>

Appendix 3

(DVP - DVP) The 8LDYSMTH-8POSSUM 500 kV line (from bus 314911 to bus 314922 ckt 1) loads from 102.75% to 105.79% (**DC power flow**) of its emergency rating (2442 MVA) for the single line contingency outage of 'LN 594'. This project contributes approximately 74.59 MW to the thermal violation.

CONTINGENCY 'LN 594'

OPEN BRANCH FROM BUS 314916 TO BUS 314934 CKT 1

/* 8MORRSVL

500.00 - 8SPOTSYL 500.00

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315053	1BELMED1	3.04
315054	1BELMED2	3.04
315055	1BELMED3	2.52
315060	1CHESTF5	10.76
315061	1CHESTG7	4.22
315063	1CHESTG8	4.18
315062	1CHESTS7	1.92
315064	1CHESTS8	2.14
315067	1DARBY 1	2.76
315068	1DARBY 2	2.76
315069	1DARBY 3	2.8
315070	1DARBY 4	2.8
315043	1FRIVERA	3.63
315045	1FRIVERC	3.63
315048	1FRIVERF	3.63
315225	1N ANNA1	41.53
315226	1N ANNA2	40.88
315083	1SPRUNCA	1.86
315084	1SPRUNCB	1.86
315085	1SPRUNCC	1.38
315086	1SPRUNCD	1.38
315091	1YORKTN2	27.38
314309	6IRON208	0.42
314236	6NRTHEST	0.2
314251	6S PUMP	0.92
297087	V2-040	0.13
921092	AA1-049 C	2.21

<i>LTF</i>	<i>AA1-058</i>	<i>0.69</i>
<i>921292</i>	<i>AA1-083</i>	<i>3.38</i>
<i>921532</i>	<i>AA1-132 C</i>	<i>6.81</i>
<i>921542</i>	<i>AA1-133 C</i>	<i>9.11</i>
<i>921552</i>	<i>AA1-134 C</i>	<i>8.92</i>
<i>921572</i>	<i>AA1-138 C</i>	<i>8.78</i>
<i>921582</i>	<i>AA1-139 C</i>	<i>13.66</i>
<i>921622</i>	<i>AA1-145</i>	<i>57.41</i>
<i>921772</i>	<i>AA2-059 C</i>	<i>2.12</i>
<i>LTF</i>	<i>AA2-074</i>	<i>4.71</i>
<i>921982</i>	<i>AA2-088 C</i>	<i>5.67</i>
<i>922522</i>	<i>AA2-177 C</i>	<i>9.32</i>
<i>922532</i>	<i>AA2-178 C</i>	<i>8.51</i>
<i>922602</i>	<i>AB1-013 C</i>	<i>2.57</i>
<i>922682</i>	<i>AB1-027 C</i>	<i>2.4</i>
<i>922732</i>	<i>AB1-054 C</i>	<i>5.99</i>
<i>923272</i>	<i>AB1-135 C OP</i>	<i>2.37</i>
<i>923801</i>	<i>AB2-015 C OP</i>	<i>7.66</i>
<i>923831</i>	<i>AB2-022 C</i>	<i>2.09</i>
<i>923841</i>	<i>AB2-024 C</i>	<i>2.26</i>
<i>923851</i>	<i>AB2-025 C</i>	<i>2.17</i>
<i>923861</i>	<i>AB2-026 C</i>	<i>2.1</i>
<i>923981</i>	<i>AB2-039 C OP</i>	<i>7.66</i>
<i>924061</i>	<i>AB2-050</i>	<i>3.38</i>
<i>924071</i>	<i>AB2-051 C OP</i>	<i>125.7</i>
<i>924241</i>	<i>AB2-068 OP</i>	<i>187.58</i>
<i>924511</i>	<i>AB2-100 C</i>	<i>9.84</i>
<i>924761</i>	<i>AB2-128 C</i>	<i>8.43</i>
<i>924811</i>	<i>AB2-134 C OP</i>	<i>11.95</i>
<i>924941</i>	<i>AB2-149 C OP</i>	<i>3.08</i>
<i>924961</i>	<i>AB2-152</i>	<i>2.51</i>
<i>925051</i>	<i>AB2-160 C OP</i>	<i>5.05</i>
<i>925061</i>	<i>AB2-161 C OP</i>	<i>3.1</i>
<i>925141</i>	<i>AB2-171 C OP</i>	<i>4.33</i>
<i>925281</i>	<i>AB2-186 C</i>	<i>0.55</i>
<i>925291</i>	<i>AB2-188 C OP</i>	<i>2.1</i>
<i>925331</i>	<i>AB2-190 C</i>	<i>21.3</i>
<i>925361</i>	<i>AC1-007 C OP</i>	<i>0.63</i>
<i>925521</i>	<i>AC1-027 C</i>	<i>1.84</i>

925691	ACI-045 C	1.58
925701	ACI-046 C	1.59
925711	ACI-047 C	2.11
925811	ACI-060	2.28
925821	ACI-061	0.03
925841	ACI-063	0.35
925861	ACI-065 C	3.05
926291	ACI-107 OP	283.14
926411	ACI-112 C	1.87
926441	ACI-115 C	0.92
926551	ACI-134	8.44
926661	ACI-147 C	2.07
926731	ACI-158 C	74.59
926741	ACI-159 C	124.73
926751	ACI-161 C OP	27.92
926781	ACI-164 C OP	39.07
927041	ACI-191 C	9.28
927051	ACI-193 C	3.17
927221	ACI-216 C OP	9.12