

***Generation Interconnection
Combined Feasibility/System Impact Study Report***

For

***PJM Generation Interconnection Request
Queue Position AC2-147***

Maryland

July 2017

Network Impacts

The Queue Project AC2-147 was evaluated as a 20.0 MW (Capacity 7.6 MW) injection at the Maryland 138 kV substation in the ComEd area. Project AC2-147 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AC2-147 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Analysis – 2020

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None.

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

1. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 99.99% to 100.0% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4__'. This project contributes approximately 1.56 MW to the thermal violation.

```
CONTINGENCY '112-65-BT3-4__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END
```

Please refer to Appendix 1 for a table containing the generators having contribution to this flowgate.

2. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 99.99% to 100.0% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5__'. This project contributes approximately 1.56 MW to the thermal violation.

```
CONTINGENCY '112-65-BT4-5__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END
```

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None.

Short Circuit

(Summary of impacted circuit breakers)

None.

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

1. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 99.99% to 100.0% (DC power flow) of its normal rating (971 MVA) for the single line contingency outage of '695_B2'. This project contributes approximately 1.56 MW to the thermal violation.

CONTINGENCY '695_B2'

OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1

/ 243206 05DUMONT 765 270644 WILTO; 765 1

END

Summer Peak Load Flow Analysis Reinforcements

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

Multiple Facility Contingency

1. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 99.99% to 100.0% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4__'. This project contributes approximately 1.56 MW to the thermal violation.

ComEd:

ComEd 345 kV L6615 SLD rating is 1237 MVA & the ALDR is 1423 MVA. No upgrade is required.

AEP:

A sag check will be required for the AEP owned section of the Olive – Green Acres (CE) 345 kV line to determine if the line section can be operated above its emergency rating of 971 MVA. The result could prove that no additional upgrades are necessary, that some upgrades on the circuit are necessary, or

that the entire 40.64 mile section of line would need to be rebuilt. Estimated Cost for the Sag Study: \$162,560. Estimated Cost to re-conductor/rebuild AEP section of line: \$81,280,000.

New Rating after mitigation is complete: S/N: 971 MVA S/E: 1091 MVA; Schedule: 6 to 12 months for the Sag Study

2. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 99.99% to 100.0% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT4-5__'. This project contributes approximately 1.56 MW to the thermal violation.

Same as Multiple Facility #1

Appendices

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact.

It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Appendix 1

(CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 99.99% to 100.0% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of '112-65-BT3-4__'. This project contributes approximately 1.56 MW to the thermal violation.

CONTINGENCY '112-65-BT3-4__'

TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765

TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765

TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345

TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
931011	AC2-007 C	0.57
931012	AC2-007 E	1.07
931881	AC2-115 1	1.62
931891	AC2-115 2	1.62
931921	AC2-116	0.57
932341	AC2-147 C	0.59
932342	AC2-147 E	0.96
932361	AC2-149 C	0.63
932362	AC2-149 E	1.03
932381	AC2-151 C	0.67
932382	AC2-151 E	1.09
932401	AC2-153 C	0.32
932402	AC2-153 E	0.52
932411	AC2-154 C	1.77
932412	AC2-154 E	2.9
932431	AC2-156 C OP	0.65
932432	AC2-156 E OP	1.06
932511	AC2-166 C	1.59
932512	AC2-166 E	2.59
932561	AC2-173 C OP	5.43
932562	AC2-173 E OP	2.6
274751	CRETE EC ;1U	2.1
274752	CRETE EC ;2U	2.1
274753	CRETE EC ;3U	2.1
274754	CRETE EC ;4U	2.1
274859	EASYR;U1 E	3.08
274860	EASYR;U2 E	3.08
290051	GSG-6; E	7.08
961131	J643	16.14
275149	KEMPTON ;1E	13.07
290108	LEEDK;1U E	16.5
274850	MENDOTA H;RU	4.08
275148	MILKS GRV;1E	13.07

293061	N-015 E	10.7
293644	O22 E1	7.43
293645	O22 E2	14.43
290021	O50 E	13.28
294392	P-010 E	13.59
294763	P-046 E	6.36
274830	PWR VTREC;1U	4.15
274831	PWR VTREC;2U	4.15
274722	S-055 E	7.69
884780	S-058 C	34.96
884781	S-058 E	104.88
295111	SUBLETTE E	1.84
900371	V4-046	1.61
900381	V4-047	1.61
295109	WESTBROOK E	3.79
274687	WILL CNTY;4U	47.69
910542	X3-005 E	0.53
920462	Y2-103	30.76
920472	Y3-013 1	2.56
920482	Y3-013 2	2.56
920492	Y3-013 3	2.56
LTF	Z1-043	19.25
916502	Z1-106 E1	0.86
916504	Z1-106 E2	0.86
916512	Z1-107 E	1.76
916522	Z1-108 E	1.7
LTF	Z1-112	6.32
916651	Z1-127 1	1.22
916652	Z1-127 2	0.56
920782	Z2-081	1.1
920932	AA1-018 C	1.62
920933	AA1-018 E	10.84
921012	AA1-040 1	0.87
921022	AA1-040 2	0.87
LTF	AA1-071	4.22
918972	AA1-116 E	1.87
918982	AA1-117 E	1.87
921692	AA2-035	87.49
922053	AA2-107 E	1.67
922183	AA2-123 E	1.67
923002	AB1-089 C	45.7
923012	AB1-090 C	45.7
923022	AB1-091 C OP	51.95
930751	AB1-121	79.47
930752	AB1-121 E	75.37

930761	ABI-122 1	51.06
930762	ABI-122 2	48.37
923562	ABI-172	0.55
LTF	AB2-013	10.81
924471	AB2-096	28.84
925301	AB2-191 C	0.86
925302	AB2-191 E	0.76
925891	AC1-067 C2	22.55
925901	AC1-067 C3	30.12
925911	AC1-067 C4	22.55
925881	AC1-067 C1	30.12
926311	AC1-109	1.3
926321	AC1-109 2	1.3
926331	AC1-110	1.3
926341	AC1-110 2	1.3
926351	AC1-111	0.52
926361	AC1-111 2	0.52
926371	AC1-111 3	0.52
926381	AC1-111 4	0.52
926391	AC1-111 5	0.52
926401	AC1-111 6	0.52
926421	AC1-113 1	0.81
926422	AC1-113 2	0.81
926431	AC1-114	1.62
926601	AC1-142A	2.9
926602	AC1-142A 2	2.9
926701	AC1-153 C	52.58
926711	AC1-153 C2	55.5
926702	AC1-153 E	2.1
926712	AC1-153 E2	2.22
926821	AC1-168 C OP	0.81
926822	AC1-168 E OP	5.42
926981	AC1-185 1	0.46
926982	AC1-185 2	0.46
926983	AC1-185 3	0.46
926984	AC1-185 4	0.46
926985	AC1-185 5	0.46
926986	AC1-185 6	0.46
926987	AC1-185 7	0.46
926988	AC1-185 8	0.46
927091	AC1-204	49.92
927092	AC1-204 2	49.88