Generation Interconnection Feasibility Study Report Queue Position AD2-002

General

Interconnection Customer has proposed a 20.0 MW natural gas generating facility located in Green County, Pennsylvania. PJM recognizes 20.0 MW Capacity Interconnection Rights (CIR) for this project. The proposed in-service date for this project is December 6, 2019. **This study does not imply a West Penn Power commitment to this in-service date.**

Point of Interconnection (POI)

The AD2-002 will interconnect with the West Penn Power distribution system by tapping the Franklin – Emerald 25 kV line at point located approximately 5.6 miles from Franklin substation and 7 miles from Emerald substation (circuit bus no. 236051). This POI is state jurisdictional.

Network Impacts

The Queue Project AD2-002 was evaluated as a 20.0 MW (Capacity 20.0 MW) injection at Jacob Junction 25kV substation in the APS area. Project AD2-002 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AD2-002 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Analysis - 2021

Generator Deliverability
(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency
(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

Contribution to Previously Identified Overloads
(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

Steady-State Voltage Requirements

To be determined during the system impact study phase.

Short Circuit

None

Affected System Analysis & Mitigation

NYISO Impacts:

NYISO Impacts to be determined during later study phases (as applicable).

Delivery of Energy Portion of Interconnection Request
PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.
Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

Not Applicable

Light Load Analysis - 2021

Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).

System Reinforcements

Short Circuit

None

Stability and Reactive Power Requirement

To be determined during the system impact study phase.

Summer Peak Load Flow Analysis Reinforcements

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

None

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

None

Light Load Load Flow Analysis Reinforcements

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

None

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

None