

***Generation Interconnection  
Feasibility Study Report***

***For***

***PJM Generation Interconnection Request  
Queue Position AD2-145***

***Star 345kV***

**July 2018**

## Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

The conduct of light load analysis as required under the PJM planning process is not performed during the Generation Interconnection Feasibility Study phase of the PJM study process. Additional reinforcement requirements for this Interconnection Request may be defined during the conduct of the light load analysis which shall be performed following execution of the System Impact Study agreement.

## General

The Interconnection Customer (IC), has proposed a wind generating facility located in Randolph County, Indiana. The installed facilities will have a total capability of 150 MW with 26.4 MW of this output being recognized by PJM as capacity. The proposed in-service date for this project is December 31, 2020. **This study does not imply a ATSI commitment to this in-service date.**

### Point of Interconnection

AD2-145 will interconnect with the ATSI Transmission system along one of the following points of interconnection:

- Star 345 kV Switchyard
- North Medina 345 kV Switchyard

### Cost Summary

The AD2-145 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$ 0
Direct Connection Network Upgrades	\$ 0
Non Direct Connection Network Upgrades	\$ 1,200,300
<b>Total Costs</b>	<b>\$ 1,200,300</b>

In addition, the AD2-145 project may be responsible for a contribution to the following costs:

Description	Total Cost
New System Upgrades	\$ 0
Previously Identified Upgrades	\$ 0
<b>Total Costs</b>	<b>\$ 0</b>

Cost allocations for these upgrades will be provided in the System Impact Study Report.

**General Information**

Queue Position: AD2-145

Interconnected  
Transmission Owner ("TO"): American Transmission Systems, Incorporated ("ATSI")

Affected TO(s)  
(if applicable): American Transmission Systems, Incorporated ("ATSI")

PJM Zone: ATSI

FE Operating Company or  
Planning Region: Ohio Edison

**Customer Connection Request**

Requested Backfeed Date: \_\_\_\_\_ Requested Commercial  
Operation Date: 12/31/2020  
*This study does not imply a FirstEnergy commitment to these dates.*

**New Facilities**

Capacity: 26.40 MW  
Energy: 150.00 MW  
MFO<sup>1</sup>: 150.00 MW  
Fuel: Wind

**Existing Facilities**

Capacity: \_\_\_\_\_  
Energy: \_\_\_\_\_  
MFO: \_\_\_\_\_  
Prior Queue Position(s): N/A

\_\_\_\_\_

<sup>1</sup> Maximum Facility Output

## Attachment Facilities

No Attachment Facilities are required to support this interconnection request.

## Direct Connection Cost Estimate

No Direct Connection Facilities are required to support this interconnection request.

## Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Activity Cost	Tax (if applicable)	Total Cost
Add 345 kV breaker and line relaying for AD2-145 at Star substation. <ul style="list-style-type: none"><li>Standard Pilot (2) SEL 411L Relay Panel over Fiber with DTT for the new AD2-145 generation tie 345 kV line.</li><li>SEL 501 for the new 345 kV breaker, Breaker failure to Trip (BFT)</li><li>Adjust protection setting at terminals as required</li></ul>	\$ 1,200,300	\$ 160,000	\$ 1,360,300
<b>Total Non-Direct Connection Facility Costs</b>	<b>\$ 1,200,300</b>	<b>\$ 160,000</b>	<b>\$ 1,360,300</b>

## Connection Facility Requirements

### Primary POI

The interconnection of the project at the Primary POI will be accomplished by adding one (1) new 345 kV circuit breaker at the existing Star substation to convert the Star-Juniper 345 kV line exit into a breaker and half configuration. The customer collector substation will be located approximately 180 miles from the Star substation. The IC will be responsible for acquiring all easements, properties, and permits that may be required to construct both the new interconnection point and the associated attachment facilities. The project may require non-direct connection upgrades at Juniper substation.

A summary of the connection facilities that will be required for the Primary POI and their estimated costs are shown in the following table. Based on this scope of work, it is expected to take a minimum of 14 months after the signing of an Interconnection Construction Service Agreement. This include preliminary payment that compensated FE for the first three months of

the engineering design work that is related to the construction of the AD2-145 interconnection substation. This assumes that there will be no environmental issues with any of the new properties associated with this project, that there will be no delays in acquiring the necessary permits for implementing the defined direct connection and network upgrades, and that PJM will allow all transmission system outages when requested.

## **Secondary POI**

The interconnection of the project at the Secondary POI will be accomplished by adding one (1) new 345 kV circuit breaker at North Medina substation, to convert the exiting North Medina 345 kV three (3) circuit breaker ring bus substation into a four (4) circuit breaker ring bus. The customer collecting facility will be located approximately 180 miles from North Medina substation. A full scope of work or estimated cost is not provided for the Secondary POI.

## **Interconnection Customer Requirements**

1. An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.
2. The Interconnection Customer may be required to install and/or pay for metering as necessary to properly track real time output of the facility as well as installing metering which shall be used for billing purposes. See Section 8 of Appendix 2 to the Interconnection Service Agreement as well as Section 4 of PJM Manual 14D for additional information.
3. The Interconnection Customer seeking to interconnect a wind generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per item 5.iv. of Schedule H to the Interconnection Service Agreement.
4. The purchase and installation of a fully rated 345 kV circuit breaker to protect the AD2-145 generator lead line. A single circuit breaker must be used to protect this line; if the project has several GSU transformers, the individual GSU transformer breakers cannot be used to protect this line.
5. The purchase and installation of the minimum required FE generation interconnection relaying and control facilities. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
6. The purchase and installation of supervisory control and data acquisition (“SCADA”) equipment to provide information in a compatible format to the FE Transmission System Control Center.
7. Compliance with the FE and PJM generator power factor and voltage control requirements.

8. The execution of a back-up service agreement to serve the customer load supplied from the AD2-145 generation project metering point when the units are out-of-service. This assumes the intent of the IC is to net the generation with the load.
9. The IC shall design its wind-powered non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the FE transmission system.

## **Revenue Metering, SCADA, & Protection Requirements**

### **PJM Requirements**

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

### **Metering**

The IC will be required to comply with all FE revenue metering requirements for generation interconnection customers which can be found in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>.

### **FE Requirements**

The Interconnection Customer will be required to comply with all FE Revenue Metering Requirements for Generation Interconnection Customers. The Revenue Metering Requirements may be found within the "FirstEnergy Requirements for Transmission Connected Facilities" document located at the following links:

<http://www.firstenergycorp.com/feconnect>

<http://www.pjm.com/planning/design-engineering/to-tech-standards.aspx>

### **System Protection**

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

## **Network Impacts**

### **Option 1**

The Queue Project AD2-145 was evaluated as a 150.0 MW (Capacity 26.4 MW) injection at the Star 345 kV substation in the ATSI area. Project AD2-145 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AD2-145 was studied with a commercial probability of 53%. Potential network impacts were as follows:

### **Summer Peak Analysis – 2021**

#### **Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

None.

#### **Multiple Facility Contingency**

*(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)*

None.

#### **Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

None.

#### **Short Circuit**

*(Summary of impacted circuit breakers)*

None.

#### **Steady-State Voltage Requirements**

*(Summary of the VAR requirements based upon the results of the steady-state voltage studies)*

Steady State Voltage Studies to be conducted during later study phases

## **Stability and Reactive Power Requirement for Low Voltage Ride Through**

*(Summary of the VAR requirements based upon the results of the dynamic studies)*

Stability Studies to be conducted during later study phases

## **Affected System Analysis & Mitigation**

### **MISO Impacts:**

MISO Impacts to be determined during later study phases (as applicable)

## **Winter Analysis - 2021**

Winter Studies to be conducted during later study phases

## **Light Load Analysis - 2021**

Light Load Studies to be conducted during later study phases

## **Potential Congestion due to Local Energy Deliverability**

*PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.*

None.

## **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None.

## **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

None.

## **Network Impacts**

### **Option 2**

The Queue Project AD2-145 was evaluated as a 150.0 MW (Capacity 26.4 MW) injection at the North Medina 345kV substation in the ATSI area. Project AD2-145 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AD2-145 was studied with a commercial probability of 53%. Potential network impacts were as follows:

### **Summer Peak Analysis - 2021**

#### **Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

None.

#### **Multiple Facility Contingency**

*(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)*

None.

#### **Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

None.

#### **Short Circuit**

*(Summary of impacted circuit breakers)*

None.

#### **Steady-State Voltage Requirements**

*(Summary of the VAR requirements based upon the results of the steady-state voltage studies)*

Steady State Voltage Studies to be conducted during later study phases

## **Stability and Reactive Power Requirement for Low Voltage Ride Through**

*(Summary of the VAR requirements based upon the results of the dynamic studies)*

Stability Studies to be conducted during later study phases

## **Affected System Analysis & Mitigation**

### **MISO Impacts:**

MISO Impacts to be determined during later study phases (as applicable)

## **Winter Analysis - 2021**

Winter Studies to be conducted during later study phases

## **Light Load Analysis - 2021**

Light Load Studies to be conducted during later study phases

## **Potential Congestion due to Local Energy Deliverability**

*PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.*

None.

## **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None.

## **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

None.