

***Revised
Generation Interconnection
Feasibility Study Report***

For

***PJM Generation Interconnection Request
Queue Position AD2-195***

***Trowbridge-Pantego 115 kV
55.9 MW Capacity / 80 MW Energy***

August / 2018

Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Virginia Electric and Power Company (VEPCO).

Preface

The intent of the Feasibility Study is to determine a plan, with high level estimated cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the IC. The IC may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the IC may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the Impact Study is performed.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The IC is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by ITO, the costs may be included in the study.

Revision from July 2018

The study report has been updated to reflect more accurate information regarding the Dominion Energy and Duke/Progress tie line reinforcement requirements and how an Affected System Study will be required with Duke/Progress to determine upgrades required on facilities outside of PJM.

General

The IC has proposed a solar generating facility located in Washington County, North Carolina. The installed facilities will have a total capability of **80 MW** with **55.9 MW** of this output being recognized by PJM as capacity. The proposed in-service date for this project is **6/1/2021**. **This study does not imply an ITO commitment to this in-service date.**

Point of Interconnection

AD2-195 will interconnect with the ITO transmission system via a tap off of the Trowbridge-Pantego 115 line. No secondary POI was chosen.

Cost Summary

The AD2-195 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$ 1,550,000
Direct Connection Network Upgrades	\$ 6,300,000
Non Direct Connection Network Upgrades	\$ 0
Total Costs	\$ 7,850,000

In addition, the AD2-195 project may be responsible for a contribution to the following costs:

Description	Total Cost
New System Upgrades	\$ 124,950,000
Previously Identified Upgrades	\$ 206,735,000
Total Costs	\$ 331,685,000

Cost allocations for these upgrades will be provided in the System Impact Study Report.

Note: PJM Open Access Transmission Tariff (OATT) section 217.3A outline cost allocation rules. The rules are further clarified in PJM Manual 14A Attachment B. The allocation of costs for a network upgrade will start with the first Queue project to cause the need for the upgrade. Later queue projects will receive cost allocation contingent on their contribution to the violation and are allocated to the queues that have not closed less than 5 years following the execution of the first Interconnection Service Agreement which identifies the need for this upgrade.

The Feasibility Study is used to make a preliminary determination of the type and scope of Attachment Facilities, Local Upgrades, and Network Upgrades that will be necessary to accommodate the Interconnection Request and to provide the Interconnection Customer a preliminary estimate of the time that will be required to construct any necessary facilities and upgrades and the Interconnection Customer's cost responsibility. The System Impact Study provides refined and comprehensive estimates of cost responsibility and construction lead times for new facilities and system upgrades. Facilities Studies will include, commensurate with the degree of engineering specificity as provided in the Facilities Study Agreement, good faith estimates of the cost, determined in accordance with Section 217 of the Tariff,

- (a) to be charged to each affected New Service Customer for the Facilities and System Upgrades that are necessary to accommodate this queue project;
- (b) the time required to complete detailed design and construction of the facilities and upgrades; and
- (c) a description of any site-specific environmental issues or requirements that could reasonably be anticipated to affect the cost or time required to complete construction of such facilities and upgrades.

Transmission Owner Scope of Work

Attachment Facilities

Generation Substation: Install metering and associated protection equipment. Estimated Cost \$550,000.

Transmission: Construct approximately one span of 115 kV Attachment line between the generation substation and a new AD2-195 Switching Station. The estimated cost for this work is \$1,000,000.

The estimated total cost of the Attachment Facilities is \$1,550,000. It is estimated to take 18-24 months to complete this work upon execution of an Interconnection Construction Service Agreement (ICSA). These preliminary cost estimates are based on typical engineering costs. A more detailed engineering cost estimates are normally done when the IC provides an exact site plan location for the generation substation during the Facility Study phase. See Attachment One.

Direct Connection Cost Estimate

Substation: Establish the new 115 kV AD2-195 Switching Substation (interconnection substation). The arrangement in the substation will be as shown below on Dominion Attachment One: One-Line Diagram. The estimated cost of this work scope is \$5,500,000.

Transmission: Install transmission structure in-line with transmission line to allow the proposed interconnection switching station to be interconnected with the transmission system. Estimated cost is \$800,000 dollars and is estimated to take 24-30 months to complete. See Attachment One.

The total estimated cost to complete the Direct Connection Network Facilities is \$6,300,000. It is estimated to take 24-36 months to complete this work upon execution of an Interconnection Construction Service Agreement.

Non-Direct Network Upgrades:

Remote Terminal Work: During the Facilities Study, ITO's System Protection Engineering Department will review transmission line protection as well as anti-islanding required to accommodate the new generation and interconnection substation. System Protection Engineering will determine the minimal acceptable protection requirements to reliably interconnect the proposed generating facility with the transmission system. The review is based on maintaining system reliability by reviewing ITO's protection requirements with the known transmission system configuration which includes generating facilities in the area. This review may determine that transmission line protection and communication upgrades are required at remote substations.

System Reinforcement

Violation #	Upgrade Description	Upgrade Cost
# 1,2	DVP: Line #246 Earleys – Nucor TP – Suffolk 230 kV: wreck and rebuild the line of 45 miles to increase its line rating to 722 MVA (normal), 722 MVA (emergency), and 830 MVA (load dump). It is estimated to take 44-48 months to engineer, permit, and construct. A Va CPCN is required.	\$110,950,000
# 3	DVP: Line #189 Pantego – AB2-169 TAP 115 kV: wreck and rebuild the line of 7 miles to increase its line rating to 262 MVA (normal), 287 MVA (emergency), and 349 MVA (load dump). It is estimated to take 30-36 months to engineer, permit, and construct. A Va CPCN is required.	\$14,000,000
6	DVP: Elmont 500 – 230 kV Tx#1: replace the 500-230 kV transformer #1 increase its line rating to 1134 MVA (normal), 1203 MVA (emergency), and 1365 MVA (load dump). It is estimated to take 24-30 months to engineer and construct.	\$17,500,000
7,8,9	DVP: Line #238 Clubhouse to Sapony 230 kV: replace wave trap at Clubhouse Substation to increase its line rating to 722 MVA (normal), 722 MVA (emergency), and 830 MVA (load dump). It is estimated to take 12-16 months to engineer and construct.	\$150,000
12	DVP: Line #218 Everetts-AD2-068 Tap 230 kV: wreck and rebuild the line of 18 miles to increase its line rating to 722 MVA (normal), 722 MVA (emergency), and 830 MVA (load dump). It is estimated to take 44-48 months to engineer, permit, and construct. A Va CPCN is required. A certificate from the NC PUC will most likely be required.	\$45,000,000
13	DVP: Line #189 AB2-169 Tap – Five Points DP – Wharton 115 kV: wreck and rebuild the line of 24 miles to increase its line rating to 262 MVA (normal), 287 MVA (emergency), and 349 MVA (load dump). It is estimated to take 30-36 months to engineer, permit, and construct. A Va CPCN is required.	\$47,310,000
14, 15, 16	DVP: Line #254 AB2-100 Tap – Lakeview 230 kV: wreck and rebuild the line of 16 miles to increase its line rating to 722 MVA (normal), 722 MVA (emergency), and 830 MVA (load dump). It is estimated to take 44-48 months to engineer, permit, and construct. A Va CPCN is required. A certificate from the NC PUC will most likely be required.	\$40,000,000
17	DVP: Line #25 Pop Chap – Everetts 115 kV: replace relay in Everetts to increase its line rating to 263 MVA (normal), 287 MVA (emergency), and 349 MVA (load dump). It is estimated to take 14-16 months to engineer, permit and construct.	\$200,000

Violation #	Upgrade Description	Upgrade Cost
18, 19	DVP: Line #2021 Elizabeth City – Shawboro 230 kV: wreck and rebuild the line of 8 miles to increase its line rating to 1047 MVA (normal), 1047 MVA (emergency), and 1204 MVA (load dump). It is estimated to take 30-36 months to engineer, permit, and construct. A Va CPCN is required.	\$25,700,000
20, 21	DVP: Line #2131 Z1-036 – Tap S Hertford – Winfall 230 kV: wreck and rebuild the line of 8 miles to increase its line rating to 1047 MVA (normal), 1047 MVA (emergency), and 1204 MVA (load dump). It is estimated to take 30-36 months to engineer, permit, and construct. A Va CPCN is required.	\$19,875,000
24,25,26	DVP: Line #254 AB2-100 Tap – Clubhouse 230 kV: wreck and rebuild the AB2-100 TAP-Clubhouse 230kV line of 2 miles to increase its line rating to 722 MVA (normal), 722 MVA (emergency), and 830 MVA (load dump). It is estimated to take 24-28 months to engineer, permit and construct. A Va CPCN is required.	\$5,000,000
28,29	DVP/CPLE: The AD2-068 TAP-6GREENVILLE T 230 kV line is a joint tie line between the Dominion Energy and Duke/Progress transmission systems. The VEPCO portion can be resolved by wrecking and rebuilding the line of 3 miles to increase its line rating to 722 MVA (normal), 722 MVA (emergency), and 830 MVA (load dump). It is estimated to take 44-48 months to engineer, permit, and construct. A Va CPCN is required. A certificate from the NC PUC will most likely be required. An affected systems study will need to be completed with Duke/Progress to determine upgrades required on the Duke/Progress system.	\$6,000,000
	Total System Reinforcements	\$331,685,000

Interconnection Customer Requirements

ITO's Facility Connection Requirements as posted on PJM's website

<http://www.pjm.com/~media/planning/plan-standards/private-dominion/facility-connection-requirements1.ashx>

Revenue Metering and SCADA Requirements

PJM Requirements

The IC will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

Meteorological Data Reporting Requirement

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Temperature (degrees Fahrenheit)
- Atmospheric pressure (hectopascals)
- Irradiance
- Forced outage data

Network Impacts

The Queue Project AD2-195 was evaluated as a 80.0 MW (Capacity 55.9 MW) injection tapping the Trowbridge to Pantego 115kV line in the VAP area. Project AD2-195 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AD2-195 was studied with a commercial probability of 53%. Potential network impacts were as follows:

PJM assessed the impact of the proposed Queue Project as an injection into the ITO, for compliance with NERC Reliability Criteria. The system was assessed using the summer 2021 RTEP case. When performing analysis, ITO Criteria considers a transmission facility overloaded if it exceeds 94% of its emergency rating under single contingency (normal and stressed system conditions). A full listing of the ITO's Planning Criteria and interconnection requirements can be found in the ITO's Facility Connection Requirements which are publicly available at: <http://www.dom.com>.

The results of these studies evaluate the system under a limited set of operating conditions and do not guarantee the full delivery of the capacity and associated energy of this proposed generation facility under all operating conditions. NERC Planning and Operating Reliability Criteria allow for the re-dispatch of generating units to resolve projected and actual deficiencies in real time and planning studies. Specifically NERC Category C Contingency Conditions (Bus Fault, Tower Line, N-1-1, and Stuck Breaker scenarios) allow for re-dispatch of generating units to resolve potential reliability deficiencies. For ITO Planning Criteria the re-dispatch of generating units for these contingency conditions is allowed as long as the projected loading does not exceed 100% of a facility Load Dump Rating. The results of these studies are discussed in more detail below.

Contingency Descriptions

The following contingencies resulted in overloads:

Contingency Name	Description
"313845	No Data
"314620	No Data
AEP_P1-2_#1377	CONTINGENCY 'AEP_P1-2_#1377' OPEN BRANCH FROM BUS 242514 TO BUS 242520 CKT 1 / 242514 05J.FERR 765 242520 05J.FERR 500 1 OPEN BRANCH FROM BUS 242520 TO BUS 306719 CKT 1 / 242520 05J.FERR 500 306719 8ANTIOCH 500 1 END
DVP_P1-2: LN 1020_B	CONTINGENCY 'DVP_P1-2: LN 1020_B' /*ADDED ON 4/19/2016 OPEN BRANCH FROM BUS 937440 TO BUS 314613 CKT 1 /* AD2-195 TAP 115.00 - 3TRWBRDG 115.00 END
DVP_P1-2: LN 130-A	CONTINGENCY 'DVP_P1-2: LN 130-A' OPEN BRANCH FROM BUS 314562 TO BUS 314570 CKT 1 /* 3CLUBHSE 115.00 - 3METCATP 115.00 OPEN BRANCH FROM BUS 314570 TO BUS 314572 CKT 1 /* 3METCATP 115.00 - 3EMPORIA 115.00 OPEN BRANCH FROM BUS 314570 TO BUS 314588 CKT 1 /* 3METCATP 115.00 - 3METCALF 115.00 OPEN BRANCH FROM BUS 314572 TO BUS 925170 CKT 1 /* 3EMPORIA 115.00 - AB2-174 TAP 115.00 OPEN BRANCH FROM BUS 314572 TO BUS 314863 CKT 1 /* 3EMPORIA 115.00 - 3EMPOR_1 115.00 OPEN BUS 314570 /* ISLAND OPEN BUS 314572 /* ISLAND OPEN BUS 314588 /* ISLAND END

DVP_P1-2: LN 2020	<p>CONTINGENCY 'DVP_P1-2: LN 2020'</p> <p>OPEN BRANCH FROM BUS 313851 TO BUS 314638 CKT 1 /* 6ECITYDP2 230.00 - 6ELIZ CT 230.00</p> <p>OPEN BRANCH FROM BUS 313851 TO BUS 314639 CKT 1 /* 6ECITYDP2 230.00 - 6TANGLEW 230.00</p> <p>OPEN BRANCH FROM BUS 314639 TO BUS 314651 CKT 1 /* 6TANGLEW 230.00 - 6WINFALL 230.00</p> <p>OPEN BUS 313851 /* ISLAND</p> <p>OPEN BUS 314639 /* ISLAND</p> <p>OPEN BUS 913391 /* ISLAND</p> <p>OPEN BUS 913392 /* ISLAND</p> <p>END</p>
DVP_P1-2: LN 2058	<p>CONTINGENCY 'DVP_P1-2: LN 2058'</p> <p>OPEN BRANCH FROM BUS 304222 TO BUS 313845 CKT 1 /* 6ROCKYMT230T230.00 - 6MORNSTR 230.00</p> <p>END</p>
DVP_P1-2: LN 2131_FSA	<p>CONTINGENCY 'DVP_P1-2: LN 2131_FSA'</p> <p>OPEN BRANCH FROM BUS 314203 TO BUS 314637 CKT 1 /* 6MACKEYS 230.00 - 6EDENTON 230.00</p> <p>OPEN BRANCH FROM BUS 314637 TO BUS 916040 CKT 1 /* 6EDENTON 230.00 - Z1-036 TAP 230.00</p> <p>OPEN BRANCH FROM BUS 314662 TO BUS 916040 CKT 1 /* ADDED BY JT FOR FULL FSA TAP REMOVAL</p> <p>OPEN BUS 314637 /* ISLAND</p> <p>END</p>
DVP_P1-2: LN 2131A	<p>CONTINGENCY 'DVP_P1-2: LN 2131A'</p> <p>OPEN BRANCH FROM BUS 314662 TO BUS 916040 CKT 1 /* 6S HERTFORD 230.00 - Z1-036 TAP 230.00</p> <p>OPEN BRANCH FROM BUS 314651 TO BUS 314662 CKT 1 /* 6WINFALL 230.00 - 6S HERTFORD 230.00</p> <p>OPEN BUS 314662 /* ISLAND</p>

	END
DVP_P1-2: LN 2181	CONTINGENCY 'DVP_P1-2: LN 2181' OPEN BUS 304226 /* ISLAND: 6PA-RMOUNT#4115.00 OPEN BRANCH FROM BUS 304226 TO BUS 314591 CKT 1 /* 6PA-RMOUNT#4230.00 - 6NASH 230.00 OPEN BRANCH FROM BUS 313845 TO BUS 314591 CKT 1 /* 6HATHAWAY 230.00 - 6NASH 230.00 OPEN BUS 314591 /* ISLAND: 6NASH 230.00 END
DVP_P1-2: LN 246	CONTINGENCY 'DVP_P1-2: LN 246' OPEN BRANCH FROM BUS 314537 TO BUS 314575 CKT 1 /* 6SUFFOLK 230.00 - 6NUCO TP 230.00 OPEN BRANCH FROM BUS 314569 TO BUS 314575 CKT 1 /* 6EARLEYS 230.00 - 6NUCO TP 230.00 OPEN BRANCH FROM BUS 314575 TO BUS 314590 CKT 1 /* 6NUCO TP 230.00 - 6NUCOR 230.00 OPEN BUS 314575 /* ISLAND OPEN BUS 314590 /* ISLAND END
DVP_P1-2: LN 247	CONTINGENCY 'DVP_P1-2: LN 247' OPEN BRANCH FROM BUS 314537 TO BUS 314648 CKT 1 /* 6SUFFOLK 230.00 - 6SUNBURY 230.00 OPEN BRANCH FROM BUS 314648 TO BUS 901080 CKT 1 /* 6SUNBURY 230.00 - W1-029 230.00 OPEN BUS 314648 /* ISLAND END

DVP_P1-2: LN 563	CONTINGENCY 'DVP_P1-2: LN 563' OPEN BRANCH FROM BUS 314902 TO BUS 314914 CKT 1 /* 8CARSON 500.00 - 8MDLTHAN 500.00 END
DVP_P4-2: 2014T2034	CONTINGENCY 'DVP_P4-2: 2014T2034' /* EARLEYS OPEN BRANCH FROM BUS 314569 TO BUS 314620 CKT 1 /* 2034 OPEN BRANCH FROM BUS 314620 TO BUS 933990 CKT 1 /* 2034 OPEN BRANCH FROM BUS 314569 TO BUS 314574 CKT 1 /* 2014 END
DVP_P4-2: 2020T2144	CONTINGENCY 'DVP_P4-2: 2020T2144' /* WINFALL 230 KV OPEN BRANCH FROM BUS 313851 TO BUS 314638 CKT 1 /* 6ECITYDP2 230.00 - 6ELIZ CT 230.00 OPEN BRANCH FROM BUS 313851 TO BUS 314639 CKT 1 /* 6ECITYDP2 230.00 - 6TANGLEW 230.00 OPEN BRANCH FROM BUS 314639 TO BUS 314651 CKT 1 /* 6TANGLEW 230.00 - 6WINFALL 230.00 OPEN BUS 313851 /* ISLAND: 6ECITYDP2 230.00 OPEN BUS 314639 /* ISLAND: 6TANGLEW 230.00 OPEN BUS 913391 /* ISLAND: Y1-086 C 230.00 OPEN BUS 913392 /* ISLAND: Y1-086 E 230.00 OPEN BUS 917121 /* ISLAND: Z2-027 C 230.00 OPEN BUS 917122 /* ISLAND: Z2-027 E 230.00 OPEN BRANCH FROM BUS 314651 TO BUS 901080 CKT 1 /* 6WINFALL 230.00 - W1-029 230.00 END

DVP_P4-2: 24662	CONTINGENCY 'DVP_P4-2: 24662' /* EARLEYS OPEN BRANCH FROM BUS 314568 TO BUS 314569 CKT 1 /* TX. #3 OPEN BRANCH FROM BUS 314569 TO BUS 314575 CKT 1 /* 246 OPEN BRANCH FROM BUS 314575 TO BUS 314537 CKT 1 /* 246 OPEN BRANCH FROM BUS 314575 TO BUS 314590 CKT 1 /* 246 - NUCOR END
DVP_P4-2: 24682	CONTINGENCY 'DVP_P4-2: 24682' /* 24682 @ SUFFOLK OPEN BRANCH FROM BUS 314537 TO BUS 314575 CKT 1 /* SUFFOLK - NUCOR TAP OPEN BRANCH FROM BUS 314569 TO BUS 314575 CKT 1 /* NUCOR TAP - EARLEYS OPEN BRANCH FROM BUS 314536 TO BUS 314537 CKT 2 /* SUFFOLK 230-115 TX#5 OPEN BRANCH FROM BUS 314928 TO BUS 314537 CKT 2 /* SUFFOLK 500-230 TX#8 END
DVP_P4-2: 246T247	CONTINGENCY 'DVP_P4-2: 246T247' /* SUFFOLK 230 KV OPEN BRANCH FROM BUS 314537 TO BUS 314575 CKT 1 /* 6SUFFOLK 230.00 - 6NUCO TP 230.00 OPEN BRANCH FROM BUS 314569 TO BUS 314575 CKT 1 /* 6EARLEYS 230.00 - 6NUCO TP 230.00 OPEN BRANCH FROM BUS 314575 TO BUS 314590 CKT 1 /* 6NUCO TP 230.00 - 6NUCOR 230.00 OPEN BUS 314575 /* ISLAND: 6NUCO TP 230.00 OPEN BUS 314590 /* ISLAND: 6NUCOR 230.00 OPEN BRANCH FROM BUS 314537 TO BUS 314648 CKT 1 /* 6SUFFOLK 230.00 - 6SUNBURY 230.00 OPEN BRANCH FROM BUS 314648 TO BUS 901080 CKT 1 /* 6SUNBURY 230.00 - W1-029 230.00 OPEN BUS 314648 /* ISLAND: 6SUNBURY 230.00

	END
DVP_P4-2: 24742	CONTINGENCY 'DVP_P4-2: 24742' /* SUFFOLK 230 KV OPEN BRANCH FROM BUS 314537 TO BUS 314648 CKT 1 /* 6SUFFOLK 230.00 - 6SUNBURY 230.00 OPEN BRANCH FROM BUS 314648 TO BUS 901080 CKT 1 /* 6SUNBURY 230.00 - W1-029 230.00 OPEN BUS 314648 /* ISLAND: 6SUNBURY 230.00 OPEN BRANCH FROM BUS 314536 TO BUS 314537 CKT 1 /* 3SUFFOLK 115.00 - 6SUFFOLK 230.00 OPEN BRANCH FROM BUS 314537 TO BUS 314928 CKT 1 /* 6SUFFOLK 230.00 - 8SUFFOLK 500.00 REMOVE SWSHUNT FROM BUS 314537 END
DVP_P4-2: H2T557	CONTINGENCY 'DVP_P4-2: H2T557' /* ELMONT OPEN BRANCH FROM BUS 314908 TO BUS 314903 CKT 1 /*ELMONT TO CHICKAHOMINY (LINE 557) OPEN BRANCH FROM BUS 314903 TO BUS 314214 CKT 1 /*CHICKAHOMINY 500-230 (TX#1) OPEN BRANCH FROM BUS 314908 TO BUS 314218 CKT 2 /*ELMONT 500-230 (TX#2) END

DVP_P7-1: LN 2058-2181	CONTINGENCY 'DVP_P7-1: LN 2058-2181' OPEN BRANCH FROM BUS 304222 TO BUS 313845 CKT 1 /* 6ROCKYMT230T230.00 - 6HATHAWAY 230.00 OPEN BUS 304226 /* ISLAND: 6PA-RMOUNT#4115.00 OPEN BRANCH FROM BUS 304226 TO BUS 314591 CKT 1 /* 6PA-RMOUNT#4230.00 - 6NASH 230.00 OPEN BRANCH FROM BUS 313845 TO BUS 314591 CKT 1 /* 6HATHAWAY 230.00 - 6NASH 230.00 OPEN BUS 314591 /* ISLAND: 6NASH 230.00 END
DVP_P7-1: LN 25-2034_A	CONTINGENCY 'DVP_P7-1: LN 25-2034_A' /*REPLACED ON 4/19/2016 OPEN BRANCH FROM BUS 314573 TO BUS 314596 CKT 1 /* 3EVERETS 115.00 - 3POPLR C 115.00 OPEN BRANCH FROM BUS 314596 TO BUS 314614 CKT 1 /* 3POPLR C 115.00 - 3TROWBR2 115.00 OPEN BUS 314596 /* ISLAND OPEN BRANCH FROM BUS 314569 TO BUS 314620 CKT 1 /* 6EARLEYS 230.00 - 6CASHIE 230.00 OPEN BRANCH FROM BUS 314614 TO BUS 314616 CKT 1 /* 3TROWBR2 115.00 - 6TRWBRDG 230.00 OPEN BRANCH FROM BUS 314616 TO BUS 933990 CKT 1 /* 6TRWBRDG 230.00 - AD1-023 TAP 230.00 END

Summer Peak Analysis - 2021

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

Overload Number	Type	Contingency Name	Affected Area	Facility Description	Bus			Power Flow	Loading %		Rating		MW Contribution	Flowgate Appendix
					From	To	Circuit		Initial	Final	Type	MVA		
1	N-1	DVP_P1-2: LN 2131A	DVP - DVP	6NUCO TP-6SUFFOLK 230 kV line	314575	314537	1	DC	97.19	100.34	ER	572	17.93	1
2	N-1	DVP_P1-2: LN 2131_FSA	DVP - DVP	6NUCO TP-6SUFFOLK 230 kV line	314575	314537	1	DC	96.91	100.05	ER	572	17.93	

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

Overload Number	Type	Contingency Name	Affected Area	Facility Description	Bus			Power Flow	Loading %		Rating		MW Contribution	Flowgate Appendix
					From	To	Circuit		Initial	Final	Type	MVA		
3	DCTL	DVP_P7-1: LN 25-2034_A	DVP - DVP	3PANTEGO-AB2-169 TAP 115 kV line	314592	925120	1	DC	97.89	126.17		91	25.73	2

Short Circuit

(Summary of impacted circuit breakers)

New circuit breakers found to be over-duty:

None

Contributions to previously identified circuit breakers found to be over-duty:

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

Overload Number	Contingency Type	Contingency Name	Affected Area	Facility Description	Bus		Circuit	Power Flow	Loading %		Rating		MW Contribution	Flowgate Appendix
					From	To			Initial	Final	Type	MVA		
4	N-1	"313845	DVP - CPLE	6MORNSTR-6ROCKYMT230T 230 kV line	313845	304222	1	DC	112.44	113.91	ER	374	5.5	3
5	N-1	DVP_P1-2: LN 2181	DVP - CPLE	6MORNSTR-6ROCKYMT230T 230 kV line	313845	304222	1	DC	108.65	110.12	ER	374	5.5	
6	LFFB	DVP_P4-2: H2T557	DVP - DVP	8ELMONT 500/230 kV transformer	314218	314908	1	DC	153.05	153.44		1051	11.13	4
7	LFFB	DVP_P4-2: 246T247	DVP - DVP	6CLUBHSE-6SAPONY 230 kV line	314563	314435	1	DC	135.21	136.09		637	12.35	5
8	LFFB	DVP_P4-2: 24662	DVP - DVP	6CLUBHSE-6SAPONY 230 kV line	314563	314435	1	DC	128.44	129.24		637	11.18	
9	LFFB	DVP_P4-2: 24682	DVP - DVP	6CLUBHSE-6SAPONY 230 kV line	314563	314435	1	DC	128.37	129.17		637	11.28	
10	N-1	DVP_P1-2: LN 2131A	DVP - DVP	6EARLEYS-6NUCO TP 230 kV line	314569	314575	1	DC	103.21	106.36	ER	572	17.93	6
11	N-1	DVP_P1-2: LN 2131_FSA	DVP - DVP	6EARLEYS-6NUCO TP 230 kV line	314569	314575	1	DC	102.95	106.09	ER	572	17.93	
12	DCT L	DVP_P7-1: LN 2058-2181	DVP - DVP	6EVERETS-AD2-068 TAP 230 kV line	314574	936530	1	DC	134.57	138.36		485	18.41	7
13	DCT L	DVP_P7-1: LN 25-2034_A	DVP - DVP	3FIVE PT-3WHARTON 115 kV line	314576	314622	1	DC	126.19	154.47		91	25.73	8
14	LFFB	DVP_P4-2: 246T247	DVP - DVP	6LAKEVEW-AB2-100 TAP 230 kV line	314583	924510	1	DC	130.43	132.98		459	11.81	9
15	N-1	DVP_P1-2: LN 246	DVP - DVP	6LAKEVEW-AB2-100 TAP 230 kV line	314583	924510	1	DC	109.45	111.46	ER	375	7.5	
16	N-1	DVP_P1-2: LN 2131A	DVP - DVP	6LAKEVEW-AB2-100 TAP 230 kV line	314583	924510	1	DC	104.95	107.11	ER	375	8.08	
17	LFFB	DVP_P4-2: 2014T2034	DVP - DVP	3POPLR C-3EVERETS 115 kV line	314596	314573	1	DC	118.16	126.67		239	20.34	10
18	LFFB	DVP_P4-2: 246T247	DVP - DVP	6ELIZ CT-6SHAWBRO 230 kV line	314638	314647	1	DC	135.38	139.05		699	25.62	11
19	LFFB	DVP_P4-2: 24742	DVP - DVP	6ELIZ CT-6SHAWBRO 230 kV line	314638	314647	1	DC	105.7	108.8		699	21.56	

					8	7			1					
20	DCT L	DVP_P7-1: LN 25- 2034_A	DVP - DVP	6S HERTFORD-6WINFALL 230 kV line	31466 2	31465 1	1	DC	105.3 3	111.3 7		897	54.18	12
21	LFFB	DVP_P4-2: 24682	DVP - DVP	6S HERTFORD-6WINFALL 230 kV line	31466 2	31465 1	1	DC	107.9 8	111.2 8		897	29.62	
22	LFFB	DVP_P4-2: 24682	DVP - DVP	Z1-036 TAP-6S HERTFORD 230 kV line	91604 0	31466 2	1	DC	109.3 2	112.6 3		897	29.62	13
23	DCT L	DVP_P7-1: LN 25- 2034_A	DVP - DVP	Z1-036 TAP-6S HERTFORD 230 kV line	91604 0	31466 2	1	DC	106.5 5	112.5 9		897	54.18	
24	LFFB	DVP_P4-2: 246T247	DVP - DVP	AB2-100 TAP-6CLUBHSE 230 kV line	92451 0	31456 3	1	DC	144.2	146.7 9		459	11.81	14
25	N-1	DVP_P1-2: LN 246	DVP - DVP	AB2-100 TAP-6CLUBHSE 230 kV line	92451 0	31456 3	1	DC	120.7 9	122.8	ER	375	7.5	
26	N-1	DVP_P1-2: LN 130-A	DVP - DVP	AB2-100 TAP-6CLUBHSE 230 kV line	92451 0	31456 3	1	DC	115.7 7	117.3 6	ER	375	5.94	
27	DCT L	DVP_P7-1: LN 25- 2034_A	DVP - DVP	AB2-169 TAP-3FIVE PT 115 kV line	92512 0	31457 6	1	DC	137.5 1	165.7 9		91	25.73	15
28	DCT L	DVP_P7-1: LN 2058- 2181	DVP - CPLE	AD2-068 TAP-6GREENVILE T 230 kV line	93653 0	30445 1	1	DC	141.9 1	145.7 6	ER	478	18.41	16
29	LFFB	DVP_P4-2: 2020T2144	DVP - CPLE	AD2-068 TAP-6GREENVILE T 230 kV line	93653 0	30445 1	1	DC	119.1 5	122.2 8	ER	478	20.73	

Steady-State Voltage Requirements

(Summary of the VAR requirements based upon the results of the steady-state voltage studies)

To be determined during Impact Study

Stability and Reactive Power Requirement for Low Voltage Ride Through

(Summary of the VAR requirements based upon the results of the dynamic studies)

To be determined during Impact Study

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

Violation #	Overloaded Facility	Upgrade Description	Network Upgrade Number	Upgrade Cost
1, 2	6NUCO TP-6SUFFOLK 230 kV line	DVP: Line #246 Earleys – Nucor TP – Suffolk 230 kV: wreck and rebuild the line of 45 miles to increase its line rating to 722 MVA (normal), 722 MVA (emergency), and 830 MVA (load dump). It is estimated to take 44-48 months to engineer, permit, and construct. A Va CPCN is required.	Pending	\$110,950,000
3	3PANTEGO-AB2-169 TAP 115 kV line	DVP: Line #189 Pantego – AB2-169 TAP 115 kV: wreck and rebuild the line of 7 miles to increase its line rating to 262 MVA (normal), 287 MVA (emergency), and 349 MVA (load dump). It is estimated to take 30-36 months to engineer, permit, and construct. A Va CPCN is required.	Pending	\$14,000,000
Total New Network Upgrades				\$124,950,000

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

Violation #	Overloaded Facility	Upgrade Description	Network Upgrade Number	Upgrade Cost
4, 5	6MORNSTR-6ROCKYMT230T 230 kV	DVP / CPLE: This is a joint tie line with Duke/Progress Energy. The line limit is not overloaded on the PJM ITO portion of the line. The ratings are limited on Duke Energy's side. The latest update indicates the line ratings are 478 MVA (normal), 478 MVA (Emergency) and 478 MVA (load dump). An affected systems study will need to be completed with Duke/Progress to determine upgrades required on the Duke/Progress system.	-	-

Violation #	Overloaded Facility	Upgrade Description	Network Upgrade Number	Upgrade Cost
6	8ELMONT 500/230 kV transformer	DVP: Elmont 500 – 230 kV Tx#1: replace the 500-230 kV transformer #1 increase its line rating to 1134 MVA (normal), 1203 MVA (emergency), and 1365 MVA (load dump). It is estimated to take 24-30 months to engineer and construct.	Pending	\$17,500,000
7, 8, 9	6CLUBHSE-6SAPONY 230 kV line	DVP: Line #238 Clubhouse to Sapony 230 kV: replace wave trap at Clubhouse Substation to increase its line rating to 722 MVA (normal), 722 MVA (emergency), and 830 MVA (load dump). It is estimated to take 12-16 months to engineer and construct.	Pending	\$150,000
10, 11	6EARLEYS-6NUCO TP 230 kV line	Same as New Reinforcement for violations 1 and 2 above	-	-
12	6EVERETS-AD2-068 TAP 230 kV line	DVP: Line #218 Everetts-AD2-068 Tap 230 kV: wreck and rebuild the line of 18 miles to increase its line rating to 722 MVA (normal), 722 MVA (emergency), and 830 MVA (load dump). It is estimated to take 44-48 months to engineer, permit, and construct. A Va CPCN is required. A certificate from the NC PUC will most likely be required.	Pending	\$45,000,000
13	3FIVE PT-3WHARTON 115 kV line	DVP: Line #189 AB2-169 Tap – Five Points DP – Wharton 115 kV: wreck and rebuild the line of 24 miles to increase its line rating to 262 MVA (normal), 287 MVA (emergency), and 349 MVA (load dump). It is estimated to take 30-36 months to engineer, permit, and construct. A Va CPCN is required.	Pending	\$47,310,000
14, 15, 16	6LAKEVEW-AB2-100 TAP 230 kV line	DVP: Line #254 AB2-100 Tap – Lakeview 230 kV: wreck and rebuild the line of 16 miles to increase its line rating to 722 MVA (normal), 722 MVA (emergency), and 830 MVA (load dump). It is estimated to take 44-48 months to engineer, permit, and construct. A Va CPCN is required. A certificate from the NC PUC will most likely be required.	Pending	\$40,000,000
17	3POPLR C-3EVERETS 115 kV line	DVP: Line #25 Pop Chap – Everetts 115 kV: replace relay in Everetts to increase its line rating to 263 MVA (normal), 287 MVA (emergency), and 349 MVA (load dump). It is estimated to take 14-16 months to engineer, permit and construct.	Pending	\$200,000

Violation #	Overloaded Facility	Upgrade Description	Network Upgrade Number	Upgrade Cost
18, 19	6ELIZ CT-6SHAWBRO 230 kV line	DVP: Line #2021 Elizabeth City – Shawboro 230 kV: wreck and rebuild the line of 8 miles to increase its line rating to 1047 MVA (normal), 1047 MVA (emergency), and 1204 MVA (load dump). It is estimated to take 30-36 months to engineer, permit, and construct. A Va CPCN is required.	Pending	\$25,700,000
20, 21	6S HERTFORD-6WINFALL 230 kV line	DVP: Line #2131 Z1-036 – Tap S Hertford – Winfall 230 kV: wreck and rebuild the line of 8 miles to increase its line rating to 1047 MVA (normal), 1047 MVA (emergency), and 1204 MVA (load dump). It is estimated to take 30-36 months to engineer, permit, and construct. A Va CPCN is required.	Pending	\$19,875,000
22, 23	Z1-036 TAP-6S HERTFORD 230 kV line	Same reinforcement as for Violations 20 and 21 above.	-	-
24, 25, 26	AB2-100 TAP-6CLUBHSE 230 kV line	DVP: Line #254 AB2-100 Tap – Clubhouse 230 kV: wreck and rebuild the AB2-100 TAP-Clubhouse 230kV line of 2 miles to increase its line rating to 722 MVA (normal), 722 MVA (emergency), and 830 MVA (load dump). It is estimated to take 24-28 months to engineer, permit and construct. A Va CPCN is required.	Pending	\$5,000,000
27	AB2-169 TAP-3FIVE PT 115 kV line	Same reinforcement as for Violation 13 above.	-	-
28, 29	AD2-068 TAP-6GREENVILE T 230 kV line	DVP/CPL: The AD2-068 TAP-6GREENVILE T 230 kV line is a joint tie line between the Dominion Energy and Duke/Progress transmission systems. The VEPCO portion can be resolved by wrecking and rebuilding the line of 3 miles to increase its line rating to 722 MVA (normal), 722 MVA (emergency), and 830 MVA (load dump). It is estimated to take 44-48 months to engineer, permit, and construct. A Va CPCN is required. A certificate from the NC PUC will most likely be required. An affected systems study will need to be completed with Duke/Progress to determine upgrades required on the Duke/Progress system.	-	\$6,000,000
Total Previous Network Upgrades (This project may have a contribution towards these reinforcements)				\$206,735,000

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The IC can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

Overload Number	Contingency Type	Contingency Name	Affected Area	Facility Description	Bus		Circuit	Power Flow	Loading %		Rating		MW Contribution	Flowgate Appendix
					From	To			Initial	Final	Type	MVA		
30	N-1	"313845	DVP - CPLE	6MORNSTR-6ROCKYMT230T 230 kV line	313845	304222	1	DC	155.67	156.62	ER	374	7.87	
31	N-1	DVP_P1-2: LN 2058	DVP - DVP	6MORNSTR-6NASH 230 kV line	313845	314591	1	DC	134	135.79	ER	449	8.03	
32	N-1	DVP_P1-2: LN 246	DVP - DVP	6MACKEYS-6EDENTON 230 kV line	314203	314637	1	DC	108.29	112.36	ER	731	29.75	
33	N-1	DVP_P1-2: LN 563	DVP - DVP	6CHESTFB-6BASIN 230 kV line	314287	314276	1	DC	183.37	183.83	ER	449	4.51	
34	N-1	DVP_P1-2: LN 2131A	DVP - DVP	6SAPONY-6CARSON 230 kV line	314435	314282	1	DC	127.56	128.37	ER	679	12.1	
35	N-1	DVP_P1-2: LN 246	DVP - DVP	6CLUBHSE-6SAPONY 230 kV line	314563	314435	1	DC	136.5	137.35	ER	599	11.21	
36	Non	Non	DVP - DVP	6CLUBHSE-6SAPONY 230 kV line	314563	314435	1	DC	116.32	116.97	NR	599	8.1	
37	N-1	DVP_P1-2: LN 2131A	DVP - DVP	6EARLEYS-6NUCO TP 230 kV line	314569	314575	1	DC	166.89	171.07	ER	572	25.66	
38	Non	Non	DVP - DVP	6EARLEYS-6NUCO TP 230 kV line	314569	314575	1	DC	99.3	101.86	NR	572	14.58	
39	N-1	DVP_P1-2: LN 2131A	DVP - DVP	6EVERETS-AD2-068 TAP 230 kV line	314574	936530	1	DC	122.43	124.88	ER	449	20.71	
40	Non	Non	DVP - DVP	6EVERETS-AD2-068 TAP 230 kV line	314574	936530	1	DC	100.94	103.22	NR	449	16.13	
41	N-1	DVP_P1-2: LN 2131A	DVP - DVP	6NUCO TP-6SUFFOLK 230 kV line	314575	314537	1	DC	160.87	165.06	ER	572	25.66	
42	N-1	DVP_P1-2: LN 1020_B	DVP - DVP	3FIVE PT-3WHARTON 115 kV line	314576	314622	1	DC	45.79	153.51	ER	74	80	
43	N-1	DVP_P1-2: LN 2131A	DVP - DVP	6LAKEVEW-AB2-100 TAP 230 kV line	31458	92451	1	DC	159.8	161.2	ER	375	11.56	

					3	0			1					
44	Non	Non	DVP - DVP	6LAKEVEW-AB2-100 TAP 230 kV line	31458 3	92451 0	1	DC	122.3 2	123.2 7	NR	375	7.84	
45	N-1	DVP_P1-2: LN 2058	DVP - CPLE	6NASH-6PA-RMOUNT#4 230 kV line	31459 1	30422 6	1	DC	123.0 9	124.8	ER	470	8.03	
46	N-1	"314620	DVP - DVP	3POPLR C-3EVERETS 115 kV line	31459 6	31457 3	1	DC	122.1 2	132.0 4	ER	225	22.3	
47	N-1	"314620	DVP - DVP	3TRWBRDG2-3POPLR C 115 kV line	31461 4	31459 6	1	DC	99.71	107.5 2	ER	286	22.3	
48	N-1	DVP_P1-2: LN 2131A	DVP - DVP	6TRWBRDG-AD1-023 TAP 230 kV line	31461 6	93399 0	1	DC	133.9 4	141.4 4	ER	572	42.88	
49	N-1	DVP_P1-2: LN 2131A	DVP - DVP	6CASHIE-6EARLEYS 230 kV line	31462 0	31456 9	1	DC	148.8 5	156.3 5	ER	572	42.88	
50	N-1	DVP_P1-2: LN 246	DVP - DVP	6EDENTON-Z1-036 TAP 230 kV line	31463 7	91604 0	1	DC	103.8 7	107.9 3	ER	733	29.75	
51	N-1	DVP_P1-2: LN 247	DVP - DVP	6ELIZ CT-6SHAWBRO 230 kV line	31463 8	31464 7	1	DC	129.0 8	132.8 3	ER	572	21.45	
52	N-1	DVP_P1-2: LN 2020	DVP - DVP	6SUNBURY-6SUFFOLK 230 kV line	31464 8	31453 7	1	DC	152.7 5	157.6 2	ER	449	19.92	
53	N-1	DVP_P1-2: LN 2020	DVP - DVP	6WINFALL-W1-029 230 kV line	31465 1	90108 0	1	DC	107.9	112.3 4	ER	449	19.94	
54	N-1	DVP_P1-2: LN 246	DVP - DVP	6S HERTFORD-6WINFALL 230 kV line	31466 2	31465 1	1	DC	131.8 8	135.9 4	ER	733	29.73	
55	Non	Non	DVP - DVP	6S HERTFORD-6WINFALL 230 kV line	31466 2	31465 1	1	DC	97.47	100.9 3	NR	733	25.3	
56	N-1	DVP_P1-2: LN 2020	DVP - DVP	W1-029-6SUNBURY 230 kV line	90108 0	31464 8	1	DC	154.6 4	159.0 8	ER	449	19.92	
57	N-1	DVP_P1-2: LN 246	DVP - DVP	Z1-036 TAP-6S HERTFORD 230 kV line	91604 0	31466 2	1	DC	133.5 2	137.5 8	ER	733	29.73	
58	Non	Non	DVP - DVP	Z1-036 TAP-6S HERTFORD 230 kV line	91604 0	31466 2	1	DC	100.7 7	104.2 2	NR	733	25.3	
59	N-1	DVP_P1-2: LN 130-A	DVP - DVP	AB2-100 TAP-6CLUBHSE 230 kV line	92451 0	31456 3	1	DC	171.7 4	174.0 1	ER	375	8.5	
60	Non	Non	DVP - DVP	AB2-100 TAP-6CLUBHSE 230 kV line	92451 0	31456 3	1	DC	137.8 1	138.7 5	NR	375	7.84	
61	N-1	DVP_P1-2: LN 1020_B	DVP - DVP	AB2-169 TAP-3FIVE PT 115 kV line	92512 0	31457 6	1	DC	59.66	167.3 8	ER	74	80	
62	N-1	DVP_P1-2: LN 2131A	DVP - DVP	AD1-023 TAP-6CASHIE 230 kV line	93399 0	31462 0	1	DC	150.5 3	158.0 4	ER	572	42.88	

63	N-1	DVP_P1-2: LN 2131A	DVP - CPLE	AD2-068 TAP-6GREENVILE T 230 kV line	93653 0	30445 1	1	DC	119.3 5	122.2 2	ER	478	20.71	
64	Non	Non	DVP - CPLE	AD2-068 TAP-6GREENVILE T 230 kV line	93653 0	30445 1	1	DC	99.62	102.2 5	NR	478	16.13	
65	N-1	AEP_P1-2_#1377	AEP - AEP	05EDAN 1-05DANVL2 138 kV line	24263 1	24262 0	1	DC	143.7 8	144.2 6	ER	415	4.49	

Light Load Analysis

Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).

Affected System Analysis & Mitigation

Duke, Progress & TVA Impacts:

Duke Carolina, Progress, & TVA Impacts to be determined during later study phases (as applicable).

Attachment 1.
System Configuration

Attachment 2.

Flowgate Appendices

Appendices

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. When a flowgate is identified in multiple analysis the appendix is presented for only the analysis with the greatest overload.

It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Appendix 1

(DVP - DVP) The 6NUCO TP-6SUFFOLK 230 kV line (from bus 314575 to bus 314537 ckt 1) loads from 97.19% to 100.34% (**DC power flow**) of its emergency rating (572 MVA) for the single line contingency outage of 'DVP_P1-2: LN 2131A'. This project contributes approximately 17.93 MW to the thermal violation.

CONTINGENCY 'DVP_P1-2: LN 2131A'

OPEN BRANCH FROM BUS 314662 TO BUS 916040 CKT 1 /* 6S HERTFORD
230.00 - Z1-036 TAP 230.00

OPEN BRANCH FROM BUS 314651 TO BUS 314662 CKT 1 /* 6WINFALL
230.00 - 6S HERTFORD 230.00

OPEN BUS 314662 /* ISLAND

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	4.18
315292	1DOMTR78	2.83
315293	1DOMTR9	2.31
315131	1EDGECEMA	9.03
315132	1EDGECEMB	9.03
315139	1GASTONA	3.41
315141	1GASTONB	3.41
315159	1KERR 2	0.75
315163	1KERR 6	0.73
315164	1KERR 7	0.73
315126	1ROARAP2	1.38
315128	1ROARAP4	1.33
315136	1ROSEMG1	2.41
315138	1ROSEMG2	1.13
315137	1ROSEMS1	1.49
314704	3LAWRENC	0.2
932631	AC2-084 C	11.32

933991	AD1-023 C	27.83
934201	AD1-047 C	6.39
934231	AD1-050 C	2.75
934331	AD1-057 C O1	10.19
934521	AD1-076 C O1	112.9
LTF	AD1-120	4.28
LTF	AD1-121	4.25
936401	AD2-051 C O1	16.62
936531	AD2-068 C	6.82
936701	AD2-089 C	8.51
LTF	AD2-099	3.34
937441	AD2-195 C	17.93
LTF	CARR	0.08
LTF	CBM-S1	5.3
LTF	CBM-S2	10.7
LTF	CBM-W1	11.88
LTF	CBM-W2	28.77
LTF	CIN	2.66
LTF	CPL	3.69
LTF	IPL	1.7
LTF	LGEE	0.57
LTF	MEC	5.96
LTF	MECS	2.73
LTF	RENSSELAER	0.06
LTF	ROSETON	0.47
900671	V4-068 C	0.1

<i>LTF</i>	<i>WEC</i>	<i>0.73</i>
<i>916041</i>	<i>Z1-036 C</i>	<i>2.36</i>
<i>917331</i>	<i>Z2-043 C</i>	<i>0.67</i>
<i>917341</i>	<i>Z2-044 C</i>	<i>0.24</i>
<i>917511</i>	<i>Z2-088 C OPI</i>	<i>1.06</i>
<i>918411</i>	<i>AA1-050</i>	<i>0.89</i>
<i>918491</i>	<i>AA1-063AC OP</i>	<i>1.26</i>
<i>918511</i>	<i>AA1-065 C OP</i>	<i>3.52</i>
<i>918531</i>	<i>AA1-067 C</i>	<i>0.46</i>
<i>918561</i>	<i>AA1-072 C</i>	<i>0.1</i>
<i>919691</i>	<i>AA2-053 C</i>	<i>1.77</i>
<i>919701</i>	<i>AA2-057 C</i>	<i>1.31</i>
<i>LTF</i>	<i>AA2-074</i>	<i>2.51</i>
<i>920041</i>	<i>AA2-088 C</i>	<i>0.73</i>
<i>920591</i>	<i>AA2-165 C</i>	<i>0.18</i>
<i>920671</i>	<i>AA2-174 C</i>	<i>0.08</i>
<i>920691</i>	<i>AA2-178 C</i>	<i>19.71</i>
<i>930051</i>	<i>AB1-013 C</i>	<i>5.95</i>
<i>930401</i>	<i>AB1-081 C</i>	<i>8.64</i>
<i>930861</i>	<i>AB1-132 C</i>	<i>15.16</i>
<i>931231</i>	<i>AB1-173 C</i>	<i>1.8</i>
<i>931241</i>	<i>AB1-173AC</i>	<i>1.8</i>
<i>923911</i>	<i>AB2-031 C OI</i>	<i>1.78</i>
<i>923941</i>	<i>AB2-035 C</i>	<i>0.4</i>
<i>923991</i>	<i>AB2-040 C OI</i>	<i>5.86</i>
<i>924151</i>	<i>AB2-059 C OI</i>	<i>10.18</i>

<i>924391</i>	<i>AB2-088 C</i>	<i>0.51</i>
<i>924401</i>	<i>AB2-089 C</i>	<i>1.25</i>
<i>924491</i>	<i>AB2-098 C</i>	<i>0.88</i>
<i>924501</i>	<i>AB2-099 C</i>	<i>0.99</i>
<i>924511</i>	<i>AB2-100 C</i>	<i>7.32</i>
<i>925121</i>	<i>AB2-169 C</i>	<i>11.96</i>
<i>925171</i>	<i>AB2-174 C O1</i>	<i>5.33</i>
<i>925291</i>	<i>AB2-188 C O1</i>	<i>4.86</i>
<i>925591</i>	<i>AC1-034 C</i>	<i>6.6</i>
<i>925781</i>	<i>AC1-054 C</i>	<i>4.54</i>
<i>926071</i>	<i>AC1-086 C</i>	<i>22.32</i>
<i>926201</i>	<i>AC1-098 C</i>	<i>7.94</i>
<i>926211</i>	<i>AC1-099 C</i>	<i>2.66</i>
<i>926771</i>	<i>AC1-163 C</i>	<i>3.28</i>
<i>927021</i>	<i>AC1-189 C</i>	<i>11.67</i>
<i>927141</i>	<i>AC1-208 C</i>	<i>9.96</i>

Appendix 2

(DVP - DVP) The 3PANTEGO-AB2-169 TAP 115 kV line (from bus 314592 to bus 925120 ckt 1) loads from 97.89% to 126.17% (**DC power flow**) of its load dump rating (91 MVA) for the tower line contingency outage of 'DVP_P7-1: LN 25-2034_A'. This project contributes approximately 25.73 MW to the thermal violation.

```

CONTINGENCY 'DVP_P7-1: LN 25-2034_A'                /*REPLACED ON
4/19/2016
  OPEN BRANCH FROM BUS 314573 TO BUS 314596 CKT 1    /* 3EVERETS
115.00 - 3POPLR C 115.00
  OPEN BRANCH FROM BUS 314596 TO BUS 314614 CKT 1    /* 3POPLR C
115.00 - 3TROWBR2 115.00
  OPEN BUS 314596                                     /* ISLAND
  OPEN BRANCH FROM BUS 314569 TO BUS 314620 CKT 1    /* 6EARLEYS
230.00 - 6CASHIE 230.00
  OPEN BRANCH FROM BUS 314614 TO BUS 314616 CKT 1    /* 3TROWBR2
115.00 - 6TRWBRDG 230.00
  OPEN BRANCH FROM BUS 314616 TO BUS 933990 CKT 1    /* 6TRWBRDG
230.00 - AD1-023 TAP 230.00
END
  
```

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	2.78
315292	1DOMTR78	1.88
315293	1DOMTR9	1.53
314566	3CRESWEL	1.3
314594	6PLYMOTH	0.56
934521	AD1-076 C O1	37.19
934522	AD1-076 E O1	18.94
937441	AD2-195 C	17.98
937442	AD2-195 E	7.75
LTF	AMIL	0.06
LTF	BAYOU	0.31
LTF	BIG_CAJUNI	0.49

<i>LTF</i>	<i>BIG_CAJUN2</i>	<i>0.98</i>
<i>LTF</i>	<i>BLUEG</i>	<i>0.31</i>
<i>LTF</i>	<i>CALDERWOOD</i>	<i>0.18</i>
<i>LTF</i>	<i>CANNELTON</i>	<i>0.06</i>
<i>LTF</i>	<i>CARR</i>	<i>< 0.01</i>
<i>LTF</i>	<i>CATAWBA</i>	<i>0.17</i>
<i>LTF</i>	<i>CELEVELAND</i>	<i>0.49</i>
<i>LTF</i>	<i>CHEOAH</i>	<i>0.17</i>
<i>LTF</i>	<i>CHILHOWEE</i>	<i>0.06</i>
<i>LTF</i>	<i>CHOCTAW</i>	<i>0.33</i>
<i>LTF</i>	<i>CLIFTY</i>	<i>1.12</i>
<i>LTF</i>	<i>COTTONWOOD</i>	<i>1.21</i>
<i>LTF</i>	<i>DEARBORN</i>	<i>0.11</i>
<i>LTF</i>	<i>EDWARDS</i>	<i>0.09</i>
<i>LTF</i>	<i>ELMERSMITH</i>	<i>0.17</i>
<i>LTF</i>	<i>FARMERCITY</i>	<i>0.07</i>
<i>LTF</i>	<i>G-007A</i>	<i>0.11</i>
<i>LTF</i>	<i>GIBSON</i>	<i>0.11</i>
<i>LTF</i>	<i>HAMLET</i>	<i>0.72</i>
<i>LTF</i>	<i>MORGAN</i>	<i>0.53</i>
<i>LTF</i>	<i>NEWTON</i>	<i>0.26</i>
<i>LTF</i>	<i>PRAIRIE</i>	<i>0.56</i>
<i>LTF</i>	<i>RENSSELAER</i>	<i>< 0.01</i>
<i>LTF</i>	<i>ROSETON</i>	<i>< 0.01</i>
<i>LTF</i>	<i>ROWAN</i>	<i>0.35</i>
<i>LTF</i>	<i>SANTEETLA</i>	<i>0.05</i>

<i>LTF</i>	<i>SMITHLAND</i>	<i>0.05</i>
<i>LTF</i>	<i>TATANKA</i>	<i>0.13</i>
<i>LTF</i>	<i>TILTON</i>	<i>0.11</i>
<i>LTF</i>	<i>TRIMBLE</i>	<i>0.06</i>
<i>LTF</i>	<i>TVA</i>	<i>0.22</i>
<i>LTF</i>	<i>UNIONPOWER</i>	<i>0.32</i>
<i>LTF</i>	<i>VFT</i>	<i>0.29</i>
<i>916042</i>	<i>Z1-036 E</i>	<i>16.14</i>
<i>920691</i>	<i>AA2-178 C</i>	<i>5.21</i>
<i>920692</i>	<i>AA2-178 E</i>	<i>2.23</i>
<i>930051</i>	<i>AB1-013 C</i>	<i>1.57</i>
<i>930052</i>	<i>AB1-013 E</i>	<i>10.53</i>
<i>925281</i>	<i>AB2-186 C</i>	<i>0.2</i>
<i>925282</i>	<i>AB2-186 E</i>	<i>0.08</i>
<i>925291</i>	<i>AB2-188 C O1</i>	<i>1.28</i>
<i>925292</i>	<i>AB2-188 E O1</i>	<i>0.58</i>

Appendix 3

(DVP - CPLE) The 6MORNSTR-6ROCKYMT230T 230 kV line (from bus 313845 to bus 304222 ckt 1) loads from 112.44% to 113.91% (**DC power flow**) of its emergency rating (374 MVA) for the single line contingency outage of "'313845'. This project contributes approximately 5.5 MW to the thermal violation.

CONTINGENCY '313845'

6MORNSTR 230 314591 6NASH 230

1

OPEN BRANCH FROM BUS 313845 TO BUS 314591 CKT 1

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	1.22
315292	1DOMTR78	0.82
315293	1DOMTR9	0.67
315131	1EDGECEMA	24.66
315132	1EDGECEMB	24.66
315139	1GASTONA	3.54
315141	1GASTONB	3.54
315126	1ROARAP2	1.13
315128	1ROARAP4	1.09
315136	1ROSEMG1	2.96
315138	1ROSEMG2	1.38
315137	1ROSEMS1	1.83
315115	1S HAMPT1	0.78
314704	3LAWRENC	0.18
932631	AC2-084 C	8.4
933991	AD1-023 C	7.23
934201	AD1-047 C	5.75
934231	AD1-050 C	1.59

<i>934331</i>	<i>AD1-057 C OI</i>	<i>19.74</i>
<i>934521</i>	<i>AD1-076 C OI</i>	<i>28.41</i>
<i>936401</i>	<i>AD2-051 C OI</i>	<i>6.11</i>
<i>936701</i>	<i>AD2-089 C</i>	<i>14.39</i>
<i>936711</i>	<i>AD2-090 C OI</i>	<i>3.69</i>
<i>937441</i>	<i>AD2-195 C</i>	<i>5.5</i>
<i>LTF</i>	<i>AMIL</i>	<i>0.38</i>
<i>LTF</i>	<i>BAYOU</i>	<i>2.</i>
<i>LTF</i>	<i>BIG_CAJUN1</i>	<i>3.15</i>
<i>LTF</i>	<i>BIG_CAJUN2</i>	<i>6.33</i>
<i>LTF</i>	<i>BLUEG</i>	<i>2.01</i>
<i>LTF</i>	<i>CALDERWOOD</i>	<i>1.18</i>
<i>LTF</i>	<i>CANNELTON</i>	<i>0.38</i>
<i>LTF</i>	<i>CARR</i>	<i>< 0.01</i>
<i>LTF</i>	<i>CATAWBA</i>	<i>1.15</i>
<i>LTF</i>	<i>CELEVELAND</i>	<i>3.28</i>
<i>LTF</i>	<i>CHEOAH</i>	<i>1.1</i>
<i>LTF</i>	<i>CHILHOWEE</i>	<i>0.38</i>
<i>LTF</i>	<i>CHOCTAW</i>	<i>2.14</i>
<i>LTF</i>	<i>CLIFTY</i>	<i>7.37</i>
<i>LTF</i>	<i>COTTONWOOD</i>	<i>7.82</i>
<i>LTF</i>	<i>DEARBORN</i>	<i>0.73</i>
<i>LTF</i>	<i>EDWARDS</i>	<i>0.62</i>
<i>LTF</i>	<i>ELMERSMITH</i>	<i>1.12</i>
<i>LTF</i>	<i>FARMERCITY</i>	<i>0.48</i>
<i>LTF</i>	<i>G-007A</i>	<i>0.77</i>

<i>LTF</i>	<i>GIBSON</i>	<i>0.7</i>
<i>LTF</i>	<i>HAMLET</i>	<i>4.56</i>
<i>LTF</i>	<i>MORGAN</i>	<i>3.46</i>
<i>LTF</i>	<i>NEWTON</i>	<i>1.69</i>
<i>LTF</i>	<i>PRAIRIE</i>	<i>3.65</i>
<i>LTF</i>	<i>RENSSELAER</i>	<i>< 0.01</i>
<i>LTF</i>	<i>ROSETON</i>	<i>< 0.01</i>
<i>LTF</i>	<i>ROWAN</i>	<i>2.42</i>
<i>LTF</i>	<i>SANTEETLA</i>	<i>0.33</i>
<i>LTF</i>	<i>SMITHLAND</i>	<i>0.32</i>
<i>LTF</i>	<i>TATANKA</i>	<i>0.82</i>
<i>LTF</i>	<i>TILTON</i>	<i>0.73</i>
<i>LTF</i>	<i>TRIMBLE</i>	<i>0.38</i>
<i>LTF</i>	<i>TVA</i>	<i>1.46</i>
<i>LTF</i>	<i>UNIONPOWER</i>	<i>2.1</i>
<i>900671</i>	<i>V4-068 C</i>	<i>0.06</i>
<i>LTF</i>	<i>VFT</i>	<i>2.05</i>
<i>901081</i>	<i>W1-029C</i>	<i>0.35</i>
<i>916041</i>	<i>Z1-036 C</i>	<i>0.42</i>
<i>917331</i>	<i>Z2-043 C</i>	<i>0.32</i>
<i>917341</i>	<i>Z2-044 C</i>	<i>0.28</i>
<i>917511</i>	<i>Z2-088 C OP1</i>	<i>1.46</i>
<i>918411</i>	<i>AA1-050</i>	<i>1.23</i>
<i>918491</i>	<i>AA1-063AC OP</i>	<i>1.05</i>
<i>918511</i>	<i>AA1-065 C OP</i>	<i>1.01</i>
<i>918531</i>	<i>AA1-067 C</i>	<i>0.22</i>

918561	AA1-072 C	0.05
919691	AA2-053 C	1.16
919701	AA2-057 C	1.39
920041	AA2-088 C	0.64
920591	AA2-165 C	0.19
920671	AA2-174 C	0.05
920691	AA2-178 C	4.33
930051	AB1-013 C	1.31
930401	AB1-081 C	14.25
930861	AB1-132 C	15.73
931231	AB1-173 C	1.62
931241	AB1-173AC	1.62
923801	AB2-015 C O1	4.04
923851	AB2-025 C	0.17
923911	AB2-031 C O1	1.61
923941	AB2-035 C	0.67
923991	AB2-040 C O1	5.27
924151	AB2-059 C O1	16.8
924391	AB2-088 C	0.86
924401	AB2-089 C	0.72
924491	AB2-098 C	0.42
924501	AB2-099 C	0.4
924511	AB2-100 C	8.38
925121	AB2-169 C	4.01
925171	AB2-174 C O1	4.92
925281	AB2-186 C	0.21

<i>925291</i>	<i>AB2-188 C OI</i>	<i>1.07</i>
<i>925591</i>	<i>ACI-034 C</i>	<i>10.88</i>
<i>925781</i>	<i>ACI-054 C</i>	<i>2.81</i>
<i>926071</i>	<i>ACI-086 C</i>	<i>23.16</i>
<i>926201</i>	<i>ACI-098 C</i>	<i>5.89</i>
<i>926211</i>	<i>ACI-099 C</i>	<i>1.98</i>
<i>926771</i>	<i>ACI-163 C</i>	<i>1.31</i>
<i>927021</i>	<i>ACI-189 C</i>	<i>12.13</i>
<i>927141</i>	<i>ACI-208 C</i>	<i>8.7</i>

Appendix 4

(DVP - DVP) The 8ELMONT 500/230 kV transformer (from bus 314218 to bus 314908 ckt 1) loads from 153.05% to 153.44% (**DC power flow**) of its load dump rating (1051 MVA) for the line fault with failed breaker contingency outage of 'DVP_P4-2: H2T557'. This project contributes approximately 11.13 MW to the thermal violation.

```
CONTINGENCY 'DVP_P4-2: H2T557'                               /* ELMONT
  OPEN BRANCH FROM BUS 314908 TO BUS 314903 CKT 1          /*ELMONT TO
CHICKAHOMINY (LINE 557)
  OPEN BRANCH FROM BUS 314903 TO BUS 314214 CKT 1
/*CHICKAHOMINY 500-230 (TX#1)
  OPEN BRANCH FROM BUS 314908 TO BUS 314218 CKT 2          /*ELMONT 500-
230 (TX#2)
END
```

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315053	1BELMED1	25.63
315054	1BELMED2	25.63
315055	1BELMED3	21.27
315058	1CHESTF3	27.13
315059	1CHESTF4	43.98
315067	1DARBY 1	4.37
315068	1DARBY 2	4.38
315069	1DARBY 3	4.39
315070	1DARBY 4	4.4
315043	1FOUR RIVERA	5.82
315044	1FOUR RIVERB	4.5
315045	1FOUR RIVERC	5.82
315046	1FOUR RIVERD	4.5
315047	1FOUR RIVERE	4.5
315048	1FOUR RIVERF	5.82

<i>315074</i>	<i>1HOPCGN1</i>	<i>11.31</i>
<i>315075</i>	<i>1HOPCGN2</i>	<i>11.16</i>
<i>315083</i>	<i>1SPRUNCA</i>	<i>14.98</i>
<i>315084</i>	<i>1SPRUNCB</i>	<i>14.98</i>
<i>315085</i>	<i>1SPRUNCC</i>	<i>11.11</i>
<i>315086</i>	<i>1SPRUNCD</i>	<i>11.11</i>
<i>315073</i>	<i>1STONECA</i>	<i>9.38</i>
<i>315090</i>	<i>1YORKTN1</i>	<i>31.01</i>
<i>315091</i>	<i>1YORKTN2</i>	<i>32.18</i>
<i>314566</i>	<i>3CRESWEL</i>	<i>2.11</i>
<i>314572</i>	<i>3EMPORIA</i>	<i>0.36</i>
<i>314315</i>	<i>3LOCKS E</i>	<i>1.66</i>
<i>314617</i>	<i>3TUNIS</i>	<i>0.72</i>
<i>314539</i>	<i>3UNCAMP</i>	<i>2.2</i>
<i>314541</i>	<i>3WATKINS</i>	<i>0.62</i>
<i>314620</i>	<i>6CASHIE</i>	<i>0.72</i>
<i>314229</i>	<i>6MT RD221</i>	<i>1.41</i>
<i>314236</i>	<i>6NRTHEST</i>	<i>0.32</i>
<i>314189</i>	<i>6PAPERMILL</i>	<i>8.84</i>
<i>314594</i>	<i>6PLYMOTH</i>	<i>0.74</i>
<i>314250</i>	<i>6ROCKVILLE</i>	<i>0.35</i>
<i>314256</i>	<i>6ROCKVILLE E</i>	<i>1.16</i>
<i>314648</i>	<i>6SUNBURY</i>	<i>0.81</i>
<i>314651</i>	<i>6WINFALL</i>	<i>1.59</i>
<i>932041</i>	<i>AC2-012 C</i>	<i>9.65</i>
<i>932042</i>	<i>AC2-012 E</i>	<i>15.74</i>

932501	AC2-070 C	2.91
932502	AC2-070 E	1.2
932531	AC2-073 C	3.11
932532	AC2-073 E	1.57
932581	AC2-078 C	4.76
932582	AC2-078 E	7.77
932591	AC2-079 C	5.81
932592	AC2-079 E	9.48
932831	AC2-110 C	1.75
932832	AC2-110 E	2.85
933061	AC2-130	3.49
933071	AC2-131 1	2.36
933081	AC2-131 2	1.07
933111	AC2-132 1	1.24
933121	AC2-132 2	0.64
933261	AC2-137 C	3.16
933262	AC2-137 E	2.03
933271	AC2-138 C	0.87
933272	AC2-138 E	1.09
933291	AC2-141 C	27.25
933292	AC2-141 E	11.63
933471	AC2-161 C	2.48
933472	AC2-161 E	1.28
933481	AC2-162 C	4.17
933482	AC2-162 E	2.15
933731	AC2-196 C	1.66

933732	AC2-196 E	1.11
933991	AD1-023 C	11.33
933992	AD1-023 E	6.17
934011	AD1-025 C O1	20.87
934012	AD1-025 E O1	12.36
934061	AD1-033 C O1	6.98
934062	AD1-033 E O1	4.66
934141	AD1-041 C O1	6.75
934142	AD1-041 E O1	4.5
934191	AD1-046 C	4.73
934192	AD1-046 E	3.15
934201	AD1-047 C	6.77
934202	AD1-047 E	4.52
934211	AD1-048 C	3.83
934212	AD1-048 E	1.93
934391	AD1-063 C	2.1
934392	AD1-063 E	1.4
934521	AD1-076 C O1	47.05
934522	AD1-076 E O1	23.96
934571	AD1-082 C O1	8.29
934572	AD1-082 E O1	4.73
934781	AD1-105 C	8.11
934782	AD1-105 E	5.63
LTF	AD1-120	5.98
LTF	AD1-121	5.94
935111	AD1-144 C	1.68

935112	AD1-144 E	0.92
935161	AD1-151 C OI	19.94
935162	AD1-151 E OI	13.29
935211	AD1-156 C	2.56
935212	AD1-156 E	1.71
936041	AD2-007	2.22
936051	AD2-008 C	3.63
936052	AD2-008 E	7.91
936151	AD2-021	0.36
936241	AD2-030 C	2.89
936242	AD2-030 E	1.48
936301	AD2-039 C	1.75
936302	AD2-039 E	2.85
936341	AD2-044 C	0.27
936342	AD2-044 E	0.31
936391	AD2-049 C	1.89
936392	AD2-049 E	1.89
936401	AD2-051 C OI	7.36
936402	AD2-051 E OI	3.16
936581	AD2-073 C	2.25
936582	AD2-073 E	1.11
936591	AD2-074 C	6.55
936592	AD2-074 E	10.68
936661	AD2-085 C	3.51
936662	AD2-085 E	5.73
936711	AD2-090 C OI	6.4

936712	AD2-090 E OI	4.26
<i>LTF</i>	AD2-099	4.57
937221	AD2-160 C OI	5.42
937222	AD2-160 E OI	2.84
937251	AD2-164	5.15
937441	AD2-195 C	7.78
937442	AD2-195 E	3.35
937541	AD2-215 C	1.7
937542	AD2-215 E	0.9
<i>LTF</i>	CARR	0.65
<i>LTF</i>	CBM-S1	4.02
<i>LTF</i>	CBM-S2	13.98
<i>LTF</i>	CBM-W1	0.84
<i>LTF</i>	CBM-W2	18.98
<i>LTF</i>	CIN	0.26
<i>LTF</i>	CLIFTY	1.24
<i>LTF</i>	CPL	4.79
<i>LTF</i>	DEARBORN	0.43
<i>LTF</i>	G-007	2.25
<i>LTF</i>	IPL	0.14
<i>LTF</i>	LGEE	0.07
<i>LTF</i>	MEC	2.24
<i>LTF</i>	O-066	14.38
<i>LTF</i>	RENSSELAER	0.51
<i>LTF</i>	ROSETON	3.71
292791	U1-032 E	4.88

297087	V2-040	0.24
900672	V4-068 E	0.26
901082	W1-029E	41.96
LTF	WEC	0.09
907092	X1-038 E	5.49
913392	Y1-086 E	2.
916042	Z1-036 E	40.98
916192	Z1-068 E	1.76
917122	Z2-027 E	0.97
918492	AA1-063AE OP	3.36
918512	AA1-065 E OP	3.75
918691	AA1-083	1.02
919152	AA1-139 E	5.94
919211	AA1-145	17.36
919692	AA2-053 E	3.07
LTF	AA2-074	3.26
920042	AA2-088 E	9.19
920672	AA2-174 E	0.35
920691	AA2-178 C	8.45
920692	AA2-178 E	3.62
930051	ABI-013 C	2.55
930052	ABI-013 E	17.08
930121	ABI-027 C	0.76
930122	ABI-027 E	1.9
930861	ABI-132 C	11.82
930862	ABI-132 E	5.07

931231	ABI-173 C	1.9
931232	ABI-173 E	0.89
931241	ABI-173AC	1.9
931242	ABI-173AE	0.89
923801	AB2-015 C O1	7.75
923802	AB2-015 E O1	6.36
923831	AB2-022 C	2.11
923832	AB2-022 E	1.13
923842	AB2-024 E	1.49
923852	AB2-025 E	1.09
923862	AB2-026 E	0.88
923911	AB2-031 C O1	1.89
923912	AB2-031 E O1	0.93
923991	AB2-040 C O1	6.21
923992	AB2-040 E O1	5.08
924061	AB2-050	1.02
924071	AB2-051	129.26
924241	AB2-068 O1	178.5
924501	AB2-099 C	0.5
924502	AB2-099 E	0.21
924511	AB2-100 C	10.52
924512	AB2-100 E	5.18
924811	AB2-134 C O1	15.91
924812	AB2-134 E O1	15.11
925051	AB2-160 C O1	7.19
925052	AB2-160 E O1	11.74

925061	AB2-161 C O1	3.64
925062	AB2-161 E O1	5.94
925171	AB2-174 C O1	5.98
925172	AB2-174 E O1	5.41
925281	AB2-186 C	0.55
925282	AB2-186 E	0.24
925291	AB2-188 C O1	2.08
925292	AB2-188 E O1	0.94
925331	AB2-190 C	24.81
925332	AB2-190 E	10.63
925522	AC1-027 E	1.07
925692	AC1-045 E	0.92
925861	AC1-065 C	4.37
925862	AC1-065 E	7.13
926071	AC1-086 C	17.41
926072	AC1-086 E	7.92
926291	AC1-107	269.44
926411	AC1-112 C	0.59
926412	AC1-112 E	1.93
926472	AC1-118 E	1.08
926551	AC1-134	14.85
926662	AC1-147 E	1.25
926741	AC1-159	62.33
926751	AC1-161 C	27.25
926752	AC1-161 E	11.63
926771	AC1-163 C	1.63

<i>926772</i>	<i>ACI-163 E</i>	<i>0.76</i>
<i>926781</i>	<i>ACI-164 C</i>	<i>58.53</i>
<i>926782</i>	<i>ACI-164 E</i>	<i>26.3</i>
<i>927041</i>	<i>ACI-191 C</i>	<i>17.49</i>
<i>927042</i>	<i>ACI-191 E</i>	<i>8.71</i>
<i>927221</i>	<i>ACI-216 C OI</i>	<i>12.14</i>
<i>927222</i>	<i>ACI-216 E OI</i>	<i>9.55</i>

Appendix 5

(DVP - DVP) The 6CLUBHSE-6SAPONY 230 kV line (from bus 314563 to bus 314435 ckt 1) loads from 135.21% to 136.09% (**DC power flow**) of its load dump rating (637 MVA) for the line fault with failed breaker contingency outage of 'DVP_P4-2: 246T247'. This project contributes approximately 12.35 MW to the thermal violation.

```

CONTINGENCY 'DVP_P4-2: 246T247'                /* SUFFOLK 230 KV
  OPEN BRANCH FROM BUS 314537 TO BUS 314575 CKT 1    /* 6SUFFOLK
230.00 - 6NUCO TP 230.00
  OPEN BRANCH FROM BUS 314569 TO BUS 314575 CKT 1    /* 6EARLEYS
230.00 - 6NUCO TP 230.00
  OPEN BRANCH FROM BUS 314575 TO BUS 314590 CKT 1    /* 6NUCO TP
230.00 - 6NUCOR 230.00
  OPEN BUS 314575                                /* ISLAND: 6NUCO TP 230.00
  OPEN BUS 314590                                /* ISLAND: 6NUCOR 230.00
  OPEN BRANCH FROM BUS 314537 TO BUS 314648 CKT 1    /* 6SUFFOLK
230.00 - 6SUNBURY 230.00
  OPEN BRANCH FROM BUS 314648 TO BUS 901080 CKT 1    /* 6SUNBURY
230.00 - W1-029 230.00
  OPEN BUS 314648                                /* ISLAND: 6SUNBURY 230.00
END
  
```

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315150	1BUGGS 1	8.64
315151	1BUGGS 2	8.64
315131	1EDGECMA	10.81
315132	1EDGECMB	10.81
315139	1GASTONA	6.65
315141	1GASTONB	6.65
315126	1ROARAP2	2.38
315128	1ROARAP4	2.29
315136	1ROSEMG1	4.49
315138	1ROSEMG2	2.1
315137	1ROSEMS1	2.78

<i>314557</i>	<i>3BETHELC</i>	<i>0.9</i>
<i>314554</i>	<i>3BTLEBRO</i>	<i>0.91</i>
<i>314566</i>	<i>3CRESWEL</i>	<i>1.69</i>
<i>314572</i>	<i>3EMPORIA</i>	<i>1.04</i>
<i>314578</i>	<i>3HORNRTN</i>	<i>5.4</i>
<i>314582</i>	<i>3KELFORD</i>	<i>1.09</i>
<i>314704</i>	<i>3LAWRENC</i>	<i>0.72</i>
<i>314603</i>	<i>3SCOT NK</i>	<i>4.39</i>
<i>314617</i>	<i>3TUNIS</i>	<i>1.</i>
<i>314541</i>	<i>3WATKINS</i>	<i>0.48</i>
<i>314620</i>	<i>6CASHIE</i>	<i>0.87</i>
<i>314574</i>	<i>6EVERETS</i>	<i>2.55</i>
<i>314594</i>	<i>6PLYMOTH</i>	<i>0.72</i>
<i>932631</i>	<i>AC2-084 C</i>	<i>11.81</i>
<i>932632</i>	<i>AC2-084 E</i>	<i>5.82</i>
<i>933991</i>	<i>AD1-023 C</i>	<i>12.49</i>
<i>933992</i>	<i>AD1-023 E</i>	<i>6.8</i>
<i>934201</i>	<i>AD1-047 C</i>	<i>17.57</i>
<i>934202</i>	<i>AD1-047 E</i>	<i>11.71</i>
<i>934231</i>	<i>AD1-050 C</i>	<i>5.08</i>
<i>934232</i>	<i>AD1-050 E</i>	<i>2.78</i>
<i>934331</i>	<i>AD1-057 C OI</i>	<i>15.84</i>
<i>934332</i>	<i>AD1-057 E OI</i>	<i>8.45</i>
<i>934521</i>	<i>AD1-076 C OI</i>	<i>47.2</i>
<i>934522</i>	<i>AD1-076 E OI</i>	<i>24.04</i>
<i>LTF</i>	<i>AD1-120</i>	<i>4.44</i>

<i>LTF</i>	<i>AD1-121</i>	<i>4.42</i>
<i>936261</i>	<i>AD2-033 C</i>	<i>9.73</i>
<i>936262</i>	<i>AD2-033 E</i>	<i>6.49</i>
<i>936361</i>	<i>AD2-046 C O1</i>	<i>8.38</i>
<i>936362</i>	<i>AD2-046 E O1</i>	<i>3.85</i>
<i>936401</i>	<i>AD2-051 C O1</i>	<i>11.34</i>
<i>936402</i>	<i>AD2-051 E O1</i>	<i>4.87</i>
<i>936481</i>	<i>AD2-063 C O1</i>	<i>11.53</i>
<i>936482</i>	<i>AD2-063 E O1</i>	<i>7.69</i>
<i>936531</i>	<i>AD2-068 C</i>	<i>4.92</i>
<i>936532</i>	<i>AD2-068 E</i>	<i>2.53</i>
<i>936701</i>	<i>AD2-089 C</i>	<i>8.13</i>
<i>936702</i>	<i>AD2-089 E</i>	<i>5.42</i>
<i>936711</i>	<i>AD2-090 C O1</i>	<i>5.56</i>
<i>936712</i>	<i>AD2-090 E O1</i>	<i>3.71</i>
<i>LTF</i>	<i>AD2-099</i>	<i>3.35</i>
<i>937441</i>	<i>AD2-195 C</i>	<i>8.63</i>
<i>937442</i>	<i>AD2-195 E</i>	<i>3.72</i>
<i>LTF</i>	<i>CARR</i>	<i>0.11</i>
<i>LTF</i>	<i>CBM-S1</i>	<i>5.45</i>
<i>LTF</i>	<i>CBM-S2</i>	<i>10.91</i>
<i>LTF</i>	<i>CBM-W1</i>	<i>12.07</i>
<i>LTF</i>	<i>CBM-W2</i>	<i>29.49</i>
<i>LTF</i>	<i>CIN</i>	<i>2.71</i>
<i>LTF</i>	<i>CPL</i>	<i>3.68</i>
<i>LTF</i>	<i>G-007</i>	<i>0.77</i>

<i>LTF</i>	<i>IPL</i>	<i>1.73</i>
<i>LTF</i>	<i>LGEE</i>	<i>0.59</i>
<i>LTF</i>	<i>MEC</i>	<i>6.09</i>
<i>LTF</i>	<i>MECS</i>	<i>2.73</i>
<i>LTF</i>	<i>O-066</i>	<i>4.89</i>
<i>LTF</i>	<i>RENSSELAER</i>	<i>0.09</i>
<i>LTF</i>	<i>ROSETON</i>	<i>0.67</i>
<i>900671</i>	<i>V4-068 C</i>	<i>0.1</i>
<i>900672</i>	<i>V4-068 E</i>	<i>0.33</i>
<i>LTF</i>	<i>WEC</i>	<i>0.74</i>
<i>917331</i>	<i>Z2-043 C</i>	<i>0.52</i>
<i>917332</i>	<i>Z2-043 E</i>	<i>1.31</i>
<i>917341</i>	<i>Z2-044 C</i>	<i>0.28</i>
<i>917342</i>	<i>Z2-044 E</i>	<i>0.7</i>
<i>917511</i>	<i>Z2-088 C OP1</i>	<i>0.93</i>
<i>917512</i>	<i>Z2-088 E OP1</i>	<i>4.29</i>
<i>918411</i>	<i>AA1-050</i>	<i>0.79</i>
<i>918491</i>	<i>AA1-063AC OP</i>	<i>2.06</i>
<i>918492</i>	<i>AA1-063AE OP</i>	<i>5.65</i>
<i>918511</i>	<i>AA1-065 C OP</i>	<i>1.96</i>
<i>918512</i>	<i>AA1-065 E OP</i>	<i>5.62</i>
<i>918531</i>	<i>AA1-067 C</i>	<i>0.31</i>
<i>918532</i>	<i>AA1-067 E</i>	<i>0.76</i>
<i>918561</i>	<i>AA1-072 C</i>	<i>0.08</i>
<i>918562</i>	<i>AA1-072 E</i>	<i>0.22</i>
<i>919691</i>	<i>AA2-053 C</i>	<i>2.38</i>

919692	AA2-053 E	5.95
919701	AA2-057 C	1.55
919702	AA2-057 E	4.52
LTF	AA2-074	2.51
920041	AA2-088 C	1.09
920042	AA2-088 E	10.3
920591	AA2-165 C	0.21
920592	AA2-165 E	0.6
920671	AA2-174 C	0.11
920672	AA2-174 E	0.69
920691	AA2-178 C	6.77
920692	AA2-178 E	2.9
930051	AB1-013 C	2.04
930052	AB1-013 E	13.68
930401	AB1-081 C	10.25
930402	AB1-081 E	4.39
930861	AB1-132 C	29.52
930862	AB1-132 E	12.65
931231	AB1-173 C	4.94
931232	AB1-173 E	2.31
931241	AB1-173AC	4.94
931242	AB1-173AE	2.31
923801	AB2-015 C O1	5.48
923802	AB2-015 E O1	4.49
923911	AB2-031 C O1	4.9
923912	AB2-031 E O1	2.42

923941	AB2-035 C	0.38
923942	AB2-035 E	0.16
923991	AB2-040 C OI	16.1
923992	AB2-040 E OI	13.17
924021	AB2-043 C OI	2.68
924022	AB2-043 E OI	4.39
924151	AB2-059 C OI	12.09
924152	AB2-059 E OI	6.23
924161	AB2-060 C OI	7.59
924162	AB2-060 E OI	3.57
924301	AB2-077 C OI	1.68
924302	AB2-077 E OI	1.12
924311	AB2-078 C OI	1.68
924312	AB2-078 E OI	1.12
924321	AB2-079 C OI	1.68
924322	AB2-079 E OI	1.12
924391	AB2-088 C	0.49
924392	AB2-088 E	0.23
924401	AB2-089 C	2.31
924402	AB2-089 E	1.19
924411	AB2-090 C	3.37
924412	AB2-090 E	1.73
924491	AB2-098 C	0.59
924492	AB2-098 E	0.26
924501	AB2-099 C	0.73
924502	AB2-099 E	0.31

924511	AB2-100 C	35.91
924512	AB2-100 E	17.69
925121	AB2-169 C	6.15
925122	AB2-169 E	5.52
925171	AB2-174 C O1	16.16
925172	AB2-174 E O1	14.62
925221	AB2-176 C	1.39
925222	AB2-176 E	0.59
925291	AB2-188 C O1	1.67
925292	AB2-188 E O1	0.75
925591	AC1-034 C	7.83
925592	AC1-034 E	5.91
925611	AC1-036 C	0.64
925612	AC1-036 E	1.04
925781	AC1-054 C	8.28
925782	AC1-054 E	3.81
926071	AC1-086 C	43.47
926072	AC1-086 E	19.79
926201	AC1-098 C	8.29
926202	AC1-098 E	4.94
926211	AC1-099 C	2.78
926212	AC1-099 E	1.63
926771	AC1-163 C	2.41
926772	AC1-163 E	1.13
927021	AC1-189 C	9.39
927022	AC1-189 E	4.68

<i>927141</i>	<i>ACI-208 C</i>	<i>13.11</i>
<i>927142</i>	<i>ACI-208 E</i>	<i>5.82</i>

Appendix 6

(DVP - DVP) The 6EARLEYS-6NUCO TP 230 kV line (from bus 314569 to bus 314575 ckt 1) loads from 103.21% to 106.36% (**DC power flow**) of its emergency rating (572 MVA) for the single line contingency outage of 'DVP_P1-2: LN 2131A'. This project contributes approximately 17.93 MW to the thermal violation.

CONTINGENCY 'DVP_P1-2: LN 2131A'

OPEN BRANCH FROM BUS 314662 TO BUS 916040 CKT 1 /* 6S HERTFORD
230.00 - Z1-036 TAP 230.00

OPEN BRANCH FROM BUS 314651 TO BUS 314662 CKT 1 /* 6WINFALL
230.00 - 6S HERTFORD 230.00

OPEN BUS 314662 /* ISLAND

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	4.18
315292	1DOMTR78	2.83
315293	1DOMTR9	2.31
315131	1EDGECEMA	9.03
315132	1EDGECEMB	9.03
315139	1GASTONA	3.41
315141	1GASTONB	3.41
315159	1KERR 2	0.75
315163	1KERR 6	0.73
315164	1KERR 7	0.73
315126	1ROARAP2	1.38
315128	1ROARAP4	1.33
315136	1ROSEMG1	2.41
315138	1ROSEMG2	1.13
315137	1ROSEMS1	1.49
314704	3LAWRENC	0.2

932631	AC2-084 C	11.32
933991	AD1-023 C	27.83
934201	AD1-047 C	6.39
934231	AD1-050 C	2.75
934331	AD1-057 C O1	10.19
934521	AD1-076 C O1	112.9
LTF	AD1-120	4.28
LTF	AD1-121	4.25
936401	AD2-051 C O1	16.62
936531	AD2-068 C	6.82
936701	AD2-089 C	8.51
LTF	AD2-099	3.34
937441	AD2-195 C	17.93
LTF	CARR	0.08
LTF	CBM-S1	5.3
LTF	CBM-S2	10.7
LTF	CBM-W1	11.88
LTF	CBM-W2	28.77
LTF	CIN	2.66
LTF	CPL	3.69
LTF	IPL	1.7
LTF	LGEE	0.57
LTF	MEC	5.96
LTF	MECS	2.73
LTF	RENSSELAER	0.06
LTF	ROSETON	0.47

900671	V4-068 C	0.1
LTF	WEC	0.73
916041	Z1-036 C	2.36
917331	Z2-043 C	0.67
917341	Z2-044 C	0.24
917511	Z2-088 C OPI	1.06
918411	AA1-050	0.89
918491	AA1-063AC OP	1.26
918511	AA1-065 C OP	3.52
918531	AA1-067 C	0.46
918561	AA1-072 C	0.1
919691	AA2-053 C	1.77
919701	AA2-057 C	1.31
LTF	AA2-074	2.51
920041	AA2-088 C	0.73
920591	AA2-165 C	0.18
920671	AA2-174 C	0.08
920691	AA2-178 C	19.71
930051	AB1-013 C	5.95
930401	AB1-081 C	8.64
930861	AB1-132 C	15.16
931231	AB1-173 C	1.8
931241	AB1-173AC	1.8
923911	AB2-031 C OI	1.78
923941	AB2-035 C	0.4
923991	AB2-040 C OI	5.86

<i>924151</i>	<i>AB2-059 C OI</i>	<i>10.18</i>
<i>924391</i>	<i>AB2-088 C</i>	<i>0.51</i>
<i>924401</i>	<i>AB2-089 C</i>	<i>1.25</i>
<i>924491</i>	<i>AB2-098 C</i>	<i>0.88</i>
<i>924501</i>	<i>AB2-099 C</i>	<i>0.99</i>
<i>924511</i>	<i>AB2-100 C</i>	<i>7.32</i>
<i>925121</i>	<i>AB2-169 C</i>	<i>11.96</i>
<i>925171</i>	<i>AB2-174 C OI</i>	<i>5.33</i>
<i>925291</i>	<i>AB2-188 C OI</i>	<i>4.86</i>
<i>925591</i>	<i>AC1-034 C</i>	<i>6.6</i>
<i>925781</i>	<i>AC1-054 C</i>	<i>4.54</i>
<i>926071</i>	<i>AC1-086 C</i>	<i>22.32</i>
<i>926201</i>	<i>AC1-098 C</i>	<i>7.94</i>
<i>926211</i>	<i>AC1-099 C</i>	<i>2.66</i>
<i>926771</i>	<i>AC1-163 C</i>	<i>3.28</i>
<i>927021</i>	<i>AC1-189 C</i>	<i>11.67</i>
<i>927141</i>	<i>AC1-208 C</i>	<i>9.96</i>

Appendix 7

(DVP - DVP) The 6EVERETS-AD2-068 TAP 230 kV line (from bus 314574 to bus 936530 ckt 1) loads from 134.57% to 138.36% (**DC power flow**) of its load dump rating (485 MVA) for the tower line contingency outage of 'DVP_P7-1: LN 2058-2181'. This project contributes approximately 18.41 MW to the thermal violation.

CONTINGENCY 'DVP_P7-1: LN 2058-2181'

OPEN BRANCH FROM BUS 304222 TO BUS 313845 CKT 1 /*

6ROCKYMT230T230.00 - 6HATHAWAY 230.00

OPEN BUS 304226 /* ISLAND: 6PA-RMOUNT#4115.00

OPEN BRANCH FROM BUS 304226 TO BUS 314591 CKT 1 /* 6PA-

RMOUNT#4230.00 - 6NASH 230.00

OPEN BRANCH FROM BUS 313845 TO BUS 314591 CKT 1 /* 6HATHAWAY
230.00 - 6NASH 230.00

OPEN BUS 314591 /* ISLAND: 6NASH 230.00

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	2.74
315292	1DOMTR78	1.85
315293	1DOMTR9	1.51
315131	1EDGECEMA	9.28
315132	1EDGECEMB	9.28
315136	1ROSEMG1	1.74
315138	1ROSEMG2	0.81
315137	1ROSEMS1	1.08
314557	3BETHEL	1.14
314554	3BTLEBRO	0.43
314566	3CRESWEL	2.04
314572	3EMPORIA	0.21
314578	3HORNRTN	2.04
314582	3KELFORD	0.72

314603	3SCOT NK	2.51
314617	3TUNIS	0.7
314539	3UNCAMP	1.18
314541	3WATKINS	0.36
314620	6CASHIE	0.88
314574	6EVERETS	5.39
314594	6PLYMOTH	0.83
314648	6SUNBURY	0.4
314651	6WINFALL	0.97
932631	AC2-084 C	6.16
932632	AC2-084 E	3.04
933991	AD1-023 C	13.46
933992	AD1-023 E	7.33
934201	AD1-047 C	4.28
934202	AD1-047 E	2.86
934331	AD1-057 C O1	8.8
934332	AD1-057 E O1	4.69
934521	AD1-076 C O1	54.73
934522	AD1-076 E O1	27.87
936401	AD2-051 C O1	8.4
936402	AD2-051 E O1	3.61
936701	AD2-089 C	10.3
936702	AD2-089 E	6.87
936711	AD2-090 C O1	3.91
936712	AD2-090 E O1	2.61
937441	AD2-195 C	12.87

937442	AD2-195 E	5.55
<i>LTF</i>	<i>AMIL</i>	0.48
<i>LTF</i>	<i>BAYOU</i>	2.64
<i>LTF</i>	<i>BIG_CAJUN1</i>	4.17
<i>LTF</i>	<i>BIG_CAJUN2</i>	8.38
<i>LTF</i>	<i>BLUEG</i>	2.5
<i>LTF</i>	<i>CALDERWOOD</i>	1.54
<i>LTF</i>	<i>CANNELTON</i>	0.48
<i>LTF</i>	<i>CATAWBA</i>	1.51
<i>LTF</i>	<i>CBM-N</i>	< 0.01
<i>LTF</i>	<i>CELEVELAND</i>	4.27
<i>LTF</i>	<i>CHEOAH</i>	1.44
<i>LTF</i>	<i>CHILHOWEE</i>	0.5
<i>LTF</i>	<i>CHOCTAW</i>	2.84
<i>LTF</i>	<i>CLIFTY</i>	9.04
<i>LTF</i>	<i>COTTONWOOD</i>	10.32
<i>LTF</i>	<i>DEARBORN</i>	0.89
<i>LTF</i>	<i>EDWARDS</i>	0.78
<i>LTF</i>	<i>ELMERSMITH</i>	1.41
<i>LTF</i>	<i>FARMERCITY</i>	0.62
<i>LTF</i>	<i>G-007A</i>	1.04
<i>LTF</i>	<i>GIBSON</i>	0.88
<i>LTF</i>	<i>HAMLET</i>	6.47
<i>LTF</i>	<i>MORGAN</i>	4.57
<i>LTF</i>	<i>NEWTON</i>	2.15
<i>LTF</i>	<i>NYISO</i>	0.06

<i>LTF</i>	<i>PRAIRIE</i>	<i>4.68</i>
<i>LTF</i>	<i>ROWAN</i>	<i>2.99</i>
<i>LTF</i>	<i>SANTEETLA</i>	<i>0.43</i>
<i>LTF</i>	<i>SMITHLAND</i>	<i>0.42</i>
<i>LTF</i>	<i>TATANKA</i>	<i>1.05</i>
<i>LTF</i>	<i>TILTON</i>	<i>0.92</i>
<i>LTF</i>	<i>TRIMBLE</i>	<i>0.47</i>
<i>LTF</i>	<i>TVA</i>	<i>1.92</i>
<i>LTF</i>	<i>UNIONPOWER</i>	<i>2.74</i>
<i>900672</i>	<i>V4-068 E</i>	<i>0.21</i>
<i>LTF</i>	<i>VFT</i>	<i>2.76</i>
<i>901082</i>	<i>W1-029E</i>	<i>23.37</i>
<i>907092</i>	<i>X1-038 E</i>	<i>2.96</i>
<i>913392</i>	<i>Y1-086 E</i>	<i>1.05</i>
<i>916042</i>	<i>Z1-036 E</i>	<i>29.11</i>
<i>917122</i>	<i>Z2-027 E</i>	<i>0.51</i>
<i>917331</i>	<i>Z2-043 C</i>	<i>0.34</i>
<i>917332</i>	<i>Z2-043 E</i>	<i>0.86</i>
<i>917342</i>	<i>Z2-044 E</i>	<i>0.33</i>
<i>917511</i>	<i>Z2-088 C OP1</i>	<i>1.33</i>
<i>917512</i>	<i>Z2-088 E OP1</i>	<i>6.13</i>
<i>918411</i>	<i>AA1-050</i>	<i>1.12</i>
<i>918492</i>	<i>AA1-063AE OP</i>	<i>2.44</i>
<i>918511</i>	<i>AA1-065 C OP</i>	<i>1.69</i>
<i>918512</i>	<i>AA1-065 E OP</i>	<i>4.84</i>
<i>918531</i>	<i>AA1-067 C</i>	<i>0.65</i>

918532	AA1-067 E	1.62
918561	AA1-072 C	0.05
918562	AA1-072 E	0.14
919692	AA2-053 E	2.58
919702	AA2-057 E	2.12
920042	AA2-088 E	6.24
920592	AA2-165 E	0.28
920672	AA2-174 E	0.3
920691	AA2-178 C	8.16
920692	AA2-178 E	3.5
930051	AB1-013 C	2.46
930052	AB1-013 E	16.47
930401	AB1-081 C	5.63
930402	AB1-081 E	2.41
930861	AB1-132 C	10.35
930862	AB1-132 E	4.44
931231	AB1-173 C	1.21
931232	AB1-173 E	0.56
931241	AB1-173AC	1.21
931242	AB1-173AE	0.56
923801	AB2-015 C O1	4.39
923802	AB2-015 E O1	3.6
923831	AB2-022 C	1.02
923832	AB2-022 E	0.55
923911	AB2-031 C O1	1.2
923912	AB2-031 E O1	0.59

923941	AB2-035 C	0.48
923942	AB2-035 E	0.21
923991	AB2-040 C OI	3.93
923992	AB2-040 E OI	3.21
924151	AB2-059 C OI	6.64
924152	AB2-059 E OI	3.42
924391	AB2-088 C	0.62
924392	AB2-088 E	0.3
924491	AB2-098 C	1.26
924492	AB2-098 E	0.54
924501	AB2-099 C	0.53
924502	AB2-099 E	0.23
924511	AB2-100 C	5.85
924512	AB2-100 E	2.88
925121	AB2-169 C	10.01
925122	AB2-169 E	8.99
925171	AB2-174 C OI	3.64
925172	AB2-174 E OI	3.29
925281	AB2-186 C	0.37
925282	AB2-186 E	0.16
925291	AB2-188 C OI	2.01
925292	AB2-188 E OI	0.9
925591	ACI-034 C	4.3
925592	ACI-034 E	3.24
926071	ACI-086 C	15.25
926072	ACI-086 E	6.94

<i>926201</i>	<i>ACI-098 C</i>	<i>4.32</i>
<i>926202</i>	<i>ACI-098 E</i>	<i>2.58</i>
<i>926211</i>	<i>ACI-099 C</i>	<i>1.45</i>
<i>926212</i>	<i>ACI-099 E</i>	<i>0.85</i>
<i>LTF</i>	<i>ACI-133</i>	<i>22.48</i>
<i>926771</i>	<i>ACI-163 C</i>	<i>1.74</i>
<i>926772</i>	<i>ACI-163 E</i>	<i>0.81</i>
<i>927021</i>	<i>ACI-189 C</i>	<i>15.45</i>
<i>927022</i>	<i>ACI-189 E</i>	<i>7.7</i>
<i>927141</i>	<i>ACI-208 C</i>	<i>5.74</i>
<i>927142</i>	<i>ACI-208 E</i>	<i>2.55</i>

Appendix 8

(DVP - DVP) The 3FIVE PT-3WHARTON 115 kV line (from bus 314576 to bus 314622 ckt 1) loads from 126.19% to 154.47% (**DC power flow**) of its load dump rating (91 MVA) for the tower line contingency outage of 'DVP_P7-1: LN 25-2034_A'. This project contributes approximately 25.73 MW to the thermal violation.

```

CONTINGENCY 'DVP_P7-1: LN 25-2034_A'                /*REPLACED ON
4/19/2016
  OPEN BRANCH FROM BUS 314573 TO BUS 314596 CKT 1    /* 3EVERETS
115.00 - 3POPLR C 115.00
  OPEN BRANCH FROM BUS 314596 TO BUS 314614 CKT 1    /* 3POPLR C
115.00 - 3TROWBR2 115.00
  OPEN BUS 314596                                     /* ISLAND
  OPEN BRANCH FROM BUS 314569 TO BUS 314620 CKT 1    /* 6EARLEYS
230.00 - 6CASHIE 230.00
  OPEN BRANCH FROM BUS 314614 TO BUS 314616 CKT 1    /* 3TROWBR2
115.00 - 6TRWBRDG 230.00
  OPEN BRANCH FROM BUS 314616 TO BUS 933990 CKT 1    /* 6TRWBRDG
230.00 - AD1-023 TAP 230.00
END
  
```

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	2.78
315292	1DOMTR78	1.88
315293	1DOMTR9	1.53
314566	3CRESWEL	1.3
314594	6PLYMOTH	0.56
934521	AD1-076 C O1	37.19
934522	AD1-076 E O1	18.94
937441	AD2-195 C	17.98
937442	AD2-195 E	7.75
LTF	AMIL	0.06
LTF	BAYOU	0.31
LTF	BIG_CAJUNI	0.49

<i>LTF</i>	<i>BIG_CAJUN2</i>	<i>0.98</i>
<i>LTF</i>	<i>BLUEG</i>	<i>0.31</i>
<i>LTF</i>	<i>CALDERWOOD</i>	<i>0.18</i>
<i>LTF</i>	<i>CANNELTON</i>	<i>0.06</i>
<i>LTF</i>	<i>CARR</i>	<i>< 0.01</i>
<i>LTF</i>	<i>CATAWBA</i>	<i>0.17</i>
<i>LTF</i>	<i>CELEVELAND</i>	<i>0.49</i>
<i>LTF</i>	<i>CHEOAH</i>	<i>0.17</i>
<i>LTF</i>	<i>CHILHOWEE</i>	<i>0.06</i>
<i>LTF</i>	<i>CHOCTAW</i>	<i>0.33</i>
<i>LTF</i>	<i>CLIFTY</i>	<i>1.12</i>
<i>LTF</i>	<i>COTTONWOOD</i>	<i>1.21</i>
<i>LTF</i>	<i>DEARBORN</i>	<i>0.11</i>
<i>LTF</i>	<i>EDWARDS</i>	<i>0.09</i>
<i>LTF</i>	<i>ELMERSMITH</i>	<i>0.17</i>
<i>LTF</i>	<i>FARMERCITY</i>	<i>0.07</i>
<i>LTF</i>	<i>G-007A</i>	<i>0.11</i>
<i>LTF</i>	<i>GIBSON</i>	<i>0.11</i>
<i>LTF</i>	<i>HAMLET</i>	<i>0.72</i>
<i>LTF</i>	<i>MORGAN</i>	<i>0.53</i>
<i>LTF</i>	<i>NEWTON</i>	<i>0.26</i>
<i>LTF</i>	<i>PRAIRIE</i>	<i>0.56</i>
<i>LTF</i>	<i>RENSSELAER</i>	<i>< 0.01</i>
<i>LTF</i>	<i>ROSETON</i>	<i>< 0.01</i>
<i>LTF</i>	<i>ROWAN</i>	<i>0.35</i>
<i>LTF</i>	<i>SANTEETLA</i>	<i>0.05</i>

<i>LTF</i>	<i>SMITHLAND</i>	<i>0.05</i>
<i>LTF</i>	<i>TATANKA</i>	<i>0.13</i>
<i>LTF</i>	<i>TILTON</i>	<i>0.11</i>
<i>LTF</i>	<i>TRIMBLE</i>	<i>0.06</i>
<i>LTF</i>	<i>TVA</i>	<i>0.22</i>
<i>LTF</i>	<i>UNIONPOWER</i>	<i>0.32</i>
<i>LTF</i>	<i>VFT</i>	<i>0.29</i>
<i>916042</i>	<i>Z1-036 E</i>	<i>16.14</i>
<i>920691</i>	<i>AA2-178 C</i>	<i>5.21</i>
<i>920692</i>	<i>AA2-178 E</i>	<i>2.23</i>
<i>930051</i>	<i>AB1-013 C</i>	<i>1.57</i>
<i>930052</i>	<i>AB1-013 E</i>	<i>10.53</i>
<i>925121</i>	<i>AB2-169 C</i>	<i>19.</i>
<i>925122</i>	<i>AB2-169 E</i>	<i>17.05</i>
<i>925281</i>	<i>AB2-186 C</i>	<i>0.2</i>
<i>925282</i>	<i>AB2-186 E</i>	<i>0.08</i>
<i>925291</i>	<i>AB2-188 C O1</i>	<i>1.28</i>
<i>925292</i>	<i>AB2-188 E O1</i>	<i>0.58</i>

Appendix 9

(DVP - DVP) The 6LAKEVEW-AB2-100 TAP 230 kV line (from bus 314583 to bus 924510 ckt 1) loads from 130.4% to 132.98% (**DC power flow**) of its load dump rating (459 MVA) for the line fault with failed breaker contingency outage of 'DVP_P4-2: 246T247'. This project contributes approximately 11.81 MW to the thermal violation.

```

CONTINGENCY 'DVP_P4-2: 246T247'                /* SUFFOLK 230 KV
  OPEN BRANCH FROM BUS 314537 TO BUS 314575 CKT 1    /* 6SUFFOLK
230.00 - 6NUCO TP 230.00
  OPEN BRANCH FROM BUS 314569 TO BUS 314575 CKT 1    /* 6EARLEYS
230.00 - 6NUCO TP 230.00
  OPEN BRANCH FROM BUS 314575 TO BUS 314590 CKT 1    /* 6NUCO TP
230.00 - 6NUCOR 230.00
  OPEN BUS 314575                                /* ISLAND: 6NUCO TP 230.00
  OPEN BUS 314590                                /* ISLAND: 6NUCOR 230.00
  OPEN BRANCH FROM BUS 314537 TO BUS 314648 CKT 1    /* 6SUFFOLK
230.00 - 6SUNBURY 230.00
  OPEN BRANCH FROM BUS 314648 TO BUS 901080 CKT 1    /* 6SUNBURY
230.00 - W1-029 230.00
  OPEN BUS 314648                                /* ISLAND: 6SUNBURY 230.00
END
  
```

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	1.86
315131	1EDGECEMA	10.47
315132	1EDGECEMB	10.47
315139	1GASTONA	6.95
315141	1GASTONB	6.95
315126	1ROARAP2	1.43
315128	1ROARAP4	1.37
315136	1ROSEMG1	4.67
315138	1ROSEMG2	2.19
315137	1ROSEMS1	2.9
314557	3BETHEL C	0.87

<i>314554</i>	<i>3BTLEBRO</i>	<i>0.84</i>
<i>314566</i>	<i>3CRESWEL</i>	<i>1.63</i>
<i>314578</i>	<i>3HORNRTN</i>	<i>3.35</i>
<i>314582</i>	<i>3KELFORD</i>	<i>0.91</i>
<i>314603</i>	<i>3SCOT NK</i>	<i>3.55</i>
<i>314617</i>	<i>3TUNIS</i>	<i>0.81</i>
<i>314541</i>	<i>3WATKINS</i>	<i>0.32</i>
<i>314620</i>	<i>6CASHIE</i>	<i>0.83</i>
<i>314574</i>	<i>6EVERETS</i>	<i>2.43</i>
<i>314594</i>	<i>6PLYMOTH</i>	<i>0.69</i>
<i>932631</i>	<i>AC2-084 C</i>	<i>9.33</i>
<i>932632</i>	<i>AC2-084 E</i>	<i>4.6</i>
<i>933991</i>	<i>AD1-023 C</i>	<i>11.94</i>
<i>933992</i>	<i>AD1-023 E</i>	<i>6.5</i>
<i>934331</i>	<i>AD1-057 C O1</i>	<i>16.08</i>
<i>934332</i>	<i>AD1-057 E O1</i>	<i>8.58</i>
<i>934521</i>	<i>AD1-076 C O1</i>	<i>45.26</i>
<i>934522</i>	<i>AD1-076 E O1</i>	<i>23.05</i>
<i>LTF</i>	<i>AD1-120</i>	<i>3.74</i>
<i>LTF</i>	<i>AD1-121</i>	<i>3.72</i>
<i>936401</i>	<i>AD2-051 C O1</i>	<i>9.84</i>
<i>936402</i>	<i>AD2-051 E O1</i>	<i>4.22</i>
<i>936531</i>	<i>AD2-068 C</i>	<i>4.66</i>
<i>936532</i>	<i>AD2-068 E</i>	<i>2.4</i>
<i>936701</i>	<i>AD2-089 C</i>	<i>7.83</i>
<i>936702</i>	<i>AD2-089 E</i>	<i>5.22</i>

936711	AD2-090 C OI	3.74
936712	AD2-090 E OI	2.5
LTF	AD2-099	2.89
937441	AD2-195 C	8.25
937442	AD2-195 E	3.56
LTF	CARR	0.09
LTF	CBM-S1	4.49
LTF	CBM-S2	9.26
LTF	CBM-W1	9.78
LTF	CBM-W2	24.29
LTF	CIN	2.19
LTF	CPL	3.18
LTF	G-007	0.61
LTF	IPL	1.4
LTF	LGEE	0.47
LTF	MEC	4.97
LTF	MECS	2.19
LTF	O-066	3.89
LTF	RENSSELAER	0.07
LTF	ROSETON	0.54
900672	V4-068 E	0.24
LTF	WEC	0.6
916042	Z1-036 E	21.79
917331	Z2-043 C	0.44
917332	Z2-043 E	1.1
917341	Z2-044 C	0.24

917342	Z2-044 E	0.61
917511	Z2-088 C OPI	0.9
917512	Z2-088 E OPI	4.12
918411	AA1-050	0.76
918491	AA1-063AC OP	1.28
918492	AA1-063AE OP	3.51
918511	AA1-065 C OP	1.86
918512	AA1-065 E OP	5.34
918531	AA1-067 C	0.29
918532	AA1-067 E	0.73
918561	AA1-072 C	0.07
918562	AA1-072 E	0.18
919691	AA2-053 C	1.55
919692	AA2-053 E	3.86
919701	AA2-057 C	1.28
919702	AA2-057 E	3.73
LTF	AA2-074	2.16
920042	AA2-088 E	6.94
920591	AA2-165 C	0.17
920592	AA2-165 E	0.49
920671	AA2-174 C	0.07
920672	AA2-174 E	0.45
920691	AA2-178 C	6.54
920692	AA2-178 E	2.8
930051	ABI-013 C	1.97
930052	ABI-013 E	13.2

930401	ABI-081 C	9.52
930402	ABI-081 E	4.08
930861	ABI-132 C	30.89
930862	ABI-132 E	13.24
923941	AB2-035 C	0.37
923942	AB2-035 E	0.16
924151	AB2-059 C OI	11.22
924152	AB2-059 E OI	5.78
924391	AB2-088 C	0.47
924392	AB2-088 E	0.23
924491	AB2-098 C	0.57
924492	AB2-098 E	0.24
924501	AB2-099 C	0.61
924502	AB2-099 E	0.26
925121	AB2-169 C	5.87
925122	AB2-169 E	5.27
925281	AB2-186 C	0.27
925282	AB2-186 E	0.12
925291	AB2-188 C OI	1.61
925292	AB2-188 E OI	0.72
925591	ACI-034 C	7.27
925592	ACI-034 E	5.48
925781	ACI-054 C	3.71
925782	ACI-054 E	1.71
926071	ACI-086 C	45.49
926072	ACI-086 E	20.7

<i>926201</i>	<i>ACI-098 C</i>	<i>6.55</i>
<i>926202</i>	<i>ACI-098 E</i>	<i>3.9</i>
<i>926211</i>	<i>ACI-099 C</i>	<i>2.19</i>
<i>926212</i>	<i>ACI-099 E</i>	<i>1.29</i>
<i>926771</i>	<i>ACI-163 C</i>	<i>2.03</i>
<i>926772</i>	<i>ACI-163 E</i>	<i>0.95</i>
<i>927021</i>	<i>ACI-189 C</i>	<i>8.99</i>
<i>927022</i>	<i>ACI-189 E</i>	<i>4.48</i>
<i>927141</i>	<i>ACI-208 C</i>	<i>9.41</i>
<i>927142</i>	<i>ACI-208 E</i>	<i>4.18</i>

Appendix 10

(DVP - DVP) The 3POPLR C-3EVERETS 115 kV line (from bus 314596 to bus 314573 ckt 1) loads from 118.16% to 126.67% (**DC power flow**) of its load dump rating (239 MVA) for the line fault with failed breaker contingency outage of 'DVP_P4-2: 2014T2034'. This project contributes approximately 20.34 MW to the thermal violation.

CONTINGENCY 'DVP_P4-2: 2014T2034' /* EARLEYS
 OPEN BRANCH FROM BUS 314569 TO BUS 314620 CKT 1 /* 2034
 OPEN BRANCH FROM BUS 314620 TO BUS 933990 CKT 1 /* 2034
 OPEN BRANCH FROM BUS 314569 TO BUS 314574 CKT 1 /* 2014
 END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	4.39
315292	1DOMTR78	2.97
315293	1DOMTR9	2.42
314566	3CRESWEL	2.76
314594	6PLYMOTH	1.18
314648	6SUNBURY	0.34
314651	6WINFALL	1.05
933991	AD1-023 C	18.97
933992	AD1-023 E	10.33
934521	AD1-076 C O1	78.29
934522	AD1-076 E O1	39.86
937441	AD2-195 C	14.21
937442	AD2-195 E	6.13
LTF	AMIL	0.17
LTF	BAYOU	0.91
LTF	BIG_CAJUN1	1.44
LTF	BIG_CAJUN2	2.9

<i>LTF</i>	<i>BLUEG</i>	<i>0.88</i>
<i>LTF</i>	<i>CALDERWOOD</i>	<i>0.54</i>
<i>LTF</i>	<i>CANNELTON</i>	<i>0.17</i>
<i>LTF</i>	<i>CATAWBA</i>	<i>0.52</i>
<i>LTF</i>	<i>CBM-N</i>	<i>< 0.01</i>
<i>LTF</i>	<i>CELEVELAND</i>	<i>1.48</i>
<i>LTF</i>	<i>CHEOAH</i>	<i>0.5</i>
<i>LTF</i>	<i>CHILHOWEE</i>	<i>0.17</i>
<i>LTF</i>	<i>CHOCTAW</i>	<i>0.98</i>
<i>LTF</i>	<i>CLIFTY</i>	<i>3.22</i>
<i>LTF</i>	<i>COTTONWOOD</i>	<i>3.57</i>
<i>LTF</i>	<i>DEARBORN</i>	<i>0.32</i>
<i>LTF</i>	<i>EDWARDS</i>	<i>0.27</i>
<i>LTF</i>	<i>ELMERSMITH</i>	<i>0.5</i>
<i>LTF</i>	<i>FARMERCITY</i>	<i>0.22</i>
<i>LTF</i>	<i>G-007A</i>	<i>0.38</i>
<i>LTF</i>	<i>GIBSON</i>	<i>0.31</i>
<i>LTF</i>	<i>HAMLET</i>	<i>2.18</i>
<i>LTF</i>	<i>MORGAN</i>	<i>1.58</i>
<i>LTF</i>	<i>NEWTON</i>	<i>0.75</i>
<i>LTF</i>	<i>NYISO</i>	<i>0.03</i>
<i>LTF</i>	<i>PRAIRIE</i>	<i>1.64</i>
<i>LTF</i>	<i>ROWAN</i>	<i>1.05</i>
<i>LTF</i>	<i>SANTEETLA</i>	<i>0.15</i>
<i>LTF</i>	<i>SMITHLAND</i>	<i>0.15</i>
<i>LTF</i>	<i>TATANKA</i>	<i>0.37</i>

<i>LTF</i>	<i>TILTON</i>	<i>0.32</i>
<i>LTF</i>	<i>TRIMBLE</i>	<i>0.17</i>
<i>LTF</i>	<i>TVA</i>	<i>0.66</i>
<i>LTF</i>	<i>UNIONPOWER</i>	<i>0.95</i>
<i>LTF</i>	<i>VFT</i>	<i>1.01</i>
<i>901082</i>	<i>W1-029E</i>	<i>23.47</i>
<i>913392</i>	<i>Y1-086 E</i>	<i>1.07</i>
<i>916041</i>	<i>Z1-036 C</i>	<i>0.89</i>
<i>916042</i>	<i>Z1-036 E</i>	<i>34.83</i>
<i>917122</i>	<i>Z2-027 E</i>	<i>0.52</i>
<i>920691</i>	<i>AA2-178 C</i>	<i>11.05</i>
<i>920692</i>	<i>AA2-178 E</i>	<i>4.74</i>
<i>930051</i>	<i>AB1-013 C</i>	<i>3.33</i>
<i>930052</i>	<i>AB1-013 E</i>	<i>22.31</i>
<i>923831</i>	<i>AB2-022 C</i>	<i>0.99</i>
<i>923832</i>	<i>AB2-022 E</i>	<i>0.53</i>
<i>925121</i>	<i>AB2-169 C</i>	<i>4.79</i>
<i>925122</i>	<i>AB2-169 E</i>	<i>4.3</i>
<i>925281</i>	<i>AB2-186 C</i>	<i>0.42</i>
<i>925282</i>	<i>AB2-186 E</i>	<i>0.18</i>
<i>925291</i>	<i>AB2-188 C OI</i>	<i>2.72</i>
<i>925292</i>	<i>AB2-188 E OI</i>	<i>1.22</i>

Appendix 11

(DVP - DVP) The 6ELIZ CT-6SHAWBRO 230 kV line (from bus 314638 to bus 314647 ckt 1) loads from 135.38% to 139.05% (**DC power flow**) of its load dump rating (699 MVA) for the line fault with failed breaker contingency outage of 'DVP_P4-2: 246T247'. This project contributes approximately 25.62 MW to the thermal violation.

```

CONTINGENCY 'DVP_P4-2: 246T247'                /* SUFFOLK 230 KV
  OPEN BRANCH FROM BUS 314537 TO BUS 314575 CKT 1    /* 6SUFFOLK
230.00 - 6NUCO TP 230.00
  OPEN BRANCH FROM BUS 314569 TO BUS 314575 CKT 1    /* 6EARLEYS
230.00 - 6NUCO TP 230.00
  OPEN BRANCH FROM BUS 314575 TO BUS 314590 CKT 1    /* 6NUCO TP
230.00 - 6NUCOR 230.00
  OPEN BUS 314575                                /* ISLAND: 6NUCO TP 230.00
  OPEN BUS 314590                                /* ISLAND: 6NUCOR 230.00
  OPEN BRANCH FROM BUS 314537 TO BUS 314648 CKT 1    /* 6SUFFOLK
230.00 - 6SUNBURY 230.00
  OPEN BRANCH FROM BUS 314648 TO BUS 901080 CKT 1    /* 6SUNBURY
230.00 - W1-029 230.00
  OPEN BUS 314648                                /* ISLAND: 6SUNBURY 230.00
END
  
```

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	4.3
315292	1DOMTR78	2.91
315293	1DOMTR9	2.37
315139	1GASTONA	1.96
315141	1GASTONB	1.96
315136	1ROSEMG1	1.39
315138	1ROSEMG2	0.65
315137	1ROSEMS1	0.86
314557	3BETHELC	0.6
314566	3CRESWEL	6.73
314582	3KELFORD	0.78

<i>314603</i>	<i>3SCOT NK</i>	<i>2.7</i>
<i>314617</i>	<i>3TUNIS</i>	<i>0.7</i>
<i>314620</i>	<i>6CASHIE</i>	<i>1.59</i>
<i>314574</i>	<i>6EVERETS</i>	<i>2.49</i>
<i>314594</i>	<i>6PLYMOTH</i>	<i>2.03</i>
<i>314651</i>	<i>6WINFALL</i>	<i>6.57</i>
<i>932631</i>	<i>AC2-084 C</i>	<i>6.53</i>
<i>932632</i>	<i>AC2-084 E</i>	<i>3.22</i>
<i>933991</i>	<i>AD1-023 C</i>	<i>27.52</i>
<i>933992</i>	<i>AD1-023 E</i>	<i>14.98</i>
<i>934521</i>	<i>AD1-076 C O1</i>	<i>125.49</i>
<i>934522</i>	<i>AD1-076 E O1</i>	<i>63.9</i>
<i>936401</i>	<i>AD2-051 C O1</i>	<i>9.29</i>
<i>936402</i>	<i>AD2-051 E O1</i>	<i>3.99</i>
<i>936531</i>	<i>AD2-068 C</i>	<i>4.44</i>
<i>936532</i>	<i>AD2-068 E</i>	<i>2.29</i>
<i>936701</i>	<i>AD2-089 C</i>	<i>5.4</i>
<i>936702</i>	<i>AD2-089 E</i>	<i>3.6</i>
<i>937441</i>	<i>AD2-195 C</i>	<i>17.9</i>
<i>937442</i>	<i>AD2-195 E</i>	<i>7.72</i>
<i>LTF</i>	<i>CARR</i>	<i>0.06</i>
<i>LTF</i>	<i>CBM-S1</i>	<i>3.23</i>
<i>LTF</i>	<i>CBM-S2</i>	<i>6.65</i>
<i>LTF</i>	<i>CBM-W1</i>	<i>7.09</i>
<i>LTF</i>	<i>CBM-W2</i>	<i>17.48</i>
<i>LTF</i>	<i>CIN</i>	<i>1.59</i>

<i>LTF</i>	<i>CPLE</i>	<i>2.31</i>
<i>LTF</i>	<i>G-007</i>	<i>0.43</i>
<i>LTF</i>	<i>IPL</i>	<i>1.01</i>
<i>LTF</i>	<i>LGEE</i>	<i>0.34</i>
<i>LTF</i>	<i>MEC</i>	<i>3.59</i>
<i>LTF</i>	<i>MECS</i>	<i>1.6</i>
<i>LTF</i>	<i>O-066</i>	<i>2.71</i>
<i>LTF</i>	<i>RENSSELAER</i>	<i>0.05</i>
<i>LTF</i>	<i>ROSETON</i>	<i>0.36</i>
<i>900671</i>	<i>V4-068 C</i>	<i>0.06</i>
<i>900672</i>	<i>V4-068 E</i>	<i>0.18</i>
<i>901081</i>	<i>W1-029C</i>	<i>4.4</i>
<i>901082</i>	<i>W1-029E</i>	<i>171.42</i>
<i>LTF</i>	<i>WEC</i>	<i>0.44</i>
<i>913391</i>	<i>Y1-086 C</i>	<i>0.95</i>
<i>913392</i>	<i>Y1-086 E</i>	<i>8.99</i>
<i>916041</i>	<i>Z1-036 C</i>	<i>4.05</i>
<i>916042</i>	<i>Z1-036 E</i>	<i>157.71</i>
<i>917121</i>	<i>Z2-027 C</i>	<i>1.75</i>
<i>917122</i>	<i>Z2-027 E</i>	<i>4.35</i>
<i>917331</i>	<i>Z2-043 C</i>	<i>0.38</i>
<i>917332</i>	<i>Z2-043 E</i>	<i>0.94</i>
<i>917511</i>	<i>Z2-088 C OPI</i>	<i>0.68</i>
<i>917512</i>	<i>Z2-088 E OPI</i>	<i>3.1</i>
<i>918411</i>	<i>AA1-050</i>	<i>0.57</i>
<i>918511</i>	<i>AA1-065 C OP</i>	<i>1.95</i>

918512	AA1-065 E OP	5.58
918531	AA1-067 C	0.3
918532	AA1-067 E	0.75
918561	AA1-072 C	0.06
918562	AA1-072 E	0.16
919691	AA2-053 C	1.01
919692	AA2-053 E	2.52
919701	AA2-057 C	0.78
919702	AA2-057 E	2.26
LTF	AA2-074	1.57
920591	AA2-165 C	0.11
920592	AA2-165 E	0.3
920671	AA2-174 C	0.05
920672	AA2-174 E	0.29
920691	AA2-178 C	26.93
920692	AA2-178 E	11.54
930051	AB1-013 C	8.13
930052	AB1-013 E	54.4
930861	AB1-132 C	8.69
930862	AB1-132 E	3.72
923831	AB2-022 C	9.92
923832	AB2-022 E	5.34
923941	AB2-035 C	0.25
923942	AB2-035 E	0.11
924391	AB2-088 C	0.32
924392	AB2-088 E	0.16

924491	AB2-098 C	0.58
924492	AB2-098 E	0.25
924501	AB2-099 C	0.56
924502	AB2-099 E	0.24
925121	AB2-169 C	11.25
925122	AB2-169 E	10.1
925281	AB2-186 C	2.19
925282	AB2-186 E	0.94
925291	AB2-188 C OI	6.64
925292	AB2-188 E OI	2.98
926071	AC1-086 C	12.79
926072	AC1-086 E	5.82
926201	AC1-098 C	4.58
926202	AC1-098 E	2.73
926211	AC1-099 C	1.54
926212	AC1-099 E	0.9
926771	AC1-163 C	1.84
926772	AC1-163 E	0.86
927021	AC1-189 C	7.54
927022	AC1-189 E	3.75
927141	AC1-208 C	5.8
927142	AC1-208 E	2.58

Appendix 12

(DVP - DVP) The 6S HERTFORD-6WINFALL 230 kV line (from bus 314662 to bus 314651 ckt 1) loads from 105.33% to 111.37% (**DC power flow**) of its load dump rating (897 MVA) for the tower line contingency outage of 'DVP_P7-1: LN 25-2034_A'. This project contributes approximately 54.18 MW to the thermal violation.

```

CONTINGENCY 'DVP_P7-1: LN 25-2034_A'                /*REPLACED ON
4/19/2016
  OPEN BRANCH FROM BUS 314573 TO BUS 314596 CKT 1    /* 3EVERETS
115.00 - 3POPLR C 115.00
  OPEN BRANCH FROM BUS 314596 TO BUS 314614 CKT 1    /* 3POPLR C
115.00 - 3TROWBR2 115.00
  OPEN BUS 314596                                     /* ISLAND
  OPEN BRANCH FROM BUS 314569 TO BUS 314620 CKT 1    /* 6EARLEYS
230.00 - 6CASHIE 230.00
  OPEN BRANCH FROM BUS 314614 TO BUS 314616 CKT 1    /* 3TROWBR2
115.00 - 6TRWBRDG 230.00
  OPEN BRANCH FROM BUS 314616 TO BUS 933990 CKT 1    /* 6TRWBRDG
230.00 - AD1-023 TAP 230.00
END
  
```

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	9.92
315292	1DOMTR78	6.71
315293	1DOMTR9	5.47
314566	3CRESWEL	12.68
314594	6PLYMOTH	4.43
934521	AD1-076 C O1	283.16
934522	AD1-076 E O1	144.18
937441	AD2-195 C	37.86
937442	AD2-195 E	16.32
LTF	CARR	0.04
LTF	CBM-S1	0.47
LTF	CBM-S2	1.24

<i>LTF</i>	<i>CBM-W1</i>	<i>0.71</i>
<i>LTF</i>	<i>CBM-W2</i>	<i>2.45</i>
<i>LTF</i>	<i>CIN</i>	<i>0.16</i>
<i>LTF</i>	<i>CPLE</i>	<i>0.45</i>
<i>LTF</i>	<i>G-007</i>	<i>0.16</i>
<i>LTF</i>	<i>IPL</i>	<i>0.1</i>
<i>LTF</i>	<i>LGEE</i>	<i>0.04</i>
<i>LTF</i>	<i>MEC</i>	<i>0.43</i>
<i>LTF</i>	<i>MECS</i>	<i>0.09</i>
<i>LTF</i>	<i>O-066</i>	<i>1.04</i>
<i>LTF</i>	<i>RENSSELAER</i>	<i>0.03</i>
<i>LTF</i>	<i>ROSETON</i>	<i>0.22</i>
<i>LTF</i>	<i>WEC</i>	<i>0.05</i>
<i>916041</i>	<i>Z1-036 C</i>	<i>6.28</i>
<i>916042</i>	<i>Z1-036 E</i>	<i>244.88</i>
<i>920691</i>	<i>AA2-178 C</i>	<i>50.73</i>
<i>920692</i>	<i>AA2-178 E</i>	<i>21.74</i>
<i>930051</i>	<i>AB1-013 C</i>	<i>15.31</i>
<i>930052</i>	<i>AB1-013 E</i>	<i>102.45</i>
<i>925121</i>	<i>AB2-169 C</i>	<i>19.96</i>
<i>925122</i>	<i>AB2-169 E</i>	<i>17.91</i>
<i>925281</i>	<i>AB2-186 C</i>	<i>3.3</i>
<i>925282</i>	<i>AB2-186 E</i>	<i>1.41</i>
<i>925291</i>	<i>AB2-188 C O1</i>	<i>12.5</i>
<i>925292</i>	<i>AB2-188 E O1</i>	<i>5.62</i>

Appendix 13

(DVP - DVP) The Z1-036 TAP-6S HERTFORD 230 kV line (from bus 916040 to bus 314662 ckt 1) loads from 109.32% to 112.63% (**DC power flow**) of its load dump rating (897 MVA) for the line fault with failed breaker contingency outage of 'DVP_P4-2: 24682'. This project contributes approximately 29.62 MW to the thermal violation.

CONTINGENCY 'DVP_P4-2: 24682' /* 24682 @ SUFFOLK
 OPEN BRANCH FROM BUS 314537 TO BUS 314575 CKT 1 /* SUFFOLK -
 NUCOR TAP
 OPEN BRANCH FROM BUS 314569 TO BUS 314575 CKT 1 /* NUCOR TAP -
 EARLEYS
 OPEN BRANCH FROM BUS 314536 TO BUS 314537 CKT 2 /* SUFFOLK 230-
 115 TX#5
 OPEN BRANCH FROM BUS 314928 TO BUS 314537 CKT 2 /* SUFFOLK 500-
 230 TX#8
 END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	4.98
315292	1DOMTR78	3.36
315293	1DOMTR9	2.74
315131	1EDGECEMA	6.42
315132	1EDGECEMB	6.42
315139	1GASTONA	2.25
315141	1GASTONB	2.25
315136	1ROSEMG1	1.6
315138	1ROSEMG2	0.75
315137	1ROSEMS1	0.99
314557	3BETHEL	0.69
314554	3BTLEBRO	0.54
314566	3CRESWEL	7.79
314578	3HORNRTN	2.2

314582	3KELFORD	0.9
314603	3SCOT NK	3.1
314617	3TUNIS	0.8
314620	6CASHIE	1.83
314574	6EVERETS	2.87
314594	6PLYMOTH	2.34
932631	AC2-084 C	7.52
932632	AC2-084 E	3.7
933991	AD1-023 C	31.82
933992	AD1-023 E	17.32
934331	AD1-057 C OI	7.
934332	AD1-057 E OI	3.74
934521	AD1-076 C OI	145.12
934522	AD1-076 E OI	73.89
936401	AD2-051 C OI	10.69
936402	AD2-051 E OI	4.59
936531	AD2-068 C	5.14
936532	AD2-068 E	2.65
936701	AD2-089 C	6.24
936702	AD2-089 E	4.16
LTF	AD2-099	2.43
937441	AD2-195 C	20.7
937442	AD2-195 E	8.92
LTF	CARR	0.06
LTF	CBM-S1	3.83
LTF	CBM-S2	7.77

<i>LTF</i>	<i>CBM-W1</i>	<i>8.54</i>
<i>LTF</i>	<i>CBM-W2</i>	<i>20.76</i>
<i>LTF</i>	<i>CIN</i>	<i>1.91</i>
<i>LTF</i>	<i>CPLE</i>	<i>2.69</i>
<i>LTF</i>	<i>G-007</i>	<i>0.46</i>
<i>LTF</i>	<i>IPL</i>	<i>1.22</i>
<i>LTF</i>	<i>LGEE</i>	<i>0.41</i>
<i>LTF</i>	<i>MEC</i>	<i>4.29</i>
<i>LTF</i>	<i>MECS</i>	<i>1.95</i>
<i>LTF</i>	<i>O-066</i>	<i>2.92</i>
<i>LTF</i>	<i>RENSSELAER</i>	<i>0.05</i>
<i>LTF</i>	<i>ROSETON</i>	<i>0.35</i>
<i>900671</i>	<i>V4-068 C</i>	<i>0.06</i>
<i>900672</i>	<i>V4-068 E</i>	<i>0.21</i>
<i>LTF</i>	<i>WEC</i>	<i>0.53</i>
<i>916041</i>	<i>Z1-036 C</i>	<i>4.68</i>
<i>916042</i>	<i>Z1-036 E</i>	<i>182.47</i>
<i>917331</i>	<i>Z2-043 C</i>	<i>0.43</i>
<i>917332</i>	<i>Z2-043 E</i>	<i>1.08</i>
<i>917341</i>	<i>Z2-044 C</i>	<i>0.16</i>
<i>917342</i>	<i>Z2-044 E</i>	<i>0.41</i>
<i>917511</i>	<i>Z2-088 C OPI</i>	<i>0.78</i>
<i>917512</i>	<i>Z2-088 E OPI</i>	<i>3.58</i>
<i>918411</i>	<i>AA1-050</i>	<i>0.66</i>
<i>918511</i>	<i>AA1-065 C OP</i>	<i>2.25</i>
<i>918512</i>	<i>AA1-065 E OP</i>	<i>6.44</i>

918531	AA1-067 C	0.35
918532	AA1-067 E	0.86
918561	AA1-072 C	0.07
918562	AA1-072 E	0.18
919691	AA2-053 C	1.16
919692	AA2-053 E	2.9
919701	AA2-057 C	0.9
919702	AA2-057 E	2.6
LTF	AA2-074	1.83
920591	AA2-165 C	0.12
920592	AA2-165 E	0.34
920671	AA2-174 C	0.05
920672	AA2-174 E	0.33
920691	AA2-178 C	31.16
920692	AA2-178 E	13.35
930051	AB1-013 C	9.4
930052	AB1-013 E	62.92
930401	AB1-081 C	6.09
930402	AB1-081 E	2.61
930861	AB1-132 C	10.01
930862	AB1-132 E	4.29
923941	AB2-035 C	0.29
923942	AB2-035 E	0.12
924151	AB2-059 C O1	7.18
924152	AB2-059 E O1	3.7
924391	AB2-088 C	0.37

924392	<i>AB2-088 E</i>	<i>0.18</i>
924491	<i>AB2-098 C</i>	<i>0.67</i>
924492	<i>AB2-098 E</i>	<i>0.29</i>
924501	<i>AB2-099 C</i>	<i>0.64</i>
924502	<i>AB2-099 E</i>	<i>0.27</i>
925121	<i>AB2-169 C</i>	<i>13.01</i>
925122	<i>AB2-169 E</i>	<i>11.67</i>
925291	<i>AB2-188 C OI</i>	<i>7.68</i>
925292	<i>AB2-188 E OI</i>	<i>3.45</i>
925591	<i>AC1-034 C</i>	<i>4.65</i>
925592	<i>AC1-034 E</i>	<i>3.51</i>
926071	<i>AC1-086 C</i>	<i>14.74</i>
926072	<i>AC1-086 E</i>	<i>6.71</i>
926201	<i>AC1-098 C</i>	<i>5.27</i>
926202	<i>AC1-098 E</i>	<i>3.14</i>
926211	<i>AC1-099 C</i>	<i>1.77</i>
926212	<i>AC1-099 E</i>	<i>1.04</i>
926771	<i>AC1-163 C</i>	<i>2.11</i>
926772	<i>AC1-163 E</i>	<i>0.99</i>
927021	<i>AC1-189 C</i>	<i>8.71</i>
927022	<i>AC1-189 E</i>	<i>4.34</i>
927141	<i>AC1-208 C</i>	<i>6.67</i>
927142	<i>AC1-208 E</i>	<i>2.96</i>

Appendix 14

(DVP - DVP) The AB2-100 TAP-6CLUBHSE 230 kV line (from bus 924510 to bus 314563 ckt 1) loads from 144.2% to 146.79% (**DC power flow**) of its load dump rating (459 MVA) for the line fault with failed breaker contingency outage of 'DVP_P4-2: 246T247'. This project contributes approximately 11.81 MW to the thermal violation.

```

CONTINGENCY 'DVP_P4-2: 246T247'                /* SUFFOLK 230 KV
  OPEN BRANCH FROM BUS 314537 TO BUS 314575 CKT 1    /* 6SUFFOLK
230.00 - 6NUCO TP 230.00
  OPEN BRANCH FROM BUS 314569 TO BUS 314575 CKT 1    /* 6EARLEYS
230.00 - 6NUCO TP 230.00
  OPEN BRANCH FROM BUS 314575 TO BUS 314590 CKT 1    /* 6NUCO TP
230.00 - 6NUCOR 230.00
  OPEN BUS 314575                                /* ISLAND: 6NUCO TP 230.00
  OPEN BUS 314590                                /* ISLAND: 6NUCOR 230.00
  OPEN BRANCH FROM BUS 314537 TO BUS 314648 CKT 1    /* 6SUFFOLK
230.00 - 6SUNBURY 230.00
  OPEN BRANCH FROM BUS 314648 TO BUS 901080 CKT 1    /* 6SUNBURY
230.00 - W1-029 230.00
  OPEN BUS 314648                                /* ISLAND: 6SUNBURY 230.00
END
  
```

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	1.86
315131	1EDGECEMA	10.47
315132	1EDGECEMB	10.47
315139	1GASTONA	6.95
315141	1GASTONB	6.95
315126	1ROARAP2	1.43
315128	1ROARAP4	1.37
315136	1ROSEMG1	4.67
315138	1ROSEMG2	2.19
315137	1ROSEMS1	2.9
314557	3BETHEL C	0.87

<i>314554</i>	<i>3BTLEBRO</i>	<i>0.84</i>
<i>314566</i>	<i>3CRESWEL</i>	<i>1.63</i>
<i>314578</i>	<i>3HORNRTN</i>	<i>3.35</i>
<i>314582</i>	<i>3KELFORD</i>	<i>0.91</i>
<i>314603</i>	<i>3SCOT NK</i>	<i>3.55</i>
<i>314617</i>	<i>3TUNIS</i>	<i>0.81</i>
<i>314541</i>	<i>3WATKINS</i>	<i>0.32</i>
<i>314620</i>	<i>6CASHIE</i>	<i>0.83</i>
<i>314574</i>	<i>6EVERETS</i>	<i>2.43</i>
<i>314594</i>	<i>6PLYMOTH</i>	<i>0.69</i>
<i>932631</i>	<i>AC2-084 C</i>	<i>9.33</i>
<i>932632</i>	<i>AC2-084 E</i>	<i>4.6</i>
<i>933991</i>	<i>AD1-023 C</i>	<i>11.94</i>
<i>933992</i>	<i>AD1-023 E</i>	<i>6.5</i>
<i>934331</i>	<i>AD1-057 C O1</i>	<i>16.08</i>
<i>934332</i>	<i>AD1-057 E O1</i>	<i>8.58</i>
<i>934521</i>	<i>AD1-076 C O1</i>	<i>45.26</i>
<i>934522</i>	<i>AD1-076 E O1</i>	<i>23.05</i>
<i>LTF</i>	<i>AD1-120</i>	<i>3.74</i>
<i>LTF</i>	<i>AD1-121</i>	<i>3.72</i>
<i>936401</i>	<i>AD2-051 C O1</i>	<i>9.84</i>
<i>936402</i>	<i>AD2-051 E O1</i>	<i>4.22</i>
<i>936531</i>	<i>AD2-068 C</i>	<i>4.66</i>
<i>936532</i>	<i>AD2-068 E</i>	<i>2.4</i>
<i>936701</i>	<i>AD2-089 C</i>	<i>7.83</i>
<i>936702</i>	<i>AD2-089 E</i>	<i>5.22</i>

936711	AD2-090 C OI	3.74
936712	AD2-090 E OI	2.5
LTF	AD2-099	2.89
937441	AD2-195 C	8.25
937442	AD2-195 E	3.56
LTF	CARR	0.09
LTF	CBM-S1	4.49
LTF	CBM-S2	9.26
LTF	CBM-W1	9.78
LTF	CBM-W2	24.29
LTF	CIN	2.19
LTF	CPL	3.18
LTF	G-007	0.61
LTF	IPL	1.4
LTF	LGEE	0.47
LTF	MEC	4.97
LTF	MECS	2.19
LTF	O-066	3.89
LTF	RENSSELAER	0.07
LTF	ROSETON	0.54
900672	V4-068 E	0.24
LTF	WEC	0.6
916042	Z1-036 E	21.79
917331	Z2-043 C	0.44
917332	Z2-043 E	1.1
917341	Z2-044 C	0.24

917342	Z2-044 E	0.61
917511	Z2-088 C OPI	0.9
917512	Z2-088 E OPI	4.12
918411	AA1-050	0.76
918491	AA1-063AC OP	1.28
918492	AA1-063AE OP	3.51
918511	AA1-065 C OP	1.86
918512	AA1-065 E OP	5.34
918531	AA1-067 C	0.29
918532	AA1-067 E	0.73
918561	AA1-072 C	0.07
918562	AA1-072 E	0.18
919691	AA2-053 C	1.55
919692	AA2-053 E	3.86
919701	AA2-057 C	1.28
919702	AA2-057 E	3.73
LTF	AA2-074	2.16
920042	AA2-088 E	6.94
920591	AA2-165 C	0.17
920592	AA2-165 E	0.49
920671	AA2-174 C	0.07
920672	AA2-174 E	0.45
920691	AA2-178 C	6.54
920692	AA2-178 E	2.8
930051	ABI-013 C	1.97
930052	ABI-013 E	13.2

930401	ABI-081 C	9.52
930402	ABI-081 E	4.08
930861	ABI-132 C	30.89
930862	ABI-132 E	13.24
923941	AB2-035 C	0.37
923942	AB2-035 E	0.16
924151	AB2-059 C OI	11.22
924152	AB2-059 E OI	5.78
924391	AB2-088 C	0.47
924392	AB2-088 E	0.23
924491	AB2-098 C	0.57
924492	AB2-098 E	0.24
924501	AB2-099 C	0.61
924502	AB2-099 E	0.26
924511	AB2-100 C	42.68
924512	AB2-100 E	21.02
925121	AB2-169 C	5.87
925122	AB2-169 E	5.27
925291	AB2-188 C OI	1.61
925292	AB2-188 E OI	0.72
925591	ACI-034 C	7.27
925592	ACI-034 E	5.48
925781	ACI-054 C	3.71
925782	ACI-054 E	1.71
926071	ACI-086 C	45.49
926072	ACI-086 E	20.7

<i>926201</i>	<i>ACI-098 C</i>	<i>6.55</i>
<i>926202</i>	<i>ACI-098 E</i>	<i>3.9</i>
<i>926211</i>	<i>ACI-099 C</i>	<i>2.19</i>
<i>926212</i>	<i>ACI-099 E</i>	<i>1.29</i>
<i>926771</i>	<i>ACI-163 C</i>	<i>2.03</i>
<i>926772</i>	<i>ACI-163 E</i>	<i>0.95</i>
<i>927021</i>	<i>ACI-189 C</i>	<i>8.99</i>
<i>927022</i>	<i>ACI-189 E</i>	<i>4.48</i>
<i>927141</i>	<i>ACI-208 C</i>	<i>9.41</i>
<i>927142</i>	<i>ACI-208 E</i>	<i>4.18</i>

Appendix 15

(DVP - DVP) The AB2-169 TAP-3FIVE PT 115 kV line (from bus 925120 to bus 314576 ckt 1) loads from 137.51% to 165.79% (**DC power flow**) of its load dump rating (91 MVA) for the tower line contingency outage of 'DVP_P7-1: LN 25-2034_A'. This project contributes approximately 25.73 MW to the thermal violation.

```

CONTINGENCY 'DVP_P7-1: LN 25-2034_A'                /*REPLACED ON
4/19/2016
  OPEN BRANCH FROM BUS 314573 TO BUS 314596 CKT 1    /* 3EVERETS
115.00 - 3POPLR C 115.00
  OPEN BRANCH FROM BUS 314596 TO BUS 314614 CKT 1    /* 3POPLR C
115.00 - 3TROWBR2 115.00
  OPEN BUS 314596                                     /* ISLAND
  OPEN BRANCH FROM BUS 314569 TO BUS 314620 CKT 1    /* 6EARLEYS
230.00 - 6CASHIE 230.00
  OPEN BRANCH FROM BUS 314614 TO BUS 314616 CKT 1    /* 3TROWBR2
115.00 - 6TRWBRDG 230.00
  OPEN BRANCH FROM BUS 314616 TO BUS 933990 CKT 1    /* 6TRWBRDG
230.00 - AD1-023 TAP 230.00
END
  
```

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	2.78
315292	1DOMTR78	1.88
315293	1DOMTR9	1.53
314566	3CRESWEL	1.3
314594	6PLYMOTH	0.56
934521	AD1-076 C O1	37.19
934522	AD1-076 E O1	18.94
937441	AD2-195 C	17.98
937442	AD2-195 E	7.75
LTF	AMIL	0.06
LTF	BAYOU	0.31
LTF	BIG_CAJUNI	0.49

<i>LTF</i>	<i>BIG_CAJUN2</i>	<i>0.98</i>
<i>LTF</i>	<i>BLUEG</i>	<i>0.31</i>
<i>LTF</i>	<i>CALDERWOOD</i>	<i>0.18</i>
<i>LTF</i>	<i>CANNELTON</i>	<i>0.06</i>
<i>LTF</i>	<i>CARR</i>	<i>< 0.01</i>
<i>LTF</i>	<i>CATAWBA</i>	<i>0.17</i>
<i>LTF</i>	<i>CELEVELAND</i>	<i>0.49</i>
<i>LTF</i>	<i>CHEOAH</i>	<i>0.17</i>
<i>LTF</i>	<i>CHILHOWEE</i>	<i>0.06</i>
<i>LTF</i>	<i>CHOCTAW</i>	<i>0.33</i>
<i>LTF</i>	<i>CLIFTY</i>	<i>1.12</i>
<i>LTF</i>	<i>COTTONWOOD</i>	<i>1.21</i>
<i>LTF</i>	<i>DEARBORN</i>	<i>0.11</i>
<i>LTF</i>	<i>EDWARDS</i>	<i>0.09</i>
<i>LTF</i>	<i>ELMERSMITH</i>	<i>0.17</i>
<i>LTF</i>	<i>FARMERCITY</i>	<i>0.07</i>
<i>LTF</i>	<i>G-007A</i>	<i>0.11</i>
<i>LTF</i>	<i>GIBSON</i>	<i>0.11</i>
<i>LTF</i>	<i>HAMLET</i>	<i>0.72</i>
<i>LTF</i>	<i>MORGAN</i>	<i>0.53</i>
<i>LTF</i>	<i>NEWTON</i>	<i>0.26</i>
<i>LTF</i>	<i>PRAIRIE</i>	<i>0.56</i>
<i>LTF</i>	<i>RENSSELAER</i>	<i>< 0.01</i>
<i>LTF</i>	<i>ROSETON</i>	<i>< 0.01</i>
<i>LTF</i>	<i>ROWAN</i>	<i>0.35</i>
<i>LTF</i>	<i>SANTEETLA</i>	<i>0.05</i>

<i>LTF</i>	<i>SMITHLAND</i>	<i>0.05</i>
<i>LTF</i>	<i>TATANKA</i>	<i>0.13</i>
<i>LTF</i>	<i>TILTON</i>	<i>0.11</i>
<i>LTF</i>	<i>TRIMBLE</i>	<i>0.06</i>
<i>LTF</i>	<i>TVA</i>	<i>0.22</i>
<i>LTF</i>	<i>UNIONPOWER</i>	<i>0.32</i>
<i>LTF</i>	<i>VFT</i>	<i>0.29</i>
<i>916042</i>	<i>Z1-036 E</i>	<i>16.14</i>
<i>920691</i>	<i>AA2-178 C</i>	<i>5.21</i>
<i>920692</i>	<i>AA2-178 E</i>	<i>2.23</i>
<i>930051</i>	<i>AB1-013 C</i>	<i>1.57</i>
<i>930052</i>	<i>AB1-013 E</i>	<i>10.53</i>
<i>925121</i>	<i>AB2-169 C</i>	<i>19.</i>
<i>925122</i>	<i>AB2-169 E</i>	<i>17.05</i>
<i>925281</i>	<i>AB2-186 C</i>	<i>0.2</i>
<i>925282</i>	<i>AB2-186 E</i>	<i>0.08</i>
<i>925291</i>	<i>AB2-188 C O1</i>	<i>1.28</i>
<i>925292</i>	<i>AB2-188 E O1</i>	<i>0.58</i>

Appendix 16

(DVP - CPLE) The AD2-068 TAP-6GREENVILE T 230 kV line (from bus 936530 to bus 304451 ckt 1) loads from 141.91% to 145.76% (**DC power flow**) of its emergency rating (478 MVA) for the tower line contingency outage of 'DVP_P7-1: LN 2058-2181'. This project contributes approximately 18.41 MW to the thermal violation.

CONTINGENCY 'DVP_P7-1: LN 2058-2181'

OPEN BRANCH FROM BUS 304222 TO BUS 313845 CKT 1 /*

6ROCKYMT230T230.00 - 6HATHAWAY 230.00

OPEN BUS 304226 /* ISLAND: 6PA-RMOUNT#4115.00

OPEN BRANCH FROM BUS 304226 TO BUS 314591 CKT 1 /* 6PA-

RMOUNT#4230.00 - 6NASH 230.00

OPEN BRANCH FROM BUS 313845 TO BUS 314591 CKT 1 /* 6HATHAWAY
230.00 - 6NASH 230.00

OPEN BUS 314591 /* ISLAND: 6NASH 230.00

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
315294	1DOMTR10	2.74
315292	1DOMTR78	1.85
315293	1DOMTR9	1.51
315131	1EDGECEMA	9.28
315132	1EDGECEMB	9.28
315136	1ROSEMG1	1.74
315138	1ROSEMG2	0.81
315137	1ROSEMS1	1.08
314557	3BETHEL	1.14
314554	3BTLEBRO	0.43
314566	3CRESWEL	2.04
314572	3EMPORIA	0.21
314578	3HORNRTN	2.04
314582	3KELFORD	0.72

314603	3SCOT NK	2.51
314617	3TUNIS	0.7
314539	3UNCAMP	1.18
314541	3WATKINS	0.36
314620	6CASHIE	0.88
314574	6EVERETS	5.39
314594	6PLYMOTH	0.83
314648	6SUNBURY	0.4
314651	6WINFALL	0.97
932631	AC2-084 C	6.16
932632	AC2-084 E	3.04
933991	AD1-023 C	13.46
933992	AD1-023 E	7.33
934201	AD1-047 C	4.28
934202	AD1-047 E	2.86
934331	AD1-057 C O1	8.8
934332	AD1-057 E O1	4.69
934521	AD1-076 C O1	54.73
934522	AD1-076 E O1	27.87
936401	AD2-051 C O1	8.4
936402	AD2-051 E O1	3.61
936531	AD2-068 C	17.02
936532	AD2-068 E	8.77
936701	AD2-089 C	10.3
936702	AD2-089 E	6.87
936711	AD2-090 C O1	3.91

936712	AD2-090 E O1	2.61
937441	AD2-195 C	12.87
937442	AD2-195 E	5.55
LTF	AMIL	0.48
LTF	BAYOU	2.64
LTF	BIG_CAJUN1	4.17
LTF	BIG_CAJUN2	8.38
LTF	BLUEG	2.5
LTF	CALDERWOOD	1.54
LTF	CANNELTON	0.48
LTF	CATAWBA	1.51
LTF	CBM-N	< 0.01
LTF	CELEVELAND	4.27
LTF	CHEOAH	1.44
LTF	CHILHOWEE	0.5
LTF	CHOCTAW	2.84
LTF	CLIFTY	9.04
LTF	COTTONWOOD	10.32
LTF	DEARBORN	0.89
LTF	EDWARDS	0.78
LTF	ELMERSMITH	1.41
LTF	FARMERCITY	0.62
LTF	G-007A	1.04
LTF	GIBSON	0.88
LTF	HAMLET	6.47
LTF	MORGAN	4.57

<i>LTF</i>	<i>NEWTON</i>	<i>2.15</i>
<i>LTF</i>	<i>NYISO</i>	<i>0.06</i>
<i>LTF</i>	<i>PRAIRIE</i>	<i>4.68</i>
<i>LTF</i>	<i>ROWAN</i>	<i>2.99</i>
<i>LTF</i>	<i>SANTEETLA</i>	<i>0.43</i>
<i>LTF</i>	<i>SMITHLAND</i>	<i>0.42</i>
<i>LTF</i>	<i>TATANKA</i>	<i>1.05</i>
<i>LTF</i>	<i>TILTON</i>	<i>0.92</i>
<i>LTF</i>	<i>TRIMBLE</i>	<i>0.47</i>
<i>LTF</i>	<i>TVA</i>	<i>1.92</i>
<i>LTF</i>	<i>UNIONPOWER</i>	<i>2.74</i>
<i>900672</i>	<i>V4-068 E</i>	<i>0.21</i>
<i>LTF</i>	<i>VFT</i>	<i>2.76</i>
<i>901082</i>	<i>W1-029E</i>	<i>23.37</i>
<i>907092</i>	<i>X1-038 E</i>	<i>2.96</i>
<i>913392</i>	<i>Y1-086 E</i>	<i>1.05</i>
<i>916042</i>	<i>Z1-036 E</i>	<i>29.11</i>
<i>917122</i>	<i>Z2-027 E</i>	<i>0.51</i>
<i>917331</i>	<i>Z2-043 C</i>	<i>0.34</i>
<i>917332</i>	<i>Z2-043 E</i>	<i>0.86</i>
<i>917342</i>	<i>Z2-044 E</i>	<i>0.33</i>
<i>917511</i>	<i>Z2-088 C OPI</i>	<i>1.33</i>
<i>917512</i>	<i>Z2-088 E OPI</i>	<i>6.13</i>
<i>918411</i>	<i>AA1-050</i>	<i>1.12</i>
<i>918492</i>	<i>AA1-063AE OP</i>	<i>2.44</i>
<i>918511</i>	<i>AA1-065 C OP</i>	<i>1.69</i>

918512	AA1-065 E OP	4.84
918531	AA1-067 C	0.65
918532	AA1-067 E	1.62
918561	AA1-072 C	0.05
918562	AA1-072 E	0.14
919692	AA2-053 E	2.58
919702	AA2-057 E	2.12
920042	AA2-088 E	6.24
920592	AA2-165 E	0.28
920672	AA2-174 E	0.3
920691	AA2-178 C	8.16
920692	AA2-178 E	3.5
930051	AB1-013 C	2.46
930052	AB1-013 E	16.47
930401	AB1-081 C	5.63
930402	AB1-081 E	2.41
930861	AB1-132 C	10.35
930862	AB1-132 E	4.44
931231	AB1-173 C	1.21
931232	AB1-173 E	0.56
931241	AB1-173AC	1.21
931242	AB1-173AE	0.56
923801	AB2-015 C OI	4.39
923802	AB2-015 E OI	3.6
923831	AB2-022 C	1.02
923832	AB2-022 E	0.55

923911	AB2-031 C OI	1.2
923912	AB2-031 E OI	0.59
923941	AB2-035 C	0.48
923942	AB2-035 E	0.21
923991	AB2-040 C OI	3.93
923992	AB2-040 E OI	3.21
924151	AB2-059 C OI	6.64
924152	AB2-059 E OI	3.42
924391	AB2-088 C	0.62
924392	AB2-088 E	0.3
924491	AB2-098 C	1.26
924492	AB2-098 E	0.54
924501	AB2-099 C	0.53
924502	AB2-099 E	0.23
924511	AB2-100 C	5.85
924512	AB2-100 E	2.88
925121	AB2-169 C	10.01
925122	AB2-169 E	8.99
925171	AB2-174 C OI	3.64
925172	AB2-174 E OI	3.29
925281	AB2-186 C	0.37
925282	AB2-186 E	0.16
925291	AB2-188 C OI	2.01
925292	AB2-188 E OI	0.9
925591	ACI-034 C	4.3
925592	ACI-034 E	3.24

<i>926071</i>	<i>ACI-086 C</i>	<i>15.25</i>
<i>926072</i>	<i>ACI-086 E</i>	<i>6.94</i>
<i>926201</i>	<i>ACI-098 C</i>	<i>4.32</i>
<i>926202</i>	<i>ACI-098 E</i>	<i>2.58</i>
<i>926211</i>	<i>ACI-099 C</i>	<i>1.45</i>
<i>926212</i>	<i>ACI-099 E</i>	<i>0.85</i>
<i>LTF</i>	<i>ACI-133</i>	<i>22.48</i>
<i>926771</i>	<i>ACI-163 C</i>	<i>1.74</i>
<i>926772</i>	<i>ACI-163 E</i>	<i>0.81</i>
<i>927021</i>	<i>ACI-189 C</i>	<i>15.45</i>
<i>927022</i>	<i>ACI-189 E</i>	<i>7.7</i>
<i>927141</i>	<i>ACI-208 C</i>	<i>5.74</i>
<i>927142</i>	<i>ACI-208 E</i>	<i>2.55</i>