



**Generation Interconnection
Feasibility Study Report
for
Queue Project AE1-172
LORETTO-WILTON CENTER
52.8 MW Capacity / 300 MW Energy**

June, 2019

Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model.

The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

The conduct of light load analysis as well as Affected Systems as required under the PJM planning process is not performed during the Generation Interconnection Feasibility Study phase of the PJM study process. Additional reinforcement requirements for this Interconnection Request may be defined during the conduct of the System Impact Study.

General

The Interconnection Customer (IC) has proposed a Wind generating facility located in Livingston County, Illinois. The installed facilities will have a total capability of 300 MW with 52.5 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is 10/01/2021. This study does not imply a TO commitment to this in-service date.

Queue Number	AE1-172
Project Name	LORETTO-WILTON CENTER
State	None
County	Livingston
Transmission Owner	ComEd
MFO	300
MWE	300
MWC	52.8
Fuel	Wind
Basecase Study Year	2022

Primary Point of Interconnection

Queue Position AE1-172, a 300 MW wind farm, proposes to interconnect with the ComEd transmission system by tying into the Loretto-Wilton Center 345kV Line 11212, approximately 6.5 miles from Loretto TSS 93.

Cost Summary

The AE1-172 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$ 1,000,000
Direct Connection Network Upgrade	\$23,000,000
Non Direct Connection Network Upgrades	\$ 2,000,000
Total Costs	\$26,000,000

In addition, the AE1-172 project may be responsible for a contribution to the following costs (see later sections of this report.

Description	Total Cost
System Upgrades	\$108,768,120


Cost allocations for these upgrades will be provided in the System Impact Study Report.

Interconnected Transmission Owner Scope of Work

Attachment Facilities

The AE1-172 generator lead would interconnect to a new 345kV Interconnection Substation (see details in Direct Connection section below). The required Attachment Facilities are one 345kV line MOD, a dead-end structure and revenue metering as shown in the one-line diagram.

Scope of Work	Cost Estimate
Installation of one 345kV line MOD, one dead-end structure and one set of revenue metering (see notes below on cost estimate)	\$1,000,000



Direct Connection Cost Estimate

In order to accommodate interconnection of AE1-172, a new 345kV Interconnection Substation would need to be built close to the Loretto-Wilton Center 345kV Line 11212, approximately 6.5 miles from Loretto TSS 93.

The scope of work includes the installation of three 345kV circuit breakers in a “breaker-and-a-half” bus configuration and cutting in the Interconnection Substation to Loretto-Wilton Center 345kV Line 11212, as shown in the one-line diagram below.

The Interconnection Customer (“IC”) is responsible for constructing all of the facilities on the IC side of the Point of Interconnection (“POI”). It is assumed for the purposes of this report that the IC will obtain the site for the Interconnection Substation and right-of-way between the Interconnection Substation and the 345kV transmission line.

In the event that the IC exercises the option to build the Interconnecting Substation, the IC will be required to construct all interconnection facilities that will be turned over to ComEd in accordance with ComEd published standards and the PJM Tariff.

ComEd would design, engineer and construct the tie in of the Interconnection Substation to the Loretto-Wilton Center 345kV Line 11212.

The preliminary cost estimate for Direct Connection Network Upgrade is given in the following tables.

For Option to Build Direct Connection cost estimates:

Scope of Work	Cost Estimate
Installation of a new 345kV substation as described above	N/A
Transmission line tie in work (foundations, structures, conductors)	\$ 3,000,000
ComEd oversight and testing	\$ 1,500,000
Total Cost Estimate (see notes below on cost estimate)	\$ 4,500,000

For ComEd building the interconnecting substation cost estimates:

Scope of Work	Cost Estimate
Installation of a new 345kV substation as described above	\$ 20,000,000
Transmission line tie in work (foundations, structures, conductors)	\$ 3,000,000
Total Cost Estimate (see notes below on cost estimate)	\$ 23,000,000

Non-Direct Connection Cost Estimate

The integration of the new 345kV Interconnection Substation would require relay/communications/SCADA upgrades at the Loretto TSS 93 and Wilton Center TSS 112. The ComEd cost is given below:

Scope of Work	Cost Estimate
Relay/communications/SCADA upgrades at Loretto TSS 93	\$ 1,000,000
Relay/communications/SCADA upgrades at Wilton Center TSS 112	\$ 1,000,000
Total Cost Estimate (see notes below on cost estimate)	\$ 2,000,000

Schedule

ComEd would take approximately 24-months to construct the substation and transmission line work after the ISA / ICSA are signed.

Transmission Owner Analysis

Notes on Cost Estimate:

- 1) These estimates are Order-of-Magnitude estimates of the costs that ComEd would bill to the customer for this interconnection. These estimates are based on a one-line electrical diagram of the project and the information provided by the Interconnection Customer.
- 2) There were no site visits performed for these estimates. There may be costs related to specific site related issues that are not identified in these estimates. The site reviews will be performed during the Facilities Study or during detailed engineering.
- 3) These estimates are not a guarantee of the maximum amount payable by the Interconnection Customer and the actual costs of ComEd's work may differ significantly from these estimates. Interconnection Customer will be responsible for paying actual costs of ComEd's work in accordance with Sections 212.1 and 217 of the PJM Open Access Transmission Tariff.
- 4) The Interconnection Customer is responsible for all engineering, procurement, testing and construction of all equipment on the Interconnection Customer's side of the POI.
- 5) These cost estimates do not include cost of acquiring right-of-way for the transmission line and purchasing any additional land, if needed, for the line terminations. The need and cost for acquiring property and associated legal costs will be investigation during Facilities Study for this project.

Interconnection Customer Requirements

Exelon Utilities Transmission Bus Configuration Design Philosophy, ComEd Interconnection Guidelines, and Exelon Utilities Transmission Facility Interconnection Requirements shall apply. They are available on the PJM website. To the extent that these Applicable Technical Requirements and Standards conflict with the terms and conditions of the Tariff, the Tariff shall control.

Revenue Metering and SCADA Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

Primary Point of Interconnection Network Impacts

The Queue Project AE1-172 was evaluated as a 300 MW (Capacity 52.8 MW) injection tapping the Loretto; B to Wilton; B 345 kV line in the ComEd area. Project AE1-172 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE1-172 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Load Flow

Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
172794	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P4_#8805_05OLIVE 345_D	breaker	4105.0	97.23	97.87	DC	87.74
779808	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P4_#8805_05OLIVE 345_D	breaker	4105.0	97.23	97.87	DC	87.74
172710	270717	DRESDEN ; R	CE	270697	COLLINS ; R	CE	1	COMED_P4_111-45-L1223T_	breaker	1528.0	100.03	100.59	DC	18.79
173966	925880	AC1-067 TAP	CE	270675	BURNHAM ;1R	CE	1	COMED_P7_345-L2001_B-S+_345-L2003_R-S	tower	1768.0	99.81	100.23	DC	16.27

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
----	-----------	----------	---------------	---------	--------	-------------	--------	-----------	------	------------	-----------------------	------------------------	-------	-----------

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC/D C	MW IMPACT
779505	243918	05ELDERBRYSS	AEP	938670	AE1-089 TAP	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	117.39	118.06	DC	21.09
779506	243918	05ELDERBRYSS	AEP	938670	AE1-089 TAP	AEP	1	COMED_P4_112-65-BT4-5	breaker	1409.0	108.45	108.98	DC	22.47
779507	243918	05ELDERBRYSS	AEP	938670	AE1-089 TAP	AEP	1	COMED_P4_112-65-BT3-4	breaker	1409.0	108.45	108.98	DC	22.47
779508	243918	05ELDERBRYSS	AEP	938670	AE1-089 TAP	AEP	1	COMED_P4_023-65-BT2-3	breaker	1409.0	108.45	108.98	DC	22.46
172683	255104	17GREEN_ACRE	NIPS	270771	GREENACRE; T	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	103.27	103.92	DC	23.27
172512	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	109.01	109.87	DC	25.31
172513	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_023-65-BT2-3	breaker	1091.0	111.32	112.12	DC	25.42
172514	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_112-65-BT4-5	breaker	1091.0	109.21	110.07	DC	25.45
172515	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_112-65-BT3-4	breaker	1091.0	109.21	110.06	DC	25.45
779180	255113	17STILLWELL	NIPS	243219	05DUMONT	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	173.76	174.49	DC	40.94
173879	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L94507_B-S_+ 345-L97008_R-S	tower	4105.0	103.83	104.37	DC	94.14
173880	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L6607_B-S_+ 345-L97008_R-S	tower	4105.0	103.06	103.66	DC	94.27
781033	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L94507_B-S_+ 345-L97008_R-S	tower	4105.0	103.83	104.37	DC	94.14
781034	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L6607_B-S_+ 345-L97008_R-S	tower	4105.0	103.06	103.66	DC	94.27
172688	270677	BURNHAM ;OR	CE	255109	17MUNSTER	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1441.0	113.05	113.71	DC	35.12
172671	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	111.15	112.1	DC	35.54
172672	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	COMED_P4_023-65-BT2-3	breaker	1399.0	110.8	111.73	DC	35.59
172673	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	COMED_P4_112-65-BT4-5	breaker	1399.0	110.72	111.65	DC	35.65
172674	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	COMED_P4_112-65-BT3-4	breaker	1399.0	110.72	111.65	DC	35.65
172554	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	116.01	116.74	DC	23.27
779444	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	116.01	116.74	DC	23.27
173042	270853	PONTIAC ; R	CE	935000	AD1-133 TAP	CE	1	COMED_P1-2_345-L11212_B-S-C-A	single	1528.0	100.37	101.98	DC	24.59
172517	270886	ST JOHN ; T	CE	255104	17GREEN_ACRE	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	109.01	109.87	DC	25.31
172518	270886	ST JOHN ; T	CE	255104	17GREEN_ACRE	NIPS	1	COMED_P4_023-65-BT2-3	breaker	1091.0	111.32	112.12	DC	25.42
172519	270886	ST JOHN ; T	CE	255104	17GREEN_ACRE	NIPS	1	COMED_P4_112-65-BT4-5	breaker	1091.0	109.21	110.07	DC	25.45
172520	270886	ST JOHN ; T	CE	255104	17GREEN_ACRE	NIPS	1	COMED_P4_112-65-BT3-4	breaker	1091.0	109.21	110.06	DC	25.45
172378	270926	WILTON ; B	CE	275232	WILTON ;3M	CE	1	COMED_P4_112-65-BT5-6	breaker	1379.0	166.14	166.79	DC	54.08
172380	270927	WILTON ; R	CE	275233	WILTON ;4M	CE	1	COMED_P4_112-65-BT2-3	breaker	1379.0	164.04	164.99	DC	55.15
172410	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	124.43	125.44	DC	35.06
172411	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	COMED_P4_023-65-BT2-3	breaker	1399.0	123.84	124.86	DC	35.11
172412	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	COMED_P4_112-65-BT4-5	breaker	1399.0	123.78	124.8	DC	35.17

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC/D C	MW IMPACT
172413	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	COMED_P4_112-65-BT3-4	breaker	1399.0	123.78	124.8	DC	35.17
172467	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	134.98	135.93	DC	27.88
172468	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT2-3	breaker	971.0	132.95	133.99	DC	28.04
172469	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT4-5	breaker	971.0	133.75	134.71	DC	28.05
172470	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT3-4	breaker	971.0	133.75	134.71	DC	28.05
172471	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT4-5	breaker	971.0	133.74	134.7	DC	28.06
779313	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	134.98	135.93	DC	27.88
779314	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT2-3	breaker	971.0	132.95	133.99	DC	28.04
779315	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT4-5	breaker	971.0	133.75	134.71	DC	28.05
779316	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT3-4	breaker	971.0	133.75	134.71	DC	28.05
779317	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT4-5	breaker	971.0	133.74	134.7	DC	28.06
172377	275232	WILTON ;3M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT5-6	breaker	1379.0	166.14	166.79	DC	54.08
172382	275233	WILTON ;4M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT2-3	breaker	1379.0	164.04	164.99	DC	55.15
779280	346809	7CASEY	AMIL	247712	05SULLIVAN	AEP	1	AEP_P4_#3128_05EUGENE 345_A2	breaker	1466.0	143.6	144.31	DC	22.83
779753	932800	AC2-104 TAP	AEP	242928	05MARYSV	AEP	1	AEP_P4_#7334_05JEFRSOT 765_A2	breaker	4571.0	103.34	103.44	DC	75.35
173716	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	COMED_P7_345-L17704AR-S_+ 345-L17907TB-S-A	tower	1846.0	138.35	143.05	DC	86.71
173717	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	COMED_P7_345-L2001_B-S_+ 345-L2003_R-S	tower	1846.0	135.55	140.46	DC	90.56
173016	935000	AD1-133 TAP	CE	270717	DRESDEN ; R	CE	1	COMED_P1-2_345-L11212_B-S-C-A	single	1528.0	108.11	109.72	DC	24.59
173690	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	COMED_P7_345-L17704AR-S_+ 345-L17907TB-S-A	tower	1846.0	145.54	150.23	DC	86.71
173691	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	COMED_P7_345-L2001_B-S_+ 345-L2003_R-S	tower	1846.0	143.09	147.99	DC	90.56
779430	938670	AE1-089 TAP	AEP	243219	05DUMONT	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	125.76	126.44	DC	21.09
172973	939400	AE1-172 TAP	CE	934720	AD1-100 TAP	CE	1	COMED_P1-2_345-L8014__-S-B	single	1528.0	113.38	115.71	DC	35.5
172974	939400	AE1-172 TAP	CE	934720	AD1-100 TAP	CE	1	COMED_P1-2_345-L8014__-S-A	single	1528.0	108.06	110.39	DC	35.5

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
780469	243918	05ELDERBRYSS	AEP	938670	AE1-089 TAP	AEP	1	AEP_P1-2_#695A	operation	1409.0	108.44	108.98	DC	22.47
173414	255104	17GREEN_ACRE	NIPS	270771	GREENACRE; T	CE	1	AEP_P1-2_#695A	operation	1091.0	101.99	102.64	DC	23.48
173220	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	AEP_P1-2_#695A	operation	1091.0	109.2	110.05	DC	25.46
780004	255113	17STILLWELL	NIPS	243219	05DUMONT	AEP	1	AEP_P1-2_#695A	operation	1409.0	170.25	171.01	DC	41.8
780010	255113	17STILLWELL	NIPS	243219	05DUMONT	AEP	1	Base Case	operation	1409.0	111.19	111.61	DC	22.68
173470	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	Base Case	operation	3555.0	105.87	106.39	DC	81.9
173471	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P1-2_#697A	operation	4105.0	97.2	97.84	DC	87.77
780533	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	Base Case	operation	3555.0	105.87	106.39	DC	81.9
780534	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P1-2_#697A	operation	4105.0	97.2	97.84	DC	87.77
173413	270677	BURNHAM ;OR	CE	255109	17MUNSTER	NIPS	1	AEP_P1-2_#695A	operation	1441.0	112.22	112.88	DC	35.3
173423	270717	DRESDEN ; R	CE	270697	COLLINS ; R	CE	1	COMED_P1-2_345-L1223_TR-S	operation	1528.0	99.89	100.45	DC	18.87
173381	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	AEP_P1-2_#695A	operation	1399.0	110.68	111.61	DC	35.68
173269	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	114.57	115.3	DC	23.48
780249	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	114.57	115.3	DC	23.48
173302	270796	KINCAID ; B	CE	347955	7AUSTIN	AMIL	1	COMED_P1-2_345-L11212_B-S-C-A	operation	956.0	117.43	121.56	DC	39.74
173037	270853	PONTIAC ; R	CE	935000	AD1-133 TAP	CE	1	COMED_P1-2_345-L11212_B-S-C-A	operation	1528.0	174.88	184.03	DC	139.69
173041	270853	PONTIAC ; R	CE	935000	AD1-133 TAP	CE	1	Base Case	operation	1334.0	120.62	124.03	DC	45.48
173216	270886	ST JOHN ; T	CE	255104	17GREEN_ACRE	NIPS	1	AEP_P1-2_#695A	operation	1091.0	109.2	110.05	DC	25.46
173495	270926	WILTON ; B	CE	275232	WILTON ;3M	CE	1	COMED_P1-2_765-L11216_-S	operation	1379.0	104.3	104.71	DC	34.0
173469	270927	WILTON ; R	CE	275233	WILTON ;4M	CE	1	COMED_P1-2_765-L11216_-S	operation	1379.0	105.79	106.4	DC	35.52
173138	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	AEP_P1-2_#695A	operation	1399.0	123.74	124.76	DC	35.2
173202	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	133.74	134.7	DC	28.06
780174	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	133.74	134.7	DC	28.06
780168	346809	7CASEY	AMIL	247712	05SULLIVAN	AEP	1	AEP_P1-2_#286	operation	1466.0	137.93	138.66	DC	23.22
780169	346809	7CASEY	AMIL	247712	05SULLIVAN	AEP	1	Base Case	operation	1334.0	122.12	122.74	DC	18.01
780643	348885	7BUNSONVILLE	AMIL	243221	05EUGENE	AEP	1	AEP_P1-2_#8907	operation	1793.0	101.23	101.7	DC	24.64
173133	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	COMED_P1-2_345-L8014_-S-B	operation	1528.0	152.43	158.48	DC	92.45
173137	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	Base Case	operation	1364.0	135.19	141.16	DC	81.35

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
173515	934730	AD1-100 TAP	CE	270670	BRAIDWOOD; B	CE	1	COMED_P1-2_345-L11212_B-S-A	operation	1528.0	89.65	96.89	DC	110.59
173011	935000	AD1-133 TAP	CE	270717	DRESDEN ; R	CE	1	COMED_P1-2_345-L11212_B-S-C-A	operation	1528.0	187.88	197.03	DC	139.69
173014	935000	AD1-133 TAP	CE	270717	DRESDEN ; R	CE	1	Base Case	operation	1334.0	133.29	136.7	DC	45.48
173096	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	COMED_P1-2_345-L8014__-S-B	operation	1528.0	159.13	165.18	DC	92.45
173100	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	Base Case	operation	1364.0	145.09	151.06	DC	81.35
780332	938670	AE1-089 TAP	AEP	243219	05DUMONT	AEP	1	AEP_P1-2_#695A	operation	1409.0	116.6	117.32	DC	22.47
172968	939400	AE1-172 TAP	CE	934720	AD1-100 TAP	CE	1	COMED_P1-2_345-L8014__-S-B	operation	1528.0	199.8	213.0	DC	201.7
172970	939400	AE1-172 TAP	CE	934720	AD1-100 TAP	CE	1	Base Case	operation	1364.0	149.2	162.08	DC	175.68

System Reinforcements

ID	Index	Facility	Upgrade Description	Cost
172382	18	WILTON ;4M 345.0 kV - WILTON ; 765.0 kV Ckt 1	<u>CE</u> Description : PJM network upgrade n5145: Reconfigure Wilton 765kV bus thereby allowing for 765kV L11216 (currently on Bus 6) to be relocated to Bus 8. Along with this line relocation, installation of 2-765kV BT CB's (6-8 & 8-2). The baseline project has an projected in-service date of 06/30/2019. Time Estimate : 36.0 Months Cost : \$ 11,000,000	\$11,000,000
172377	17	WILTON ;3M 345.0 kV - WILTON ; 765.0 kV Ckt 1		
172380	14	WILTON ; R 345.0 kV - WILTON ;4M 345.0 kV Ckt 1		
172378	13	WILTON ; B 345.0 kV - WILTON ;3M 345.0 kV Ckt 1		
172688	8	BURNHAM ;0R 345.0 kV - 17MUNSTER 345.0 kV Ckt 1	<u>CE</u> Description : Line conductor & station conductor upgrades. (Note that there may be additional 345kV line tower costs as a result of this upgrade. This estimate does not include potential tower work. The tower costs will be determined during the Facility Study). Time Estimate : 36.0 Months Cost : \$9,200,000 <u>NIPS</u> Description : The external (i.e. Non-PJM) Transmission Owner, NIPS, will not evaluate this violation until the impact study phase.	\$9,200,000
172520,172517,172518,172519	12	ST JOHN ; T 345.0 kV - 17GREEN_ACRE 345.0 kV Ckt 1	<u>CE</u> Description : The upgrade will be to mitigate the sag on the line. Note, the estimate provided does not include potential transmission tower pole upgrades. This cost will be determined during the Facilities Studies. Time Estimate : 24-30 Months Cost : \$2,600,000 <u>NIPS</u> Description : The external (i.e. Non-PJM) Transmission Owner, NIPS, will not evaluate this violation until the impact study phase	\$2,600,000
172512,172513,172514,172515	6	17STJOHN 345.0 kV - ST JOHN ; T 345.0 kV Ckt 1		
173042	11	PONTIAC ; R 345.0 kV - AD1-133 TAP 345.0 kV Ckt 1	<u>CE</u> Description : No Violation. The SSTE rating is 1797 MVA.	\$0

ID	Index	Facility	Upgrade Description	Cost
172672,172673,172674,172671	9	E FRANKFO; B 345.0 kV - CRETE EC ;BP 345.0 kV Ckt 1	<u>CE</u> Description : Line conductoring upgrade. Note that there may be additional 345kV line tower costs as a result of this upgrade. This estimate does not include potential tower work. The tower costs will be determined during the Facility Study. Time Estimate : 30.0 Months Cost : \$14,400,000	\$14,400,000
779808,781033,781034,173879,173880,172794	1	WILTON ; 765.0 kV - 05DUMONT 765.0 kV Ckt 1	<u>CE</u> Description : No Violation. The SLD rating is 4802 MVA. <u>AEP</u> Description : 1) Replace Dumont Circuit Breaker [Breaker (3000A) Non oil - Dumont] Time Estimate : 24-36 Months Cost : \$3,000,000	\$3,000,000
173690,173691	23	AD2-137 TAP 345.0 kV - WILTON ; B 345.0 kV Ckt 1	<u>CE</u> Description : Replace 2-345kV circuit breakers and station conductor @ Wilton Center, Reconductor 5 miles, replace 1 MOD, relay upgrade. Time Estimate : 36.0 Months Cost : \$15,600,000	\$15,600,000
173016	22	AD1-133 TAP 345.0 kV - DRESDEN ; R 345.0 kV Ckt 1	<u>CE</u> Description : No Violation. The SSTE rating is 1797 MVA.	\$0
779315,779313,779314,172467,172468,172469,172470,172471,779316,779317	16	UNIV PK N;RP 345.0 kV - 05OLIVE 345.0 kV Ckt 1	<u>CE</u> Description : Line sag mitigation. Note that there may be additional 345kV line tower costs as a result of this upgrade. This estimate does not include potential tower work. The tower costs will be determined during the Facility Study Time Estimate : 24-30 Months Cost : \$13,800,000 <u>AEP</u> Description : 1) A Sag Study will be required on the 40.64 miles of ACSR/PE 1414 62/19 conductor to mitigate the overload. The new ratings after sag study will be: S/N: 971 MVA, S/E: 1419 MVA, Depending on the sag study results, the cost for this upgrade is expected to be between \$162,560 (no remediation required, just sag study) and \$81.28 million (complete line Reconductor/rebuild). Time Estimate: a) Sag Study: 6-12 months b) Rebuild: The standard time required for construction differs from state to state. An approximate construction time would be 24 to 36 months after signing an interconnection agreement. 2) Replace 5 Jumpers (Sub cond 2156 ACSR 84/19 STD at Olive station, estimated cost : \$175,000 Time Estimate : 6-12 Months Cost : \$337,560	\$14,137,560

ID	Index	Facility	Upgrade Description	Cost
172683	5	17GREEN_ACRE 345.0 kV - GREENACRE; T 345.0 kV Ckt 1	<u>CE</u> Description : No Violation. The SSTE rating is 1134 MVA. <u>NIPS</u> Description : The external (i.e. Non-PJM) Transmission Owner, NIPS, will not evaluate this violation until the impact study phase.	\$0
172410,172411,172412,172413	15	CRETE EC ;BP 345.0 kV - 17STJOHN 345.0 kV Ckt 1	<u>CE</u> Description : The upgrade will be to re-conductor the line and upgrade station conductor. Time Estimate : 24-30 Months Cost : \$5,500,000 <u>NIPS</u> Description : The external (i.e. Non-PJM) Transmission Owner, NIPS, will not evaluate this violation until the impact study phase.	\$5,500,000
779280	19	7CASEY 345.0 kV - 05SULLIVAN 345.0 kV Ckt 1	<u>AEP</u> Description : 1) Rebuild / reconductor 0.6 miles of conductor (ACAR ~ 1024.5 ~ 30/7 ~ RAIL1 - Conductor section 5), estimated cost : \$1.2 million 2) Rebuild / reconductor 1.44 miles of conductor (ACSR/PE ~ 1414 ~ 62/19 ~ - Conductor section 2), estimated cost : \$2.88 million. 3) Replace two Sullivan 3000A Wavetraps , Estimated cost : \$225, 000. Time Estimate : 24-36 Months Cost : \$4,305,000 <u>AMIL</u> Description : The external (i.e. Non-PJM) Transmission Owner, AMIL, will not evaluate this violation until the impact study phase.	\$4,305,000
779430	24	AE1-089 TAP 345.0 kV - 05DUMONT 345.0 kV Ckt 1	<u>AEP</u> Description : 1) A Sag Study will be required on the 7.0 miles of conductor to mitigate the overload. The new ratings after sag study will be: S/N: 1409 MVA, S/E: 1888 MVA, Depending on the sag study results, the cost for this upgrade is expected to be between \$28,000(no remediation required, just sag study) and \$14.0 million (complete line Reconductor/rebuild). Time Estimate: a) Sag Study: 6-12 months b) Rebuild: The standard time required for construction differs from state to state. An approximate construction time would be 24 to 36 months after signing an interconnection agreement. Time Estimate : 6-12 Months Cost : \$28,000	\$28,000
779505,779506,779507,779508	4	05ELDERBRYSS 345.0 kV - AE1-089 TAP 345.0 kV Ckt 1		
172973,172974	25	AE1-172 TAP 345.0 kV - AD1-100 TAP 345.0 kV Ckt 1	<u>CE</u> Description : No Violation. The SSTE rating is 1846 MVA.	\$0
173966	3	AC1-067 TAP 345.0 kV - BURNHAM ;1R 345.0 kV Ckt 1	<u>CE</u> Description : No Violation. ComEd 345kV L17704 SLD & ALDR ratings are 1768 MVA & 2033 MVA respectively.	\$0

ID	Index	Facility	Upgrade Description	Cost
172710	2	DRESDEN ; R 345.0 kV - COLLINS ; R 345.0 kV Ckt 1	<u>CE</u> Description : No Violation. The SSTE rating is 1837 MVA.	\$0
172554,779444	10	GREENACRE; T 345.0 kV - 05OLIVE 345.0 kV Ckt 1	<u>CE</u> Description : No Violation. ComEd 345kV L6615 SSTE rating is 1134 MVA. <u>AEP</u> Description : 1) A Sag Study will be required on the 40.64 miles of ACSR/PE 1414 62/19 conductor to mitigate the overload. The new ratings after sag study will be: S/N: 971 MVA, S/E: 1419 MVA, Depending on the sag study results, the cost for this upgrade is expected to be between \$162,560 (no remediation required, just sag study) and \$81.28 million (complete line Reconductor/rebuild). Time Estimate: a) Sag Study: 6-12 months b) Rebuild: The standard time required for construction differs from state to state. An approximate construction time would be 24 to 36 months after signing an interconnection agreement. 2) Replace 5 Jumpers (Sub cond 2156 ACSR 84/19 STD at Olive station, estimated cost : \$175,000 Time Estimate : 6-12 Months Cost : \$337,560	\$337,560
173716,173717	21	AD1-100 TAP 345.0 kV - AD2-137 TAP 345.0 kV Ckt 1	<u>CE</u> Description : Upgrade 2-345kV circuit breakers at TSS 112. Time Estimate : 30.0 Months Cost : \$6,000,000	\$6,000,000
779753	20	AC2-104 TAP 765.0 kV - 05MARYSV 765.0 kV Ckt 1	<u>AEP</u> Description : Replace three 3000A wavetraps at Marysville. Estimated cost: \$675,000 Time Estimate : 24-36 Months Cost : \$675,000	\$675,000

ID	Index	Facility	Upgrade Description	Cost
779180	7	17STILLWELL 345.0 kV - 05DUMONT 345.0 kV Ckt 1	AEP Description : 1) Rebuild / reconductor 8.58 miles of conductor (ACSR ~ 954 ~ 45/7 ~ RAIL - Conductor section 1), Estimated Cost : \$17.16 million . 2) Replace Dumont Wavetrap , Estimated Cost : \$200k. 3) An Engineering study will need to be conducted to determine if the CT Thermal Limits can be adjusted to mitigate the overload. Estimated Cost: \$25,000. 4) Replace two Dumont Breakers , Estimated Cost: \$2.4 million 5) Replace 11 Dumont risers (11 Sub cond 2-1700 kcm AAC 61 Str.- Dumont) , Estimated Cost : \$ 175,000 6) Replace four 3000 A Dumont Switches , Estimated Cost : \$2,000,000 7) An Engineering study will need to be conducted to determine if the CT Thermal Limit settings can be adjusted to mitigate the overload. Estimated Cost: \$25,000. New relay package will be required if the settings cannot be adjusted, Estimated Cost: \$600,000. Time Estimate : 24-36 Months Cost : \$21,985,000 NIPS Description : The external (i.e. Non-PJM) Transmission Owner, NIPS, will not evaluate this violation until the impact study phase.	\$21,985,000
			TOTAL COST	\$108,768,120

Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gauge other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
781033	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L94507_B-S+_345-L97008_R-S	tower	4105.0	103.83	104.37	DC	94.14

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	32.17
274722	S-055 E	29.55
274772	LINCOLN ;3U	4.7
274773	LINCOLN ;4U	4.7
274774	LINCOLN ;5U	4.7
274775	LINCOLN ;6U	4.7
274776	LINCOLN ;7U	4.7
274777	LINCOLN ;8U	4.7
274832	U4-027	28.06
274859	EASYR;U1 E	29.13
274860	EASYR;U2 E	29.13
274888	PILOT HIL;1E	44.3
274890	CAYUG;1U E	36.07
274891	CAYUG;2U E	36.07
275149	KEMPTON ;1E	44.3
290021	O50 E	49.24
290051	GSG-6; E	28.08
290108	LEEDK;1U E	65.57
293061	N-015 E	41.22
293516	O-009 E1	23.79
293517	O-009 E2	12.09
293518	O-009 E3	13.31
293644	O22 E1	25.31
293645	O22 E2	49.12
293715	O-029 E	25.78
293716	O-029 E	14.13
293717	O-029 E	12.99
293771	O-035 E	16.49
294392	P-010 E	52.34
294763	P-046 E	24.88
295109	WESTBROOK E	15.03
295111	SUBLETTE E	6.87
296125	R-030 C3	9.31
296128	R-030 E3	37.24
296271	R-030 C2	9.2
296272	R-030 E2	36.8
296308	R-030 C1	9.2
296309	R-030 E1	36.8
910542	X3-005 E	1.57
914641	Y2-103	118.19

Bus #	Bus	MW Impact
915011	Y3-013 1	9.85
915021	Y3-013 2	9.85
915031	Y3-013 3	9.85
916211	Z1-072 E	12.48
916221	Z1-073 E	14.49
916502	Z1-106 E1	3.41
916504	Z1-106 E2	3.41
916512	Z1-107 E	6.53
916522	Z1-108 E	6.62
917502	Z2-087 E	48.13
918052	AA1-018 E	40.41
919221	AA1-146	46.5
919581	AA2-030	46.5
919621	AA2-039 C	3.78
919622	AA2-039 E	25.31
920272	AA2-123 E	6.51
924471	AB2-096	112.6
925161	AB2-173	8.29
925302	AB2-191 E	3.72
925581	AC1-033 C	3.62
925582	AC1-033 E	24.22
926311	AC1-109 1	5.21
926321	AC1-109 2	5.21
926331	AC1-110 1	5.12
926341	AC1-110 2	5.12
926351	AC1-111 1	2.07
926361	AC1-111 2	2.07
926371	AC1-111 3	2.07
926381	AC1-111 4	2.07
926391	AC1-111 5	2.07
926401	AC1-111 6	2.07
926431	AC1-114	6.32
926821	AC1-168 C O1	2.98
926822	AC1-168 E O1	20.01
927091	AC1-204 1	184.27
927101	AC1-204 2	184.31
927201	AC1-214 C O1	5.29
927202	AC1-214 E O1	16.83
927451	AC1-142A 1	10.61
927461	AC1-142A 2	10.61
927511	AC1-113 1	3.16
927521	AC1-113 2	3.16
927531	AC1-185 1	1.82
927541	AC1-185 2	1.82
927551	AC1-185 3	1.82
927561	AC1-185 4	1.82
927571	AC1-185 5	1.82
927581	AC1-185 6	1.82
927591	AC1-185 7	1.82
927601	AC1-185 8	1.82
930481	AB1-089	175.15
930501	AB1-091 O1	173.97

Bus #	Bus	MW Impact
930741	AB1-122 1O1	194.95
930751	AB1-122 2O1	188.67
932881	AC2-115 1	6.32
932891	AC2-115 2	6.32
932921	AC2-116	2.21
932931	AC2-117	14.95
933341	AC2-147 C	2.31
933342	AC2-147 E	3.77
933411	AC2-154 C	6.01
933412	AC2-154 E	9.81
933431	AC2-156 C O1	2.64
933432	AC2-156 E O1	4.3
933911	AD1-013 C	4.95
933912	AD1-013 E	7.9
933931	AD1-016 C	2.47
933932	AD1-016 E	4.03
934051	AD1-031 C O1	7.35
934052	AD1-031 E O1	11.99
934101	AD1-039 1	19.1
934111	AD1-039 2	18.49
934401	AD1-064 C O1	8.56
934402	AD1-064 E O1	40.08
934431	AD1-067 C	0.35
934432	AD1-067 E	1.48
934651	AD1-096 C	2.37
934652	AD1-096 E	3.86
934701	AD1-098 C O1	18.47
934702	AD1-098 E O1	13.48
934721	AD1-100 C	51.04
934722	AD1-100 E	238.17
934871	AD1-116 C	2.35
934872	AD1-116 E	3.84
934881	AD1-117 C	14.23
934882	AD1-117 E	9.49
934971	AD1-129 C	2.4
934972	AD1-129 E	1.6
935001	AD1-133 C O1	55.95
935002	AD1-133 E O1	37.3
936291	AD2-038 C O1	5.86
936292	AD2-038 E O1	39.2
936371	AD2-047 C O1	5.38
936372	AD2-047 E O1	57.91
936461	AD2-060	6.33
936511	AD2-066 C O1	21.47
936512	AD2-066 E O1	14.31
936781	AD2-101 C	10.68
936782	AD2-101 E	49.98
936791	AD2-102 C	31.89
936792	AD2-102 E	30.64
936961	AD2-130	1.4
937001	AD2-134 C	7.34
937002	AD2-134 E	30.33

Bus #	Bus	MW Impact
937031	AD2-137 C O1	10.26
937032	AD2-137 E O1	48.01
937051	AD2-140 C O1	10.5
937052	AD2-140 E O1	49.17
937061	AD2-141 C O1	10.44
937062	AD2-141 E O1	49.23
937071	AD2-142 C O1	21.0
937072	AD2-142 E O1	98.34
937121	AD2-148 C O1	8.35
937122	AD2-148 E O1	39.1
937131	AD2-149 C O1	8.35
937132	AD2-149 E O1	39.1
937141	AD2-150 C O1	8.35
937142	AD2-150 E O1	39.1
937181	AD2-155 C O1	8.35
937182	AD2-155 E O1	39.1
937311	AD2-172 C	6.53
937312	AD2-172 E	9.02
937321	AD2-175 C	38.91
937322	AD2-175 E	25.94
937331	AD2-176 C O1	19.52
937332	AD2-176 E O1	13.01
937401	AD2-194 1	19.82
937411	AD2-194 2	19.82
937531	AD2-214 C	11.6
937532	AD2-214 E	5.46
938012	AE1-002 E O1	20.59
938511	AE1-070 1	23.28
938521	AE1-070 2	21.31
938851	AE1-113 C O1	22.28
938852	AE1-113 E O1	70.05
938861	AE1-114 C O1	9.53
938862	AE1-114 E O1	36.45
939051	AE1-134 1	3.61
939061	AE1-134 2	3.61
939321	AE1-163 C O1	14.72
939322	AE1-163 E O1	90.42
939351	AE1-166 C O1	26.27
939352	AE1-166 E O1	24.25
939401	AE1-172 C O1	16.57
939402	AE1-172 E O1	77.57
939631	AE1-193 C O1	17.95
939632	AE1-193 E O1	120.14
939641	AE1-194 C	21.1
939642	AE1-194 E	141.24
939651	AE1-195 C	21.1
939652	AE1-195 E	141.24
939681	AE1-198 C O1	53.3
939682	AE1-198 E O1	45.3
939691	AE1-199	6.42
939701	AE1-201 C	5.34
939702	AE1-201 E	1.17

Bus #	Bus	MW Impact
939732	AE1-204 E	0.77
939741	AE1-205 C O1	23.29
939742	AE1-205 E O1	32.16
939861	AE1-222 1	215.29
939871	AE1-222 2	208.36
939921	AE1-228 C O1	27.02
939922	AE1-228 E O1	18.01
939961	AE1-233 C O1	6.29
939962	AE1-233 E O1	25.97
940101	AE1-252 C O1	28.24
940102	AE1-252 E O1	18.83
AB2-013	AB2-013	41.07
AE1-033	AE1-033	47.69
BLUEG	BLUEG	16.82
CALDERWOOD	CALDERWOOD	0.23
CANNELTON	CANNELTON	0.26
CARR	CARR	1.97
CATAWBA	CATAWBA	0.8
CBM-S1	CBM-S1	3.44
CBM-W1	CBM-W1	76.96
CBM-W2	CBM-W2	140.68
CHEOAH	CHEOAH	0.24
CHILHOWEE	CHILHOWEE	0.07
DEARBORN	DEARBORN	6.43
ELMERSMITH	ELMERSMITH	0.27
G-007	G-007	5.53
GIBSON	GIBSON	0.08
HAMLET	HAMLET	3.02
MEC	MEC	98.2
O-066	O-066	18.61
RENSSELAER	RENSSELAER	1.56
SANTEETLA	SANTEETLA	0.08
TRIMBLE	TRIMBLE	1.99
WEC	WEC	20.94
Z1-043	Z1-043	73.86

Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
172710	270717	DRESDEN ; R	CE	270697	COLLINS ; R	CE	1	COMED_P4_111-45-L1223T_	breaker	1528.0	100.03	100.59	DC	18.79

Bus #	Bus	MW Impact
274659	DRESDEN ;3U	42.28
274729	ELWOOD EC;1P	2.69
274731	ELWOOD EC;2P	2.69
274733	ELWOOD EC;3P	2.69
274735	ELWOOD EC;4P	2.69
274736	ELWOOD EC;9P	2.66
274890	CAYUG;1U E	9.67
274891	CAYUG;2U E	9.67
276150	W2-048 E	0.97
290021	O50 E	11.1
290261	S-027 E	15.15
290265	S-028 E	15.15
296125	R-030 C3	3.8
296128	R-030 E3	15.19
296271	R-030 C2	3.75
296272	R-030 E2	15.01
296308	R-030 C1	3.75
296309	R-030 E1	15.01
905082	W4-005 E	25.39
909052	X2-022 E	13.53
917502	Z2-087 E	19.63
924041	AB2-047 C O1	3.61
924042	AB2-047 E O1	24.18
924261	AB2-070 C O1	1.95
924262	AB2-070 E O1	13.08
925771	AC1-053 C	1.93
925772	AC1-053 E	12.91
926841	AC1-171 C O1	0.6
926842	AC1-171 E O1	4.0
927091	AC1-204 1	64.57
927101	AC1-204 2	65.35
930741	AB1-122 1O1	173.78
930751	AB1-122 2O1	33.89
934101	AD1-039 1	17.03
934111	AD1-039 2	3.32
935001	AD1-133 C O1	39.0
935002	AD1-133 E O1	26.0
935141	AD1-148	3.54
936291	AD2-038 C O1	1.13
936292	AD2-038 E O1	7.56
936771	AD2-100 C O1	7.92

Bus #	Bus	MW Impact
936772	AD2-100 E O1	5.28
936972	AD2-131 E O1	1.67
937161	AD2-153 C O1	2.52
937162	AD2-153 E O1	11.79
937171	AD2-154 C O1	2.52
937172	AD2-154 E O1	11.79
937211	AD2-159 C	2.74
937212	AD2-159 E	12.84
937401	AD2-194 1	6.94
937411	AD2-194 2	7.03
938511	AE1-070 1	8.16
938521	AE1-070 2	7.55
938851	AE1-113 C O1	5.02
938852	AE1-113 E O1	15.79
939321	AE1-163 C O1	2.84
939322	AE1-163 E O1	17.43
939401	AE1-172 C O1	3.31
939402	AE1-172 E O1	15.48
939741	AE1-205 C O1	9.44
939742	AE1-205 E O1	13.03
939861	AE1-222 1	191.92
939871	AE1-222 2	37.43
940101	AE1-252 C O1	5.64
940102	AE1-252 E O1	3.76
951741	J474 C	1.23
951742	J474 E	6.63
952651	J756 C	1.67
952652	J756 E	9.05
954181	J884	6.11
AB2-013	AB2-013	11.51
CARR	CARR	0.16
CBM-S1	CBM-S1	2.68
CBM-S2	CBM-S2	0.28
CBM-W1	CBM-W1	3.41
CBM-W2	CBM-W2	44.28
CIN	CIN	2.13
CPL	CPL	0.02
DEARBORN	DEARBORN	0.86
G-007	G-007	0.45
IPL	IPL	0.97
LGEE	LGEE	0.09
MEC	MEC	12.36
O-066	O-066	1.51
RENSSELAER	RENSSELAER	0.13
Z1-043	Z1-043	11.82

Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
173966	925880	AC1-067 TAP	CE	270675	BURNHAM ;1R	CE	1	COMED_P7_345-L2001__B-S_+_345-L2003__R-S	tower	1768.0	99.81	100.23	DC	16.27

Bus #	Bus	MW Impact
274654	BRAIDWOOD;1U	19.31
274655	BRAIDWOOD;2U	18.58
274881	PLEAS RDG;2U	0.85
274887	PILOT HIL;1U	0.85
274888	PILOT HIL;1E	22.19
275149	KEMPTON ;1E	22.19
293061	N-015 E	7.44
294392	P-010 E	9.45
925881	AC1-067 O1	812.21
930501	AB1-091 O1	101.52
933411	AC2-154 C	3.01
933412	AC2-154 E	4.91
934721	AD1-100 C	12.9
934722	AD1-100 E	60.19
936371	AD2-047 C O1	2.69
936372	AD2-047 E O1	29.01
936461	AD2-060	3.17
936781	AD2-101 C	4.32
936782	AD2-101 E	20.24
937121	AD2-148 C O1	4.82
937122	AD2-148 E O1	22.54
937131	AD2-149 C O1	4.82
937132	AD2-149 E O1	22.54
937141	AD2-150 C O1	4.82
937142	AD2-150 E O1	22.54
937181	AD2-155 C O1	4.82
937182	AD2-155 E O1	22.54
937321	AD2-175 C	22.44
937322	AD2-175 E	14.96
939351	AE1-166 C O1	7.96
939352	AE1-166 E O1	7.34
939401	AE1-172 C O1	2.86
939402	AE1-172 E O1	13.41
940101	AE1-252 C O1	4.88
940102	AE1-252 E O1	3.26
BLUEG	BLUEG	1.25
CALDERWOOD	CALDERWOOD	0.04
CANNELTON	CANNELTON	0.03
CARR	CARR	0.15
CATAWBA	CATAWBA	0.07

Bus #	Bus	MW Impact
CBM-S1	CBM-S1	0.08
CBM-W1	CBM-W1	1.21
CBM-W2	CBM-W2	8.35
CHEOAH	CHEOAH	0.04
CHILHOWEE	CHILHOWEE	0.01
DEARBORN	DEARBORN	0.65
ELMERSMITH	ELMERSMITH	0.03
G-007	G-007	0.42
GIBSON	GIBSON	0.01
HAMLET	HAMLET	0.25
MEC	MEC	4.71
O-066	O-066	1.4
RENSSELAER	RENSSELAER	0.12
SANTEETLA	SANTEETLA	0.01
TRIMBLE	TRIMBLE	0.15
WEC	WEC	0.71

Index 4

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
779505	243918	05ELDERBRYSS	AEP	938670	AE1-089 TAP	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	117.39	118.06	DC	21.09

Bus #	Bus	MW Impact
247900	05FR-11G E	6.85
247901	05FR-12G E	6.74
247902	05FR-21G E	7.2
247903	05FR-22G E	6.89
247904	05FR-3G E	13.96
247905	05FR-4G E	10.5
247906	05MDL-1G E	15.63
247907	05MDL-2G E	7.75
247912	05MDL-3G E	8.11
247913	05MDL-4G E	7.83
247943	T-127 E	7.83
270859	PWR VTR EC;R	7.11
274722	S-055 E	6.55
274809	UNIV PK N;5U	0.8
274811	UNIV PK N;7U	0.8
274812	UNIV PK N;8U	0.8
274814	UNIV PK N;0U	0.8
274815	UNIV PK N;XU	0.8
274859	EASYR;U1 E	5.56
274860	EASYR;U2 E	5.56
274888	PILOT HIL;1E	10.32
274890	CAYUG;1U E	8.28
274891	CAYUG;2U E	8.28
275149	KEMPTON ;1E	10.32
290021	O50 E	11.46
290051	GSG-6; E	6.16
290108	LEEDK;1U E	14.23
293061	N-015 E	8.96
293644	O22 E1	5.93
293645	O22 E2	11.51
294392	P-010 E	11.37
294763	P-046 E	5.56
295109	WESTBROOK E	3.3
909145	X2-052	36.23
914641	Y2-103	26.18
915011	Y3-013 1	2.18
915021	Y3-013 2	2.18
915031	Y3-013 3	2.18
916221	Z1-073 E	3.18
916502	Z1-106 E1	0.73

Bus #	Bus	MW Impact
916504	Z1-106 E2	0.73
916512	Z1-107 E	1.5
916522	Z1-108 E	1.45
917711	Z2-114 C	0.06
917712	Z2-114 E	0.4
918052	AA1-018 E	9.8
920272	AA2-123 E	1.43
924471	AB2-096	24.87
925302	AB2-191 E	0.82
926311	AC1-109 1	1.1
926321	AC1-109 2	1.1
926331	AC1-110 1	1.1
926341	AC1-110 2	1.1
926351	AC1-111 1	0.44
926361	AC1-111 2	0.44
926371	AC1-111 3	0.44
926381	AC1-111 4	0.44
926391	AC1-111 5	0.44
926401	AC1-111 6	0.44
926431	AC1-114	1.4
926821	AC1-168 C O1	0.7
926822	AC1-168 E O1	4.71
927091	AC1-204 1	41.9
927101	AC1-204 2	41.91
927451	AC1-142A 1	2.42
927461	AC1-142A 2	2.42
927511	AC1-113 1	0.7
927521	AC1-113 2	0.7
927531	AC1-185 1	0.41
927541	AC1-185 2	0.41
927551	AC1-185 3	0.41
927561	AC1-185 4	0.41
927571	AC1-185 5	0.41
927581	AC1-185 6	0.41
927591	AC1-185 7	0.41
927601	AC1-185 8	0.41
930042	AB1-006 E	17.03
930391	AB1-080	2.15
930481	AB1-089	38.75
930501	AB1-091 O1	40.14
930741	AB1-122 1O1	41.99
930751	AB1-122 2O1	42.66
932601	AC2-080 C O1	3.72
932602	AC2-080 E O1	24.91
932881	AC2-115 1	1.4
932891	AC2-115 2	1.4
932921	AC2-116	0.49
932931	AC2-117	5.17
933341	AC2-147 C	0.52
933342	AC2-147 E	0.85
933411	AC2-154 C	1.4
933412	AC2-154 E	2.28

Bus #	Bus	MW Impact
933431	AC2-156 C O1	0.55
933432	AC2-156 E O1	0.9
933911	AD1-013 C	1.08
933912	AD1-013 E	1.73
933931	AD1-016 C	0.54
933932	AD1-016 E	0.89
934101	AD1-039 1	4.12
934111	AD1-039 2	4.18
934401	AD1-064 C O1	1.88
934402	AD1-064 E O1	8.8
934431	AD1-067 C	0.08
934432	AD1-067 E	0.33
934651	AD1-096 C	0.53
934652	AD1-096 E	0.86
934701	AD1-098 C O1	4.06
934702	AD1-098 E O1	2.96
934721	AD1-100 C	11.12
934722	AD1-100 E	51.9
934871	AD1-116 C	0.57
934872	AD1-116 E	0.93
934881	AD1-117 C	3.21
934882	AD1-117 E	2.14
934971	AD1-129 C	0.53
934972	AD1-129 E	0.35
935001	AD1-133 C O1	12.63
935002	AD1-133 E O1	8.42
935271	AD1-137 C	5.69
935272	AD1-137 E	38.05
936291	AD2-038 C O1	1.41
936292	AD2-038 E O1	9.44
936371	AD2-047 C O1	1.25
936372	AD2-047 E O1	13.49
936461	AD2-060	1.47
936511	AD2-066 C O1	4.99
936512	AD2-066 E O1	3.33
936781	AD2-101 C	2.48
936782	AD2-101 E	11.59
936791	AD2-102 C	7.12
936792	AD2-102 E	6.84
936961	AD2-130	0.32
936981	AD2-132 C	5.04
936982	AD2-132 E	23.6
937001	AD2-134 C	1.61
937002	AD2-134 E	6.66
937031	AD2-137 C O1	1.92
937032	AD2-137 E O1	9.0
937041	AD2-138 C	5.04
937042	AD2-138 E	23.6
937051	AD2-140 C O1	1.92
937052	AD2-140 E O1	8.99
937061	AD2-141 C O1	1.91
937062	AD2-141 E O1	9.0

Bus #	Bus	MW Impact
937071	AD2-142 C O1	3.84
937072	AD2-142 E O1	17.98
937121	AD2-148 C O1	1.93
937122	AD2-148 E O1	9.02
937131	AD2-149 C O1	1.93
937132	AD2-149 E O1	9.02
937141	AD2-150 C O1	1.93
937142	AD2-150 E O1	9.02
937181	AD2-155 C O1	1.93
937182	AD2-155 E O1	9.02
937311	AD2-172 C	1.46
937312	AD2-172 E	2.02
937321	AD2-175 C	8.98
937322	AD2-175 E	5.98
937331	AD2-176 C O1	4.29
937332	AD2-176 E O1	2.86
937401	AD2-194 1	4.51
937411	AD2-194 2	4.51
938012	AE1-002 E O1	3.86
938511	AE1-070 1	5.29
938521	AE1-070 2	4.84
938851	AE1-113 C O1	5.18
938852	AE1-113 E O1	16.3
938861	AE1-114 C O1	2.14
938862	AE1-114 E O1	8.19
939321	AE1-163 C O1	3.54
939322	AE1-163 E O1	21.77
939351	AE1-166 C O1	5.85
939352	AE1-166 E O1	5.4
939401	AE1-172 C O1	3.71
939402	AE1-172 E O1	17.38
939641	AE1-194 C	5.61
939642	AE1-194 E	37.52
939651	AE1-195 C	5.61
939652	AE1-195 E	37.52
939691	AE1-199	1.41
939701	AE1-201 C	1.17
939702	AE1-201 E	0.26
939732	AE1-204 E	0.17
939861	AE1-222 1	46.37
939871	AE1-222 2	47.11
939921	AE1-228 C O1	5.92
939922	AE1-228 E O1	3.95
939961	AE1-233 C O1	1.36
939962	AE1-233 E O1	5.62
940101	AE1-252 C O1	6.33
940102	AE1-252 E O1	4.22
AB2-013	AB2-013	10.01
AE1-033	AE1-033	10.77
CARR	CARR	0.59
CATAWBA	CATAWBA	0.05
CBM-S1	CBM-S1	4.6

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	19.73
CBM-W2	CBM-W2	68.15
CIN	CIN	7.05
DEARBORN	DEARBORN	1.82
G-007	G-007	1.64
HAMLET	HAMLET	0.34
IPL	IPL	3.28
LGEE	LGEE	0.73
MEC	MEC	25.32
O-066	O-066	5.54
RENSSELAER	RENSSELAER	0.47
WEC	WEC	4.7
Z1-043	Z1-043	17.65

Index 5

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
172683	255104	17GREEN_ACR E	NIPS	270771	GREENACR E; T	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	103.27	103.92	DC	23.27

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	8.06
274722	S-055 E	7.52
274751	CRETE EC ;1U	1.93
274752	CRETE EC ;2U	1.93
274753	CRETE EC ;3U	1.93
274754	CRETE EC ;4U	1.93
274832	U4-027	7.11
274859	EASYR;U1 E	7.3
274860	EASYR;U2 E	7.3
274888	PILOT HIL;1E	12.4
274890	CAYUG;1U E	8.92
274891	CAYUG;2U E	8.92
275149	KEMPTON ;1E	12.4
290021	O50 E	12.98
290051	GSG-6; E	6.94
290108	LEEDK;1U E	16.14
293061	N-015 E	10.24
293516	O-009 E1	5.99
293517	O-009 E2	3.04
293518	O-009 E3	3.35
293644	O22 E1	7.24
293645	O22 E2	14.06
293715	O-029 E	6.47
293716	O-029 E	3.55
293717	O-029 E	3.26
294392	P-010 E	13.0
294763	P-046 E	6.23
295109	WESTBROOK E	3.72
295111	SUBLETTE E	1.72
910542	X3-005 E	0.52
914641	Y2-103	30.09
915011	Y3-013 1	2.51
915021	Y3-013 2	2.51
915031	Y3-013 3	2.51
916221	Z1-073 E	3.58
916502	Z1-106 E1	0.84
916504	Z1-106 E2	0.84
916512	Z1-107 E	1.71
916522	Z1-108 E	1.66
918052	AA1-018 E	10.62
919221	AA1-146	11.67

Bus #	Bus	MW Impact
919581	AA2-030	11.67
920272	AA2-123 E	1.63
924471	AB2-096	28.21
925161	AB2-173	2.08
925302	AB2-191 E	0.92
925881	AC1-067 O1	102.57
926311	AC1-109 1	1.27
926321	AC1-109 2	1.27
926331	AC1-110 1	1.27
926341	AC1-110 2	1.27
926351	AC1-111 1	0.51
926361	AC1-111 2	0.51
926371	AC1-111 3	0.51
926381	AC1-111 4	0.51
926391	AC1-111 5	0.51
926401	AC1-111 6	0.51
926431	AC1-114	1.58
926821	AC1-168 C O1	0.76
926822	AC1-168 E O1	5.08
927091	AC1-204 1	48.76
927101	AC1-204 2	48.73
927201	AC1-214 C O1	0.74
927202	AC1-214 E O1	2.34
927451	AC1-142A 1	2.83
927461	AC1-142A 2	2.83
927511	AC1-113 1	0.79
927521	AC1-113 2	0.79
927531	AC1-185 1	0.46
927541	AC1-185 2	0.46
927551	AC1-185 3	0.46
927561	AC1-185 4	0.46
927571	AC1-185 5	0.46
927581	AC1-185 6	0.46
927591	AC1-185 7	0.46
927601	AC1-185 8	0.46
930481	AB1-089	43.76
930501	AB1-091 O1	49.15
930741	AB1-122 1O1	47.58
930751	AB1-122 2O1	49.75
932881	AC2-115 1	1.58
932891	AC2-115 2	1.58
932921	AC2-116	0.55
933341	AC2-147 C	0.58
933342	AC2-147 E	0.94
933411	AC2-154 C	1.68
933412	AC2-154 E	2.75
933431	AC2-156 C O1	0.64
933432	AC2-156 E O1	1.04
933911	AD1-013 C	1.22
933912	AD1-013 E	1.95
933931	AD1-016 C	0.62
933932	AD1-016 E	1.01

Bus #	Bus	MW Impact
934101	AD1-039 1	4.66
934111	AD1-039 2	4.88
934401	AD1-064 C O1	2.13
934402	AD1-064 E O1	9.99
934431	AD1-067 C	0.09
934432	AD1-067 E	0.37
934651	AD1-096 C	0.59
934652	AD1-096 E	0.97
934701	AD1-098 C O1	4.57
934702	AD1-098 E O1	3.34
934721	AD1-100 C	12.94
934722	AD1-100 E	60.39
934871	AD1-116 C	0.62
934872	AD1-116 E	1.01
934881	AD1-117 C	3.57
934882	AD1-117 E	2.38
934971	AD1-129 C	0.6
934972	AD1-129 E	0.4
935001	AD1-133 C O1	13.73
935002	AD1-133 E O1	9.15
936291	AD2-038 C O1	1.54
936292	AD2-038 E O1	10.32
936371	AD2-047 C O1	1.51
936372	AD2-047 E O1	16.21
936461	AD2-060	1.77
936511	AD2-066 C O1	5.56
936512	AD2-066 E O1	3.71
936781	AD2-101 C	3.17
936782	AD2-101 E	14.84
936791	AD2-102 C	8.0
936792	AD2-102 E	7.69
936961	AD2-130	0.38
937001	AD2-134 C	1.82
937002	AD2-134 E	7.5
937031	AD2-137 C O1	2.31
937032	AD2-137 E O1	10.8
937051	AD2-140 C O1	2.32
937052	AD2-140 E O1	10.87
937061	AD2-141 C O1	2.31
937062	AD2-141 E O1	10.88
937071	AD2-142 C O1	4.64
937072	AD2-142 E O1	21.73
937121	AD2-148 C O1	2.36
937122	AD2-148 E O1	11.04
937131	AD2-149 C O1	2.36
937132	AD2-149 E O1	11.04
937141	AD2-150 C O1	2.36
937142	AD2-150 E O1	11.04
937181	AD2-155 C O1	2.36
937182	AD2-155 E O1	11.04
937311	AD2-172 C	1.64
937312	AD2-172 E	2.26

Bus #	Bus	MW Impact
937321	AD2-175 C	10.99
937322	AD2-175 E	7.33
937331	AD2-176 C O1	4.89
937332	AD2-176 E O1	3.26
937401	AD2-194 1	5.24
937411	AD2-194 2	5.24
937531	AD2-214 C	2.92
937532	AD2-214 E	1.37
938012	AE1-002 E O1	4.63
938511	AE1-070 1	6.16
938521	AE1-070 2	5.63
938851	AE1-113 C O1	5.88
938852	AE1-113 E O1	18.47
938861	AE1-114 C O1	2.39
938862	AE1-114 E O1	9.13
939051	AE1-134 1	0.91
939061	AE1-134 2	0.91
939321	AE1-163 C O1	3.87
939322	AE1-163 E O1	23.79
939351	AE1-166 C O1	6.84
939352	AE1-166 E O1	6.31
939401	AE1-172 C O1	4.1
939402	AE1-172 E O1	19.18
939641	AE1-194 C	10.88
939642	AE1-194 E	72.84
939651	AE1-195 C	10.88
939652	AE1-195 E	72.84
939691	AE1-199	1.59
939701	AE1-201 C	1.34
939702	AE1-201 E	0.29
939732	AE1-204 E	0.2
939861	AE1-222 1	52.55
939871	AE1-222 2	54.95
939921	AE1-228 C O1	6.68
939922	AE1-228 E O1	4.45
939961	AE1-233 C O1	1.55
939962	AE1-233 E O1	6.39
940101	AE1-252 C O1	6.98
940102	AE1-252 E O1	4.65
951721	J643	15.51
952581	J740 C	3.4
952582	J740 E	18.42
953871	J847	8.38
AB2-013	AB2-013	10.64
AE1-033	AE1-033	12.03
BLUEG	BLUEG	2.86
CANNELTON	CANNELTON	0.0
CARR	CARR	0.5
CATAWBA	CATAWBA	0.16
CBM-S1	CBM-S1	1.36
CBM-W1	CBM-W1	19.98
CBM-W2	CBM-W2	38.44

Bus #	Bus	MW Impact
CIN	CIN	0.12
DEARBORN	DEARBORN	2.29
G-007	G-007	1.38
HAMLET	HAMLET	0.65
MEC	MEC	25.05
O-066	O-066	4.65
RENSSELAER	RENSSELAER	0.39
SANTEETLA	SANTEETLA	0.0
TRIMBLE	TRIMBLE	0.34
WEC	WEC	5.32
Z1-043	Z1-043	18.82

Index 6

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
172513	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_023-65-BT2-3__	breaker	1091.0	111.32	112.12	DC	25.42

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	9.04
274654	BRAIDWOOD;1U	19.05
274655	BRAIDWOOD;2U	18.24
274661	LASCO STA;2U	17.6
274687	WILL CNTY;4U	8.03
274704	KENDALL ;1C	2.81
274705	KENDALL ;1S	1.88
274706	KENDALL ;2C	2.81
274707	KENDALL ;2S	1.88
274722	S-055 E	8.45
274751	CRETE EC ;1U	3.36
274752	CRETE EC ;2U	3.36
274753	CRETE EC ;3U	3.36
274754	CRETE EC ;4U	3.36
274859	EASYR;U1 E	8.17
274860	EASYR;U2 E	8.17
274861	TOP CROP ;1U	0.33
274862	TOP CROP ;2U	0.63
274888	PILOT HIL;1E	12.81
274890	CAYUG;1U E	9.74
274891	CAYUG;2U E	9.74
275149	KEMPTON ;1E	12.81
290021	O50 E	14.65
290051	GSG-6; E	7.78
290108	LEEDK;1U E	18.09
293061	N-015 E	11.61
293516	O-009 E1	6.69
293517	O-009 E2	3.4
293518	O-009 E3	3.74
293644	O22 E1	8.5
293645	O22 E2	16.51
293715	O-029 E	7.24
293716	O-029 E	3.97
293717	O-029 E	3.65
294392	P-010 E	14.75
294763	P-046 E	6.98
295109	WESTBROOK E	4.16
295111	SUBLETTE E	1.92
914641	Y2-103	33.8
915011	Y3-013 1	2.82

Bus #	Bus	MW Impact
915021	Y3-013 2	2.82
915031	Y3-013 3	2.82
916221	Z1-073 E	4.01
916502	Z1-106 E1	0.94
916504	Z1-106 E2	0.94
916512	Z1-107 E	1.85
916522	Z1-108 E	1.86
918052	AA1-018 E	11.64
919221	AA1-146	13.04
919581	AA2-030	13.04
920272	AA2-123 E	1.83
924471	AB2-096	31.63
925161	AB2-173	2.33
925302	AB2-191 E	1.03
926311	AC1-109 1	1.42
926321	AC1-109 2	1.42
926331	AC1-110 1	1.42
926341	AC1-110 2	1.42
926351	AC1-111 1	0.57
926361	AC1-111 2	0.57
926371	AC1-111 3	0.57
926381	AC1-111 4	0.57
926391	AC1-111 5	0.57
926401	AC1-111 6	0.57
926431	AC1-114	1.77
926821	AC1-168 C O1	0.85
926822	AC1-168 E O1	5.68
927091	AC1-204 1	55.19
927101	AC1-204 2	55.12
927451	AC1-142A 1	3.2
927461	AC1-142A 2	3.2
927511	AC1-113 1	0.89
927521	AC1-113 2	0.89
927531	AC1-185 1	0.51
927541	AC1-185 2	0.51
927551	AC1-185 3	0.51
927561	AC1-185 4	0.51
927571	AC1-185 5	0.51
927581	AC1-185 6	0.51
927591	AC1-185 7	0.51
927601	AC1-185 8	0.51
930481	AB1-089	49.05
930501	AB1-091 O1	50.61
930741	AB1-122 1O1	52.99
930751	AB1-122 2O1	56.33
932881	AC2-115 1	1.77
932891	AC2-115 2	1.77
932921	AC2-116	0.62
933341	AC2-147 C	0.65
933342	AC2-147 E	1.06
933411	AC2-154 C	1.74
933412	AC2-154 E	2.84

Bus #	Bus	MW Impact
933431	AC2-156 C O1	0.71
933432	AC2-156 E O1	1.16
933911	AD1-013 C	1.37
933912	AD1-013 E	2.19
933931	AD1-016 C	0.69
933932	AD1-016 E	1.13
934101	AD1-039 1	5.19
934111	AD1-039 2	5.52
934401	AD1-064 C O1	2.39
934402	AD1-064 E O1	11.2
934431	AD1-067 C	0.1
934432	AD1-067 E	0.41
934651	AD1-096 C	0.66
934652	AD1-096 E	1.08
934701	AD1-098 C O1	5.12
934702	AD1-098 E O1	3.74
934721	AD1-100 C	14.27
934722	AD1-100 E	66.6
934871	AD1-116 C	0.68
934872	AD1-116 E	1.11
934881	AD1-117 C	3.99
934882	AD1-117 E	2.66
934971	AD1-129 C	0.67
934972	AD1-129 E	0.45
935001	AD1-133 C O1	15.16
935002	AD1-133 E O1	10.11
936291	AD2-038 C O1	1.71
936292	AD2-038 E O1	11.45
936371	AD2-047 C O1	1.56
936372	AD2-047 E O1	16.75
936461	AD2-060	1.83
936511	AD2-066 C O1	6.19
936512	AD2-066 E O1	4.13
936781	AD2-101 C	3.09
936782	AD2-101 E	14.46
936791	AD2-102 C	8.96
936792	AD2-102 E	8.61
936961	AD2-130	0.42
937001	AD2-134 C	2.03
937002	AD2-134 E	8.4
937031	AD2-137 C O1	2.44
937032	AD2-137 E O1	11.43
937051	AD2-140 C O1	2.44
937052	AD2-140 E O1	11.42
937061	AD2-141 C O1	2.43
937062	AD2-141 E O1	11.44
937071	AD2-142 C O1	4.88
937072	AD2-142 E O1	22.85
937121	AD2-148 C O1	2.43
937122	AD2-148 E O1	11.37
937131	AD2-149 C O1	2.43
937132	AD2-149 E O1	11.37

Bus #	Bus	MW Impact
937141	AD2-150 C O1	2.43
937142	AD2-150 E O1	11.37
937181	AD2-155 C O1	2.43
937182	AD2-155 E O1	11.37
937311	AD2-172 C	1.83
937312	AD2-172 E	2.53
937321	AD2-175 C	11.32
937322	AD2-175 E	7.55
937331	AD2-176 C O1	5.48
937332	AD2-176 E O1	3.65
937401	AD2-194 1	5.94
937411	AD2-194 2	5.93
937531	AD2-214 C	0.8
937532	AD2-214 E	0.38
938012	AE1-002 E O1	4.9
938511	AE1-070 1	6.97
938521	AE1-070 2	6.37
938851	AE1-113 C O1	6.63
938852	AE1-113 E O1	20.84
938861	AE1-114 C O1	2.67
938862	AE1-114 E O1	10.22
939051	AE1-134 1	1.01
939061	AE1-134 2	1.01
939321	AE1-163 C O1	4.3
939322	AE1-163 E O1	26.41
939351	AE1-166 C O1	7.6
939352	AE1-166 E O1	7.02
939401	AE1-172 C O1	4.47
939402	AE1-172 E O1	20.95
939641	AE1-194 C	18.96
939642	AE1-194 E	126.86
939651	AE1-195 C	18.96
939652	AE1-195 E	126.86
939691	AE1-199	1.78
939701	AE1-201 C	1.5
939702	AE1-201 E	0.33
939732	AE1-204 E	0.22
939861	AE1-222 1	58.52
939871	AE1-222 2	62.2
939921	AE1-228 C O1	7.48
939922	AE1-228 E O1	4.99
939961	AE1-233 C O1	1.73
939962	AE1-233 E O1	7.16
940101	AE1-252 C O1	7.63
940102	AE1-252 E O1	5.08
AB2-013	AB2-013	11.87
AE1-033	AE1-033	13.47
BLUEG	BLUEG	5.05
CALDERWOOD	CALDERWOOD	0.09
CANNELTON	CANNELTON	0.11
CARR	CARR	0.56
CATAWBA	CATAWBA	0.23

Bus #	Bus	MW Impact
CBM-S1	CBM-S1	0.77
CBM-W1	CBM-W1	20.04
CBM-W2	CBM-W2	37.14
CHEOAH	CHEOAH	0.09
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.24
ELMERSMITH	ELMERSMITH	0.14
G-007	G-007	1.57
GIBSON	GIBSON	0.06
HAMLET	HAMLET	0.87
MEC	MEC	27.58
O-066	O-066	5.3
RENSSELAER	RENSSELAER	0.45
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.59
WEC	WEC	5.97
Z1-043	Z1-043	20.98

Index 7

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
779180	255113	17STILLWEL	NIPS	243219	05DUMONT	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	173.76	174.49	DC	40.94

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	13.92
274722	S-055 E	12.95
274724	RIVER EC ;11	4.75
274788	SE CHICAG;5U	1.14
274789	SE CHICAG;6U	1.14
274790	SE CHICAG;7U	1.14
274791	SE CHICAG;8U	1.14
274795	SE CHICAG;2U	1.12
274832	U4-027	12.45
274859	EASYR;U1 E	12.67
274860	EASYR;U2 E	12.67
274888	PILOT HIL;1E	22.3
274890	CAYUG;1U E	15.76
274891	CAYUG;2U E	15.76
275149	KEMPTON ;1E	22.3
290021	O50 E	22.31
290051	GSG-6; E	12.02
290108	LEEDK;1U E	27.92
293061	N-015 E	17.54
293516	O-009 E1	10.45
293517	O-009 E2	5.31
293518	O-009 E3	5.85
293644	O22 E1	11.95
293645	O22 E2	23.2
293715	O-029 E	11.27
293716	O-029 E	6.18
293717	O-029 E	5.68
293771	O-035 E	7.36
294392	P-010 E	22.27
294763	P-046 E	10.8
295109	WESTBROOK E	6.44
295111	SUBLETTE E	2.99
910542	X3-005 E	1.0
914641	Y2-103	51.8
915011	Y3-013 1	4.32
915021	Y3-013 2	4.32
915031	Y3-013 3	4.32
916211	Z1-072 E	5.57
916221	Z1-073 E	6.2
916502	Z1-106 E1	1.45
916504	Z1-106 E2	1.45

Bus #	Bus	MW Impact
916512	Z1-107 E	3.03
916522	Z1-108 E	2.86
918052	AA1-018 E	18.74
919221	AA1-146	20.28
919581	AA2-030	20.28
920272	AA2-123 E	2.81
924471	AB2-096	48.73
925161	AB2-173	3.62
925302	AB2-191 E	1.59
925581	AC1-033 C	1.61
925582	AC1-033 E	10.81
925881	AC1-067 O1	198.49
926311	AC1-109 1	2.19
926321	AC1-109 2	2.19
926331	AC1-110 1	2.18
926341	AC1-110 2	2.18
926351	AC1-111 1	0.88
926361	AC1-111 2	0.88
926371	AC1-111 3	0.88
926381	AC1-111 4	0.88
926391	AC1-111 5	0.88
926401	AC1-111 6	0.88
926431	AC1-114	2.74
926821	AC1-168 C O1	1.32
926822	AC1-168 E O1	8.85
927091	AC1-204 1	83.26
927101	AC1-204 2	83.23
927201	AC1-214 C O1	2.36
927202	AC1-214 E O1	7.51
927451	AC1-142A 1	4.83
927461	AC1-142A 2	4.84
927511	AC1-113 1	1.37
927521	AC1-113 2	1.37
927531	AC1-185 1	0.79
927541	AC1-185 2	0.79
927551	AC1-185 3	0.79
927561	AC1-185 4	0.79
927571	AC1-185 5	0.79
927581	AC1-185 6	0.79
927591	AC1-185 7	0.79
927601	AC1-185 8	0.79
930481	AB1-089	75.67
930501	AB1-091 O1	88.22
930741	AB1-122 1O1	82.42
930751	AB1-122 2O1	84.95
932881	AC2-115 1	2.74
932891	AC2-115 2	2.74
932921	AC2-116	0.96
932931	AC2-117	5.81
933341	AC2-147 C	1.0
933342	AC2-147 E	1.64
933411	AC2-154 C	3.03

Bus #	Bus	MW Impact
933412	AC2-154 E	4.94
933431	AC2-156 C O1	1.1
933432	AC2-156 E O1	1.79
933911	AD1-013 C	2.12
933912	AD1-013 E	3.38
933931	AD1-016 C	1.07
933932	AD1-016 E	1.74
934101	AD1-039 1	8.08
934111	AD1-039 2	8.33
934401	AD1-064 C O1	3.69
934402	AD1-064 E O1	17.25
934431	AD1-067 C	0.15
934432	AD1-067 E	0.63
934651	AD1-096 C	1.03
934652	AD1-096 E	1.67
934701	AD1-098 C O1	7.91
934702	AD1-098 E O1	5.78
934721	AD1-100 C	22.45
934722	AD1-100 E	104.76
934871	AD1-116 C	1.09
934872	AD1-116 E	1.78
934881	AD1-117 C	6.19
934882	AD1-117 E	4.13
934971	AD1-129 C	1.04
934972	AD1-129 E	0.69
935001	AD1-133 C O1	24.06
935002	AD1-133 E O1	16.04
936291	AD2-038 C O1	2.69
936292	AD2-038 E O1	18.02
936371	AD2-047 C O1	2.71
936372	AD2-047 E O1	29.15
936461	AD2-060	3.19
936511	AD2-066 C O1	9.67
936512	AD2-066 E O1	6.45
936781	AD2-101 C	5.9
936782	AD2-101 E	27.62
936791	AD2-102 C	13.85
936792	AD2-102 E	13.3
936961	AD2-130	0.66
937001	AD2-134 C	3.14
937002	AD2-134 E	12.98
937031	AD2-137 C O1	4.08
937032	AD2-137 E O1	19.09
937051	AD2-140 C O1	4.11
937052	AD2-140 E O1	19.25
937061	AD2-141 C O1	4.09
937062	AD2-141 E O1	19.27
937071	AD2-142 C O1	8.22
937072	AD2-142 E O1	38.5
937121	AD2-148 C O1	4.23
937122	AD2-148 E O1	19.82
937131	AD2-149 C O1	4.23

Bus #	Bus	MW Impact
937132	AD2-149 E O1	19.82
937141	AD2-150 C O1	4.23
937142	AD2-150 E O1	19.82
937181	AD2-155 C O1	4.23
937182	AD2-155 E O1	19.82
937311	AD2-172 C	2.83
937312	AD2-172 E	3.91
937321	AD2-175 C	19.73
937322	AD2-175 E	13.15
937331	AD2-176 C O1	8.43
937332	AD2-176 E O1	5.62
937401	AD2-194 1	8.95
937411	AD2-194 2	8.95
937531	AD2-214 C	5.1
937532	AD2-214 E	2.4
938012	AE1-002 E O1	8.18
938511	AE1-070 1	10.52
938521	AE1-070 2	9.62
938851	AE1-113 C O1	10.1
938852	AE1-113 E O1	31.74
938861	AE1-114 C O1	4.14
938862	AE1-114 E O1	15.83
939051	AE1-134 1	1.58
939061	AE1-134 2	1.58
939321	AE1-163 C O1	6.77
939322	AE1-163 E O1	41.57
939351	AE1-166 C O1	11.8
939352	AE1-166 E O1	10.89
939401	AE1-172 C O1	7.21
939402	AE1-172 E O1	33.74
939631	AE1-193 C O1	4.73
939632	AE1-193 E O1	31.63
939641	AE1-194 C	10.24
939642	AE1-194 E	68.55
939651	AE1-195 C	10.24
939652	AE1-195 E	68.55
939681	AE1-198 C O1	23.78
939682	AE1-198 E O1	20.2
939691	AE1-199	2.75
939701	AE1-201 C	2.31
939702	AE1-201 E	0.51
939732	AE1-204 E	0.34
939861	AE1-222 1	91.02
939871	AE1-222 2	93.81
939921	AE1-228 C O1	11.56
939922	AE1-228 E O1	7.71
939961	AE1-233 C O1	2.67
939962	AE1-233 E O1	11.05
940101	AE1-252 C O1	12.28
940102	AE1-252 E O1	8.19
951721	J643	25.73
952581	J740 C	4.3

Bus #	Bus	MW Impact
952582	J740 E	23.28
953871	J847	13.1
954751	J351	434.54
AB2-013	AB2-013	18.6
AE1-033	AE1-033	20.85
BLUEG	BLUEG	1.07
CARR	CARR	0.9
CATAWBA	CATAWBA	0.22
CBM-S1	CBM-S1	3.95
CBM-W1	CBM-W1	35.83
CBM-W2	CBM-W2	81.92
CIN	CIN	3.3
DEARBORN	DEARBORN	4.0
G-007	G-007	2.51
HAMLET	HAMLET	0.96
IPL	IPL	1.12
MEC	MEC	44.69
O-066	O-066	8.44
RENSSELAER	RENSSELAER	0.71
TRIMBLE	TRIMBLE	0.16
WEC	WEC	9.2
Z1-043	Z1-043	32.93

Index 8

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
172688	270677	BURNHAM ;OR	CE	255109	17MUNSTER	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1441.0	113.05	113.71	DC	35.12

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	11.75
274722	S-055 E	10.96
274723	RIVER EC ;12	4.32
274792	SE CHICAG;9U	0.96
274793	SE CHICAG;0U	0.96
274794	SE CHICAG;1U	0.96
274795	SE CHICAG;2U	0.96
274832	U4-027	10.31
274859	EASYR;U1 E	10.61
274860	EASYR;U2 E	10.61
274888	PILOT HIL;1E	20.48
274890	CAYUG;1U E	13.4
274891	CAYUG;2U E	13.4
275149	KEMPTON ;1E	20.48
290021	O50 E	18.57
290051	GSG-6; E	10.13
290108	LEEDK;1U E	23.57
293061	N-015 E	14.82
293516	O-009 E1	8.7
293517	O-009 E2	4.42
293518	O-009 E3	4.87
293644	O22 E1	9.26
293645	O22 E2	17.98
293715	O-029 E	9.4
293716	O-029 E	5.15
293717	O-029 E	4.74
293771	O-035 E	6.09
294392	P-010 E	18.82
294763	P-046 E	9.07
295109	WESTBROOK E	5.42
295111	SUBLETTE E	2.5
296125	R-030 C3	3.43
296128	R-030 E3	13.71
296271	R-030 C2	3.39
296272	R-030 E2	13.54
296308	R-030 C1	3.39
296309	R-030 E1	13.54
910541	X3-005 C	0.08
910542	X3-005 E	0.91
914641	Y2-103	43.82
915011	Y3-013 1	3.65

Bus #	Bus	MW Impact
915021	Y3-013 2	3.65
915031	Y3-013 3	3.65
916211	Z1-072 E	4.61
916221	Z1-073 E	5.23
916502	Z1-106 E1	1.23
916504	Z1-106 E2	1.23
916512	Z1-107 E	2.58
916522	Z1-108 E	2.42
917502	Z2-087 E	8.96
918052	AA1-018 E	16.81
919221	AA1-146	16.93
919581	AA2-030	16.93
920272	AA2-123 E	2.37
924471	AB2-096	41.11
925161	AB2-173	3.02
925302	AB2-191 E	1.34
925881	AC1-067 O1	301.08
926311	AC1-109 1	1.86
926321	AC1-109 2	1.86
926331	AC1-110 1	1.85
926341	AC1-110 2	1.85
926351	AC1-111 1	0.75
926361	AC1-111 2	0.75
926371	AC1-111 3	0.75
926381	AC1-111 4	0.75
926391	AC1-111 5	0.75
926401	AC1-111 6	0.75
926431	AC1-114	2.31
926821	AC1-168 C O1	1.1
926822	AC1-168 E O1	7.36
927091	AC1-204 1	70.09
927101	AC1-204 2	70.14
927201	AC1-214 C O1	1.95
927202	AC1-214 E O1	6.21
927451	AC1-142A 1	4.09
927461	AC1-142A 2	4.09
927511	AC1-113 1	1.15
927521	AC1-113 2	1.15
927531	AC1-185 1	0.66
927541	AC1-185 2	0.66
927551	AC1-185 3	0.66
927561	AC1-185 4	0.66
927571	AC1-185 5	0.66
927581	AC1-185 6	0.66
927591	AC1-185 7	0.66
927601	AC1-185 8	0.66
930481	AB1-089	63.73
930501	AB1-091 O1	82.27
930741	AB1-122 1O1	70.02
930751	AB1-122 2O1	70.99
932881	AC2-115 1	2.31
932891	AC2-115 2	2.31

Bus #	Bus	MW Impact
932921	AC2-116	0.81
932931	AC2-117	5.3
933341	AC2-147 C	0.84
933342	AC2-147 E	1.37
933411	AC2-154 C	2.78
933412	AC2-154 E	4.53
933431	AC2-156 C O1	0.93
933432	AC2-156 E O1	1.52
933911	AD1-013 C	1.78
933912	AD1-013 E	2.85
933931	AD1-016 C	0.9
933932	AD1-016 E	1.47
934101	AD1-039 1	6.86
934111	AD1-039 2	6.96
934401	AD1-064 C O1	3.11
934402	AD1-064 E O1	14.56
934431	AD1-067 C	0.13
934432	AD1-067 E	0.53
934651	AD1-096 C	0.86
934652	AD1-096 E	1.41
934701	AD1-098 C O1	6.66
934702	AD1-098 E O1	4.86
934721	AD1-100 C	19.54
934722	AD1-100 E	91.19
934871	AD1-116 C	0.98
934872	AD1-116 E	1.6
934881	AD1-117 C	5.18
934882	AD1-117 E	3.46
934971	AD1-129 C	0.88
934972	AD1-129 E	0.58
935001	AD1-133 C O1	20.3
935002	AD1-133 E O1	13.53
936291	AD2-038 C O1	2.33
936292	AD2-038 E O1	15.58
936371	AD2-047 C O1	2.49
936372	AD2-047 E O1	26.77
936461	AD2-060	2.93
936511	AD2-066 C O1	8.14
936512	AD2-066 E O1	5.43
936781	AD2-101 C	4.75
936782	AD2-101 E	22.22
936791	AD2-102 C	11.64
936792	AD2-102 E	11.19
936961	AD2-130	0.56
937001	AD2-134 C	2.65
937002	AD2-134 E	10.94
937031	AD2-137 C O1	3.67
937032	AD2-137 E O1	17.17
937051	AD2-140 C O1	3.72
937052	AD2-140 E O1	17.42
937061	AD2-141 C O1	3.7
937062	AD2-141 E O1	17.44

Bus #	Bus	MW Impact
937071	AD2-142 C O1	7.44
937072	AD2-142 E O1	34.83
937121	AD2-148 C O1	3.94
937122	AD2-148 E O1	18.43
937131	AD2-149 C O1	3.94
937132	AD2-149 E O1	18.43
937141	AD2-150 C O1	3.94
937142	AD2-150 E O1	18.43
937181	AD2-155 C O1	3.94
937182	AD2-155 E O1	18.43
937311	AD2-172 C	2.38
937312	AD2-172 E	3.29
937321	AD2-175 C	18.34
937322	AD2-175 E	12.23
937331	AD2-176 C O1	7.12
937332	AD2-176 E O1	4.75
937401	AD2-194 1	7.54
937411	AD2-194 2	7.54
937531	AD2-214 C	4.24
937532	AD2-214 E	1.99
938012	AE1-002 E O1	7.36
938511	AE1-070 1	8.86
938521	AE1-070 2	8.11
938851	AE1-113 C O1	8.4
938852	AE1-113 E O1	26.41
938861	AE1-114 C O1	3.47
938862	AE1-114 E O1	13.28
939051	AE1-134 1	1.32
939061	AE1-134 2	1.32
939321	AE1-163 C O1	5.85
939322	AE1-163 E O1	35.94
939351	AE1-166 C O1	10.23
939352	AE1-166 E O1	9.45
939401	AE1-172 C O1	6.18
939402	AE1-172 E O1	28.94
939691	AE1-199	2.32
939701	AE1-201 C	1.95
939702	AE1-201 E	0.43
939732	AE1-204 E	0.28
939741	AE1-205 C O1	8.57
939742	AE1-205 E O1	11.84
939861	AE1-222 1	77.33
939871	AE1-222 2	78.4
939921	AE1-228 C O1	9.74
939922	AE1-228 E O1	6.49
939961	AE1-233 C O1	2.26
939962	AE1-233 E O1	9.34
940101	AE1-252 C O1	10.54
940102	AE1-252 E O1	7.02
AB2-013	AB2-013	15.32
AE1-033	AE1-033	17.49
BLUEG	BLUEG	5.47

Bus #	Bus	MW Impact
CALDERWOOD	CALDERWOOD	0.06
CANNELTON	CANNELTON	0.08
CARR	CARR	0.73
CATAWBA	CATAWBA	0.27
CBM-S1	CBM-S1	1.44
CBM-W1	CBM-W1	23.88
CBM-W2	CBM-W2	51.81
CHEOAH	CHEOAH	0.06
CHILHOWEE	CHILHOWEE	0.02
DEARBORN	DEARBORN	2.93
ELMERSMITH	ELMERSMITH	0.08
G-007	G-007	2.03
GIBSON	GIBSON	0.04
HAMLET	HAMLET	1.05
MEC	MEC	36.09
O-066	O-066	6.84
RENSSELAER	RENSSELAER	0.58
SANTEETLA	SANTEETLA	0.02
TRIMBLE	TRIMBLE	0.65
WEC	WEC	7.74
Z1-043	Z1-043	27.27

Index 9

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
172671	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	111.15	112.1	DC	35.54

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	12.73
274654	BRAIDWOOD;1U	27.26
274655	BRAIDWOOD;2U	26.09
274660	LASCO STA;1U	24.9
274661	LASCO STA;2U	24.94
274675	JOLIET 29;7U	11.25
274676	JOLIET 29;8U	11.26
274687	WILL CNTY;4U	11.37
274704	KENDALL ;1C	4.0
274705	KENDALL ;1S	2.67
274706	KENDALL ;2C	4.0
274707	KENDALL ;2S	2.67
274722	S-055 E	11.91
274736	ELWOOD EC;9P	3.23
274832	U4-027	11.21
274859	EASYR;U1 E	11.52
274860	EASYR;U2 E	11.52
274861	TOP CROP ;1U	0.47
274862	TOP CROP ;2U	0.92
274888	PILOT HIL;1E	17.1
274890	CAYUG;1U E	13.64
274891	CAYUG;2U E	13.64
275149	KEMPTON ;1E	17.1
290021	O50 E	20.79
290051	GSG-6; E	10.94
290108	LEEDK;1U E	25.43
293061	N-015 E	16.43
293516	O-009 E1	9.45
293517	O-009 E2	4.8
293518	O-009 E3	5.29
293644	O22 E1	12.34
293645	O22 E2	23.96
293715	O-029 E	10.21
293716	O-029 E	5.6
293717	O-029 E	5.15
293771	O-035 E	6.61
294392	P-010 E	20.87
294763	P-046 E	9.84
295109	WESTBROOK E	5.86
295111	SUBLETTE E	2.71

Bus #	Bus	MW Impact
914641	Y2-103	47.64
915011	Y3-013 1	3.97
915021	Y3-013 2	3.97
915031	Y3-013 3	3.97
916211	Z1-072 E	5.0
916221	Z1-073 E	5.65
916502	Z1-106 E1	1.33
916504	Z1-106 E2	1.33
916512	Z1-107 E	2.55
916522	Z1-108 E	2.62
918052	AA1-018 E	16.2
919221	AA1-146	18.41
919581	AA2-030	18.41
920272	AA2-123 E	2.57
924471	AB2-096	44.55
925161	AB2-173	3.28
925302	AB2-191 E	1.45
925581	AC1-033 C	1.45
925582	AC1-033 E	9.71
926311	AC1-109 1	2.0
926321	AC1-109 2	2.0
926331	AC1-110 1	2.0
926341	AC1-110 2	2.0
926351	AC1-111 1	0.8
926361	AC1-111 2	0.8
926371	AC1-111 3	0.8
926381	AC1-111 4	0.8
926391	AC1-111 5	0.8
926401	AC1-111 6	0.8
926431	AC1-114	2.5
926821	AC1-168 C O1	1.2
926822	AC1-168 E O1	8.03
927091	AC1-204 1	78.31
927101	AC1-204 2	78.18
927201	AC1-214 C O1	2.12
927202	AC1-214 E O1	6.75
927451	AC1-142A 1	4.53
927461	AC1-142A 2	4.53
927511	AC1-113 1	1.25
927521	AC1-113 2	1.25
927531	AC1-185 1	0.72
927541	AC1-185 2	0.72
927551	AC1-185 3	0.72
927561	AC1-185 4	0.72
927571	AC1-185 5	0.72
927581	AC1-185 6	0.72
927591	AC1-185 7	0.72
927601	AC1-185 8	0.72
930481	AB1-089	69.1
930501	AB1-091 O1	67.39
930741	AB1-122 1O1	74.68
930751	AB1-122 2O1	79.86

Bus #	Bus	MW Impact
932881	AC2-115 1	2.5
932891	AC2-115 2	2.5
932921	AC2-116	0.88
933341	AC2-147 C	0.91
933342	AC2-147 E	1.49
933411	AC2-154 C	2.32
933412	AC2-154 E	3.79
933431	AC2-156 C O1	1.0
933432	AC2-156 E O1	1.63
933911	AD1-013 C	1.93
933912	AD1-013 E	3.08
933931	AD1-016 C	0.98
933932	AD1-016 E	1.6
934101	AD1-039 1	7.32
934111	AD1-039 2	7.83
934401	AD1-064 C O1	3.37
934402	AD1-064 E O1	15.78
934431	AD1-067 C	0.14
934432	AD1-067 E	0.58
934651	AD1-096 C	0.94
934652	AD1-096 E	1.53
934701	AD1-098 C O1	7.2
934702	AD1-098 E O1	5.26
934721	AD1-100 C	19.95
934722	AD1-100 E	93.11
934871	AD1-116 C	0.94
934872	AD1-116 E	1.54
934881	AD1-117 C	5.63
934882	AD1-117 E	3.75
934971	AD1-129 C	0.95
934972	AD1-129 E	0.63
935001	AD1-133 C O1	21.34
935002	AD1-133 E O1	14.23
936291	AD2-038 C O1	2.41
936292	AD2-038 E O1	16.1
936371	AD2-047 C O1	2.08
936372	AD2-047 E O1	22.36
936461	AD2-060	2.44
936511	AD2-066 C O1	8.72
936512	AD2-066 E O1	5.81
936781	AD2-101 C	3.97
936782	AD2-101 E	18.57
936791	AD2-102 C	12.63
936792	AD2-102 E	12.14
936961	AD2-130	0.59
937001	AD2-134 C	2.86
937002	AD2-134 E	11.82
937031	AD2-137 C O1	3.34
937032	AD2-137 E O1	15.64
937051	AD2-140 C O1	3.33
937052	AD2-140 E O1	15.57
937061	AD2-141 C O1	3.31

Bus #	Bus	MW Impact
937062	AD2-141 E O1	15.59
937071	AD2-142 C O1	6.65
937072	AD2-142 E O1	31.14
937121	AD2-148 C O1	3.24
937122	AD2-148 E O1	15.15
937131	AD2-149 C O1	3.24
937132	AD2-149 E O1	15.15
937141	AD2-150 C O1	3.24
937142	AD2-150 E O1	15.15
937181	AD2-155 C O1	3.24
937182	AD2-155 E O1	15.15
937311	AD2-172 C	2.58
937312	AD2-172 E	3.57
937321	AD2-175 C	15.07
937322	AD2-175 E	10.05
937331	AD2-176 C O1	7.72
937332	AD2-176 E O1	5.15
937401	AD2-194 1	8.42
937411	AD2-194 2	8.41
937531	AD2-214 C	4.61
937532	AD2-214 E	2.17
938012	AE1-002 E O1	6.71
938511	AE1-070 1	9.9
938521	AE1-070 2	9.04
938851	AE1-113 C O1	9.41
938852	AE1-113 E O1	29.58
938861	AE1-114 C O1	3.77
938862	AE1-114 E O1	14.41
939051	AE1-134 1	1.43
939061	AE1-134 2	1.43
939321	AE1-163 C O1	6.04
939322	AE1-163 E O1	37.13
939351	AE1-166 C O1	10.67
939352	AE1-166 E O1	9.85
939401	AE1-172 C O1	6.26
939402	AE1-172 E O1	29.29
939631	AE1-193 C O1	1.03
939632	AE1-193 E O1	6.9
939681	AE1-198 C O1	21.36
939682	AE1-198 E O1	18.15
939691	AE1-199	2.5
939701	AE1-201 C	2.11
939702	AE1-201 E	0.46
939732	AE1-204 E	0.31
939861	AE1-222 1	82.47
939871	AE1-222 2	88.2
939921	AE1-228 C O1	10.52
939922	AE1-228 E O1	7.01
939961	AE1-233 C O1	2.44
939962	AE1-233 E O1	10.07
940101	AE1-252 C O1	10.66
940102	AE1-252 E O1	7.11

Bus #	Bus	MW Impact
AB2-013	AB2-013	16.84
AE1-033	AE1-033	19.0
BLUEG	BLUEG	5.85
CALDERWOOD	CALDERWOOD	0.03
CANNELTON	CANNELTON	0.09
CARR	CARR	0.74
CATAWBA	CATAWBA	0.27
CBM-S1	CBM-S1	1.66
CBM-W1	CBM-W1	26.48
CBM-W2	CBM-W2	55.79
CHEOAH	CHEOAH	0.04
CHILHOWEE	CHILHOWEE	0.01
DEARBORN	DEARBORN	3.02
ELMERSMITH	ELMERSMITH	0.09
G-007	G-007	2.06
GIBSON	GIBSON	0.05
HAMLET	HAMLET	1.03
MEC	MEC	39.2
O-066	O-066	6.93
RENSSELAER	RENSSELAER	0.58
SANTEETLA	SANTEETLA	0.01
TRIMBLE	TRIMBLE	0.69
WEC	WEC	8.42
Z1-043	Z1-043	29.68

Index 10

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
779444	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	116.01	116.74	DC	23.27

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	8.06
274722	S-055 E	7.52
274751	CRETE EC ;1U	1.93
274752	CRETE EC ;2U	1.93
274753	CRETE EC ;3U	1.93
274754	CRETE EC ;4U	1.93
274832	U4-027	7.11
274859	EASYR;U1 E	7.3
274860	EASYR;U2 E	7.3
274888	PILOT HIL;1E	12.4
274890	CAYUG;1U E	8.92
274891	CAYUG;2U E	8.92
275149	KEMPTON ;1E	12.4
290021	O50 E	12.98
290051	GSG-6; E	6.94
290108	LEEDK;1U E	16.14
293061	N-015 E	10.24
293516	O-009 E1	5.99
293517	O-009 E2	3.04
293518	O-009 E3	3.35
293644	O22 E1	7.24
293645	O22 E2	14.06
293715	O-029 E	6.47
293716	O-029 E	3.55
293717	O-029 E	3.26
294392	P-010 E	13.0
294763	P-046 E	6.23
295109	WESTBROOK E	3.72
295111	SUBLETTE E	1.72
910542	X3-005 E	0.52
914641	Y2-103	30.09
915011	Y3-013 1	2.51
915021	Y3-013 2	2.51
915031	Y3-013 3	2.51
916221	Z1-073 E	3.58
916502	Z1-106 E1	0.84
916504	Z1-106 E2	0.84
916512	Z1-107 E	1.71
916522	Z1-108 E	1.66
918052	AA1-018 E	10.62
919221	AA1-146	11.67

Bus #	Bus	MW Impact
919581	AA2-030	11.67
920272	AA2-123 E	1.63
924471	AB2-096	28.21
925161	AB2-173	2.08
925302	AB2-191 E	0.92
925881	AC1-067 O1	102.57
926311	AC1-109 1	1.27
926321	AC1-109 2	1.27
926331	AC1-110 1	1.27
926341	AC1-110 2	1.27
926351	AC1-111 1	0.51
926361	AC1-111 2	0.51
926371	AC1-111 3	0.51
926381	AC1-111 4	0.51
926391	AC1-111 5	0.51
926401	AC1-111 6	0.51
926431	AC1-114	1.58
926821	AC1-168 C O1	0.76
926822	AC1-168 E O1	5.08
927091	AC1-204 1	48.76
927101	AC1-204 2	48.73
927201	AC1-214 C O1	0.74
927202	AC1-214 E O1	2.34
927451	AC1-142A 1	2.83
927461	AC1-142A 2	2.83
927511	AC1-113 1	0.79
927521	AC1-113 2	0.79
927531	AC1-185 1	0.46
927541	AC1-185 2	0.46
927551	AC1-185 3	0.46
927561	AC1-185 4	0.46
927571	AC1-185 5	0.46
927581	AC1-185 6	0.46
927591	AC1-185 7	0.46
927601	AC1-185 8	0.46
930481	AB1-089	43.76
930501	AB1-091 O1	49.15
930741	AB1-122 1O1	47.58
930751	AB1-122 2O1	49.75
932881	AC2-115 1	1.58
932891	AC2-115 2	1.58
932921	AC2-116	0.55
933341	AC2-147 C	0.58
933342	AC2-147 E	0.94
933411	AC2-154 C	1.68
933412	AC2-154 E	2.75
933431	AC2-156 C O1	0.64
933432	AC2-156 E O1	1.04
933911	AD1-013 C	1.22
933912	AD1-013 E	1.95
933931	AD1-016 C	0.62
933932	AD1-016 E	1.01

Bus #	Bus	MW Impact
934101	AD1-039 1	4.66
934111	AD1-039 2	4.88
934401	AD1-064 C O1	2.13
934402	AD1-064 E O1	9.99
934431	AD1-067 C	0.09
934432	AD1-067 E	0.37
934651	AD1-096 C	0.59
934652	AD1-096 E	0.97
934701	AD1-098 C O1	4.57
934702	AD1-098 E O1	3.34
934721	AD1-100 C	12.94
934722	AD1-100 E	60.39
934871	AD1-116 C	0.62
934872	AD1-116 E	1.01
934881	AD1-117 C	3.57
934882	AD1-117 E	2.38
934971	AD1-129 C	0.6
934972	AD1-129 E	0.4
935001	AD1-133 C O1	13.73
935002	AD1-133 E O1	9.15
936291	AD2-038 C O1	1.54
936292	AD2-038 E O1	10.32
936371	AD2-047 C O1	1.51
936372	AD2-047 E O1	16.21
936461	AD2-060	1.77
936511	AD2-066 C O1	5.56
936512	AD2-066 E O1	3.71
936781	AD2-101 C	3.17
936782	AD2-101 E	14.84
936791	AD2-102 C	8.0
936792	AD2-102 E	7.69
936961	AD2-130	0.38
937001	AD2-134 C	1.82
937002	AD2-134 E	7.5
937031	AD2-137 C O1	2.31
937032	AD2-137 E O1	10.8
937051	AD2-140 C O1	2.32
937052	AD2-140 E O1	10.87
937061	AD2-141 C O1	2.31
937062	AD2-141 E O1	10.88
937071	AD2-142 C O1	4.64
937072	AD2-142 E O1	21.73
937121	AD2-148 C O1	2.36
937122	AD2-148 E O1	11.04
937131	AD2-149 C O1	2.36
937132	AD2-149 E O1	11.04
937141	AD2-150 C O1	2.36
937142	AD2-150 E O1	11.04
937181	AD2-155 C O1	2.36
937182	AD2-155 E O1	11.04
937311	AD2-172 C	1.64
937312	AD2-172 E	2.26

Bus #	Bus	MW Impact
937321	AD2-175 C	10.99
937322	AD2-175 E	7.33
937331	AD2-176 C O1	4.89
937332	AD2-176 E O1	3.26
937401	AD2-194 1	5.24
937411	AD2-194 2	5.24
937531	AD2-214 C	2.92
937532	AD2-214 E	1.37
938012	AE1-002 E O1	4.63
938511	AE1-070 1	6.16
938521	AE1-070 2	5.63
938851	AE1-113 C O1	5.88
938852	AE1-113 E O1	18.47
938861	AE1-114 C O1	2.39
938862	AE1-114 E O1	9.13
939051	AE1-134 1	0.91
939061	AE1-134 2	0.91
939321	AE1-163 C O1	3.87
939322	AE1-163 E O1	23.79
939351	AE1-166 C O1	6.84
939352	AE1-166 E O1	6.31
939401	AE1-172 C O1	4.1
939402	AE1-172 E O1	19.18
939641	AE1-194 C	10.88
939642	AE1-194 E	72.84
939651	AE1-195 C	10.88
939652	AE1-195 E	72.84
939691	AE1-199	1.59
939701	AE1-201 C	1.34
939702	AE1-201 E	0.29
939732	AE1-204 E	0.2
939861	AE1-222 1	52.55
939871	AE1-222 2	54.95
939921	AE1-228 C O1	6.68
939922	AE1-228 E O1	4.45
939961	AE1-233 C O1	1.55
939962	AE1-233 E O1	6.39
940101	AE1-252 C O1	6.98
940102	AE1-252 E O1	4.65
951721	J643	15.51
952581	J740 C	3.4
952582	J740 E	18.42
953871	J847	8.38
AB2-013	AB2-013	10.64
AE1-033	AE1-033	12.03
BLUEG	BLUEG	2.86
CANNELTON	CANNELTON	0.0
CARR	CARR	0.5
CATAWBA	CATAWBA	0.16
CBM-S1	CBM-S1	1.36
CBM-W1	CBM-W1	19.98
CBM-W2	CBM-W2	38.44

Bus #	Bus	MW Impact
CIN	CIN	0.12
DEARBORN	DEARBORN	2.29
G-007	G-007	1.38
HAMLET	HAMLET	0.65
MEC	MEC	25.05
O-066	O-066	4.65
RENSSELAER	RENSSELAER	0.39
SANTEETLA	SANTEETLA	0.0
TRIMBLE	TRIMBLE	0.34
WEC	WEC	5.32
Z1-043	Z1-043	18.82

Index 11

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
173042	270853	PONTIAC ; R	CE	935000	AD1-133 TAP	CE	1	COMED_P1-2_345-L11212_B-S-C-A	single	1528.0	100.37	101.98	DC	24.59

Bus #	Bus	MW Impact
274650	KINCAID ;1U	15.48
274651	KINCAID ;2U	15.51
274853	TWINGROVE;U1	2.3
274854	TWINGROVE;U2	2.3
274863	CAYUGA RI;1U	2.14
274864	CAYUGA RI;2U	2.14
900404	X3-028 C	78.36
905081	W4-005 C	2.19
917501	Z2-087 C	1.85
924041	AB2-047 C O1	14.84
924261	AB2-070 C O1	6.98
925771	AC1-053 C	6.83
926841	AC1-171 C O1	0.75
930461	AB1-087	28.73
930471	AB1-088	28.73
933441	AC2-157 C	3.97
935141	AD1-148	12.29
936771	AD2-100 C O1	25.48
937161	AD2-153 C O1	9.91
937171	AD2-154 C O1	9.91
937211	AD2-159 C	10.33
939401	AE1-172 C O1	24.59
939741	AE1-205 C O1	39.11
940101	AE1-252 C O1	41.91
950701	J196 C	1.11
951001	J339	12.11
951741	J474 C	4.81
952271	J644	12.24
952321	J734	10.17
952651	J756 C	4.36
952871	J757 C	5.2
953241	J467 C	1.73
953401	J811	10.29
953651	J815	34.83
953741	J826 C	3.01
953801	J835 C	3.42
953851	J845 C	2.96
953881	J848 C	5.38
954081	J872 C	4.15
954181	J884	24.98

Bus #	Bus	MW Impact
954411	J912	13.29
954721	J750 C	3.3
954761	J468 C	3.94
AD2-098	AD2-098	0.45
AE1-042	AE1-042	5.79
CBM-N	CBM-N	0.66
CBM-S1	CBM-S1	9.87
CBM-S2	CBM-S2	3.13
CBM-W2	CBM-W2	111.77
CIN	CIN	10.82
CPLE	CPLE	1.12
DEARBORN	DEARBORN	0.52
EDWARDS	EDWARDS	0.05
G-007A	G-007A	2.18
IPL	IPL	5.9
LGEE	LGEE	1.65
MEC	MEC	2.66
NYISO	NYISO	2.85
O-066A	O-066A	1.01
TATANKA	TATANKA	0.42
VFT	VFT	5.85

Index 12

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
172518	270886	ST JOHN ; T	CE	255104	17GREEN_ACRE	NIPS	1	COMED_P4_023-65-BT2-3__	breaker	1091.0	111.32	112.12	DC	25.42

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	9.04
274654	BRAIDWOOD;1U	19.05
274655	BRAIDWOOD;2U	18.24
274661	LASCO STA;2U	17.6
274687	WILL CNTY;4U	8.03
274704	KENDALL ;1C	2.81
274705	KENDALL ;1S	1.88
274706	KENDALL ;2C	2.81
274707	KENDALL ;2S	1.88
274722	S-055 E	8.45
274751	CRETE EC ;1U	3.36
274752	CRETE EC ;2U	3.36
274753	CRETE EC ;3U	3.36
274754	CRETE EC ;4U	3.36
274859	EASYR;U1 E	8.17
274860	EASYR;U2 E	8.17
274861	TOP CROP ;1U	0.33
274862	TOP CROP ;2U	0.63
274888	PILOT HIL;1E	12.81
274890	CAYUG;1U E	9.74
274891	CAYUG;2U E	9.74
275149	KEMPTON ;1E	12.81
290021	O50 E	14.65
290051	GSG-6; E	7.78
290108	LEEDK;1U E	18.09
293061	N-015 E	11.61
293516	O-009 E1	6.69
293517	O-009 E2	3.4
293518	O-009 E3	3.74
293644	O22 E1	8.5
293645	O22 E2	16.51
293715	O-029 E	7.24
293716	O-029 E	3.97
293717	O-029 E	3.65
294392	P-010 E	14.75
294763	P-046 E	6.98
295109	WESTBROOK E	4.16
295111	SUBLETTE E	1.92
914641	Y2-103	33.8
915011	Y3-013 1	2.82

Bus #	Bus	MW Impact
915021	Y3-013 2	2.82
915031	Y3-013 3	2.82
916221	Z1-073 E	4.01
916502	Z1-106 E1	0.94
916504	Z1-106 E2	0.94
916512	Z1-107 E	1.85
916522	Z1-108 E	1.86
918052	AA1-018 E	11.64
919221	AA1-146	13.04
919581	AA2-030	13.04
920272	AA2-123 E	1.83
924471	AB2-096	31.63
925161	AB2-173	2.33
925302	AB2-191 E	1.03
926311	AC1-109 1	1.42
926321	AC1-109 2	1.42
926331	AC1-110 1	1.42
926341	AC1-110 2	1.42
926351	AC1-111 1	0.57
926361	AC1-111 2	0.57
926371	AC1-111 3	0.57
926381	AC1-111 4	0.57
926391	AC1-111 5	0.57
926401	AC1-111 6	0.57
926431	AC1-114	1.77
926821	AC1-168 C O1	0.85
926822	AC1-168 E O1	5.68
927091	AC1-204 1	55.19
927101	AC1-204 2	55.12
927451	AC1-142A 1	3.2
927461	AC1-142A 2	3.2
927511	AC1-113 1	0.89
927521	AC1-113 2	0.89
927531	AC1-185 1	0.51
927541	AC1-185 2	0.51
927551	AC1-185 3	0.51
927561	AC1-185 4	0.51
927571	AC1-185 5	0.51
927581	AC1-185 6	0.51
927591	AC1-185 7	0.51
927601	AC1-185 8	0.51
930481	AB1-089	49.05
930501	AB1-091 O1	50.61
930741	AB1-122 1O1	52.99
930751	AB1-122 2O1	56.33
932881	AC2-115 1	1.77
932891	AC2-115 2	1.77
932921	AC2-116	0.62
933341	AC2-147 C	0.65
933342	AC2-147 E	1.06
933411	AC2-154 C	1.74
933412	AC2-154 E	2.84

Bus #	Bus	MW Impact
933431	AC2-156 C O1	0.71
933432	AC2-156 E O1	1.16
933911	AD1-013 C	1.37
933912	AD1-013 E	2.19
933931	AD1-016 C	0.69
933932	AD1-016 E	1.13
934101	AD1-039 1	5.19
934111	AD1-039 2	5.52
934401	AD1-064 C O1	2.39
934402	AD1-064 E O1	11.2
934431	AD1-067 C	0.1
934432	AD1-067 E	0.41
934651	AD1-096 C	0.66
934652	AD1-096 E	1.08
934701	AD1-098 C O1	5.12
934702	AD1-098 E O1	3.74
934721	AD1-100 C	14.27
934722	AD1-100 E	66.6
934871	AD1-116 C	0.68
934872	AD1-116 E	1.11
934881	AD1-117 C	3.99
934882	AD1-117 E	2.66
934971	AD1-129 C	0.67
934972	AD1-129 E	0.45
935001	AD1-133 C O1	15.16
935002	AD1-133 E O1	10.11
936291	AD2-038 C O1	1.71
936292	AD2-038 E O1	11.45
936371	AD2-047 C O1	1.56
936372	AD2-047 E O1	16.75
936461	AD2-060	1.83
936511	AD2-066 C O1	6.19
936512	AD2-066 E O1	4.13
936781	AD2-101 C	3.09
936782	AD2-101 E	14.46
936791	AD2-102 C	8.96
936792	AD2-102 E	8.61
936961	AD2-130	0.42
937001	AD2-134 C	2.03
937002	AD2-134 E	8.4
937031	AD2-137 C O1	2.44
937032	AD2-137 E O1	11.43
937051	AD2-140 C O1	2.44
937052	AD2-140 E O1	11.42
937061	AD2-141 C O1	2.43
937062	AD2-141 E O1	11.44
937071	AD2-142 C O1	4.88
937072	AD2-142 E O1	22.85
937121	AD2-148 C O1	2.43
937122	AD2-148 E O1	11.37
937131	AD2-149 C O1	2.43
937132	AD2-149 E O1	11.37

Bus #	Bus	MW Impact
937141	AD2-150 C O1	2.43
937142	AD2-150 E O1	11.37
937181	AD2-155 C O1	2.43
937182	AD2-155 E O1	11.37
937311	AD2-172 C	1.83
937312	AD2-172 E	2.53
937321	AD2-175 C	11.32
937322	AD2-175 E	7.55
937331	AD2-176 C O1	5.48
937332	AD2-176 E O1	3.65
937401	AD2-194 1	5.94
937411	AD2-194 2	5.93
937531	AD2-214 C	0.8
937532	AD2-214 E	0.38
938012	AE1-002 E O1	4.9
938511	AE1-070 1	6.97
938521	AE1-070 2	6.37
938851	AE1-113 C O1	6.63
938852	AE1-113 E O1	20.84
938861	AE1-114 C O1	2.67
938862	AE1-114 E O1	10.22
939051	AE1-134 1	1.01
939061	AE1-134 2	1.01
939321	AE1-163 C O1	4.3
939322	AE1-163 E O1	26.41
939351	AE1-166 C O1	7.6
939352	AE1-166 E O1	7.02
939401	AE1-172 C O1	4.47
939402	AE1-172 E O1	20.95
939641	AE1-194 C	18.96
939642	AE1-194 E	126.86
939651	AE1-195 C	18.96
939652	AE1-195 E	126.86
939691	AE1-199	1.78
939701	AE1-201 C	1.5
939702	AE1-201 E	0.33
939732	AE1-204 E	0.22
939861	AE1-222 1	58.52
939871	AE1-222 2	62.2
939921	AE1-228 C O1	7.48
939922	AE1-228 E O1	4.99
939961	AE1-233 C O1	1.73
939962	AE1-233 E O1	7.16
940101	AE1-252 C O1	7.63
940102	AE1-252 E O1	5.08
AB2-013	AB2-013	11.87
AE1-033	AE1-033	13.47
BLUEG	BLUEG	5.05
CALDERWOOD	CALDERWOOD	0.09
CANNELTON	CANNELTON	0.11
CARR	CARR	0.56
CATAWBA	CATAWBA	0.23

Bus #	Bus	MW Impact
CBM-S1	CBM-S1	0.77
CBM-W1	CBM-W1	20.04
CBM-W2	CBM-W2	37.14
CHEOAH	CHEOAH	0.09
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.24
ELMERSMITH	ELMERSMITH	0.14
G-007	G-007	1.57
GIBSON	GIBSON	0.06
HAMLET	HAMLET	0.87
MEC	MEC	27.58
O-066	O-066	5.3
RENSSELAER	RENSSELAER	0.45
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.59
WEC	WEC	5.97
Z1-043	Z1-043	20.98

Index 13

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
172378	270926	WILTON ; B	CE	275232	WILTON ;3M	CE	1	COMED_P4_112-65-BT5-6__	breaker	1379.0	166.14	166.79	DC	54.08

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	14.81
274722	S-055 E	13.75
274772	LINCOLN ;3U	3.36
274773	LINCOLN ;4U	3.36
274774	LINCOLN ;5U	3.36
274775	LINCOLN ;6U	3.36
274776	LINCOLN ;7U	3.36
274777	LINCOLN ;8U	3.36
274859	EASYR;U1 E	13.46
274860	EASYR;U2 E	13.46
274888	PILOT HIL;1E	23.62
274890	CAYUG;1U E	20.25
274891	CAYUG;2U E	20.25
275149	KEMPTON ;1E	23.62
290021	O50 E	23.75
290051	GSG-6; E	12.8
290108	LEEDK;1U E	29.74
293061	N-015 E	19.44
293516	O-009 E1	1.0
293517	O-009 E2	0.51
293518	O-009 E3	0.56
293644	O22 E1	12.55
293645	O22 E2	24.37
293715	O-029 E	11.98
293716	O-029 E	6.57
293717	O-029 E	6.04
294392	P-010 E	24.69
294763	P-046 E	11.48
295109	WESTBROOK E	6.85
295111	SUBLETTE E	3.18
296125	R-030 C3	4.98
296128	R-030 E3	19.93
296271	R-030 C2	4.92
296272	R-030 E2	19.7
296308	R-030 C1	4.92
296309	R-030 E1	19.7
910542	X3-005 E	0.9
914641	Y2-103	55.02
915011	Y3-013 1	4.58
915021	Y3-013 2	4.58
915031	Y3-013 3	4.58

Bus #	Bus	MW Impact
916221	Z1-073 E	6.61
916502	Z1-106 E1	1.55
916504	Z1-106 E2	1.55
916512	Z1-107 E	3.17
916522	Z1-108 E	3.04
917502	Z2-087 E	25.76
918052	AA1-018 E	20.13
919221	AA1-146	21.54
919581	AA2-030	21.54
920272	AA2-123 E	2.99
924041	AB2-047 C O1	4.75
924042	AB2-047 E O1	31.79
924471	AB2-096	51.84
925161	AB2-173	3.84
925302	AB2-191 E	1.7
925881	AC1-067 O1	168.51
926311	AC1-109 1	2.34
926321	AC1-109 2	2.34
926331	AC1-110 1	2.33
926341	AC1-110 2	2.33
926351	AC1-111 1	0.94
926361	AC1-111 2	0.94
926371	AC1-111 3	0.94
926381	AC1-111 4	0.94
926391	AC1-111 5	0.94
926401	AC1-111 6	0.94
926431	AC1-114	2.91
926821	AC1-168 C O1	1.43
926822	AC1-168 E O1	9.59
927091	AC1-204 1	88.93
927101	AC1-204 2	88.93
927451	AC1-142A 1	5.12
927461	AC1-142A 2	5.12
927511	AC1-113 1	1.46
927521	AC1-113 2	1.46
927531	AC1-185 1	0.84
927541	AC1-185 2	0.84
927551	AC1-185 3	0.84
927561	AC1-185 4	0.84
927571	AC1-185 5	0.84
927581	AC1-185 6	0.84
927591	AC1-185 7	0.84
927601	AC1-185 8	0.84
930481	AB1-089	80.5
930501	AB1-091 O1	93.97
930741	AB1-122 1O1	89.35
930751	AB1-122 2O1	90.31
932881	AC2-115 1	2.91
932891	AC2-115 2	2.91
932921	AC2-116	1.02
932931	AC2-117	6.52
933341	AC2-147 C	1.07

Bus #	Bus	MW Impact
933342	AC2-147 E	1.74
933411	AC2-154 C	3.21
933412	AC2-154 E	5.23
933431	AC2-156 C O1	1.17
933432	AC2-156 E O1	1.91
933911	AD1-013 C	2.25
933912	AD1-013 E	3.6
933931	AD1-016 C	1.14
933932	AD1-016 E	1.85
934101	AD1-039 1	8.76
934111	AD1-039 2	8.85
934401	AD1-064 C O1	3.92
934402	AD1-064 E O1	18.37
934431	AD1-067 C	0.16
934432	AD1-067 E	0.68
934651	AD1-096 C	1.09
934652	AD1-096 E	1.78
934701	AD1-098 C O1	8.43
934702	AD1-098 E O1	6.15
934721	AD1-100 C	29.44
934722	AD1-100 E	137.37
934871	AD1-116 C	1.17
934872	AD1-116 E	1.91
934881	AD1-117 C	6.58
934882	AD1-117 E	4.39
934971	AD1-129 C	1.11
934972	AD1-129 E	0.74
935001	AD1-133 C O1	27.42
935002	AD1-133 E O1	18.28
936291	AD2-038 C O1	2.88
936292	AD2-038 E O1	19.29
936371	AD2-047 C O1	2.87
936372	AD2-047 E O1	30.87
936461	AD2-060	3.37
936511	AD2-066 C O1	10.36
936512	AD2-066 E O1	6.91
936781	AD2-101 C	5.83
936782	AD2-101 E	27.31
936791	AD2-102 C	14.71
936792	AD2-102 E	14.14
936961	AD2-130	0.69
937001	AD2-134 C	3.35
937002	AD2-134 E	13.82
937031	AD2-137 C O1	7.17
937032	AD2-137 E O1	33.59
937051	AD2-140 C O1	7.53
937052	AD2-140 E O1	35.28
937061	AD2-141 C O1	7.49
937062	AD2-141 E O1	35.32
937071	AD2-142 C O1	15.07
937072	AD2-142 E O1	70.55
937121	AD2-148 C O1	4.51

Bus #	Bus	MW Impact
937122	AD2-148 E O1	21.13
937131	AD2-149 C O1	4.51
937132	AD2-149 E O1	21.13
937141	AD2-150 C O1	4.51
937142	AD2-150 E O1	21.13
937181	AD2-155 C O1	4.51
937182	AD2-155 E O1	21.13
937311	AD2-172 C	3.01
937312	AD2-172 E	4.16
937321	AD2-175 C	21.03
937322	AD2-175 E	14.02
937331	AD2-176 C O1	8.97
937332	AD2-176 E O1	5.98
937401	AD2-194 1	9.56
937411	AD2-194 2	9.56
938012	AE1-002 E O1	14.4
938511	AE1-070 1	11.24
938521	AE1-070 2	10.28
938851	AE1-113 C O1	10.75
938852	AE1-113 E O1	33.78
938861	AE1-114 C O1	4.4
938862	AE1-114 E O1	16.84
939051	AE1-134 1	1.67
939061	AE1-134 2	1.67
939321	AE1-163 C O1	7.24
939322	AE1-163 E O1	44.49
939351	AE1-166 C O1	14.52
939352	AE1-166 E O1	13.41
939401	AE1-172 C O1	9.52
939402	AE1-172 E O1	44.57
939691	AE1-199	2.93
939701	AE1-201 C	2.45
939702	AE1-201 E	0.54
939732	AE1-204 E	0.36
939741	AE1-205 C O1	12.48
939742	AE1-205 E O1	17.23
939861	AE1-222 1	98.68
939871	AE1-222 2	99.73
939921	AE1-228 C O1	12.31
939922	AE1-228 E O1	8.21
939961	AE1-233 C O1	2.85
939962	AE1-233 E O1	11.77
940101	AE1-252 C O1	16.23
940102	AE1-252 E O1	10.82
AB2-013	AB2-013	19.85
AE1-033	AE1-033	22.1
BLUEG	BLUEG	7.86
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.96
CATAWBA	CATAWBA	0.38
CBM-S1	CBM-S1	1.85

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	37.32
CBM-W2	CBM-W2	71.02
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.9
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.69
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.46
MEC	MEC	46.58
O-066	O-066	9.06
RENSSELAER	RENSSELAER	0.76
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.94
WEC	WEC	9.75
Z1-043	Z1-043	35.51

Index 14

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
172380	270927	WILTON	CE	275233	WILTON	CE	1	COMED_P4_112-65-BT2-3__	breaker	1379.0	164.04	164.99	DC	55.15

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	15.13
274722	S-055 E	14.05
274772	LINCOLN ;3U	3.45
274773	LINCOLN ;4U	3.45
274774	LINCOLN ;5U	3.45
274775	LINCOLN ;6U	3.45
274776	LINCOLN ;7U	3.45
274777	LINCOLN ;8U	3.45
274832	U4-027	6.82
274859	EASYR;U1 E	13.75
274860	EASYR;U2 E	13.75
274888	PILOT HIL;1E	24.11
274890	CAYUG;1U E	20.66
274891	CAYUG;2U E	20.66
275149	KEMPTON ;1E	24.11
290021	O50 E	24.25
290051	GSG-6; E	13.07
290108	LEEDK;1U E	30.37
293061	N-015 E	19.85
293516	O-009 E1	11.37
293517	O-009 E2	5.78
293518	O-009 E3	6.36
293644	O22 E1	12.82
293645	O22 E2	24.89
293715	O-029 E	12.24
293716	O-029 E	6.71
293717	O-029 E	6.17
293771	O-035 E	8.08
294392	P-010 E	25.21
294763	P-046 E	11.72
295109	WESTBROOK E	7.0
295111	SUBLETTE E	3.24
296125	R-030 C3	5.08
296128	R-030 E3	20.34
296271	R-030 C2	5.02
296272	R-030 E2	20.09
296308	R-030 C1	5.02
296309	R-030 E1	20.09
910542	X3-005 E	0.91
914641	Y2-103	56.19
915011	Y3-013 1	4.68

Bus #	Bus	MW Impact
915021	Y3-013 2	4.68
915031	Y3-013 3	4.68
916211	Z1-072 E	6.11
916221	Z1-073 E	6.75
916502	Z1-106 E1	1.58
916504	Z1-106 E2	1.58
916512	Z1-107 E	3.23
916522	Z1-108 E	3.11
917502	Z2-087 E	26.28
918052	AA1-018 E	20.57
919221	AA1-146	22.0
919581	AA2-030	22.0
920272	AA2-123 E	3.06
924041	AB2-047 C O1	4.85
924042	AB2-047 E O1	32.43
924471	AB2-096	52.94
925161	AB2-173	3.92
925302	AB2-191 E	1.73
925881	AC1-067 O1	172.23
926311	AC1-109 1	2.39
926321	AC1-109 2	2.39
926331	AC1-110 1	2.37
926341	AC1-110 2	2.37
926351	AC1-111 1	0.96
926361	AC1-111 2	0.96
926371	AC1-111 3	0.96
926381	AC1-111 4	0.96
926391	AC1-111 5	0.96
926401	AC1-111 6	0.96
926431	AC1-114	2.97
926821	AC1-168 C O1	1.46
926822	AC1-168 E O1	9.79
927091	AC1-204 1	90.83
927101	AC1-204 2	90.83
927201	AC1-214 C O1	2.59
927202	AC1-214 E O1	8.24
927451	AC1-142A 1	5.23
927461	AC1-142A 2	5.23
927511	AC1-113 1	1.49
927521	AC1-113 2	1.49
927531	AC1-185 1	0.86
927541	AC1-185 2	0.86
927551	AC1-185 3	0.86
927561	AC1-185 4	0.86
927571	AC1-185 5	0.86
927581	AC1-185 6	0.86
927591	AC1-185 7	0.86
927601	AC1-185 8	0.86
930481	AB1-089	82.21
930501	AB1-091 O1	95.92
930741	AB1-122 1O1	91.25
930751	AB1-122 2O1	92.24

Bus #	Bus	MW Impact
932881	AC2-115 1	2.97
932891	AC2-115 2	2.97
932921	AC2-116	1.04
932931	AC2-117	6.67
933341	AC2-147 C	1.09
933342	AC2-147 E	1.78
933411	AC2-154 C	3.27
933412	AC2-154 E	5.34
933431	AC2-156 C O1	1.2
933432	AC2-156 E O1	1.95
933911	AD1-013 C	2.3
933912	AD1-013 E	3.68
933931	AD1-016 C	1.16
933932	AD1-016 E	1.89
934101	AD1-039 1	8.94
934111	AD1-039 2	9.04
934401	AD1-064 C O1	4.01
934402	AD1-064 E O1	18.76
934431	AD1-067 C	0.16
934432	AD1-067 E	0.69
934651	AD1-096 C	1.11
934652	AD1-096 E	1.82
934701	AD1-098 C O1	8.6
934702	AD1-098 E O1	6.28
934721	AD1-100 C	30.02
934722	AD1-100 E	140.09
934871	AD1-116 C	1.2
934872	AD1-116 E	1.95
934881	AD1-117 C	6.72
934882	AD1-117 E	4.48
934971	AD1-129 C	1.13
934972	AD1-129 E	0.75
935001	AD1-133 C O1	27.99
935002	AD1-133 E O1	18.66
936291	AD2-038 C O1	2.94
936292	AD2-038 E O1	19.7
936371	AD2-047 C O1	2.93
936372	AD2-047 E O1	31.51
936461	AD2-060	3.44
936511	AD2-066 C O1	10.58
936512	AD2-066 E O1	7.05
936781	AD2-101 C	5.95
936782	AD2-101 E	27.88
936791	AD2-102 C	15.03
936792	AD2-102 E	14.44
936961	AD2-130	0.7
937001	AD2-134 C	3.42
937002	AD2-134 E	14.12
937031	AD2-137 C O1	7.31
937032	AD2-137 E O1	34.21
937051	AD2-140 C O1	7.67
937052	AD2-140 E O1	35.93

Bus #	Bus	MW Impact
937061	AD2-141 C O1	7.63
937062	AD2-141 E O1	35.97
937071	AD2-142 C O1	15.35
937072	AD2-142 E O1	71.86
937121	AD2-148 C O1	4.61
937122	AD2-148 E O1	21.57
937131	AD2-149 C O1	4.61
937132	AD2-149 E O1	21.57
937141	AD2-150 C O1	4.61
937142	AD2-150 E O1	21.57
937181	AD2-155 C O1	4.61
937182	AD2-155 E O1	21.57
937311	AD2-172 C	3.08
937312	AD2-172 E	4.25
937321	AD2-175 C	21.46
937322	AD2-175 E	14.31
937331	AD2-176 C O1	9.17
937332	AD2-176 E O1	6.11
937401	AD2-194 1	9.77
937411	AD2-194 2	9.77
938012	AE1-002 E O1	14.67
938511	AE1-070 1	11.48
938521	AE1-070 2	10.5
938851	AE1-113 C O1	10.98
938852	AE1-113 E O1	34.5
938861	AE1-114 C O1	4.5
938862	AE1-114 E O1	17.19
939051	AE1-134 1	1.71
939061	AE1-134 2	1.71
939321	AE1-163 C O1	7.4
939322	AE1-163 E O1	45.45
939351	AE1-166 C O1	14.82
939352	AE1-166 E O1	13.68
939401	AE1-172 C O1	9.71
939402	AE1-172 E O1	45.45
939691	AE1-199	2.99
939701	AE1-201 C	2.51
939702	AE1-201 E	0.55
939732	AE1-204 E	0.37
939741	AE1-205 C O1	12.73
939742	AE1-205 E O1	17.58
939861	AE1-222 1	100.77
939871	AE1-222 2	101.86
939921	AE1-228 C O1	12.57
939922	AE1-228 E O1	8.38
939961	AE1-233 C O1	2.91
939962	AE1-233 E O1	12.02
940101	AE1-252 C O1	16.55
940102	AE1-252 E O1	11.03
AB2-013	AB2-013	20.27
AE1-033	AE1-033	22.58
BLUEG	BLUEG	8.03

Bus #	Bus	MW Impact
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.98
CATAWBA	CATAWBA	0.39
CBM-S1	CBM-S1	1.88
CBM-W1	CBM-W1	38.11
CBM-W2	CBM-W2	72.48
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.96
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.75
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.49
MEC	MEC	47.56
O-066	O-066	9.26
RENSSELAER	RENSSELAER	0.77
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.96
WEC	WEC	9.96
Z1-043	Z1-043	36.25

Index 15

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
172410	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	124.43	125.44	DC	35.06

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	12.57
274654	BRAIDWOOD;1U	26.97
274655	BRAIDWOOD;2U	25.8
274661	LASCO STA;2U	24.66
274687	WILL CNTY;4U	11.24
274704	KENDALL ;1C	3.96
274705	KENDALL ;1S	2.64
274706	KENDALL ;2C	3.96
274707	KENDALL ;2S	2.64
274722	S-055 E	11.77
274751	CRETE EC ;1U	5.74
274752	CRETE EC ;2U	5.74
274753	CRETE EC ;3U	5.74
274754	CRETE EC ;4U	5.74
274859	EASYR;U1 E	11.37
274860	EASYR;U2 E	11.37
274861	TOP CROP ;1U	0.47
274862	TOP CROP ;2U	0.91
274888	PILOT HIL;1E	16.88
274890	CAYUG;1U E	13.45
274891	CAYUG;2U E	13.45
275149	KEMPTON ;1E	16.88
290021	O50 E	20.54
290051	GSG-6; E	10.8
290108	LEEDK;1U E	25.11
293061	N-015 E	16.24
293516	O-009 E1	9.32
293517	O-009 E2	4.73
293518	O-009 E3	5.21
293644	O22 E1	12.21
293645	O22 E2	23.71
293715	O-029 E	10.07
293716	O-029 E	5.52
293717	O-029 E	5.08
294392	P-010 E	20.62
294763	P-046 E	9.71
295109	WESTBROOK E	5.78
295111	SUBLETTE E	2.68
914641	Y2-103	47.06
915011	Y3-013 1	3.92
915021	Y3-013 2	3.92

Bus #	Bus	MW Impact
915031	Y3-013 3	3.92
916221	Z1-073 E	5.57
916502	Z1-106 E1	1.31
916504	Z1-106 E2	1.31
916512	Z1-107 E	2.52
916522	Z1-108 E	2.59
918052	AA1-018 E	15.99
919221	AA1-146	18.16
919581	AA2-030	18.16
920272	AA2-123 E	2.54
924471	AB2-096	43.99
925161	AB2-173	3.24
925302	AB2-191 E	1.43
926311	AC1-109 1	1.97
926321	AC1-109 2	1.97
926331	AC1-110 1	1.98
926341	AC1-110 2	1.98
926351	AC1-111 1	0.79
926361	AC1-111 2	0.79
926371	AC1-111 3	0.79
926381	AC1-111 4	0.79
926391	AC1-111 5	0.79
926401	AC1-111 6	0.79
926431	AC1-114	2.47
926821	AC1-168 C O1	1.18
926822	AC1-168 E O1	7.92
927091	AC1-204 1	77.42
927101	AC1-204 2	77.29
927451	AC1-142A 1	4.48
927461	AC1-142A 2	4.48
927511	AC1-113 1	1.23
927521	AC1-113 2	1.23
927531	AC1-185 1	0.71
927541	AC1-185 2	0.71
927551	AC1-185 3	0.71
927561	AC1-185 4	0.71
927571	AC1-185 5	0.71
927581	AC1-185 6	0.71
927591	AC1-185 7	0.71
927601	AC1-185 8	0.71
930481	AB1-089	68.22
930501	AB1-091 O1	66.51
930741	AB1-122 1O1	73.76
930751	AB1-122 2O1	78.95
932881	AC2-115 1	2.47
932891	AC2-115 2	2.47
932921	AC2-116	0.86
933341	AC2-147 C	0.9
933342	AC2-147 E	1.47
933411	AC2-154 C	2.29
933412	AC2-154 E	3.74
933431	AC2-156 C O1	0.99

Bus #	Bus	MW Impact
933432	AC2-156 E O1	1.61
933911	AD1-013 C	1.9
933912	AD1-013 E	3.04
933931	AD1-016 C	0.97
933932	AD1-016 E	1.58
934101	AD1-039 1	7.23
934111	AD1-039 2	7.74
934401	AD1-064 C O1	3.33
934402	AD1-064 E O1	15.58
934431	AD1-067 C	0.14
934432	AD1-067 E	0.57
934651	AD1-096 C	0.92
934652	AD1-096 E	1.51
934701	AD1-098 C O1	7.11
934702	AD1-098 E O1	5.19
934721	AD1-100 C	19.71
934722	AD1-100 E	91.99
934871	AD1-116 C	0.93
934872	AD1-116 E	1.52
934881	AD1-117 C	5.55
934882	AD1-117 E	3.7
934971	AD1-129 C	0.94
934972	AD1-129 E	0.63
935001	AD1-133 C O1	21.05
935002	AD1-133 E O1	14.03
936291	AD2-038 C O1	2.37
936292	AD2-038 E O1	15.89
936371	AD2-047 C O1	2.05
936372	AD2-047 E O1	22.06
936461	AD2-060	2.41
936511	AD2-066 C O1	8.6
936512	AD2-066 E O1	5.74
936781	AD2-101 C	3.03
936782	AD2-101 E	14.16
936791	AD2-102 C	12.47
936792	AD2-102 E	11.98
936961	AD2-130	0.59
937001	AD2-134 C	2.82
937002	AD2-134 E	11.67
937031	AD2-137 C O1	3.3
937032	AD2-137 E O1	15.44
937051	AD2-140 C O1	3.28
937052	AD2-140 E O1	15.37
937061	AD2-141 C O1	3.27
937062	AD2-141 E O1	15.39
937071	AD2-142 C O1	6.57
937072	AD2-142 E O1	30.75
937121	AD2-148 C O1	3.19
937122	AD2-148 E O1	14.95
937131	AD2-149 C O1	3.19
937132	AD2-149 E O1	14.95
937141	AD2-150 C O1	3.19

Bus #	Bus	MW Impact
937142	AD2-150 E O1	14.95
937181	AD2-155 C O1	3.19
937182	AD2-155 E O1	14.95
937311	AD2-172 C	2.55
937312	AD2-172 E	3.52
937321	AD2-175 C	14.88
937322	AD2-175 E	9.92
937331	AD2-176 C O1	7.62
937332	AD2-176 E O1	5.08
937401	AD2-194 1	8.33
937411	AD2-194 2	8.31
937531	AD2-214 C	4.54
937532	AD2-214 E	2.14
938012	AE1-002 E O1	6.62
938511	AE1-070 1	9.78
938521	AE1-070 2	8.93
938851	AE1-113 C O1	9.29
938852	AE1-113 E O1	29.21
938861	AE1-114 C O1	3.72
938862	AE1-114 E O1	14.22
939051	AE1-134 1	1.41
939061	AE1-134 2	1.41
939321	AE1-163 C O1	5.97
939322	AE1-163 E O1	36.64
939351	AE1-166 C O1	10.54
939352	AE1-166 E O1	9.73
939401	AE1-172 C O1	6.17
939402	AE1-172 E O1	28.89
939641	AE1-194 C	32.38
939642	AE1-194 E	216.73
939651	AE1-195 C	32.38
939652	AE1-195 E	216.73
939691	AE1-199	2.47
939701	AE1-201 C	2.08
939702	AE1-201 E	0.46
939732	AE1-204 E	0.31
939861	AE1-222 1	81.46
939871	AE1-222 2	87.19
939921	AE1-228 C O1	10.39
939922	AE1-228 E O1	6.93
939961	AE1-233 C O1	2.41
939962	AE1-233 E O1	9.95
940101	AE1-252 C O1	10.52
940102	AE1-252 E O1	7.01
AB2-013	AB2-013	16.6
AE1-033	AE1-033	18.74
BLUEG	BLUEG	6.66
CALDERWOOD	CALDERWOOD	0.12
CANNELTON	CANNELTON	0.14
CARR	CARR	0.8
CATAWBA	CATAWBA	0.32
CBM-S1	CBM-S1	1.14

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	25.55
CBM-W2	CBM-W2	51.99
CHEOAH	CHEOAH	0.12
CHILHOWEE	CHILHOWEE	0.04
DEARBORN	DEARBORN	3.16
ELMERSMITH	ELMERSMITH	0.17
G-007	G-007	2.23
GIBSON	GIBSON	0.08
HAMLET	HAMLET	1.22
MEC	MEC	38.45
O-066	O-066	7.49
RENSSELAER	RENSSELAER	0.63
SANTEETLA	SANTEETLA	0.04
TRIMBLE	TRIMBLE	0.78
WEC	WEC	8.32
Z1-043	Z1-043	29.26

Index 16

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
779313	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	134.98	135.93	DC	27.88

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	9.79
274722	S-055 E	9.15
274808	UNIV PK N;4U	1.62
274809	UNIV PK N;5U	1.62
274811	UNIV PK N;7U	1.62
274812	UNIV PK N;8U	1.62
274814	UNIV PK N;0U	1.62
274815	UNIV PK N;XU	1.62
274832	U4-027	8.61
274859	EASYR;U1 E	8.84
274860	EASYR;U2 E	8.84
274888	PILOT HIL;1E	14.86
274890	CAYUG;1U E	10.7
274891	CAYUG;2U E	10.7
275149	KEMPTON ;1E	14.86
290021	O50 E	15.62
290051	GSG-6; E	8.43
290108	LEEDK;1U E	19.61
293061	N-015 E	12.6
293516	O-009 E1	7.26
293517	O-009 E2	3.69
293518	O-009 E3	4.06
293644	O22 E1	7.88
293645	O22 E2	15.3
293715	O-029 E	7.84
293716	O-029 E	4.3
293717	O-029 E	3.95
293771	O-035 E	5.09
294392	P-010 E	16.0
294401	BSHIL;1U E	6.8
294410	BSHIL;2U E	6.8
294763	P-046 E	7.56
295109	WESTBROOK E	4.51
295111	SUBLETTE E	2.08
910542	X3-005 E	0.51
914641	Y2-103	36.59
915011	Y3-013 1	3.05
915021	Y3-013 2	3.05
915031	Y3-013 3	3.05
916211	Z1-072 E	3.85

Bus #	Bus	MW Impact
916221	Z1-073 E	4.35
916502	Z1-106 E1	1.02
916504	Z1-106 E2	1.02
916512	Z1-107 E	2.17
916522	Z1-108 E	2.02
918052	AA1-018 E	14.29
919221	AA1-146	14.12
919581	AA2-030	14.12
919621	AA2-039 C	1.66
919622	AA2-039 E	11.1
920272	AA2-123 E	1.98
924471	AB2-096	34.27
925161	AB2-173	2.52
925302	AB2-191 E	1.12
925581	AC1-033 C	1.11
925582	AC1-033 E	7.46
925881	AC1-067 O1	97.44
926311	AC1-109 1	1.55
926321	AC1-109 2	1.55
926331	AC1-110 1	1.54
926341	AC1-110 2	1.54
926351	AC1-111 1	0.62
926361	AC1-111 2	0.62
926371	AC1-111 3	0.62
926381	AC1-111 4	0.62
926391	AC1-111 5	0.62
926401	AC1-111 6	0.62
926431	AC1-114	1.92
926821	AC1-168 C O1	0.92
926822	AC1-168 E O1	6.18
927091	AC1-204 1	59.17
927101	AC1-204 2	59.21
927201	AC1-214 C O1	1.63
927202	AC1-214 E O1	5.19
927451	AC1-142A 1	3.45
927461	AC1-142A 2	3.45
927511	AC1-113 1	0.96
927521	AC1-113 2	0.96
927531	AC1-185 1	0.55
927541	AC1-185 2	0.55
927551	AC1-185 3	0.55
927561	AC1-185 4	0.55
927571	AC1-185 5	0.55
927581	AC1-185 6	0.55
927591	AC1-185 7	0.55
927601	AC1-185 8	0.55
930481	AB1-089	53.11
930501	AB1-091 O1	57.12
930741	AB1-122 1O1	58.21
930751	AB1-122 2O1	59.68
932881	AC2-115 1	1.92
932891	AC2-115 2	1.92

Bus #	Bus	MW Impact
932921	AC2-116	0.67
932931	AC2-117	10.39
933341	AC2-147 C	0.7
933342	AC2-147 E	1.15
933411	AC2-154 C	2.02
933412	AC2-154 E	3.29
933431	AC2-156 C O1	0.77
933432	AC2-156 E O1	1.26
933911	AD1-013 C	1.48
933912	AD1-013 E	2.37
933931	AD1-016 C	0.75
933932	AD1-016 E	1.23
934051	AD1-031 C O1	2.26
934052	AD1-031 E O1	3.69
934101	AD1-039 1	5.7
934111	AD1-039 2	5.85
934401	AD1-064 C O1	2.59
934402	AD1-064 E O1	12.13
934431	AD1-067 C	0.11
934432	AD1-067 E	0.44
934651	AD1-096 C	0.72
934652	AD1-096 E	1.17
934701	AD1-098 C O1	5.55
934702	AD1-098 E O1	4.05
934721	AD1-100 C	15.58
934722	AD1-100 E	72.69
934871	AD1-116 C	0.83
934872	AD1-116 E	1.36
934881	AD1-117 C	4.32
934882	AD1-117 E	2.88
934971	AD1-129 C	0.73
934972	AD1-129 E	0.49
935001	AD1-133 C O1	16.67
935002	AD1-133 E O1	11.11
936291	AD2-038 C O1	1.97
936292	AD2-038 E O1	13.19
936371	AD2-047 C O1	1.8
936372	AD2-047 E O1	19.42
936461	AD2-060	2.12
936511	AD2-066 C O1	6.83
936512	AD2-066 E O1	4.55
936781	AD2-101 C	3.51
936782	AD2-101 E	16.41
936791	AD2-102 C	9.71
936792	AD2-102 E	9.33
936961	AD2-130	0.46
937001	AD2-134 C	2.2
937002	AD2-134 E	9.1
937031	AD2-137 C O1	2.69
937032	AD2-137 E O1	12.6
937051	AD2-140 C O1	2.69
937052	AD2-140 E O1	12.61

Bus #	Bus	MW Impact
937061	AD2-141 C O1	2.68
937062	AD2-141 E O1	12.63
937071	AD2-142 C O1	5.39
937072	AD2-142 E O1	25.22
937121	AD2-148 C O1	2.74
937122	AD2-148 E O1	12.83
937131	AD2-149 C O1	2.74
937132	AD2-149 E O1	12.83
937141	AD2-150 C O1	2.74
937142	AD2-150 E O1	12.83
937181	AD2-155 C O1	2.74
937182	AD2-155 E O1	12.83
937311	AD2-172 C	1.98
937312	AD2-172 E	2.74
937321	AD2-175 C	12.77
937322	AD2-175 E	8.51
937331	AD2-176 C O1	5.94
937332	AD2-176 E O1	3.96
937401	AD2-194 1	6.36
937411	AD2-194 2	6.37
937531	AD2-214 C	3.53
937532	AD2-214 E	1.66
938012	AE1-002 E O1	5.4
938511	AE1-070 1	7.48
938521	AE1-070 2	6.84
938851	AE1-113 C O1	7.07
938852	AE1-113 E O1	22.22
938861	AE1-114 C O1	2.9
938862	AE1-114 E O1	11.07
939051	AE1-134 1	1.1
939061	AE1-134 2	1.1
939321	AE1-163 C O1	4.95
939322	AE1-163 E O1	30.42
939351	AE1-166 C O1	8.28
939352	AE1-166 E O1	7.64
939401	AE1-172 C O1	4.91
939402	AE1-172 E O1	22.97
939631	AE1-193 C O1	5.53
939632	AE1-193 E O1	37.0
939681	AE1-198 C O1	16.41
939682	AE1-198 E O1	13.95
939691	AE1-199	1.93
939701	AE1-201 C	1.62
939702	AE1-201 E	0.36
939732	AE1-204 E	0.24
939861	AE1-222 1	64.28
939871	AE1-222 2	65.91
939921	AE1-228 C O1	8.11
939922	AE1-228 E O1	5.4
939961	AE1-233 C O1	1.88
939962	AE1-233 E O1	7.77
940101	AE1-252 C O1	8.36

Bus #	Bus	MW Impact
940102	AE1-252 E O1	5.58
990901	L-005 E	5.05
AB2-013	AB2-013	12.84
AE1-033	AE1-033	14.59
BLUEG	BLUEG	4.41
CALDERWOOD	CALDERWOOD	0.05
CANNELTON	CANNELTON	0.06
CARR	CARR	0.61
CATAWBA	CATAWBA	0.23
CBM-S1	CBM-S1	1.22
CBM-W1	CBM-W1	21.89
CBM-W2	CBM-W2	43.2
CHEOAH	CHEOAH	0.05
CHILHOWEE	CHILHOWEE	0.01
DEARBORN	DEARBORN	2.62
ELMERSMITH	ELMERSMITH	0.06
G-007	G-007	1.71
GIBSON	GIBSON	0.02
HAMLET	HAMLET	0.88
MEC	MEC	30.08
O-066	O-066	5.77
RENSSELAER	RENSSELAER	0.49
SANTEETLA	SANTEETLA	0.02
TRIMBLE	TRIMBLE	0.52
WEC	WEC	6.46
Z1-043	Z1-043	22.86

Index 17

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
172377	275232	WILTON ;3M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT5-6__	breaker	1379.0	166.14	166.79	DC	54.08

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	14.81
274722	S-055 E	13.75
274772	LINCOLN ;3U	3.36
274773	LINCOLN ;4U	3.36
274774	LINCOLN ;5U	3.36
274775	LINCOLN ;6U	3.36
274776	LINCOLN ;7U	3.36
274777	LINCOLN ;8U	3.36
274859	EASYR;U1 E	13.46
274860	EASYR;U2 E	13.46
274888	PILOT HIL;1E	23.62
274890	CAYUG;1U E	20.25
274891	CAYUG;2U E	20.25
275149	KEMPTON ;1E	23.62
290021	O50 E	23.75
290051	GSG-6; E	12.8
290108	LEEDK;1U E	29.74
293061	N-015 E	19.44
293516	O-009 E1	1.0
293517	O-009 E2	0.51
293518	O-009 E3	0.56
293644	O22 E1	12.55
293645	O22 E2	24.37
293715	O-029 E	11.98
293716	O-029 E	6.57
293717	O-029 E	6.04
294392	P-010 E	24.69
294763	P-046 E	11.48
295109	WESTBROOK E	6.85
295111	SUBLETTE E	3.18
296125	R-030 C3	4.98
296128	R-030 E3	19.93
296271	R-030 C2	4.92
296272	R-030 E2	19.7
296308	R-030 C1	4.92
296309	R-030 E1	19.7
910542	X3-005 E	0.9
914641	Y2-103	55.02
915011	Y3-013 1	4.58
915021	Y3-013 2	4.58
915031	Y3-013 3	4.58

Bus #	Bus	MW Impact
916221	Z1-073 E	6.61
916502	Z1-106 E1	1.55
916504	Z1-106 E2	1.55
916512	Z1-107 E	3.17
916522	Z1-108 E	3.04
917502	Z2-087 E	25.76
918052	AA1-018 E	20.13
919221	AA1-146	21.54
919581	AA2-030	21.54
920272	AA2-123 E	2.99
924041	AB2-047 C O1	4.75
924042	AB2-047 E O1	31.79
924471	AB2-096	51.84
925161	AB2-173	3.84
925302	AB2-191 E	1.7
925881	AC1-067 O1	168.51
926311	AC1-109 1	2.34
926321	AC1-109 2	2.34
926331	AC1-110 1	2.33
926341	AC1-110 2	2.33
926351	AC1-111 1	0.94
926361	AC1-111 2	0.94
926371	AC1-111 3	0.94
926381	AC1-111 4	0.94
926391	AC1-111 5	0.94
926401	AC1-111 6	0.94
926431	AC1-114	2.91
926821	AC1-168 C O1	1.43
926822	AC1-168 E O1	9.59
927091	AC1-204 1	88.93
927101	AC1-204 2	88.93
927451	AC1-142A 1	5.12
927461	AC1-142A 2	5.12
927511	AC1-113 1	1.46
927521	AC1-113 2	1.46
927531	AC1-185 1	0.84
927541	AC1-185 2	0.84
927551	AC1-185 3	0.84
927561	AC1-185 4	0.84
927571	AC1-185 5	0.84
927581	AC1-185 6	0.84
927591	AC1-185 7	0.84
927601	AC1-185 8	0.84
930481	AB1-089	80.5
930501	AB1-091 O1	93.97
930741	AB1-122 1O1	89.35
930751	AB1-122 2O1	90.31
932881	AC2-115 1	2.91
932891	AC2-115 2	2.91
932921	AC2-116	1.02
932931	AC2-117	6.52
933341	AC2-147 C	1.07

Bus #	Bus	MW Impact
933342	AC2-147 E	1.74
933411	AC2-154 C	3.21
933412	AC2-154 E	5.23
933431	AC2-156 C O1	1.17
933432	AC2-156 E O1	1.91
933911	AD1-013 C	2.25
933912	AD1-013 E	3.6
933931	AD1-016 C	1.14
933932	AD1-016 E	1.85
934101	AD1-039 1	8.76
934111	AD1-039 2	8.85
934401	AD1-064 C O1	3.92
934402	AD1-064 E O1	18.37
934431	AD1-067 C	0.16
934432	AD1-067 E	0.68
934651	AD1-096 C	1.09
934652	AD1-096 E	1.78
934701	AD1-098 C O1	8.43
934702	AD1-098 E O1	6.15
934721	AD1-100 C	29.44
934722	AD1-100 E	137.37
934871	AD1-116 C	1.17
934872	AD1-116 E	1.91
934881	AD1-117 C	6.58
934882	AD1-117 E	4.39
934971	AD1-129 C	1.11
934972	AD1-129 E	0.74
935001	AD1-133 C O1	27.42
935002	AD1-133 E O1	18.28
936291	AD2-038 C O1	2.88
936292	AD2-038 E O1	19.29
936371	AD2-047 C O1	2.87
936372	AD2-047 E O1	30.87
936461	AD2-060	3.37
936511	AD2-066 C O1	10.36
936512	AD2-066 E O1	6.91
936781	AD2-101 C	5.83
936782	AD2-101 E	27.31
936791	AD2-102 C	14.71
936792	AD2-102 E	14.14
936961	AD2-130	0.69
937001	AD2-134 C	3.35
937002	AD2-134 E	13.82
937031	AD2-137 C O1	7.17
937032	AD2-137 E O1	33.59
937051	AD2-140 C O1	7.53
937052	AD2-140 E O1	35.28
937061	AD2-141 C O1	7.49
937062	AD2-141 E O1	35.32
937071	AD2-142 C O1	15.07
937072	AD2-142 E O1	70.55
937121	AD2-148 C O1	4.51

Bus #	Bus	MW Impact
937122	AD2-148 E O1	21.13
937131	AD2-149 C O1	4.51
937132	AD2-149 E O1	21.13
937141	AD2-150 C O1	4.51
937142	AD2-150 E O1	21.13
937181	AD2-155 C O1	4.51
937182	AD2-155 E O1	21.13
937311	AD2-172 C	3.01
937312	AD2-172 E	4.16
937321	AD2-175 C	21.03
937322	AD2-175 E	14.02
937331	AD2-176 C O1	8.97
937332	AD2-176 E O1	5.98
937401	AD2-194 1	9.56
937411	AD2-194 2	9.56
938012	AE1-002 E O1	14.4
938511	AE1-070 1	11.24
938521	AE1-070 2	10.28
938851	AE1-113 C O1	10.75
938852	AE1-113 E O1	33.78
938861	AE1-114 C O1	4.4
938862	AE1-114 E O1	16.84
939051	AE1-134 1	1.67
939061	AE1-134 2	1.67
939321	AE1-163 C O1	7.24
939322	AE1-163 E O1	44.49
939351	AE1-166 C O1	14.52
939352	AE1-166 E O1	13.41
939401	AE1-172 C O1	9.52
939402	AE1-172 E O1	44.57
939691	AE1-199	2.93
939701	AE1-201 C	2.45
939702	AE1-201 E	0.54
939732	AE1-204 E	0.36
939741	AE1-205 C O1	12.48
939742	AE1-205 E O1	17.23
939861	AE1-222 1	98.68
939871	AE1-222 2	99.73
939921	AE1-228 C O1	12.31
939922	AE1-228 E O1	8.21
939961	AE1-233 C O1	2.85
939962	AE1-233 E O1	11.77
940101	AE1-252 C O1	16.23
940102	AE1-252 E O1	10.82
AB2-013	AB2-013	19.85
AE1-033	AE1-033	22.1
BLUEG	BLUEG	7.86
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.96
CATAWBA	CATAWBA	0.38
CBM-S1	CBM-S1	1.85

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	37.32
CBM-W2	CBM-W2	71.02
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.9
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.69
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.46
MEC	MEC	46.58
O-066	O-066	9.06
RENSSELAER	RENSSELAER	0.76
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.94
WEC	WEC	9.75
Z1-043	Z1-043	35.51

Index 18

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
172382	275233	WILTON ;4M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT2-3__	breaker	1379.0	164.04	164.99	DC	55.15

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	15.13
274722	S-055 E	14.05
274772	LINCOLN ;3U	3.45
274773	LINCOLN ;4U	3.45
274774	LINCOLN ;5U	3.45
274775	LINCOLN ;6U	3.45
274776	LINCOLN ;7U	3.45
274777	LINCOLN ;8U	3.45
274832	U4-027	6.82
274859	EASYR;U1 E	13.75
274860	EASYR;U2 E	13.75
274888	PILOT HIL;1E	24.11
274890	CAYUG;1U E	20.66
274891	CAYUG;2U E	20.66
275149	KEMPTON ;1E	24.11
290021	O50 E	24.25
290051	GSG-6; E	13.07
290108	LEEDK;1U E	30.37
293061	N-015 E	19.85
293516	O-009 E1	11.37
293517	O-009 E2	5.78
293518	O-009 E3	6.36
293644	O22 E1	12.82
293645	O22 E2	24.89
293715	O-029 E	12.24
293716	O-029 E	6.71
293717	O-029 E	6.17
293771	O-035 E	8.08
294392	P-010 E	25.21
294763	P-046 E	11.72
295109	WESTBROOK E	7.0
295111	SUBLETTE E	3.24
296125	R-030 C3	5.08
296128	R-030 E3	20.34
296271	R-030 C2	5.02
296272	R-030 E2	20.09
296308	R-030 C1	5.02
296309	R-030 E1	20.09
910542	X3-005 E	0.91
914641	Y2-103	56.19
915011	Y3-013 1	4.68

Bus #	Bus	MW Impact
915021	Y3-013 2	4.68
915031	Y3-013 3	4.68
916211	Z1-072 E	6.11
916221	Z1-073 E	6.75
916502	Z1-106 E1	1.58
916504	Z1-106 E2	1.58
916512	Z1-107 E	3.23
916522	Z1-108 E	3.11
917502	Z2-087 E	26.28
918052	AA1-018 E	20.57
919221	AA1-146	22.0
919581	AA2-030	22.0
920272	AA2-123 E	3.06
924041	AB2-047 C O1	4.85
924042	AB2-047 E O1	32.43
924471	AB2-096	52.94
925161	AB2-173	3.92
925302	AB2-191 E	1.73
925881	AC1-067 O1	172.23
926311	AC1-109 1	2.39
926321	AC1-109 2	2.39
926331	AC1-110 1	2.37
926341	AC1-110 2	2.37
926351	AC1-111 1	0.96
926361	AC1-111 2	0.96
926371	AC1-111 3	0.96
926381	AC1-111 4	0.96
926391	AC1-111 5	0.96
926401	AC1-111 6	0.96
926431	AC1-114	2.97
926821	AC1-168 C O1	1.46
926822	AC1-168 E O1	9.79
927091	AC1-204 1	90.83
927101	AC1-204 2	90.83
927201	AC1-214 C O1	2.59
927202	AC1-214 E O1	8.24
927451	AC1-142A 1	5.23
927461	AC1-142A 2	5.23
927511	AC1-113 1	1.49
927521	AC1-113 2	1.49
927531	AC1-185 1	0.86
927541	AC1-185 2	0.86
927551	AC1-185 3	0.86
927561	AC1-185 4	0.86
927571	AC1-185 5	0.86
927581	AC1-185 6	0.86
927591	AC1-185 7	0.86
927601	AC1-185 8	0.86
930481	AB1-089	82.21
930501	AB1-091 O1	95.92
930741	AB1-122 1O1	91.25
930751	AB1-122 2O1	92.24

Bus #	Bus	MW Impact
932881	AC2-115 1	2.97
932891	AC2-115 2	2.97
932921	AC2-116	1.04
932931	AC2-117	6.67
933341	AC2-147 C	1.09
933342	AC2-147 E	1.78
933411	AC2-154 C	3.27
933412	AC2-154 E	5.34
933431	AC2-156 C O1	1.2
933432	AC2-156 E O1	1.95
933911	AD1-013 C	2.3
933912	AD1-013 E	3.68
933931	AD1-016 C	1.16
933932	AD1-016 E	1.89
934101	AD1-039 1	8.94
934111	AD1-039 2	9.04
934401	AD1-064 C O1	4.01
934402	AD1-064 E O1	18.76
934431	AD1-067 C	0.16
934432	AD1-067 E	0.69
934651	AD1-096 C	1.11
934652	AD1-096 E	1.82
934701	AD1-098 C O1	8.6
934702	AD1-098 E O1	6.28
934721	AD1-100 C	30.02
934722	AD1-100 E	140.09
934871	AD1-116 C	1.2
934872	AD1-116 E	1.95
934881	AD1-117 C	6.72
934882	AD1-117 E	4.48
934971	AD1-129 C	1.13
934972	AD1-129 E	0.75
935001	AD1-133 C O1	27.99
935002	AD1-133 E O1	18.66
936291	AD2-038 C O1	2.94
936292	AD2-038 E O1	19.7
936371	AD2-047 C O1	2.93
936372	AD2-047 E O1	31.51
936461	AD2-060	3.44
936511	AD2-066 C O1	10.58
936512	AD2-066 E O1	7.05
936781	AD2-101 C	5.95
936782	AD2-101 E	27.88
936791	AD2-102 C	15.03
936792	AD2-102 E	14.44
936961	AD2-130	0.7
937001	AD2-134 C	3.42
937002	AD2-134 E	14.12
937031	AD2-137 C O1	7.31
937032	AD2-137 E O1	34.21
937051	AD2-140 C O1	7.67
937052	AD2-140 E O1	35.93

Bus #	Bus	MW Impact
937061	AD2-141 C O1	7.63
937062	AD2-141 E O1	35.97
937071	AD2-142 C O1	15.35
937072	AD2-142 E O1	71.86
937121	AD2-148 C O1	4.61
937122	AD2-148 E O1	21.57
937131	AD2-149 C O1	4.61
937132	AD2-149 E O1	21.57
937141	AD2-150 C O1	4.61
937142	AD2-150 E O1	21.57
937181	AD2-155 C O1	4.61
937182	AD2-155 E O1	21.57
937311	AD2-172 C	3.08
937312	AD2-172 E	4.25
937321	AD2-175 C	21.46
937322	AD2-175 E	14.31
937331	AD2-176 C O1	9.17
937332	AD2-176 E O1	6.11
937401	AD2-194 1	9.77
937411	AD2-194 2	9.77
938012	AE1-002 E O1	14.67
938511	AE1-070 1	11.48
938521	AE1-070 2	10.5
938851	AE1-113 C O1	10.98
938852	AE1-113 E O1	34.5
938861	AE1-114 C O1	4.5
938862	AE1-114 E O1	17.19
939051	AE1-134 1	1.71
939061	AE1-134 2	1.71
939321	AE1-163 C O1	7.4
939322	AE1-163 E O1	45.45
939351	AE1-166 C O1	14.82
939352	AE1-166 E O1	13.68
939401	AE1-172 C O1	9.71
939402	AE1-172 E O1	45.45
939691	AE1-199	2.99
939701	AE1-201 C	2.51
939702	AE1-201 E	0.55
939732	AE1-204 E	0.37
939741	AE1-205 C O1	12.73
939742	AE1-205 E O1	17.58
939861	AE1-222 1	100.77
939871	AE1-222 2	101.86
939921	AE1-228 C O1	12.57
939922	AE1-228 E O1	8.38
939961	AE1-233 C O1	2.91
939962	AE1-233 E O1	12.02
940101	AE1-252 C O1	16.55
940102	AE1-252 E O1	11.03
AB2-013	AB2-013	20.27
AE1-033	AE1-033	22.58
BLUEG	BLUEG	8.03

Bus #	Bus	MW Impact
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.98
CATAWBA	CATAWBA	0.39
CBM-S1	CBM-S1	1.88
CBM-W1	CBM-W1	38.11
CBM-W2	CBM-W2	72.48
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.96
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.75
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.49
MEC	MEC	47.56
O-066	O-066	9.26
RENSSELAER	RENSSELAER	0.77
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.96
WEC	WEC	9.96
Z1-043	Z1-043	36.25

Index 19

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
779280	346809	7CASEY	AMIL	247712	05SULLIVAN	AEP	1	AEP_P4_#3128_05EUGENE 345_A2	breaker	1466.0	143.6	144.31	DC	22.83

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	6.24
274650	KINCAID ;1U	14.71
274651	KINCAID ;2U	14.73
274832	U4-027	8.54
274853	TWINGROVE;U1	0.74
274854	TWINGROVE;U2	0.74
274859	EASYR;U1 E	6.8
274860	EASYR;U2 E	6.8
274890	CAYUG;1U E	10.14
274891	CAYUG;2U E	10.14
276150	W2-048 E	2.05
290021	O50 E	10.78
290051	GSG-6; E	5.68
290108	LEEDK;1U E	12.4
290261	S-027 E	19.36
290265	S-028 E	19.36
293516	O-009 E1	6.47
293517	O-009 E2	3.29
293518	O-009 E3	3.62
293644	O22 E1	4.9
293645	O22 E2	9.51
293715	O-029 E	6.65
293716	O-029 E	3.65
293717	O-029 E	3.35
293771	O-035 E	5.18
294401	BSHIL;1U E	7.08
294410	BSHIL;2U E	7.08
294763	P-046 E	5.38
295109	WESTBROOK E	3.04
295111	SUBLETTE E	1.65
296125	R-030 C3	3.34
296128	R-030 E3	13.34
296271	R-030 C2	3.3
296272	R-030 E2	13.18
296308	R-030 C1	3.3
296309	R-030 E1	13.18
905081	W4-005 C	0.98
905082	W4-005 E	42.62
909052	X2-022 E	28.51
916211	Z1-072 E	3.92
916221	Z1-073 E	2.93

Bus #	Bus	MW Impact
917502	Z2-087 E	17.32
918052	AA1-018 E	7.91
919221	AA1-146	11.65
919581	AA2-030	11.65
919621	AA2-039 C	1.73
919622	AA2-039 E	11.55
920272	AA2-123 E	1.22
924041	AB2-047 C O1	3.3
924042	AB2-047 E O1	22.1
924261	AB2-070 C O1	3.84
924262	AB2-070 E O1	25.68
924471	AB2-096	21.83
925161	AB2-173	2.08
925302	AB2-191 E	0.75
925581	AC1-033 C	1.16
925582	AC1-033 E	7.76
925771	AC1-053 C	3.87
925772	AC1-053 E	25.93
926431	AC1-114	1.3
926821	AC1-168 C O1	0.83
926822	AC1-168 E O1	5.54
926841	AC1-171 C O1	1.14
926842	AC1-171 E O1	7.61
927201	AC1-214 C O1	1.66
927202	AC1-214 E O1	5.29
927511	AC1-113 1	0.65
927521	AC1-113 2	0.65
927531	AC1-185 1	0.43
927541	AC1-185 2	0.43
927551	AC1-185 3	0.43
927561	AC1-185 4	0.43
927571	AC1-185 5	0.43
927581	AC1-185 6	0.43
927591	AC1-185 7	0.43
927601	AC1-185 8	0.43
930481	AB1-089	35.32
930741	AB1-122 1O1	34.94
932881	AC2-115 1	1.3
932891	AC2-115 2	1.3
932921	AC2-116	0.45
933341	AC2-147 C	0.54
933342	AC2-147 E	0.88
933911	AD1-013 C	0.99
933912	AD1-013 E	1.59
933931	AD1-016 C	0.46
933932	AD1-016 E	0.76
934051	AD1-031 C O1	2.35
934052	AD1-031 E O1	3.84
934101	AD1-039 1	3.42
934401	AD1-064 C O1	1.64
934402	AD1-064 E O1	7.66
934431	AD1-067 C	0.07

Bus #	Bus	MW Impact
934432	AD1-067 E	0.3
934651	AD1-096 C	0.51
934652	AD1-096 E	0.83
934701	AD1-098 C O1	3.77
934702	AD1-098 E O1	2.75
934871	AD1-116 C	0.46
934872	AD1-116 E	0.75
934881	AD1-117 C	3.31
934882	AD1-117 E	2.21
934971	AD1-129 C	0.47
934972	AD1-129 E	0.31
935001	AD1-133 C O1	14.12
935002	AD1-133 E O1	9.41
935141	AD1-148	7.45
936291	AD2-038 C O1	1.34
936292	AD2-038 E O1	8.98
936511	AD2-066 C O1	4.76
936512	AD2-066 E O1	3.17
936771	AD2-100 C O1	21.12
936772	AD2-100 E O1	14.08
936791	AD2-102 C	6.72
936792	AD2-102 E	6.46
936972	AD2-131 E O1	8.38
937001	AD2-134 C	1.48
937002	AD2-134 E	6.13
937161	AD2-153 C O1	3.2
937162	AD2-153 E O1	15.0
937171	AD2-154 C O1	3.2
937172	AD2-154 E O1	15.0
937211	AD2-159 C	4.61
937212	AD2-159 E	21.56
937311	AD2-172 C	1.41
937312	AD2-172 E	1.95
937331	AD2-176 C O1	3.65
937332	AD2-176 E O1	2.44
937531	AD2-214 C	3.23
937532	AD2-214 E	1.52
938851	AE1-113 C O1	4.88
938852	AE1-113 E O1	15.33
938861	AE1-114 C O1	2.16
938862	AE1-114 E O1	8.27
939051	AE1-134 1	0.91
939061	AE1-134 2	0.91
939321	AE1-163 C O1	3.37
939322	AE1-163 E O1	20.72
939401	AE1-172 C O1	4.02
939402	AE1-172 E O1	18.81
939631	AE1-193 C O1	5.75
939632	AE1-193 E O1	38.49
939681	AE1-198 C O1	17.08
939682	AE1-198 E O1	14.51
939691	AE1-199	1.29

Bus #	Bus	MW Impact
939701	AE1-201 C	1.0
939702	AE1-201 E	0.22
939741	AE1-205 C O1	8.33
939742	AE1-205 E O1	11.5
939861	AE1-222 1	38.59
939921	AE1-228 C O1	5.41
939922	AE1-228 E O1	3.61
939961	AE1-233 C O1	1.15
939962	AE1-233 E O1	4.76
940101	AE1-252 C O1	6.85
940102	AE1-252 E O1	4.57
950291	J291	3.2
950701	J196 C	1.33
950702	J196 E	5.3
951001	J339	6.03
951741	J474 C	2.02
951742	J474 E	10.95
952251	J641	10.35
952271	J644	9.57
952321	J734	5.07
952651	J756 C	2.46
952652	J756 E	13.33
952871	J757 C	4.06
952872	J757 E	21.98
953241	J467 C	2.76
953242	J467 E	14.91
953371	J808	9.06
953401	J811	17.76
953431	J853	11.11
953641	J813	43.81
953651	J815	32.11
953671	J817	10.67
953741	J826 C	1.65
953742	J826 E	8.94
953801	J835 C	2.68
953802	J835 E	14.48
953851	J845 C	1.72
953852	J845 E	9.32
953881	J848 C	5.27
953882	J848 E	28.51
953951	J859	9.79
954081	J872 C	4.44
954082	J872 E	24.03
954181	J884	7.67
954411	J912	14.24
954681	J949	38.92
954721	J750 C	2.11
954722	J750 E	11.4
954761	J468 C	7.08
954762	J468 E	28.32
990901	L-005 E	11.18
AB2-013	AB2-013	13.3

Bus #	Bus	MW Impact
AE1-033	AE1-033	10.55
AE1-042	AE1-042	10.08
BLUEG	BLUEG	10.38
CARR	CARR	0.29
CBM-S1	CBM-S1	13.17
CBM-S2	CBM-S2	2.35
CBM-W1	CBM-W1	28.23
CBM-W2	CBM-W2	199.79
CIN	CIN	3.85
CPL	CPL	0.56
DEARBORN	DEARBORN	0.69
G-007	G-007	0.8
GIBSON	GIBSON	0.02
MEC	MEC	45.61
O-066	O-066	2.69
RENSSELAER	RENSSELAER	0.23
TRIMBLE	TRIMBLE	1.31
WEC	WEC	4.13
Z1-043	Z1-043	21.97

Index 20

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
779753	932800	AC2-104 TAP	AEP	242928	05MARYSV	AEP	1	AEP_P4_#7334_05JEFRSO 765_A2	breaker	4571.0	103.34	103.44	DC	75.35

Bus #	Bus	MW Impact
243440	05CKG1	42.14
243441	05CKG2	52.39
246397	05ELKHART HY	1.01
246416	05TWIN BRCH1	0.2
246422	05MAYFLWER	0.26
246431	05BUCHANAN	1.1
246536	05MOTTVILL	0.42
247643	Z2-116 C	0.05
247906	05MDL-1G E	39.75
247907	05MDL-2G E	19.72
247912	05MDL-3G E	20.61
247913	05MDL-4G E	19.91
247943	T-127 E	19.91
247969	Z2-116 E	0.35
274722	S-055 E	22.69
274774	LINCOLN ;5U	3.14
274775	LINCOLN ;6U	3.14
274776	LINCOLN ;7U	3.14
274777	LINCOLN ;8U	3.14
274888	PILOT HIL;1E	36.41
275149	KEMPTON ;1E	36.41
290108	LEEDK;1U E	49.86
293061	N-015 E	30.86
293644	O22 E1	20.61
293645	O22 E2	40.01
294392	P-010 E	39.19
909145	X2-052	28.34
910542	X3-005 E	1.47
914641	Y2-103	90.77
915011	Y3-013 1	7.56
915021	Y3-013 2	7.56
915031	Y3-013 3	7.56
916502	Z1-106 E1	2.55
916504	Z1-106 E2	2.55
916512	Z1-107 E	5.16
916522	Z1-108 E	5.04
917702	Z2-113 E	0.6
917711	Z2-114 C	0.1
917712	Z2-114 E	0.68
918052	AA1-018 E	32.95

Bus #	Bus	MW Impact
920211	AA2-116	268.49
920272	AA2-123 E	4.99
925881	AC1-067 O1	286.39
926311	AC1-109 1	3.84
926321	AC1-109 2	3.84
926331	AC1-110 1	3.82
926341	AC1-110 2	3.82
926351	AC1-111 1	1.54
926361	AC1-111 2	1.54
926371	AC1-111 3	1.54
926381	AC1-111 4	1.54
926391	AC1-111 5	1.54
926401	AC1-111 6	1.54
926581	AC1-141	24.58
927091	AC1-204 1	143.52
927101	AC1-204 2	143.52
927451	AC1-142A 1	8.26
927461	AC1-142A 2	8.26
930042	AB1-006 E	43.31
930391	AB1-080	1.68
930501	AB1-091 O1	143.18
930741	AB1-122 1O1	146.79
930751	AB1-122 2O1	147.02
932601	AC2-080 C O1	6.66
932602	AC2-080 E O1	44.56
932801	AC2-104 C	35.99
932802	AC2-104 E	240.86
932931	AC2-117	12.03
933281	AC2-140 C	11.31
933282	AC2-140 E	0.6
933411	AC2-154 C	4.94
933412	AC2-154 E	8.06
933431	AC2-156 C O1	1.94
933432	AC2-156 E O1	3.16
933931	AD1-016 C	1.9
933932	AD1-016 E	3.09
934101	AD1-039 1	14.39
934111	AD1-039 2	14.41
934721	AD1-100 C	38.86
934722	AD1-100 E	181.34
934771	AD1-104 C	29.01
934772	AD1-104 E	194.13
934871	AD1-116 C	1.92
934872	AD1-116 E	3.13
935001	AD1-133 C O1	44.87
935002	AD1-133 E O1	29.91
936141	AD2-020 C O1	16.34
936142	AD2-020 E O1	10.06
936371	AD2-047 C O1	4.42
936372	AD2-047 E O1	47.59
936461	AD2-060	5.2
936511	AD2-066 C O1	17.37

Bus #	Bus	MW Impact
936512	AD2-066 E O1	11.58
936631	AD2-079 C O1	3.23
936632	AD2-079 E O1	2.15
936781	AD2-101 C	9.18
936782	AD2-101 E	43.0
936961	AD2-130	1.11
936981	AD2-132 C	9.01
936982	AD2-132 E	42.2
937031	AD2-137 C O1	7.0
937032	AD2-137 E O1	32.75
937041	AD2-138 C	9.01
937042	AD2-138 E	42.2
937051	AD2-140 C O1	7.03
937052	AD2-140 E O1	32.91
937061	AD2-141 C O1	6.99
937062	AD2-141 E O1	32.95
937071	AD2-142 C O1	14.06
937072	AD2-142 E O1	65.83
937121	AD2-148 C O1	6.87
937122	AD2-148 E O1	32.18
937131	AD2-149 C O1	6.87
937132	AD2-149 E O1	32.18
937141	AD2-150 C O1	6.87
937142	AD2-150 E O1	32.18
937181	AD2-155 C O1	6.87
937182	AD2-155 E O1	32.18
937321	AD2-175 C	32.02
937322	AD2-175 E	21.35
937331	AD2-176 C O1	14.97
937332	AD2-176 E O1	9.98
937401	AD2-194 1	15.43
937411	AD2-194 2	15.43
938012	AE1-002 E O1	14.04
938261	AE1-039	0.21
938511	AE1-070 1	18.13
938521	AE1-070 2	16.59
938671	AE1-089 C	36.65
938672	AE1-089 E	50.31
938851	AE1-113 C O1	5.1
938852	AE1-113 E O1	16.03
939351	AE1-166 C O1	20.24
939352	AE1-166 E O1	18.68
939391	AE1-170 C O1	16.87
939392	AE1-170 E O1	23.3
939401	AE1-172 C O1	13.26
939402	AE1-172 E O1	62.09
939641	AE1-194 C	17.06
939642	AE1-194 E	114.19
939651	AE1-195 C	17.06
939652	AE1-195 E	114.19
939701	AE1-201 C	4.09
939702	AE1-201 E	0.9

Bus #	Bus	MW Impact
939732	AE1-204 E	0.59
939861	AE1-222 1	162.11
939871	AE1-222 2	162.36
939961	AE1-233 C O1	4.76
939962	AE1-233 E O1	19.65
940101	AE1-252 C O1	22.6
940102	AE1-252 E O1	15.07
AB2-013	AB2-013	35.55
AE1-033	AE1-033	37.8
AE1-042	AE1-042	10.86
CARR	CARR	2.36
CATAWBA	CATAWBA	0.63
CBM-S1	CBM-S1	20.07
CBM-W1	CBM-W1	112.29
CBM-W2	CBM-W2	293.15
CIN	CIN	39.78
G-007	G-007	6.85
HAMLET	HAMLET	2.77
IPL	IPL	24.98
LGEE	LGEE	4.88
MEC	MEC	92.49
MECS	MECS	52.19
O-066	O-066	23.05
RENSSELAER	RENSSELAER	1.87
WEC	WEC	16.38
Z1-043	Z1-043	62.52

Index 21

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
173716	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	COMED_P7_345-L17704AR-S_+_345-L17907TB-S-A	tower	1846.0	138.35	143.05	DC	86.71

Bus #	Bus	MW Impact
274654	BRAIDWOOD;1U	33.0
274655	BRAIDWOOD;2U	31.46
274660	LASCO STA;1U	20.77
274661	LASCO STA;2U	20.81
274847	GR RIDGE ;BU	0.46
274853	TWINGROVE;U1	0.88
274854	TWINGROVE;U2	0.88
274863	CAYUGA RI;1U	1.14
274864	CAYUGA RI;2U	1.14
274871	GR RIDGE ;2U	0.59
274881	PLEAS RDG;2U	0.94
274887	PILOT HIL;1U	0.94
274888	PILOT HIL;1E	24.62
274890	CAYUG;1U E	29.8
274891	CAYUG;2U E	29.8
275149	KEMPTON ;1E	24.62
276150	W2-048 E	1.36
290261	S-027 E	23.06
290265	S-028 E	23.06
293061	N-015 E	12.12
294392	P-010 E	15.39
296125	R-030 C3	5.9
296128	R-030 E3	23.58
296271	R-030 C2	5.83
296272	R-030 E2	23.3
296308	R-030 C1	5.83
296309	R-030 E1	23.3
905081	W4-005 C	0.86
905082	W4-005 E	37.37
909052	X2-022 E	18.92
917501	Z2-087 C	0.7
917502	Z2-087 E	30.46
924041	AB2-047 C O1	5.59
924042	AB2-047 E O1	37.43
924261	AB2-070 C O1	2.78
924262	AB2-070 E O1	18.6
925771	AC1-053 C	2.73
925772	AC1-053 E	18.26
925881	AC1-067 O1	219.35
926821	AC1-168 C O1	0.64

Bus #	Bus	MW Impact
926822	AC1-168 E O1	4.29
930501	AB1-091 O1	110.96
933411	AC2-154 C	3.34
933412	AC2-154 E	5.45
934721	AD1-100 C	48.31
934722	AD1-100 E	225.47
935001	AD1-133 C O1	18.1
935002	AD1-133 E O1	12.07
935141	AD1-148	4.94
936371	AD2-047 C O1	2.99
936372	AD2-047 E O1	32.19
936461	AD2-060	3.52
936771	AD2-100 C O1	10.55
936772	AD2-100 E O1	7.04
936781	AD2-101 C	7.11
936782	AD2-101 E	33.27
936972	AD2-131 E O1	2.22
937121	AD2-148 C O1	5.34
937122	AD2-148 E O1	25.01
937131	AD2-149 C O1	5.34
937132	AD2-149 E O1	25.01
937141	AD2-150 C O1	5.34
937142	AD2-150 E O1	25.01
937161	AD2-153 C O1	3.8
937162	AD2-153 E O1	17.78
937171	AD2-154 C O1	3.8
937172	AD2-154 E O1	17.78
937181	AD2-155 C O1	5.34
937182	AD2-155 E O1	25.01
937211	AD2-159 C	4.04
937212	AD2-159 E	18.9
937321	AD2-175 C	24.89
937322	AD2-175 E	16.59
938012	AE1-002 E O1	29.83
939351	AE1-166 C O1	20.52
939352	AE1-166 E O1	18.94
939401	AE1-172 C O1	15.26
939402	AE1-172 E O1	71.45
939741	AE1-205 C O1	14.83
939742	AE1-205 E O1	20.48
940101	AE1-252 C O1	26.01
940102	AE1-252 E O1	17.34
951741	J474 C	1.71
951742	J474 E	9.28
953741	J826 C	1.0
953742	J826 E	5.4
954181	J884	8.88
AB2-013	AB2-013	5.61
BLUEG	BLUEG	0.01
CARR	CARR	0.27
CBM-S1	CBM-S1	2.75
CBM-S2	CBM-S2	0.06

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	5.33
CBM-W2	CBM-W2	48.81
CIN	CIN	2.54
DEARBORN	DEARBORN	1.27
G-007	G-007	0.73
HAMLET	HAMLET	0.06
IPL	IPL	1.1
LGEE	LGEE	0.03
MEC	MEC	13.64
O-066	O-066	2.47
RENSSELAER	RENSSELAER	0.21
TRIMBLE	TRIMBLE	0.04
WEC	WEC	1.22
Z1-043	Z1-043	14.81

Index 22

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
173016	935000	AD1-133 TAP	CE	270717	DRESDEN ; R	CE	1	COMED_P1-2_345-L11212_B-S-C-A	single	1528.0	108.11	109.72	DC	24.59

Bus #	Bus	MW Impact
274650	KINCAID ;1U	15.48
274651	KINCAID ;2U	15.51
274853	TWINGROVE;U1	2.3
274854	TWINGROVE;U2	2.3
274863	CAYUGA RI;1U	2.14
274864	CAYUGA RI;2U	2.14
900404	X3-028 C	78.36
905081	W4-005 C	2.19
917501	Z2-087 C	1.85
924041	AB2-047 C O1	14.84
924261	AB2-070 C O1	6.98
925771	AC1-053 C	6.83
926841	AC1-171 C O1	0.75
930461	AB1-087	28.73
930471	AB1-088	28.73
933441	AC2-157 C	3.97
935001	AD1-133 C O1	120.38
935141	AD1-148	12.29
936771	AD2-100 C O1	25.48
937161	AD2-153 C O1	9.91
937171	AD2-154 C O1	9.91
937211	AD2-159 C	10.33
939401	AE1-172 C O1	24.59
939741	AE1-205 C O1	39.11
940101	AE1-252 C O1	41.91
950701	J196 C	1.11
951001	J339	12.11
951741	J474 C	4.81
952271	J644	12.24
952321	J734	10.17
952651	J756 C	4.36
952871	J757 C	5.2
953241	J467 C	1.73
953401	J811	10.29
953651	J815	34.83
953741	J826 C	3.01
953801	J835 C	3.42
953851	J845 C	2.96
953881	J848 C	5.38
954081	J872 C	4.15

Bus #	Bus	MW Impact
954181	J884	24.98
954411	J912	13.29
954721	J750 C	3.3
954761	J468 C	3.94
AD2-098	AD2-098	0.45
AE1-042	AE1-042	5.79
CBM-N	CBM-N	0.66
CBM-S1	CBM-S1	9.87
CBM-S2	CBM-S2	3.13
CBM-W2	CBM-W2	111.77
CIN	CIN	10.82
CPL	CPL	1.12
DEARBORN	DEARBORN	0.52
EDWARDS	EDWARDS	0.05
G-007A	G-007A	2.18
IPL	IPL	5.9
LGEE	LGEE	1.65
MEC	MEC	2.66
NYISO	NYISO	2.85
O-066A	O-066A	1.01
TATANKA	TATANKA	0.42
VFT	VFT	5.85

Index 23

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
173690	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	COMED_P7_345-L17704AR-S_+_345-L17907TB-S-A	tower	1846.0	145.54	150.23	DC	86.71

Bus #	Bus	MW Impact
274654	BRAIDWOOD;1U	33.0
274655	BRAIDWOOD;2U	31.46
274660	LASCO STA;1U	20.77
274661	LASCO STA;2U	20.81
274847	GR RIDGE ;BU	0.46
274853	TWINGROVE;U1	0.88
274854	TWINGROVE;U2	0.88
274863	CAYUGA RI;1U	1.14
274864	CAYUGA RI;2U	1.14
274871	GR RIDGE ;2U	0.59
274881	PLEAS RDG;2U	0.94
274887	PILOT HIL;1U	0.94
274888	PILOT HIL;1E	24.62
274890	CAYUG;1U E	29.8
274891	CAYUG;2U E	29.8
275149	KEMPTON ;1E	24.62
276150	W2-048 E	1.36
290261	S-027 E	23.06
290265	S-028 E	23.06
293061	N-015 E	12.12
294392	P-010 E	15.39
296125	R-030 C3	5.9
296128	R-030 E3	23.58
296271	R-030 C2	5.83
296272	R-030 E2	23.3
296308	R-030 C1	5.83
296309	R-030 E1	23.3
905081	W4-005 C	0.86
905082	W4-005 E	37.37
909052	X2-022 E	18.92
917501	Z2-087 C	0.7
917502	Z2-087 E	30.46
924041	AB2-047 C O1	5.59
924042	AB2-047 E O1	37.43
924261	AB2-070 C O1	2.78
924262	AB2-070 E O1	18.6
925771	AC1-053 C	2.73
925772	AC1-053 E	18.26
925881	AC1-067 O1	219.35
930501	AB1-091 O1	110.96

Bus #	Bus	MW Impact
933411	AC2-154 C	3.34
933412	AC2-154 E	5.45
934721	AD1-100 C	48.31
934722	AD1-100 E	225.47
935001	AD1-133 C O1	18.1
935002	AD1-133 E O1	12.07
935141	AD1-148	4.94
936371	AD2-047 C O1	2.99
936372	AD2-047 E O1	32.19
936461	AD2-060	3.52
936771	AD2-100 C O1	10.55
936772	AD2-100 E O1	7.04
936781	AD2-101 C	7.11
936782	AD2-101 E	33.27
936972	AD2-131 E O1	2.22
937031	AD2-137 C O1	18.53
937032	AD2-137 E O1	86.74
937121	AD2-148 C O1	5.34
937122	AD2-148 E O1	25.01
937131	AD2-149 C O1	5.34
937132	AD2-149 E O1	25.01
937141	AD2-150 C O1	5.34
937142	AD2-150 E O1	25.01
937161	AD2-153 C O1	3.8
937162	AD2-153 E O1	17.78
937171	AD2-154 C O1	3.8
937172	AD2-154 E O1	17.78
937181	AD2-155 C O1	5.34
937182	AD2-155 E O1	25.01
937211	AD2-159 C	4.04
937212	AD2-159 E	18.9
937321	AD2-175 C	24.89
937322	AD2-175 E	16.59
938012	AE1-002 E O1	70.17
939351	AE1-166 C O1	20.52
939352	AE1-166 E O1	18.94
939401	AE1-172 C O1	15.26
939402	AE1-172 E O1	71.45
939741	AE1-205 C O1	14.83
939742	AE1-205 E O1	20.48
940101	AE1-252 C O1	26.01
940102	AE1-252 E O1	17.34
951741	J474 C	1.71
951742	J474 E	9.28
954181	J884	8.88
AB2-013	AB2-013	5.61
BLUEG	BLUEG	0.01
CARR	CARR	0.27
CBM-S1	CBM-S1	2.75
CBM-S2	CBM-S2	0.06
CBM-W1	CBM-W1	5.33
CBM-W2	CBM-W2	48.81

Bus #	Bus	MW Impact
CIN	CIN	2.54
DEARBORN	DEARBORN	1.27
G-007	G-007	0.73
HAMLET	HAMLET	0.06
IPL	IPL	1.1
LGEE	LGEE	0.03
MEC	MEC	13.64
O-066	O-066	2.47
RENSSELAER	RENSSELAER	0.21
TRIMBLE	TRIMBLE	0.04
WEC	WEC	1.22
Z1-043	Z1-043	14.81

Index 24

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
779430	938670	AE1-089 TAP	AEP	243219	05DUMONT	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	125.76	126.44	DC	21.09

Bus #	Bus	MW Impact
247900	05FR-11G E	6.85
247901	05FR-12G E	6.74
247902	05FR-21G E	7.2
247903	05FR-22G E	6.89
247904	05FR-3G E	13.96
247905	05FR-4G E	10.5
247906	05MDL-1G E	15.63
247907	05MDL-2G E	7.75
247912	05MDL-3G E	8.11
247913	05MDL-4G E	7.83
247943	T-127 E	7.83
270859	PWR VTR EC;R	7.11
274722	S-055 E	6.55
274809	UNIV PK N;5U	0.8
274811	UNIV PK N;7U	0.8
274812	UNIV PK N;8U	0.8
274814	UNIV PK N;0U	0.8
274815	UNIV PK N;XU	0.8
274888	PILOT HIL;1E	10.32
275149	KEMPTON ;1E	10.32
290021	O50 E	11.46
290051	GSG-6; E	6.16
290108	LEEDK;1U E	14.23
293061	N-015 E	8.96
293644	O22 E1	5.93
293645	O22 E2	11.51
294392	P-010 E	11.37
295109	WESTBROOK E	3.3
909145	X2-052	36.23
914641	Y2-103	26.18
915011	Y3-013 1	2.18
915021	Y3-013 2	2.18
915031	Y3-013 3	2.18
916221	Z1-073 E	3.18
916502	Z1-106 E1	0.73
916504	Z1-106 E2	0.73
916512	Z1-107 E	1.5
916522	Z1-108 E	1.45
917711	Z2-114 C	0.06
917712	Z2-114 E	0.4

Bus #	Bus	MW Impact
918052	AA1-018 E	9.8
920272	AA2-123 E	1.43
924471	AB2-096	24.87
925302	AB2-191 E	0.82
926311	AC1-109 1	1.1
926321	AC1-109 2	1.1
926331	AC1-110 1	1.1
926341	AC1-110 2	1.1
926351	AC1-111 1	0.44
926361	AC1-111 2	0.44
926371	AC1-111 3	0.44
926381	AC1-111 4	0.44
926391	AC1-111 5	0.44
926401	AC1-111 6	0.44
926431	AC1-114	1.4
927091	AC1-204 1	41.9
927101	AC1-204 2	41.91
927451	AC1-142A 1	2.42
927461	AC1-142A 2	2.42
927511	AC1-113 1	0.7
927521	AC1-113 2	0.7
930042	AB1-006 E	17.03
930391	AB1-080	2.15
930481	AB1-089	38.75
930501	AB1-091 O1	40.14
930741	AB1-122 1O1	41.99
930751	AB1-122 2O1	42.66
932601	AC2-080 C O1	3.72
932602	AC2-080 E O1	24.91
932881	AC2-115 1	1.4
932891	AC2-115 2	1.4
932921	AC2-116	0.49
932931	AC2-117	5.17
933411	AC2-154 C	1.4
933412	AC2-154 E	2.28
933431	AC2-156 C O1	0.55
933432	AC2-156 E O1	0.9
933911	AD1-013 C	1.08
933912	AD1-013 E	1.73
933931	AD1-016 C	0.54
933932	AD1-016 E	0.89
934101	AD1-039 1	4.12
934111	AD1-039 2	4.18
934401	AD1-064 C O1	1.88
934402	AD1-064 E O1	8.8
934431	AD1-067 C	0.08
934432	AD1-067 E	0.33
934701	AD1-098 C O1	4.06
934702	AD1-098 E O1	2.96
934721	AD1-100 C	11.12
934722	AD1-100 E	51.9
934871	AD1-116 C	0.57

Bus #	Bus	MW Impact
934872	AD1-116 E	0.93
934971	AD1-129 C	0.53
934972	AD1-129 E	0.35
935001	AD1-133 C O1	12.63
935002	AD1-133 E O1	8.42
935271	AD1-137 C	5.69
935272	AD1-137 E	38.05
936291	AD2-038 C O1	1.41
936292	AD2-038 E O1	9.44
936371	AD2-047 C O1	1.25
936372	AD2-047 E O1	13.49
936461	AD2-060	1.47
936511	AD2-066 C O1	4.99
936512	AD2-066 E O1	3.33
936781	AD2-101 C	2.48
936782	AD2-101 E	11.59
936961	AD2-130	0.32
936981	AD2-132 C	5.04
936982	AD2-132 E	23.6
937001	AD2-134 C	1.61
937002	AD2-134 E	6.66
937031	AD2-137 C O1	1.92
937032	AD2-137 E O1	9.0
937041	AD2-138 C	5.04
937042	AD2-138 E	23.6
937051	AD2-140 C O1	1.92
937052	AD2-140 E O1	8.99
937061	AD2-141 C O1	1.91
937062	AD2-141 E O1	9.0
937071	AD2-142 C O1	3.84
937072	AD2-142 E O1	17.98
937121	AD2-148 C O1	1.93
937122	AD2-148 E O1	9.02
937131	AD2-149 C O1	1.93
937132	AD2-149 E O1	9.02
937141	AD2-150 C O1	1.93
937142	AD2-150 E O1	9.02
937181	AD2-155 C O1	1.93
937182	AD2-155 E O1	9.02
937321	AD2-175 C	8.98
937322	AD2-175 E	5.98
937331	AD2-176 C O1	4.29
937332	AD2-176 E O1	2.86
937401	AD2-194 1	4.51
937411	AD2-194 2	4.51
938012	AE1-002 E O1	3.86
938511	AE1-070 1	5.29
938521	AE1-070 2	4.84
938671	AE1-089 C	74.55
938672	AE1-089 E	102.34
938851	AE1-113 C O1	5.18
938852	AE1-113 E O1	16.3

Bus #	Bus	MW Impact
939321	AE1-163 C O1	3.54
939322	AE1-163 E O1	21.77
939351	AE1-166 C O1	5.85
939352	AE1-166 E O1	5.4
939401	AE1-172 C O1	3.71
939402	AE1-172 E O1	17.38
939641	AE1-194 C	5.61
939642	AE1-194 E	37.52
939651	AE1-195 C	5.61
939652	AE1-195 E	37.52
939691	AE1-199	1.41
939701	AE1-201 C	1.17
939702	AE1-201 E	0.26
939732	AE1-204 E	0.17
939861	AE1-222 1	46.37
939871	AE1-222 2	47.11
939921	AE1-228 C O1	5.92
939922	AE1-228 E O1	3.95
939961	AE1-233 C O1	1.36
939962	AE1-233 E O1	5.62
940101	AE1-252 C O1	6.33
940102	AE1-252 E O1	4.22
AB2-013	AB2-013	10.01
AE1-033	AE1-033	10.77
CARR	CARR	0.59
CATAWBA	CATAWBA	0.05
CBM-S1	CBM-S1	4.6
CBM-W1	CBM-W1	19.73
CBM-W2	CBM-W2	68.15
CIN	CIN	7.05
DEARBORN	DEARBORN	1.82
G-007	G-007	1.64
HAMLET	HAMLET	0.34
IPL	IPL	3.28
LGEE	LGEE	0.73
MEC	MEC	25.32
O-066	O-066	5.54
RENSSELAER	RENSSELAER	0.47
WEC	WEC	4.7
Z1-043	Z1-043	17.65

Index 25

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
172973	939400	AE1-172 TAP	CE	934720	AD1-100 TAP	CE	1	COMED_P1-2_345-L8014____-S-B	single	1528.0	113.38	115.71	DC	35.5

Bus #	Bus	MW Impact
274650	KINCAID ;1U	17.25
274651	KINCAID ;2U	17.28
274853	TWINGROVE;U1	2.5
274854	TWINGROVE;U2	2.5
274863	CAYUGA RI;1U	2.82
274864	CAYUGA RI;2U	2.82
900404	X3-028 C	84.69
905081	W4-005 C	2.39
917501	Z2-087 C	2.01
924041	AB2-047 C O1	16.06
924261	AB2-070 C O1	7.65
925771	AC1-053 C	7.49
926841	AC1-171 C O1	0.96
930461	AB1-087	31.05
930471	AB1-088	31.05
933441	AC2-157 C	4.29
935001	AD1-133 C O1	90.83
935141	AD1-148	13.51
936771	AD2-100 C O1	28.25
937161	AD2-153 C O1	10.77
937171	AD2-154 C O1	10.77
937211	AD2-159 C	11.3
939401	AE1-172 C O1	35.5
939741	AE1-205 C O1	42.48
940101	AE1-252 C O1	60.51
950701	J196 C	1.14
951001	J339	12.81
951741	J474 C	5.17
952271	J644	13.59
952321	J734	10.76
952651	J756 C	4.83
952871	J757 C	5.78
953241	J467 C	1.82
953401	J811	10.88
953651	J815	37.45
953741	J826 C	3.19
953801	J835 C	3.81
953851	J845 C	3.12
953881	J848 C	5.76
954081	J872 C	4.43

Bus #	Bus	MW Impact
954181	J884	26.75
954411	J912	14.21
954721	J750 C	3.62
AD2-098	AD2-098	0.36
AE1-042	AE1-042	6.61
CBM-N	CBM-N	0.57
CBM-S1	CBM-S1	11.07
CBM-S2	CBM-S2	3.34
CBM-W2	CBM-W2	129.48
CIN	CIN	11.59
CPLE	CPLE	1.17
DEARBORN	DEARBORN	0.85
G-007A	G-007A	1.93
IPL	IPL	6.27
LGEE	LGEE	1.7
MEC	MEC	9.12
NYISO	NYISO	2.48
O-066A	O-066A	0.9
VFT	VFT	5.19

Affected Systems

MISO

MISO Impacts to be determined during later study phases (as applicable).

Contingency Name	Contingency Definition
COMED_P1-2_345-L11212_B-S-A	CONTINGENCY 'COMED_P1-2_345-L11212_B-S-A' TRIP BRANCH FROM BUS 270926 TO BUS 937030 CKT 1 / WILTO; B 345 AD2-137 TAP 345 END
AEP_P1-2_#8907	CONTINGENCY 'AEP_P1-2_#8907' OPEN BRANCH FROM BUS 247712 TO BUS 346809 CKT 1 / 247712 05SULLIVAN 345 346809 7CASEY 345 1 END
COMED_P4_112-65-BT3-4__	CONTINGENCY 'COMED_P4_112-65-BT3-4__' TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33 END
COMED_P1-2_765-L11216__S	CONTINGENCY 'COMED_P1-2_765-L11216__S' TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765 END
COMED_P4_023-65-BT2-3__	CONTINGENCY 'COMED_P4_023-65-BT2-3__' TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765 END
AEP_P1-2_#286	CONTINGENCY 'AEP_P1-2_#286' OPEN BRANCH FROM BUS 243221 TO BUS 348885 CKT 1 / 243221 05EUGENE 345 348885 7BUNSONVILLE 345 1 END
COMED_P7_345-L94507_B-S_+_345-L97008_R-S	CONTINGENCY 'COMED_P7_345-L94507_B-S_+_345-L97008_R-S' TRIP BRANCH FROM BUS 274750 TO BUS 255112 CKT 1 / CRETE;BP 345 17STJOHN 345 TRIP BRANCH FROM BUS 274804 TO BUS 243229 CKT 1 / UPNOR;RP 345 05OLIVE 345 END
COMED_P1-2_345-L11212_B-S-C-A	CONTINGENCY 'COMED_P1-2_345-L11212_B-S-C-A' TRIP BRANCH FROM BUS 934720 TO BUS 939400 CKT 1 / AD1-100 TAP 345 AE1-172 TAP 345 END
AEP_P4_#3128_05EUGENE 345_A2	CONTINGENCY 'AEP_P4_#3128_05EUGENE 345_A2' OPEN BRANCH FROM BUS 243221 TO BUS 249504 CKT 1 / 243221 05EUGENE 345 249504 08CAYSUB 345 1 OPEN BRANCH FROM BUS 243221 TO BUS 348885 CKT 1 / 243221 05EUGENE 345 348885 7BUNSONVILLE 345 1 END


Contingency Name	Contingency Definition
COMED_P7_345-L2001__B-S+_345-L2003__R-S	CONTINGENCY 'COMED_P7_345-L2001__B-S+_345-L2003__R-S' TRIP BRANCH FROM BUS 270670 TO BUS 270728 CKT 1 / BRAID; B 345 E FRA; B 345 TRIP BRANCH FROM BUS 270728 TO BUS 270766 CKT 1 / E FRA; B 345 GOODI;3B 345 TRIP BRANCH FROM BUS 270728 TO BUS 274750 CKT 1 / E FRA; B 345 CRETE;BP 345 TRIP BRANCH FROM BUS 270671 TO BUS 270729 CKT 1 / BRAID; R 345 E FRA; R 345 END
AEP_P4_#7334_05JEFRSO 765_A2	CONTINGENCY 'AEP_P4_#7334_05JEFRSO 765_A2' OPEN BRANCH FROM BUS 242924 TO BUS 243208 CKT 1 / 242924 05HANG R 765 243208 05JEFRSO 765 1 OPEN BRANCH FROM BUS 243208 TO BUS 242865 CKT 2 / 243208 05JEFRSO 765 242865 05JEFRSO 345 2 OPEN BRANCH FROM BUS 242865 TO BUS 248000 CKT Z1 / 242865 05JEFRSO 345 248000 06CLIFTY 345 Z1 END
COMED_P1-2_345-L8014__S-A	CONTINGENCY 'COMED_P1-2_345-L8014__S-A' TRIP BRANCH FROM BUS 270853 TO BUS 935000 CKT 1 / PONTIAC ; R 345 AD1-133 TAP 345 END
COMED_P4_023-65-BT4-5__	CONTINGENCY 'COMED_P4_023-65-BT4-5__' TRIP BRANCH FROM BUS 275168 TO BUS 270607 CKT 1 / COLLI;2M 345 COLLI; 765 TRIP BRANCH FROM BUS 275168 TO BUS 270697 CKT 1 / COLLI;2M 345 COLLI; R 345 TRIP BRANCH FROM BUS 275168 TO BUS 275268 CKT 1 / COLLI;2M 345 COLLI;2C 33 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 END
COMED_P1-2_345-L8014__S-B	CONTINGENCY 'COMED_P1-2_345-L8014__S-B' TRIP BRANCH FROM BUS 935000 TO BUS 270717 CKT 1 / AD1-133 TAP 345 DRESDEN ; R 345 END
COMED_P1-2_345-L1223_TR-S	CONTINGENCY 'COMED_P1-2_345-L1223_TR-S' TRIP BRANCH FROM BUS 270717 TO BUS 270731 CKT 1 / DRESD; R 345 ELECT;4R 345 TRIP BRANCH FROM BUS 275180 TO BUS 270717 CKT 1 / DRESD;3M 138 DRESD; R 345 TRIP BRANCH FROM BUS 275180 TO BUS 271336 CKT 1 / DRESD;3M 138 DRESD; B 138 TRIP BRANCH FROM BUS 275180 TO BUS 275280 CKT 1 / DRESD;3M 138 DRESD;3C 34.5 END
COMED_P4_112-65-BT4-5__	CONTINGENCY 'COMED_P4_112-65-BT4-5__' TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33 END
COMED_P7_345-L6607__B-S+_345-L97008_R-S	CONTINGENCY 'COMED_P7_345-L6607__B-S+_345-L97008_R-S' TRIP BRANCH FROM BUS 270728 TO BUS 274750 CKT 1 / E FRANKFO; B 345 CRETE EC ;BP 345 TRIP BRANCH FROM BUS 274804 TO BUS 243229 CKT 1 / UNIV PK N;RP 345 05OLIVE 345 END
Base Case	

Contingency Name	Contingency Definition
AEP_P1-2_#695A	CONTINGENCY 'AEP_P1-2_#695A' OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1 END
COMED_P7_345-L17704AR-S+_345-L17907TB-S-A	CONTINGENCY 'COMED_P7_345-L17704AR-S+_345-L17907TB-S-A' TRIP BRANCH FROM BUS 270675 TO BUS 925880 CKT 1 / BURNHAM ;1R 345 AC1-067 TAP 345 TRIP BRANCH FROM BUS 270662 TO BUS 936780 CKT 1 / BLOOM ; B 345 AD2-101 TAP 345 TRIP BRANCH FROM BUS 270662 TO BUS 271098 TO BUS 275258 CKT 1 / BLOOM ; B 345 BLOOM ; B 138 BLOOM ;4C 34.5 END
COMED_P4_111-45-L1223T_	CONTINGENCY 'COMED_P4_111-45-L1223T_' TRIP BRANCH FROM BUS 270717 TO BUS 270731 CKT 1 / DRESDEN ; R 345 ELEC JUNC;4R 345 TRIP BRANCH FROM BUS 275180 TO BUS 270717 CKT 1 / DRESDEN ;3M 138 DRESDEN ; R 345 TRIP BRANCH FROM BUS 275180 TO BUS 271336 CKT 1 / DRESDEN ;3M 138 DRESDEN ; B 138 TRIP BRANCH FROM BUS 275180 TO BUS 275280 CKT 1 / DRESDEN ;3M 138 DRESDEN ;3C 34.5 DISCONNECT BUS 270731 / ELEC JUNC;4R 345 DISCONNECT BUS 275184 / ELEC JUNC;4M 138 END
AEP_P4_#8805_05OLIVE 345_D	CONTINGENCY 'AEP_P4_#8805_05OLIVE 345_D' OPEN BRANCH FROM BUS 243229 TO BUS 932600 CKT 1 / 243229 05OLIVE 345 932600 AC2-080 TAP 345 1 /* CONTINGENCY LINE ADDED FOR AE1 BUILD OPEN BRANCH FROM BUS 243229 TO BUS 274804 CKT 1 / 243229 05OLIVE 345 274804 UNIV PK N;RP 345 1 END
COMED_P4_112-65-BT2-3__	CONTINGENCY 'COMED_P4_112-65-BT2-3__' TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33 END
AEP_P4_#2978_05DUMONT 765_B	CONTINGENCY 'AEP_P4_#2978_05DUMONT 765_B' OPEN BRANCH FROM BUS 243206 TO BUS 243207 CKT 1 / 243206 05DUMONT 765 243207 05GRNTWN 765 1 OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1 END
COMED_P4_112-65-BT5-6__	CONTINGENCY 'COMED_P4_112-65-BT5-6__' TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33 END
AEP_P1-2_#697A	CONTINGENCY 'AEP_P1-2_#697A' OPEN BRANCH FROM BUS 243229 TO BUS 274804 CKT 1 / 243229 05OLIVE 345 274804 UNIV PK N;RP 345 1 END

Short Circuit

No issues identified

Secondary Point of Interconnection Network Impacts



The Queue Project AE1-172 was evaluated as a 300 MW (Capacity 52.8 MW) injection at the Loretto; B 345 kV substation in the ComEd area. Project AE1-172 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE1-172 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Load Flow

Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

ID	FROM	FROM	FROM	TO	TO BUS	TO	CKT	CONT NAME	Type	Rating	PRE	POST	AC DC	MW
----	------	------	------	----	--------	----	-----	-----------	------	--------	-----	------	-------	----

	BUS#	BUS	BUS AREA	BUS#		BUS AREA	ID			MVA	PROJECT LOADING %	PROJECT LOADING %		IMPACT
468953	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P4_#8805_05OLIVE 345_D	breaker	4105.0	97.2	97.84	DC	87.74
785579	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P4_#8805_05OLIVE 345_D	breaker	4105.0	97.2	97.84	DC	87.74
785498	270717	DRESDEN ; R	CE	270697	COLLINS ; R	CE	1	COMED_P4_111-45-L1223T_	breaker	1528.0	99.98	100.54	DC	18.79
786761	925880	AC1-067 TAP	CE	270675	BURNHAM ;1R	CE	1	COMED_P7_345-L2001_B-S+_345-L2003_R-S	tower	1768.0	99.8	100.22	DC	16.27

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC/D C	MW IMPACT
468650	243918	05ELDERBRYSS	AEP	938670	AE1-089 TAP	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	117.38	118.05	DC	21.09
468651	243918	05ELDERBRYSS	AEP	938670	AE1-089 TAP	AEP	1	COMED_P4_112-65-BT4-5_	breaker	1409.0	108.44	108.97	DC	22.47
468652	243918	05ELDERBRYSS	AEP	938670	AE1-089 TAP	AEP	1	COMED_P4_112-65-BT3-4_	breaker	1409.0	108.44	108.97	DC	22.47
468653	243918	05ELDERBRYSS	AEP	938670	AE1-089 TAP	AEP	1	COMED_P4_023-65-BT2-3_	breaker	1409.0	108.44	108.97	DC	22.46
785471	255104	17GREEN_ACRE	NIPS	270771	GREENACRE; T	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	103.28	103.93	DC	23.27
785305	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	109.05	109.91	DC	25.31
785306	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_023-65-BT2-3_	breaker	1091.0	111.35	112.16	DC	25.42
785307	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_112-65-BT4-5_	breaker	1091.0	109.25	110.11	DC	25.45
785308	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_112-65-BT3-4_	breaker	1091.0	109.25	110.1	DC	25.45
468325	255113	17STILLWELL	NIPS	243219	05DUMONT	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	173.75	174.48	DC	40.94
470178	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L94507_B-S+_345-L97008_R-S	tower	4105.0	103.81	104.34	DC	94.14
470179	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L6607_B-S+_345-L97008_R-S	tower	4105.0	103.04	103.64	DC	94.27
786672	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L94507_B-S+_345-L97008_R-S	tower	4105.0	103.81	104.34	DC	94.14
786673	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L6607_B-S+_345-L97008_R-S	tower	4105.0	103.04	103.64	DC	94.27
785476	270677	BURNHAM ;0R	CE	255109	17MUNSTER	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1441.0	113.0	113.66	DC	35.12
785455	270728	E FRANKFO; B	CE	274750	CRETE EC;BP	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	111.21	112.16	DC	35.54
785456	270728	E FRANKFO; B	CE	274750	CRETE EC;BP	CE	1	COMED_P4_023-65-BT2-3_	breaker	1399.0	110.87	111.8	DC	35.59
785457	270728	E FRANKFO; B	CE	274750	CRETE EC;BP	CE	1	COMED_P4_112-65-BT4-5_	breaker	1399.0	110.78	111.71	DC	35.65
785458	270728	E FRANKFO; B	CE	274750	CRETE EC;BP	CE	1	COMED_P4_112-65-BT3-4_	breaker	1399.0	110.78	111.71	DC	35.65

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC/D C	MW IMPACT
468589	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	116.02	116.75	DC	23.27
785347	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	116.02	116.75	DC	23.27
785835	270853	PONTIAC ; R	CE	935000	AD1-133 TAP	CE	1	COMED_P1-2_345-L11212_B-S-C-A	single	1528.0	100.36	101.97	DC	24.59
785310	270886	ST JOHN ; T	CE	255104	17GREEN_ACR E	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	109.05	109.91	DC	25.31
785311	270886	ST JOHN ; T	CE	255104	17GREEN_ACR E	NIPS	1	COMED_P4_023-65-BT2-3__	breaker	1091.0	111.35	112.16	DC	25.42
785312	270886	ST JOHN ; T	CE	255104	17GREEN_ACR E	NIPS	1	COMED_P4_112-65-BT4-5__	breaker	1091.0	109.25	110.11	DC	25.45
785313	270886	ST JOHN ; T	CE	255104	17GREEN_ACR E	NIPS	1	COMED_P4_112-65-BT3-4__	breaker	1091.0	109.25	110.1	DC	25.45
785171	270926	WILTON ; B	CE	275232	WILTON ;3M	CE	1	COMED_P4_112-65-BT5-6__	breaker	1379.0	166.12	166.76	DC	54.08
785173	270927	WILTON ; R	CE	275233	WILTON ;4M	CE	1	COMED_P4_112-65-BT2-3__	breaker	1379.0	164.02	164.96	DC	55.15
785203	274750	CRETE EC;BP	CE	255112	17STJOHN	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	124.49	125.51	DC	35.06
785204	274750	CRETE EC;BP	CE	255112	17STJOHN	NIPS	1	COMED_P4_023-65-BT2-3__	breaker	1399.0	123.91	124.93	DC	35.11
785205	274750	CRETE EC;BP	CE	255112	17STJOHN	NIPS	1	COMED_P4_112-65-BT4-5__	breaker	1399.0	123.84	124.87	DC	35.17
785206	274750	CRETE EC;BP	CE	255112	17STJOHN	NIPS	1	COMED_P4_112-65-BT3-4__	breaker	1399.0	123.84	124.86	DC	35.17
468458	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	134.92	135.87	DC	27.88
468459	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT2-3__	breaker	971.0	132.89	133.93	DC	28.04
468460	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT4-5__	breaker	971.0	133.69	134.65	DC	28.05
468461	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT3-4__	breaker	971.0	133.69	134.65	DC	28.05
468462	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT4-5__	breaker	971.0	133.69	134.65	DC	28.06
785265	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	134.92	135.87	DC	27.88
785266	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT2-3__	breaker	971.0	132.89	133.93	DC	28.04
785267	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT4-5__	breaker	971.0	133.69	134.65	DC	28.05
785268	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT3-4__	breaker	971.0	133.69	134.65	DC	28.05
785269	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT4-5__	breaker	971.0	133.69	134.65	DC	28.06
785170	275232	WILTON ;3M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT5-6__	breaker	1379.0	166.12	166.76	DC	54.08
785175	275233	WILTON ;4M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT2-3__	breaker	1379.0	164.02	164.96	DC	55.15
468425	346809	7CASEY	AMIL	247712	05SULLIVAN	AEP	1	AEP_P4_#3128_05EUGEN E 345_A2	breaker	1466.0	143.62	144.34	DC	22.83
468898	932800	AC2-104 TAP	AEP	242928	05MARYSV	AEP	1	AEP_P4_#7334_05JEFRSO 765_A2	breaker	4571.0	103.34	103.44	DC	75.35
786511	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	COMED_P7_345-L17704AR-S_+ 345-L17907TB-S-A	tower	1846.0	138.35	143.04	DC	86.71
786512	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	COMED_P7_345-L2001_B-S_+ 345-L2003_R-S	tower	1846.0	135.55	140.46	DC	90.56
785809	935000	AD1-133 TAP	CE	270717	DRESDEN ; R	CE	1	COMED_P1-2_345-L11212_B-S-C-A	single	1528.0	108.1	109.71	DC	24.59
786485	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	COMED_P7_345-L17704AR-S_+ 345-L17907TB-S-A	tower	1846.0	145.54	150.23	DC	86.71

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
786486	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	COMED_P7_345-L2001_B-S+_345-L2003_R-S	tower	1846.0	143.09	147.99	DC	90.56
468587	938670	AE1-089 TAP	AEP	243219	05DUMONT	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	125.75	126.43	DC	21.09
785766	939400	AE1-172 TAP	CE	934720	AD1-100 TAP	CE	1	COMED_P1-2_345-L8014_-S-B	single	1528.0	113.38	115.71	DC	35.5
785767	939400	AE1-172 TAP	CE	934720	AD1-100 TAP	CE	1	COMED_P1-2_345-L8014_-S-A	single	1528.0	108.06	110.39	DC	35.5

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
469614	243918	05ELDERBRYSS	AEP	938670	AE1-089 TAP	AEP	1	AEP_P1-2_#695A	operation	1409.0	108.43	108.97	DC	22.47
786186	255104	17GREEN_ACRE	NIPS	270771	GREENACRE; T	CE	1	AEP_P1-2_#695A	operation	1091.0	102.0	102.65	DC	23.48
786013	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	AEP_P1-2_#695A	operation	1091.0	109.24	110.09	DC	25.46
469149	255113	17STILLWELL	NIPS	243219	05DUMONT	AEP	1	AEP_P1-2_#695A	operation	1409.0	170.24	171.0	DC	41.8
469155	255113	17STILLWELL	NIPS	243219	05DUMONT	AEP	1	Base Case	operation	1409.0	111.2	111.62	DC	22.68
469678	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	Base Case	operation	3555.0	105.84	106.35	DC	81.9
469679	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P1-2_#697A	operation	4105.0	97.17	97.8	DC	87.77
786259	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	Base Case	operation	3555.0	105.84	106.35	DC	81.9
786260	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P1-2_#697A	operation	4105.0	97.17	97.8	DC	87.77
786185	270677	BURNHAM ;OR	CE	255109	17MUNSTER	NIPS	1	AEP_P1-2_#695A	operation	1441.0	112.17	112.83	DC	35.3
786210	270717	DRESDEN ; R	CE	270697	COLLINS ; R	CE	1	COMED_P1-2_345-L1223_TR-S	operation	1528.0	99.84	100.4	DC	18.87
786163	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	AEP_P1-2_#695A	operation	1399.0	110.74	111.67	DC	35.68
469394	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	114.58	115.31	DC	23.48
786062	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	114.58	115.31	DC	23.48

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
786095	270796	KINCAID ; B	CE	347955	7AUSTIN	AMIL	1	COMED_P1-2_345-L11212_B-S-C-A	operation	956.0	117.43	121.56	DC	39.74
785830	270853	PONTIAC ; R	CE	935000	AD1-133 TAP	CE	1	COMED_P1-2_345-L11212_B-S-C-A	operation	1528.0	174.88	184.03	DC	139.69
785834	270853	PONTIAC ; R	CE	935000	AD1-133 TAP	CE	1	Base Case	operation	1334.0	120.62	124.03	DC	45.48
786009	270886	ST JOHN ; T	CE	255104	17GREEN_ACRE	NIPS	1	AEP_P1-2_#695A	operation	1091.0	109.24	110.09	DC	25.46
786289	270926	WILTON ; B	CE	275232	WILTON ;3M	CE	1	COMED_P1-2_765-L11216_-S	operation	1379.0	104.28	104.69	DC	34.0
786258	270927	WILTON ; R	CE	275233	WILTON ;4M	CE	1	COMED_P1-2_765-L11216_-S	operation	1379.0	105.78	106.39	DC	35.52
785931	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	AEP_P1-2_#695A	operation	1399.0	123.8	124.82	DC	35.2
469319	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	133.68	134.64	DC	28.06
785991	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	133.68	134.64	DC	28.06
469313	346809	7CASEY	AMIL	247712	05SULLIVAN	AEP	1	AEP_P1-2_#286	operation	1466.0	137.95	138.68	DC	23.22
469314	346809	7CASEY	AMIL	247712	05SULLIVAN	AEP	1	Base Case	operation	1334.0	122.14	122.76	DC	18.01
469788	348885	7BUNSONVILLE	AMIL	243221	05EUGENE	AEP	1	AEP_P1-2_#8907	operation	1793.0	101.24	101.71	DC	24.64
785926	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	COMED_P1-2_345-L8014_-S-B	operation	1528.0	152.43	158.48	DC	92.45
785930	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	Base Case	operation	1364.0	135.19	141.16	DC	81.35
786312	934730	AD1-100 TAP	CE	270670	BRAIDWOOD; B	CE	1	COMED_P1-2_345-L11212_B-S-A	operation	1528.0	89.65	96.89	DC	110.59
785804	935000	AD1-133 TAP	CE	270717	DRESDEN ; R	CE	1	COMED_P1-2_345-L11212_B-S-C-A	operation	1528.0	187.87	197.02	DC	139.69
785807	935000	AD1-133 TAP	CE	270717	DRESDEN ; R	CE	1	Base Case	operation	1334.0	133.29	136.7	DC	45.48
785889	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	COMED_P1-2_345-L8014_-S-B	operation	1528.0	159.13	165.18	DC	92.45
785893	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	Base Case	operation	1364.0	145.09	151.06	DC	81.35
469485	938670	AE1-089 TAP	AEP	243219	05DUMONT	AEP	1	AEP_P1-2_#695A	operation	1409.0	116.22	116.95	DC	22.47
785761	939400	AE1-172 TAP	CE	934720	AD1-100 TAP	CE	1	COMED_P1-2_345-L8014_-S-B	operation	1528.0	199.8	213.0	DC	201.7
785763	939400	AE1-172 TAP	CE	934720	AD1-100 TAP	CE	1	Base Case	operation	1364.0	149.46	162.34	DC	175.68

Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gauge other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
786672	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L94507_B-S+_345-L97008_R-S	tower	4105.0	103.81	104.34	DC	94.14

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	32.17
274722	S-055 E	29.55
274772	LINCOLN ;3U	4.7
274773	LINCOLN ;4U	4.7
274774	LINCOLN ;5U	4.7
274775	LINCOLN ;6U	4.7
274776	LINCOLN ;7U	4.7
274777	LINCOLN ;8U	4.7
274832	U4-027	28.06
274859	EASYR;U1 E	29.13
274860	EASYR;U2 E	29.13
274888	PILOT HIL;1E	44.3
274890	CAYUG;1U E	36.07
274891	CAYUG;2U E	36.07
275149	KEMPTON ;1E	44.3
290021	O50 E	49.24
290051	GSG-6; E	28.08
290108	LEEDK;1U E	65.57
293061	N-015 E	41.22
293516	O-009 E1	23.79
293517	O-009 E2	12.09
293518	O-009 E3	13.31
293644	O22 E1	25.31
293645	O22 E2	49.12
293715	O-029 E	25.78
293716	O-029 E	14.13
293717	O-029 E	12.99
293771	O-035 E	16.49
294392	P-010 E	52.34
294763	P-046 E	24.88
295109	WESTBROOK E	15.03
295111	SUBLETTE E	6.87
296125	R-030 C3	9.31
296128	R-030 E3	37.24
296271	R-030 C2	9.2
296272	R-030 E2	36.8
296308	R-030 C1	9.2
296309	R-030 E1	36.8
910542	X3-005 E	1.57
914641	Y2-103	118.19

Bus #	Bus	MW Impact
915011	Y3-013 1	9.85
915021	Y3-013 2	9.85
915031	Y3-013 3	9.85
916211	Z1-072 E	12.48
916221	Z1-073 E	14.49
916502	Z1-106 E1	3.41
916504	Z1-106 E2	3.41
916512	Z1-107 E	6.53
916522	Z1-108 E	6.62
917502	Z2-087 E	48.13
918052	AA1-018 E	40.41
919221	AA1-146	46.5
919581	AA2-030	46.5
919621	AA2-039 C	3.78
919622	AA2-039 E	25.31
920272	AA2-123 E	6.51
924471	AB2-096	112.6
925161	AB2-173	8.29
925302	AB2-191 E	3.72
925581	AC1-033 C	3.62
925582	AC1-033 E	24.22
926311	AC1-109 1	5.21
926321	AC1-109 2	5.21
926331	AC1-110 1	5.12
926341	AC1-110 2	5.12
926351	AC1-111 1	2.07
926361	AC1-111 2	2.07
926371	AC1-111 3	2.07
926381	AC1-111 4	2.07
926391	AC1-111 5	2.07
926401	AC1-111 6	2.07
926431	AC1-114	6.32
926821	AC1-168 C O1	2.98
926822	AC1-168 E O1	20.01
927091	AC1-204 1	184.27
927101	AC1-204 2	184.31
927201	AC1-214 C O1	5.29
927202	AC1-214 E O1	16.83
927451	AC1-142A 1	10.61
927461	AC1-142A 2	10.61
927511	AC1-113 1	3.16
927521	AC1-113 2	3.16
927531	AC1-185 1	1.82
927541	AC1-185 2	1.82
927551	AC1-185 3	1.82
927561	AC1-185 4	1.82
927571	AC1-185 5	1.82
927581	AC1-185 6	1.82
927591	AC1-185 7	1.82
927601	AC1-185 8	1.82
930481	AB1-089	175.15
930501	AB1-091 O1	173.97

Bus #	Bus	MW Impact
930741	AB1-122 1O1	194.95
930751	AB1-122 2O1	188.67
932881	AC2-115 1	6.32
932891	AC2-115 2	6.32
932921	AC2-116	2.21
932931	AC2-117	14.95
933341	AC2-147 C	2.31
933342	AC2-147 E	3.77
933411	AC2-154 C	6.01
933412	AC2-154 E	9.81
933431	AC2-156 C O1	2.64
933432	AC2-156 E O1	4.3
933911	AD1-013 C	4.95
933912	AD1-013 E	7.9
933931	AD1-016 C	2.47
933932	AD1-016 E	4.03
934051	AD1-031 C O1	7.35
934052	AD1-031 E O1	11.99
934101	AD1-039 1	19.1
934111	AD1-039 2	18.49
934401	AD1-064 C O1	8.56
934402	AD1-064 E O1	40.08
934431	AD1-067 C	0.35
934432	AD1-067 E	1.48
934651	AD1-096 C	2.37
934652	AD1-096 E	3.86
934701	AD1-098 C O1	18.47
934702	AD1-098 E O1	13.48
934721	AD1-100 C	51.04
934722	AD1-100 E	238.17
934871	AD1-116 C	2.35
934872	AD1-116 E	3.84
934881	AD1-117 C	14.23
934882	AD1-117 E	9.49
934971	AD1-129 C	2.4
934972	AD1-129 E	1.6
935001	AD1-133 C O1	55.95
935002	AD1-133 E O1	37.3
936291	AD2-038 C O1	5.86
936292	AD2-038 E O1	39.2
936371	AD2-047 C O1	5.38
936372	AD2-047 E O1	57.91
936461	AD2-060	6.33
936511	AD2-066 C O1	21.47
936512	AD2-066 E O1	14.31
936781	AD2-101 C	10.68
936782	AD2-101 E	49.98
936791	AD2-102 C	31.89
936792	AD2-102 E	30.64
936961	AD2-130	1.4
937001	AD2-134 C	7.34
937002	AD2-134 E	30.33

Bus #	Bus	MW Impact
937031	AD2-137 C O1	10.26
937032	AD2-137 E O1	48.01
937051	AD2-140 C O1	10.5
937052	AD2-140 E O1	49.17
937061	AD2-141 C O1	10.44
937062	AD2-141 E O1	49.23
937071	AD2-142 C O1	21.0
937072	AD2-142 E O1	98.34
937121	AD2-148 C O1	8.35
937122	AD2-148 E O1	39.1
937131	AD2-149 C O1	8.35
937132	AD2-149 E O1	39.1
937141	AD2-150 C O1	8.35
937142	AD2-150 E O1	39.1
937181	AD2-155 C O1	8.35
937182	AD2-155 E O1	39.1
937311	AD2-172 C	6.53
937312	AD2-172 E	9.02
937321	AD2-175 C	38.91
937322	AD2-175 E	25.94
937331	AD2-176 C O1	19.52
937332	AD2-176 E O1	13.01
937401	AD2-194 1	19.82
937411	AD2-194 2	19.82
937531	AD2-214 C	11.6
937532	AD2-214 E	5.46
938012	AE1-002 E O1	20.59
938511	AE1-070 1	23.28
938521	AE1-070 2	21.31
938851	AE1-113 C O1	21.75
938852	AE1-113 E O1	68.37
938861	AE1-114 C O1	9.46
938862	AE1-114 E O1	36.16
939051	AE1-134 1	3.61
939061	AE1-134 2	3.61
939321	AE1-163 C O1	14.69
939322	AE1-163 E O1	90.24
939351	AE1-166 C O1	26.27
939352	AE1-166 E O1	24.25
939401	AE1-172 C O1	16.57
939402	AE1-172 E O1	77.57
939631	AE1-193 C O1	17.95
939632	AE1-193 E O1	120.14
939641	AE1-194 C	21.1
939642	AE1-194 E	141.24
939651	AE1-195 C	21.1
939652	AE1-195 E	141.24
939681	AE1-198 C O1	53.3
939682	AE1-198 E O1	45.3
939691	AE1-199	6.42
939701	AE1-201 C	5.34
939702	AE1-201 E	1.17

Bus #	Bus	MW Impact
939732	AE1-204 E	0.77
939741	AE1-205 C O1	23.29
939742	AE1-205 E O1	32.16
939861	AE1-222 1	215.29
939871	AE1-222 2	208.36
939921	AE1-228 C O1	27.02
939922	AE1-228 E O1	18.01
939961	AE1-233 C O1	6.29
939962	AE1-233 E O1	25.97
940101	AE1-252 C O1	27.05
940102	AE1-252 E O1	18.03
AB2-013	AB2-013	41.07
AE1-033	AE1-033	47.69
BLUEG	BLUEG	16.82
CALDERWOOD	CALDERWOOD	0.23
CANNELTON	CANNELTON	0.26
CARR	CARR	1.97
CATAWBA	CATAWBA	0.8
CBM-S1	CBM-S1	3.44
CBM-W1	CBM-W1	76.96
CBM-W2	CBM-W2	140.68
CHEOAH	CHEOAH	0.24
CHILHOWEE	CHILHOWEE	0.07
DEARBORN	DEARBORN	6.43
ELMERSMITH	ELMERSMITH	0.27
G-007	G-007	5.53
GIBSON	GIBSON	0.08
HAMLET	HAMLET	3.02
MEC	MEC	98.2
O-066	O-066	18.61
RENSSELAER	RENSSELAER	1.56
SANTEETLA	SANTEETLA	0.08
TRIMBLE	TRIMBLE	1.99
WEC	WEC	20.94
Z1-043	Z1-043	73.86

Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785498	270717	DRESDEN ; R	CE	270697	COLLINS ; R	CE	1	COMED_P4_111-45-L1223T_	breaker	1528.0	99.98	100.54	DC	18.79

Bus #	Bus	MW Impact
274659	DRESDEN ;3U	42.28
274729	ELWOOD EC;1P	2.69
274731	ELWOOD EC;2P	2.69
274733	ELWOOD EC;3P	2.69
274735	ELWOOD EC;4P	2.69
274736	ELWOOD EC;9P	2.66
274890	CAYUG;1U E	9.67
274891	CAYUG;2U E	9.67
276150	W2-048 E	0.97
290021	O50 E	11.1
290261	S-027 E	15.15
290265	S-028 E	15.15
296125	R-030 C3	3.8
296128	R-030 E3	15.19
296271	R-030 C2	3.75
296272	R-030 E2	15.01
296308	R-030 C1	3.75
296309	R-030 E1	15.01
905082	W4-005 E	25.39
909052	X2-022 E	13.53
917502	Z2-087 E	19.63
924041	AB2-047 C O1	3.61
924042	AB2-047 E O1	24.18
924261	AB2-070 C O1	1.95
924262	AB2-070 E O1	13.08
925771	AC1-053 C	1.93
925772	AC1-053 E	12.91
926841	AC1-171 C O1	0.6
926842	AC1-171 E O1	4.0
927091	AC1-204 1	64.57
927101	AC1-204 2	65.35
930741	AB1-122 1O1	173.78
930751	AB1-122 2O1	33.89
934101	AD1-039 1	17.03
934111	AD1-039 2	3.32
935001	AD1-133 C O1	39.0
935002	AD1-133 E O1	26.0
935141	AD1-148	3.54
936291	AD2-038 C O1	1.13
936292	AD2-038 E O1	7.56
936771	AD2-100 C O1	7.92

Bus #	Bus	MW Impact
936772	AD2-100 E O1	5.28
936972	AD2-131 E O1	1.67
937161	AD2-153 C O1	2.52
937162	AD2-153 E O1	11.79
937171	AD2-154 C O1	2.52
937172	AD2-154 E O1	11.79
937211	AD2-159 C	2.74
937212	AD2-159 E	12.84
937401	AD2-194 1	6.94
937411	AD2-194 2	7.03
938511	AE1-070 1	8.16
938521	AE1-070 2	7.55
938851	AE1-113 C O1	4.19
938852	AE1-113 E O1	13.18
939321	AE1-163 C O1	3.11
939322	AE1-163 E O1	19.12
939401	AE1-172 C O1	3.31
939402	AE1-172 E O1	15.48
939741	AE1-205 C O1	9.44
939742	AE1-205 E O1	13.03
939861	AE1-222 1	191.92
939871	AE1-222 2	37.43
940101	AE1-252 C O1	7.26
940102	AE1-252 E O1	4.84
951741	J474 C	1.23
951742	J474 E	6.63
952651	J756 C	1.67
952652	J756 E	9.05
954181	J884	6.11
AB2-013	AB2-013	11.51
CARR	CARR	0.16
CBM-S1	CBM-S1	2.68
CBM-S2	CBM-S2	0.28
CBM-W1	CBM-W1	3.41
CBM-W2	CBM-W2	44.28
CIN	CIN	2.13
CPL	CPL	0.02
DEARBORN	DEARBORN	0.86
G-007	G-007	0.45
IPL	IPL	0.97
LGEE	LGEE	0.09
MEC	MEC	12.36
O-066	O-066	1.51
RENSSELAER	RENSSELAER	0.13
Z1-043	Z1-043	11.82

Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
786761	925880	AC1-067 TAP	CE	270675	BURNHAM ;1R	CE	1	COMED_P7_345-L2001__B-S_+_345-L2003__R-S	tower	1768.0	99.8	100.22	DC	16.27

Bus #	Bus	MW Impact
274654	BRAIDWOOD;1U	19.31
274655	BRAIDWOOD;2U	18.58
274881	PLEAS RDG;2U	0.85
274887	PILOT HIL;1U	0.85
274888	PILOT HIL;1E	22.19
275149	KEMPTON ;1E	22.19
293061	N-015 E	7.44
294392	P-010 E	9.45
925881	AC1-067 O1	812.21
930501	AB1-091 O1	101.52
933411	AC2-154 C	3.01
933412	AC2-154 E	4.91
934721	AD1-100 C	12.9
934722	AD1-100 E	60.19
936371	AD2-047 C O1	2.69
936372	AD2-047 E O1	29.01
936461	AD2-060	3.17
936781	AD2-101 C	4.32
936782	AD2-101 E	20.24
937121	AD2-148 C O1	4.82
937122	AD2-148 E O1	22.54
937131	AD2-149 C O1	4.82
937132	AD2-149 E O1	22.54
937141	AD2-150 C O1	4.82
937142	AD2-150 E O1	22.54
937181	AD2-155 C O1	4.82
937182	AD2-155 E O1	22.54
937321	AD2-175 C	22.44
937322	AD2-175 E	14.96
939351	AE1-166 C O1	7.96
939352	AE1-166 E O1	7.34
939401	AE1-172 C O1	2.86
939402	AE1-172 E O1	13.41
BLUEG	BLUEG	1.25
CALDERWOOD	CALDERWOOD	0.04
CANNELTON	CANNELTON	0.03
CARR	CARR	0.15
CATAWBA	CATAWBA	0.07
CBM-S1	CBM-S1	0.08
CBM-W1	CBM-W1	1.21

Bus #	Bus	MW Impact
CBM-W2	CBM-W2	8.35
CHEOAH	CHEOAH	0.04
CHILHOWEE	CHILHOWEE	0.01
DEARBORN	DEARBORN	0.65
ELMERSMITH	ELMERSMITH	0.03
G-007	G-007	0.42
GIBSON	GIBSON	0.01
HAMLET	HAMLET	0.25
MEC	MEC	4.71
O-066	O-066	1.4
RENSSELAER	RENSSELAER	0.12
SANTEETLA	SANTEETLA	0.01
TRIMBLE	TRIMBLE	0.15
WEC	WEC	0.71

Index 4

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
468650	243918	05ELDERBRYSS	AEP	938670	AE1-089 TAP	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	117.38	118.05	DC	21.09

Bus #	Bus	MW Impact
247900	05FR-11G E	6.85
247901	05FR-12G E	6.74
247902	05FR-21G E	7.2
247903	05FR-22G E	6.89
247904	05FR-3G E	13.96
247905	05FR-4G E	10.5
247906	05MDL-1G E	15.63
247907	05MDL-2G E	7.75
247912	05MDL-3G E	8.11
247913	05MDL-4G E	7.83
247943	T-127 E	7.83
270859	PWR VTR EC;R	7.11
274722	S-055 E	6.55
274809	UNIV PK N;5U	0.8
274811	UNIV PK N;7U	0.8
274812	UNIV PK N;8U	0.8
274814	UNIV PK N;0U	0.8
274815	UNIV PK N;XU	0.8
274859	EASYR;U1 E	5.56
274860	EASYR;U2 E	5.56
274888	PILOT HIL;1E	10.32
274890	CAYUG;1U E	8.28
274891	CAYUG;2U E	8.28
275149	KEMPTON ;1E	10.32
290021	O50 E	11.46
290051	GSG-6; E	6.16
290108	LEEDK;1U E	14.23
293061	N-015 E	8.96
293644	O22 E1	5.93
293645	O22 E2	11.51
294392	P-010 E	11.37
294763	P-046 E	5.56
295109	WESTBROOK E	3.3
909145	X2-052	36.23
914641	Y2-103	26.18
915011	Y3-013 1	2.18
915021	Y3-013 2	2.18
915031	Y3-013 3	2.18
916221	Z1-073 E	3.18
916502	Z1-106 E1	0.73

Bus #	Bus	MW Impact
916504	Z1-106 E2	0.73
916512	Z1-107 E	1.5
916522	Z1-108 E	1.45
917711	Z2-114 C	0.06
917712	Z2-114 E	0.4
918052	AA1-018 E	9.8
920272	AA2-123 E	1.43
924471	AB2-096	24.87
925302	AB2-191 E	0.82
926311	AC1-109 1	1.1
926321	AC1-109 2	1.1
926331	AC1-110 1	1.1
926341	AC1-110 2	1.1
926351	AC1-111 1	0.44
926361	AC1-111 2	0.44
926371	AC1-111 3	0.44
926381	AC1-111 4	0.44
926391	AC1-111 5	0.44
926401	AC1-111 6	0.44
926431	AC1-114	1.4
926821	AC1-168 C O1	0.7
926822	AC1-168 E O1	4.71
927091	AC1-204 1	41.9
927101	AC1-204 2	41.91
927451	AC1-142A 1	2.42
927461	AC1-142A 2	2.42
927511	AC1-113 1	0.7
927521	AC1-113 2	0.7
927531	AC1-185 1	0.41
927541	AC1-185 2	0.41
927551	AC1-185 3	0.41
927561	AC1-185 4	0.41
927571	AC1-185 5	0.41
927581	AC1-185 6	0.41
927591	AC1-185 7	0.41
927601	AC1-185 8	0.41
930042	AB1-006 E	17.03
930391	AB1-080	2.15
930481	AB1-089	38.75
930501	AB1-091 O1	40.14
930741	AB1-122 1O1	41.99
930751	AB1-122 2O1	42.66
932601	AC2-080 C O1	3.72
932602	AC2-080 E O1	24.91
932881	AC2-115 1	1.4
932891	AC2-115 2	1.4
932921	AC2-116	0.49
932931	AC2-117	5.17
933341	AC2-147 C	0.52
933342	AC2-147 E	0.85
933411	AC2-154 C	1.4
933412	AC2-154 E	2.28

Bus #	Bus	MW Impact
933431	AC2-156 C O1	0.55
933432	AC2-156 E O1	0.9
933911	AD1-013 C	1.08
933912	AD1-013 E	1.73
933931	AD1-016 C	0.54
933932	AD1-016 E	0.89
934101	AD1-039 1	4.12
934111	AD1-039 2	4.18
934401	AD1-064 C O1	1.88
934402	AD1-064 E O1	8.8
934431	AD1-067 C	0.08
934432	AD1-067 E	0.33
934651	AD1-096 C	0.53
934652	AD1-096 E	0.86
934701	AD1-098 C O1	4.06
934702	AD1-098 E O1	2.96
934721	AD1-100 C	11.12
934722	AD1-100 E	51.9
934871	AD1-116 C	0.57
934872	AD1-116 E	0.93
934881	AD1-117 C	3.21
934882	AD1-117 E	2.14
934971	AD1-129 C	0.53
934972	AD1-129 E	0.35
935001	AD1-133 C O1	12.63
935002	AD1-133 E O1	8.42
935271	AD1-137 C	5.69
935272	AD1-137 E	38.05
936291	AD2-038 C O1	1.41
936292	AD2-038 E O1	9.44
936371	AD2-047 C O1	1.25
936372	AD2-047 E O1	13.49
936461	AD2-060	1.47
936511	AD2-066 C O1	4.99
936512	AD2-066 E O1	3.33
936781	AD2-101 C	2.48
936782	AD2-101 E	11.59
936791	AD2-102 C	7.12
936792	AD2-102 E	6.84
936961	AD2-130	0.32
936981	AD2-132 C	5.04
936982	AD2-132 E	23.6
937001	AD2-134 C	1.61
937002	AD2-134 E	6.66
937031	AD2-137 C O1	1.92
937032	AD2-137 E O1	9.0
937041	AD2-138 C	5.04
937042	AD2-138 E	23.6
937051	AD2-140 C O1	1.92
937052	AD2-140 E O1	8.99
937061	AD2-141 C O1	1.91
937062	AD2-141 E O1	9.0

Bus #	Bus	MW Impact
937071	AD2-142 C O1	3.84
937072	AD2-142 E O1	17.98
937121	AD2-148 C O1	1.93
937122	AD2-148 E O1	9.02
937131	AD2-149 C O1	1.93
937132	AD2-149 E O1	9.02
937141	AD2-150 C O1	1.93
937142	AD2-150 E O1	9.02
937181	AD2-155 C O1	1.93
937182	AD2-155 E O1	9.02
937311	AD2-172 C	1.46
937312	AD2-172 E	2.02
937321	AD2-175 C	8.98
937322	AD2-175 E	5.98
937331	AD2-176 C O1	4.29
937332	AD2-176 E O1	2.86
937401	AD2-194 1	4.51
937411	AD2-194 2	4.51
938012	AE1-002 E O1	3.86
938511	AE1-070 1	5.29
938521	AE1-070 2	4.84
938851	AE1-113 C O1	5.24
938852	AE1-113 E O1	16.46
938861	AE1-114 C O1	2.13
938862	AE1-114 E O1	8.16
939321	AE1-163 C O1	3.48
939322	AE1-163 E O1	21.35
939351	AE1-166 C O1	5.85
939352	AE1-166 E O1	5.4
939401	AE1-172 C O1	3.71
939402	AE1-172 E O1	17.38
939641	AE1-194 C	5.61
939642	AE1-194 E	37.52
939651	AE1-195 C	5.61
939652	AE1-195 E	37.52
939691	AE1-199	1.41
939701	AE1-201 C	1.17
939702	AE1-201 E	0.26
939732	AE1-204 E	0.17
939861	AE1-222 1	46.37
939871	AE1-222 2	47.11
939921	AE1-228 C O1	5.92
939922	AE1-228 E O1	3.95
939961	AE1-233 C O1	1.36
939962	AE1-233 E O1	5.62
940101	AE1-252 C O1	6.21
940102	AE1-252 E O1	4.14
AB2-013	AB2-013	10.01
AE1-033	AE1-033	10.77
CARR	CARR	0.59
CATAWBA	CATAWBA	0.05
CBM-S1	CBM-S1	4.6

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	19.73
CBM-W2	CBM-W2	68.15
CIN	CIN	7.05
DEARBORN	DEARBORN	1.82
G-007	G-007	1.64
HAMLET	HAMLET	0.34
IPL	IPL	3.28
LGEE	LGEE	0.73
MEC	MEC	25.32
O-066	O-066	5.54
RENSSELAER	RENSSELAER	0.47
WEC	WEC	4.7
Z1-043	Z1-043	17.65

Index 5

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
78547 1	25510 4	17GREEN_ACR E	NIPS	27077 1	GREENACR E; T	CE	1	AEP_P4_#2978_05DUMON T 765_B	breaker	1091. 0	103.28	103.93	DC	23.27

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	8.06
274722	S-055 E	7.52
274751	CRETE EC ;1U	1.93
274752	CRETE EC ;2U	1.93
274753	CRETE EC ;3U	1.93
274754	CRETE EC ;4U	1.93
274832	U4-027	7.11
274859	EASYR;U1 E	7.3
274860	EASYR;U2 E	7.3
274888	PILOT HIL;1E	12.4
274890	CAYUG;1U E	8.92
274891	CAYUG;2U E	8.92
275149	KEMPTON ;1E	12.4
290021	O50 E	12.98
290051	GSG-6; E	6.94
290108	LEEDK;1U E	16.14
293061	N-015 E	10.24
293516	O-009 E1	5.99
293517	O-009 E2	3.04
293518	O-009 E3	3.35
293644	O22 E1	7.24
293645	O22 E2	14.06
293715	O-029 E	6.47
293716	O-029 E	3.55
293717	O-029 E	3.26
294392	P-010 E	13.0
294763	P-046 E	6.23
295109	WESTBROOK E	3.72
295111	SUBLETTE E	1.72
910542	X3-005 E	0.52
914641	Y2-103	30.09
915011	Y3-013 1	2.51
915021	Y3-013 2	2.51
915031	Y3-013 3	2.51
916221	Z1-073 E	3.58
916502	Z1-106 E1	0.84
916504	Z1-106 E2	0.84
916512	Z1-107 E	1.71
916522	Z1-108 E	1.66
918052	AA1-018 E	10.62
919221	AA1-146	11.67

Bus #	Bus	MW Impact
919581	AA2-030	11.67
920272	AA2-123 E	1.63
924471	AB2-096	28.21
925161	AB2-173	2.08
925302	AB2-191 E	0.92
925881	AC1-067 O1	102.57
926311	AC1-109 1	1.27
926321	AC1-109 2	1.27
926331	AC1-110 1	1.27
926341	AC1-110 2	1.27
926351	AC1-111 1	0.51
926361	AC1-111 2	0.51
926371	AC1-111 3	0.51
926381	AC1-111 4	0.51
926391	AC1-111 5	0.51
926401	AC1-111 6	0.51
926431	AC1-114	1.58
926821	AC1-168 C O1	0.76
926822	AC1-168 E O1	5.08
927091	AC1-204 1	48.76
927101	AC1-204 2	48.73
927201	AC1-214 C O1	0.74
927202	AC1-214 E O1	2.34
927451	AC1-142A 1	2.83
927461	AC1-142A 2	2.83
927511	AC1-113 1	0.79
927521	AC1-113 2	0.79
927531	AC1-185 1	0.46
927541	AC1-185 2	0.46
927551	AC1-185 3	0.46
927561	AC1-185 4	0.46
927571	AC1-185 5	0.46
927581	AC1-185 6	0.46
927591	AC1-185 7	0.46
927601	AC1-185 8	0.46
930481	AB1-089	43.76
930501	AB1-091 O1	49.15
930741	AB1-122 1O1	47.58
930751	AB1-122 2O1	49.75
932881	AC2-115 1	1.58
932891	AC2-115 2	1.58
932921	AC2-116	0.55
933341	AC2-147 C	0.58
933342	AC2-147 E	0.94
933411	AC2-154 C	1.68
933412	AC2-154 E	2.75
933431	AC2-156 C O1	0.64
933432	AC2-156 E O1	1.04
933911	AD1-013 C	1.22
933912	AD1-013 E	1.95
933931	AD1-016 C	0.62
933932	AD1-016 E	1.01

Bus #	Bus	MW Impact
934101	AD1-039 1	4.66
934111	AD1-039 2	4.88
934401	AD1-064 C O1	2.13
934402	AD1-064 E O1	9.99
934431	AD1-067 C	0.09
934432	AD1-067 E	0.37
934651	AD1-096 C	0.59
934652	AD1-096 E	0.97
934701	AD1-098 C O1	4.57
934702	AD1-098 E O1	3.34
934721	AD1-100 C	12.94
934722	AD1-100 E	60.39
934871	AD1-116 C	0.62
934872	AD1-116 E	1.01
934881	AD1-117 C	3.57
934882	AD1-117 E	2.38
934971	AD1-129 C	0.6
934972	AD1-129 E	0.4
935001	AD1-133 C O1	13.73
935002	AD1-133 E O1	9.15
936291	AD2-038 C O1	1.54
936292	AD2-038 E O1	10.32
936371	AD2-047 C O1	1.51
936372	AD2-047 E O1	16.21
936461	AD2-060	1.77
936511	AD2-066 C O1	5.56
936512	AD2-066 E O1	3.71
936781	AD2-101 C	3.17
936782	AD2-101 E	14.84
936791	AD2-102 C	8.0
936792	AD2-102 E	7.69
936961	AD2-130	0.38
937001	AD2-134 C	1.82
937002	AD2-134 E	7.5
937031	AD2-137 C O1	2.31
937032	AD2-137 E O1	10.8
937051	AD2-140 C O1	2.32
937052	AD2-140 E O1	10.87
937061	AD2-141 C O1	2.31
937062	AD2-141 E O1	10.88
937071	AD2-142 C O1	4.64
937072	AD2-142 E O1	21.73
937121	AD2-148 C O1	2.36
937122	AD2-148 E O1	11.04
937131	AD2-149 C O1	2.36
937132	AD2-149 E O1	11.04
937141	AD2-150 C O1	2.36
937142	AD2-150 E O1	11.04
937181	AD2-155 C O1	2.36
937182	AD2-155 E O1	11.04
937311	AD2-172 C	1.64
937312	AD2-172 E	2.26

Bus #	Bus	MW Impact
937321	AD2-175 C	10.99
937322	AD2-175 E	7.33
937331	AD2-176 C O1	4.89
937332	AD2-176 E O1	3.26
937401	AD2-194 1	5.24
937411	AD2-194 2	5.24
937531	AD2-214 C	2.92
937532	AD2-214 E	1.37
938012	AE1-002 E O1	4.63
938511	AE1-070 1	6.16
938521	AE1-070 2	5.63
938851	AE1-113 C O1	5.72
938852	AE1-113 E O1	17.99
938861	AE1-114 C O1	2.37
938862	AE1-114 E O1	9.06
939051	AE1-134 1	0.91
939061	AE1-134 2	0.91
939321	AE1-163 C O1	4.03
939322	AE1-163 E O1	24.74
939351	AE1-166 C O1	6.84
939352	AE1-166 E O1	6.31
939401	AE1-172 C O1	4.1
939402	AE1-172 E O1	19.18
939641	AE1-194 C	10.88
939642	AE1-194 E	72.84
939651	AE1-195 C	10.88
939652	AE1-195 E	72.84
939691	AE1-199	1.59
939701	AE1-201 C	1.34
939702	AE1-201 E	0.29
939732	AE1-204 E	0.2
939861	AE1-222 1	52.55
939871	AE1-222 2	54.95
939921	AE1-228 C O1	6.68
939922	AE1-228 E O1	4.45
939961	AE1-233 C O1	1.55
939962	AE1-233 E O1	6.39
940101	AE1-252 C O1	6.69
940102	AE1-252 E O1	4.46
951721	J643	15.51
952581	J740 C	3.4
952582	J740 E	18.42
953871	J847	8.38
AB2-013	AB2-013	10.64
AE1-033	AE1-033	12.03
BLUEG	BLUEG	2.86
CANNELTON	CANNELTON	0.0
CARR	CARR	0.5
CATAWBA	CATAWBA	0.16
CBM-S1	CBM-S1	1.36
CBM-W1	CBM-W1	19.98
CBM-W2	CBM-W2	38.44

Bus #	Bus	MW Impact
CIN	CIN	0.12
DEARBORN	DEARBORN	2.29
G-007	G-007	1.38
HAMLET	HAMLET	0.65
MEC	MEC	25.05
O-066	O-066	4.65
RENSSELAER	RENSSELAER	0.39
SANTEETLA	SANTEETLA	0.0
TRIMBLE	TRIMBLE	0.34
WEC	WEC	5.32
Z1-043	Z1-043	18.82

Index 6

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785306	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_023-65-BT2-3__	breaker	1091.0	111.35	112.16	DC	25.42

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	9.04
274654	BRAIDWOOD;1U	19.05
274655	BRAIDWOOD;2U	18.24
274661	LASCO STA;2U	17.6
274687	WILL CNTY;4U	8.03
274704	KENDALL ;1C	2.81
274705	KENDALL ;1S	1.88
274706	KENDALL ;2C	2.81
274707	KENDALL ;2S	1.88
274722	S-055 E	8.45
274751	CRETE EC ;1U	3.36
274752	CRETE EC ;2U	3.36
274753	CRETE EC ;3U	3.36
274754	CRETE EC ;4U	3.36
274859	EASYR;U1 E	8.17
274860	EASYR;U2 E	8.17
274861	TOP CROP ;1U	0.33
274862	TOP CROP ;2U	0.63
274888	PILOT HIL;1E	12.81
274890	CAYUG;1U E	9.74
274891	CAYUG;2U E	9.74
275149	KEMPTON ;1E	12.81
290021	O50 E	14.65
290051	GSG-6; E	7.78
290108	LEEDK;1U E	18.09
293061	N-015 E	11.61
293516	O-009 E1	6.69
293517	O-009 E2	3.4
293518	O-009 E3	3.74
293644	O22 E1	8.5
293645	O22 E2	16.51
293715	O-029 E	7.24
293716	O-029 E	3.97
293717	O-029 E	3.65
294392	P-010 E	14.75
294763	P-046 E	6.98
295109	WESTBROOK E	4.16
295111	SUBLETTE E	1.92
914641	Y2-103	33.8
915011	Y3-013 1	2.82

Bus #	Bus	MW Impact
915021	Y3-013 2	2.82
915031	Y3-013 3	2.82
916221	Z1-073 E	4.01
916502	Z1-106 E1	0.94
916504	Z1-106 E2	0.94
916512	Z1-107 E	1.85
916522	Z1-108 E	1.86
918052	AA1-018 E	11.64
919221	AA1-146	13.04
919581	AA2-030	13.04
920272	AA2-123 E	1.83
924471	AB2-096	31.63
925161	AB2-173	2.33
925302	AB2-191 E	1.03
926311	AC1-109 1	1.42
926321	AC1-109 2	1.42
926331	AC1-110 1	1.42
926341	AC1-110 2	1.42
926351	AC1-111 1	0.57
926361	AC1-111 2	0.57
926371	AC1-111 3	0.57
926381	AC1-111 4	0.57
926391	AC1-111 5	0.57
926401	AC1-111 6	0.57
926431	AC1-114	1.77
926821	AC1-168 C O1	0.85
926822	AC1-168 E O1	5.68
927091	AC1-204 1	55.19
927101	AC1-204 2	55.12
927451	AC1-142A 1	3.2
927461	AC1-142A 2	3.2
927511	AC1-113 1	0.89
927521	AC1-113 2	0.89
927531	AC1-185 1	0.51
927541	AC1-185 2	0.51
927551	AC1-185 3	0.51
927561	AC1-185 4	0.51
927571	AC1-185 5	0.51
927581	AC1-185 6	0.51
927591	AC1-185 7	0.51
927601	AC1-185 8	0.51
930481	AB1-089	49.05
930501	AB1-091 O1	50.61
930741	AB1-122 1O1	52.99
930751	AB1-122 2O1	56.33
932881	AC2-115 1	1.77
932891	AC2-115 2	1.77
932921	AC2-116	0.62
933341	AC2-147 C	0.65
933342	AC2-147 E	1.06
933411	AC2-154 C	1.74
933412	AC2-154 E	2.84

Bus #	Bus	MW Impact
933431	AC2-156 C O1	0.71
933432	AC2-156 E O1	1.16
933911	AD1-013 C	1.37
933912	AD1-013 E	2.19
933931	AD1-016 C	0.69
933932	AD1-016 E	1.13
934101	AD1-039 1	5.19
934111	AD1-039 2	5.52
934401	AD1-064 C O1	2.39
934402	AD1-064 E O1	11.2
934431	AD1-067 C	0.1
934432	AD1-067 E	0.41
934651	AD1-096 C	0.66
934652	AD1-096 E	1.08
934701	AD1-098 C O1	5.12
934702	AD1-098 E O1	3.74
934721	AD1-100 C	14.27
934722	AD1-100 E	66.6
934871	AD1-116 C	0.68
934872	AD1-116 E	1.11
934881	AD1-117 C	3.99
934882	AD1-117 E	2.66
934971	AD1-129 C	0.67
934972	AD1-129 E	0.45
935001	AD1-133 C O1	15.16
935002	AD1-133 E O1	10.11
936291	AD2-038 C O1	1.71
936292	AD2-038 E O1	11.45
936371	AD2-047 C O1	1.56
936372	AD2-047 E O1	16.75
936461	AD2-060	1.83
936511	AD2-066 C O1	6.19
936512	AD2-066 E O1	4.13
936781	AD2-101 C	3.09
936782	AD2-101 E	14.46
936791	AD2-102 C	8.96
936792	AD2-102 E	8.61
936961	AD2-130	0.42
937001	AD2-134 C	2.03
937002	AD2-134 E	8.4
937031	AD2-137 C O1	2.44
937032	AD2-137 E O1	11.43
937051	AD2-140 C O1	2.44
937052	AD2-140 E O1	11.42
937061	AD2-141 C O1	2.43
937062	AD2-141 E O1	11.44
937071	AD2-142 C O1	4.88
937072	AD2-142 E O1	22.85
937121	AD2-148 C O1	2.43
937122	AD2-148 E O1	11.37
937131	AD2-149 C O1	2.43
937132	AD2-149 E O1	11.37

Bus #	Bus	MW Impact
937141	AD2-150 C O1	2.43
937142	AD2-150 E O1	11.37
937181	AD2-155 C O1	2.43
937182	AD2-155 E O1	11.37
937311	AD2-172 C	1.83
937312	AD2-172 E	2.53
937321	AD2-175 C	11.32
937322	AD2-175 E	7.55
937331	AD2-176 C O1	5.48
937332	AD2-176 E O1	3.65
937401	AD2-194 1	5.94
937411	AD2-194 2	5.93
937531	AD2-214 C	0.8
937532	AD2-214 E	0.38
938012	AE1-002 E O1	4.9
938511	AE1-070 1	6.97
938521	AE1-070 2	6.37
938851	AE1-113 C O1	6.35
938852	AE1-113 E O1	19.97
938861	AE1-114 C O1	2.65
938862	AE1-114 E O1	10.14
939051	AE1-134 1	1.01
939061	AE1-134 2	1.01
939321	AE1-163 C O1	4.63
939322	AE1-163 E O1	28.43
939351	AE1-166 C O1	7.6
939352	AE1-166 E O1	7.02
939401	AE1-172 C O1	4.47
939402	AE1-172 E O1	20.95
939641	AE1-194 C	18.96
939642	AE1-194 E	126.86
939651	AE1-195 C	18.96
939652	AE1-195 E	126.86
939691	AE1-199	1.78
939701	AE1-201 C	1.5
939702	AE1-201 E	0.33
939732	AE1-204 E	0.22
939861	AE1-222 1	58.52
939871	AE1-222 2	62.2
939921	AE1-228 C O1	7.48
939922	AE1-228 E O1	4.99
939961	AE1-233 C O1	1.73
939962	AE1-233 E O1	7.16
940101	AE1-252 C O1	7.31
940102	AE1-252 E O1	4.87
AB2-013	AB2-013	11.87
AE1-033	AE1-033	13.47
BLUEG	BLUEG	5.05
CALDERWOOD	CALDERWOOD	0.09
CANNELTON	CANNELTON	0.11
CARR	CARR	0.56
CATAWBA	CATAWBA	0.23

Bus #	Bus	MW Impact
CBM-S1	CBM-S1	0.77
CBM-W1	CBM-W1	20.04
CBM-W2	CBM-W2	37.14
CHEOAH	CHEOAH	0.09
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.24
ELMERSMITH	ELMERSMITH	0.14
G-007	G-007	1.57
GIBSON	GIBSON	0.06
HAMLET	HAMLET	0.87
MEC	MEC	27.58
O-066	O-066	5.3
RENSSELAER	RENSSELAER	0.45
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.59
WEC	WEC	5.97
Z1-043	Z1-043	20.98

Index 7

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
468325	255113	17STILLWEL	NIPS	243219	05DUMONT	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	173.75	174.48	DC	40.94

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	13.92
274722	S-055 E	12.95
274724	RIVER EC ;11	4.75
274788	SE CHICAG;5U	1.14
274789	SE CHICAG;6U	1.14
274790	SE CHICAG;7U	1.14
274791	SE CHICAG;8U	1.14
274795	SE CHICAG;2U	1.12
274832	U4-027	12.45
274859	EASYR;U1 E	12.67
274860	EASYR;U2 E	12.67
274888	PILOT HIL;1E	22.3
274890	CAYUG;1U E	15.76
274891	CAYUG;2U E	15.76
275149	KEMPTON ;1E	22.3
290021	O50 E	22.31
290051	GSG-6; E	12.02
290108	LEEDK;1U E	27.92
293061	N-015 E	17.54
293516	O-009 E1	10.45
293517	O-009 E2	5.31
293518	O-009 E3	5.85
293644	O22 E1	11.95
293645	O22 E2	23.2
293715	O-029 E	11.27
293716	O-029 E	6.18
293717	O-029 E	5.68
293771	O-035 E	7.36
294392	P-010 E	22.27
294763	P-046 E	10.8
295109	WESTBROOK E	6.44
295111	SUBLETTE E	2.99
910542	X3-005 E	1.0
914641	Y2-103	51.8
915011	Y3-013 1	4.32
915021	Y3-013 2	4.32
915031	Y3-013 3	4.32
916211	Z1-072 E	5.57
916221	Z1-073 E	6.2
916502	Z1-106 E1	1.45
916504	Z1-106 E2	1.45

Bus #	Bus	MW Impact
916512	Z1-107 E	3.03
916522	Z1-108 E	2.86
918052	AA1-018 E	18.74
919221	AA1-146	20.28
919581	AA2-030	20.28
920272	AA2-123 E	2.81
924471	AB2-096	48.73
925161	AB2-173	3.62
925302	AB2-191 E	1.59
925581	AC1-033 C	1.61
925582	AC1-033 E	10.81
925881	AC1-067 O1	198.49
926311	AC1-109 1	2.19
926321	AC1-109 2	2.19
926331	AC1-110 1	2.18
926341	AC1-110 2	2.18
926351	AC1-111 1	0.88
926361	AC1-111 2	0.88
926371	AC1-111 3	0.88
926381	AC1-111 4	0.88
926391	AC1-111 5	0.88
926401	AC1-111 6	0.88
926431	AC1-114	2.74
926821	AC1-168 C O1	1.32
926822	AC1-168 E O1	8.85
927091	AC1-204 1	83.26
927101	AC1-204 2	83.23
927201	AC1-214 C O1	2.36
927202	AC1-214 E O1	7.51
927451	AC1-142A 1	4.83
927461	AC1-142A 2	4.84
927511	AC1-113 1	1.37
927521	AC1-113 2	1.37
927531	AC1-185 1	0.79
927541	AC1-185 2	0.79
927551	AC1-185 3	0.79
927561	AC1-185 4	0.79
927571	AC1-185 5	0.79
927581	AC1-185 6	0.79
927591	AC1-185 7	0.79
927601	AC1-185 8	0.79
930481	AB1-089	75.67
930501	AB1-091 O1	88.22
930741	AB1-122 1O1	82.42
930751	AB1-122 2O1	84.95
932881	AC2-115 1	2.74
932891	AC2-115 2	2.74
932921	AC2-116	0.96
932931	AC2-117	5.81
933341	AC2-147 C	1.0
933342	AC2-147 E	1.64
933411	AC2-154 C	3.03

Bus #	Bus	MW Impact
933412	AC2-154 E	4.94
933431	AC2-156 C O1	1.1
933432	AC2-156 E O1	1.79
933911	AD1-013 C	2.12
933912	AD1-013 E	3.38
933931	AD1-016 C	1.07
933932	AD1-016 E	1.74
934101	AD1-039 1	8.08
934111	AD1-039 2	8.33
934401	AD1-064 C O1	3.69
934402	AD1-064 E O1	17.25
934431	AD1-067 C	0.15
934432	AD1-067 E	0.63
934651	AD1-096 C	1.03
934652	AD1-096 E	1.67
934701	AD1-098 C O1	7.91
934702	AD1-098 E O1	5.78
934721	AD1-100 C	22.45
934722	AD1-100 E	104.76
934871	AD1-116 C	1.09
934872	AD1-116 E	1.78
934881	AD1-117 C	6.19
934882	AD1-117 E	4.13
934971	AD1-129 C	1.04
934972	AD1-129 E	0.69
935001	AD1-133 C O1	24.06
935002	AD1-133 E O1	16.04
936291	AD2-038 C O1	2.69
936292	AD2-038 E O1	18.02
936371	AD2-047 C O1	2.71
936372	AD2-047 E O1	29.15
936461	AD2-060	3.19
936511	AD2-066 C O1	9.67
936512	AD2-066 E O1	6.45
936781	AD2-101 C	5.9
936782	AD2-101 E	27.62
936791	AD2-102 C	13.85
936792	AD2-102 E	13.3
936961	AD2-130	0.66
937001	AD2-134 C	3.14
937002	AD2-134 E	12.98
937031	AD2-137 C O1	4.08
937032	AD2-137 E O1	19.09
937051	AD2-140 C O1	4.11
937052	AD2-140 E O1	19.25
937061	AD2-141 C O1	4.09
937062	AD2-141 E O1	19.27
937071	AD2-142 C O1	8.22
937072	AD2-142 E O1	38.5
937121	AD2-148 C O1	4.23
937122	AD2-148 E O1	19.82
937131	AD2-149 C O1	4.23

Bus #	Bus	MW Impact
937132	AD2-149 E O1	19.82
937141	AD2-150 C O1	4.23
937142	AD2-150 E O1	19.82
937181	AD2-155 C O1	4.23
937182	AD2-155 E O1	19.82
937311	AD2-172 C	2.83
937312	AD2-172 E	3.91
937321	AD2-175 C	19.73
937322	AD2-175 E	13.15
937331	AD2-176 C O1	8.43
937332	AD2-176 E O1	5.62
937401	AD2-194 1	8.95
937411	AD2-194 2	8.95
937531	AD2-214 C	5.1
937532	AD2-214 E	2.4
938012	AE1-002 E O1	8.18
938511	AE1-070 1	10.52
938521	AE1-070 2	9.62
938851	AE1-113 C O1	10.0
938852	AE1-113 E O1	31.44
938861	AE1-114 C O1	4.11
938862	AE1-114 E O1	15.72
939051	AE1-134 1	1.58
939061	AE1-134 2	1.58
939321	AE1-163 C O1	6.81
939322	AE1-163 E O1	41.82
939351	AE1-166 C O1	11.8
939352	AE1-166 E O1	10.89
939401	AE1-172 C O1	7.21
939402	AE1-172 E O1	33.74
939631	AE1-193 C O1	4.73
939632	AE1-193 E O1	31.63
939641	AE1-194 C	10.24
939642	AE1-194 E	68.55
939651	AE1-195 C	10.24
939652	AE1-195 E	68.55
939681	AE1-198 C O1	23.78
939682	AE1-198 E O1	20.2
939691	AE1-199	2.75
939701	AE1-201 C	2.31
939702	AE1-201 E	0.51
939732	AE1-204 E	0.34
939861	AE1-222 1	91.02
939871	AE1-222 2	93.81
939921	AE1-228 C O1	11.56
939922	AE1-228 E O1	7.71
939961	AE1-233 C O1	2.67
939962	AE1-233 E O1	11.05
940101	AE1-252 C O1	11.82
940102	AE1-252 E O1	7.88
951721	J643	25.73
952581	J740 C	4.3

Bus #	Bus	MW Impact
952582	J740 E	23.28
953871	J847	13.1
954751	J351	434.54
AB2-013	AB2-013	18.6
AE1-033	AE1-033	20.85
BLUEG	BLUEG	1.07
CARR	CARR	0.9
CATAWBA	CATAWBA	0.22
CBM-S1	CBM-S1	3.95
CBM-W1	CBM-W1	35.83
CBM-W2	CBM-W2	81.92
CIN	CIN	3.3
DEARBORN	DEARBORN	4.0
G-007	G-007	2.51
HAMLET	HAMLET	0.96
IPL	IPL	1.12
MEC	MEC	44.69
O-066	O-066	8.44
RENSSELAER	RENSSELAER	0.71
TRIMBLE	TRIMBLE	0.16
WEC	WEC	9.2
Z1-043	Z1-043	32.93

Index 8

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPAC T
785476	270677	BURNHAM ;OR	CE	255109	17MUNSTER	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1441.0	113.0	113.66	DC	35.12

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	11.75
274722	S-055 E	10.96
274723	RIVER EC ;12	4.32
274792	SE CHICAG;9U	0.96
274793	SE CHICAG;0U	0.96
274794	SE CHICAG;1U	0.96
274795	SE CHICAG;2U	0.96
274832	U4-027	10.31
274859	EASYR;U1 E	10.61
274860	EASYR;U2 E	10.61
274888	PILOT HIL;1E	20.48
274890	CAYUG;1U E	13.4
274891	CAYUG;2U E	13.4
275149	KEMPTON ;1E	20.48
290021	O50 E	18.57
290051	GSG-6; E	10.13
290108	LEEDK;1U E	23.57
293061	N-015 E	14.82
293516	O-009 E1	8.7
293517	O-009 E2	4.42
293518	O-009 E3	4.87
293644	O22 E1	9.26
293645	O22 E2	17.98
293715	O-029 E	9.4
293716	O-029 E	5.15
293717	O-029 E	4.74
293771	O-035 E	6.09
294392	P-010 E	18.82
294763	P-046 E	9.07
295109	WESTBROOK E	5.42
295111	SUBLETTE E	2.5
296125	R-030 C3	3.43
296128	R-030 E3	13.71
296271	R-030 C2	3.39
296272	R-030 E2	13.54
296308	R-030 C1	3.39
296309	R-030 E1	13.54
910541	X3-005 C	0.08
910542	X3-005 E	0.91
914641	Y2-103	43.82
915011	Y3-013 1	3.65

Bus #	Bus	MW Impact
915021	Y3-013 2	3.65
915031	Y3-013 3	3.65
916211	Z1-072 E	4.61
916221	Z1-073 E	5.23
916502	Z1-106 E1	1.23
916504	Z1-106 E2	1.23
916512	Z1-107 E	2.58
916522	Z1-108 E	2.42
917502	Z2-087 E	8.96
918052	AA1-018 E	16.81
919221	AA1-146	16.93
919581	AA2-030	16.93
920272	AA2-123 E	2.37
924471	AB2-096	41.11
925161	AB2-173	3.02
925302	AB2-191 E	1.34
925881	AC1-067 O1	301.08
926311	AC1-109 1	1.86
926321	AC1-109 2	1.86
926331	AC1-110 1	1.85
926341	AC1-110 2	1.85
926351	AC1-111 1	0.75
926361	AC1-111 2	0.75
926371	AC1-111 3	0.75
926381	AC1-111 4	0.75
926391	AC1-111 5	0.75
926401	AC1-111 6	0.75
926431	AC1-114	2.31
926821	AC1-168 C O1	1.1
926822	AC1-168 E O1	7.36
927091	AC1-204 1	70.09
927101	AC1-204 2	70.14
927201	AC1-214 C O1	1.95
927202	AC1-214 E O1	6.21
927451	AC1-142A 1	4.09
927461	AC1-142A 2	4.09
927511	AC1-113 1	1.15
927521	AC1-113 2	1.15
927531	AC1-185 1	0.66
927541	AC1-185 2	0.66
927551	AC1-185 3	0.66
927561	AC1-185 4	0.66
927571	AC1-185 5	0.66
927581	AC1-185 6	0.66
927591	AC1-185 7	0.66
927601	AC1-185 8	0.66
930481	AB1-089	63.73
930501	AB1-091 O1	82.27
930741	AB1-122 1O1	70.02
930751	AB1-122 2O1	70.99
932881	AC2-115 1	2.31
932891	AC2-115 2	2.31

Bus #	Bus	MW Impact
932921	AC2-116	0.81
932931	AC2-117	5.3
933341	AC2-147 C	0.84
933342	AC2-147 E	1.37
933411	AC2-154 C	2.78
933412	AC2-154 E	4.53
933431	AC2-156 C O1	0.93
933432	AC2-156 E O1	1.52
933911	AD1-013 C	1.78
933912	AD1-013 E	2.85
933931	AD1-016 C	0.9
933932	AD1-016 E	1.47
934101	AD1-039 1	6.86
934111	AD1-039 2	6.96
934401	AD1-064 C O1	3.11
934402	AD1-064 E O1	14.56
934431	AD1-067 C	0.13
934432	AD1-067 E	0.53
934651	AD1-096 C	0.86
934652	AD1-096 E	1.41
934701	AD1-098 C O1	6.66
934702	AD1-098 E O1	4.86
934721	AD1-100 C	19.54
934722	AD1-100 E	91.19
934871	AD1-116 C	0.98
934872	AD1-116 E	1.6
934881	AD1-117 C	5.18
934882	AD1-117 E	3.46
934971	AD1-129 C	0.88
934972	AD1-129 E	0.58
935001	AD1-133 C O1	20.3
935002	AD1-133 E O1	13.53
936291	AD2-038 C O1	2.33
936292	AD2-038 E O1	15.58
936371	AD2-047 C O1	2.49
936372	AD2-047 E O1	26.77
936461	AD2-060	2.93
936511	AD2-066 C O1	8.14
936512	AD2-066 E O1	5.43
936781	AD2-101 C	4.75
936782	AD2-101 E	22.22
936791	AD2-102 C	11.64
936792	AD2-102 E	11.19
936961	AD2-130	0.56
937001	AD2-134 C	2.65
937002	AD2-134 E	10.94
937031	AD2-137 C O1	3.67
937032	AD2-137 E O1	17.17
937051	AD2-140 C O1	3.72
937052	AD2-140 E O1	17.42
937061	AD2-141 C O1	3.7
937062	AD2-141 E O1	17.44

Bus #	Bus	MW Impact
937071	AD2-142 C O1	7.44
937072	AD2-142 E O1	34.83
937121	AD2-148 C O1	3.94
937122	AD2-148 E O1	18.43
937131	AD2-149 C O1	3.94
937132	AD2-149 E O1	18.43
937141	AD2-150 C O1	3.94
937142	AD2-150 E O1	18.43
937181	AD2-155 C O1	3.94
937182	AD2-155 E O1	18.43
937311	AD2-172 C	2.38
937312	AD2-172 E	3.29
937321	AD2-175 C	18.34
937322	AD2-175 E	12.23
937331	AD2-176 C O1	7.12
937332	AD2-176 E O1	4.75
937401	AD2-194 1	7.54
937411	AD2-194 2	7.54
937531	AD2-214 C	4.24
937532	AD2-214 E	1.99
938012	AE1-002 E O1	7.36
938511	AE1-070 1	8.86
938521	AE1-070 2	8.11
938851	AE1-113 C O1	8.65
938852	AE1-113 E O1	27.18
938861	AE1-114 C O1	3.45
938862	AE1-114 E O1	13.17
939051	AE1-134 1	1.32
939061	AE1-134 2	1.32
939321	AE1-163 C O1	5.47
939322	AE1-163 E O1	33.6
939351	AE1-166 C O1	10.23
939352	AE1-166 E O1	9.45
939401	AE1-172 C O1	6.18
939402	AE1-172 E O1	28.94
939691	AE1-199	2.32
939701	AE1-201 C	1.95
939702	AE1-201 E	0.43
939732	AE1-204 E	0.28
939741	AE1-205 C O1	8.57
939742	AE1-205 E O1	11.84
939861	AE1-222 1	77.33
939871	AE1-222 2	78.4
939921	AE1-228 C O1	9.74
939922	AE1-228 E O1	6.49
939961	AE1-233 C O1	2.26
939962	AE1-233 E O1	9.34
940101	AE1-252 C O1	10.05
940102	AE1-252 E O1	6.7
AB2-013	AB2-013	15.32
AE1-033	AE1-033	17.49
BLUEG	BLUEG	5.47

Bus #	Bus	MW Impact
CALDERWOOD	CALDERWOOD	0.06
CANNELTON	CANNELTON	0.08
CARR	CARR	0.73
CATAWBA	CATAWBA	0.27
CBM-S1	CBM-S1	1.44
CBM-W1	CBM-W1	23.88
CBM-W2	CBM-W2	51.81
CHEOAH	CHEOAH	0.06
CHILHOWEE	CHILHOWEE	0.02
DEARBORN	DEARBORN	2.93
ELMERSMITH	ELMERSMITH	0.08
G-007	G-007	2.03
GIBSON	GIBSON	0.04
HAMLET	HAMLET	1.05
MEC	MEC	36.09
O-066	O-066	6.84
RENSSELAER	RENSSELAER	0.58
SANTEETLA	SANTEETLA	0.02
TRIMBLE	TRIMBLE	0.65
WEC	WEC	7.74
Z1-043	Z1-043	27.27

Index 9

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785455	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	111.21	112.16	DC	35.54

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	12.73
274654	BRAIDWOOD;1U	27.26
274655	BRAIDWOOD;2U	26.09
274660	LASCO STA;1U	24.9
274661	LASCO STA;2U	24.94
274675	JOLIET 29;7U	11.25
274676	JOLIET 29;8U	11.26
274687	WILL CNTY;4U	11.37
274704	KENDALL ;1C	4.0
274705	KENDALL ;1S	2.67
274706	KENDALL ;2C	4.0
274707	KENDALL ;2S	2.67
274722	S-055 E	11.91
274736	ELWOOD EC;9P	3.23
274832	U4-027	11.21
274859	EASYR;U1 E	11.52
274860	EASYR;U2 E	11.52
274861	TOP CROP ;1U	0.47
274862	TOP CROP ;2U	0.92
274888	PILOT HIL;1E	17.1
274890	CAYUG;1U E	13.64
274891	CAYUG;2U E	13.64
275149	KEMPTON ;1E	17.1
290021	O50 E	20.79
290051	GSG-6; E	10.94
290108	LEEDK;1U E	25.43
293061	N-015 E	16.43
293516	O-009 E1	9.45
293517	O-009 E2	4.8
293518	O-009 E3	5.29
293644	O22 E1	12.34
293645	O22 E2	23.96
293715	O-029 E	10.21
293716	O-029 E	5.6
293717	O-029 E	5.15
293771	O-035 E	6.61
294392	P-010 E	20.87
294763	P-046 E	9.84
295109	WESTBROOK E	5.86
295111	SUBLETTE E	2.71

Bus #	Bus	MW Impact
914641	Y2-103	47.64
915011	Y3-013 1	3.97
915021	Y3-013 2	3.97
915031	Y3-013 3	3.97
916211	Z1-072 E	5.0
916221	Z1-073 E	5.65
916502	Z1-106 E1	1.33
916504	Z1-106 E2	1.33
916512	Z1-107 E	2.55
916522	Z1-108 E	2.62
918052	AA1-018 E	16.2
919221	AA1-146	18.41
919581	AA2-030	18.41
920272	AA2-123 E	2.57
924471	AB2-096	44.55
925161	AB2-173	3.28
925302	AB2-191 E	1.45
925581	AC1-033 C	1.45
925582	AC1-033 E	9.71
926311	AC1-109 1	2.0
926321	AC1-109 2	2.0
926331	AC1-110 1	2.0
926341	AC1-110 2	2.0
926351	AC1-111 1	0.8
926361	AC1-111 2	0.8
926371	AC1-111 3	0.8
926381	AC1-111 4	0.8
926391	AC1-111 5	0.8
926401	AC1-111 6	0.8
926431	AC1-114	2.5
926821	AC1-168 C O1	1.2
926822	AC1-168 E O1	8.03
927091	AC1-204 1	78.31
927101	AC1-204 2	78.18
927201	AC1-214 C O1	2.12
927202	AC1-214 E O1	6.75
927451	AC1-142A 1	4.53
927461	AC1-142A 2	4.53
927511	AC1-113 1	1.25
927521	AC1-113 2	1.25
927531	AC1-185 1	0.72
927541	AC1-185 2	0.72
927551	AC1-185 3	0.72
927561	AC1-185 4	0.72
927571	AC1-185 5	0.72
927581	AC1-185 6	0.72
927591	AC1-185 7	0.72
927601	AC1-185 8	0.72
930481	AB1-089	69.1
930501	AB1-091 O1	67.39
930741	AB1-122 1O1	74.68
930751	AB1-122 2O1	79.86

Bus #	Bus	MW Impact
932881	AC2-115 1	2.5
932891	AC2-115 2	2.5
932921	AC2-116	0.88
933341	AC2-147 C	0.91
933342	AC2-147 E	1.49
933411	AC2-154 C	2.32
933412	AC2-154 E	3.79
933431	AC2-156 C O1	1.0
933432	AC2-156 E O1	1.63
933911	AD1-013 C	1.93
933912	AD1-013 E	3.08
933931	AD1-016 C	0.98
933932	AD1-016 E	1.6
934101	AD1-039 1	7.32
934111	AD1-039 2	7.83
934401	AD1-064 C O1	3.37
934402	AD1-064 E O1	15.78
934431	AD1-067 C	0.14
934432	AD1-067 E	0.58
934651	AD1-096 C	0.94
934652	AD1-096 E	1.53
934701	AD1-098 C O1	7.2
934702	AD1-098 E O1	5.26
934721	AD1-100 C	19.95
934722	AD1-100 E	93.11
934871	AD1-116 C	0.94
934872	AD1-116 E	1.54
934881	AD1-117 C	5.63
934882	AD1-117 E	3.75
934971	AD1-129 C	0.95
934972	AD1-129 E	0.63
935001	AD1-133 C O1	21.34
935002	AD1-133 E O1	14.23
936291	AD2-038 C O1	2.41
936292	AD2-038 E O1	16.1
936371	AD2-047 C O1	2.08
936372	AD2-047 E O1	22.36
936461	AD2-060	2.44
936511	AD2-066 C O1	8.72
936512	AD2-066 E O1	5.81
936781	AD2-101 C	3.97
936782	AD2-101 E	18.57
936791	AD2-102 C	12.63
936792	AD2-102 E	12.14
936961	AD2-130	0.59
937001	AD2-134 C	2.86
937002	AD2-134 E	11.82
937031	AD2-137 C O1	3.34
937032	AD2-137 E O1	15.64
937051	AD2-140 C O1	3.33
937052	AD2-140 E O1	15.57
937061	AD2-141 C O1	3.31

Bus #	Bus	MW Impact
937062	AD2-141 E O1	15.59
937071	AD2-142 C O1	6.65
937072	AD2-142 E O1	31.14
937121	AD2-148 C O1	3.24
937122	AD2-148 E O1	15.15
937131	AD2-149 C O1	3.24
937132	AD2-149 E O1	15.15
937141	AD2-150 C O1	3.24
937142	AD2-150 E O1	15.15
937181	AD2-155 C O1	3.24
937182	AD2-155 E O1	15.15
937311	AD2-172 C	2.58
937312	AD2-172 E	3.57
937321	AD2-175 C	15.07
937322	AD2-175 E	10.05
937331	AD2-176 C O1	7.72
937332	AD2-176 E O1	5.15
937401	AD2-194 1	8.42
937411	AD2-194 2	8.41
937531	AD2-214 C	4.61
937532	AD2-214 E	2.17
938012	AE1-002 E O1	6.71
938511	AE1-070 1	9.9
938521	AE1-070 2	9.04
938851	AE1-113 C O1	8.93
938852	AE1-113 E O1	28.07
938861	AE1-114 C O1	3.74
938862	AE1-114 E O1	14.3
939051	AE1-134 1	1.43
939061	AE1-134 2	1.43
939321	AE1-163 C O1	6.65
939322	AE1-163 E O1	40.82
939351	AE1-166 C O1	10.67
939352	AE1-166 E O1	9.85
939401	AE1-172 C O1	6.26
939402	AE1-172 E O1	29.29
939631	AE1-193 C O1	1.03
939632	AE1-193 E O1	6.9
939681	AE1-198 C O1	21.36
939682	AE1-198 E O1	18.15
939691	AE1-199	2.5
939701	AE1-201 C	2.11
939702	AE1-201 E	0.46
939732	AE1-204 E	0.31
939861	AE1-222 1	82.47
939871	AE1-222 2	88.2
939921	AE1-228 C O1	10.52
939922	AE1-228 E O1	7.01
939961	AE1-233 C O1	2.44
939962	AE1-233 E O1	10.07
940101	AE1-252 C O1	10.23
940102	AE1-252 E O1	6.82

Bus #	Bus	MW Impact
AB2-013	AB2-013	16.84
AE1-033	AE1-033	19.0
BLUEG	BLUEG	5.85
CALDERWOOD	CALDERWOOD	0.03
CANNELTON	CANNELTON	0.09
CARR	CARR	0.74
CATAWBA	CATAWBA	0.27
CBM-S1	CBM-S1	1.66
CBM-W1	CBM-W1	26.48
CBM-W2	CBM-W2	55.79
CHEOAH	CHEOAH	0.04
CHILHOWEE	CHILHOWEE	0.01
DEARBORN	DEARBORN	3.02
ELMERSMITH	ELMERSMITH	0.09
G-007	G-007	2.06
GIBSON	GIBSON	0.05
HAMLET	HAMLET	1.03
MEC	MEC	39.2
O-066	O-066	6.93
RENSSELAER	RENSSELAER	0.58
SANTEETLA	SANTEETLA	0.01
TRIMBLE	TRIMBLE	0.69
WEC	WEC	8.42
Z1-043	Z1-043	29.68

Index 10

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785347	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	116.02	116.75	DC	23.27

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	8.06
274722	S-055 E	7.52
274751	CRETE EC ;1U	1.93
274752	CRETE EC ;2U	1.93
274753	CRETE EC ;3U	1.93
274754	CRETE EC ;4U	1.93
274832	U4-027	7.11
274859	EASYR;U1 E	7.3
274860	EASYR;U2 E	7.3
274888	PILOT HIL;1E	12.4
274890	CAYUG;1U E	8.92
274891	CAYUG;2U E	8.92
275149	KEMPTON ;1E	12.4
290021	O50 E	12.98
290051	GSG-6; E	6.94
290108	LEEDK;1U E	16.14
293061	N-015 E	10.24
293516	O-009 E1	5.99
293517	O-009 E2	3.04
293518	O-009 E3	3.35
293644	O22 E1	7.24
293645	O22 E2	14.06
293715	O-029 E	6.47
293716	O-029 E	3.55
293717	O-029 E	3.26
294392	P-010 E	13.0
294763	P-046 E	6.23
295109	WESTBROOK E	3.72
295111	SUBLETTE E	1.72
910542	X3-005 E	0.52
914641	Y2-103	30.09
915011	Y3-013 1	2.51
915021	Y3-013 2	2.51
915031	Y3-013 3	2.51
916221	Z1-073 E	3.58
916502	Z1-106 E1	0.84
916504	Z1-106 E2	0.84
916512	Z1-107 E	1.71
916522	Z1-108 E	1.66
918052	AA1-018 E	10.62
919221	AA1-146	11.67

Bus #	Bus	MW Impact
919581	AA2-030	11.67
920272	AA2-123 E	1.63
924471	AB2-096	28.21
925161	AB2-173	2.08
925302	AB2-191 E	0.92
925881	AC1-067 O1	102.57
926311	AC1-109 1	1.27
926321	AC1-109 2	1.27
926331	AC1-110 1	1.27
926341	AC1-110 2	1.27
926351	AC1-111 1	0.51
926361	AC1-111 2	0.51
926371	AC1-111 3	0.51
926381	AC1-111 4	0.51
926391	AC1-111 5	0.51
926401	AC1-111 6	0.51
926431	AC1-114	1.58
926821	AC1-168 C O1	0.76
926822	AC1-168 E O1	5.08
927091	AC1-204 1	48.76
927101	AC1-204 2	48.73
927201	AC1-214 C O1	0.74
927202	AC1-214 E O1	2.34
927451	AC1-142A 1	2.83
927461	AC1-142A 2	2.83
927511	AC1-113 1	0.79
927521	AC1-113 2	0.79
927531	AC1-185 1	0.46
927541	AC1-185 2	0.46
927551	AC1-185 3	0.46
927561	AC1-185 4	0.46
927571	AC1-185 5	0.46
927581	AC1-185 6	0.46
927591	AC1-185 7	0.46
927601	AC1-185 8	0.46
930481	AB1-089	43.76
930501	AB1-091 O1	49.15
930741	AB1-122 1O1	47.58
930751	AB1-122 2O1	49.75
932881	AC2-115 1	1.58
932891	AC2-115 2	1.58
932921	AC2-116	0.55
933341	AC2-147 C	0.58
933342	AC2-147 E	0.94
933411	AC2-154 C	1.68
933412	AC2-154 E	2.75
933431	AC2-156 C O1	0.64
933432	AC2-156 E O1	1.04
933911	AD1-013 C	1.22
933912	AD1-013 E	1.95
933931	AD1-016 C	0.62
933932	AD1-016 E	1.01

Bus #	Bus	MW Impact
934101	AD1-039 1	4.66
934111	AD1-039 2	4.88
934401	AD1-064 C O1	2.13
934402	AD1-064 E O1	9.99
934431	AD1-067 C	0.09
934432	AD1-067 E	0.37
934651	AD1-096 C	0.59
934652	AD1-096 E	0.97
934701	AD1-098 C O1	4.57
934702	AD1-098 E O1	3.34
934721	AD1-100 C	12.94
934722	AD1-100 E	60.39
934871	AD1-116 C	0.62
934872	AD1-116 E	1.01
934881	AD1-117 C	3.57
934882	AD1-117 E	2.38
934971	AD1-129 C	0.6
934972	AD1-129 E	0.4
935001	AD1-133 C O1	13.73
935002	AD1-133 E O1	9.15
936291	AD2-038 C O1	1.54
936292	AD2-038 E O1	10.32
936371	AD2-047 C O1	1.51
936372	AD2-047 E O1	16.21
936461	AD2-060	1.77
936511	AD2-066 C O1	5.56
936512	AD2-066 E O1	3.71
936781	AD2-101 C	3.17
936782	AD2-101 E	14.84
936791	AD2-102 C	8.0
936792	AD2-102 E	7.69
936961	AD2-130	0.38
937001	AD2-134 C	1.82
937002	AD2-134 E	7.5
937031	AD2-137 C O1	2.31
937032	AD2-137 E O1	10.8
937051	AD2-140 C O1	2.32
937052	AD2-140 E O1	10.87
937061	AD2-141 C O1	2.31
937062	AD2-141 E O1	10.88
937071	AD2-142 C O1	4.64
937072	AD2-142 E O1	21.73
937121	AD2-148 C O1	2.36
937122	AD2-148 E O1	11.04
937131	AD2-149 C O1	2.36
937132	AD2-149 E O1	11.04
937141	AD2-150 C O1	2.36
937142	AD2-150 E O1	11.04
937181	AD2-155 C O1	2.36
937182	AD2-155 E O1	11.04
937311	AD2-172 C	1.64
937312	AD2-172 E	2.26

Bus #	Bus	MW Impact
937321	AD2-175 C	10.99
937322	AD2-175 E	7.33
937331	AD2-176 C O1	4.89
937332	AD2-176 E O1	3.26
937401	AD2-194 1	5.24
937411	AD2-194 2	5.24
937531	AD2-214 C	2.92
937532	AD2-214 E	1.37
938012	AE1-002 E O1	4.63
938511	AE1-070 1	6.16
938521	AE1-070 2	5.63
938851	AE1-113 C O1	5.72
938852	AE1-113 E O1	17.99
938861	AE1-114 C O1	2.37
938862	AE1-114 E O1	9.06
939051	AE1-134 1	0.91
939061	AE1-134 2	0.91
939321	AE1-163 C O1	4.03
939322	AE1-163 E O1	24.74
939351	AE1-166 C O1	6.84
939352	AE1-166 E O1	6.31
939401	AE1-172 C O1	4.1
939402	AE1-172 E O1	19.18
939641	AE1-194 C	10.88
939642	AE1-194 E	72.84
939651	AE1-195 C	10.88
939652	AE1-195 E	72.84
939691	AE1-199	1.59
939701	AE1-201 C	1.34
939702	AE1-201 E	0.29
939732	AE1-204 E	0.2
939861	AE1-222 1	52.55
939871	AE1-222 2	54.95
939921	AE1-228 C O1	6.68
939922	AE1-228 E O1	4.45
939961	AE1-233 C O1	1.55
939962	AE1-233 E O1	6.39
940101	AE1-252 C O1	6.69
940102	AE1-252 E O1	4.46
951721	J643	15.51
952581	J740 C	3.4
952582	J740 E	18.42
953871	J847	8.38
AB2-013	AB2-013	10.64
AE1-033	AE1-033	12.03
BLUEG	BLUEG	2.86
CANNELTON	CANNELTON	0.0
CARR	CARR	0.5
CATAWBA	CATAWBA	0.16
CBM-S1	CBM-S1	1.36
CBM-W1	CBM-W1	19.98
CBM-W2	CBM-W2	38.44

Bus #	Bus	MW Impact
CIN	CIN	0.12
DEARBORN	DEARBORN	2.29
G-007	G-007	1.38
HAMLET	HAMLET	0.65
MEC	MEC	25.05
O-066	O-066	4.65
RENSSELAER	RENSSELAER	0.39
SANTEETLA	SANTEETLA	0.0
TRIMBLE	TRIMBLE	0.34
WEC	WEC	5.32
Z1-043	Z1-043	18.82

Index 11

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785835	270853	PONTIAC ; R	CE	935000	AD1-133 TAP	CE	1	COMED_P1-2_345-L11212_B-S-C-A	single	1528.0	100.36	101.97	DC	24.59

Bus #	Bus	MW Impact
274650	KINCAID ;1U	15.48
274651	KINCAID ;2U	15.51
274853	TWINGROVE;U1	2.3
274854	TWINGROVE;U2	2.3
274863	CAYUGA RI;1U	2.14
274864	CAYUGA RI;2U	2.14
900404	X3-028 C	78.36
905081	W4-005 C	2.19
917501	Z2-087 C	1.85
924041	AB2-047 C O1	14.84
924261	AB2-070 C O1	6.98
925771	AC1-053 C	6.83
926841	AC1-171 C O1	0.75
930461	AB1-087	28.73
930471	AB1-088	28.73
933441	AC2-157 C	3.97
935141	AD1-148	12.29
936771	AD2-100 C O1	25.48
937161	AD2-153 C O1	9.91
937171	AD2-154 C O1	9.91
937211	AD2-159 C	10.33
939401	AE1-172 C O1	24.59
939741	AE1-205 C O1	39.11
940101	AE1-252 C O1	41.91
950701	J196 C	1.11
951001	J339	12.11
951741	J474 C	4.81
952271	J644	12.24
952321	J734	10.17
952651	J756 C	4.36
952871	J757 C	5.2
953241	J467 C	1.73
953401	J811	10.29
953651	J815	34.83
953741	J826 C	3.01
953801	J835 C	3.42
953851	J845 C	2.96
953881	J848 C	5.38
954081	J872 C	4.15
954181	J884	24.98

Bus #	Bus	MW Impact
954411	J912	13.29
954721	J750 C	3.3
954761	J468 C	3.94
AD2-098	AD2-098	0.45
AE1-042	AE1-042	5.79
CBM-N	CBM-N	0.66
CBM-S1	CBM-S1	9.87
CBM-S2	CBM-S2	3.13
CBM-W2	CBM-W2	111.77
CIN	CIN	10.82
CPL	CPL	1.12
DEARBORN	DEARBORN	0.52
EDWARDS	EDWARDS	0.05
G-007A	G-007A	2.18
IPL	IPL	5.9
LGEE	LGEE	1.65
MEC	MEC	2.66
NYISO	NYISO	2.85
O-066A	O-066A	1.01
TATANKA	TATANKA	0.42
VFT	VFT	5.85

Index 12

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785311	270886	ST JOHN ; T	CE	255104	17GREEN_ACRE	NIPS	1	COMED_P4_023-65-BT2-3__	breaker	1091.0	111.35	112.16	DC	25.42

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	9.04
274654	BRAIDWOOD;1U	19.05
274655	BRAIDWOOD;2U	18.24
274661	LASCO STA;2U	17.6
274687	WILL CNTY;4U	8.03
274704	KENDALL ;1C	2.81
274705	KENDALL ;1S	1.88
274706	KENDALL ;2C	2.81
274707	KENDALL ;2S	1.88
274722	S-055 E	8.45
274751	CRETE EC ;1U	3.36
274752	CRETE EC ;2U	3.36
274753	CRETE EC ;3U	3.36
274754	CRETE EC ;4U	3.36
274859	EASYR;U1 E	8.17
274860	EASYR;U2 E	8.17
274861	TOP CROP ;1U	0.33
274862	TOP CROP ;2U	0.63
274888	PILOT HIL;1E	12.81
274890	CAYUG;1U E	9.74
274891	CAYUG;2U E	9.74
275149	KEMPTON ;1E	12.81
290021	O50 E	14.65
290051	GSG-6; E	7.78
290108	LEEDK;1U E	18.09
293061	N-015 E	11.61
293516	O-009 E1	6.69
293517	O-009 E2	3.4
293518	O-009 E3	3.74
293644	O22 E1	8.5
293645	O22 E2	16.51
293715	O-029 E	7.24
293716	O-029 E	3.97
293717	O-029 E	3.65
294392	P-010 E	14.75
294763	P-046 E	6.98
295109	WESTBROOK E	4.16
295111	SUBLETTE E	1.92
914641	Y2-103	33.8
915011	Y3-013 1	2.82

Bus #	Bus	MW Impact
915021	Y3-013 2	2.82
915031	Y3-013 3	2.82
916221	Z1-073 E	4.01
916502	Z1-106 E1	0.94
916504	Z1-106 E2	0.94
916512	Z1-107 E	1.85
916522	Z1-108 E	1.86
918052	AA1-018 E	11.64
919221	AA1-146	13.04
919581	AA2-030	13.04
920272	AA2-123 E	1.83
924471	AB2-096	31.63
925161	AB2-173	2.33
925302	AB2-191 E	1.03
926311	AC1-109 1	1.42
926321	AC1-109 2	1.42
926331	AC1-110 1	1.42
926341	AC1-110 2	1.42
926351	AC1-111 1	0.57
926361	AC1-111 2	0.57
926371	AC1-111 3	0.57
926381	AC1-111 4	0.57
926391	AC1-111 5	0.57
926401	AC1-111 6	0.57
926431	AC1-114	1.77
926821	AC1-168 C O1	0.85
926822	AC1-168 E O1	5.68
927091	AC1-204 1	55.19
927101	AC1-204 2	55.12
927451	AC1-142A 1	3.2
927461	AC1-142A 2	3.2
927511	AC1-113 1	0.89
927521	AC1-113 2	0.89
927531	AC1-185 1	0.51
927541	AC1-185 2	0.51
927551	AC1-185 3	0.51
927561	AC1-185 4	0.51
927571	AC1-185 5	0.51
927581	AC1-185 6	0.51
927591	AC1-185 7	0.51
927601	AC1-185 8	0.51
930481	AB1-089	49.05
930501	AB1-091 O1	50.61
930741	AB1-122 1O1	52.99
930751	AB1-122 2O1	56.33
932881	AC2-115 1	1.77
932891	AC2-115 2	1.77
932921	AC2-116	0.62
933341	AC2-147 C	0.65
933342	AC2-147 E	1.06
933411	AC2-154 C	1.74
933412	AC2-154 E	2.84

Bus #	Bus	MW Impact
933431	AC2-156 C O1	0.71
933432	AC2-156 E O1	1.16
933911	AD1-013 C	1.37
933912	AD1-013 E	2.19
933931	AD1-016 C	0.69
933932	AD1-016 E	1.13
934101	AD1-039 1	5.19
934111	AD1-039 2	5.52
934401	AD1-064 C O1	2.39
934402	AD1-064 E O1	11.2
934431	AD1-067 C	0.1
934432	AD1-067 E	0.41
934651	AD1-096 C	0.66
934652	AD1-096 E	1.08
934701	AD1-098 C O1	5.12
934702	AD1-098 E O1	3.74
934721	AD1-100 C	14.27
934722	AD1-100 E	66.6
934871	AD1-116 C	0.68
934872	AD1-116 E	1.11
934881	AD1-117 C	3.99
934882	AD1-117 E	2.66
934971	AD1-129 C	0.67
934972	AD1-129 E	0.45
935001	AD1-133 C O1	15.16
935002	AD1-133 E O1	10.11
936291	AD2-038 C O1	1.71
936292	AD2-038 E O1	11.45
936371	AD2-047 C O1	1.56
936372	AD2-047 E O1	16.75
936461	AD2-060	1.83
936511	AD2-066 C O1	6.19
936512	AD2-066 E O1	4.13
936781	AD2-101 C	3.09
936782	AD2-101 E	14.46
936791	AD2-102 C	8.96
936792	AD2-102 E	8.61
936961	AD2-130	0.42
937001	AD2-134 C	2.03
937002	AD2-134 E	8.4
937031	AD2-137 C O1	2.44
937032	AD2-137 E O1	11.43
937051	AD2-140 C O1	2.44
937052	AD2-140 E O1	11.42
937061	AD2-141 C O1	2.43
937062	AD2-141 E O1	11.44
937071	AD2-142 C O1	4.88
937072	AD2-142 E O1	22.85
937121	AD2-148 C O1	2.43
937122	AD2-148 E O1	11.37
937131	AD2-149 C O1	2.43
937132	AD2-149 E O1	11.37

Bus #	Bus	MW Impact
937141	AD2-150 C O1	2.43
937142	AD2-150 E O1	11.37
937181	AD2-155 C O1	2.43
937182	AD2-155 E O1	11.37
937311	AD2-172 C	1.83
937312	AD2-172 E	2.53
937321	AD2-175 C	11.32
937322	AD2-175 E	7.55
937331	AD2-176 C O1	5.48
937332	AD2-176 E O1	3.65
937401	AD2-194 1	5.94
937411	AD2-194 2	5.93
937531	AD2-214 C	0.8
937532	AD2-214 E	0.38
938012	AE1-002 E O1	4.9
938511	AE1-070 1	6.97
938521	AE1-070 2	6.37
938851	AE1-113 C O1	6.35
938852	AE1-113 E O1	19.97
938861	AE1-114 C O1	2.65
938862	AE1-114 E O1	10.14
939051	AE1-134 1	1.01
939061	AE1-134 2	1.01
939321	AE1-163 C O1	4.63
939322	AE1-163 E O1	28.43
939351	AE1-166 C O1	7.6
939352	AE1-166 E O1	7.02
939401	AE1-172 C O1	4.47
939402	AE1-172 E O1	20.95
939641	AE1-194 C	18.96
939642	AE1-194 E	126.86
939651	AE1-195 C	18.96
939652	AE1-195 E	126.86
939691	AE1-199	1.78
939701	AE1-201 C	1.5
939702	AE1-201 E	0.33
939732	AE1-204 E	0.22
939861	AE1-222 1	58.52
939871	AE1-222 2	62.2
939921	AE1-228 C O1	7.48
939922	AE1-228 E O1	4.99
939961	AE1-233 C O1	1.73
939962	AE1-233 E O1	7.16
940101	AE1-252 C O1	7.31
940102	AE1-252 E O1	4.87
AB2-013	AB2-013	11.87
AE1-033	AE1-033	13.47
BLUEG	BLUEG	5.05
CALDERWOOD	CALDERWOOD	0.09
CANNELTON	CANNELTON	0.11
CARR	CARR	0.56
CATAWBA	CATAWBA	0.23

Bus #	Bus	MW Impact
CBM-S1	CBM-S1	0.77
CBM-W1	CBM-W1	20.04
CBM-W2	CBM-W2	37.14
CHEOAH	CHEOAH	0.09
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.24
ELMERSMITH	ELMERSMITH	0.14
G-007	G-007	1.57
GIBSON	GIBSON	0.06
HAMLET	HAMLET	0.87
MEC	MEC	27.58
O-066	O-066	5.3
RENSSELAER	RENSSELAER	0.45
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.59
WEC	WEC	5.97
Z1-043	Z1-043	20.98

Index 13

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785171	270926	WILTON ; B	CE	275232	WILTON ;3M	CE	1	COMED_P4_112-65-BT5-6__	breaker	1379.0	166.12	166.76	DC	54.08

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	14.81
274722	S-055 E	13.75
274772	LINCOLN ;3U	3.36
274773	LINCOLN ;4U	3.36
274774	LINCOLN ;5U	3.36
274775	LINCOLN ;6U	3.36
274776	LINCOLN ;7U	3.36
274777	LINCOLN ;8U	3.36
274859	EASYR;U1 E	13.46
274860	EASYR;U2 E	13.46
274888	PILOT HIL;1E	23.62
274890	CAYUG;1U E	20.25
274891	CAYUG;2U E	20.25
275149	KEMPTON ;1E	23.62
290021	O50 E	23.75
290051	GSG-6; E	12.8
290108	LEEDK;1U E	29.74
293061	N-015 E	19.44
293516	O-009 E1	1.0
293517	O-009 E2	0.51
293518	O-009 E3	0.56
293644	O22 E1	12.55
293645	O22 E2	24.37
293715	O-029 E	11.98
293716	O-029 E	6.57
293717	O-029 E	6.04
294392	P-010 E	24.69
294763	P-046 E	11.48
295109	WESTBROOK E	6.85
295111	SUBLETTE E	3.18
296125	R-030 C3	4.98
296128	R-030 E3	19.93
296271	R-030 C2	4.92
296272	R-030 E2	19.7
296308	R-030 C1	4.92
296309	R-030 E1	19.7
910542	X3-005 E	0.9
914641	Y2-103	55.02
915011	Y3-013 1	4.58
915021	Y3-013 2	4.58
915031	Y3-013 3	4.58

Bus #	Bus	MW Impact
916221	Z1-073 E	6.61
916502	Z1-106 E1	1.55
916504	Z1-106 E2	1.55
916512	Z1-107 E	3.17
916522	Z1-108 E	3.04
917502	Z2-087 E	25.76
918052	AA1-018 E	20.13
919221	AA1-146	21.54
919581	AA2-030	21.54
920272	AA2-123 E	2.99
924041	AB2-047 C O1	4.75
924042	AB2-047 E O1	31.79
924471	AB2-096	51.84
925161	AB2-173	3.84
925302	AB2-191 E	1.7
925881	AC1-067 O1	168.51
926311	AC1-109 1	2.34
926321	AC1-109 2	2.34
926331	AC1-110 1	2.33
926341	AC1-110 2	2.33
926351	AC1-111 1	0.94
926361	AC1-111 2	0.94
926371	AC1-111 3	0.94
926381	AC1-111 4	0.94
926391	AC1-111 5	0.94
926401	AC1-111 6	0.94
926431	AC1-114	2.91
926821	AC1-168 C O1	1.43
926822	AC1-168 E O1	9.59
927091	AC1-204 1	88.93
927101	AC1-204 2	88.93
927451	AC1-142A 1	5.12
927461	AC1-142A 2	5.12
927511	AC1-113 1	1.46
927521	AC1-113 2	1.46
927531	AC1-185 1	0.84
927541	AC1-185 2	0.84
927551	AC1-185 3	0.84
927561	AC1-185 4	0.84
927571	AC1-185 5	0.84
927581	AC1-185 6	0.84
927591	AC1-185 7	0.84
927601	AC1-185 8	0.84
930481	AB1-089	80.5
930501	AB1-091 O1	93.97
930741	AB1-122 1O1	89.35
930751	AB1-122 2O1	90.31
932881	AC2-115 1	2.91
932891	AC2-115 2	2.91
932921	AC2-116	1.02
932931	AC2-117	6.52
933341	AC2-147 C	1.07

Bus #	Bus	MW Impact
933342	AC2-147 E	1.74
933411	AC2-154 C	3.21
933412	AC2-154 E	5.23
933431	AC2-156 C O1	1.17
933432	AC2-156 E O1	1.91
933911	AD1-013 C	2.25
933912	AD1-013 E	3.6
933931	AD1-016 C	1.14
933932	AD1-016 E	1.85
934101	AD1-039 1	8.76
934111	AD1-039 2	8.85
934401	AD1-064 C O1	3.92
934402	AD1-064 E O1	18.37
934431	AD1-067 C	0.16
934432	AD1-067 E	0.68
934651	AD1-096 C	1.09
934652	AD1-096 E	1.78
934701	AD1-098 C O1	8.43
934702	AD1-098 E O1	6.15
934721	AD1-100 C	29.44
934722	AD1-100 E	137.37
934871	AD1-116 C	1.17
934872	AD1-116 E	1.91
934881	AD1-117 C	6.58
934882	AD1-117 E	4.39
934971	AD1-129 C	1.11
934972	AD1-129 E	0.74
935001	AD1-133 C O1	27.42
935002	AD1-133 E O1	18.28
936291	AD2-038 C O1	2.88
936292	AD2-038 E O1	19.29
936371	AD2-047 C O1	2.87
936372	AD2-047 E O1	30.87
936461	AD2-060	3.37
936511	AD2-066 C O1	10.36
936512	AD2-066 E O1	6.91
936781	AD2-101 C	5.83
936782	AD2-101 E	27.31
936791	AD2-102 C	14.71
936792	AD2-102 E	14.14
936961	AD2-130	0.69
937001	AD2-134 C	3.35
937002	AD2-134 E	13.82
937031	AD2-137 C O1	7.17
937032	AD2-137 E O1	33.59
937051	AD2-140 C O1	7.53
937052	AD2-140 E O1	35.28
937061	AD2-141 C O1	7.49
937062	AD2-141 E O1	35.32
937071	AD2-142 C O1	15.07
937072	AD2-142 E O1	70.55
937121	AD2-148 C O1	4.51

Bus #	Bus	MW Impact
937122	AD2-148 E O1	21.13
937131	AD2-149 C O1	4.51
937132	AD2-149 E O1	21.13
937141	AD2-150 C O1	4.51
937142	AD2-150 E O1	21.13
937181	AD2-155 C O1	4.51
937182	AD2-155 E O1	21.13
937311	AD2-172 C	3.01
937312	AD2-172 E	4.16
937321	AD2-175 C	21.03
937322	AD2-175 E	14.02
937331	AD2-176 C O1	8.97
937332	AD2-176 E O1	5.98
937401	AD2-194 1	9.56
937411	AD2-194 2	9.56
938012	AE1-002 E O1	14.4
938511	AE1-070 1	11.24
938521	AE1-070 2	10.28
938851	AE1-113 C O1	10.7
938852	AE1-113 E O1	33.64
938861	AE1-114 C O1	4.37
938862	AE1-114 E O1	16.72
939051	AE1-134 1	1.67
939061	AE1-134 2	1.67
939321	AE1-163 C O1	7.21
939322	AE1-163 E O1	44.26
939351	AE1-166 C O1	14.52
939352	AE1-166 E O1	13.41
939401	AE1-172 C O1	9.52
939402	AE1-172 E O1	44.57
939691	AE1-199	2.93
939701	AE1-201 C	2.45
939702	AE1-201 E	0.54
939732	AE1-204 E	0.36
939741	AE1-205 C O1	12.48
939742	AE1-205 E O1	17.23
939861	AE1-222 1	98.68
939871	AE1-222 2	99.73
939921	AE1-228 C O1	12.31
939922	AE1-228 E O1	8.21
939961	AE1-233 C O1	2.85
939962	AE1-233 E O1	11.77
940101	AE1-252 C O1	15.19
940102	AE1-252 E O1	10.13
AB2-013	AB2-013	19.85
AE1-033	AE1-033	22.1
BLUEG	BLUEG	7.86
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.96
CATAWBA	CATAWBA	0.38
CBM-S1	CBM-S1	1.85

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	37.32
CBM-W2	CBM-W2	71.02
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.9
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.69
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.46
MEC	MEC	46.58
O-066	O-066	9.06
RENSSELAER	RENSSELAER	0.76
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.94
WEC	WEC	9.75
Z1-043	Z1-043	35.51

Index 14

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785173	270927	WILTON	CE	275233	WILTON	CE	1	COMED_P4_112-65-BT2-3__	breaker	1379.0	164.02	164.96	DC	55.15

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	15.13
274722	S-055 E	14.05
274772	LINCOLN ;3U	3.45
274773	LINCOLN ;4U	3.45
274774	LINCOLN ;5U	3.45
274775	LINCOLN ;6U	3.45
274776	LINCOLN ;7U	3.45
274777	LINCOLN ;8U	3.45
274832	U4-027	6.82
274859	EASYR;U1 E	13.75
274860	EASYR;U2 E	13.75
274888	PILOT HIL;1E	24.11
274890	CAYUG;1U E	20.66
274891	CAYUG;2U E	20.66
275149	KEMPTON ;1E	24.11
290021	O50 E	24.25
290051	GSG-6; E	13.07
290108	LEEDK;1U E	30.37
293061	N-015 E	19.85
293516	O-009 E1	11.37
293517	O-009 E2	5.78
293518	O-009 E3	6.36
293644	O22 E1	12.82
293645	O22 E2	24.89
293715	O-029 E	12.24
293716	O-029 E	6.71
293717	O-029 E	6.17
293771	O-035 E	8.08
294392	P-010 E	25.21
294763	P-046 E	11.72
295109	WESTBROOK E	7.0
295111	SUBLETTE E	3.24
296125	R-030 C3	5.08
296128	R-030 E3	20.34
296271	R-030 C2	5.02
296272	R-030 E2	20.09
296308	R-030 C1	5.02
296309	R-030 E1	20.09
910542	X3-005 E	0.91
914641	Y2-103	56.19
915011	Y3-013 1	4.68

Bus #	Bus	MW Impact
915021	Y3-013 2	4.68
915031	Y3-013 3	4.68
916211	Z1-072 E	6.11
916221	Z1-073 E	6.75
916502	Z1-106 E1	1.58
916504	Z1-106 E2	1.58
916512	Z1-107 E	3.23
916522	Z1-108 E	3.11
917502	Z2-087 E	26.28
918052	AA1-018 E	20.57
919221	AA1-146	22.0
919581	AA2-030	22.0
920272	AA2-123 E	3.06
924041	AB2-047 C O1	4.85
924042	AB2-047 E O1	32.43
924471	AB2-096	52.94
925161	AB2-173	3.92
925302	AB2-191 E	1.73
925881	AC1-067 O1	172.23
926311	AC1-109 1	2.39
926321	AC1-109 2	2.39
926331	AC1-110 1	2.37
926341	AC1-110 2	2.37
926351	AC1-111 1	0.96
926361	AC1-111 2	0.96
926371	AC1-111 3	0.96
926381	AC1-111 4	0.96
926391	AC1-111 5	0.96
926401	AC1-111 6	0.96
926431	AC1-114	2.97
926821	AC1-168 C O1	1.46
926822	AC1-168 E O1	9.79
927091	AC1-204 1	90.83
927101	AC1-204 2	90.83
927201	AC1-214 C O1	2.59
927202	AC1-214 E O1	8.24
927451	AC1-142A 1	5.23
927461	AC1-142A 2	5.23
927511	AC1-113 1	1.49
927521	AC1-113 2	1.49
927531	AC1-185 1	0.86
927541	AC1-185 2	0.86
927551	AC1-185 3	0.86
927561	AC1-185 4	0.86
927571	AC1-185 5	0.86
927581	AC1-185 6	0.86
927591	AC1-185 7	0.86
927601	AC1-185 8	0.86
930481	AB1-089	82.21
930501	AB1-091 O1	95.92
930741	AB1-122 1O1	91.25
930751	AB1-122 2O1	92.24

Bus #	Bus	MW Impact
932881	AC2-115 1	2.97
932891	AC2-115 2	2.97
932921	AC2-116	1.04
932931	AC2-117	6.67
933341	AC2-147 C	1.09
933342	AC2-147 E	1.78
933411	AC2-154 C	3.27
933412	AC2-154 E	5.34
933431	AC2-156 C O1	1.2
933432	AC2-156 E O1	1.95
933911	AD1-013 C	2.3
933912	AD1-013 E	3.68
933931	AD1-016 C	1.16
933932	AD1-016 E	1.89
934101	AD1-039 1	8.94
934111	AD1-039 2	9.04
934401	AD1-064 C O1	4.01
934402	AD1-064 E O1	18.76
934431	AD1-067 C	0.16
934432	AD1-067 E	0.69
934651	AD1-096 C	1.11
934652	AD1-096 E	1.82
934701	AD1-098 C O1	8.6
934702	AD1-098 E O1	6.28
934721	AD1-100 C	30.02
934722	AD1-100 E	140.09
934871	AD1-116 C	1.2
934872	AD1-116 E	1.95
934881	AD1-117 C	6.72
934882	AD1-117 E	4.48
934971	AD1-129 C	1.13
934972	AD1-129 E	0.75
935001	AD1-133 C O1	27.99
935002	AD1-133 E O1	18.66
936291	AD2-038 C O1	2.94
936292	AD2-038 E O1	19.7
936371	AD2-047 C O1	2.93
936372	AD2-047 E O1	31.51
936461	AD2-060	3.44
936511	AD2-066 C O1	10.58
936512	AD2-066 E O1	7.05
936781	AD2-101 C	5.95
936782	AD2-101 E	27.88
936791	AD2-102 C	15.03
936792	AD2-102 E	14.44
936961	AD2-130	0.7
937001	AD2-134 C	3.42
937002	AD2-134 E	14.12
937031	AD2-137 C O1	7.31
937032	AD2-137 E O1	34.21
937051	AD2-140 C O1	7.67
937052	AD2-140 E O1	35.93

Bus #	Bus	MW Impact
937061	AD2-141 C O1	7.63
937062	AD2-141 E O1	35.97
937071	AD2-142 C O1	15.35
937072	AD2-142 E O1	71.86
937121	AD2-148 C O1	4.61
937122	AD2-148 E O1	21.57
937131	AD2-149 C O1	4.61
937132	AD2-149 E O1	21.57
937141	AD2-150 C O1	4.61
937142	AD2-150 E O1	21.57
937181	AD2-155 C O1	4.61
937182	AD2-155 E O1	21.57
937311	AD2-172 C	3.08
937312	AD2-172 E	4.25
937321	AD2-175 C	21.46
937322	AD2-175 E	14.31
937331	AD2-176 C O1	9.17
937332	AD2-176 E O1	6.11
937401	AD2-194 1	9.77
937411	AD2-194 2	9.77
938012	AE1-002 E O1	14.67
938511	AE1-070 1	11.48
938521	AE1-070 2	10.5
938851	AE1-113 C O1	10.93
938852	AE1-113 E O1	34.37
938861	AE1-114 C O1	4.47
938862	AE1-114 E O1	17.07
939051	AE1-134 1	1.71
939061	AE1-134 2	1.71
939321	AE1-163 C O1	7.36
939322	AE1-163 E O1	45.2
939351	AE1-166 C O1	14.82
939352	AE1-166 E O1	13.68
939401	AE1-172 C O1	9.71
939402	AE1-172 E O1	45.45
939691	AE1-199	2.99
939701	AE1-201 C	2.51
939702	AE1-201 E	0.55
939732	AE1-204 E	0.37
939741	AE1-205 C O1	12.73
939742	AE1-205 E O1	17.58
939861	AE1-222 1	100.77
939871	AE1-222 2	101.86
939921	AE1-228 C O1	12.57
939922	AE1-228 E O1	8.38
939961	AE1-233 C O1	2.91
939962	AE1-233 E O1	12.02
940101	AE1-252 C O1	15.49
940102	AE1-252 E O1	10.33
AB2-013	AB2-013	20.27
AE1-033	AE1-033	22.58
BLUEG	BLUEG	8.03

Bus #	Bus	MW Impact
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.98
CATAWBA	CATAWBA	0.39
CBM-S1	CBM-S1	1.88
CBM-W1	CBM-W1	38.11
CBM-W2	CBM-W2	72.48
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.96
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.75
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.49
MEC	MEC	47.56
O-066	O-066	9.26
RENSSELAER	RENSSELAER	0.77
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.96
WEC	WEC	9.96
Z1-043	Z1-043	36.25

Index 15

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785203	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	124.49	125.51	DC	35.06

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	12.57
274654	BRAIDWOOD;1U	26.97
274655	BRAIDWOOD;2U	25.8
274661	LASCO STA;2U	24.66
274687	WILL CNTY;4U	11.24
274704	KENDALL ;1C	3.96
274705	KENDALL ;1S	2.64
274706	KENDALL ;2C	3.96
274707	KENDALL ;2S	2.64
274722	S-055 E	11.77
274751	CRETE EC ;1U	5.74
274752	CRETE EC ;2U	5.74
274753	CRETE EC ;3U	5.74
274754	CRETE EC ;4U	5.74
274859	EASYR;U1 E	11.37
274860	EASYR;U2 E	11.37
274861	TOP CROP ;1U	0.47
274862	TOP CROP ;2U	0.91
274888	PILOT HIL;1E	16.88
274890	CAYUG;1U E	13.45
274891	CAYUG;2U E	13.45
275149	KEMPTON ;1E	16.88
290021	O50 E	20.54
290051	GSG-6; E	10.8
290108	LEEDK;1U E	25.11
293061	N-015 E	16.24
293516	O-009 E1	9.32
293517	O-009 E2	4.73
293518	O-009 E3	5.21
293644	O22 E1	12.21
293645	O22 E2	23.71
293715	O-029 E	10.07
293716	O-029 E	5.52
293717	O-029 E	5.08
294392	P-010 E	20.62
294763	P-046 E	9.71
295109	WESTBROOK E	5.78
295111	SUBLETTE E	2.68
914641	Y2-103	47.06
915011	Y3-013 1	3.92
915021	Y3-013 2	3.92

Bus #	Bus	MW Impact
915031	Y3-013 3	3.92
916221	Z1-073 E	5.57
916502	Z1-106 E1	1.31
916504	Z1-106 E2	1.31
916512	Z1-107 E	2.52
916522	Z1-108 E	2.59
918052	AA1-018 E	15.99
919221	AA1-146	18.16
919581	AA2-030	18.16
920272	AA2-123 E	2.54
924471	AB2-096	43.99
925161	AB2-173	3.24
925302	AB2-191 E	1.43
926311	AC1-109 1	1.97
926321	AC1-109 2	1.97
926331	AC1-110 1	1.98
926341	AC1-110 2	1.98
926351	AC1-111 1	0.79
926361	AC1-111 2	0.79
926371	AC1-111 3	0.79
926381	AC1-111 4	0.79
926391	AC1-111 5	0.79
926401	AC1-111 6	0.79
926431	AC1-114	2.47
926821	AC1-168 C O1	1.18
926822	AC1-168 E O1	7.92
927091	AC1-204 1	77.42
927101	AC1-204 2	77.29
927451	AC1-142A 1	4.48
927461	AC1-142A 2	4.48
927511	AC1-113 1	1.23
927521	AC1-113 2	1.23
927531	AC1-185 1	0.71
927541	AC1-185 2	0.71
927551	AC1-185 3	0.71
927561	AC1-185 4	0.71
927571	AC1-185 5	0.71
927581	AC1-185 6	0.71
927591	AC1-185 7	0.71
927601	AC1-185 8	0.71
930481	AB1-089	68.22
930501	AB1-091 O1	66.51
930741	AB1-122 1O1	73.76
930751	AB1-122 2O1	78.95
932881	AC2-115 1	2.47
932891	AC2-115 2	2.47
932921	AC2-116	0.86
933341	AC2-147 C	0.9
933342	AC2-147 E	1.47
933411	AC2-154 C	2.29
933412	AC2-154 E	3.74
933431	AC2-156 C O1	0.99

Bus #	Bus	MW Impact
933432	AC2-156 E O1	1.61
933911	AD1-013 C	1.9
933912	AD1-013 E	3.04
933931	AD1-016 C	0.97
933932	AD1-016 E	1.58
934101	AD1-039 1	7.23
934111	AD1-039 2	7.74
934401	AD1-064 C O1	3.33
934402	AD1-064 E O1	15.58
934431	AD1-067 C	0.14
934432	AD1-067 E	0.57
934651	AD1-096 C	0.92
934652	AD1-096 E	1.51
934701	AD1-098 C O1	7.11
934702	AD1-098 E O1	5.19
934721	AD1-100 C	19.71
934722	AD1-100 E	91.99
934871	AD1-116 C	0.93
934872	AD1-116 E	1.52
934881	AD1-117 C	5.55
934882	AD1-117 E	3.7
934971	AD1-129 C	0.94
934972	AD1-129 E	0.63
935001	AD1-133 C O1	21.05
935002	AD1-133 E O1	14.03
936291	AD2-038 C O1	2.37
936292	AD2-038 E O1	15.89
936371	AD2-047 C O1	2.05
936372	AD2-047 E O1	22.06
936461	AD2-060	2.41
936511	AD2-066 C O1	8.6
936512	AD2-066 E O1	5.74
936781	AD2-101 C	3.03
936782	AD2-101 E	14.16
936791	AD2-102 C	12.47
936792	AD2-102 E	11.98
936961	AD2-130	0.59
937001	AD2-134 C	2.82
937002	AD2-134 E	11.67
937031	AD2-137 C O1	3.3
937032	AD2-137 E O1	15.44
937051	AD2-140 C O1	3.28
937052	AD2-140 E O1	15.37
937061	AD2-141 C O1	3.27
937062	AD2-141 E O1	15.39
937071	AD2-142 C O1	6.57
937072	AD2-142 E O1	30.75
937121	AD2-148 C O1	3.19
937122	AD2-148 E O1	14.95
937131	AD2-149 C O1	3.19
937132	AD2-149 E O1	14.95
937141	AD2-150 C O1	3.19

Bus #	Bus	MW Impact
937142	AD2-150 E O1	14.95
937181	AD2-155 C O1	3.19
937182	AD2-155 E O1	14.95
937311	AD2-172 C	2.55
937312	AD2-172 E	3.52
937321	AD2-175 C	14.88
937322	AD2-175 E	9.92
937331	AD2-176 C O1	7.62
937332	AD2-176 E O1	5.08
937401	AD2-194 1	8.33
937411	AD2-194 2	8.31
937531	AD2-214 C	4.54
937532	AD2-214 E	2.14
938012	AE1-002 E O1	6.62
938511	AE1-070 1	9.78
938521	AE1-070 2	8.93
938851	AE1-113 C O1	8.81
938852	AE1-113 E O1	27.71
938861	AE1-114 C O1	3.69
938862	AE1-114 E O1	14.11
939051	AE1-134 1	1.41
939061	AE1-134 2	1.41
939321	AE1-163 C O1	6.57
939322	AE1-163 E O1	40.34
939351	AE1-166 C O1	10.54
939352	AE1-166 E O1	9.73
939401	AE1-172 C O1	6.17
939402	AE1-172 E O1	28.89
939641	AE1-194 C	32.38
939642	AE1-194 E	216.73
939651	AE1-195 C	32.38
939652	AE1-195 E	216.73
939691	AE1-199	2.47
939701	AE1-201 C	2.08
939702	AE1-201 E	0.46
939732	AE1-204 E	0.31
939861	AE1-222 1	81.46
939871	AE1-222 2	87.19
939921	AE1-228 C O1	10.39
939922	AE1-228 E O1	6.93
939961	AE1-233 C O1	2.41
939962	AE1-233 E O1	9.95
940101	AE1-252 C O1	10.09
940102	AE1-252 E O1	6.73
AB2-013	AB2-013	16.6
AE1-033	AE1-033	18.74
BLUEG	BLUEG	6.66
CALDERWOOD	CALDERWOOD	0.12
CANNELTON	CANNELTON	0.14
CARR	CARR	0.8
CATAWBA	CATAWBA	0.32
CBM-S1	CBM-S1	1.14

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	25.55
CBM-W2	CBM-W2	51.99
CHEOAH	CHEOAH	0.12
CHILHOWEE	CHILHOWEE	0.04
DEARBORN	DEARBORN	3.16
ELMERSMITH	ELMERSMITH	0.17
G-007	G-007	2.23
GIBSON	GIBSON	0.08
HAMLET	HAMLET	1.22
MEC	MEC	38.45
O-066	O-066	7.49
RENSSELAER	RENSSELAER	0.63
SANTEETLA	SANTEETLA	0.04
TRIMBLE	TRIMBLE	0.78
WEC	WEC	8.32
Z1-043	Z1-043	29.26

Index 16

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785265	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	134.92	135.87	DC	27.88

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	9.79
274722	S-055 E	9.15
274808	UNIV PK N;4U	1.62
274809	UNIV PK N;5U	1.62
274811	UNIV PK N;7U	1.62
274812	UNIV PK N;8U	1.62
274814	UNIV PK N;0U	1.62
274815	UNIV PK N;XU	1.62
274832	U4-027	8.61
274859	EASYR;U1 E	8.84
274860	EASYR;U2 E	8.84
274888	PILOT HIL;1E	14.86
274890	CAYUG;1U E	10.7
274891	CAYUG;2U E	10.7
275149	KEMPTON ;1E	14.86
290021	O50 E	15.62
290051	GSG-6; E	8.43
290108	LEEDK;1U E	19.61
293061	N-015 E	12.6
293516	O-009 E1	7.26
293517	O-009 E2	3.69
293518	O-009 E3	4.06
293644	O22 E1	7.88
293645	O22 E2	15.3
293715	O-029 E	7.84
293716	O-029 E	4.3
293717	O-029 E	3.95
293771	O-035 E	5.09
294392	P-010 E	16.0
294401	BSHIL;1U E	6.8
294410	BSHIL;2U E	6.8
294763	P-046 E	7.56
295109	WESTBROOK E	4.51
295111	SUBLETTE E	2.08
910542	X3-005 E	0.51
914641	Y2-103	36.59
915011	Y3-013 1	3.05
915021	Y3-013 2	3.05
915031	Y3-013 3	3.05
916211	Z1-072 E	3.85

Bus #	Bus	MW Impact
916221	Z1-073 E	4.35
916502	Z1-106 E1	1.02
916504	Z1-106 E2	1.02
916512	Z1-107 E	2.17
916522	Z1-108 E	2.02
918052	AA1-018 E	14.29
919221	AA1-146	14.12
919581	AA2-030	14.12
919621	AA2-039 C	1.66
919622	AA2-039 E	11.1
920272	AA2-123 E	1.98
924471	AB2-096	34.27
925161	AB2-173	2.52
925302	AB2-191 E	1.12
925581	AC1-033 C	1.11
925582	AC1-033 E	7.46
925881	AC1-067 O1	97.44
926311	AC1-109 1	1.55
926321	AC1-109 2	1.55
926331	AC1-110 1	1.54
926341	AC1-110 2	1.54
926351	AC1-111 1	0.62
926361	AC1-111 2	0.62
926371	AC1-111 3	0.62
926381	AC1-111 4	0.62
926391	AC1-111 5	0.62
926401	AC1-111 6	0.62
926431	AC1-114	1.92
926821	AC1-168 C O1	0.92
926822	AC1-168 E O1	6.18
927091	AC1-204 1	59.17
927101	AC1-204 2	59.21
927201	AC1-214 C O1	1.63
927202	AC1-214 E O1	5.19
927451	AC1-142A 1	3.45
927461	AC1-142A 2	3.45
927511	AC1-113 1	0.96
927521	AC1-113 2	0.96
927531	AC1-185 1	0.55
927541	AC1-185 2	0.55
927551	AC1-185 3	0.55
927561	AC1-185 4	0.55
927571	AC1-185 5	0.55
927581	AC1-185 6	0.55
927591	AC1-185 7	0.55
927601	AC1-185 8	0.55
930481	AB1-089	53.11
930501	AB1-091 O1	57.12
930741	AB1-122 1O1	58.21
930751	AB1-122 2O1	59.68
932881	AC2-115 1	1.92
932891	AC2-115 2	1.92

Bus #	Bus	MW Impact
932921	AC2-116	0.67
932931	AC2-117	10.39
933341	AC2-147 C	0.7
933342	AC2-147 E	1.15
933411	AC2-154 C	2.02
933412	AC2-154 E	3.29
933431	AC2-156 C O1	0.77
933432	AC2-156 E O1	1.26
933911	AD1-013 C	1.48
933912	AD1-013 E	2.37
933931	AD1-016 C	0.75
933932	AD1-016 E	1.23
934051	AD1-031 C O1	2.26
934052	AD1-031 E O1	3.69
934101	AD1-039 1	5.7
934111	AD1-039 2	5.85
934401	AD1-064 C O1	2.59
934402	AD1-064 E O1	12.13
934431	AD1-067 C	0.11
934432	AD1-067 E	0.44
934651	AD1-096 C	0.72
934652	AD1-096 E	1.17
934701	AD1-098 C O1	5.55
934702	AD1-098 E O1	4.05
934721	AD1-100 C	15.58
934722	AD1-100 E	72.69
934871	AD1-116 C	0.83
934872	AD1-116 E	1.36
934881	AD1-117 C	4.32
934882	AD1-117 E	2.88
934971	AD1-129 C	0.73
934972	AD1-129 E	0.49
935001	AD1-133 C O1	16.67
935002	AD1-133 E O1	11.11
936291	AD2-038 C O1	1.97
936292	AD2-038 E O1	13.19
936371	AD2-047 C O1	1.8
936372	AD2-047 E O1	19.42
936461	AD2-060	2.12
936511	AD2-066 C O1	6.83
936512	AD2-066 E O1	4.55
936781	AD2-101 C	3.51
936782	AD2-101 E	16.41
936791	AD2-102 C	9.71
936792	AD2-102 E	9.33
936961	AD2-130	0.46
937001	AD2-134 C	2.2
937002	AD2-134 E	9.1
937031	AD2-137 C O1	2.69
937032	AD2-137 E O1	12.6
937051	AD2-140 C O1	2.69
937052	AD2-140 E O1	12.61

Bus #	Bus	MW Impact
937061	AD2-141 C O1	2.68
937062	AD2-141 E O1	12.63
937071	AD2-142 C O1	5.39
937072	AD2-142 E O1	25.22
937121	AD2-148 C O1	2.74
937122	AD2-148 E O1	12.83
937131	AD2-149 C O1	2.74
937132	AD2-149 E O1	12.83
937141	AD2-150 C O1	2.74
937142	AD2-150 E O1	12.83
937181	AD2-155 C O1	2.74
937182	AD2-155 E O1	12.83
937311	AD2-172 C	1.98
937312	AD2-172 E	2.74
937321	AD2-175 C	12.77
937322	AD2-175 E	8.51
937331	AD2-176 C O1	5.94
937332	AD2-176 E O1	3.96
937401	AD2-194 1	6.36
937411	AD2-194 2	6.37
937531	AD2-214 C	3.53
937532	AD2-214 E	1.66
938012	AE1-002 E O1	5.4
938511	AE1-070 1	7.48
938521	AE1-070 2	6.84
938851	AE1-113 C O1	7.32
938852	AE1-113 E O1	23.0
938861	AE1-114 C O1	2.87
938862	AE1-114 E O1	10.98
939051	AE1-134 1	1.1
939061	AE1-134 2	1.1
939321	AE1-163 C O1	4.63
939322	AE1-163 E O1	28.42
939351	AE1-166 C O1	8.28
939352	AE1-166 E O1	7.64
939401	AE1-172 C O1	4.91
939402	AE1-172 E O1	22.97
939631	AE1-193 C O1	5.53
939632	AE1-193 E O1	37.0
939681	AE1-198 C O1	16.41
939682	AE1-198 E O1	13.95
939691	AE1-199	1.93
939701	AE1-201 C	1.62
939702	AE1-201 E	0.36
939732	AE1-204 E	0.24
939861	AE1-222 1	64.28
939871	AE1-222 2	65.91
939921	AE1-228 C O1	8.11
939922	AE1-228 E O1	5.4
939961	AE1-233 C O1	1.88
939962	AE1-233 E O1	7.77
940101	AE1-252 C O1	8.02

Bus #	Bus	MW Impact
940102	AE1-252 E O1	5.35
990901	L-005 E	5.05
AB2-013	AB2-013	12.84
AE1-033	AE1-033	14.59
BLUEG	BLUEG	4.41
CALDERWOOD	CALDERWOOD	0.05
CANNELTON	CANNELTON	0.06
CARR	CARR	0.61
CATAWBA	CATAWBA	0.23
CBM-S1	CBM-S1	1.22
CBM-W1	CBM-W1	21.89
CBM-W2	CBM-W2	43.2
CHEOAH	CHEOAH	0.05
CHILHOWEE	CHILHOWEE	0.01
DEARBORN	DEARBORN	2.62
ELMERSMITH	ELMERSMITH	0.06
G-007	G-007	1.71
GIBSON	GIBSON	0.02
HAMLET	HAMLET	0.88
MEC	MEC	30.08
O-066	O-066	5.77
RENSSELAER	RENSSELAER	0.49
SANTEETLA	SANTEETLA	0.02
TRIMBLE	TRIMBLE	0.52
WEC	WEC	6.46
Z1-043	Z1-043	22.86

Index 17

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785170	275232	WILTON ;3M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT5-6__	breaker	1379.0	166.12	166.76	DC	54.08

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	14.81
274722	S-055 E	13.75
274772	LINCOLN ;3U	3.36
274773	LINCOLN ;4U	3.36
274774	LINCOLN ;5U	3.36
274775	LINCOLN ;6U	3.36
274776	LINCOLN ;7U	3.36
274777	LINCOLN ;8U	3.36
274859	EASYR;U1 E	13.46
274860	EASYR;U2 E	13.46
274888	PILOT HIL;1E	23.62
274890	CAYUG;1U E	20.25
274891	CAYUG;2U E	20.25
275149	KEMPTON ;1E	23.62
290021	O50 E	23.75
290051	GSG-6; E	12.8
290108	LEEDK;1U E	29.74
293061	N-015 E	19.44
293516	O-009 E1	1.0
293517	O-009 E2	0.51
293518	O-009 E3	0.56
293644	O22 E1	12.55
293645	O22 E2	24.37
293715	O-029 E	11.98
293716	O-029 E	6.57
293717	O-029 E	6.04
294392	P-010 E	24.69
294763	P-046 E	11.48
295109	WESTBROOK E	6.85
295111	SUBLETTE E	3.18
296125	R-030 C3	4.98
296128	R-030 E3	19.93
296271	R-030 C2	4.92
296272	R-030 E2	19.7
296308	R-030 C1	4.92
296309	R-030 E1	19.7
910542	X3-005 E	0.9
914641	Y2-103	55.02
915011	Y3-013 1	4.58
915021	Y3-013 2	4.58
915031	Y3-013 3	4.58

Bus #	Bus	MW Impact
916221	Z1-073 E	6.61
916502	Z1-106 E1	1.55
916504	Z1-106 E2	1.55
916512	Z1-107 E	3.17
916522	Z1-108 E	3.04
917502	Z2-087 E	25.76
918052	AA1-018 E	20.13
919221	AA1-146	21.54
919581	AA2-030	21.54
920272	AA2-123 E	2.99
924041	AB2-047 C O1	4.75
924042	AB2-047 E O1	31.79
924471	AB2-096	51.84
925161	AB2-173	3.84
925302	AB2-191 E	1.7
925881	AC1-067 O1	168.51
926311	AC1-109 1	2.34
926321	AC1-109 2	2.34
926331	AC1-110 1	2.33
926341	AC1-110 2	2.33
926351	AC1-111 1	0.94
926361	AC1-111 2	0.94
926371	AC1-111 3	0.94
926381	AC1-111 4	0.94
926391	AC1-111 5	0.94
926401	AC1-111 6	0.94
926431	AC1-114	2.91
926821	AC1-168 C O1	1.43
926822	AC1-168 E O1	9.59
927091	AC1-204 1	88.93
927101	AC1-204 2	88.93
927451	AC1-142A 1	5.12
927461	AC1-142A 2	5.12
927511	AC1-113 1	1.46
927521	AC1-113 2	1.46
927531	AC1-185 1	0.84
927541	AC1-185 2	0.84
927551	AC1-185 3	0.84
927561	AC1-185 4	0.84
927571	AC1-185 5	0.84
927581	AC1-185 6	0.84
927591	AC1-185 7	0.84
927601	AC1-185 8	0.84
930481	AB1-089	80.5
930501	AB1-091 O1	93.97
930741	AB1-122 1O1	89.35
930751	AB1-122 2O1	90.31
932881	AC2-115 1	2.91
932891	AC2-115 2	2.91
932921	AC2-116	1.02
932931	AC2-117	6.52
933341	AC2-147 C	1.07

Bus #	Bus	MW Impact
933342	AC2-147 E	1.74
933411	AC2-154 C	3.21
933412	AC2-154 E	5.23
933431	AC2-156 C O1	1.17
933432	AC2-156 E O1	1.91
933911	AD1-013 C	2.25
933912	AD1-013 E	3.6
933931	AD1-016 C	1.14
933932	AD1-016 E	1.85
934101	AD1-039 1	8.76
934111	AD1-039 2	8.85
934401	AD1-064 C O1	3.92
934402	AD1-064 E O1	18.37
934431	AD1-067 C	0.16
934432	AD1-067 E	0.68
934651	AD1-096 C	1.09
934652	AD1-096 E	1.78
934701	AD1-098 C O1	8.43
934702	AD1-098 E O1	6.15
934721	AD1-100 C	29.44
934722	AD1-100 E	137.37
934871	AD1-116 C	1.17
934872	AD1-116 E	1.91
934881	AD1-117 C	6.58
934882	AD1-117 E	4.39
934971	AD1-129 C	1.11
934972	AD1-129 E	0.74
935001	AD1-133 C O1	27.42
935002	AD1-133 E O1	18.28
936291	AD2-038 C O1	2.88
936292	AD2-038 E O1	19.29
936371	AD2-047 C O1	2.87
936372	AD2-047 E O1	30.87
936461	AD2-060	3.37
936511	AD2-066 C O1	10.36
936512	AD2-066 E O1	6.91
936781	AD2-101 C	5.83
936782	AD2-101 E	27.31
936791	AD2-102 C	14.71
936792	AD2-102 E	14.14
936961	AD2-130	0.69
937001	AD2-134 C	3.35
937002	AD2-134 E	13.82
937031	AD2-137 C O1	7.17
937032	AD2-137 E O1	33.59
937051	AD2-140 C O1	7.53
937052	AD2-140 E O1	35.28
937061	AD2-141 C O1	7.49
937062	AD2-141 E O1	35.32
937071	AD2-142 C O1	15.07
937072	AD2-142 E O1	70.55
937121	AD2-148 C O1	4.51

Bus #	Bus	MW Impact
937122	AD2-148 E O1	21.13
937131	AD2-149 C O1	4.51
937132	AD2-149 E O1	21.13
937141	AD2-150 C O1	4.51
937142	AD2-150 E O1	21.13
937181	AD2-155 C O1	4.51
937182	AD2-155 E O1	21.13
937311	AD2-172 C	3.01
937312	AD2-172 E	4.16
937321	AD2-175 C	21.03
937322	AD2-175 E	14.02
937331	AD2-176 C O1	8.97
937332	AD2-176 E O1	5.98
937401	AD2-194 1	9.56
937411	AD2-194 2	9.56
938012	AE1-002 E O1	14.4
938511	AE1-070 1	11.24
938521	AE1-070 2	10.28
938851	AE1-113 C O1	10.7
938852	AE1-113 E O1	33.64
938861	AE1-114 C O1	4.37
938862	AE1-114 E O1	16.72
939051	AE1-134 1	1.67
939061	AE1-134 2	1.67
939321	AE1-163 C O1	7.21
939322	AE1-163 E O1	44.26
939351	AE1-166 C O1	14.52
939352	AE1-166 E O1	13.41
939401	AE1-172 C O1	9.52
939402	AE1-172 E O1	44.57
939691	AE1-199	2.93
939701	AE1-201 C	2.45
939702	AE1-201 E	0.54
939732	AE1-204 E	0.36
939741	AE1-205 C O1	12.48
939742	AE1-205 E O1	17.23
939861	AE1-222 1	98.68
939871	AE1-222 2	99.73
939921	AE1-228 C O1	12.31
939922	AE1-228 E O1	8.21
939961	AE1-233 C O1	2.85
939962	AE1-233 E O1	11.77
940101	AE1-252 C O1	15.19
940102	AE1-252 E O1	10.13
AB2-013	AB2-013	19.85
AE1-033	AE1-033	22.1
BLUEG	BLUEG	7.86
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.96
CATAWBA	CATAWBA	0.38
CBM-S1	CBM-S1	1.85

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	37.32
CBM-W2	CBM-W2	71.02
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.9
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.69
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.46
MEC	MEC	46.58
O-066	O-066	9.06
RENSSELAER	RENSSELAER	0.76
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.94
WEC	WEC	9.75
Z1-043	Z1-043	35.51

Index 18

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785175	275233	WILTON ;4M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT2-3__	breaker	1379.0	164.02	164.96	DC	55.15

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	15.13
274722	S-055 E	14.05
274772	LINCOLN ;3U	3.45
274773	LINCOLN ;4U	3.45
274774	LINCOLN ;5U	3.45
274775	LINCOLN ;6U	3.45
274776	LINCOLN ;7U	3.45
274777	LINCOLN ;8U	3.45
274832	U4-027	6.82
274859	EASYR;U1 E	13.75
274860	EASYR;U2 E	13.75
274888	PILOT HIL;1E	24.11
274890	CAYUG;1U E	20.66
274891	CAYUG;2U E	20.66
275149	KEMPTON ;1E	24.11
290021	O50 E	24.25
290051	GSG-6; E	13.07
290108	LEEDK;1U E	30.37
293061	N-015 E	19.85
293516	O-009 E1	11.37
293517	O-009 E2	5.78
293518	O-009 E3	6.36
293644	O22 E1	12.82
293645	O22 E2	24.89
293715	O-029 E	12.24
293716	O-029 E	6.71
293717	O-029 E	6.17
293771	O-035 E	8.08
294392	P-010 E	25.21
294763	P-046 E	11.72
295109	WESTBROOK E	7.0
295111	SUBLETTE E	3.24
296125	R-030 C3	5.08
296128	R-030 E3	20.34
296271	R-030 C2	5.02
296272	R-030 E2	20.09
296308	R-030 C1	5.02
296309	R-030 E1	20.09
910542	X3-005 E	0.91
914641	Y2-103	56.19
915011	Y3-013 1	4.68

Bus #	Bus	MW Impact
915021	Y3-013 2	4.68
915031	Y3-013 3	4.68
916211	Z1-072 E	6.11
916221	Z1-073 E	6.75
916502	Z1-106 E1	1.58
916504	Z1-106 E2	1.58
916512	Z1-107 E	3.23
916522	Z1-108 E	3.11
917502	Z2-087 E	26.28
918052	AA1-018 E	20.57
919221	AA1-146	22.0
919581	AA2-030	22.0
920272	AA2-123 E	3.06
924041	AB2-047 C O1	4.85
924042	AB2-047 E O1	32.43
924471	AB2-096	52.94
925161	AB2-173	3.92
925302	AB2-191 E	1.73
925881	AC1-067 O1	172.23
926311	AC1-109 1	2.39
926321	AC1-109 2	2.39
926331	AC1-110 1	2.37
926341	AC1-110 2	2.37
926351	AC1-111 1	0.96
926361	AC1-111 2	0.96
926371	AC1-111 3	0.96
926381	AC1-111 4	0.96
926391	AC1-111 5	0.96
926401	AC1-111 6	0.96
926431	AC1-114	2.97
926821	AC1-168 C O1	1.46
926822	AC1-168 E O1	9.79
927091	AC1-204 1	90.83
927101	AC1-204 2	90.83
927201	AC1-214 C O1	2.59
927202	AC1-214 E O1	8.24
927451	AC1-142A 1	5.23
927461	AC1-142A 2	5.23
927511	AC1-113 1	1.49
927521	AC1-113 2	1.49
927531	AC1-185 1	0.86
927541	AC1-185 2	0.86
927551	AC1-185 3	0.86
927561	AC1-185 4	0.86
927571	AC1-185 5	0.86
927581	AC1-185 6	0.86
927591	AC1-185 7	0.86
927601	AC1-185 8	0.86
930481	AB1-089	82.21
930501	AB1-091 O1	95.92
930741	AB1-122 1O1	91.25
930751	AB1-122 2O1	92.24

Bus #	Bus	MW Impact
932881	AC2-115 1	2.97
932891	AC2-115 2	2.97
932921	AC2-116	1.04
932931	AC2-117	6.67
933341	AC2-147 C	1.09
933342	AC2-147 E	1.78
933411	AC2-154 C	3.27
933412	AC2-154 E	5.34
933431	AC2-156 C O1	1.2
933432	AC2-156 E O1	1.95
933911	AD1-013 C	2.3
933912	AD1-013 E	3.68
933931	AD1-016 C	1.16
933932	AD1-016 E	1.89
934101	AD1-039 1	8.94
934111	AD1-039 2	9.04
934401	AD1-064 C O1	4.01
934402	AD1-064 E O1	18.76
934431	AD1-067 C	0.16
934432	AD1-067 E	0.69
934651	AD1-096 C	1.11
934652	AD1-096 E	1.82
934701	AD1-098 C O1	8.6
934702	AD1-098 E O1	6.28
934721	AD1-100 C	30.02
934722	AD1-100 E	140.09
934871	AD1-116 C	1.2
934872	AD1-116 E	1.95
934881	AD1-117 C	6.72
934882	AD1-117 E	4.48
934971	AD1-129 C	1.13
934972	AD1-129 E	0.75
935001	AD1-133 C O1	27.99
935002	AD1-133 E O1	18.66
936291	AD2-038 C O1	2.94
936292	AD2-038 E O1	19.7
936371	AD2-047 C O1	2.93
936372	AD2-047 E O1	31.51
936461	AD2-060	3.44
936511	AD2-066 C O1	10.58
936512	AD2-066 E O1	7.05
936781	AD2-101 C	5.95
936782	AD2-101 E	27.88
936791	AD2-102 C	15.03
936792	AD2-102 E	14.44
936961	AD2-130	0.7
937001	AD2-134 C	3.42
937002	AD2-134 E	14.12
937031	AD2-137 C O1	7.31
937032	AD2-137 E O1	34.21
937051	AD2-140 C O1	7.67
937052	AD2-140 E O1	35.93

Bus #	Bus	MW Impact
937061	AD2-141 C O1	7.63
937062	AD2-141 E O1	35.97
937071	AD2-142 C O1	15.35
937072	AD2-142 E O1	71.86
937121	AD2-148 C O1	4.61
937122	AD2-148 E O1	21.57
937131	AD2-149 C O1	4.61
937132	AD2-149 E O1	21.57
937141	AD2-150 C O1	4.61
937142	AD2-150 E O1	21.57
937181	AD2-155 C O1	4.61
937182	AD2-155 E O1	21.57
937311	AD2-172 C	3.08
937312	AD2-172 E	4.25
937321	AD2-175 C	21.46
937322	AD2-175 E	14.31
937331	AD2-176 C O1	9.17
937332	AD2-176 E O1	6.11
937401	AD2-194 1	9.77
937411	AD2-194 2	9.77
938012	AE1-002 E O1	14.67
938511	AE1-070 1	11.48
938521	AE1-070 2	10.5
938851	AE1-113 C O1	10.93
938852	AE1-113 E O1	34.37
938861	AE1-114 C O1	4.47
938862	AE1-114 E O1	17.07
939051	AE1-134 1	1.71
939061	AE1-134 2	1.71
939321	AE1-163 C O1	7.36
939322	AE1-163 E O1	45.2
939351	AE1-166 C O1	14.82
939352	AE1-166 E O1	13.68
939401	AE1-172 C O1	9.71
939402	AE1-172 E O1	45.45
939691	AE1-199	2.99
939701	AE1-201 C	2.51
939702	AE1-201 E	0.55
939732	AE1-204 E	0.37
939741	AE1-205 C O1	12.73
939742	AE1-205 E O1	17.58
939861	AE1-222 1	100.77
939871	AE1-222 2	101.86
939921	AE1-228 C O1	12.57
939922	AE1-228 E O1	8.38
939961	AE1-233 C O1	2.91
939962	AE1-233 E O1	12.02
940101	AE1-252 C O1	15.49
940102	AE1-252 E O1	10.33
AB2-013	AB2-013	20.27
AE1-033	AE1-033	22.58
BLUEG	BLUEG	8.03

Bus #	Bus	MW Impact
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.98
CATAWBA	CATAWBA	0.39
CBM-S1	CBM-S1	1.88
CBM-W1	CBM-W1	38.11
CBM-W2	CBM-W2	72.48
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.96
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.75
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.49
MEC	MEC	47.56
O-066	O-066	9.26
RENSSELAER	RENSSELAER	0.77
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.96
WEC	WEC	9.96
Z1-043	Z1-043	36.25

Index 19

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
468425	346809	7CASEY	AMIL	247712	05SULLIVAN	AEP	1	AEP_P4_#3128_05EUGENE 345_A2	breaker	1466.0	143.62	144.34	DC	22.83

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	6.24
274650	KINCAID ;1U	14.71
274651	KINCAID ;2U	14.73
274832	U4-027	8.54
274853	TWINGROVE;U1	0.74
274854	TWINGROVE;U2	0.74
274859	EASYR;U1 E	6.8
274860	EASYR;U2 E	6.8
274890	CAYUG;1U E	10.14
274891	CAYUG;2U E	10.14
276150	W2-048 E	2.05
290021	O50 E	10.78
290051	GSG-6; E	5.68
290108	LEEDK;1U E	12.4
290261	S-027 E	19.36
290265	S-028 E	19.36
293516	O-009 E1	6.47
293517	O-009 E2	3.29
293518	O-009 E3	3.62
293644	O22 E1	4.9
293645	O22 E2	9.51
293715	O-029 E	6.65
293716	O-029 E	3.65
293717	O-029 E	3.35
293771	O-035 E	5.18
294401	BSHIL;1U E	7.08
294410	BSHIL;2U E	7.08
294763	P-046 E	5.38
295109	WESTBROOK E	3.04
295111	SUBLETTE E	1.65
296125	R-030 C3	3.34
296128	R-030 E3	13.34
296271	R-030 C2	3.3
296272	R-030 E2	13.18
296308	R-030 C1	3.3
296309	R-030 E1	13.18
905081	W4-005 C	0.98
905082	W4-005 E	42.62
909052	X2-022 E	28.51
916211	Z1-072 E	3.92
916221	Z1-073 E	2.93

Bus #	Bus	MW Impact
917502	Z2-087 E	17.32
918052	AA1-018 E	7.91
919221	AA1-146	11.65
919581	AA2-030	11.65
919621	AA2-039 C	1.73
919622	AA2-039 E	11.55
920272	AA2-123 E	1.22
924041	AB2-047 C O1	3.3
924042	AB2-047 E O1	22.1
924261	AB2-070 C O1	3.84
924262	AB2-070 E O1	25.68
924471	AB2-096	21.83
925161	AB2-173	2.08
925302	AB2-191 E	0.75
925581	AC1-033 C	1.16
925582	AC1-033 E	7.76
925771	AC1-053 C	3.87
925772	AC1-053 E	25.93
926431	AC1-114	1.3
926821	AC1-168 C O1	0.83
926822	AC1-168 E O1	5.54
926841	AC1-171 C O1	1.14
926842	AC1-171 E O1	7.61
927201	AC1-214 C O1	1.66
927202	AC1-214 E O1	5.29
927511	AC1-113 1	0.65
927521	AC1-113 2	0.65
927531	AC1-185 1	0.43
927541	AC1-185 2	0.43
927551	AC1-185 3	0.43
927561	AC1-185 4	0.43
927571	AC1-185 5	0.43
927581	AC1-185 6	0.43
927591	AC1-185 7	0.43
927601	AC1-185 8	0.43
930481	AB1-089	35.32
930741	AB1-122 1O1	34.94
932881	AC2-115 1	1.3
932891	AC2-115 2	1.3
932921	AC2-116	0.45
933341	AC2-147 C	0.54
933342	AC2-147 E	0.88
933911	AD1-013 C	0.99
933912	AD1-013 E	1.59
933931	AD1-016 C	0.46
933932	AD1-016 E	0.76
934051	AD1-031 C O1	2.35
934052	AD1-031 E O1	3.84
934101	AD1-039 1	3.42
934401	AD1-064 C O1	1.64
934402	AD1-064 E O1	7.66
934431	AD1-067 C	0.07

Bus #	Bus	MW Impact
934432	AD1-067 E	0.3
934651	AD1-096 C	0.51
934652	AD1-096 E	0.83
934701	AD1-098 C O1	3.77
934702	AD1-098 E O1	2.75
934871	AD1-116 C	0.46
934872	AD1-116 E	0.75
934881	AD1-117 C	3.31
934882	AD1-117 E	2.21
934971	AD1-129 C	0.47
934972	AD1-129 E	0.31
935001	AD1-133 C O1	14.12
935002	AD1-133 E O1	9.41
935141	AD1-148	7.45
936291	AD2-038 C O1	1.34
936292	AD2-038 E O1	8.98
936511	AD2-066 C O1	4.76
936512	AD2-066 E O1	3.17
936771	AD2-100 C O1	21.12
936772	AD2-100 E O1	14.08
936791	AD2-102 C	6.72
936792	AD2-102 E	6.46
936972	AD2-131 E O1	8.38
937001	AD2-134 C	1.48
937002	AD2-134 E	6.13
937161	AD2-153 C O1	3.2
937162	AD2-153 E O1	15.0
937171	AD2-154 C O1	3.2
937172	AD2-154 E O1	15.0
937211	AD2-159 C	4.61
937212	AD2-159 E	21.56
937311	AD2-172 C	1.41
937312	AD2-172 E	1.95
937331	AD2-176 C O1	3.65
937332	AD2-176 E O1	2.44
937531	AD2-214 C	3.23
937532	AD2-214 E	1.52
938851	AE1-113 C O1	4.98
938852	AE1-113 E O1	15.67
938861	AE1-114 C O1	2.2
938862	AE1-114 E O1	8.42
939051	AE1-134 1	0.91
939061	AE1-134 2	0.91
939321	AE1-163 C O1	3.4
939322	AE1-163 E O1	20.86
939401	AE1-172 C O1	4.02
939402	AE1-172 E O1	18.81
939631	AE1-193 C O1	5.75
939632	AE1-193 E O1	38.49
939681	AE1-198 C O1	17.08
939682	AE1-198 E O1	14.51
939691	AE1-199	1.29

Bus #	Bus	MW Impact
939701	AE1-201 C	1.0
939702	AE1-201 E	0.22
939741	AE1-205 C O1	8.33
939742	AE1-205 E O1	11.5
939861	AE1-222 1	38.59
939921	AE1-228 C O1	5.41
939922	AE1-228 E O1	3.61
939961	AE1-233 C O1	1.15
939962	AE1-233 E O1	4.76
940101	AE1-252 C O1	7.6
940102	AE1-252 E O1	5.07
950291	J291	3.2
950701	J196 C	1.33
950702	J196 E	5.3
951001	J339	6.03
951741	J474 C	2.02
951742	J474 E	10.95
952251	J641	10.35
952271	J644	9.57
952321	J734	5.07
952651	J756 C	2.46
952652	J756 E	13.33
952871	J757 C	4.06
952872	J757 E	21.98
953241	J467 C	2.76
953242	J467 E	14.91
953371	J808	9.06
953401	J811	17.76
953431	J853	11.11
953641	J813	43.81
953651	J815	32.11
953671	J817	10.67
953741	J826 C	1.65
953742	J826 E	8.94
953801	J835 C	2.68
953802	J835 E	14.48
953851	J845 C	1.72
953852	J845 E	9.32
953881	J848 C	5.27
953882	J848 E	28.51
953951	J859	9.79
954081	J872 C	4.44
954082	J872 E	24.03
954181	J884	7.67
954411	J912	14.24
954681	J949	38.92
954721	J750 C	2.11
954722	J750 E	11.4
954761	J468 C	7.08
954762	J468 E	28.32
990901	L-005 E	11.18
AB2-013	AB2-013	13.3

Bus #	Bus	MW Impact
AE1-033	AE1-033	10.55
AE1-042	AE1-042	10.08
BLUEG	BLUEG	10.38
CARR	CARR	0.29
CBM-S1	CBM-S1	13.17
CBM-S2	CBM-S2	2.35
CBM-W1	CBM-W1	28.23
CBM-W2	CBM-W2	199.79
CIN	CIN	3.85
CPL	CPL	0.56
DEARBORN	DEARBORN	0.69
G-007	G-007	0.8
GIBSON	GIBSON	0.02
MEC	MEC	45.61
O-066	O-066	2.69
RENSSELAER	RENSSELAER	0.23
TRIMBLE	TRIMBLE	1.31
WEC	WEC	4.13
Z1-043	Z1-043	21.97

Index 20

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
468898	932800	AC2-104 TAP	AEP	242928	05MARYSV	AEP	1	AEP_P4_#7334_05JEFRSO 765_A2	breaker	4571.0	103.34	103.44	DC	75.35

Bus #	Bus	MW Impact
243440	05CKG1	42.14
243441	05CKG2	52.39
246397	05ELKHART HY	1.01
246416	05TWIN BRCH1	0.2
246422	05MAYFLWER	0.26
246431	05BUCHANAN	1.1
246536	05MOTTVILL	0.42
247643	Z2-116 C	0.05
247906	05MDL-1G E	39.75
247907	05MDL-2G E	19.72
247912	05MDL-3G E	20.61
247913	05MDL-4G E	19.91
247943	T-127 E	19.91
247969	Z2-116 E	0.35
274722	S-055 E	22.69
274774	LINCOLN ;5U	3.14
274775	LINCOLN ;6U	3.14
274776	LINCOLN ;7U	3.14
274777	LINCOLN ;8U	3.14
274888	PILOT HIL;1E	36.41
275149	KEMPTON ;1E	36.41
290021	O50 E	30.98
290108	LEEDK;1U E	49.86
293061	N-015 E	30.86
293644	O22 E1	20.61
293645	O22 E2	40.01
294392	P-010 E	39.19
909145	X2-052	28.34
910542	X3-005 E	1.47
914641	Y2-103	90.77
915011	Y3-013 1	7.56
915021	Y3-013 2	7.56
915031	Y3-013 3	7.56
916502	Z1-106 E1	2.55
916504	Z1-106 E2	2.55
916512	Z1-107 E	5.16
916522	Z1-108 E	5.04
917702	Z2-113 E	0.6
917711	Z2-114 C	0.1
917712	Z2-114 E	0.68

Bus #	Bus	MW Impact
918052	AA1-018 E	32.95
920211	AA2-116	268.49
920272	AA2-123 E	4.99
925881	AC1-067 O1	286.39
926311	AC1-109 1	3.84
926321	AC1-109 2	3.84
926331	AC1-110 1	3.82
926341	AC1-110 2	3.82
926351	AC1-111 1	1.54
926361	AC1-111 2	1.54
926371	AC1-111 3	1.54
926381	AC1-111 4	1.54
926391	AC1-111 5	1.54
926401	AC1-111 6	1.54
926581	AC1-141	24.58
927091	AC1-204 1	143.52
927101	AC1-204 2	143.52
927451	AC1-142A 1	8.26
927461	AC1-142A 2	8.26
930042	AB1-006 E	43.31
930391	AB1-080	1.68
930501	AB1-091 O1	143.18
930741	AB1-122 1O1	146.79
930751	AB1-122 2O1	147.02
932601	AC2-080 C O1	6.66
932602	AC2-080 E O1	44.56
932801	AC2-104 C	35.99
932802	AC2-104 E	240.86
932931	AC2-117	12.03
933281	AC2-140 C	11.31
933282	AC2-140 E	0.6
933411	AC2-154 C	4.94
933412	AC2-154 E	8.06
933431	AC2-156 C O1	1.94
933432	AC2-156 E O1	3.16
933931	AD1-016 C	1.9
933932	AD1-016 E	3.09
934101	AD1-039 1	14.39
934111	AD1-039 2	14.41
934721	AD1-100 C	38.86
934722	AD1-100 E	181.34
934771	AD1-104 C	29.01
934772	AD1-104 E	194.13
934871	AD1-116 C	1.92
934872	AD1-116 E	3.13
935001	AD1-133 C O1	44.87
935002	AD1-133 E O1	29.91
936141	AD2-020 C O1	16.34
936142	AD2-020 E O1	10.06
936371	AD2-047 C O1	4.42
936372	AD2-047 E O1	47.59
936461	AD2-060	5.2

Bus #	Bus	MW Impact
936511	AD2-066 C O1	17.37
936512	AD2-066 E O1	11.58
936631	AD2-079 C O1	3.23
936632	AD2-079 E O1	2.15
936781	AD2-101 C	9.18
936782	AD2-101 E	43.0
936961	AD2-130	1.11
936981	AD2-132 C	9.01
936982	AD2-132 E	42.2
937031	AD2-137 C O1	7.0
937032	AD2-137 E O1	32.75
937041	AD2-138 C	9.01
937042	AD2-138 E	42.2
937051	AD2-140 C O1	7.03
937052	AD2-140 E O1	32.91
937061	AD2-141 C O1	6.99
937062	AD2-141 E O1	32.95
937071	AD2-142 C O1	14.06
937072	AD2-142 E O1	65.83
937121	AD2-148 C O1	6.87
937122	AD2-148 E O1	32.18
937131	AD2-149 C O1	6.87
937132	AD2-149 E O1	32.18
937141	AD2-150 C O1	6.87
937142	AD2-150 E O1	32.18
937181	AD2-155 C O1	6.87
937182	AD2-155 E O1	32.18
937321	AD2-175 C	32.02
937322	AD2-175 E	21.35
937331	AD2-176 C O1	14.97
937332	AD2-176 E O1	9.98
937401	AD2-194 1	15.43
937411	AD2-194 2	15.43
938012	AE1-002 E O1	14.04
938261	AE1-039	0.21
938511	AE1-070 1	18.13
938521	AE1-070 2	16.59
938671	AE1-089 C	36.65
938672	AE1-089 E	50.31
939351	AE1-166 C O1	20.24
939352	AE1-166 E O1	18.68
939391	AE1-170 C O1	16.87
939392	AE1-170 E O1	23.3
939401	AE1-172 C O1	13.26
939402	AE1-172 E O1	62.09
939641	AE1-194 C	17.06
939642	AE1-194 E	114.19
939651	AE1-195 C	17.06
939652	AE1-195 E	114.19
939701	AE1-201 C	4.09
939702	AE1-201 E	0.9
939732	AE1-204 E	0.59

Bus #	Bus	MW Impact
939861	AE1-222 1	162.11
939871	AE1-222 2	162.36
939961	AE1-233 C O1	4.76
939962	AE1-233 E O1	19.65
AB2-013	AB2-013	35.55
AE1-033	AE1-033	37.8
AE1-042	AE1-042	10.86
CARR	CARR	2.36
CATAWBA	CATAWBA	0.63
CBM-S1	CBM-S1	20.07
CBM-W1	CBM-W1	112.29
CBM-W2	CBM-W2	293.15
CIN	CIN	39.78
G-007	G-007	6.85
HAMLET	HAMLET	2.77
IPL	IPL	24.98
LGEE	LGEE	4.88
MEC	MEC	92.49
MECS	MECS	52.19
O-066	O-066	23.05
RENSSELAER	RENSSELAER	1.87
WEC	WEC	16.38
Z1-043	Z1-043	62.52

Index 21

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
786511	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	COMED_P7_345-L17704AR-S_+_345-L17907TB-S-A	tower	1846.0	138.35	143.04	DC	86.71

Bus #	Bus	MW Impact
274654	BRAIDWOOD;1U	33.0
274655	BRAIDWOOD;2U	31.46
274660	LASCO STA;1U	20.77
274661	LASCO STA;2U	20.81
274847	GR RIDGE ;BU	0.46
274853	TWINGROVE;U1	0.88
274854	TWINGROVE;U2	0.88
274863	CAYUGA RI;1U	1.14
274864	CAYUGA RI;2U	1.14
274871	GR RIDGE ;2U	0.59
274881	PLEAS RDG;2U	0.94
274887	PILOT HIL;1U	0.94
274888	PILOT HIL;1E	24.62
274890	CAYUG;1U E	29.8
274891	CAYUG;2U E	29.8
275149	KEMPTON ;1E	24.62
276150	W2-048 E	1.36
290261	S-027 E	23.06
290265	S-028 E	23.06
293061	N-015 E	12.12
294392	P-010 E	15.39
296125	R-030 C3	5.9
296128	R-030 E3	23.58
296271	R-030 C2	5.83
296272	R-030 E2	23.3
296308	R-030 C1	5.83
296309	R-030 E1	23.3
905081	W4-005 C	0.86
905082	W4-005 E	37.37
909052	X2-022 E	18.92
917501	Z2-087 C	0.7
917502	Z2-087 E	30.46
924041	AB2-047 C O1	5.59
924042	AB2-047 E O1	37.43
924261	AB2-070 C O1	2.78
924262	AB2-070 E O1	18.6
925771	AC1-053 C	2.73
925772	AC1-053 E	18.26
925881	AC1-067 O1	219.35
926821	AC1-168 C O1	0.64

Bus #	Bus	MW Impact
926822	AC1-168 E O1	4.29
930501	AB1-091 O1	110.96
933411	AC2-154 C	3.34
933412	AC2-154 E	5.45
934721	AD1-100 C	48.31
934722	AD1-100 E	225.47
935001	AD1-133 C O1	18.1
935002	AD1-133 E O1	12.07
935141	AD1-148	4.94
936371	AD2-047 C O1	2.99
936372	AD2-047 E O1	32.19
936461	AD2-060	3.52
936771	AD2-100 C O1	10.55
936772	AD2-100 E O1	7.04
936781	AD2-101 C	7.11
936782	AD2-101 E	33.27
936972	AD2-131 E O1	2.22
937121	AD2-148 C O1	5.34
937122	AD2-148 E O1	25.01
937131	AD2-149 C O1	5.34
937132	AD2-149 E O1	25.01
937141	AD2-150 C O1	5.34
937142	AD2-150 E O1	25.01
937161	AD2-153 C O1	3.8
937162	AD2-153 E O1	17.78
937171	AD2-154 C O1	3.8
937172	AD2-154 E O1	17.78
937181	AD2-155 C O1	5.34
937182	AD2-155 E O1	25.01
937211	AD2-159 C	4.04
937212	AD2-159 E	18.9
937321	AD2-175 C	24.89
937322	AD2-175 E	16.59
938012	AE1-002 E O1	29.83
939351	AE1-166 C O1	20.52
939352	AE1-166 E O1	18.94
939401	AE1-172 C O1	15.26
939402	AE1-172 E O1	71.45
939741	AE1-205 C O1	14.83
939742	AE1-205 E O1	20.48
940101	AE1-252 C O1	22.35
940102	AE1-252 E O1	14.9
951741	J474 C	1.71
951742	J474 E	9.28
953741	J826 C	1.0
953742	J826 E	5.4
954181	J884	8.88
AB2-013	AB2-013	5.61
BLUEG	BLUEG	0.01
CARR	CARR	0.27
CBM-S1	CBM-S1	2.75
CBM-S2	CBM-S2	0.06

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	5.33
CBM-W2	CBM-W2	48.81
CIN	CIN	2.54
DEARBORN	DEARBORN	1.27
G-007	G-007	0.73
HAMLET	HAMLET	0.06
IPL	IPL	1.1
LGEE	LGEE	0.03
MEC	MEC	13.64
O-066	O-066	2.47
RENSSELAER	RENSSELAER	0.21
TRIMBLE	TRIMBLE	0.04
WEC	WEC	1.22
Z1-043	Z1-043	14.81

Index 22

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785809	935000	AD1-133 TAP	CE	270717	DRESDEN ; R	CE	1	COMED_P1-2_345-L11212_B-S-C-A	single	1528.0	108.1	109.71	DC	24.59

Bus #	Bus	MW Impact
274650	KINCAID ;1U	15.48
274651	KINCAID ;2U	15.51
274853	TWINGROVE;U1	2.3
274854	TWINGROVE;U2	2.3
274863	CAYUGA RI;1U	2.14
274864	CAYUGA RI;2U	2.14
900404	X3-028 C	78.36
905081	W4-005 C	2.19
917501	Z2-087 C	1.85
924041	AB2-047 C O1	14.84
924261	AB2-070 C O1	6.98
925771	AC1-053 C	6.83
926841	AC1-171 C O1	0.75
930461	AB1-087	28.73
930471	AB1-088	28.73
933441	AC2-157 C	3.97
935001	AD1-133 C O1	120.38
935141	AD1-148	12.29
936771	AD2-100 C O1	25.48
937161	AD2-153 C O1	9.91
937171	AD2-154 C O1	9.91
937211	AD2-159 C	10.33
939401	AE1-172 C O1	24.59
939741	AE1-205 C O1	39.11
940101	AE1-252 C O1	41.91
950701	J196 C	1.11
951001	J339	12.11
951741	J474 C	4.81
952271	J644	12.24
952321	J734	10.17
952651	J756 C	4.36
952871	J757 C	5.2
953241	J467 C	1.73
953401	J811	10.29
953651	J815	34.83
953741	J826 C	3.01
953801	J835 C	3.42
953851	J845 C	2.96
953881	J848 C	5.38
954081	J872 C	4.15

Bus #	Bus	MW Impact
954181	J884	24.98
954411	J912	13.29
954721	J750 C	3.3
954761	J468 C	3.94
AD2-098	AD2-098	0.45
AE1-042	AE1-042	5.79
CBM-N	CBM-N	0.66
CBM-S1	CBM-S1	9.87
CBM-S2	CBM-S2	3.13
CBM-W2	CBM-W2	111.77
CIN	CIN	10.82
CPL	CPL	1.12
DEARBORN	DEARBORN	0.52
EDWARDS	EDWARDS	0.05
G-007A	G-007A	2.18
IPL	IPL	5.9
LGEE	LGEE	1.65
MEC	MEC	2.66
NYISO	NYISO	2.85
O-066A	O-066A	1.01
TATANKA	TATANKA	0.42
VFT	VFT	5.85

Index 23

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
786485	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	COMED_P7_345-L17704AR-S_+_345-L17907TB-S-A	tower	1846.0	145.54	150.23	DC	86.71

Bus #	Bus	MW Impact
274654	BRAIDWOOD;1U	33.0
274655	BRAIDWOOD;2U	31.46
274660	LASCO STA;1U	20.77
274661	LASCO STA;2U	20.81
274847	GR RIDGE ;BU	0.46
274853	TWINGROVE;U1	0.88
274854	TWINGROVE;U2	0.88
274863	CAYUGA RI;1U	1.14
274864	CAYUGA RI;2U	1.14
274871	GR RIDGE ;2U	0.59
274881	PLEAS RDG;2U	0.94
274887	PILOT HIL;1U	0.94
274888	PILOT HIL;1E	24.62
274890	CAYUG;1U E	29.8
274891	CAYUG;2U E	29.8
275149	KEMPTON ;1E	24.62
276150	W2-048 E	1.36
290261	S-027 E	23.06
290265	S-028 E	23.06
293061	N-015 E	12.12
294392	P-010 E	15.39
296125	R-030 C3	5.9
296128	R-030 E3	23.58
296271	R-030 C2	5.83
296272	R-030 E2	23.3
296308	R-030 C1	5.83
296309	R-030 E1	23.3
905081	W4-005 C	0.86
905082	W4-005 E	37.37
909052	X2-022 E	18.92
917501	Z2-087 C	0.7
917502	Z2-087 E	30.46
924041	AB2-047 C O1	5.59
924042	AB2-047 E O1	37.43
924261	AB2-070 C O1	2.78
924262	AB2-070 E O1	18.6
925771	AC1-053 C	2.73
925772	AC1-053 E	18.26
925881	AC1-067 O1	219.35
930501	AB1-091 O1	110.96

Bus #	Bus	MW Impact
933411	AC2-154 C	3.34
933412	AC2-154 E	5.45
934721	AD1-100 C	48.31
934722	AD1-100 E	225.47
935001	AD1-133 C O1	18.1
935002	AD1-133 E O1	12.07
935141	AD1-148	4.94
936371	AD2-047 C O1	2.99
936372	AD2-047 E O1	32.19
936461	AD2-060	3.52
936771	AD2-100 C O1	10.55
936772	AD2-100 E O1	7.04
936781	AD2-101 C	7.11
936782	AD2-101 E	33.27
936972	AD2-131 E O1	2.22
937031	AD2-137 C O1	18.53
937032	AD2-137 E O1	86.74
937121	AD2-148 C O1	5.34
937122	AD2-148 E O1	25.01
937131	AD2-149 C O1	5.34
937132	AD2-149 E O1	25.01
937141	AD2-150 C O1	5.34
937142	AD2-150 E O1	25.01
937161	AD2-153 C O1	3.8
937162	AD2-153 E O1	17.78
937171	AD2-154 C O1	3.8
937172	AD2-154 E O1	17.78
937181	AD2-155 C O1	5.34
937182	AD2-155 E O1	25.01
937211	AD2-159 C	4.04
937212	AD2-159 E	18.9
937321	AD2-175 C	24.89
937322	AD2-175 E	16.59
938012	AE1-002 E O1	70.17
939351	AE1-166 C O1	20.52
939352	AE1-166 E O1	18.94
939401	AE1-172 C O1	15.26
939402	AE1-172 E O1	71.45
939741	AE1-205 C O1	14.83
939742	AE1-205 E O1	20.48
940101	AE1-252 C O1	22.35
940102	AE1-252 E O1	14.9
951741	J474 C	1.71
951742	J474 E	9.28
954181	J884	8.88
AB2-013	AB2-013	5.61
BLUEG	BLUEG	0.01
CARR	CARR	0.27
CBM-S1	CBM-S1	2.75
CBM-S2	CBM-S2	0.06
CBM-W1	CBM-W1	5.33
CBM-W2	CBM-W2	48.81

Bus #	Bus	MW Impact
CIN	CIN	2.54
DEARBORN	DEARBORN	1.27
G-007	G-007	0.73
HAMLET	HAMLET	0.06
IPL	IPL	1.1
LGEE	LGEE	0.03
MEC	MEC	13.64
O-066	O-066	2.47
RENSSELAER	RENSSELAER	0.21
TRIMBLE	TRIMBLE	0.04
WEC	WEC	1.22
Z1-043	Z1-043	14.81

Index 24

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
468587	938670	AE1-089 TAP	AEP	243219	05DUMONT	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	125.75	126.43	DC	21.09

Bus #	Bus	MW Impact
247900	05FR-11G E	6.85
247901	05FR-12G E	6.74
247902	05FR-21G E	7.2
247903	05FR-22G E	6.89
247904	05FR-3G E	13.96
247905	05FR-4G E	10.5
247906	05MDL-1G E	15.63
247907	05MDL-2G E	7.75
247912	05MDL-3G E	8.11
247913	05MDL-4G E	7.83
247943	T-127 E	7.83
270859	PWR VTR EC;R	7.11
274722	S-055 E	6.55
274809	UNIV PK N;5U	0.8
274811	UNIV PK N;7U	0.8
274812	UNIV PK N;8U	0.8
274814	UNIV PK N;0U	0.8
274815	UNIV PK N;XU	0.8
274888	PILOT HIL;1E	10.32
275149	KEMPTON ;1E	10.32
290021	O50 E	11.46
290051	GSG-6; E	6.16
290108	LEEDK;1U E	14.23
293061	N-015 E	8.96
293644	O22 E1	5.93
293645	O22 E2	11.51
294392	P-010 E	11.37
295109	WESTBROOK E	3.3
909145	X2-052	36.23
914641	Y2-103	26.18
915011	Y3-013 1	2.18
915021	Y3-013 2	2.18
915031	Y3-013 3	2.18
916221	Z1-073 E	3.18
916502	Z1-106 E1	0.73
916504	Z1-106 E2	0.73
916512	Z1-107 E	1.5
916522	Z1-108 E	1.45
917711	Z2-114 C	0.06
917712	Z2-114 E	0.4

Bus #	Bus	MW Impact
918052	AA1-018 E	9.8
920272	AA2-123 E	1.43
924471	AB2-096	24.87
925302	AB2-191 E	0.82
926311	AC1-109 1	1.1
926321	AC1-109 2	1.1
926331	AC1-110 1	1.1
926341	AC1-110 2	1.1
926351	AC1-111 1	0.44
926361	AC1-111 2	0.44
926371	AC1-111 3	0.44
926381	AC1-111 4	0.44
926391	AC1-111 5	0.44
926401	AC1-111 6	0.44
926431	AC1-114	1.4
927091	AC1-204 1	41.9
927101	AC1-204 2	41.91
927451	AC1-142A 1	2.42
927461	AC1-142A 2	2.42
927511	AC1-113 1	0.7
927521	AC1-113 2	0.7
930042	AB1-006 E	17.03
930391	AB1-080	2.15
930481	AB1-089	38.75
930501	AB1-091 O1	40.14
930741	AB1-122 1O1	41.99
930751	AB1-122 2O1	42.66
932601	AC2-080 C O1	3.72
932602	AC2-080 E O1	24.91
932881	AC2-115 1	1.4
932891	AC2-115 2	1.4
932921	AC2-116	0.49
932931	AC2-117	5.17
933411	AC2-154 C	1.4
933412	AC2-154 E	2.28
933431	AC2-156 C O1	0.55
933432	AC2-156 E O1	0.9
933911	AD1-013 C	1.08
933912	AD1-013 E	1.73
933931	AD1-016 C	0.54
933932	AD1-016 E	0.89
934101	AD1-039 1	4.12
934111	AD1-039 2	4.18
934401	AD1-064 C O1	1.88
934402	AD1-064 E O1	8.8
934431	AD1-067 C	0.08
934432	AD1-067 E	0.33
934701	AD1-098 C O1	4.06
934702	AD1-098 E O1	2.96
934721	AD1-100 C	11.12
934722	AD1-100 E	51.9
934871	AD1-116 C	0.57

Bus #	Bus	MW Impact
934872	AD1-116 E	0.93
934971	AD1-129 C	0.53
934972	AD1-129 E	0.35
935001	AD1-133 C O1	12.63
935002	AD1-133 E O1	8.42
935271	AD1-137 C	5.69
935272	AD1-137 E	38.05
936291	AD2-038 C O1	1.41
936292	AD2-038 E O1	9.44
936371	AD2-047 C O1	1.25
936372	AD2-047 E O1	13.49
936461	AD2-060	1.47
936511	AD2-066 C O1	4.99
936512	AD2-066 E O1	3.33
936781	AD2-101 C	2.48
936782	AD2-101 E	11.59
936961	AD2-130	0.32
936981	AD2-132 C	5.04
936982	AD2-132 E	23.6
937001	AD2-134 C	1.61
937002	AD2-134 E	6.66
937031	AD2-137 C O1	1.92
937032	AD2-137 E O1	9.0
937041	AD2-138 C	5.04
937042	AD2-138 E	23.6
937051	AD2-140 C O1	1.92
937052	AD2-140 E O1	8.99
937061	AD2-141 C O1	1.91
937062	AD2-141 E O1	9.0
937071	AD2-142 C O1	3.84
937072	AD2-142 E O1	17.98
937121	AD2-148 C O1	1.93
937122	AD2-148 E O1	9.02
937131	AD2-149 C O1	1.93
937132	AD2-149 E O1	9.02
937141	AD2-150 C O1	1.93
937142	AD2-150 E O1	9.02
937181	AD2-155 C O1	1.93
937182	AD2-155 E O1	9.02
937321	AD2-175 C	8.98
937322	AD2-175 E	5.98
937331	AD2-176 C O1	4.29
937332	AD2-176 E O1	2.86
937401	AD2-194 1	4.51
937411	AD2-194 2	4.51
938012	AE1-002 E O1	3.86
938511	AE1-070 1	5.29
938521	AE1-070 2	4.84
938671	AE1-089 C	74.55
938672	AE1-089 E	102.34
938851	AE1-113 C O1	5.24
938852	AE1-113 E O1	16.46

Bus #	Bus	MW Impact
939321	AE1-163 C O1	3.48
939322	AE1-163 E O1	21.35
939351	AE1-166 C O1	5.85
939352	AE1-166 E O1	5.4
939401	AE1-172 C O1	3.71
939402	AE1-172 E O1	17.38
939641	AE1-194 C	5.61
939642	AE1-194 E	37.52
939651	AE1-195 C	5.61
939652	AE1-195 E	37.52
939691	AE1-199	1.41
939701	AE1-201 C	1.17
939702	AE1-201 E	0.26
939732	AE1-204 E	0.17
939861	AE1-222 1	46.37
939871	AE1-222 2	47.11
939921	AE1-228 C O1	5.92
939922	AE1-228 E O1	3.95
939961	AE1-233 C O1	1.36
939962	AE1-233 E O1	5.62
AB2-013	AB2-013	10.01
AE1-033	AE1-033	10.77
CARR	CARR	0.59
CATAWBA	CATAWBA	0.05
CBM-S1	CBM-S1	4.6
CBM-W1	CBM-W1	19.73
CBM-W2	CBM-W2	68.15
CIN	CIN	7.05
DEARBORN	DEARBORN	1.82
G-007	G-007	1.64
HAMLET	HAMLET	0.34
IPL	IPL	3.28
LGEE	LGEE	0.73
MEC	MEC	25.32
O-066	O-066	5.54
RENSSELAER	RENSSELAER	0.47
WEC	WEC	4.7
Z1-043	Z1-043	17.65

Index 25

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
785766	939400	AE1-172 TAP	CE	934720	AD1-100 TAP	CE	1	COMED_P1-2_345-L8014____-S-B	single	1528.0	113.38	115.71	DC	35.5

Bus #	Bus	MW Impact
274650	KINCAID ;1U	17.25
274651	KINCAID ;2U	17.28
274853	TWINGROVE;U1	2.5
274854	TWINGROVE;U2	2.5
274863	CAYUGA RI;1U	2.82
274864	CAYUGA RI;2U	2.82
900404	X3-028 C	84.69
905081	W4-005 C	2.39
917501	Z2-087 C	2.01
924041	AB2-047 C O1	16.06
924261	AB2-070 C O1	7.65
925771	AC1-053 C	7.49
926841	AC1-171 C O1	0.96
930461	AB1-087	31.05
930471	AB1-088	31.05
933441	AC2-157 C	4.29
935001	AD1-133 C O1	90.83
935141	AD1-148	13.51
936771	AD2-100 C O1	28.25
937161	AD2-153 C O1	10.77
937171	AD2-154 C O1	10.77
937211	AD2-159 C	11.3
939401	AE1-172 C O1	35.5
939741	AE1-205 C O1	42.48
940101	AE1-252 C O1	55.08
950701	J196 C	1.14
951001	J339	12.81
951741	J474 C	5.17
952271	J644	13.59
952321	J734	10.76
952651	J756 C	4.83
952871	J757 C	5.78
953241	J467 C	1.82
953401	J811	10.88
953651	J815	37.45
953741	J826 C	3.19
953801	J835 C	3.81
953851	J845 C	3.12
953881	J848 C	5.76
954081	J872 C	4.43

Bus #	Bus	MW Impact
954181	J884	26.75
954411	J912	14.21
954721	J750 C	3.62
AD2-098	AD2-098	0.36
AE1-042	AE1-042	6.61
CBM-N	CBM-N	0.57
CBM-S1	CBM-S1	11.07
CBM-S2	CBM-S2	3.34
CBM-W2	CBM-W2	129.48
CIN	CIN	11.59
CPLE	CPLE	1.17
DEARBORN	DEARBORN	0.85
G-007A	G-007A	1.93
IPL	IPL	6.27
LGEE	LGEE	1.7
MEC	MEC	9.12
NYISO	NYISO	2.48
O-066A	O-066A	0.9
VFT	VFT	5.19

Affected Systems

MISO

MISO Impacts to be determined during later study phases (as applicable).

Contingency Name	Contingency Definition
COMED_P1-2_345-L11212_B-S-A	CONTINGENCY 'COMED_P1-2_345-L11212_B-S-A' TRIP BRANCH FROM BUS 270926 TO BUS 937030 CKT 1 / WILTO; B 345 AD2-137 TAP 345 END
AEP_P1-2_#8907	CONTINGENCY 'AEP_P1-2_#8907' OPEN BRANCH FROM BUS 247712 TO BUS 346809 CKT 1 / 247712 05SULLIVAN 345 346809 7CASEY 345 1 END
COMED_P4_112-65-BT3-4__	CONTINGENCY 'COMED_P4_112-65-BT3-4__' TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33 END
COMED_P1-2_765-L11216__-S	CONTINGENCY 'COMED_P1-2_765-L11216__-S' TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765 END
COMED_P4_023-65-BT2-3__	CONTINGENCY 'COMED_P4_023-65-BT2-3__' TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765 END
AEP_P1-2_#286	CONTINGENCY 'AEP_P1-2_#286' OPEN BRANCH FROM BUS 243221 TO BUS 348885 CKT 1 / 243221 05EUGENE 345 348885 7BUNSONVILLE 345 1 END
COMED_P7_345-L94507_B-S_+_345-L97008_R-S	CONTINGENCY 'COMED_P7_345-L94507_B-S_+_345-L97008_R-S' TRIP BRANCH FROM BUS 274750 TO BUS 255112 CKT 1 / CRETE;BP 345 17STJOHN 345 TRIP BRANCH FROM BUS 274804 TO BUS 243229 CKT 1 / UPNOR;RP 345 05OLIVE 345 END
COMED_P1-2_345-L11212_B-S-C-A	CONTINGENCY 'COMED_P1-2_345-L11212_B-S-C-A' TRIP BRANCH FROM BUS 934720 TO BUS 939400 CKT 1 / AD1-100 TAP 345 AE1-172 TAP 345 END
AEP_P4_#3128_05EUGENE 345_A2	CONTINGENCY 'AEP_P4_#3128_05EUGENE 345_A2' OPEN BRANCH FROM BUS 243221 TO BUS 249504 CKT 1 / 243221 05EUGENE 345 249504 08CAYSUB 345 1 OPEN BRANCH FROM BUS 243221 TO BUS 348885 CKT 1 / 243221 05EUGENE 345 348885 7BUNSONVILLE 345 1 END

Contingency Name	Contingency Definition
COMED_P7_345-L2001__B-S+_345-L2003__R-S	CONTINGENCY 'COMED_P7_345-L2001__B-S+_345-L2003__R-S' TRIP BRANCH FROM BUS 270670 TO BUS 270728 CKT 1 / BRAID; B 345 E FRA; B 345 TRIP BRANCH FROM BUS 270728 TO BUS 270766 CKT 1 / E FRA; B 345 GOODI;3B 345 TRIP BRANCH FROM BUS 270728 TO BUS 274750 CKT 1 / E FRA; B 345 CRETE;BP 345 TRIP BRANCH FROM BUS 270671 TO BUS 270729 CKT 1 / BRAID; R 345 E FRA; R 345 END
AEP_P4_#7334_05JEFRSO 765_A2	CONTINGENCY 'AEP_P4_#7334_05JEFRSO 765_A2' OPEN BRANCH FROM BUS 242924 TO BUS 243208 CKT 1 / 242924 05HANG R 765 243208 05JEFRSO 765 1 OPEN BRANCH FROM BUS 243208 TO BUS 242865 CKT 2 / 243208 05JEFRSO 765 242865 05JEFRSO 345 2 OPEN BRANCH FROM BUS 242865 TO BUS 248000 CKT Z1 / 242865 05JEFRSO 345 248000 06CLIFTY 345 Z1 END
COMED_P1-2_345-L8014__S-A	CONTINGENCY 'COMED_P1-2_345-L8014__S-A' TRIP BRANCH FROM BUS 270853 TO BUS 935000 CKT 1 / PONTIAC ; R 345 AD1-133 TAP 345 END
COMED_P4_023-65-BT4-5__	CONTINGENCY 'COMED_P4_023-65-BT4-5__' TRIP BRANCH FROM BUS 275168 TO BUS 270607 CKT 1 / COLLI;2M 345 COLLI; 765 TRIP BRANCH FROM BUS 275168 TO BUS 270697 CKT 1 / COLLI;2M 345 COLLI; R 345 TRIP BRANCH FROM BUS 275168 TO BUS 275268 CKT 1 / COLLI;2M 345 COLLI;2C 33 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 END
COMED_P1-2_345-L8014__S-B	CONTINGENCY 'COMED_P1-2_345-L8014__S-B' TRIP BRANCH FROM BUS 935000 TO BUS 270717 CKT 1 / AD1-133 TAP 345 DRESDEN ; R 345 END
COMED_P1-2_345-L1223_TR-S	CONTINGENCY 'COMED_P1-2_345-L1223_TR-S' TRIP BRANCH FROM BUS 270717 TO BUS 270731 CKT 1 / DRES; R 345 ELECT;4R 345 TRIP BRANCH FROM BUS 275180 TO BUS 270717 CKT 1 / DRES;3M 138 DRES; R 345 TRIP BRANCH FROM BUS 275180 TO BUS 271336 CKT 1 / DRES;3M 138 DRES; B 138 TRIP BRANCH FROM BUS 275180 TO BUS 275280 CKT 1 / DRES;3M 138 DRES;3C 34.5 END
COMED_P4_112-65-BT4-5__	CONTINGENCY 'COMED_P4_112-65-BT4-5__' TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33 END
COMED_P7_345-L6607__B-S+_345-L97008_R-S	CONTINGENCY 'COMED_P7_345-L6607__B-S+_345-L97008_R-S' TRIP BRANCH FROM BUS 270728 TO BUS 274750 CKT 1 / E FRANKFO; B 345 CRETE EC ;BP 345 TRIP BRANCH FROM BUS 274804 TO BUS 243229 CKT 1 / UNIV PK N;RP 345 05OLIVE 345 END
Base Case	

Contingency Name	Contingency Definition
AEP_P1-2_#695A	CONTINGENCY 'AEP_P1-2_#695A' OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1 END
COMED_P7_345-L17704AR-S+_345-L17907TB-S-A	CONTINGENCY 'COMED_P7_345-L17704AR-S+_345-L17907TB-S-A' TRIP BRANCH FROM BUS 270675 TO BUS 925880 CKT 1 / BURNHAM ;1R 345 AC1-067 TAP 345 TRIP BRANCH FROM BUS 270662 TO BUS 936780 CKT 1 / BLOOM ; B 345 AD2-101 TAP 345 TRIP BRANCH FROM BUS 270662 TO BUS 271098 TO BUS 275258 CKT 1 / BLOOM ; B 345 BLOOM ; B 138 BLOOM ;4C 34.5 END
COMED_P4_111-45-L1223T_	CONTINGENCY 'COMED_P4_111-45-L1223T_' TRIP BRANCH FROM BUS 270717 TO BUS 270731 CKT 1 / DRESDEN ; R 345 ELEC JUNC;4R 345 TRIP BRANCH FROM BUS 275180 TO BUS 270717 CKT 1 / DRESDEN ;3M 138 DRESDEN ; R 345 TRIP BRANCH FROM BUS 275180 TO BUS 271336 CKT 1 / DRESDEN ;3M 138 DRESDEN ; B 138 TRIP BRANCH FROM BUS 275180 TO BUS 275280 CKT 1 / DRESDEN ;3M 138 DRESDEN ;3C 34.5 DISCONNECT BUS 270731 / ELEC JUNC;4R 345 DISCONNECT BUS 275184 / ELEC JUNC;4M 138 END
AEP_P4_#8805_05OLIVE 345_D	CONTINGENCY 'AEP_P4_#8805_05OLIVE 345_D' OPEN BRANCH FROM BUS 243229 TO BUS 932600 CKT 1 / 243229 05OLIVE 345 932600 AC2-080 TAP 345 1 /* CONTINGENCY LINE ADDED FOR AE1 BUILD OPEN BRANCH FROM BUS 243229 TO BUS 274804 CKT 1 / 243229 05OLIVE 345 274804 UNIV PK N;RP 345 1 END
COMED_P4_112-65-BT2-3__	CONTINGENCY 'COMED_P4_112-65-BT2-3__' TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33 END
AEP_P4_#2978_05DUMONT 765_B	CONTINGENCY 'AEP_P4_#2978_05DUMONT 765_B' OPEN BRANCH FROM BUS 243206 TO BUS 243207 CKT 1 / 243206 05DUMONT 765 243207 05GRNTWN 765 1 OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1 END
COMED_P4_112-65-BT5-6__	CONTINGENCY 'COMED_P4_112-65-BT5-6__' TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33 END
AEP_P1-2_#697A	CONTINGENCY 'AEP_P1-2_#697A' OPEN BRANCH FROM BUS 243229 TO BUS 274804 CKT 1 / 243229 05OLIVE 345 274804 UNIV PK N;RP 345 1 END

Short Circuit

No issues identified.