



**Generation Interconnection  
Feasibility Study Report  
for  
Queue Project AE2-120  
GRAYMONT - ZION 46 KV  
12 MW Capacity / 20 MW Energy**

July, 2019

# Table Of Contents

1	Introduction.....	4
2	Preface.....	4
3	General.....	6
4	Point of Interconnection.....	7
4.1	Primary POI.....	7
5	Cost Summary.....	7
6	Transmission Owner Scope of Work.....	8
7	Attachment Facilities.....	8
8	Direct Connection Cost Estimate.....	8
9	Non-Direct Connection Cost Estimate.....	8
10	System Reinforcement Cost Estimate.....	9
11	Schedule.....	10
12	Transmission Owner Analysis.....	11
12.1	Power Flow Analysis.....	11
13	Interconnection Customer Requirements.....	12
13.1	System Protection.....	12
13.2	Compliance Issues and Interconnection Customer Requirements.....	12
13.3	Power Factor Requirements.....	13
14	Revenue Metering and SCADA Requirements.....	14
14.1	PJM Requirements.....	14
14.2	FE Requirements.....	14
15	Network Impacts.....	15
16	Generation Deliverability.....	17
17	Multiple Facility Contingency.....	17
18	Contribution to Previously Identified Overloads.....	17
19	Potential Congestion due to Local Energy Deliverability.....	17
20	System Reinforcements.....	18
21	Flow Gate Details.....	19
22	Affected Systems.....	21
22.1	LG&E.....	21
22.2	MISO.....	21

22.3 TVA.....21

22.4 Duke Energy Progress.....21

22.5 NYISO .....21

23 Contingency Descriptions.....22

24 Short Circuit.....24

25 Attachment 1 – One Line.....25

26 Attachment 2 – Project Location .....26

## 1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is West Penn Power Company (WPP- Part of Allegheny Power System, Inc. (APS)).

## 2 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully

refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model. The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

### 3 General

The Interconnection Customer (IC) has proposed a Solar generating facility located in Centre County, Pennsylvania. The installed facilities will have a total capability of 20 MW with 12 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is September 1, 2021. This study does not imply a Transmission Owner (TO) commitment to this in-service date.

<b>Queue Number</b>	<b>AE2-120</b>
<b>Project Name</b>	GRAYMONT - ZION 46 KV
<b>Interconnection Customer</b>	
<b>State</b>	PA
<b>County</b>	Centre
<b>Transmission Owner</b>	APS
<b>MFO</b>	20
<b>MWE</b>	20
<b>MWC</b>	12
<b>Fuel</b>	Solar
<b>Basecase Study Year</b>	2022

## 4 Point of Interconnection

### 4.1 Primary POI

The interconnection of the project at the Primary POI will be accomplished by tapping the Nittany – Stone Jct 46 kV line and constructing a one span tap. The transmission line tap will be located approximately 0.25 miles from Zion substation. The IC will be responsible for acquiring all easements, properties, and permits that may be required to construct both the new interconnection line tap and the associated attachment facilities. The project will also require non-direct connection upgrades at Nittany, Pleasant Gap and Milesburg substations.

Attachment 1 shows a one-line diagram of the proposed primary direct connection facilities for the AE2-120 generation project to connect to the FirstEnergy (“FE”) transmission system. Attachment 2 provides the proposed location for the point of interconnection. IC will be responsible for constructing all of the facilities on its side of the POI, including the attachment facilities which connect the generator to the FE transmission system’s direct connection facilities.

## 5 Cost Summary

The AE2-120 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$22,034
Direct Connection Network Upgrade	\$44,066
Non Direct Connection Network Upgrades	\$697,700
<b>Total Costs</b>	<b>\$763,800</b>

In addition, the AE2-120 project may be responsible for a contribution to the following costs:

Description	Total Cost
System Upgrades	\$1,500,000

Cost allocations for these upgrades will be provided in the System Impact Study Report.

## 6 Transmission Owner Scope of Work

The interconnection of the project at the Primary POI will be accomplished by tapping the Nittany – Stone Jct 46 kV line and constructing a one span tap. The transmission line tap will be located approximately 0.25 miles from Zion substation. The IC will be responsible for acquiring all easements, properties, and permits that may be required to construct both the new interconnection line tap and the associated attachment facilities. The project will also require non-direct connection upgrades at Nittany, Pleasant Gap and Milesburg substations.

## 7 Attachment Facilities

The total preliminary cost estimate for the Attachment Facility work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Install 46 kV tap switch and Provide Revenue Meter Package	\$22,034
<b>Total Direct Connection Facility Cost</b>	<b>\$22,034</b>

## 8 Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection Facility work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Tap the Milesburg – Stone Jct 46 kV Line and Install two 46 kV Line Switches	\$44,066
<b>Total Attachment Facility Cost</b>	<b>\$44,066</b>

## 9 Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Replace Line Relays at Nittany Substation	\$141,100
Replace Line Relays at Pleasant Gap Substation	\$190,100
Replace Line Relays at Milesburg Substation	\$366,500
<b>Total Non-Direct Connection Facility Cost</b>	<b>\$697,700</b>

## 10 System Reinforcement Cost Estimate

At the Primary POI, the AE2-120 project contributes to overloads on the FE transmission <100 kV system as shown below. The estimated cost of system reinforcements necessary to mitigate these overloads is \$1,500,000.

Contingency Description	Overloaded Element	Rating (MVA)	% Loading After AE2-120	Final % Loading	AE2-120 MW Contrib.	FE Comments/Reinforcements
Loss of Graymont – Marblehead and Loss of Nittany – Nittany 2 46 kV Lines	Beech Creek – Howard Jct 46 kV Line	30	77	116	7.3	Reconductor the Beech Creek – Howard Jct 46 kV Line

## 11 Schedule

Based on the scope of work for the Attachment Facilities and the Direct and Non-Direct Connection facilities, it is expected to take a minimum of 10 months after the signing of an Interconnection Construction Service Agreement to complete the installation. This includes the requirement for the IC to make a preliminary payment that compensates FE for the first three months of the engineering design work that is related to the construction of the interconnection substation. Full initial deposit will be required for Non-Direct Connection and System Reinforcement work. This assumes that there will be no environmental issues with any of the new properties associated with this project, that there will be no delays in acquiring the necessary permits for implementing the defined direct connection and network upgrades, and that all transmission system outages will be allowed when requested.

The schedule for the required Network Impact Reinforcements will be more clearly identified in future study phases. The estimate elapsed time to complete each of the required reinforcements is identified in the “System Reinforcements” section of the report.

## 12 Transmission Owner Analysis

### 12.1 Power Flow Analysis

At the Primary POI, the AE2-120 project contributes to overloads on the FE transmission <100 kV system as shown below. The estimated cost of system reinforcements necessary to mitigate these overloads is \$1,500,000.

Contingency Description	Overloaded Element	Rating (MVA)	% Loading After AE2-120	Final % Loading	AE2-120 MW Contrib.	FE Comments/Reinforcements
Loss of Graymont – Marblehead and Loss of Nittany – Nittany 2 46 kV Lines	Beech Creek – Howard Jct 46 kV Line	30	77	116	7.3	Reconductor the Beech Creek – Howard Jct 46 kV Line

## 13 Interconnection Customer Requirements

### 13.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>.

Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

The IC has requested a non-standard GSU transformer winding configuration. This transformer is in violation of section 14.2.6 of FE's "Requirements for Transmission Connected Facilities" document and will not be accepted. The GSU transformer must have a grounded wye connection on the high (utility) side and a delta connection on the low (generator) side.

### 13.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated 46 kV circuit breaker to protect the AE2-120 generator lead line. A single circuit breaker must be used to protect this line; if the project has several GSU transformers, the individual GSU transformer breakers cannot be used to protect this line.
2. The purchase and installation of the minimum required FE generation interconnection relaying and control facilities. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the FE Transmission System Control Center.
4. Compliance with the FE and PJM generator power factor and voltage control requirements.
5. The execution of a back-up service agreement to serve the customer load supplied from the AE2-120 generation project metering point when the units are out-of-service. This assumes the intent of the IC is to net the generation with the load.

The IC will also be required to meet all PJM, ReliabilityFirst, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and ReliabilityFirst audits.

Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the FE system.

### **13.3 Power Factor Requirements**

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the generator's terminals.

## 14 Revenue Metering and SCADA Requirements

### 14.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

### 14.2 FE Requirements

The IC will be required to comply with all FE revenue metering requirements for generation interconnection customers which can be found in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>

## 15 Network Impacts

The Queue Project AE2-120 was evaluated as a 20.0 MW (Capacity 12.0 MW) injection tapping the Zion to Graymont 46kV line in the APS area. Project AE2-120 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE2-120 was studied with a commercial probability of 53%. Potential network impacts were as follows:

# Summer Peak Load Flow

## 16 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

## 17 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

## 18 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

## 19 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

## 20 System Reinforcements

At the Primary POI, the AE2-120 project contributes to overloads on the FE transmission <100 kV system as shown below. The estimated cost of system reinforcements necessary to mitigate these overloads is \$1,500,000.

Contingency Description	Overloaded Element	Rating (MVA)	% Loading After AE2-120	Final % Loading	AE2-120 MW Contrib.	FE Comments/Reinforcements
Loss of Graymont – Marblehead and Loss of Nittany – Nittany 2 46 kV Lines	Beech Creek – Howard Jct 46 kV Line	30	77	116	7.3	Reconductor the Beech Creek – Howard Jct 46 kV Line

## 21 Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

None

—

# Affected Systems

## **22 Affected Systems**

### **22.1 LG&E**

LG&E Impacts to be determined during later study phases (as applicable).

### **22.2 MISO**

MISO Impacts to be determined during later study phases (as applicable).

### **22.3 TVA**

TVA Impacts to be determined during later study phases (as applicable).

### **22.4 Duke Energy Progress**

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

### **22.5 NYISO**

NYISO Impacts to be determined during later study phases (as applicable).

**23 Contingency Descriptions**

None

## Short Circuit

## 24 Short Circuit

The following Breakers are overduty:

None

**25 Attachment 1 – One Line**

**26 Attachment 2 – Project Location**