



**Generation Interconnection  
Feasibility Study Report  
for  
Queue Project AE2-237  
VERNON-SUGAR LOAF #2 115 KV  
21.4 MW Capacity / 107 MW Energy**

July, 2019

# Table of Contents

Introduction.....	4
Preface .....	4
General.....	6
Point of Interconnection.....	7
Primary POI.....	7
Secondary POI.....	7
Cost Summary .....	7
Transmission Owner Scope of Work.....	9
Attachment Facilities .....	9
Direct Connection Cost Estimate .....	10
Non-Direct Connection Cost Estimate .....	11
Schedule .....	12
Transmission Owner Analysis .....	13
Power Flow Analysis.....	13
Short Circuit Analysis .....	13
Stability Analysis .....	13
Interconnection Customer Requirements .....	14
System Protection .....	14
Compliance Issues and Interconnection Customer Requirements.....	14
Power Factor Requirements.....	15
Revenue Metering and SCADA Requirements.....	16
PJM Requirements.....	16
JCPL Requirements .....	16
Network Impacts – Primary Point of Interconnection.....	17
Generation Deliverability.....	19
Multiple Facility Contingency.....	19
Contribution to Previously Identified Overloads.....	19
Potential Congestion due to Local Energy Deliverability .....	19
System Reinforcements.....	20
Flow Gate Details.....	21
Contingency Descriptions .....	21

Short Circuit.....23

Network Impacts – Secondary Point of Interconnection.....24

Generation Deliverability.....26

Multiple Facility Contingency.....26

Contribution to Previously Identified Overloads.....26

Potential Congestion due to Local Energy Deliverability .....26

System Reinforcements.....27

Flow Gate Details.....28

    Contingency Descriptions .....28

Short Circuit.....30

Affected Systems.....32

    LG&E .....32

    MISO.....32

    TVA .....32

    Duke Energy Progress .....32

    NYISO.....32

Attachment 1 – One Line .....33

Attachment 2 – Project Location.....34

## Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Jersey Central Power & Light Company (JCPL).

## Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in

order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model. The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

## General

The Interconnection Customer (IC), has proposed a Storage generating facility located in Vernon, New Jersey. The installed facilities will have a total capability of **107 MW** with **21.4 MW** of this output being recognized by PJM as Capacity. The proposed in-service date for this project is **March 1, 2022**. **This study does not imply a Jersey Central Power & Light Company (JCPL) commitment to this in-service date.**

<b>Queue Number</b>	<b>AE2-237</b>
<b>Project Name</b>	<b>VERNON-SUGAR LOAF #2 115 kV</b>
<b>Interconnection Customer</b>	
<b>State</b>	New Jersey
<b>County</b>	Sussex
<b>Transmission Owner</b>	JCPL
<b>MFO</b>	107
<b>MWE</b>	107
<b>MWC</b>	21.4
<b>Fuel</b>	Storage
<b>Basecase Study Year</b>	2022

## Point of Interconnection

### Primary POI

The interconnection of the project at the Primary POI will be accomplished by constructing a new 115 kV three (3) breaker ring bus substation and looping the Vernon – Sugar Loaf #2 115 kV line into the new station. The new substation will be located approximately 4.9 miles from Vernon substation and approximately 10.8 miles from Sugar Loaf substation.

The primary direct connection of this project will be accomplished by building a new facility consisting of 125 kW inverters with solar panels. The project is a 121 MVA battery storage facility interconnecting along the Vernon to Sugar Loaf double circuit line. Battery arrays will connect to the new substation through 44-2.75 MVA inverters and a 115 kV PSU for a total of 44 battery arrays. The IC will be responsible for acquiring all easements, properties, and permits that may be required to construct both the new interconnection line tap and the associated attachment facilities. The project will also require non-direct connection upgrades at West Wharton substation.

Attachment 1 shows a one-line diagram of the proposed primary direct connection facilities for the AE2-237 generation project to connect to the FirstEnergy (“FE”) transmission system. Attachment 2 provides the proposed location for the point of interconnection. IC will be responsible for constructing all of the facilities on its side of the POI, including the attachment facilities which connect the generator to the FE transmission system’s direct connection facilities.

### Secondary POI

The interconnection of the project at a Secondary POI can be accomplished by constructing a new 115 kV three (3) breaker ring bus substation and looping the Vernon – Sugar Loaf #1 115 kV line 4.9 miles from Vernon substation and 10.8 miles from Sugar Loaf substation before the normally open (N.O.) point with the NYISO circuit. A full scope of work or estimated cost is not provided for the proposed Secondary POI.

## Cost Summary

The AE2-237 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$ 516,580
Direct Connection Network Upgrade	\$ 6,612,120
Non Direct Connection Network Upgrades	\$ 65,100
<b>Total Costs</b>	<b>\$ 7,193,800</b>

In addition, the AE2-237 project may be responsible for a contribution to the following costs

Description	Total Cost
-------------	------------

<b>System Upgrades</b>	\$	0
------------------------	----	---

Cost allocations for these upgrades will be provided in the System Impact Study Report.

The costs provided above exclude the Contribution in Aid of Construction (“CIAC”) Federal Income Tax Gross Up charge. If, at a future date, it is determined that the CIAC Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

The Feasibility Study is used to make a preliminary determination of the type and scope of Attachment Facilities, Local Upgrades, and Network Upgrades that will be necessary to accommodate the Interconnection Request and to provide the Interconnection Customer a preliminary estimate of the time that will be required to construct any necessary facilities and upgrades and the Interconnection Customer’s cost responsibility. The System Impact Study provides refined and comprehensive estimates of cost responsibility and construction lead times for new facilities and system upgrades. Facilities Studies will include, commensurate with the degree of engineering specificity as provided in the Facilities Study Agreement, good faith estimates of the cost, determined in accordance with Section 217 of the Tariff,

- (a) to be charged to each affected New Service Customer for the Facilities and System Upgrades that are necessary to accommodate this queue project;
- (b) the time required to complete detailed design and construction of the facilities and upgrades; and
- (c) a description of any site-specific environmental issues or requirements that could reasonably be anticipated to affect the cost or time required to complete construction of such facilities and upgrades.

The required Attachment Facilities and Direct and Non-Direct Connection work for the interconnection of the AE2-237 generation project to the FE Transmission System is detailed in the following sections. The associated one-line with the generation project Attachment Facilities and the Primary Direct and Non-Direct Connection facilities are shown in Attachment 1.

## Transmission Owner Scope of Work

The interconnection of the project at the Primary POI will be accomplished by constructing a new 115 kV three (3) breaker ring bus substation and looping the Vernon – Sugar Loaf #2 115 kV line into the new station. The transmission line loop will be located approximately 4.9 miles from Vernon substation and approximately 10.8 miles from Sugar Loaf substation.

## Attachment Facilities

To accommodate the proposed AE2-237 Project, JCPL will tap the Vernon – Sugarloaf #2 115 kV line to serve as the point of interconnection (“POI”). The IC will be responsible for acquiring all easements, properties and permits that may be required to construct the associated facilities.

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Install line exit take-off structure, foundations, disconnect switch and associated equipment at ring bus substation	\$ 516,580
<b>Total Attachment Facility Costs</b>	<b>\$ 516,580</b>

## Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Construct a three (3) breaker 115 kV ring bus for AE2-237 generator interconnection	\$ 4,649,220
Sugarloaf - West Wharton (J932) 115 kV line loop to new "Barrett" 115kV substation.	\$ 1,962,900
<b>Total Direct Connection Facility Costs</b>	<b>\$ 6,612,120</b>

Changes to the Sugarloaf - West Wharton (J932) line and the installation of a new 115 kV ring bus will need to be made at Barrett Substation to facilitate the interconnection of the new generation.

## Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Update relay settings for new ring bus at West Wharton SS	\$ 65,100
<b>Total Non-Direct Connection Facility Costs</b>	<b>\$ 65,100</b>

Remote relay and metering setting changes will need to be made at West Wharton Substation to facilitate the interconnection of the new generation.

## Schedule

Based on the scope of work for the Attachment Facilities and the Direct and Non-Direct Connection facilities, it is expected to take a minimum of **twenty-four (24)** months after the signing of an Interconnection Construction Service Agreement to complete the installation. This includes the requirement for the IC to make a preliminary payment that compensates FE for the first three months of the engineering design work that is related to the construction of the interconnection substation. This assumes that there will be no environmental issues with any of the new properties associated with this project, that there will be no delays in acquiring the necessary permits for implementing the defined direct connection and network upgrades, and that all transmission system outages will be allowed when requested.

The schedule for the required Network Impact Reinforcements will be more clearly identified in future study phases. The estimate elapsed time to complete each of the required reinforcements is identified in the “System Reinforcements” section of the report.

## Transmission Owner Analysis

### Power Flow Analysis

PJM performed a power flow analysis of the transmission system using a 2022 summer peak load flow model and the results were verified by FE. FE performed an analysis of its underlying transmission <100 kV system. The AE2-237 project did not contribute to any overloads on the FE transmission system.

### Short Circuit Analysis

PJM performed a short circuit analysis and the results were verified by FE. The connection of AE2-237 project to the system does not result in any newly overdutied circuit breakers on the FE transmission system and does not have a significant fault current contribution to existing overdutied circuit breakers

### Stability Analysis

PJM will complete a dynamic stability analysis, if necessary, as part of the System Impact Study. The results of this analysis will be reviewed by FE. Should stability concerns be identified in PJM's study, FE will develop appropriate system reinforcement(s) and included the estimated cost of any reinforcement(s) in FE's System Impact Study report.

## Interconnection Customer Requirements

### System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

The IC has requested a non-standard GSU transformer winding configuration. This transformer is in violation of section 14.2.6 of FE's "Requirements for Transmission Connected Facilities" document and will not be accepted. The GSU transformer must have a grounded wye connection on the high (utility) side and a delta connection on the low (generator) side.

### Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated 115kV circuit breaker to protect the AE2-237 generator lead line. A single circuit breaker must be used to protect this line; if the project has several GSU transformers, the individual GSU transformer breakers cannot be used to protect this line.
2. The purchase and installation of the minimum required FE generation interconnection relaying and control facilities. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the FE Transmission System Control Center.
4. Compliance with the FE and PJM generator power factor and voltage control requirements.
5. The execution of a back-up service agreement to serve the customer load supplied from the AE2-237 generation project metering point when the units are out-of-service. This assumes the intent of the IC is to net the generation with the load.

The IC will also be required to meet all PJM, ReliabilityFirst, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and ReliabilityFirst audits. Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the FE system.

## Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the FE transmission system.

## Revenue Metering and SCADA Requirements

### PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

### JCPL Requirements

The IC will be required to comply with all FE revenue metering requirements for generation interconnection customers which can be found in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>.

## Network Impacts – Primary Point of Interconnection

The Queue Project AE2-237 was evaluated as a 107 MW (Capacity 21.4 MW) injection tapping the Vernon to Sugarloaf 115kV #2 line in the JCPL area. Project AE2-237 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE2-237 was studied with a commercial probability of 53%. Potential network impacts were as follows:

# Summer Peak Load Flow

## Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

## Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

## Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

## Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
8471888	218307	ALDENE_2	PSE&G	218430	STANTER_1	PSE&G	1	PS_P1-2_G-2285/* ALDENE TO SPRINGFIELD ROAD	operation	558.0	102.29	103.08	DC	8.49
8471848	218332	KILMER_W	PSE&G	218334	LNELSN_W	PSE&G	1	Base Case	operation	523.0	106.47	107.07	DC	5.84

# System Reinforcements

None

## Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

## Contingency Descriptions

Contingency Name	Contingency Definition
Base Case	
PS_P1-2_G-2285/* ALDENE TO SPRINGFIELD ROAD	CONTINGENCY 'PS_P1-2_G-2285/* ALDENE TO SPRINGFIELD ROAD' DISCONNECT BUS 218345 /* ALDENE BUS SECTION 6 DISCONNECT BUS 216911 /* SPRINGFIELD RD BUS SECTION2 END

# Short Circuit

## Short Circuit

The following Breakers are overduty: None

## **Network Impacts – Secondary Point of Interconnection**

The Queue Project AE2-237 was evaluated as a 107 MW (Capacity 21.4 MW) injection on the Vernon – Sugar Loaf #1 115 kV line (before the N.O. point with NYISO circuit) in the JCPL area. Project AE2-237 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE2-237 was studied with a commercial probability of 53%. Potential network impacts were as follows:

# Summer Peak Load Flow

## Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None.

## Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None.

## Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None.

## Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
8471888	218307	ALDENE_2	PSE&G	218430	STANTER_1	PSE&G	1	PS_P1-2_G-2285/* ALDENE TO SPRINGFIELD ROAD	operation	558.0	102.29	103.08	DC	8.49
8471848	218332	KILMER_W	PSE&G	218334	LNELSN_W	PSE&G	1	Base Case	operation	523.0	103.06	103.66	DC	5.84

## System Reinforcements

System reinforcements were not considered for the secondary POI.

## Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gauge other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

## Contingency Descriptions

Contingency Name	Contingency Definition
Base Case	
PS_P1-2_G-2285/* ALDENE TO SPRINGFIELD ROAD	CONTINGENCY 'PS_P1-2_G-2285/* ALDENE TO SPRINGFIELD ROAD' DISCONNECT BUS 218345 /* ALDENE BUS SECTION 6 DISCONNECT BUS 216911 /* SPRINGFIELD RD BUS SECTION2 END

# Short Circuit

## Short Circuit

The following Breakers are overduty:

None.

# Affected Systems

## Affected Systems

### LG&E

LG&E Impacts to be determined during later study phases (as applicable).

### MISO

MISO Impacts to be determined during later study phases (as applicable).

### TVA

TVA Impacts to be determined during later study phases (as applicable).

### Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

### NYISO

NYISO Impacts to be determined during later study phases (as applicable).

## Attachment 1 – One Line

## Attachment 2 – Project Location